

**ERRATA SHEET  
 RESPONSE TO DEFICIENCIES IN  
 SCHEDULE F-3 ( FOR FERN PARK)  
 FOR  
 DOCKET NO. 920199-WS  
 VOLUME II  
 BOOK 11 OF 11**

REMOVE PAGE NOS.	ADD PAGE NOS.	RESPONDS TO DEFICIENCY NO.
--	133-1	PAGE 1, No. 3

**Case Nos. 1D98-0713 and 1D98-0727**

Florida Water Services Corporation vs. Florida Public Service Commission ("PSC");  
 Sugarmill Woods Civic Association, Inc. vs. Southern States Utilities, Inc. and the  
 PSC

vs. Joseph J. DeRouin, et al.

**PSC Docket No. 920199-WS**

DOCUMENT NUMBER-DATE

06388 JUN 17 1992

FPSC-RECORDS/REPORTING

**WATER TREATMENT PLANT DATA**

Company: SSU / Seminole / Fern Park

FPSC

Docket No. 920199-WS  
 Test Year Ended: 12/31/91

Schedule F-3  
 Page 1 of 1  
 Preparer: G. Morse

Explanation: Provide the following information for each water treatment plant. If the system has water plants that are interconnected, the data for these plants may be combined. All flow data must be obtained from the monthly operating reports (MORs) sent to the Department of Environmental Regulation.

		DATE	GPD
1.	Plant Capacity Reliable Plant Capacity with Largest Well Out of Service		372,960
	The hydraulic rated capacity. If different from that shown on the DER operating or construction permit, provide an explanation.		
2.	Maximum Day	09/20/91	71,000
	The single day with the highest pumpage rate for the test year. Explain, on a separate page, if fire flow, line-breaks or other unusual occurrences affected the flow this day. (There is no record of any unusual occurrences)		
3.	Five-Day Max Month	(1) 12/06/91	66,000
		(2) 12/21/91	66,000
		(3) 12/02/91	63,000
		(4) 12/27/91	60,000
		(5) 12/12/91	59,000
	The five days with the highest pumpage rate from the month with the highest pumpage rate during the test year. Explain, on a separate page, if fire flow, line-breaks or other unusual occurrences affected the flows on these days. (There is no record of any unusual occurrences)		
		AVERAGE	62,800
4.	Five-Day Max Year	(1) 09/20/91	71,000
		(2) 03/28/91	71,000
		(3) 03/29/91	71,000
		(4) 07/23/91	69,000
		(5) 12/06/91	66,000
	The five days with the highest pumpage rate from any one month in the test year. Provide an explanation if fire flow, line-breaks or other unusual occurrences affected the flows on these days. (There is no record of any unusual occurrences)		
		AVERAGE	69,600
5.	Average Daily Flow		49,833
6.	Required Fire Flow		0
	The standards will be those as set by the Insurance Service Organization or by a governmental agency ordinance. Provide documents to support this calculation.		