

DIRECT TESTIMONY OF TED L. BIDDY, P.E. / P.L.S.
BEFORE THE FLORIDA PUBLIC SERVICE COMMISSION
ON BEHALF OF THE
CITIZENS OF THE STATE OF FLORIDA
DOCKET NO. 950495-WS

Revised 5/3/96

DOCUMENT NUMBER-DATE
05081 MAY-6 1996
FPSC-RECORDS/REPORTING

1 Q. **WHAT IS YOUR NAME AND BUSINESS ADDRESS?**

2 A. My name is Ted L. Bidby. My business address is Baskerville-Donovan, Inc.
3 (BDI), 2878 Remington Green Circle, Tallahassee, Florida 32308.

4 Q. **BY WHOM ARE YOU EMPLOYED AND WHAT IS YOUR POSITION?**

5 A. I am Vice-President of Baskerville-Donovan, Inc. and Regional Manager of the
6 Tallahassee Office.

7 Q. **WHAT IS YOUR EDUCATIONAL BACKGROUND AND WORK
8 EXPERIENCE?**

9 A. I graduated from the Georgia Institute of Technology with a B.S. degree in Civil
10 Engineering in 1963. I am a registered professional engineer and land surveyor in
11 Florida, Georgia and Mississippi and several other states. Before joining BDI in
12 1991, I had operated my own civil engineering firm for 21 years. My areas of
13 expertise include civil engineering, structural engineering, sanitary engineering,
14 soils and foundation engineering and precise surveying. During my career, I have
15 designed and supervised the master planning, design and construction of thousands
16 of residential, commercial and industrial properties. My work has included: water
17 and wastewater design; roadway design; parking lot design; stormwater facilities
18 design; structural design; land surveys; and environmental permitting.

19 I have served as principal and chief designer for numerous utility projects.
20 Among my major water and wastewater facilities designs have been a 2,000 acre
21 development in Lake County, FL; a 1,200 acre development in Ocean Springs, MS;
22 a 4 mile water distribution system for Talquin Electric Cooperative, Inc. and a 320

1 lot subdivision in Leon County, FL.

2 **Q. WHAT ARE YOUR PROFESSIONAL AFFILIATIONS?**

3 A. I am a member of the Florida Engineering Society, National Society of Professional
4 Engineers, and Florida Society of Professional Land Surveyors.

5 **Q. HAVE YOU PREVIOUSLY TESTIFIED BEFORE THE FLORIDA PUBLIC
6 SERVICE COMMISSION (FPSC)?**

7 A. Yes. I have testified in the St. George Island Utilities, Ltd. case in Docket No.
8 940109-WU.

9 **Q. HAVE YOU PREVIOUSLY TESTIFIED BEFORE A STATE OR FEDERAL
10 COURT AS AN ENGINEERING EXPERT WITNESS?**

11 A. Yes, I have had numerous court appearances as an expert witness for cases
12 involving roadways, utilities, drainage, stormwater, water and wastewater facilities
13 designs.

14 **Q. HAVE YOU REVIEWED ANY RATE FILING DOCUMENTS FILED WITH
15 THE FLORIDA PUBLIC SERVICE COMMISSION REGARDING USED
16 AND USEFUL ANALYSIS AND OTHER ENGINEERING ISSUES?**

17 A. Yes, I have reviewed the FPSC staff final recommendations on engineering issues
18 for Docket No. 920733-WS and No. 900718-WU. Docket No. 920733-WS was
19 filed by the General Development Utilities, Inc. for its Silver Springs Shores
20 Division which has lime softening treatment facilities. Docket No. 900718-WU
21 was filed by Gulf Utility Company for its reverse osmosis plant expansion.

22 **Q. WHAT IS THE PURPOSE OF YOUR TESTIMONY?**

1 A. The purpose of my testimony is to provide comments on methods of used and
2 useful analysis used by Southern States Utilities, Inc. (SSU) for this rate increase
3 filing.

4 Q. WERE THE MATERIALS YOU ARE SPONSORING PREPARED BY YOU
5 OR BY PERSONS UNDER YOUR DIRECT SUPERVISION AND
6 CONTROL?

7 A. Yes, they were.

8 Q. DO YOU AGREE WITH THE MARGIN RESERVE PROPOSED BY SSU
9 FOR USED AND USEFUL CALCULATIONS?

10 A. No, I do not think margin reserve used by SSU in this rate filing is appropriate.
11 Besides the testimony provided by Witness Mr. Larkin, I have some comments to
12 add especially on 3 years and 5 years of margin reserve for water and wastewater
13 treatment facilities, respectively. Chapter 62-600.405, Florida Administrative Code
14 (F.A.C.) requires all wastewater utilities to submit capacity analysis reports (CAR)
15 to the Florida Department of Environmental Protection (FDEP) at different
16 conditions. The five year time frame mentioned in the rules is mainly used as the
17 interval for submitting a CAR. We should not translate that five year time frame
18 as the actual time required for new plant expansions. The rule is simply trying to
19 mandate wastewater treatment plant (WWTP) owners to prepare plans for possible
20 future expansion. The five year submittal will be reduced to annual update when
21 the permitted capacity will be equaled or exceeded within the next 10 years. The
22 utilities may have to expand WWTP quickly, it depends on how soon the flow is

1 anticipated to reach the permitted capacity. If the wastewater flow is not
2 anticipated to reach the permitted capacity within 10 years, on the other hand, the
3 utilities are only required to submit a CAR every 5 years and nothing else.

4 FDEP has no similar rules on water treatment facilities. The need for plant
5 expansion again is dependent upon when the future flow will reach existing
6 capacities. Sometimes it does not take a long time to increase capacity for water
7 treatment, such as adding a new well and filters. Therefore, the 3-year and 5-year
8 margin reserves requested by SSU are not justified or mandated by regulation.

9 In addition, a well planned phased development and plant expansion can
10 reduce and eventually eliminate the need of margin reserve. This is feasible and
11 can be done. The construction permit DC432-219274 of Marion Oaks WWTP is
12 a good example in this filing. In that permit, the 0.2 MGD Type I extended aeration
13 sewage treatment plant was permitted to expand in four phases to a 1.0 MGD plant.
14 Actually, the utility should have new customers or developers to pay for new plant
15 expansion through contribution or prepaid CIAC (contribution in aid of
16 construction) and other ways. Collection of these prepaid fees from future
17 customers should render a margin reserve allowance, paid by current customers, to
18 be unnecessary.

19 Under Florida conditions of tightening environmental regulation, increasing
20 water costs and water conservation concern, it is reasonable to believe that the
21 water consumption and wastewater generation of existing customers will not
22 increase. Therefore, the margin reserve requested by SSU is solely for new

1 customers. If the PSC allows margin reserve in the used and useful calculations,
2 then it will penalize existing customers by burdening them to pay extra cost for new
3 customers. Allowing margin reserve will further increase water and wastewater
4 rates to existing customers. High utility rates reduce the financial ability for
5 customers and will hinder future development. Therefore, the PSC should
6 eliminate margin reserve allowance in used and useful analysis. The utility should
7 recover the costs of plant addition from new customers or developers through other
8 measures.

9 **Q. DO YOU HAVE ANY COMMENTS ON THE FIRE FLOW**
10 **REQUIREMENT SOUTHERN STATES UTILITIES, INC. (SSU) APPLIED**
11 **IN USED AND USEFUL CALCULATIONS?**

12 **A.** Fire flow capacity should be included in used and useful calculation only if fire
13 flow provision was proven by sufficient fire flow test records. SSU did not provide
14 this information in the original filing, therefore, no fire flow was applied in my used
15 and useful calculation. However, OPC has request SSU to provide the fire flow test
16 information. Revised used and useful calculation will be submitted if SSU does
17 provide adequate information.

18 In the response to OPC Document Request No. 298, SSU provided fire flow
19 test records for seven water systems and appropriate fire flow allowance was
20 included in the revised Exhibit TLB-3 of used and useful calculations. Exhibit
21 TLB-3.1 summarizes fire flow records and adjustments of fire flow allowance.

22 Many components of a water distribution system dictate the delivery of fire

1 flow. They include high service pumps, distribution storage tanks (elevated or
2 ground) and water mains. Because of economic concerns, for many systems fire
3 flows are provided partially by high service pumps and partially by storage. See
4 Exhibit TLB-1 excerpted from AWWA M31 Manual for examples.

5 No fire flow should be applied to high service pumps, finished water storage
6 or water supply wells without confirming the fire fighting capability of each
7 system. Installing a fire hydrant in the distribution system does not guarantee the
8 required fire flow. As mentioned above SSU was asked to prove the fire flow
9 capability by providing fire flow test records. However, that information was not
10 available at the time of preparing this testimony. Therefore, no fire flow
11 requirement requested by SSU was included in my used and useful calculations in
12 Exhibit TLB-3. When fire flow test documentation becomes available, the used
13 and useful schedules may be revised and provided to the Commission.

14 If a system is not designed or proved to provide required fire flow, it is
15 dangerous and unfair to assume the fire flow requirement in used and useful
16 analysis. Residents and business owners are paying higher property insurance
17 premiums because of inadequate fire fighting provision. It is not cost effective to
18 use source of supply to meet instantaneous demands, such as peak hourly flows and
19 fire flows. Normally a small water system without storage tanks does not have the
20 capability for fire fighting.

21 In addition, AWWA Manual M31 Page 33 states "Generally, water system
22 components are out of service for short periods of time, so the probability of a

1 component being out of service when a fire occurs is low.Fortunately, fires that
2 severely stress a distribution system occur only a few times a year in large systems
3 and only once every few years in small systems. Therefore, the probability of a
4 major fire occurring while more than one water system component is out of service
5 is so low that the utility should not be expected to meet required fire flow at such
6 times."

7 **Q. SSU REQUESTED A 12.5% COMPANY-WIDE LEVEL OF**
8 **UNACCOUNTED FOR WATER. DO YOU AGREE WITH THIS**
9 **REQUEST?**

10 A. No. A company-wide unaccounted for water percentage can not represent actual
11 unaccounted for water level of each system. Some systems with high levels of
12 unaccounted for water, like Oak Forest, St. Johns Highlands, and Stone Mountain,
13 are averaged out by large numbers of low unaccounted for water systems.
14 Therefore, the company-wide approach provides a shelter to high unaccounted for
15 water systems and does not encourage operation improvement. PSC should
16 evaluate the level of unaccounted for water on an individual basis. To achieve low
17 levels of unaccounted for water, PSC should allow no more than 10% for each
18 water system. Proper adjustments have been made in Exhibit TLB-3 water system
19 used and useful calculations, to account for excess unaccounted for water.

20 **Q. DO YOU RECOMMEND THAT A SINGLE MAXIMUM DAY FLOW**
21 **SHOULD BE USED IN USED AND USEFUL CALCULATIONS?**

22 A. No, the single maximum day flows should not be used in used and useful

1 calculations in this filing. The single maximum day flows may include undetected
2 or unrecorded leaks, flushing and unusual usage, in addition to the PSC allowed
3 unaccounted for water. Normally, a water main leaks for days before detection and
4 that amount of water loss is hard to keep track of. Main breaks and line flushing
5 have similar situations because good records are hard to keep.

6 When engineers review historic flow data and evaluate for maximum daily
7 demands, any unusual and excessive uses of water should be excluded as provided
8 by AWWA M31, *Distribution System Requirement for Fire Protection*, on Page 16.
9 In this filing, SSU did not exclude any unusual and excessive water use for the
10 single maximum day flows. Therefore, an average of the five highest maximum
11 daily flows in the maximum month is justified and should be used for all used and
12 useful and engineering issues. This has been the policy historically used by the
13 Commission.

14 **Q. IS IT JUSTIFIED TO USE THE PERMITTED CAPACITIES IN**
15 **OPERATION PERMITS INSTEAD OF CONSTRUCTION PERMITS FOR**
16 **USED AND USEFUL CALCULATIONS?**

17 **A.** Normally the operation permit has the same capacity as construction permit for
18 each treatment facility. However, sometimes the same treatment facility has less
19 permit capacity in its operation permit than construction permit. For example, a
20 one MGD contact stabilization type sewage treatment plant could be rated at 0.5
21 MGD for operating in extended aeration treatment. The Beacon Hills WWTP
22 provides an actual example. According to FDEP permit number DO16-213087,

1 that facility is permitted as a 0.836 MGD extended aeration WWTP, which can also
2 be operated as a 1.78 MGD contact stabilization WWTP. I have adjusted the used
3 and useful calculation for the Beacon Hill wastewater treatment plant to reflect its
4 1.78 MGD capacity in Exhibit TLB-4. Adjustments would be appropriate for the
5 other systems if their plant capacities are similarly understated.

6 Therefore, construction permit capacities should be used unless the
7 operation permit has permanently changed the original permit capacities. This
8 question will not be an issue when SSU applies for permit renewals in the future.
9 According to the NPDES permit delegation from EPA, FDEP will combine the
10 construction and operation permits into one permit application.

11 **Q. IS IT REASONABLE TO USE "FIRM RELIABLE CAPACITIES" TO**
12 **CALCULATE USED AND USEFUL PERCENTAGES FOR SUPPLY**
13 **WELLS, HIGH SERVICE PUMPS AND WATER TREATMENT**
14 **FACILITIES?**

15 **A.** No, it is not justified to use firm reliable capacity on more than one component.
16 The firm reliable capacity is the total capacity of supply wells, high service pumps,
17 filters, or other treatment plant facilities without the largest unit in operation. That
18 largest unit is assumed to be out of service for routine maintenance or emergency
19 repair.

20 Most of the time, facilities are scheduled in advance to be out of service for
21 maintenance or repair. It is very unlikely that two facility components will be
22 scheduled for service at the same time. The chance of having two facility

1 breakdowns, simultaneously, is slim. Therefore, it is not economically justified to
2 calculate used and useful percentages for supply wells, water treatment facilities
3 and high service pumps all with "firm reliable capacity." Adjustments have been
4 made in my used and useful calculations in Exhibit TLB-3, based on the above
5 discussion.

6 **Q. DO YOU HAVE ANY COMMENTS ON WATER SUPPLY WELL USED**
7 **AND USEFUL CALCULATIONS PROPOSED BY SSU?**

8 A. SSU used so called "firm reliable capacity" in calculating used and useful
9 percentage for water supply wells. The firm reliable capacity excludes the largest
10 well capacity by assuming it to be out of service. When there are more than ten
11 wells, the largest two wells are assumed to be out of service. The combined
12 capacity of remaining supply wells is the "firm reliable capacity." If a system has
13 only supply wells and no storage facilities or high service pumps, then the well
14 pumps also serve as high service pumping facilities. For this type water system, the
15 "firm reliable capacity" proposed by SSU is acceptable.

16 However, when storage or high service pumping facilities are available, the
17 "firm reliable capacity" method is not applicable. According to Section 3.2.1.1
18 *Source capacity of Recommended Standards For Water Works:*

19 "The total developed groundwater source capacity shall equal or exceed the
20 design maximum day demand and equal or exceed the design average day demand
21 with the largest producing well out of service."

22 This design criteria should be used to calculate used and useful percentage

1 for supply wells. For the above reason, the "firm reliable capacity" method should
2 not be applied to supply wells where the water system is also equipped with storage
3 and high service pumping facilities. Adjustments have been made according to the
4 above principles in Exhibit TLB-3.

5 **Q. DO YOU HAVE ANY COMMENTS REGARDING USED AND USEFUL**
6 **CALCULATIONS OF THE FINISHED WATER STORAGE?**

7 A. The peak hour domestic demands calculations proposed by SSU is unjustified
8 without document support and clear explanation. SSU assumed the peak hour
9 demand is two times of the maximum day demand and the peak hour demand is
10 four hours long. AWWA M32, *Distribution Network Analysis for Water Utilities*,
11 suggests a peak factor range of 1.3 to 2.0 for peak-hour demand to maximum-day
12 demand. I believe 1.3 should be used because it is the minimum requirement.

13 In MFRs Volume VI Book 1 of 2 Pages 14 and 15, "maximum day gallons
14 pumped" was used instead of "maximum day gallons pumped/24 hours." The time
15 unit was omitted and an abnormal large storage for domestic peak hour demand will
16 be erroneously calculated. Though SSU did not make mistakes in this calculation,
17 it is better to clarify that the "maximum day gallons pumped" means "maximum
18 day gallons pumped within 24 hours" in the record. Normally to compute the
19 required peak hour storage, a mass diagram or hydrograph indicating the hourly rate
20 of consumption is required.

21 SSU requested an 8-hour emergency storage for large water systems,
22 including: Amelia Island, Burnt Store, Citrus Springs, Deltona Lakes, Lehigh,

1 Marco Shores, Marco Island, and Sugar Mill Country Club. Emergency storage is
2 not a design criteria in the *Recommended Standards for Water Works*. Just as
3 AWWA M32 stated, the amount of emergency storage is an owner option to be
4 included within a particular water system. It depends on an assessment of risk and
5 the desired degree of system dependability. Emergency storage is seldom included
6 in designs because of costs. SSU was unable to confirm the emergency storage in
7 the original plant design. Therefore, no emergency storage was applied in my used
8 and useful calculations.

9 SSU also requested ten percent of the total finished water storage to be
10 "dead storage" because of floor suction and vortexing effect. These concerns are
11 not true for all storage facilities, especially for elevated tanks. For ground storage
12 facilities, as-built drawings should be able to reveal the minimum operating level.
13 It is not justified to assume 10% of the storage capacity is dead storage for every
14 single storage tank. In addition, SSU has used more than 10% dead storage in the
15 used and useful calculations for most of the systems. Further, SSU provides no
16 supporting explanation to justify dead storage allowance for each storage tank.

17 When designing storage tanks and high service pumps, engineers have to
18 check the available net positive suction head (NPSH) and ensure that it is greater
19 than the net required positive suction head to avoid cavitation problems. Therefore,
20 the vortex situation is rare because high service pumps are always placed at a low
21 grade to obtain the maximum NPSH. Full storage tank capacity was applied in my
22 used and useful calculations, per Exhibit TLB-2 and Exhibit TLB-3.

1 Q. DO YOU HAVE ANY COMMENTS TO ADD ABOUT THE PROPOSED
2 HIGH SERVICE PUMPS USED AND USEFUL CALCULATIONS?

3 A. High service pumps are normally designed to handle maximum daily flows. Any
4 demands beyond maximum daily flows should be met by distribution storage tanks
5 (AWWA M32 P.41). Distribution storage means elevated storage tank or a ground
6 storage tank with booster pumps in the distribution system. Distribution storage is
7 a part of the finished water storage. Finished water storage usually means ground
8 storage tanks that store finished water to be supplied to high service pumps which
9 push the finished water to the distribution system. However, many water systems
10 have elevated storage tanks in addition to the ground storage tanks to meet the
11 system demands. According to SSU witness Mr. Bliss, Keystone Heights and
12 Lehigh are the only two water systems in this rate filing that have elevated storage
13 tanks. It is not cost effective to use high service pumps to handle peak hourly flows
14 and fire flows. If fire flows are provided by distribution storage, no fire flow
15 should be included in high service pump used and useful calculations. However,
16 SSU was unable to confirm whether fire flow is provided by elevated storage tanks
17 in Keystone Heights and Lehigh. For that reason fire flow demands will be applied
18 to high service pumps only when fire flow provision is properly proven.

19 A water system with no elevated distribution storage facilities is less cost
20 effective because both high service pumps and on site finished water storage need
21 to meet extra peak hourly demands above maximum daily flows or fire flows.
22 Without the capability of replenishing elevated storage, high service pumps need

1 to operate in a higher and wider range of pumping head. Therefore, the capital
2 costs are higher and less cost effective to operate, compared to water systems with
3 elevated storage tanks. During the peak demands, the elevated tank will first
4 provide water to the system and high service pumps will provide the remaining
5 excess water demands. For that reason a smaller high service pump can be used.
6 Examples in Exhibit TLB-1 clearly address these situations.

7 When distribution storage is not available, but the system is designed to
8 provide fire flows, engineers will size up high service pumps for fire flow
9 provision. However, the design flows used should be maximum day demands
10 (average 5 maximum days of maximum month) plus fire flows or peak hourly
11 demands, which ever is greater. This design criteria is used in AWWA M31
12 because the chance of having a fire outbreak during peak hourly demands is very
13 slim. Therefore, designing high service pumps to meet fire flows, plus peak hourly
14 flows, is not economically justified. Adjustments have been made in my used and
15 useful calculations in Exhibit TLB-3. See Exhibit TLB-2 for calculation key
16 summary.

17 **Q. DO YOU AGREE WITH THE 100% USED AND USEFUL REQUEST ON**
18 **FACILITY LANDS, HYDRO TANKS, AND AUXILIARY POWER?**

19 A. No, PSC should not grant 100% used and useful on facility lands, auxiliary power
20 and hydro tanks without individual analysis. Every system has different sizes of
21 facility lands, auxiliary power, and hydro tanks. The current demands and
22 available capacities are also unique between systems. These factors all dictate the

1 facility usage. Therefore, a used and useful calculation is really required for every
2 facility land, auxiliary power, and hydro tank. Adjustments should be made to the
3 used and useful percentages because all facility land, auxiliary power, and hydro
4 tank are part of the system, and they are designed to serve the whole system. The
5 higher the existing demand, the higher the used and useful percentage.

6 From the response to OPC Interrogatory No. 341, SSU stated that 50 water
7 and 11 wastewater systems have auxiliary power equipment. Unfortunately SSU
8 cannot specify what facilities are supported by each auxiliary power equipment.
9 Therefore, OPC has to assume that auxiliary power has the same used and useful
10 percentage as supply wells or wastewater treatment plants. Adjustments to
11 auxiliary power have been made in Exhibit TLB-3 and Exhibit TLB-4. See Exhibit
12 TLB-2 for calculation key and rationale summary. Marco Shores water system has
13 no supply wells, and the used and useful percentage of high service pumps was
14 used for auxiliary power equipment.

15 **Q. IS IT APPROPRIATE TO USE HYDRAULIC ANALYSIS IN**
16 **CALCULATING THE USED AND USEFUL PERCENTAGES OF WATER**
17 **TRANSMISSION AND DISTRIBUTION SYSTEMS?**

18 **A.** No, it is not appropriate to use hydraulic analysis modeling to calculate the used
19 and useful percentage for water transmission and distribution system. The
20 hydraulic analysis method indeed is a reliable design tool for designing water
21 transmission and distribution systems. However, it does not follow that hydraulic
22 analysis is also appropriate and applicable for the used and useful analysis in

1 economic regulations.

2 The used and useful analysis for a water transmission and distribution
3 system is not a flow measurement or flow projection technique. Used and useful
4 analysis is about allocating construction costs fairly to both existing and future
5 customers. Hydraulic analysis modeling proposed by SSU unfairly shifts the
6 majority of the cost burden to existing customers, especially in new or sparsely
7 developed areas. For example, in the same subdivision customers in densely
8 developed areas will have to pay for water mains which are less used in newly or
9 sparsely developed areas. The reason is that the distribution system will supply
10 water to high demands from densely developed areas through looped water mains
11 in sparsely developed areas. The fire flow provision also makes the water mains
12 in sparsely developed areas highly used and useful. It is the responsibility of
13 developers and utility owners to prevent scattered development. Utility owners
14 should bear the risk and costs of acquiring systems serving sparse developments.
15 Sunny Hills is a good example of the above conditions. The example below
16 illustrates the unfair used and useful determination because the flow measurement
17 technique utilized in a hydraulic analysis tends to inflate used and useful percentage
18 for sparsely developed systems.

19 Assume a water distribution system is designed to serve 1,000 single family
20 homes with a 750 gpm fire flow provision, and assume that the system currently
21 serves only 100 homes with 350 gallons per home average daily consumption.
22 Using peaking factors of 2 for maximum daily flows from average daily flows and

1 1.3 for peak hourly flows from maximum daily flows, the existing 100 homes will
2 be required to pay for 58.84% of the total water mains laid for 1,000 homes. See
3 the following calculation.

4 Used and useful % = $\frac{[(100 \times 350 \times 2 \times 1.3/1440) + 750]}{[(1000 \times 350 \times 2 \times 1.3/1440) + 750]} = 58.84\%$
5

6 This example clearly demonstrates that the hydraulic analysis method
7 unfairly allocates cost sharing between existing customers and future customers.
8 In the filing, SSU has requested a 28.09% used and useful on the Sunny Hills Well
9 5 transmission and distribution system. In that subdivision, only four customers are
10 connected to the system with a 491 lot capacity. Due to the inclusion of fire flow,
11 those customers who represent less than one percent of the system, are responsible
12 for 28.09% of the water mains cost. An economic regulatory agency like PSC
13 should not accept such a disparity created by hydraulic analysis methods. If PSC
14 accepts hydraulic analysis for used and useful calculations, future development will
15 be intimidated by highly inflated rates.

16 Hydraulic analysis modeling is too complicated and time consuming to
17 apply to water transmission and distribution used and useful analysis. Any change
18 in high service pumps, distribution storage, customer demands and water main size
19 will increase or decrease water flows in water pipes. For example, by using a larger
20 size high service pump for build out conditions, more water will pass through the
21 same water main. Therefore, a change in the system operating parameters will
22 create a different hydraulic analysis result. The build out flows presented by SSU

1 in the MFR's are not the ultimate capacities of the water mains, and they are subject
2 to change. For examples, a lot of "dry" water mains in the original "Deltona"
3 systems are not connected to existing distribution systems. Once the "dry" mains
4 are connected, the build out flow of each main will be changed. If PSC accepts the
5 use of hydraulic analysis, there will be numerous sets of used and useful
6 percentages, and it can unduly complicate the used and useful analysis.
7 Consequently customers will be paying more than their fair share on the water
8 transmission and distribution system.

9 In addition, to validate the hydraulic analysis computer model for an
10 existing distribution system, detailed calibrations are required, which includes
11 comparing system pressures with computer output and checking roughness
12 coefficient of water mains. A slight change on the roughness coefficient can affect
13 the results significantly. Calibrating a hydraulic model basically is a trial and error
14 process until the model prediction is close to field measurements. Trying to adopt
15 hydraulic modeling for used and useful analysis is not appropriate because of
16 complexity and time consumption. It is economically unfeasible for most utilities
17 to perform hydraulic modeling for rate increase filings. Due to numerous variables,
18 the enormous staff time required to verify hydraulic computer models is an
19 unnecessary burden for PSC.

20 On the other hand, the "lot count" method allocates the water main costs
21 evenly to all customers, after engineers have properly designed the whole system.
22 The lot count method assigns a fair share of the total construction cost to every

1 customer. The lot count method does not fail to recognize water main cost to
2 accommodate fire flow and looped lines, because it allocates the total cost through
3 used and useful percentages. Existing customers do not get a free ride because the
4 construction costs of fire flow accommodation and looped lines are included in the
5 total cost.

6 Water transmission and distribution systems are designed for all existing
7 and future customers. The hydraulic analysis method clearly tilts the burden to
8 existing customers. The lot count method tends to give an equal cost share to all
9 customers. Therefore, the lot count method will not discourage future development,
10 as opposed to the way hydraulic modeling will probably discourage future
11 development. For some instances, however, the lot count method still favors future
12 customers. For example, without future development, engineers would design a
13 smaller size system for existing customers. However, most of the time water
14 transmission and distribution mains are oversized for existing customers to
15 accommodate future phases of development. Lot count method does not reduce the
16 used and useful percentage for existing customers for the over sized mains.
17 Therefore, existing customers are carrying extra costs for laying larger sizes of
18 water mains that will be connected for future development. The burden on future
19 customers are therefore less than existing customers.

20 "Fill-in-lots" should not be a problem in the lot count method. When a
21 system is reaching built out, fill-in lots probably will be sold at appreciated values
22 and increase the used and useful percentages. A mass development without proper

1 phasing creates sparse development and scatters customers. Low used and useful
2 percentages of the water transmission and distribution are apparent and
3 unavoidable. Developers and utility owners should bear the risk for not preventing
4 sparse development from happening. Existing customers should not pay for the
5 consequence of low used and useful percentage on a water distribution system.
6 SSU should recover the cost of unused water mains by collecting contributions
7 from new customers. Adjustments have been made to appropriate systems in the
8 Exhibit TLB-3.

9 **Q. SHOULD RATE BASE INCLUDE WATER MAINS LAID IN THE**
10 **GROUND BUT NOT CONNECTED TO THE EXISTING DISTRIBUTION**
11 **SYSTEM?**

12 A. Any water mains constructed in place but which do not connect to the existing
13 system should be considered non-used and useful. Apparently those "dry" mains
14 are reserved for future customers. Any investment in these "dry" water mains
15 should be removed from rate base. When SSU provides the dollar investments in
16 these "dry" water mains, these amounts should be removed from rate base.

17 According to the Late Filed Deposition Exhibit No. 8 of Mr. Bliss, the
18 following dollar amounts should be removed from the rate base of each system:
19 \$913,386.25 from Citrus Spring; \$204,309.60 from Marion Oaks; \$45,144.00 from
20 Pine Ridge; and \$686,711.20 from Sunny Hills.

21 **Q. SHOULD EXCESS INFLOW AND INFILTRATION BE INCLUDED IN**
22 **ENGINEERING SCHEDULE F-2(S) GALLONS OF WASTEWATER**

1 **TREATED?**

2 A. No. The amount of wastewater treated should not include any excessive inflow and
3 infiltration. Engineering Schedules F-2(S) filed by SSU did not show the inflow
4 and infiltration amount. The inflow/infiltration information should be presented to
5 show the condition of collection system. Many guideline criteria are available and
6 can be used for infiltration allowance on gravity sewers. In the *Recommended*
7 *Standards for Wastewater Facilities*, 200 gallons per inch of pipe diameter per mile
8 per day is the recommended guideline and that criteria is generally used by the
9 FDEP staff.

10 Any excessive inflow and infiltration should be excluded from the amount
11 of wastewater treated. The used and useful analysis should be adjusted accordingly.
12 From the response to OPC Document Request No. 279, SSU indicated that eight
13 out of the forty WWTP have excess inflow and infiltration, as shown by Appendix
14 DR 279-A. The excess amounts were excluded from the used and useful
15 calculations in Exhibit TLB-4.

16 **Q. DO YOU AGREE THAT THE NEW RAW WATER SUPPLY SITE OF**
17 **MARCO ISLAND IS 100% USED AND USEFUL WITHOUT**
18 **EVALUATION?**

19 A. No. An evaluation of total water supply capacity should be conducted before
20 claiming 100% used and useful on the raw water supply site. Currently, it does not
21 seem feasible that this facility will be put into service for the projected test year
22 1996 because no facilities have been constructed on the site. In addition, witness

1 Mr. Terrero mentioned that SSU does not yet have the easement and right of way
2 to connect the new water supply site and Marco Island. Therefore, the cost of 160
3 acres new water supply site should be eliminated from the rate base in this filing.

4 **Q. DO YOU AGREE WITH THE 100% USED AND USEFUL REQUEST FOR**
5 **ALL EFFLUENT REUSE FACILITIES WITHOUT EVALUATION?**

6 A. No. Though effluent reuse is encouraged by environmental regulatory agencies
7 and the utilities are allowed to recover the costs through rate structures, it does not
8 automatically mean all effluent reuse facilities are 100% used and useful. Existing
9 customers should not pay for extra reuse capacity, just as existing customers should
10 not pay for excess capacities of wastewater treatment plants and percolation ponds.
11 In addition, the effluent reuse customers also are paying costs for using the treated
12 effluent. SSU should perform used and useful calculations on all systems that have
13 reuse facilities: Amelia Island, Deltona Lakes, Florida Central Commerce Park,
14 Lehigh, Marco Island, Point O'Woods, and University Shores. It is unjustified to
15 ask existing customers to pay for future customers. Currently no specific used and
16 useful calculations have been made due to lack of effluent reuse flow data. Under
17 this circumstance, the used and useful percentage of reuse facilities was assumed
18 the same percentage as used for percolation ponds.

19 Some systems have two or more effluent disposal measures other than
20 reuse. For example, Marco Island wastewater system has golf course irrigation,
21 percolation ponds, and deep injection well for its effluent disposal. Used and useful
22 calculations may be revised when relevant information is provided by SSU.

1 Q. DO YOU AGREE THAT AN ADJUSTMENT SHOULD BE MADE TO THE
2 DEEP INJECTION WELL ON MARCO ISLAND?

3 A. Yes. The used and useful percentage of the deep injection well on Marco Island
4 depends on the flow data that will be provided by SSU in the near future. Proper
5 adjustment may be made and filed to the Commission when necessary information
6 is provided.

7 According to the Late Filed Deposition Exhibits No. 4, 5, and 6 of Mr.
8 Tererro and Response to OPC Document Request No. 289, the deep injection well
9 on Marco Island is 37.24% used and useful. See Exhibit TLB-4 for the revised
10 used and useful percentages, and Exhibit TLB-4.1 for effluent disposal calculation
11 summary.

12 Q. DO YOU HAVE ANY SPECIFIC COMMENTS CONCERNING THE
13 BURNT STORE WATER SYSTEM?

14 A. Yes. I believe the capacity of the Burnt Store reverse osmosis water plant should
15 be 380 gallons per minute (gpm) instead of 333 gpm. The SSU response to Staff
16 Interrogatory No. 91 indicated that there are two membrane skids in service. Each
17 skid is rated for 167 gpm. However, this pure product water (167 gpm) is blended
18 with ten percent (10%) of the 223 gpm feed water. Therefore, the whole plant
19 output capacity should be as follows:

20
$$\text{Total Capacity} = 2 \times [167 \text{ gpm} + (10\% \times 223 \text{ gpm})] = 378.6 \text{ gpm}$$

21 However, at his deposition SSU witness Mr. Terrero confirmed that he considered
22 each skid to have a capacity of 190 gpm, resulting in a total capacity of 380 gpm

1 for Burnt Store's reverse osmosis water plant. Proper adjustment has been made in
2 my used and useful calculation in Exhibit TLB-3.

3 **Q. DID YOU PREPARE ANY USED AND USEFUL CALCULATIONS IN THIS**
4 **TESTIMONY?**

5 A. Yes, I have recalculated the used and useful percentages for all water and
6 wastewater systems, according to my positions on the above issues. However,
7 some information was not provided by SSU, and I had to make many assumptions
8 in the calculations. For example, fire flow provision was not included because no
9 confirmation is available. Auxiliary power is normally designed to operate supply
10 wells in water systems. In wastewater systems, auxiliary power is usually designed
11 to operate the wastewater treatment plant.

12 All numbers filed by SSU were used, and assumed to be genuine and
13 correct. The calculated used and useful percentages of water and wastewater
14 systems are presented in Exhibit TLB-3 and Exhibit TLB-4, respectively. A
15 summary of calculation key and rationale is also included in Exhibit TLB-2.
16 However, these used and useful numbers are subject to change pending further
17 responses to discovery.

18 **Q. DOES THIS CONCLUDE YOUR PREFILED TESTIMONY?**

19 A Yes, that concludes my testimony filed on February 12, 1996.

EXHIBIT TLB-1

DISTRIBUTION SYSTEM ANALYSIS EXAMPLE

PUMPING FOR DISTRIBUTION STORAGE

The two types of distribution storage—ground and elevated—have, in turn, two types of pumping systems. One is a direct pumping system, in which the instantaneous system demand is met by pumping with no elevated storage provided. The second type is an indirect system in which the pumping station lifts water to a reservoir or elevated storage tank, which floats on the system and provides system pressure by gravity.

Direct Pumping

The direct pumping system is quite rare today, but some systems still exist. Variable-speed pumping units operated off of direct system pressure are also in use in some communities. Hydropneumatic tanks at the pumping station provide some storage. These tanks permit the pumping-station pumps to start and stop, based on a variable system pressure preset by controls operating off of the tank.

Indirect Pumping

In an indirect system, the pumping station is not associated with the demands of the major load center. It is operated from the water level difference in the reservoir or elevated storage tank, enabling the prescribed water level in the tank to be maintained. The majority of systems have an elevated storage tank or a reservoir on high ground floating on the system. This arrangement permits the pumping station to operate at a uniform rate, with the storage either making up or absorbing the difference between station discharge and system demand.

ANALYSIS OF STORAGE

Two variations of distribution storage design affect the operation and reliability of a system's fire suppression capabilities. These two variations involve placement of the storage between the supply point and the major load center or beyond the major load center. An analysis of the following storage designs will be made in the remainder of this chapter:

- system A—pumping station to major center of demand (load) with no elevated storage tank;
- system B—pumping station to major center of demand with an elevated storage tank between the supply and demand; and
- system C—pumping station to major center of demand with an elevated storage tank beyond the demand.

Model System

The model system used in the analysis has the following characteristics:

Population = 27,000	
Water demand rates	
Average day— $27,000 \times 150$ gpcd	= 4.0 mgd
Maximum day— 4.0×1.5	= 6.0 mgd
Maximum hour— 6.0×1.5	= 9.0 mgd
Fire flow = 5000 gpm	= 7.2 mgd
Maximum 10-h rate	
Maximum day and fire flow— $6.0 + 7.2$	= 13.2 mgd
Minimum pressure at major load center	= 50 psi

System pipelines are all expressed as equivalent lengths of 24-in. pipe with a *C* factor of 120. Hydraulic gradient is the slope of the line joining the elevations to which water would rise in pipes freely vented and under atmospheric pressure.

System A—No Storage

If no storage is provided in system A (Figure 3-1) at a given demand rate, the pumping station hydraulic gradient must be sufficient to overcome system losses at a demand rate and maintain a minimum of 115 ft at the major load center. Thus, the pumping heads required to maintain 115 ft plus the head loss in 40,000 ft of equivalent pipe for the various conditions are as follows:

Demand Rates	Pumping Head Required
Average day, 4.0 mgd— $115 + (0.67 \times 40)$	= 142 ft
Maximum day, 6.0 mgd— $115 + (1.42 \times 40)$	= 172 ft
Maximum hour, 9.0 mgd— $115 + (3.0 \times 40)$	= 235 ft
Maximum day and fire, 13.2 mgd— $115 + (6.1 \times 40)$	= 359 ft




Figure 3-1 System A—hydraulic gradient with no storage.

System B—Storage Ahead of Load Center

If, as shown in Figure 3-2, a 1.75-mil gal storage tank is located 145 ft above the datum plane and at a distance of 35,000 ft from the pump station (5000 ft ahead of the major load center), the pumping head of a given pumping rate must be sufficient to pump against a head at the storage tank and overcome system losses at the pumping rate.

Average day. At the average-day demand, the required pumping rate (no water taken from storage) is 4 mgd. The pumping head required is equal to the hydraulic gradient at the tank plus the head loss in 35,000 ft of equivalent pipe at 4 mgd, or $145 + (0.67 \times 35) = 169$ ft. The hydraulic gradient at the load center is the hydraulic gradient at the tank minus the head loss in 5000 ft of equivalent pipe, or $145 - (0.67 \times 5) = 142$ ft.

Maximum day. At the maximum-day demand, the required pumping rate is 6 mgd (no water taken from storage). The pumping head required is equal to the hydraulic gradient at the tank plus the head loss in 35,000 ft of equivalent pipe at 6 mgd, or $145 + (1.42 \times 35) = 195$ ft. The hydraulic gradient at the load center is the hydraulic gradient at the tank minus the head loss in 5000 ft of equivalent pipe at 6 mgd, or $145 - (1.42 \times 5) = 138$ ft.

Maximum hour. At the maximum-hour demand, the flow in the 5000 ft of pipe between the tank and the load center must be 9 mgd. The hydraulic gradient at the load center is the hydraulic gradient at the tank minus the losses in 5000 ft of equivalent pipe at 9 mgd, or $145 - (3 \times 5) = 130$ ft. The pumping head required is equal to the hydraulic gradient at the tank plus the head loss in 35,000 ft of equivalent pipe at the chosen pumping rate. If 3 mgd is to be supplied from the tank,




Figure 3-2 System B—hydraulic gradients with storage between pump station and load center.

storage and the remaining 6 mgd is to be supplied from pumping, the pumping head required is $145 + (1.42 \times 35) = 195$ ft (Figure 3-2).

Maximum day plus fire flow. At the maximum-day demand plus the fire demand, the flow in the 5000 ft of pipe between the tank and the load center must be 13.2 mgd. The hydraulic gradient at the load center is the hydraulic gradient at the tank minus the head loss of 5000 ft of equivalent pipe at 13.2 mgd, or $145 - (6.1 \times 5) = 115$ ft. If it is decided to supply 4.2 mgd from storage and pump the remaining 9 mgd, the pumping head required is equal to the hydraulic gradient at the tank plus the head loss in 35,000 ft of equivalent pipe at 9 mgd, or $145 + (3 \times 35) = 250$ ft.

Demand Rates	Pumping Head Required
Average day, 4.0 mgd—no water from storage	= 169 ft
Maximum day, 6.0 mgd—no water from storage	= 195 ft
Maximum hour, 9.0 mgd—6.0 mgd from pumps + 3.0 mgd from storage	= 195 ft
Maximum day plus fire flow, 13.2 mgd—9.0 mgd from pumps + 4.2 mgd tank	= 250 ft

System C—Storage Beyond Load Center

In the arrangement shown in Figure 3-3, 1.75 mil gal of storage is provided 5000 ft beyond the load center (45,000 ft from the pump station) at an elevation of 119 ft above the datum plane. When no water is being taken from storage at a given demand rate, the pumping head must be sufficient to pump against the head at the tank and overcome losses between the pump station and the load center at that demand rate. When part of the demand is being supplied from storage, however, the pumping head need only be sufficient to pump against the head at the load center and overcome losses in the pipeline between the pump station and the load center.

Average day. At the average-day demand, the required pumping rate is 4 mgd (no water taken from storage). The pumping head required is equal to the hydraulic gradient at the tank plus the head loss in 40,000 ft of equivalent pipe, or $119 + (0.67 \times 40) = 146$ ft. The hydraulic gradient at the load center is thus identical to that at the tank (119 ft).

Maximum day. At the maximum-day demand, the required pumping rate is 6 mgd (no water taken from storage). The pumping head required is equal to the hydraulic gradient at the tank plus the head loss in 40,000 ft of equivalent pipe at 6 mgd, or $119 + (1.42 \times 40) = 176$ ft. The hydraulic gradient at the load center is identical to that at the tank (119 ft).

Maximum hour. If, at the maximum-hour demand (9 mgd), it is decided to supply 3 mgd from storage and the remaining 6 mgd from pumping, the hydraulic gradient at the load center is the hydraulic gradient at the tank minus the head loss in the 5000 ft of pipe between the tank and load center at the storage discharge rate of 3 mgd, or $119 - (0.4 \times 5) = 117$ ft. The pumping head required is equal to the hydraulic gradient at the load center plus the head loss in 40,000 ft of equivalent pipe at 6 mgd, $117 + (1.42 \times 40) = 174$ ft.

Maximum day plus fire flow. In order to maintain a head of 115 ft at the load center, the flow in the 5000 ft of pipe between the load center and the tank cannot exceed that at which the head loss is 4 ft, which is 4.2 mgd. Thus the remainder of the demand (9 mgd) must be supplied from pumping. The pumping head required is equal to the hydraulic gradient at the load center (115 ft) plus the head loss in 40,000 ft of equivalent pipe, or $115 + (3 \times 40) = 235$ ft.




Figure 3-3 System C—hydraulic gradients with storage beyond load center.

Demand Rates	Pumping Head Required
Average day, 4.0 mgd—no water from storage	= 146 ft
Maximum day, 6.0 mgd—no water from storage	= 176 ft
Maximum hour, 9.0 mgd—6.0 mgd from pumps + 3.0 mgd from tank	= 174 ft
Maximum day plus fire flow, 13.2 mgd—9.0 mgd from pumps + 4.2 mgd from tank	= 235 ft

In the analyses above, the designer has provided 1.75 mil gal of storage for fire demands. The highest rate of flow that can be sustained for the required 10 h is 4.2 mgd. The remainder of the fire flow (3 mgd) and the maximum-day demand (6 mgd) must be supplied from pumping. The fact that the pumping rate (9 mgd) is the same as the maximum-hour demand is only a coincidence.

Comparison of System A With System C

If no storage is provided, 124 ft (359 ft - 235 ft) more pumping head is required to furnish the maximum-day demand plus fire flow than if adequate storage is provided beyond the load center. With the increased pumping rates required with no storage, the power needed is approximately 1100 hp, as opposed to 495 hp with storage, or more than twice as much. Similarly, furnishing the maximum-hour demand without storage would require 500 hp, as opposed to 245 hp, still more than twice as much.

The capacities of the pumps required under these two conditions would be 13.2 mgd at 359-ft head, as opposed to 9 mgd at 235-ft head, and 9 mgd at 235-ft head, as opposed to 6 mgd at 174-ft head. During average- and maximum-day demands, the pumping head at the source is approximately the same.

Comparison of System B With System C

In comparing storage located between the source and the load center with storage located beyond the load center, the examples illustrate that an increase in height is necessary if the storage is between the source and the load center. To secure approximately equivalent pressure results, the flow line of storage in the first instance must be 26 ft (145 ft - 119 ft) higher than if the storage feeds back to the load center from a point beyond.

Pumping heads are substantially lower under all rates of flow and pressure is more uniformly regulated, if the storage is located beyond the load center. The area served is substantially greater and the pressures are better regulated by storage located beyond the load center than by storage located between the pumping station and the load center. The additional height of 26 ft for the storage tank and the additional pumping head under all rates of flow make system B more costly when considering initial capital cost and substantially higher operating costs for electrical power.

Recommended Design

System C, using a 1.75-mil gal elevated storage tank beyond the major load center, is the recommended design, because it provides the necessary water demand flows at reasonable pressures. This system is also the most cost-effective design for capital costs and operating costs.

The design chosen is based on replenishing, within the 24 h during which a major fire occurs, all water taken from storage for fire fighting. The maximum required pumping head would be reduced from 235 ft to 182 ft if all water used for fire fighting (7.2 mgd) was provided by storage, and the pumps would only have to operate at 6 mgd. If the system was so designed, however, the tank would have to be raised 6 ft in order to maintain 115 ft of head at the load center, and the fire storage would have to be increased to 3 mil gal. Fire storage would then amount to 50 percent of the maximum day and 75 percent of the average day, and that much storage might not be economically justified. On the other hand, if the storage is not provided, an additional 3 mgd of pumping capacity is required and the production and supply works must also be capable of increased output, unless finished-water storage is provided ahead of the pump station. Therefore, an economic and engineering study should generally be made to determine the most efficient way to provide the required capacity.

References

1. *Water Distribution Operator Training Handbook*. AWWA, Denver, Colo. (1976).
2. COTE, A.E. & LINVILLE, J.L., eds. *Fire Protection Handbook*. National Fire Protection Association, Quincy, Mass. (16th ed., 1986).
3. FAIR, G.M. ET AL. *Water and Wastewater Engineering*. John Wiley and Sons, Inc., New York (1966).
4. STEEL, E.W. & MCGHEE, T.G. *Water Supply and Sewerage*. McGraw-Hill Book Co., New York (1979).

EXHIBIT TLB-2

**KEY AND RATIONALE
FOR
OPC USED AND USEFUL CALCULATIONS**

KEY AND RATIONALE FOR OPC USED AND USEFUL CALCULATIONS

I. SUPPLY WELL

A. Small System (without high service pumps):

Used & Useful % = **PHF/Reliable Capacity** (w/o fire flow provision)

= **(MDF + FF)/Reliable Capacity** (w/ fire flow provision)

Rationale ---- Well pumps function as high service pumps. Therefore, according to "10 States Standards", at least two pumping units shall be provided. With any pump out of service, the remaining pump or pumps shall be capable of providing the maximum daily pumping demand of the system. It is not economically justified to use PHF+FF as design flow. A peaking factor of 1.3 is applied to MDF where PHF is used in the calculations.

B. Large System (with high service pumps and storage):

Used & Useful % = **MDF/Total Capacity** or **ADF/Reliable Capacity**,

Whichever is greater.

Rationale ---- ADF/Reliable Capacity is used because the percentage is generally greater than MDF/Total Capacity. Reliable capacity should be applied once to high service pumps, not to other facilities also. The chance of having a well and a high service pump breakdown or to be out of service simultaneously is very slim. "10 States Standards" states that "the total developed groundwater source capacity shall equal or exceed the design maximum day demand and equal or exceed the design average day demand with the largest producing well out of service."

Notes: 1. PHF = Peak Hourly Flow; MDF = Avg. 5 Max Day Flows in Max Month; ADF = Annual Avg. Day Flow; FF = Fire Flow. However, fire

flow provisions were allowed only for those systems that had verified fire flows.

2. Water flow was adjusted for excess unaccounted for water.
3. No margin reserve was included in OPC's calculations.

II. HIGH SERVICE PUMP

Used & Useful % = $(MDF + FF)/\text{Reliable Capacity}$
or $PHF/\text{Reliable Capacity}$ (no fire protection)

Rationale ---- It is not economically justified to use PHF + FF as design flow, per AWWA M31 (P.16). Reliable capacity should be used per "10 States Standards." No fire flow was applied at this time. It may be included pending future discovery response. For systems with elevated storage tanks like Keystone Heights and Lehigh, the peak hour demands are provided by elevated tanks.

III. WATER TREATMENT PLANT

Used & Useful % = $MDF/\text{Total Capacity}$

Rationale ---- The chance is very small to have a high service pump and a part of treatment facilities to be out of service at the same time.

VI. FINISHED WATER STORAGE

Used & Useful % = $(1/2 ADF + FF)/\text{Total Capacity}$ (with fire flow provision)
or $ADF/\text{Total Capacity}$ (without fire flow protection)

Rationale ---- AWWA M32 suggests that equalization storage is about 20 to 25 percent of the average day demand. Fire storage shall be included if fire flow is provided. Emergency storage is an owner option.

---- "10 States Standard" requires fire flow storage where fire protection

is provided. The minimum storage capacity for systems not providing fire protection shall be equal to the average daily consumption (ADF). This requirement may be reduced when the source and treatment facilities have sufficient capacity with stand by power to supplement peak demands of the system. Emergency storage is not mentioned in this reference.

- SSU uses a peaking factor of 2 and 4 hours of peak duration to calculate peak hour storage or equalization storage. This is a pure empirical method. SSU also requests 8 hours of ADF as emergency storage for some water systems, but no detail explanation was provided.
- OPC believes fire storage should be included where fire protection is provided. Fire flow storage was not included because SSU has not confirmed the provision of fire protection. Fire flow is assumed stored in ground storage tanks and delivered through high service pumps.

When the system is furnishing fire flow, a half day ADF storage is used. That is more than adequate for peak hour demand storage compared with 20 to 25% ADF mentioned in the AWWA M32. The volume of a half day ADF is also close to SSU's empirical method calculated. The excess storage can be considered as a provision for emergency storage. The one day ADF storage criteria used in "10 States Standards" was reduced to one half day because MDF design flow is used for supply wells, treatment plant and high service pumps. Fire storage will be included if it is confirmed.

No emergency storage was included because it is not yet confirmed by the original design or other supporting documents. Total capacity is used because SSU used more than 10% for dead storage without confirmation. Dead storage is not applicable to

elevated storage tanks.

V. HYDROPNEUMATIC TANK

Used & Useful % = $10 \times (\text{Total Capacity} - \text{Reliable Capacity of Supply Well})$

Hydro Tank Capacity

Rationale ---- Hydropneumatic tanks are usually used in very small water systems with groundwater supply wells as "10 States Standards" stated. When serving more than 150 units, ground or elevated storage should be provided.

The sizing criteria is ten times the capacity of the largest well pump. The information filed is not clear on some supply wells especially for large systems because two wells were assumed out of service. However, the largest well capacity is still assumed to be the difference between total capacity and reliable capacity of supply wells.

VI. AUXILIARY POWER

A. Water System:

Used & Useful % = $(1/2 \text{ MDF}) / (1/2 \text{ Total Capacity}) = \text{MDF} / \text{Total Capacity}$

Rationale ---- This a FDEP requirement per Chapter 62-555.320, F.A.C. SSU cannot provide proper capacity information of auxiliary power, therefore, the used and useful percentage of supply wells was used because the cost of auxiliary power is booked under the Source of Supply as Power Generation Equipment.

B. Wastewater System:

Used & Useful % = $\text{ADF of Max. Month} / \text{Total Capacity}$

Rationale ---- FDEP has no specific requirement. Since SSU cannot provide proper

capacity information to specific equipments, the same used and useful percentage of WWTP was used for auxiliary power.

VII. WASTEWATER TREATMENT PLANT

Used & Useful % = **ADF of Max. Month/Total Capacity**

Rationale ---- Though the capacity permitted is annual ADF, OPC agrees to use ADF of the maximum month because that is the PSC policy.

Note: Wastewater flow was adjusted for excess infiltration.

VIII. EFFLUENT DISPOSAL AND EFFLUENT REUSE FACILITY

Used & Useful % = **ADF of Max. Month/Total Capacity**

Rationale ---- Same as WWTP.

Note: Since no effluent reuse data was yet provided, the same used and useful percentage also was used for effluent reuse facilities for the following systems: Amelia Island, Deltona Lakes, Florida Central Commerce Park, Lehigh, Marco Island, Point O'Woods, and University Shores.

IX. WATER DISTRIBUTION SYSTEM AND WASTEWATER COLLECTION SYSTEM

Used & Useful % = **Lots Connected/Total Lots Available**

Rationale ---- See direct testimony.

X. FLOWS AND LOTS PROJECTIONS OF 1996

A. Water System:

MDF of 1996 = (ERCs of 1996/ERCs of 1994) x Avg. 5 Max. Day of 1994

B. Wastewater System:

ADF of Max. Month in 1996 = (ERCs of 1996/ERCs of 1994) x ADF of
Max. Month in 1994

C. Water Distribution and Wastewater Collection Systems

Connected Lots of 1996 = (ERCs of 1996/ERCs of 1994) x Connected Lots
of 1994

EXHIBIT TLB-3

**OPC USED AND USEFUL CALCULATIONS
OF
WATER SYSTEMS**

OPC USED AND USEFUL CALCULATIONS
Water Treatment Plant - Schedule F-5 (W)

Line No.	Company: Southern States Utilities, Inc.									
	Amelia Island	Apache Shore	Apple Valley	Bay Lake Estates	Beacon Hill	Beecher's Point	Burnt Store	Carlton Village	Chuluota	
	Schedule Year Ended: 12/31/96									
	Projected [x]									
	FPSC Uniform [x]; FPSC Non-Uniform [x]									
1	1996	1996	1996	1996	1996	1996	1996	1996	1996	1996
2	2,110,842	24,000	960,000	60,000	2,849,200	Water	239,040	94,000	488,000	
3	1,933,972	20,200	767,715	56,348	2,731,049	Purchased	220,503	108,593	367,168	
4	1,727,071	20,200	736,800	54,000	2,477,540	From	194,688	93,080	352,400	
5	1,286,547	15,268	389,878	20,038	1,492,990	Town of	164,340	45,073	207,825	
6	1,148,909	15,268	374,178	19,203	1,354,404	Weiska	145,100	38,634	199,466	
7	180,000	0	0	0	0		0	0	0	
8	1,000	0	0	0	0		0	0	0	
9	21.5%	11.9%	9.7%	8.5%	0.3%	17.6%	0.1%	19.9%	4.9%	
10	10.0%	10.0%	9.7%	8.5%	0.3%	10.0%	0.1%	10.0%	4.9%	
11	SOURCE OF SUPPLY AND PUMPING:									
12	Supply Wells:									
13	L	S	L	S	L	S	L	S	L	
14	2,800	150	1,100	275	3,850	N/A	440	300	1,300	
15	1,400	50	500	0	2,350	N/A	220	100	800	
16	56.22%	35.78%	54.15%	100.00%	49.26%	N/A	51.87%	88.33%	19.61%	
17	87.70%	25.30%	100.00%	100.00%	58.90%	N/A	80.10%	100.00%	98.50%	
18	100.00%	66.67%	100.00%	100.00%	100.00%	N/A	100.00%	100.00%	50.43%	
19	Auxiliary Power:									
20	Capacity (GPD), not provided									
21	Unavailable	Unavailable	Unavailable	Unavailable	Unavailable	Unavailable	Unavailable	Unavailable	Unavailable	
22	56.22%	54.15%	100.00%	49.26%	51.87%	88.33%	19.61%			
23	100.00%	100.00%	100.00%	100.00%	100.00%	100.00%	100.00%	100.00%	100.00%	
24	High Service Pumping:									
25	5,200	N/A	2,400	N/A	5,675	N/A	2,400	N/A	1,950	
26	2,645	N/A	1,200	N/A	4,000	N/A	900	N/A	1,450	
27	82.54%	N/A	44.43%	N/A	47.41%	N/A	17.01%	N/A	17.58%	
28	64.20%	N/A	100.00%	N/A	100.00%	N/A	100.00%	N/A	100.00%	
29	100.00%	N/A	100.00%	N/A	100.00%	N/A	100.00%	N/A	97.03%	
30										
31	WATER TREATMENT PLANT:									
32	Water Treatment Equipment:									
33	N/A	N/A	N/A	N/A	N/A	N/A	380	N/A	N/A	
34	N/A	N/A	N/A	N/A	N/A	N/A	380	N/A	N/A	
35	N/A	N/A	N/A	N/A	N/A	N/A	40.30%	N/A	N/A	
36	N/A	N/A	N/A	N/A	N/A	N/A	100.00%	N/A	N/A	
37	N/A	N/A	N/A	N/A	N/A	N/A	96.77%	N/A	N/A	
38										
39	TRANSMISSION AND DISTRIBUTION:									
40	Finished Water Storage:									
41	1,000,000		100,000		433,600		500,000		150,000	
42	289,953	N/A	90,000	N/A	390,240	N/A	401,633	N/A	135,000	
43	74.67%	N/A	100.00%	N/A	100.00%	N/A	18.43%	N/A	69.28%	
44	100.00%	N/A	100.00%	N/A	100.00%	N/A	46.90%	N/A	75.00%	
45	100.00%	N/A	100.00%	N/A	100.00%	N/A	84.75%	N/A	100.00%	
46										
47	Hydropneumatic Tanks:									
48	20,000	12,500	15,000	3,000	20,000	N/A	25,000	10,000	15,000	
49	70.00%	8.00%	40.00%	81.67%	78.00%	N/A	8.80%	20.00%	33.33%	
50	100.00%	81.00%	100.00%	100.00%	100.00%	N/A	100.00%	54.00%	100.00%	
51	100.00%	100.00%	100.00%	100.00%	100.00%	N/A	100.00%	100.00%	100.00%	
52										
53	USED AND USEFUL CALCULATIONS									
	Water Transmission & Distribution System									
54	Schedule F-7(W)									
55	TRANSMISSION AND DISTRIBUTION:									
56	1,601	153	982	72	3,266	52	490	147	682	
57	1,429	153	942	69	2,962	45	432	126	655	
58	1,513	153	962	70	3,080	49	458	137	669	
59	2,467	293	1,591	100	3,178	85	4,347	343	1,055	
60	64.88%	52.22%	61.71%	72.00%	100.00%	81.66%	11.26%	42.86%	64.67%	
61	100.00%	55.00%	100.00%	64.00%	97.00%	100.00%	13.70%	31.00%	100.00%	
62	100.00%	55.00%	100.00%	73.70%	100.00%	100.00%	13.70%	45.89%	100.00%	
63										
64	ERC CALCULATIONS (by SSU)									
65	Combined Schedule of F- 8 & 9 (W)									
66	Year	Water ERC	Water ERC	Water ERC	Water ERC	Water ERC	Water ERC	Water ERC	Water ERC	
67	1990	1,630	161	918	63	2,545	69	503	87	635
68	1991	1,804	160	941	64	2,660	80	561	96	653
69	1992	1,924	161	961	66	2,799	90	597	109	669
70	1993	2,027	157	962	68	3,078	92	651	118	679
71	1994	2,187	153	1,001	69	3,401	94	724	126	692
72	1995	2,315	153	1,022	70	3,536	103	767	137	707
73	1995.5	2,382	153	1,033	71	3,642	107	793	142	714
74	1996	2,449	153	1,043	72	3,749	110	820	147	721

OPC USED AND USEFUL CALCULATIONS
Water Treatment Plant - Schedule F-5 (W)

Line No.	Citrus Springs		Crystal River	Deerwyler Shores	Dakota Lakes	Dol Ray Manor	Druid Hills	East Lake Harris Est.	Fern Park	Fern Terrace
	1996	1996	1996	1996	1996	1996	1996	1996	1996	1996
Docket No. 950495-WS Company: Southern States Utilities, Inc. Schedule Year Ended: 12/31/96 Projected [x] FPSC Uniform [x]; FPSC Non-Uniform [x]										
1	155,700	1,384,800	46,000		15,981,000	66,600	299,000	40,200	92,000	93,680
2	144,583	1,018,008	40,744	Purchased	16,045,232	57,120	240,800	37,268	80,541	81,858
3	142,940	960,200	38,600	From	15,200,200	57,120	240,800	36,640	80,200	79,300
4	90,399	594,100	23,653	Orlando	6,764,274	26,158	124,771	18,026	52,101	37,835
5	89,372	560,364	22,408	Util. Comm.	6,408,029	26,158	124,771	17,722	51,816	36,653
6	0	0	0		260,100	0	0	0	0	0
7	0	0	0		2,168	0	0	0	0	0
8	9.9%	17.9%	2.8%	2.0%	11.6%	0.0%	14.2%	9.9%	7.9%	4.4%
9	9.9%	10.0%	2.8%	2.0%	10.0%	0.0%	10.0%	9.9%	7.9%	4.4%
10										
11	SOURCE OF SUPPLY AND PUMPING:									
12	Supply Wells:									
13	S	L	S	S	L	L	L	S	L	S
13	285	1,500	390	N/A	17,230	525	550	200	259	180
14	137	1,000	150	N/A	14,230	250	200	0	0	0
15	95.27%	43.41%	24.52%	N/A	63.63%	7.56%	41.60%	100.00%	100.00%	100.00%
16	100.00%	100.00%	100.00%	N/A	96.00%	100.00%	100.00%	100.00%	100.00%	100.00%
17	100.00%	100.00%	53.64%	N/A	92.85%	100.00%	100.00%	100.00%	100.00%	100.00%
18										
19	Auxiliary Power:									
20	Capacity (GPD), not provided									
21	Unavailable				Unavailable		Unavailable		Unavailable	
21	95.27%				63.63%		41.60%		100.00%	
22	100.00%				100.00%		100.00%		100.00%	
23										
24	High Service Pumping:									
25	N/A	4,500	N/A	N/A	23,300	500	500	N/A	250	N/A
26	N/A	3,000	N/A	N/A	21,200	250	250	N/A	0	N/A
27	N/A	21.70%	N/A	N/A	61.94%	15.87%	64.08%	N/A	100.00%	N/A
28	N/A	N/A	N/A	N/A	100.00%	100.00%	100.00%	N/A	100.00%	N/A
29	N/A	100.00%	N/A	N/A	100.00%	37.00%	100.00%	N/A	100.00%	N/A
30										
31	WATER TREATMENT PLANT:									
32	Water Treatment Equipment:									
33	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
34	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
35	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
36	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
37	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
38										
39	TRANSMISSION AND DISTRIBUTION:									
40	Finished Water Storage:									
41		500,000			7,000,000	8,000	30,000		17,000	
42	N/A	140,825	N/A	N/A	3,749,577	7,200	27,000	N/A	15,300	N/A
43	N/A	64.72%	N/A	N/A	51.26%	100.00%	100.00%	N/A	100.00%	N/A
44	N/A	N/A	N/A	N/A	100.00%	100.00%	100.00%	N/A	100.00%	N/A
45	N/A	100.00%	N/A	N/A	100.00%	100.00%	100.00%	N/A	100.00%	N/A
46										
47	Hydropneumatic Tanks:									
48	4,000	16,000	2,000	N/A	25,500	5,000	7,500	3,000	4,500	3,000
49	37.00%	31.25%	100.00%	N/A	100.00%	55.00%	46.67%	66.67%	57.56%	60.00%
50	56.00%	100.00%	100.00%	N/A	100.00%	100.00%	100.00%	70.00%	100.00%	50.00%
51	100.00%	100.00%	100.00%	N/A	100.00%	100.00%	100.00%	100.00%	100.00%	100.00%
52										
53	USED AND USEFUL CALCULATIONS									
Water Transmission & Distribution System										
54	Schedule F-7(W)									
55	TRANSMISSION AND DISTRIBUTION:									
56	350	1,892	76	124	23,933	59	247	177	178	126
57	346	1,784	72	124	22,672	59	247	174	177	122
58	346	1,840	74	124	23,327	59	247	175	177	125
59	335	11,667	91	138	34,940	77	335	214	208	126
60	100.00%	16.22%	83.52%	89.86%	68.50%	76.62%	73.73%	82.70%	85.56%	99.99%
61	100.00%	21.00%	100.00%	100.00%	89.30%	100.00%	100.00%	100.00%	100.00%	100.00%
62	100.00%	42.71%	100.00%	100.00%	89.30%	100.00%	100.00%	100.00%	100.00%	100.00%
63										
64	ERC CALCULATIONS (by SSU)									
65	Combined Schedule of F-8 & 9 (W)									
66	Year	Water ERC	Water ERC	Water ERC	Water ERC	Water ERC	Water ERC	Water ERC	Water ERC	Water ERC
67	1990	333	1,719	65	136	22,190	77	333	168	119
68	1991	326	1,810	65	133	23,064	77	331	170	121
69	1992	328	1,864	68	130	23,651	77	330	170	123
70	1993	340	1,898	70	130	24,301	75	330	173	125
71	1994	348	1,960	72	131	24,895	75	331	175	124
72	1995	348	2,021	74	131	25,614	75	331	176	127
73	1995.5	350	2,050	75	131	25,946	75	331	177	128
74	1996	352	2,078	76	131	26,279	75	331	178	128

OPC USED AND USEFUL CALCULATIONS
Water Treatment Plant - Schedule F-5 (W)

Line No.	Fisherman's Haven	Fountains	Fox Run	Friendly Center	Golden Terrace	Gospel Island	Grand Terrace	Harmony Homes	Hermits Cove
Docket No. 950495-WS									
Company: Southern States Utilities, Inc.									
Schedule Year Ended: 12/31/96	1996	1996	1996	1996	1996	1996	1996	1996	1996
Projected [x]									
FPSC Uniform [x]; FPSC Non-Uniform [x]									
1 1994 MAX DAY FOR YEAR (GPD)	56,700	65,100	69,000	12,900	Water	7,000	99,500	5,900	80,800
2 1996 AVG MAX 5 DAYS IN MAX MONTH (GPD)	41,680	50,427	62,297	9,100	Purchased	6,525	134,731	36,360	49,400
3 1994 AVG MAX 5 DAYS IN MAX MONTH (GPD)	41,680	37,820	57,057	9,100	From	5,800	93,800	36,360	49,400
4 1996 ANNUAL AVG DAILY FLOW (GPD)	26,751	14,603	30,855	4,363	City of	2,271	50,119	23,078	20,043
5 1994 ANNUAL AVG DAILY FLOW (GPD)	26,751	10,952	28,260	4,363	Inverness	2,019	34,893	23,078	20,043
6 FIRE STORAGE ACCEPTED (GAL.)	0	0	0	0		0	0	0	0
7 FIRE FLOW PROVISION (GPM)	0	0	0	0		0	0	0	0
8 Unaccounted for Water Level (%)	3.1%	13.6%	1.5%	9.3%	17.6%	9.8%	4.3%	7.6%	9.8%
9 Unaccounted for Water Allowed (%)	3.1%	10.0%	1.5%	9.3%	10.0%	9.8%	4.3%	7.6%	9.8%
10									
11 SOURCE OF SUPPLY AND PUMPING:									
12 Supply Wells:	S	L	L	S	S	S	S	S	L
13 Total Capacity (gpm)	100	300	850	140	N/A	50	600	300	110
14 Reliable Capacity (gpm)	0	80	350	0	N/A	0	0	0	0
15 OPC Calculated Used & Useful (%)	100.00%	12.22%	6.12%	100.00%	N/A	100.00%	100.00%	100.00%	100.00%
16 U & U Per Order (%)	100.00%	100.00%	100.00%	100.00%	N/A	100.00%	100.00%	100.00%	100.00%
17 SSU Requested U & U (%)	100.00%	100.00%	19.07%	100.00%	N/A	100.00%	100.00%	100.00%	100.00%
18									
19 Auxiliary Power:									
20 Capacity (GPD), not provided			Unavailable						Unavailable
21 OPC Calculated Used & Useful (%)			6.12%						100.00%
22 SSU Requested U & U (%)			100.00%						100.00%
23									
24 High Service Pumping:									
25 Total Capacity (gpm)	N/A	1,500	850	N/A	N/A	N/A	N/A	N/A	240
26 Reliable Capacity (gpm)	N/A	1,000	500	N/A	N/A	N/A	N/A	N/A	120
27 OPC Calculated Used & Useful (%)	N/A	3.38%	8.65%	N/A	N/A	N/A	N/A	N/A	37.16%
28 U & U Per Order (%)	N/A	37.00%	100.00%	N/A	N/A	N/A	N/A	N/A	60.60%
29 SSU Requested U & U (%)	N/A	83.98%	100.00%	N/A	N/A	N/A	N/A	N/A	95.85%
30									
31 WATER TREATMENT PLANT:									
32 Water Treatment Equipment:									
33 Total Capacity (gpm)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
34 Reliable Capacity (gpm)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
35 OPC Calculated Used & Useful (%)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
36 U & U Per Order (%)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
37 SSU Requested U & U (%)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
38									
39 TRANSMISSION AND DISTRIBUTION:									
40 Finished Water Storage:									
41 Total Capacity (gal.)		20,000	50,000						23,000
42 Reliable Capacity (gal.)	N/A	18,000	45,000	N/A	N/A	N/A	N/A	N/A	20,700
43 OPC Calculated Used & Useful (%)	N/A	35.19%	30.86%	N/A	N/A	N/A	N/A	N/A	43.57%
44 U & U Per Order (%)	N/A	100.00%	100.00%	N/A	N/A	N/A	N/A	N/A	100.00%
45 SSU Requested U & U (%)	N/A	100.00%	100.00%	N/A	N/A	N/A	N/A	N/A	100.00%
46									
47 Hydropneumatic Tanks:									
48 Total Capacity (gal.)	10,000	13,000	4,400	3,500	N/A	600	6,000	5,000	3,000
49 OPC Calculated Used & Useful (%)	10.00%	16.92%	100.00%	40.00%	N/A	83.33%	100.00%	60.00%	36.67%
50 U & U Per Order (%)	15.00%	100.00%	100.00%	100.00%	N/A	100.00%	100.00%	90.00%	75.90%
51 SSU Requested U & U (%)	100.00%	100.00%	100.00%	100.00%	N/A	100.00%	100.00%	100.00%	100.00%
52									
53 USED AND USEFUL CALCULATIONS									
Water Transmission & Distribution System									
54 Schedule F-7(W)									
55 TRANSMISSION AND DISTRIBUTION:									
56 Connected Lots in 1996 w/o M.R.	136	39	107	20	106	9	158	61	175
57 Connected Lots in 1994 w/o M.R.	136	29	98	20	105	8	110	61	175
58 Connected Lots in 1994 w/ M.R.	136	32	103	20	105	9	139	61	175
59 Number of Lots	144	84	109	46	120	25	111	82	350
60 OPC Calculated Used & Useful (%)	94.44%	46.18%	98.17%	43.48%	88.24%	12.34%	100.00%	98.39%	50.00%
61 U & U Per Order (%)	100.00%	14.00%	100.00%	100.00%	100.00%	36.00%	100.00%	100.00%	49.40%
62 SSU Requested U & U (%)	100.00%	53.59%	100.00%	100.00%	100.00%	12.34%	100.00%	100.00%	50.41%
63									
64 ERC CALCULATIONS (by SSU)									
65 Combined Schedule of F-8 & 9 (W)									
66 Year	Water ERC	Water ERC	Water ERC	Water ERC	Water ERC	Water ERC	Water ERC	Water ERC	Water ERC
67 1990	133	2	82	21	118	6	38	62	173
68 1991	133	4	90	20	116	8	66	62	173
69 1992	133	6	94	21	117	8	95	62	172
70 1993	133	18	96	21	119	8	108	62	173
71 1994	136	30	98	20	119	8	110	61	176
72 1995	136	33	103	20	119	9	139	61	176
73 1995.5	136	37	105	20	120	9	148	61	176
74 1996	136	40	107	20	120	9	158	61	176

OPC USED AND USEFUL CALCULATIONS
Water Treatment Plant - Schedule F-5 (W)

Line No.	Docket No. 950495-WS	Hobby Hills	Holiday Haven	Holiday Heights	Imperial Terrace	Inter-cession City	Intertachen Park Manor	Jungle Den	Keystone Heights	Kingswood
	Company: Southern States Utilities, Inc.									
	Schedule Year Ended: 12/31/96	1996	1996	1996	1996	1996	1996	1996	1996	1996
	Projected [x]									
	FPSC Uniform [x]: FPSC Non-Uniform [x]									
1	1994 MAX DAY FOR YEAR (GPD)	49,350	Water	33,000	103,000	136,190	101,400	Water	656,000	Water
2	1996 AVG MAX 5 DAYS IN MAX MONTH (GPD)	42,540	Purchased	39,600	87,062	116,250	68,818	Purchased	549,886	Purchased
3	1994 AVG MAX 5 DAYS IN MAX MONTH (GPD)	42,540	From	39,600	86,000	110,590	76,360	From	543,400	From
4	1996 ANNUAL AVG DAILY FLOW (GPD)	20,386	Astor Water	16,488	39,720	61,837	36,140	Astor Water	338,350	Brevard County
5	1994 ANNUAL AVG DAILY FLOW (GPD)	20,386	Assoc.	16,488	39,236	58,826	40,101	Assoc.	334,359	
6	FIRE STORAGE ACCEPTED (GAL)	0		0	0	0	0		120,000	
7	FIRE FLOW PROVISION (GPM)	0		0	0	0	0		1,000	
8	Unaccounted for Water Level (%)	11.8%	21.7%	7.2%	5.8%	22.3%	24.9%	1.3%	11.8%	5.2%
9	Unaccounted for Water Allowed (%)	10.0%	10.0%	7.2%	5.8%	10.0%	10.0%	1.3%	10.0%	5.2%
10										
11	SOURCE OF SUPPLY AND PUMPING:									
12	Supply Wells:	S	S	S	S	S	L	S	L	S
13	Total Capacity (gpm)	325	N/A	220	550	325	340	N/A	1,230	N/A
14	Reliable Capacity (gpm)	150	N/A	0	150	75	160	N/A	680	N/A
15	OPC Calculated Used & Useful (%)	25.14%	N/A	100.00%	52.40%	100.00%	13.35%	N/A	33.93%	N/A
16	U & U Per Order (%)	43.20%	N/A	100.00%	100.00%	100.00%	56.30%	N/A	47.10%	N/A
17	SSU Requested U & U (%)	47.94%	N/A	100.00%	100.00%	100.00%	56.30%	N/A	70.97%	N/A
18										
19	Auxiliary Power:									
20	Capacity (GPD), not provided				Unavailable	Unavailable	Unavailable		Unavailable	
21	OPC Calculated Used & Useful (%)				52.40%	100.00%	13.35%		33.93%	
22	SSU Requested U & U (%)				100.00%	100.00%	100.00%		100.00%	
23										
24	High Service Pumping:									
25	Total Capacity (gpm)	N/A	N/A	N/A	N/A	N/A	430	N/A	N/A	N/A
26	Reliable Capacity (gpm)	N/A	N/A	N/A	N/A	N/A	190	N/A	N/A	N/A
27	OPC Calculated Used & Useful (%)	N/A	N/A	N/A	N/A	N/A	21.41%	N/A	N/A	N/A
28	U & U Per Order (%)	N/A	N/A	N/A	N/A	N/A	100.00%	N/A	N/A	N/A
29	SSU Requested U & U (%)	N/A	N/A	N/A	N/A	N/A	100.00%	N/A	N/A	N/A
30										
31	WATER TREATMENT PLANT:									
32	Water Treatment Equipment:									
33	Total Capacity (gpm)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
34	Reliable Capacity (gpm)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
35	OPC Calculated Used & Useful (%)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
36	U & U Per Order (%)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
37	SSU Requested U & U (%)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
38										
39	TRANSMISSION AND DISTRIBUTION:									
40	Finished Water Storage:									
41	Total Capacity (gal)						30,500		55,000	
42	Reliable Capacity (gal)	N/A	N/A	N/A	N/A	N/A	27,450	N/A	49,500	N/A
43	OPC Calculated Used & Useful (%)	N/A	N/A	N/A	N/A	N/A	90.42%	N/A	100.00%	N/A
44	U & U Per Order (%)	N/A	N/A	N/A	N/A	N/A	100.00%	N/A	100.00%	N/A
45	SSU Requested U & U (%)	N/A	N/A	N/A	N/A	N/A	100.00%	N/A	100.00%	N/A
46										
47	Hydropneumatic Tanks:									
48	Total Capacity (gal)	3,000	N/A	3,000	3,000	5,000	10,000	N/A	10,000	N/A
49	OPC Calculated Used & Useful (%)	88.33%	N/A	73.33%	100.00%	50.00%	18.00%	N/A	55.00%	N/A
50	U & U Per Order (%)	87.50%	N/A	100.00%	100.00%	75.00%	54.00%	N/A	71.30%	N/A
51	SSU Requested U & U (%)	100.00%	N/A	100.00%	100.00%	100.00%	100.00%	N/A	100.00%	N/A
52										
53	USED AND USEFUL CALCULATIONS									
	Water Transmission & Distribution System									
54	Schedule F-7(W)									
55	TRANSMISSION AND DISTRIBUTION:									
56	Connected Lots in 1996 w/o M.R.	95	113	52	244	262	252	113	991	61
57	Connected Lots in 1994 w/o M.R.	95	112	52	241	249	280	113	979	61
58	Connected Lots in 1994 w/ M.R.	95	113	52	243	257	250	113	984	61
59	Number of Lots	125	166	53	241	546	387	135	1,673	68
60	OPC Calculated Used & Useful (%)	76.00%	68.07%	86.11%	100.00%	47.97%	65.19%	83.70%	59.22%	89.71%
61	U & U Per Order (%)	100.00%	70.00%	100.00%	100.00%	44.00%	61.50%	100.00%	68.40%	100.00%
62	SSU Requested U & U (%)	100.00%	70.00%	100.00%	100.00%	49.02%	66.33%	100.00%	68.40%	100.00%
63										
64	ERC CALCULATIONS (by SSU)									
65	Combined Schedule of F- 8 & 9 (W)	Water	Water	Water	Water	Water	Water	Water	Water	Water
66	Year	ERC	ERC	ERC	ERC	ERC	ERC	ERC	ERC	ERC
67	1990	94	111	51	238	236	235	112	1,148	61
68	1991	92	116	52	241	239	240	113	1,140	60
69	1992	91	116	51	242	247	243	113	1,152	59
70	1993	95	112	51	243	255	242	112	1,167	60
71	1994	96	114	52	243	254	243	113	1,173	61
72	1995	96	115	52	245	262	217	113	1,179	61
73	1995.5	96	115	52	245	265	218	113	1,183	61
74	1996	96	115	52	246	267	219	113	1,187	61

OPC USED AND USEFUL CALCULATIONS
Water Treatment Plant - Schedule F-5 (W)

Line No.										
	Lake Ajay	Lake Brantley	Lake Conway	Lake Harriet	Lakeview Villas	Leland Heights	Leisure Lakes	Marco Shores	Marion Oaks	Meredith Manor
Docket No. 950495-WS										
Company: Southern States Utilities, Inc.										
Schedule Year Ended: 12/31/96	1996	1996	1996	1996	1996	1996	1996	1996	1996	1996
Projected [x]										
FPSC Uniform [x]; FPSC Non-Uniform [x]										
1 1994 MAX DAY FOR YEAR (GPD)	105,070	41,000	Water	140,000	12,200	381,500	66,000	479,966	1,058,000	400,300
2 1996 AVG MAX 5 DAYS IN MAX MONTH (GPD)	131,480	31,600	Purchased	116,839	7,620	255,124	51,229	403,171	972,926	357,260
3 1994 AVG MAX 5 DAYS IN MAX MONTH (GPD)	97,514	31,600	From	115,600	7,620	252,540	50,200	403,171	896,000	357,260
4 1996 ANNUAL AVG DAILY FLOW (GPD)	49,350	17,940	Orlando	73,370	2,251	142,564	24,503	135,064	601,295	232,154
5 1994 ANNUAL AVG DAILY FLOW (GPD)	36,601	17,940	Util. Comm.	72,592	2,251	141,120	24,011	135,064	553,753	232,154
6 FIRE STORAGE ACCEPTED (GAL)	0	0		0	0	0	0	0	0	0
7 FIRE FLOW PROVISION (GPM)	0	0		0	0	0	0	0	0	0
8 Unaccounted for Water Level (%)	9.1%	5.7%	5.7%	5.1%	0.6%	9.8%	14.7%	4.3%	7.7%	2.8%
9 Unaccounted for Water Allowed (%)	9.1%	5.7%	5.7%	5.1%	0.6%	9.8%	10.0%	4.3%	7.7%	2.8%
10										
11 SOURCE OF SUPPLY AND PUMPING:										
12 Supply Wells:	L	L	S	L	S	S	L		L	L
13 Total Capacity (gpm)	200	100	N/A	600	25	470	350	N/A	1,500	1,380
14 Reliable Capacity (gpm)	100	0	N/A	0	0	100	50	N/A	1,000	300
15 OPC Calculated Used & Useful (%)	45.65%	100.00%	N/A	100.00%	100.00%	100.00%	32.43%	N/A	45.04%	53.74%
16 U & U Per Order (%)	100.00%	100.00%	N/A	100.00%	100.00%	100.00%	100.00%	N/A	63.70%	80.10%
17 SSU Requested U & U (%)	100.00%	100.00%	N/A	100.00%	100.00%	100.00%	100.00%	N/A	100.00%	92.92%
18										
19 Auxiliary Power:										
20 Capacity (GPD), not provided	Unavailable					Unavailable	Unavailable	available	Unavailable	Unavailable
21 OPC Calculated Used & Useful (%)	45.65%					100.00%	32.43%	18.67%	45.04%	53.74%
22 SSU Requested U & U (%)	100.00%					100.00%	100.00%	100.00%	100.00%	100.00%
23										
24 High Service Pumping:										
25 Total Capacity (gpm)	320	100	N/A	400	N/A	N/A	400	2,700	1,200	1,150
26 Reliable Capacity (gpm)	160	0	N/A	0	N/A	N/A	200	1,500	600	350
27 OPC Calculated Used & Useful (%)	57.07%	100.00%	N/A	100.00%	N/A	N/A	16.95%	18.67%	100.00%	70.88%
28 U & U Per Order (%)	100.00%	100.00%	N/A	100.00%	N/A	N/A	100.00%	68.20%	100.00%	100.00%
29 SSU Requested U & U (%)	100.00%	100.00%	N/A	100.00%	N/A	N/A	100.00%	100.00%	100.00%	100.00%
30										
31 WATER TREATMENT PLANT:										
32 Water Treatment Equipment:										
33 Total Capacity (gpm)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	500	N/A	N/A
34 Reliable Capacity (gpm)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	500	N/A	N/A
35 OPC Calculated Used & Useful (%)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	56.00%	N/A	N/A
36 U & U Per Order (%)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	48.00%	N/A	N/A
37 SSU Requested U & U (%)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	100.00%	N/A	N/A
38										
39 TRANSMISSION AND DISTRIBUTION:										
40 Finished Water Storage:										
41 Total Capacity (gal.)	15,000	8,000		25,000			15,000	500,000	1,000,000	50,000
42 Reliable Capacity (gal.)	13,500	7,200	N/A	22,500	N/A	N/A	13,500	367,123	900,000	45,000
43 OPC Calculated Used & Useful (%)	100.00%	100.00%	N/A	100.00%	N/A	N/A	77.84%	13.51%	30.06%	100.00%
44 U & U Per Order (%)	100.00%	100.00%	N/A	100.00%	N/A	N/A	100.00%	58.90%	100.00%	100.00%
45 SSU Requested U & U (%)	100.00%	100.00%	N/A	100.00%	N/A	N/A	100.00%	100.00%	100.00%	100.00%
46										
47 Hydropneumatic Tanks:										
48 Total Capacity (gal.)	3,000	1,000	N/A	5,000	1,000	20,000	10,000	10,000	27,000	10,000
49 OPC Calculated Used & Useful (%)	33.33%	100.00%	N/A	100.00%	25.00%	18.50%	30.00%	N/A	18.52%	100.00%
50 U & U Per Order (%)	100.00%	100.00%	N/A	100.00%	30.00%	59.00%	100.00%	100.00%	100.00%	100.00%
51 SSU Requested U & U (%)	100.00%	100.00%	N/A	100.00%	100.00%	100.00%	100.00%	100.00%	100.00%	100.00%
52										
53 USED AND USEFUL CALCULATIONS										
Water Transmission & Distribution System										
54 Schedule F-7(W)										
55 TRANSMISSION AND DISTRIBUTION:										
56 Connected Lots in 1996 w/o M.R.	111	67	84	282	12	395	252	518	2,709	639
57 Connected Lots in 1994 w/o M.R.	82	67	84	279	12	391	247	518	2,494	639
58 Connected Lots in 1994 w/ M.R.	96	67	84	280	12	393	385	518	2,601	639
59 Number of Lots	100	73	89	302	23	413	584	584	12,262	867
60 OPC Calculated Used & Useful (%)	100.00%	91.78%	94.38%	93.38%	52.17%	85.64%	43.18%	88.70%	22.09%	73.70%
61 U & U Per Order (%)	44.35%	100.00%	97.00%	100.00%	100.00%	100.00%	75.00%	70.70%	34.40%	85.20%
62 SSU Requested U & U (%)	100.00%	100.00%	97.00%	100.00%	100.00%	100.00%	75.00%	100.00%	66.83%	85.20%
63										
64 ERC CALCULATIONS (by SSU)										
65 Combined Schedule of F- 8 & 9 (W)										
Year	Water	Water	Water	Water	Water	Water	Water	Water	Water	Water
66 1990	ERC	ERC	ERC	ERC	ERC	ERC	ERC	ERC	ERC	ERC
67 1991	28	65	85	273	14	385	236	417	2,181	730
68 1992	38	65	84	273	13	386	242	410	2,316	734
69 1993	54	66	85	275	13	388	243	405	2,412	730
70 1994	74	65	85	278	12	390	243	408	2,526	730
71 1995	89	67	84	280	12	391	244	432	2,644	734
72 1995.5	104	67	84	281	12	393	247	432	2,757	734
73 1996	112	67	84	282	12	394	248	432	2,814	734
74 1996	120	67	84	283	12	395	249	432	2,871	734

OPC USED AND USEFUL CALCULATIONS
Water Treatment Plant - Schedule F-3 (W)

Line No.	Docket No. 950495-WS	Morningview	Oak Forest	Oakwood	Palisades	Palm Port	Palm Terrace	Palm Mobile Home Park	Picciola Island	Pine Ridge
	Company: Southern States Utilities, Inc.									
	Schedule Year Ended: 12/31/96	1996	1996	1996	1996	1996	1996	1996	1996	1996
	Projected [x]									
	FPSC Uniform [x]; FPSC Non-Uniform [x]									
1	1994 MAX DAY FOR YEAR (GPD)	28,900	140,000	Water	146,000	41,700	183,800	12,990	83,100	793,000
2	1996 AVG MAX 5 DAYS IN MAX MONTH (GPD)	17,540	114,637	Purchased	174,771	35,218	151,912	10,574	81,324	820,099
3	1994 AVG MAX 5 DAYS IN MAX MONTH (GPD)	17,540	111,600	From	122,100	32,560	151,660	10,574	78,420	670,000
4	1996 ANNUAL AVG DAILY FLOW (GPD)	11,245	46,900	Brevard	69,894	18,415	71,773	4,453	39,071	426,945
5	1994 ANNUAL AVG DAILY FLOW (GPD)	11,245	45,658	County	48,830	17,025	71,654	4,453	37,676	348,803
6	FIRE STORAGE ACCEPTED (GAL.)	0	0	0	0	0	0	0	0	0
7	FIRE FLOW PROVISION (GPM)	0	0	0	0	0	0	0	0	0
8	Unaccounted for Water Level (%)	8.0%	26.1%	4.2%	9.8%	12.4%	12.0%	2.4%	17.4%	5.7%
9	Unaccounted for Water Allowed (%)	8.0%	10.0%	4.2%	9.8%	10.0%	10.0%	2.4%	10.0%	5.7%
10										
11	SOURCE OF SUPPLY AND PUMPING:									
12	Supply Wells:	S	S	S	S	L	S	S	S	S
13	Total Capacity (gpm)	425	630	N/A	800	100	160	130	275	1,150
14	Reliable Capacity (gpm)	0	150	N/A	0	0	0	0	100	550
15	OPC Calculated Used & Useful (%)	100.00%	44.53%	N/A	100.00%	100.00%	100.00%	100.00%	67.98%	100.00%
16	U & U Per Order (%)	100.00%	100.00%	N/A	86.80%	100.00%	100.00%	26.50%	100.00%	100.00%
17	SSU Requested U & U (%)	100.00%	100.00%	N/A	100.00%	100.00%	100.00%	100.00%	100.00%	100.00%
18										
19	Auxiliary Power:									
20	Capacity (GPD), not provided		Unavailable					Unavailable	Unavailable	
21	OPC Calculated Used & Useful (%)		44.53%					67.98%	100.00%	
22	SSU Requested U & U (%)		100.00%					100.00%	100.00%	
23										
24	High Service Pumping:									
25	Total Capacity (gpm)	N/A	N/A	N/A	N/A	120	N/A	N/A	N/A	N/A
26	Reliable Capacity (gpm)	N/A	N/A	N/A	N/A	60	N/A	N/A	N/A	N/A
27	OPC Calculated Used & Useful (%)	N/A	N/A	N/A	N/A	39.78%	N/A	N/A	N/A	N/A
28	U & U Per Order (%)	N/A	N/A	N/A	N/A	29.50%	N/A	N/A	N/A	N/A
29	SSU Requested U & U (%)	N/A	N/A	N/A	N/A	100.00%	N/A	N/A	N/A	N/A
30										
31	WATER TREATMENT PLANT:									
32	Water Treatment Equipment:									
33	Total Capacity (gpm)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
34	Reliable Capacity (gpm)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
35	OPC Calculated Used & Useful (%)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
36	U & U Per Order (%)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
37	SSU Requested U & U (%)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
38										
39	TRANSMISSION AND DISTRIBUTION:									
40	Finished Water Storage:									
41	Total Capacity (gal.)					18,000				
42	Reliable Capacity (gal.)	N/A	N/A	N/A	N/A	16,200	N/A	N/A	N/A	N/A
43	OPC Calculated Used & Useful (%)	N/A	N/A	N/A	N/A	49.92%	N/A	N/A	N/A	N/A
44	U & U Per Order (%)	N/A	N/A	N/A	N/A	23.60%	N/A	N/A	N/A	N/A
45	SSU Requested U & U (%)	N/A	N/A	N/A	N/A	100.00%	N/A	N/A	N/A	N/A
46										
47	Hydropneumatic Tanks:									
48	Total Capacity (gal.)	4,500	10,000	N/A	15,000	5,000	3,000	1,500	5,000	16,000
49	OPC Calculated Used & Useful (%)	84.44%	48.00%	N/A	53.33%	20.00%	53.33%	86.67%	35.00%	37.50%
50	U & U Per Order (%)	100.00%	43.20%	N/A	80.00%	30.00%	80.00%	100.00%	53.00%	100.00%
51	SSU Requested U & U (%)	100.00%	100.00%	N/A	100.00%	100.00%	100.00%	100.00%	100.00%	100.00%
52										
53	USED AND USEFUL CALCULATIONS									
	Water Transmission & Distribution System									
54	Schedule F-7(W)									
55	TRANSMISSION AND DISTRIBUTION:									
56	Connected Lots in 1996 w/o M.R.	36	145	206	49	106	1,183	59	137	818
57	Connected Lots in 1994 w/o M.R.	36	141	201	34	98	1,181	59	132	668
58	Connected Lots in 1994 w/ M.R.	36	143	203	40	103	1,181	59	135	743
59	Number of Lots	42	287	191	141	137	1,213	87	213	3,828
60	OPC Calculated Used & Useful (%)	85.71%	50.49%	100.00%	34.52%	77.37%	87.52%	67.82%	64.30%	21.36%
61	U & U Per Order (%)	100.00%	50.70%	100.00%	6.30%	67.50%	100.00%	69.00%	100.00%	20.00%
62	SSU Requested U & U (%)	100.00%	51.28%	100.00%	40.08%	80.22%	100.00%	69.00%	100.00%	100.00%
63										
64	ERC CALCULATIONS (by SSU)									
65	Combined Schedule of F- 8 & 9 (W)	Water	Water	Water	Water	Water	Water	Water	Water	Water
66	Year	ERC	ERC	ERC	ERC	ERC	ERC	ERC	ERC	ERC
67	1990	44	140	189	2	86	1,199	59	125	776
68	1991	45	140	191	4	88	1,193	60	128	948
69	1992	45	143	195	19	94	1,195	59	130	1,103
70	1993	45	145	196	34	98	1,202	58	133	1,253
71	1994	46	147	201	51	98	1,204	59	135	1,415
72	1995	46	149	203	60	103	1,204	59	138	1,574
73	1995.5	46	150	204	67	105	1,205	59	139	1,653
74	1996	46	151	206	73	106	1,206	59	140	1,732

OPC USED AND USEFUL CALCULATIONS
Water Treatment Plant - Schedule F-5 (W)

Line No.	Description	Pine Ridge Estates	Piney Woods	Point O'Woods	Ponoma Park	Postmaster Village	Quail Ridge	River Grove	River Park	Rosemont Rolling Green
		1996	1996	1996	1996	1996	1996	1996	1996	1996
Docket No. 950495-WS										
Company: Southern States Utilities, Inc.										
Schedule Year Ended: 12/31/96										
Projected [x]										
FPSC Uniform [x]; FPSC Non-Uniform [x]										
1	1994 MAX DAY FOR YEAR (GPD)	124,000	112,967	132,000	84,600	114,500	27,000	49,100	74,400	153,000
2	1996 AVG MAX 5 DAYS IN MAX MONTH (GPD)	103,914	101,593	129,365	64,808	116,896	38,480	43,133	59,799	147,903
3	1994 AVG MAX 5 DAYS IN MAX MONTH (GPD)	98,788	99,800	120,200	62,740	112,540	22,200	43,133	58,300	140,000
4	1996 ANNUAL AVG DAILY FLOW (GPD)	51,873	53,646	77,342	38,030	45,728	9,076	23,715	34,230	57,388
5	1994 ANNUAL AVG DAILY FLOW (GPD)	49,314	52,699	71,863	36,616	44,024	5,236	23,715	33,372	54,321
6	FIRE STORAGE ACCEPTED (GAL)	0	0	0	0	0	0	0	0	0
7	FIRE FLOW PROVISION (GPM)	0	0	0	0	0	0	0	0	0
8	Unaccounted for Water Level (%)	11.8%	9.6%	16.2%	18.4%	10.0%	2.4%	8.2%	9.1%	8.8%
9	Unaccounted for Water Allowed (%)	10.0%	9.6%	10.0%	10.0%	10.0%	2.4%	8.2%	9.1%	8.8%
10										
11	SOURCE OF SUPPLY AND PUMPING:									
12	Supply Wells:	L	L	S	S	S	S	L	L	S
13	Total Capacity (gpm)	685	440	1,250	95	400	650	135	215	865
14	Reliable Capacity (gpm)	360	140	500	35	200	0	0	93	65
15	OPC Calculated Used & Useful (%)	10.35%	26.61%	16.85%	100.00%	52.77%	100.00%	100.00%	25.56%	100.00%
16	U & U Per Order (%)	100.00%	100.00%	100.00%	100.00%	100.00%	100.00%	100.00%	36.70%	100.00%
17	SSU Requested U & U (%)	34.14%	100.00%	100.00%	100.00%	100.00%	100.00%	100.00%	61.55%	100.00%
18										
19	Auxiliary Power:									
20	Capacity (GPD), not provided	Unavailable	Unavailable	Unavailable	Unavailable	Unavailable				Unavailable
21	OPC Calculated Used & Useful (%)	10.35%	26.61%	16.85%	100.00%	52.77%				100.00%
22	SSU Requested U & U (%)	100.00%	100.00%	100.00%	100.00%	100.00%				100.00%
23										
24	High Service Pumping:									
25	Total Capacity (gpm)	500	200	N/A	N/A	N/A	N/A	320	180	N/A
26	Reliable Capacity (gpm)	250	0	N/A	N/A	N/A	N/A	160	90	N/A
27	OPC Calculated Used & Useful (%)	26.35%	100.00%	N/A	N/A	N/A	N/A	18.72%	48.14%	N/A
28	U & U Per Order (%)	100.00%	100.00%	N/A	N/A	N/A	N/A	32.30%	75.90%	N/A
29	SSU Requested U & U (%)	100.00%	100.00%	N/A	N/A	N/A	N/A	42.91%	100.00%	N/A
30										
31	WATER TREATMENT PLANT:									
32	Water Treatment Equipment:									
33	Total Capacity (gpm)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
34	Reliable Capacity (gpm)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
35	OPC Calculated Used & Useful (%)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
36	U & U Per Order (%)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
37	SSU Requested U & U (%)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
38										
39	TRANSMISSION AND DISTRIBUTION:									
40	Finished Water Storage:									
41	Total Capacity (gal.)	15,000	25,000					15,000	5,000	
42	Reliable Capacity (gal.)	13,500	22,500	N/A	N/A	N/A	N/A	13,500	4,500	N/A
43	OPC Calculated Used & Useful (%)	100.00%	100.00%	N/A	N/A	N/A	N/A	79.05%	100.00%	N/A
44	U & U Per Order (%)	100.00%	100.00%	N/A	N/A	N/A	N/A	92.00%	100.00%	N/A
45	SSU Requested U & U (%)	100.00%	100.00%	N/A	N/A	N/A	N/A	100.00%	100.00%	N/A
46										
47	Hydropneumatic Tanks:									
48	Total Capacity (gal.)	3,500	7,000	10,000	5,000	8,000	6,500	3,000	4,500	10,000
49	OPC Calculated Used & Useful (%)	92.86%	42.86%	75.00%	12.00%	25.00%	100.00%	45.00%	27.11%	80.00%
50	U & U Per Order (%)	92.00%	90.00%	100.00%	18.00%	41.00%	100.00%	67.50%	83.00%	35.00%
51	SSU Requested U & U (%)	100.00%	100.00%	100.00%	100.00%	100.00%	100.00%	100.00%	100.00%	100.00%
52										
53	USED AND USEFUL CALCULATIONS									
Water Transmission & Distribution System										
54	Schedule F-7(W)									
55	TRANSMISSION AND DISTRIBUTION:									
56	Connected Lots in 1996 w/o M.R.	217	170	367	172	161	26	104	359	131
57	Connected Lots in 1994 w/o M.R.	206	167	341	166	155	15	104	350	124
58	Connected Lots in 1994 w/ M.R.	207	169	358	169	158	22	104	355	129
59	Number of Lots	292	215	415	535	345	114	119	754	150
60	OPC Calculated Used & Useful (%)	74.22%	79.07%	88.43%	32.10%	48.67%	22.81%	87.39%	47.61%	87.33%
61	U & U Per Order (%)	100.00%	76.50%	83.50%	32.00%	44.70%	15.80%	100.00%	44.80%	87.00%
62	SSU Requested U & U (%)	100.00%	79.44%	90.43%	32.72%	47.75%	25.20%	100.00%	48.11%	89.23%
63										
64	ERC CALCULATIONS (by SSU)									
65	Combined Schedule of F- 8 & 9 (W)	Water	Water	Water	Water	Water	Water	Water	Water	Water
66	Year	ERC	ERC	ERC	ERC	ERC	ERC	ERC	ERC	ERC
67	1990	169	163	304	171	141	0	104	334	113
68	1991	171	165	329	171	146	6	104	339	120
69	1992	173	166	342	174	148	15	104	343	123
70	1993	186	167	342	180	151	16	104	347	124
71	1994	212	167	341	182	155	15	104	350	124
72	1995	213	169	358	185	158	22	104	355	129
73	1995.5	218	169	362	187	160	24	104	357	130
74	1996	223	170	367	188	161	26	104	359	131

OPC USED AND USEFUL CALCULATIONS
Water Treatment Plant - Schedule F-5 (W)

Line No.	Docket No. 950495-WS	Salt Springs	Semira Villas	Silver Lakes West Shores	Silver Lake Oaks	Slycrest	St. Johns Highlands	Stone Mountain	Sugar Hill	Sugar Hill Woods
	Company: Southern States Utilities, Inc.									
	Schedule Year Ended: 12/31/96	1996	1996	1996	1996	1996	1996	1996	1996	1996
	Projected [x]									
	FPSC Uniform [x], FPSC Non-Uniform [x]									
1	1994 MAX DAY FOR YEAR (GPD)	202,000	8,900	1,857,200	15,700	61,700	42,800	24,600	200,000	2,806,000
2	1996 AVG MAX 5 DAYS IN MAX MONTH (GPD)	195,383	4,847	1,889,654	8,727	60,758	34,111	22,880	165,383	2,796,369
3	1994 AVG MAX 5 DAYS IN MAX MONTH (GPD)	193,000	4,847	1,796,720	8,727	59,200	32,907	20,020	158,000	2,479,400
4	1996 ANNUAL AVG DAILY FLOW (GPD)	93,150	2,472	878,354	5,208	24,086	13,974	8,241	111,469	1,187,768
5	1994 ANNUAL AVG DAILY FLOW (GPD)	92,014	2,472	835,156	5,208	23,468	13,481	7,211	106,493	1,053,134
6	FIRE STORAGE ACCEPTED (GAL.)	0	0	0	0	0	0	0	0	0
7	FIRE FLOW PROVISION (GPM)	0	0	0	0	0	0	0	0	0
8	Unaccounted for Water Level (%)	3.6%	2.1%	7.3%	4.1%	17.1%	39.2%	58.8%	7.7%	6.0%
9	Unaccounted for Water Allowed (%)	3.6%	2.1%	7.3%	4.1%	10.0%	10.0%	10.0%	7.7%	6.0%
10										
11	SOURCE OF SUPPLY AND PUMPING:									
12	Supply Wells:	S	S	L	L	S	L	S	L	L
13	Total Capacity (gpm)	633	85	2,850	40	675	75	100	730	4,800
14	Reliable Capacity (gpm)	133	0	1,450	0	175	0	0	210	4,200
15	OPC Calculated Used & Useful (%)	100.00%	100.00%	90.50%	100.00%	22.40%	100.00%	100.00%	36.86%	40.46%
16	U & U Per Order (%)	100.00%	100.00%	100.00%	100.00%	100.00%	100.00%	21.00%	57.00%	100.00%
17	SSU Requested U & U (%)	100.00%	100.00%	100.00%	100.00%	100.00%	100.00%	100.00%	77.84%	71.46%
18										
19	Auxiliary Power:									
20	Capacity (GPD), not provided	Unavailable		Unavailable		Unavailable		Unavailable		Unavailable
21	OPC Calculated Used & Useful (%)	100.00%		22.40%		36.86%		40.46%		
22	SSU Requested U & U (%)	100.00%		100.00%		100.00%		100.00%		
23										
24	High Service Pumping:									
25	Total Capacity (gpm)	N/A	N/A	3,460	140	N/A	120	N/A	2,250	3,600
26	Reliable Capacity (gpm)	N/A	N/A	2,745	70	N/A	60	N/A	1,200	2,400
27	OPC Calculated Used & Useful (%)	N/A	N/A	47.81%	8.86%	N/A	27.95%	N/A	9.57%	80.91%
28	U & U Per Order (%)	N/A	N/A	N/A	N/A	N/A	100.00%	N/A	100.00%	N/A
29	SSU Requested U & U (%)	N/A	N/A	100.00%	31.15%	N/A	100.00%	N/A	100.00%	100.00%
30										
31	WATER TREATMENT PLANT:									
32	Water Treatment Equipment:									
33	Total Capacity (gpm)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	350	N/A
34	Reliable Capacity (gpm)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	350	N/A
35	OPC Calculated Used & Useful (%)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	32.81%	N/A
36	U & U Per Order (%)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	48.10%	N/A
37	SSU Requested U & U (%)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	48.10%	N/A
38										
39	TRANSMISSION AND DISTRIBUTION:									
40	Finished Water Storage:									
41	Total Capacity (gal.)				12,000		16,000		500,000	500,000
42	Reliable Capacity (gal.)	N/A	N/A	N/A	5,400	N/A	14,400	N/A	400,564	450,000
43	OPC Calculated Used & Useful (%)	N/A	N/A	N/A	21.70%	N/A	30.92%	N/A	11.15%	100.00%
44	U & U Per Order (%)	N/A	N/A	N/A	50.00%	N/A	100.00%	N/A	73.30%	N/A
45	SSU Requested U & U (%)	N/A	N/A	N/A	100.00%	N/A	100.00%	N/A	100.00%	100.00%
46										
47	Hydropneumatic Tanks:									
48	Total Capacity (gal.)	15,000	1,500	15,000	1,000	5,000	3,000	1,000	15,000	60,000
49	OPC Calculated Used & Useful (%)	33.33%	56.67%	83.33%	40.00%	100.00%	25.00%	100.00%	8.00%	10.00%
50	U & U Per Order (%)	53.30%	85.00%	100.00%	60.00%	100.00%	49.00%	100.00%	100.00%	67.00%
51	SSU Requested U & U (%)	100.00%	100.00%	100.00%	100.00%	100.00%	100.00%	100.00%	100.00%	100.00%
52										
53	USED AND USEFUL CALCULATIONS									
	Water Transmission & Distribution System									
54	Schedule F-7(W)									
55	TRANSMISSION AND DISTRIBUTION:									
56	Connected Lots in 1996 w/o M.R.	115	2	1,285	26	117	85	8	648	2,632
57	Connected Lots in 1994 w/o M.R.	114	2	1,222	26	114	82	7	619	2,333
58	Connected Lots in 1994 w/ M.R.	114	2	1,265	26	116	84	7	636	2,508
59	Number of Lots	160	3	1,648	53	122	118	22	661	8,252
60	OPC Calculated Used & Useful (%)	72.13%	66.67%	77.99%	49.06%	95.90%	72.03%	36.36%	87.97%	31.89%
61	U & U Per Order (%)	78.00%	100.00%	100.00%	50.90%	100.00%	69.80%	25.00%	86.90%	22.40%
62	SSU Requested U & U (%)	100.00%	100.00%	100.00%	50.90%	100.00%	72.46%	36.36%	99.51%	33.39%
63										
64	ERC CALCULATIONS (by SSU)									
65	Combined Schedule of F- 8 & 9 (W)	Water	Water	Water	Water	Water	Water	Water	Water	Water
66	Year	ERC	ERC	ERC	ERC	ERC	ERC	ERC	ERC	ERC
67	1990	154	13	1,368	27	108	79	6	591	3,929
68	1991	158	13	1,503	26	111	79	6	624	4,250
69	1992	161	13	1,582	25	113	81	7	636	4,598
70	1993	156	13	1,472	24	113	83	7	636	4,862
71	1994	162	13	1,508	26	114	82	7	642	4,928
72	1995	162	13	1,561	26	116	84	7	660	5,297
73	1995.5	163	13	1,574	26	117	84	8	666	5,427
74	1996	164	13	1,586	26	117	85	8	672	5,558

OPC USED AND USEFUL CALCULATIONS
Water Treatment Plant - Schedule F-5 (W)

Line No.		Sunny Hills (99-11 144)	Sunny Hills (99-11 9)	Sunshine Parkway	Tropical Park	University Shores	Venetian Village	Welaka/ Saratoga Harbor	Westmont	Windsong
		1996	1996	1996	1996	1996	1996	1996	1996	1996
Docket No. 950495-WS										
Company: Southern States Utilities, Inc.										
Schedule Year Ended: 12/31/96										
Projected [x]										
FPSC Uniform [x]; FPSC Non-Uniform [x]										
1	1994 MAX DAY FOR YEAR (GPD)	311,500	19,000	186,900	187,700	1,658,600	65,600	55,000		44,800
2	1996 AVG MAX 5 DAYS IN MAX MONTH (GPD)	269,400	8,400	157,043	152,257	1,775,860	45,756	40,102	Purchased	36,088
3	1994 AVG MAX 5 DAYS IN MAX MONTH (GPD)	269,400	8,400	118,740	151,980	1,559,860	43,500	38,940	From	35,420
4	1996 ANNUAL AVG DAILY FLOW (GPD)	159,592	3,000	98,981	58,412	1,071,474	26,111	17,395	Orange	16,249
5	1994 ANNUAL AVG DAILY FLOW (GPD)	159,592	3,000	74,839	58,306	941,149	24,824	16,891	County	15,948
6	FIRE STORAGE ACCEPTED (GAL.)	0	0	270,000	0	0	0	0		0
7	FIRE FLOW PROVISION (GPM)	0	0	2,000	0	0	0	0		0
8	Unaccounted for Water Level (%)	4.0%	4.0%	5.4%	13.3%	3.6%	2.9%	6.9%	12.0%	2.0%
9	Unaccounted for Water Allowed (%)	4.0%	4.0%	5.4%	10.0%	3.6%	2.9%	6.9%	10.0%	2.0%
10										
11	SOURCE OF SUPPLY AND PUMPING:									
12	Supply Wells:	L	S	L	S	L	S	L	S	S
13	Total Capacity (gpm)	650	200	2,000	200	5,100	310	296	N/A	180
14	Reliable Capacity (gpm)	300	0	1,000	0	3,600	100	110	N/A	0
15	OPC Calculated Used & Useful (%)	36.94%	100.00%	6.87%	100.00%	24.18%	41.31%	10.98%	N/A	100.00%
16	U & U Per Order (%)	63.90%	63.90%	100.00%	100.00%	100.00%	44.30%	29.80%	N/A	100.00%
17	SSU Requested U & U (%)	72.11%	100.00%	100.00%	100.00%	100.00%	100.00%	38.09%	N/A	100.00%
18										
19	Auxiliary Power:									
20	Capacity (GPD), not provided	Unavailable	Unavailable	Unavailable	Unavailable	Unavailable	Unavailable	Unavailable		
21	OPC Calculated Used & Useful (%)	36.94%	100.00%	6.87%	100.00%	24.18%	41.31%			
22	SSU Requested U & U (%)	100.00%	100.00%	100.00%	100.00%	100.00%	100.00%			
23										
24	High Service Pumping:									
25	Total Capacity (gpm)	500	N/A	3,400	N/A	7,980	N/A	300	N/A	N/A
26	Reliable Capacity (gpm)	300	N/A	2,600	N/A	3,980	N/A	150	N/A	N/A
27	OPC Calculated Used & Useful (%)	62.36%	N/A	81.12%	N/A	30.99%	N/A	18.57%	N/A	N/A
28	U & U Per Order (%)	100.00%	N/A	100.00%	N/A	72.30%	N/A	N/A	N/A	N/A
29	SSU Requested U & U (%)	100.00%	N/A	99.89%	N/A	100.00%	N/A	55.87%	N/A	N/A
30										
31	WATER TREATMENT PLANT:									
32	Water Treatment Equipment:									
33	Total Capacity (gpm)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
34	Reliable Capacity (gpm)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
35	OPC Calculated Used & Useful (%)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
36	U & U Per Order (%)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
37	SSU Requested U & U (%)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
38										
39	TRANSMISSION AND DISTRIBUTION:									
40	Finished Water Storage:									
41	Total Capacity (gal.)	60,000		108,000		612,000		40,000		
42	Reliable Capacity (gal.)	54,000	N/A	97,200	N/A	550,800	N/A	36,000	N/A	N/A
43	OPC Calculated Used & Useful (%)	100.00%	N/A	100.00%	N/A	87.54%	N/A	21.74%	N/A	N/A
44	U & U Per Order (%)	100.00%	N/A	100.00%	N/A	100.00%	N/A	N/A	N/A	N/A
45	SSU Requested U & U (%)	100.00%	N/A	100.00%	N/A	100.00%	N/A	55.87%	N/A	N/A
46										
47	Hydropneumatic Tanks:									
48	Total Capacity (gal.)	20,000	7,500	10,000	10,000	20,000	4,000	4,500	N/A	4,000
49	OPC Calculated Used & Useful (%)	17.50%	26.67%	100.00%	20.00%	75.00%	52.50%	41.33%	N/A	45.00%
50	U & U Per Order (%)	93.00%	100.00%	100.00%	100.00%	100.00%	66.00%	45%/100%	N/A	56.00%
51	SSU Requested U & U (%)	100.00%	100.00%	100.00%	100.00%	100.00%	100.00%	100.00%	N/A	100.00%
52										
53	USED AND USEFUL CALCULATIONS									
	Water Transmission & Distribution System									
54	Schedule F-7(W)									
55	TRANSMISSION AND DISTRIBUTION:									
56	Connected Lots in 1996 w/o M.R.	435	4	14	533	3,800	142	134	137	107
57	Connected Lots in 1994 w/o M.R.	435	4	11	532	3,338	135	130	129	105
58	Connected Lots in 1994 w/ M.R.	435	4	13	532	3,574	139	132	134	106
59	Number of Lots	5,377	491	40	671	5,100	223	249	167	106
60	OPC Calculated Used & Useful (%)	8.09%	0.81%	36.01%	79.43%	74.51%	63.68%	63.78%	82.04%	100.00%
61	U & U Per Order (%)	11.00%	N/A	100.00%	81.40%	100.00%	61.70%	54.00%	100.00%	100.00%
62	SSU Requested U & U (%)	28.09%	28.09%	100.00%	81.40%	100.00%	65.13%	54.00%	100.00%	100.00%
63										
64	ERC CALCULATIONS (by SSU)									
65	Combined Schedule of F-8 & 9 (W)	Water	Water	Water	Water	Water	Water	Water	Water	Water
66	Year	ERC	ERC	ERC	ERC	ERC	ERC	ERC	ERC	ERC
67	1990	619	4	39	544	2,777	123	129	117	102
68	1991	604	4	42	545	2,951	129	129	121	105
69	1992	607	4	56	544	3,233	133	130	127	105
70	1993	614	4	67	545	3,548	134	132	129	106
71	1994	602	4	62	549	3,748	135	134	129	106
72	1995	602	4	74	549	4,013	139	136	134	107
73	1995.5	602	4	78	549	4,140	141	137	136	108
74	1996	602	4	82	550	4,267	142	138	137	108

OPC USED AND USEFUL CALCULATIONS
Water Treatment Plant - Schedule F-5 (W)

Line No.	Woodmere		Zephyr Shores	Buenaventura Lakes	Deep Creek	Enterprise	Geneva Lake Estates	Keystone Club Estates
	1996	1996	1996	1996	1996	1996	1996	1996
Docket No. 950495-WS Company: Southern States Utilities, Inc. Schedule Year Ended: 12/31/96 Projected [x] FPSC Uniform [x]; FPSC Non-Uniform [x]								
1	1,479,000	8,120	121,000	2,753,000	All Water	All Water	104,500	229,000
2	1,463,718	8,855	91,187	2,769,385	Purchased From	Purchased From	96,603	132,851
3	1,398,000	7,792	89,600	2,610,400	Charlottee County	Deltona Lakes	90,540	126,000
4	888,133	3,114	54,982	1,815,263			39,711	39,183
5	848,258	2,740	54,025	1,711,052			37,219	37,162
6	0	0	0	141,864			0	0
7	0	0	0	1,182			0	0
8	38.6%	6.9%	5.0%	13.5%	2.9%	11.6%	17.2%	12.6%
9	10.0%	6.9%	5.0%	10.0%	2.9%	10.0%	10.0%	10.0%
11 SOURCE OF SUPPLY AND PUMPING:								
12	Supply Wells:		L	S	S	L	S	S
13	3,000	25	120	4,700	N/A	N/A	280	450
14	1,000	0	0	2,200	N/A	N/A	100	375
15	44.04%	100.00%	100.00%	55.29%	N/A	N/A	80.93%	31.15%
16	48.30%	90.00%	100.00%	63.20%	N/A	N/A	N/A	N/A
17	100.00%	100.00%	100.00%	92.14%	N/A	N/A	100.00%	53.93%
18								
19	Auxiliary Power:							
20	Unavailable			Unavailable			Unavailable	Unavailable
21	44.04%			55.29%			80.93%	31.15%
22	100.00%			100.00%			100.00%	100.00%
23								
24	High Service Pumping:							
25	3,100	N/A	N/A	7,400	N/A	N/A	N/A	N/A
26	2,000	N/A	N/A	4,400	N/A	N/A	N/A	N/A
27	36.29%	N/A	N/A	68.05%	N/A	N/A	N/A	N/A
28	100.00%	N/A	N/A	63.2%	N/A	N/A	N/A	N/A
29	100.00%	N/A	N/A	100.0%	N/A	N/A	N/A	N/A
30								
31	WATER TREATMENT PLANT:							
32	Water Treatment Equipment:							
33	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
34	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
35	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
36	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
37	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
38								
39	TRANSMISSION AND DISTRIBUTION:							
40	Finished Water Storage:							
41	455,000			1,206,000				
42	409,500	N/A	N/A	1,085,400	N/A	N/A	N/A	N/A
43	69.68%	N/A	N/A	84.39%	N/A	N/A	N/A	N/A
44	100.00%	N/A	N/A	60.1%	N/A	N/A	N/A	N/A
45	100.00%	N/A	N/A	100.0%	N/A	N/A	N/A	N/A
46								
47	Hydropneumatic Tanks:							
48	10,000	500	7,500	N/A	N/A	N/A	3,000	8,000
49	100.00%	50.00%	16.00%	N/A	N/A	N/A	60.00%	46.88%
50	100.00%	75.00%	17.10%	N/A	N/A	N/A	N/A	N/A
51	100.00%	100.00%	100.00%	N/A	N/A	N/A	100.00%	100.00%
52								
53	USED AND USEFUL CALCULATIONS							
Water Transmission & Distribution System								
54	Schedule F-7(W)							
55	TRANSMISSION AND DISTRIBUTION:							
56	1,207	25	499	7,515	3,311	236	93	159
57	1,153	22	490	7,083	2,940	218	87	151
58	1,172	24	495	7,287	3,166	225	90	154
59	1,189	52	647	6,725	7,171	279	139	250
60	100.00%	48.88%	77.10%	100.00%	46.17%	84.71%	67.11%	63.64%
61	98.50%	28.90%	85.40%	N/A	N/A	N/A	N/A	N/A
62	100.00%	51.25%	85.40%	100.00%	48.19%	86.78%	69.13%	65.77%
63								
64	ERC CALCULATIONS (by SSU)							
65	Combined Schedule of F-8 & 9 (W)							
66	Year	Water ERC	Water ERC	Water ERC	Water ERC	Water ERC	Water ERC	Water ERC
67	1990	1,235	17	479		2,801.5	202.5	96.0
68	1991	1,244	18	518		3,087.0	216.5	97.5
69	1992	1,277	20	511		3,334.5	226.3	100.5
70	1993	1,333	21	496		3,450.8	241.3	107.5
71	1994	1,404	22	508	7,075.0	3,479.0	258.3	112.0
72	1995	1,427	24	513	7,278.3	3,746.2	269.6	115.3
73	1995.5	1,448	24	515	7,395.8	3,832.1	276.4	117.4
74	1996	1,470	25	517	7,505.9	3,918.0	283.2	119.5

OPC USED AND USEFUL CALCULATIONS
Water Treatment Plant - Schedule F-5 (W)

Line No.	Lakeside			Remington Forest			Spring Gardens		Valencia Terrace	
	1996	1996	1996	1996	1996	1996	1996	1996	1996	
Docket No. 950495-W5 Company: Southern States Utilities, Inc. Schedule Year Ended: 12/31/96 Projected [x] FPSC Uniform [x]; FPSC Non-Uniform [x]										
1	544,000	1,711,000	11,871,000	All Water	87,780	55,050	224,700			
2	317,003	1,727,685	10,439,248	Purchased	96,041	52,534	218,000			
3	298,800	1,661,200	9,924,600	From	77,540	49,530	218,000			
4	96,945	1,371,878	6,488,319	Intercoastal	37,453	24,453	133,344			
5	91,378	1,319,085	6,168,449	Utilities	30,238	23,055	133,344			
6	0	240,000	771,472		0	0	0			
7	0	2,000	3,214		0	0	0			
8	100.0%	13.6%	4.0%	8.8%	15.5%	19.8%	49.7%			
9	10.0%	10.0%	4.0%	8.8%	10.0%	10.0%	10.0%			
SOURCE OF SUPPLY AND PUMPING:										
12	Supply Wells:			S	L	L	S	L	S	S
13	1,400	1,900	9,831	N/A	48	180	1,100			
14	400	1,444	7,747	N/A	0	90	350			
15	5.50%	83.60%	73.74%	N/A	100.00%	36.56%	26.08%			
16	N/A	100.00%	100.00%	N/A	N/A	N/A	N/A			
17	100.00%	100.00%	95.99%	N/A	100.00%	100.00%	100.00%			
19	Auxiliary Power:									
20		Unavailable	Unavailable	Unavailable			Unavailable			
21		5.50%	63.60%	73.74%			26.08%			
22		100.00%	100.00%	100.00%			100.00%			
24	High Service Pumping:									
25	N/A	4,250	22,700	N/A	600	N/A	N/A			
26	N/A	3,000	17,700	N/A	220	N/A	N/A			
27	N/A	100.00%	59.12%	N/A	28.65%	N/A	N/A			
28	N/A	100.0%		N/A	N/A	N/A	N/A			
29	N/A	100.0%	100.0%	N/A	100.0%	N/A	N/A			
31	WATER TREATMENT PLANT:									
32	Water Treatment Equipment:									
33	N/A	1,736	6,944	N/A	N/A	N/A	N/A			
34	N/A	1,736	6,944	N/A	N/A	N/A	N/A			
35	N/A	66.62%	100.00%	N/A	N/A	N/A	N/A			
36	N/A	78.30%	100.00%	N/A	N/A	N/A	N/A			
37	N/A	78.30%	100.00%	N/A	N/A	N/A	N/A			
39	TRANSMISSION AND DISTRIBUTION:									
40	Finished Water Storage:									
41		1,720,000	6,500,000		15,000					
42	N/A	1,048,052	3,635,143	N/A	13,500	N/A	N/A			
43	N/A	52.40%	61.78%	N/A	100.00%	N/A	N/A			
44	N/A	61.80%	100.00%	N/A	N/A	N/A	N/A			
45	N/A	88.00%	100.00%	N/A	100.00%	N/A	N/A			
47	Hydropneumatic Tanks:									
48	15,000	10,000	N/A	N/A	5,000	1,500	5,000			
49	66.67%	45.60%	N/A	N/A	9.60%	60.00%	100.00%			
50	N/A	100.00%	N/A	N/A	N/A	N/A	N/A			
51	100.00%	100.00%	N/A	N/A	100.00%	100.00%	100.00%			
53	USED AND USEFUL CALCULATIONS									
Water Transmission & Distribution System										
54	Schedule F-7(W)									
55	TRANSMISSION AND DISTRIBUTION:									
56	93	5,800	6,063	216	80	130	323			
57	87	5,577	5,783	201	65	122	323			
58	90	5,681	5,986	209	70	126	323			
59	252	7,789	14,014	210	87	180	340			
60	36.78%	74.48%	43.41%	100.00%	92.23%	72.06%	95.00%			
61	N/A	N/A	N/A	N/A	N/A	N/A	N/A			
62	37.73%	77.17%	100.00%	100.00%	100.00%	74.06%	95.00%			
64	ERC CALCULATIONS (by SSU)									
65	Combined Schedule of F- 8 & 9 (W)									
66	Year	Water ERC	Water ERC	Water ERC	Water ERC	Water ERC	Water ERC	Water ERC	Water ERC	
67	1990		8,128.0	12,915.5	196.3	24.5				
68	1991		8,300.5	13,795.0	204.3	28.0				
69	1992		8,473.5	14,150.5	211.5	33.5				
70	1993		8,668.0	14,136.0	219.8	48.5				
71	1994	87.0	8,897.5	13,983.0	225.8	65.8	122.0	323.0		
72	1995	89.6	9,063.8	14,473.6	234.8	71.1	125.7	323.0		
73	1995.5	90.9	9,158.7	14,509.8	238.6	76.3	127.5	323.0		
74	1996	92.3	9,253.6	14,708.1	242.4	81.5	129.4	323.0		

EXHIBIT TLB-3.1

**SUMMARY OF AVAILABLE FIRE FLOW TESTS RECORDS
OF
SSU WATER SYSTEMS
AND
OPC FIRE FLOW ALLOWANCE**

EXHIBIT TLB-4

**OPC USED AND USEFUL CALCULATIONS
OF
WASTEWATER SYSTEMS**

OPC USED AND USEFUL CALCULATIONS

Wastewater Treatment Plant Schedule F-4 (S) Docket No. 950495-WS Company: Southern States Utilities, Inc. Schedule Year Ended: 12/31/96 Projected [x]		Amelia Island	Apache Shores	Apple Valley	Beacon Hill	Beecher's Point	Burnt Store	Chufuota	Citrus Park	Citrus Springs
		1996	1996	1996	1996	1996	1996	1996	1996	1996
Line No.	FPSC Uniform [x] & Non-Uniform [x]			Treated by Altomonte Springs						
1	PERMITTED PLANT CAPACITY (GPD)	950,000	17,000	1,780,000	15,000	250,000	100,000	64,000	200,000	
2	EFFLUENT DISPOSAL CAPACITY (GPD)	950,000	17,000	N/A	1,780,000	15,000	250,000	100,000	64,000	200,000
3	1994 AVG DAILY FLOW OF MAX MONTH (GPD)	844,484	12,000	N/A	783,323	8,194	135,968	42,226	48,323	134,033
4	1996 AVG DAILY FLOW OF MAX MONTH (GPD)	611,480	12,000	N/A	848,580	6,072	153,394	43,186	49,055	135,366
5	Response to OPC Doc. Request No. 279									
6	EXCESS Inflow/Infiltration (%), by EPA guidelines	36.4%			25.9%					
7	EXCESS INFLOW/INFILTRATION (GPD)	307,392	0	0	2,122	0	0	0	0	0
8										
9	TREATMENT PLANT AND EFFLUENT DISPOSAL:									
10	Treatment Plant:									
11	OPC Calculated Used & Useful (%)	64.37%	70.59%	N/A	47.67%	40.48%	61.36%	43.19%	76.65%	67.68%
12	U & U Per Order (%)	94.30%	69.60%	N/A	62.90%	39.60%	48.00%	71.00%	100.00%	51.60%
13	SSU Requested U & U (%)	100.00%	70.59%	N/A	100.00%	54.62%	85.97%	71.00%	100.00%	69.51%
14	Effluent Disposal:									
15	OPC Calculated Used & Useful (%)	64.37%	70.59%	N/A	47.67%	40.48%	61.36%	43.19%	76.65%	67.68%
16	U & U Per Order (%)	94.30%	69.60%	N/A	69.60%	39.60%	48.00%	71.00%	100.00%	51.60%
17	SSU Requested U & U (%)	100.00%	70.59%	N/A	100.00%	54.62%	85.97%	71.00%	100.00%	69.51%
18	Reuse Facilities:									
19	OPC Calculated Used & Useful (%)	64.37%								
20	SSU Requested U & U (%)	100.00%								
21										
22	Auxiliary Power:									
23	Capacity (GPD), not provided	navailable		Unavailable						
24	OPC Calculated Used & Useful (%)	64.37%		47.67%						
25	SSU Requested U & U (%)	100.00%		100.00%						
26										
27	USED AND USEFUL CALCULATIONS									
Wastewater Collection System										
28	Schedule F-7(S)									
29										
30	COLLECTION AND SYSTEM PUMPING PLANT:									
31	Connected Lots in 1996 w/o M.R.	1,450	111	163	3,085	45	418	135	136	684
32	Connected Lots in 1994 w/ M.R.	1,363	111	163	2,917	45	385	134	134	680
33	Connected Lots in 1994 w/o M.R.	1,273	111	163	2,848	45	371	132	133	677
34	Number of Lots	2,467	195	188	3,178	62	4,347	155	155	1,084
35	Calculated Used & Useful (%)	58.77%	56.92%	86.70%	97.09%	72.58%	9.63%	87.10%	87.43%	63.09%
36	U & U Per Order (%)	93.70%	59.55%	100.00%	91.00%	73.40%	9.20%	82.90%	82.90%	28.00%
37	SSU Requested U & U (%)	93.70%	59.50%	100.00%	100.00%	73.40%	10.40%	87.90%	100.00%	63.38%
38										
39										
ERC CALCULATIONS (by SSU)										
Combined Schedule of F- 8 & 10 (S)										
	Year	Sewer ERC	Sewer ERC	Sewer ERC	Sewer ERC	Sewer ERC	Sewer ERC	Sewer ERC	Sewer ERC	Sewer ERC
	1990	1,382.0	116.0	175.0	2,450.0	45.0	342.0	127.0	251.0	687.0
	1991	1,571.0	113.0	175.0	2,524.0	45.0	379.0	130.0	247.0	693.0
	1992	1,707.0	113.0	173.0	2,609.0	45.0	398.0	131.0	248.0	696.0
	1993	1,783.0	112.0	175.0	2,870.0	45.0	455.0	131.0	258.0	697.0
	1994	1,935.0	111.0	180.0	3,229.0	45.0	554.0	132.0	264.0	704.0
	1995	2,071.0	111.0	180.0	3,307.0	45.0	575.0	134.0	265.0	707.0
	1995.5	2,137.0	111.0	180.0	3,403.0	45.0	600.0	134.0	266.0	709.0
	1996	2,203.0	111.0	180.0	3,498.0	45.0	625.0	135.0	268.0	711.0

OPC USED AND USEFUL CALCULATIONS

	Deltona Lakes	Fisherman's Haven	Florida Central Commerce Park	Fox Run	Holiday Haven	Jungle Den	Leilani Heights	Leisure Lakes
Wastewater Treatment Plant Schedule F-6 (S) Docket No. 950495-WS Company: Southern States Utilities, Inc. Schedule Year Ended: 12/31/96 Projected [x]								
Line No.	1996	1996	1996	1996	1996	1996	1996	1996
				Interconn. With Martin				
1	1,200,000	25,000	95,000	County	25,000	25,000	150,000	50,000
2	1,400,000	25,000	95,000	Utilities	25,000	25,000	150,000	50,000
3	1,132,710	17,467	56,267	to Treat	18,700	16,613	172,964	18,129
4	1,207,742	17,467	71,514		18,700	16,755	145,848	18,523
5	Response to OPC Doc. Request No. 279							
6							16.1%	
7	0	0	0		0	0	27,847	0
8								
9	TREATMENT PLANT AND EFFLUENT DISPOSAL:							
10	Treatment Plant:							
11	100.00%	69.87%	75.28%	N/A	74.80%	67.02%	97.23%	37.05%
12	95.00%	80.00%	44.00%	N/A	47.00%	65.00%	100.00%	65.70%
13	100.00%	80.00%	100.00%	N/A	74.80%	68.61%	100.00%	65.70%
14	Effluent Disposal:							
15	86.27%	69.87%	75.28%	N/A	74.80%	67.02%	97.23%	37.05%
16	95.00%	80.00%	44.00%	N/A	47.00%	65.00%	100.00%	65.70%
17	100.00%	80.00%	100.00%	N/A	74.80%	68.61%	100.00%	65.70%
18	Reuse Facilities:							
19	86.27%		75.28%					
20	100.00%		100.00%					
21								
22	Auxiliary Power:							
23	Unavailable		Unavailable				Unavailable	
24	100.00%		75.28%				97.23%	
25	100.00%		100.00%				100.00%	
26								
27	USED AND USEFUL CALCULATIONS							
Wastewater Collection System								
28	Schedule F-7(S)							
29								
30	COLLECTION AND SYSTEM PUMPING PLANT:							
31	4,659	141	56	106	94	118	399	235
32	4,619	141	51	102	94	117	398	233
33	4,595	141	44	97	94	117	397	230
34	5,000	144	71	109	166	135	413	385
35	93.18%	97.92%	78.18%	97.25%	56.63%	87.41%	96.61%	61.04%
36	100.00%	100.00%	43.00%	100.00%	61.40%	100.00%	100.00%	61.60%
37	100.00%	100.00%	84.26%	100.00%	61.40%	100.00%	100.00%	61.62%
38								
39								
ERC CALCULATIONS (by SSU)								
Combined Schedule of F- 8 & 10 (S)								
	Sewer	Sewer	Sewer	Sewer	Sewer	Sewer	Sewer	Sewer
	ERC	ERC	ERC	ERC	ERC	ERC	ERC	ERC
Year	4,860.0	142.0	86.0	82.0	95.0	114.0	393.0	221.0
1990	4,852.0	142.0	130.0	88.0	97.0	115.0	393.0	227.0
1991	4,895.0	140.0	146.0	92.0	97.0	116.0	394.0	229.0
1992	4,963.0	138.0	150.0	95.0	94.0	115.0	395.0	229.0
1993	5,025.0	141.0	155.0	97.0	96.0	117.0	397.0	230.0
1994	5,051.0	141.0	181.0	102.0	96.0	117.0	398.0	233.0
1995	5,073.0	141.0	189.0	104.0	96.0	118.0	398.0	234.0
1995.5	5,095.0	141.0	197.0	106.0	96.0	118.0	399.0	235.0
1996								

OPC USED AND USEFUL CALCULATIONS

Wastewater Treatment Plant Schedule F-6 (S) Docket No. 950495-WS Company: Southern States Utilities, Inc. Schedule Year Ended: 12/31/96		Marco Shores	Marion Oaks	Meredith Manor	Morning- view	Palm Port	Palm Terrace	Park Manor	Point O'Woods	Salt Springs
Projected [x]		1996	1996	1996	1996	1996	1996	1996	1996	1996
Line No.	FPSC Uniform [x] & Non-Uniform [x]			Interconn. With The City of						
1	PERMITTED PLANT CAPACITY (GPD)	110,000	200,000	Altamonte	20,000	50,000	130,000	15,000	58,000	85,000
2	EFFLUENT DISPOSAL CAPACITY (GPD)	110,000	200,000	Springs and	20,000	50,000	130,000	15,000	58,000	34,000
3	1994 AVG DAILY FLOW OF MAX MONTH (GPD)	62,000	170,129	Sanlando	8,710	25,233	147,742	13,194	20,226	29,129
4	1996 AVG DAILY FLOW OF MAX MONTH (GPD)	64,369	172,210	Utilities	8,710	27,550	148,175	15,134	23,622	29,129
5	Response to OPC Doc. Request No. 279									
6	EXCESS Inflow/Infiltration (%), by EPA guidelines									
7	EXCESS INFLOW/INFILTRATION (GPD)	0	0		0	0	0	0	0	0
8										
9	TREATMENT PLANT AND EFFLUENT DISPOSAL:									
10	Treatment Plant:									
11	OPC Calculated Used & Useful (%)	58.52%	86.10%	N/A	43.55%	55.10%	100.00%	100.00%	40.73%	34.27%
12	U & U Per Order (%)	66.80%	81.00%	N/A	77.00%	45.00%	62.50%	28.00%	28.60%	49.00%
13	SSU Requested U & U (%)	94.24%	90.36%	N/A	77.00%	63.83%	100.00%	100.00%	51.53%	49.00%
14	Effluent Disposal:									
15	OPC Calculated Used & Useful (%)	58.52%	86.10%	N/A	43.55%	55.10%	100.00%	100.00%	40.73%	85.67%
16	U & U Per Order (%)	66.80%	81.00%	N/A	77.00%	45.00%	96.00%	28.00%	28.60%	100.00%
17	SSU Requested U & U (%)	100.00%	90.36%	N/A	77.00%	63.83%	100.00%	100.00%	51.53%	100.00%
18	Reuse Facilities:									
19	OPC Calculated Used & Useful (%)								40.73%	
20	SSU Requested U & U (%)								100.00%	
21										
22	Auxiliary Power:									
23	Capacity (GPD), not provided									
24	OPC Calculated Used & Useful (%)									
25	SSU Requested U & U (%)									
26										
27	USED AND USEFUL CALCULATIONS									
Wastewater Collection System										
28	Schedule F-7(S)									
29										
30	COLLECTION AND SYSTEM PUMPING PLANT:									
31	Connected Lots in 1996 w/o M.R.	411	1,336	29	36	107	1,026	35	160	110
32	Connected Lots in 1994 w/ M.R.	400	1,323	28	36	103	1,024	33	152	110
33	Connected Lots in 1994 w/o M.R.	396	1,320	28	36	98	1,023	30	137	110
34	Number of Lots	584	1,610	34	48	137	1,189	35	191	185
35	Calculated Used & Useful (%)	70.44%	83.00%	84.78%	75.00%	78.10%	86.29%	99.38%	83.77%	59.46%
36	U & U Per Order (%)	50.20%	85.00%	100.00%	100.00%	67.00%	85.00%	96.90%	100.00%	100.00%
37	SSU Requested U & U (%)	85.62%	85.00%	100.00%	100.00%	80.40%	86.40%	100.00%	100.00%	100.00%
38										
39										
ERC CALCULATIONS (by SSU)										
Combined Schedule of F- 8 & 10 (S)										
	Year	Sewer ERC	Sewer ERC	Sewer ERC	Sewer ERC	Sewer ERC	Sewer ERC	Sewer ERC	Sewer ERC	Sewer ERC
	1990	274.0	1,335.0	33.0	46.0	86.0	1,019.0	26.0	109.0	153.0
	1991	288.0	1,333.0	33.0	48.0	89.0	1,013.0	30.0	121.0	151.0
	1992	288.0	1,340.0	34.0	45.0	95.0	1,015.0	33.0	134.0	149.0
	1993	294.0	1,361.0	34.0	45.0	98.0	1,023.0	33.0	137.0	146.0
	1994	314.0	1,390.0	34.0	46.0	98.0	1,023.0	34.0	137.0	151.0
	1995	317.0	1,393.0	34.0	46.0	103.0	1,024.0	37.0	152.0	151.0
	1995.5	322.0	1,400.0	35.0	46.0	105.0	1,025.0	38.0	156.0	151.0
	1996	326.0	1,407.0	35.0	46.0	107.0	1,026.0	39.0	160.0	151.0

OPC USED AND USEFUL CALCULATIONS

Wastewater Treatment Plant Schedule F-6 (S) Docket No. 950495-WS Company: Southern States Utilities, Inc. Schedule Year Ended: 12/31/96 Projected [x]		Silver Lake Oaks	South Forty	Suager Mill	Sugarmill Woods	Sunny Hills	Sunshine Parkway	University Shores	Venetian Village
		1996	1996	1996	1996	1996	1996	1996	1996
Line No.	FPSC Uniform [x] & Non-Uniform [x]								
1	PERMITTED PLANT CAPACITY (GPD)	12,000	50,000	270,000	400,000	50,000	250,000	1,145,000	36,000
2	EFFLUENT DISPOSAL CAPACITY (GPD)	12,000	50,000	270,000	500,000	50,000	150,000	1,145,000	36,000
3	1994 AVG DAILY FLOW OF MAX MONTH (GPD)	7,290	35,806	160,000	261,194	29,419	86,933	1,000,226	35,581
4	1996 AVG DAILY FLOW OF MAX MONTH (GPD)	7,290	13,508	167,886	293,645	29,583	3,710	1,130,484	36,808
5	Response to OPC Doc. Request No. 279								
6	EXCESS Inflow/Infiltration (%), by EPA guidelines		63.4%				96.5%		
7	EXCESS INFLOW/INFILTRATION (GPD)	0	22,701	0	0	0	83,890	0	0
8									
9	TREATMENT PLANT AND EFFLUENT DISPOSAL:								
10	Treatment Plant:								
11	OPC Calculated Used & Useful (%)	60.75%	27.02%	62.18%	73.41%	59.17%	1.48%	96.73%	100.00%
12	U & U Per Order (%)	13.00%	74.00%	78.00%	58.20%	51.00%	51.00%	93.10%	86.00%
13	SSU Requested U & U (%)	60.75%	79.88%	78.00%	90.46%	60.02%	56.78%	100.00%	100.00%
14	Effluent Disposal:								
15	OPC Calculated Used & Useful (%)	60.75%	27.02%	62.18%	58.73%	59.17%	2.47%	96.73%	100.00%
16	U & U Per Order (%)	13.00%	74.00%	78.00%	58.20%	51.00%	51.00%	93.10%	86.00%
17	SSU Requested U & U (%)	60.75%	79.88%	78.00%	72.36%	60.02%	94.63%	100.00%	100.00%
18	Reuse Facilities:								
19	OPC Calculated Used & Useful (%)						96.73%		
20	SSU Requested U & U (%)						100.00%		
21									
22	Auxiliary Power:								
23	Capacity (GPD), not provided				Unavailable	Unavailable		Unavailable	
24	OPC Calculated Used & Useful (%)				73.41%	59.17%		96.73%	
25	SSU Requested U & U (%)				100.00%	100.00%		100.00%	

27 USED AND USEFUL CALCULATIONS

Wastewater Collection System
Schedule F-7(S)

30 COLLECTION AND SYSTEM PUMPING PLANT:

31	Connected Lots in 1996 w/o M.R.	26	35	642	2,551	177	11	3,532	90
32	Connected Lots in 1994 w/ M.R.	26	34	630	2,432	176	10	3,338	89
33	Connected Lots in 1994 w/o M.R.	26	33	612	2,269	176	9	3,125	87
34	Number of Lots	53	52	661	8,252	504	56	4,275	107
35	Calculated Used & Useful (%)	49.06%	66.38%	97.08%	30.91%	35.12%	18.92%	82.61%	84.11%
36	U & U Per Order (%)	50.90%	94.00%	84.00%	21.10%	36.00%	100.00%	72.40%	81.90%
37	SSU Requested U & U (%)	50.90%	94.00%	99.00%	32.34%	36.00%	100.00%	87.12%	85.84%

ERC CALCULATIONS (by SSU)

Combined Schedule of F-8 & 10 (S)

Year	Sewer ERC	Sewer ERC	Sewer ERC	Sewer ERC	Sewer ERC	Sewer ERC	Sewer ERC	Sewer ERC
1990	27.0	55.0	576.0	3,844.0	176.0	55.0	2,545.0	80.0
1991	27.0	68.0	605.0	4,085.0	178.0	56.0	2,763.0	83.0
1992	25.0	68.0	619.0	4,422.0	178.0	67.0	2,996.0	84.0
1993	24.0	59.0	623.0	4,719.0	177.0	78.0	3,199.0	85.0
1994	26.0	65.0	629.0	4,773.0	179.0	73.0	3,371.0	87.0
1995	26.0	66.0	648.0	5,116.0	179.0	84.0	3,601.0	89.0
1995.5	26.0	67.0	654.0	5,241.0	179.0	86.0	3,706.0	89.0
1996	26.0	67.0	660.0	5,366.0	180.0	89.0	3,810.0	90.0

OPC USED AND USEFUL CALCULATIONS

Wastewater Treatment Plant Schedule F-6 (S)		Woodmere	Zephyr Shores	Buenaventura Lakes	Deep Creek	Enterprise	Lehigh	Marco Island
Docket No. 950495-WS								
Company: Southern States Utilities, Inc.								
Schedule Year Ended: 12/31/96		1996	1996	1996	1996	1996	1996	1996
Projected [x]					All	Plant taken		
Line No.	FPSC Uniform [x] & Non-Uniform [x]				Wastewater Treated	off line. Flow goes to		
1	PERMITTED PLANT CAPACITY (GPD)	500,000	40,000	1,800,000	By	Deltona	2,100,000	3,500,000
2	EFFLUENT DISPOSAL CAPACITY (GPD)	500,000	40,000	1,800,000	Charlotte	Lakes.	2,100,000	3,500,000
3	1994 AVG DAILY FLOW OF MAX MONTH (GPD)	466,226	27,258	1,614,839	County	45,097	1,773,710	2,438,000
4	1996 AVG DAILY FLOW OF MAX MONTH (GPD)	482,889	27,744	1,713,181		59,253	1,848,001	856,291
5	Response to OPC Doc. Request No. 279							
6	EXCESS Inflow/Infiltration (%), by EPA guidelines							65.1%
7	EXCESS INFLOW/INFILTRATION (GPD)	0	0	0		0	0	1,587,138
8								
9	TREATMENT PLANT AND EFFLUENT DISPOSAL:							
10	Treatment Plant:							
11	OPC Calculated Used & Useful (%)	96.58%	69.36%	89.71%	N/A	N/A	88.00%	24.47%
12	U & U Per Order (%)	100.00%	86.30%	69.90%	N/A	N/A	100.00%	78.00%
13	SSU Requested U & U (%)	100.00%	86.30%	89.71%	N/A	100.00%	100.00%	78.00%
14	Effluent Disposal:							
15	OPC Calculated Used & Useful (%)	96.58%	69.36%	89.71%	N/A	N/A	88.00%	22.91%
16	U & U Per Order (%)	100.00%	100.00%	69.90%	N/A	N/A	81.08%	N/A
17	SSU Requested U & U (%)	100.00%	100.00%	89.71%	N/A	N/A	100.00%	100.00%
18	Reuse Facilities:							
19	OPC Calculated Used & Useful (%)						88.00%	63.83%
20	SSU Requested U & U (%)						100.00%	100.00%
21								Exh TLB-4.1
22	Auxiliary Power:							
23	Capacity (GPD), not provided			Unavailable			Unavailable	Unavailable
24	OPC Calculated Used & Useful (%)			89.71%			88.00%	22.91%
25	SSU Requested U & U (%)			100.00%			100.00%	100.00%

27 USED AND USEFUL CALCULATIONS

Wastewater Collection System

28 Schedule F-7(S)

29

30 **COLLECTION AND SYSTEM PUMPING PLANT:**

31	Connected Lots in 1996 w/o M.R.	1,155	496	7,437	3,414	166	4,436	1,976
32	Connected Lots in 1994 w/ M.R.	1,126	492	7,220	3,251	152	4,342	1,970
33	Connected Lots in 1994 w/o M.R.	1,115	487	7,010	2,999	126	4,257	1,964
34	Number of Lots	1,189	647	6,725	7,285	228	5,270	1,334
35	Calculated Used & Useful (%)	97.15%	76.64%	100.00%	46.87%	72.80%	84.17%	100.00%
36	U & U Per Order (%)	100.00%	85.30%	N/A	N/A	N/A	N/A	N/A
37	SSU Requested U & U (%)	100.00%	85.30%	100.00%	49.10%	79.19%	88.31%	100.00%

38

39

ERC CALCULATIONS (by SSU)

Combined Schedule of F- 8 @ 10 (S)

Year	Sewer ERC	Sewer ERC	Sewer ERC	Sewer ERC	Sewer ERC	Sewer ERC	Sewer ERC
1990	1,206.0	476.0			2,825.8	64.0	6,440.5
1991	1,210.0	513.0			3,178.5	129.5	6,635.0
1992	1,230.0	505.0			3,444.5	132.0	6,777.0
1993	1,279.0	493.0			3,571.0	135.5	6,888.8
1994	1,343.0	505.0	7,010.0	3,611.8	137.3	7,093.3	5,109.0
1995	1,356.0	510.0	7,220.3	3,915.8	165.2	7,234.5	5,125.3
1995.5	1,373.0	512.0	7,327.8	4,014.1	172.8	7,312.4	5,133.4
1996	1,391.0	514.0	7,436.9	4,112.3	180.4	7,390.4	5,141.6

OPC USED AND USEFUL CALCULATIONS

Wastewater Treatment Plant
Schedule F-8 (S)
Docket No. 950495-WS
Company: Southern States Utilities, Inc.
Schedule Year Ended: 12/31/96
Projected [x]

	Spring Gardens	Tropical Isle	Valencia Terrace
	1996	1996	1996

Line FPSC Uniform [x] & Non-Uniform [x]

No.		Spring Gardens	Tropical Isle	Valencia Terrace
1	PERMITTED PLANT CAPACITY (GPD)	20,000	50,000	99,000
2	EFFLUENT DISPOSAL CAPACITY (GPD)	20,000	50,000	99,000
3	1994 AVG DAILY FLOW OF MAX MONTH (GPD)	87,200	35,033	78,452
4	1996 AVG DAILY FLOW OF MAX MONTH (GPD)	92,489	43,616	78,452
5	Response to OPC Doc. Request No. 279			
6	EXCESS Inflow/Infiltration (%), by EPA guidelines			
7	EXCESS INFLOW/INFILTRATION (GPD)	0	0	0
8				
9	TREATMENT PLANT AND EFFLUENT DISPOSAL:			
10	Treatment Plant:			
11	OPC Calculated Used & Useful (%)	100.00%	87.23%	79.24%
12	U & U Per Order (%)	N/A	N/A	N/A
13	SSU Requested U & U (%)	100.00%	100.00%	79.24%
14	Effluent Disposal:			
15	OPC Calculated Used & Useful (%)	100.00%	87.23%	79.24%
16	U & U Per Order (%)	N/A	N/A	N/A
17	SSU Requested U & U (%)	100.00%	100.00%	79.24%
18	Reuse Facilities:			
19	OPC Calculated Used & Useful (%)			
20	SSU Requested U & U (%)			
21				
22	Auxiliary Power:			
23	Capacity (GPD), not provided			
24	OPC Calculated Used & Useful (%)			
25	SSU Requested U & U (%)			
26				

27 USED AND USEFUL CALCULATIONS

Wastewater Collection System

28 Schedule F-7(S)

29

30 COLLECTION AND SYSTEM PUMPING PLANT:

	Spring Gardens	Tropical Isle	Valencia Terrace
31 Connected Lots in 1996 w/o M.R.	130	274	323
32 Connected Lots in 1994 w/ M.R.	126	250	323
33 Connected Lots in 1994 w/o M.R.	122	220	323
34 Number of Lots	180	334	340
35 Calculated Used & Useful (%)	72.06%	82.07%	95.00%
36 U & U Per Order (%)	N/A	N/A	N/A
37 SSU Requested U & U (%)	74.06%	89.21%	95.00%
38			
39			

ERC CALCULATIONS (by SSU)

Combined Schedule of F- 8 & 10 (S)

Year	Sewer ERC	Sewer ERC	Sewer ERC
1990		126.5	
1991		154.0	
1992		180.5	
1993		207.5	
1994	122.0	220.0	323.0
1995	125.7	249.8	323.0
1995.5	127.5	261.9	323.0
1996	129.4	273.9	323.0

EXHIBIT TLB-4.1

**OPC USED AND USEFUL CALCULATIONS
OF
DEEP INJECTION WELL AND EFFLUENT DISPOSAL
ON
MARCO ISLAND**

OPC USED AND USEFUL CALCULATIONS

**Marco Island
Wastewater Treatment Plant
Effluent Disposal Measures**

Docket No. 950495-WS
Company: Southern States Utilities, Inc.
Schedule Year Ended: 12/31/96
Projected [x]

Deep Well	Perc Pond	Golf Courses
-----------	-----------	--------------

Line No. FPSC Uniform [] & Non-Uniform [x]

	Mar-94	May-93	May-94
1 PERMITTED PLANT CAPACITY (GPD)	3,500,000	3,500,000	3,500,000
2 EFFLUENT DISPOSAL CAPACITY (GPD)	9,900,000	3,500,000	1,000,000
3 1994/HISTORIC AVG DAILY FLOW OF MAX MONTH (GPD)	3,663,065	801,968	632,258
4 1996 AVG DAILY FLOW OF MAX MONTH (GPD)	3,686,438	801,968	636,292

5
6

7 EFFLUENT DISPOSAL:

8 Information Source:

9 Late-Filed Deposition Exhibit Nos. 4,5 & 6 of Mr. Terrero;
10 FDEP Permit: UC11-179323. (DR 289-D)
11 Deposition of Mr. Terrero

12
13

14 Effluent Disposal:

15 OPC Calculated Used & Useful (%)	37.24%	22.91%	
16 U & U Per Order (%)	N/A	N/A	
17 SSU Requested U & U (%)	100.00%	100.00%	

18 Reuse Facilities:

19 OPC Calculated Used & Useful (%)			63.63%
20 SSU Requested U & U (%)			100.00%

21

22 ERC CALCULATIONS (by SSU)

23 Combined Schedule of F- 8 & 10 (S)

24		Sewer	Sewer	Sewer
25	<u>Year</u>	<u>ERC</u>	<u>ERC</u>	<u>ERC</u>
26	1990	5,044.5	5,044.5	5,044.5
27	1991	5,228.3	5,228.3	5,228.3
28	1992	5,356.3	5,356.3	5,356.3
29	1993	5,287.3	5,287.3	5,287.3
30	1994	5,109.0	5,109.0	5,109.0
31	1995	5,125.3	5,125.3	5,125.3
32	1995.5	5,133.4	5,133.4	5,133.4
33	1996	5,141.6	5,141.6	5,141.6
34	1996.5	5,149.7	5,149.7	5,149.7
35	1997	5,157.9	5,157.9	5,157.9
36	1997.5	5,166.1	5,166.1	5,166.1
37	1998	5,174.3	5,174.3	5,174.3
38	1999	5,190.8	5,190.8	5,190.8
39	2000	5,207.3	5,207.3	5,207.3