

LAW OFFICES
ROSE, SUNDSTROM & BENTLEY, LLP
2548 BLAIRSTONE PINES DRIVE
TALLAHASSEE, FLORIDA 32301
(850) 877-6555

ORIGINAL

CHRIS H. BENTLEY, P.A.
K. MARSHALL DETERING
BRIAN L. DOSTER
MARTIN S. FRIEDMAN, P.A.
JOHN R. JENKINS, P.A.
STEVEN T. MINGLIN, P.A.
ROBERT M. C. ROSE
DAVID L. SHIPPY
WILLIAM E. SUNDSTROM, P.A.
DIANE D. TREMOR, P.A.
JOHN L. WHARTON

MAILING ADDRESS
POST OFFICE BOX 1567
TALLAHASSEE, FLORIDA 32302-1567
TELECOPIER (850) 859-6128

October 21, 1997

VIA HAND DELIVERY

Ms. Blanca Bayo, Clerk
Division of Records & Reporting
Florida Public Service Commission
2540 Shumard Oaks Boulevard
Tallahassee, Florida 32399-0850

Re: DECCA Utilities; Piersall Territory Extension
Docket No. 971053-WS
Our File No. 20982.14

Dear Ms. Bayo:

In accordance with the request of Richard Redemann in his letter dated September 30, 1997 correspondence to me, the following information is provided:

1. The map filed with this Application as Exhibit "C" and designated "Service Area Expansion" is at a scale of 1" = 600 feet. Please be advised that an overall regional map of the area in and around Oak Run was submitted with the large scale utility expansion request in PSC Docket No. 971157-WS. That map has no scale in order for the illustration to fit on a standard sheet size.

ACK _____
VFA _____ 2. The legal description provided by Mr. Redemann is
APP _____ acceptable for delineating the proposed service area extension.

CAF _____ 3. Attached are the following revised tariff sheets:

CMU _____	Wastewater Tariff	Water Tariff
CTR _____	Fourth Revised Sheet No. 2.0	Fourth Revised Sheet No. 2.0
EAG _____	Original Sheet No. 3.7	Original Sheet No. 3.7

LEG 2 _____
LIN _____ 4. DECCA presently operates a 800,000 gallon per day
OPC _____ capacity wastewater treatment facility which receives approximately
RCH _____ 350,000 gallons per day of flow from its existing service
EC 1 _____ territory; thus, it is operating at approximately 43% of capacity.
AS _____ The proposed territory expansion is adjacent to the DECCA Utilities
H _____

DOCUMENT NO.
10792-97
10/21/97

Ms. Blanca Bayo, Clerk
October 21, 1997
Page 2

wastewater collection system pipelines and, therefore, the wastewater from the expansion territory will be pumped directly to the existing gravity collection system to the south and to lift station number 19 to the east. The gravity collection system is an 8" line capable of handling over 400 units and the lift station is presently designed to serve as 290 units. All proposed infrastructure will have sufficient capacity to service the territory based upon preliminary analysis of the existing utility pump stations, force mains, and appurtenances.

To serve the proposed utility water expansion, the DECCA Utilities' water distribution system was modeled using a computer simulation network analysis. Proposed water lines were input into the model and the new area was tested for fire flow capacity, as well as peak hourly flow. Based on the results, the flow and pressure within the new area meet or exceed the design criteria required by Marion County and the Florida Department of Environmental Protection. Therefore, the existing system consisting of 6", 8" and 12" water mains and the proposed system extension consisting of 6" through 12" water lines sizes will adequately service the minimum 30 PSI residential pressure during peak demand and the minimum 20 PSI fire flow pressure during peak demand and fire demand.

5. The customers proposed for this expansion area will be single family residential units. Current plans filed with the Department of Community Affairs and Marion County provide for 404 single family detached homes.

Should the Staff require any additional information, please do not hesitate to contact me.

Very truly yours,



MARTIN S. FRIEDMAN
For The Firm

MSF/bsr
Enclosure
cc: Mr. Jim Bell
Chuck A. Pigeon, P.E.

WASTEWATER TARIFF

TABLE OF CONTENTS

Territory Served	3.0 - 3.7
Miscellaneous	4.0
Technical Terms and Abbreviations	5.0
Index of Rules and Regulations	6.0 - 7.0
Rules and Regulations	8.0 - 15.0, 15.10
Index of Rate Schedules	16.0
Rate Schedules	17.0 - 20.0
Index of Standard Forms	21.0
Standard Forms	22.0 - 25.0
Index of Service Availability	26.0
Service Availability Policy	27.0 - 28.0
Contracts and Agreements	There are no contracts at the date of original issue

James Bell
ISSUING OFFICER

Division Manager
TITLE

DOCUMENT NO.
10792-97
11/21/97

DECCA UTILITIES
WASTEWATER TARIFF

FIRST REVISED SHEET NO. 3.7
CANCELS ORIGINAL SHEET NO. 3.7

(Continued from Sheet No. 3.6)

TERRITORY SERVED

A parcel of land situated in Section 31, Township 16 South, Range 21 East, Marion County, Florida and being more particularly described as follows:

Commencing at the Northeast corner of said Section 31; thence West along the North Line of Said Section 31, a distance of 1,434 feet, more or less, to the Point of Beginning; thence South $00^{\circ}26'50''$ West, 1,703.50 feet; thence North $89^{\circ}32'27''$ West 1,285.94 feet; thence North $00^{\circ}05'22''$ East, 1,700.86 feet to the aforementioned North Line of Section 31; thence South $89^{\circ}39'32''$ East, along said North Line, 1,236.56 feet to the Point of Beginning.

James Ball
ISSUING OFFICER

Division Manager
TITLE