

RUDEN
MCGLOSKY
SMITH
SCHUSTER &
RUSSELL, P.A.
ATTORNEYS AT LAW

215 SOUTH MONROE STREET
SUITE 815
TALLAHASSEE, FLORIDA 32301

TELEPHONE: (850) 681-9027
FAX: (850) 224-2032

E-MAIL: BKG@RUDEN.COM

RECEIVED-FPSC

SEP 30 PM 12:43

RECORDS AND
REPORTING

September 30, 1998

ORIGINAL

Blanca S. Bayo, Director
Division of Records & Reporting
Florida Public Service Commission
2540 Shumard Oak Boulevard
Tallahassee, FL 32399-0850

VIA HAND DELIVERY

Re: Docket No. 950387-SU (Remand)
Application of Florida Cities Water Company - North Ft. Myers
Division - for increased wastewater rates in Lee County.

Dear Ms. Bayo:

Enclosed on behalf of Florida Cities Water Company, for filing
in the above docket, are an original and fifteen (15) copies of
following:

1. Remand Testimony of Mike Acosta, along with exhibits (MA-1) through (MA-4); **10756-98**
2. Remand Testimony of Larry Coel, along with exhibit (LC-1); **10757-98**
3. Remand Testimony of Thomas A. Cummings, along with exhibits (TAC-01) and (TAC-2); and **10758-98**
4. our Certificate of Service.

Please acknowledge receipt of the foregoing by stamping the enclosed extra copy of this letter and returning same to my attention. Thank you for your assistance.

Sincerely,

B. Kenneth Gatlin

B. Kenneth Gatlin

RECEIVED & FILED

mas
FPSC-BUREAU OF RECORDS

ACK 2

AFA _____

APP _____

CAF _____

CMU _____

CTR _____

EAG _____

LEG 1

LIN 3 to go

OPC _____

RCH _____

SEC _____

WAS Willis

OTH _____

TAL:18783:1

FORT LAUDERDALE ■ MIAMI ■ NAPLES ■ ST. PETERSBURG ■ SARASOTA ■ TALLAHASSEE ■ TAMPA ■ WEST PALM BEACH

BEFORE THE FLORIDA PUBLIC SERVICE COMMISSION

In re: Application for a rate) DOCKET NO. 950387-SU
increase for North Ft. Myers)
Division in Lee County by)
Florida Cities Water Company -) Filed: September 30, 1998
Lee County Division.)

Certificate of Service


I HEREBY CERTIFY that a true and correct copy of Remand Testimonies and Exhibits of Mike Acosta, Larry Coel, and Thomas A. Cummings have been furnished by U.S. Mail this 30th day of September, 1998 to:

Cheryl Walla
1750 Dockway Drive
North Fort Myers, FL 33903

Jerilyn Victor
1740 Dockway Drive
North Fort Myers, FL 33903

Harold McLean, Associate
Public Counsel
Office of Public Counsel
c/o The Florida Legislature
Claude Pepper Building,
Room 812
111 W. Madison Street
Tallahassee, FL 32399-1400

Ralph Jaeger, Esquire
(Hand Delivery)
Division of Legal Services
Florida Public Service
Commission
2540 Shumard Oak Boulevard
Tallahassee, FL 32399-0850



B. KENNETH GATLIN
Fla. Bar No.: 0027966
Ruden, McClosky, Smith,
Schuster & Russell, P.A.
215 South Monroe Street,
Suite 815
Tallahassee, FL 32301
Phone: (850) 681-9027
Attorneys for Florida Cities
Water Company

ORIGINAL

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25

**FLORIDA CITIES WATER COMPANY
REOPENING OF RECORD WATERWAY ESTATES
ADVANCED WASTEWATER TREATMENT PLANT
DOCKET NO. 950387 - SU
REMAND TESTIMONY OF MICHAEL ACOSTA**

Q. Please state your name and business address.

A. Michael Acosta, 4837 Swift Road, Suite 100, Sarasota, Florida 34231.

Q. By whom are you employed and in what capacity?

A. I am employed by Florida Cities Water Company (FCWC) as Vice President, Engineering & Operations.

Q. Please describe your educational background and professional qualifications.

A. I received my Bachelor of Science degree in Environmental Engineering from the University of Florida in 1985. I have been a registered professional engineer in the State of Florida since 1991.

Q. Please describe your professional engineering experience concerning wastewater treatment facilities.

A. I have 13 years of continuous experience in the planning, design, permitting and construction of wastewater treatment facilities. I have been involved in the planning, design, permitting and construction of 11 upgrades and/or expansions of wastewater treatment plants. This includes completion of capacity analysis reports, all aspects of process design, advanced treatment process design, effluent disposal including reuse of reclaimed water and land disposal systems and all

1 associated permitting.

2 Q. What is the purpose of your testimony?

3 A. The purpose of my testimony is to explain why average daily flow in
4 the maximum month (ADFMM) should not be ignored by the Public
5 Service Commission (Commission) in determining the percentage of
6 the Waterway Estates Advanced Wastewater Treatment Plant
7 (Waterway) that is used and useful.

8 Q. Please explain the Commission's traditional method of determining
9 used and useful for wastewater treatment plants.

10 A. The Commission has historically used the ADFMM, for the test year in
11 question, plus the margin reserve flow equivalent divided by the
12 design treatment plant capacity. The formula used is as follows:
13
$$\text{U\&U Percentage} = \frac{\text{ADFMM} + \text{Margin Reserve Flow}}{\text{Design Capacity}}$$

14 The use of ADFMM recognizes the inevitable peaks in treatment plant
15 flows that the plant experiences and that must be treated to water
16 quality standards established by the Florida Department of
17 Environmental Protection (FDEP). The Margin Reserve Flow
18 accounts for the changing demands of existing customers and growth
19 expected within the service area. Finally, the Design Capacity of the
20 plant is the flow at which the plant can consistently meet the water
21 quality standards mandated by FDEP.

22 Q. Did the Commission follow this methodology of using ADFMM in the
23 numerator of its used and useful calculation in Florida Cities Water
24 Company (FCWC), North Fort Myers Division's previous rate case,
25 Docket 910756-SU?

1 A. Yes.

2 Q. Did the Commission use ADFMM to calculate how much treatment
3 capacity was used and useful in other FCWC rate cases?

4 A. Yes. These include, most recently, in re: Application FCWC (Golden
5 Gate Division), 92 F.P.S.C. 8:270, 291 (1992); in re: Application of
6 FCWC (South Ft. Myers System), 92 F.P.S.C. 4:547, 551-552 (1992);
7 and in re: Application of FCWC, (Barefoot Bay Division), 97 F.P.S.C.
8 2:561, 566-68 (1997).

9 Q. Did the Commission change its methodology for calculating used and
10 useful for wastewater treatment plant in this docket?

11 A. Yes, sometime between the Proposed Agency Action Order and the
12 Final Order in this case the Commission changed the flow used in the
13 numerator of the used and useful formula from ADFMM to annual
14 average daily flow (AADF).

15 Q. Do you know why the Commission changed the flow from ADFMM to
16 AADF?

17 A. In the Final Order, PSC-96-1133-FOF-SU, the Commission states
18 "The flows to be considered should be annual average flows, as
19 specified in the DEP permit" and "Flows shown in the MFRs for the
20 used and useful calculations are not annual average flows, but instead
21 are average flows from the peak month. These flows do not match the
22 plant design [nor] the permitting considerations in the DEP
23 construction permit. For these reasons, the flows shown in the MFRs
24 are rejected." The Commission apparently believes that because the
25 basis of design of the plant is AADF that all peak flows should be

1 ignored. The Commission has also relied upon a change in the permit
2 application form used by FDEP for wastewater treatment facilities as a
3 reason to change the methodology.

4 Q. Has the FDEP changed the method by which plant capacity is
5 determined?

6 A. No.

7 Q. What did the FDEP do regarding operating permits that is different
8 than before?

9 A. In approximately 1991, the FDEP changed the permit application form.
10 This change required the permittee to designate the basis of design,
11 as AADF, ADFMM, three-month average daily flow or other of the
12 treatment plant, Exhibit___ (MA-1) shows the designation on the
13 Waterway permit application. This change bears no relationship to,
14 nor does it change, the capacity of Waterway or any other wastewater
15 treatment plant.

16 Q. Prior to the new form designating basis of design, what was the basis
17 of design used for Waterway and where was it noted.

18 A. The basis of design for Waterway and almost all domestic municipal
19 wastewater treatment plants is AADF. This was typically noted in the
20 engineering report that was submitted with the permit application.

21 Q. Why was AADF and not ADFMM chosen as the basis of design?

22 A. As in the previous answer, AADF is almost exclusively the basis of
23 design flow for domestic municipal wastewater treatment plants. A
24 basis of design of ADFMM is usually reserved for highly seasonal
25 treatment plants, plants whose flow is received over a condensed

1 portion of the year such as a campground or recreational vehicle park.
2 In these cases, flow may not be received by the plant year round and
3 the use of AADF would give an artificially low flow. The use ADFMM
4 as the basis of design does not preclude the use of peak flow in the
5 design of the treatment plant. Indeed, peak flows must be
6 incorporated and would be calculated in a similar fashion as if the
7 basis of design were AADF. The peak flow design for plant using
8 ADFMM as the basis of design would approximate a peak day or peak
9 several days. In designing Waterway, using AADF, peak flows were
10 accounted for as discussed in more detail in the remand testimony of
11 Thomas A. Cummings in this docket.

12 Q. Did the FDEP change in format change the plant capacity of
13 Waterway prior to expansion.

14 A. No.

15 Q. Did the FDEP permit application form change affect the design of the
16 expansion of Waterway?

17 A. No, since the basis of previous design of Waterway was already
18 AADF, the design was unaffected by the change.

19 Q. Should the Commission change the traditional method of determining
20 used and useful so that the flows used in the numerator of the used
21 and useful formula (that is, use of ADFMM or peak flows) depends
22 upon (and "matches") the flows shown on the FDEP permit as the
23 permitted plant capacity (that is AADF or ADFMM)?

24 A. No, peak flows (ADFMM) should always be considered. While the
25 basis of design flow may be AADF, the hydraulic component is but one

1 of the considerations in the design of a wastewater treatment plant.
2 The biological process design is equally, if not more, important than
3 the hydraulic component. To look at only the AADF without regard for
4 peak flows misses the important biological process design, hydraulic
5 peaks and other important permitting or design considerations. As
6 stated in the recognized authority Design of Municipal Wastewater
7 Treatment Plants, Manual of Practice No. 8, Vol. I, Water Environment
8 Federation, Alexandria, VA, 74 (1992), "Wastewater treatment plants
9 and their processes are commonly discussed and defined in terms of
10 their average day capacity. As a practical matter, average day
11 conditions are points on a curve of events that may not be observed
12 on a daily basis. Sound design practice does not use average day
13 condition for anything except as a convenient point of reference for
14 peaking factors that are actually of interest in the design.
15 Conceptually, preferred practice applies two peaking factors: a
16 hydraulic peak and a process peak." In reality a plant's capacity is its
17 ability to (1) pass a specific instantaneous flow rate (gallon per minute
18 or million gallons per day), (2) satisfy a specific biochemical oxygen
19 demand (pounds per hour or day), (3) remove specific amounts of
20 suspended solids (pounds per day), and (4) remove specific amounts
21 of dissolved mineral and organic compounds (pounds per day).
22 Characterizing capacity in terms of these parameters would be much
23 more accurate but obviously too cumbersome for practical use.
24 Each component and process unit must be designed to meet the
25 expected peak pollutant and hydraulic loading. Failure to select the

1 most sever combination would result in hydraulic backup in the
2 wastewater collection system or spills from treatment units and/or
3 failure to meet effluent quality standards. Obviously, any of these
4 events is serious since environmental regulations would likely be
5 violated and the ability to provide continuous quality service is
6 jeopardized. Again, from Design of Municipal Wastewater Treatment
7 Plants, Manual of Practice No. 8, Vol. I, Water Environment
8 Federation, Alexandria, VA, 74-75 (1992), "Process design should be
9 based on required performance attainment at maximum process
10 loading conditions. Before Public Law 92-500 (*Clean Water Act*) and
11 its implementing regulations, performance and the loading basis on
12 which performance was to be measured were considered in terms of
13 seasonal or annual average conditions. Now, a minimum definition for
14 this condition of design corresponds with the compliance interval
15 included in the plant's National Pollutant Discharge Elimination
16 System permit. This interval typically represents the maximum month
17 and week period of compliance as noted in Chapter 2." Exhibit
18 ____ (MA-2)

19 The Commission's simplistic approach is inappropriate and leads to
20 erroneous conclusions that could jeopardize both continuous quality
21 service and the environment.

22 Q. Is it good engineering practice to design all the components of a
23 wastewater treatment plant on an AADF basis?

24 A. No. By the very definition of average, if all components were designed
25 on an annual average basis, peak flows could not be contained and

1 peak organic loadings could not be treated to the water quality
2 standards required in the FDEP permit. It should be noted that peak
3 flows and peak organic loadings do not necessarily occur
4 simultaneously. A peak organic loading can upset the biological
5 process very quickly, much quicker than a peak flow. If treatment
6 plants were designed to only meet the AADF any flow in excess of the
7 AADF would result in overflows or in effluent that did not meet all
8 water quality standards.

9 Q. Do you agree with the Commission that the type of flows used in the
10 numerator and denominator of the used and useful formula must both
11 be peak flows or both be annual average flows, that is, that the flows
12 must "match"?

13 A. No, I do not. A determination of used and useful must be concerned
14 with the maximum flows the treatment plant may experience in order to
15 allow for such an event. This is the only way to ensure that safe,
16 adequate service is continuously provided. In Florida, large seasonal
17 population fluctuations contribute to widely varying use patterns for
18 water, and therefore wastewater, service. Using the AADF completely
19 misses these seasonal fluctuations. The use of AADF is analogous to
20 a person having one foot in freezing water and one foot in boiling
21 water and saying that on average the person is comfortable.
22 Obviously, this analogy shows that widely varying peaks are ignored
23 by an average. The same is true of the use of AADF. A treatment
24 plant design based on solely the AADF would lead to a plant that
25 could not provide service during peak flow and/or peak organic

1 loading periods. There is no "matching" used in the design of a
2 wastewater treatment plant. To use such a concept in the
3 determination of used and useful for a plant is improper. A plant
4 designed on an AADF basis must also be able to contain and treat the
5 ADFMM when it arrives. To ignore this basic design principle is
6 simply wrong.

7 Q. Does the margin reserve calculation allow any recognition into rate
8 base of facilities required to accommodate maximum flows
9 experienced in connection with current customers?

10 A. Generally no.

11 Q. Please explain your answer.

12 A. Assuming existing customers do not increase their usage, margin
13 reserve would be used by future customers. The maximum flows
14 associated with current customers would not be accounted for within
15 the margin reserve calculation.

16 Q. Does AFPI allow any recognition into rate base of facilities required to
17 accommodate maximum flows experienced in connection with current
18 customers?

19 A. No, it does not.

20 Q. Please explain your answer.

21 A. AFPI does not allow facilities into rate base. AFPI is associated with
22 prudently constructed plant that is deemed non-used and useful plant,
23 which is associated with future customers. As such, AFPI makes no
24 accommodation for maximum flows experienced in connection with
25 current customers.

- 1 Q. Please set forth the manner in which used and useful should be
2 determined in this case.
- 3 A. First, the reuse facilities used and useful determination should be
4 determined separately from the rest of the facilities, pursuant to the
5 Court's interpretation of 367.0817 in Southern States Utilities v.
6 Florida Public Service Commission, et. al., Case No. 96-4227 (June
7 10, 1998) (Fla. 1st DCA 1998). These facilities as well as the
8 Lochmoor site were found by the Commission to have been prudently
9 incurred (Order No. PSC-96-1133-FOF-SU, pg. 39). They must
10 therefore be considered 100% used and useful in rate base.
- 11 Second, use of the ADFMM in the numerator and the plant capacity of
12 1.25 mgd, as ordered by the court in Florida Cities Water Co. v.
13 Florida Public Service Commission, 705 So. 2d 620 (Fla. 1st DCA
14 1998) results in a 100% used and useful determination:
15 $\%U\&U = [(1.1753 + 0.0573) / 1.25] [100] = 98.61$, say 100%
- 16 Q. What would the result be if the Commission used AADF in the
17 numerator of the equation instead of ADFMM?
- 18 A. Use of AADF in the numerator would yield a used and useful
19 determination of 80%, as follows:
20 $\%U\&U = [(0.9421 + 0.0573) / 1.25] [100] = 79.94$, say 80%
- 21 It is interesting to note that the AADF during the test year was ~~under~~
22 less than the permitted capacity of the plant (0.9421 mgd compared to
23 1.0 mgd) yet FDEP, under the requirements of 62-600 FAC, required
24 that the plant be expanded Exhibit ____ (MA-3). Using the
25 Commission's methodology (AADF), the calculated used and useful

- 1 percentage for the Waterway Estates Advanced Wastewater
2 Treatment Plant prior to expansion would have 99.94%. Clearly, any
3 additional plant capacity would yield a result of less than 100 percent
4 used and useful. This is a clear indication that the use of AADF does
5 not recognize what is happening at the treatment plant (peak flows)
6 and is not consistent with Chapter 62-600 FAC.
- 7 Q. Please describe the requirements of Chapter 62-600 FAC as it relates
8 to wastewater treatment plant planning and construction.
- 9 A. Chapter 62-600.405 requires utilities to initiate planning via an initial
10 Capacity Analysis Report (CAR) upon the three-month average daily
11 flow exceeding 50% of the permitted capacity of the treatment plant. If
12 the CAR indicates that capacity will be equaled or exceeded withing
13 the next five years preliminary design must be initiated. If the capacity
14 will be equaled or exceeded with the next four years plans and
15 specifications for the necessary expansion must begin to be prepared.
16 If capacity will be equaled or exceeded within the next three years a
17 complete construction permit application must be submitted to the
18 FDEP within 30 days of submission of the CAR. If capacity will be
19 equaled or exceeded within the next six months an operation permit
20 application for the expanded facility must be submitted to the FDEP.
- 21 Exhibit___(MA-4)
- 22 Q. Does Commission's used and useful percentage (80%) accurately
23 represent the percentage of facilities which are needed to provide
24 service to current customers?
- 25 A. No, it does not.

- 1 Q. Please explain your answer.
- 2 A. Under this determination, sufficient capacity to accommodate the
3 maximum month flows is not recognized. The plant is required, by
4 regulation, to not only accept these flows but also to biologically treat
5 the flows sufficiently to meet effluent water quality standards
6 established and enforced by the FDEP. A plant designed both
7 biologically and hydraulically to accommodate AADF without regard to
8 peak flows will not meet these requirements.
- 9 Q. Does this conclude your testimony?
- 10 A. Yes.

For exhibit:

See Hearing Exh. 33