



Beverly Y. Menard
Regulatory & Governmental Affairs
Assistant Vice President - Florida/Georgia

GTE Service Corporation

One Tampa City Center
Post Office Box 110, FLTC0616
Tampa, Florida 33601-0110
813-483-2526
813-223-4888 (Facsimile)

May 26, 1999

Ms. Blanca S. Bayo, Director
Division of Records & Reporting
Florida Public Service Commission
2540 Shumard Oak Boulevard
Tallahassee, FL 32399-0850

990969-TP

99 MAY 27 11:44
SERIES
FEDERAL

Re: Sprint Request for Physical Collocation in GTE Florida Incorporated's
Bradenton Bay Central Office

Dear Ms. Bayo:

Sprint has requested physical collocation in the Bradenton Bay Central Office of GTE Florida Incorporated (GTEFL). GTEFL has notified Sprint that there is no space available to accommodate Sprint's request.

Under the FCC's recent order on collocation, GTEFL is required to provide the state commission with floor plans of any office in which physical collocation has been denied. In accordance with that requirement, floor plans of the Bradenton Bay central office are enclosed. Deployment of Wireline Services Offering Advanced Telecomm. Capability, FCC 99-48, CC Dkt. 98-147 (March 31, 1999).

If you have any questions, please contact me.

Sincerely,

AFA	_____
APP	_____
CAF	_____
CMU	<u>I w/ map</u>
CTR	_____
EAG	_____
LEG	<u>I w/ map</u>
MAS	_____
OPC	_____
RRR	_____
SEC	<u>1</u>
WAW	_____
OTH	_____

Beverly Y. Menard
Beverly Y. Menard

Beverly Y. Menard

BYM:tas

Enclosures

DOCUMENT NUMBER-DATE

06670 MAY 27 99

BRADENTON BAY CENTRAL OFFICE

LEGEND SHEET

.....

1. Central Office Study.
2. Two Year W.O. History sheets.
3. Two Year Growth Breakdown.
4. Floor Plans.

NETWORK DESIGN

3/27/99

Central Office: BRADENTON BAY

C.O. CLLI Code: BRBAFLXA75H

Address: 5611 26 TH.ST.WEST BRADENTON, FLA

Total Square Footage: 22,807.70 sq.ft.

The Bradenton Bay C.O. houses a GTD5 switch. The equipment located in the C.O. consists of fiber optic terminals, digit cross-connect systems, multiplexers, digital channel banks, subscriber carrier terminals, and digital cross connect panels. The circuit equipment provides connectivity to other C.O.'s and local customers. Rectifiers and battery strings provide power to the above equipment.

Central Office: **BRADENTON BAY**

C.O. CLLI Code: **BRBAFLXA75H**

Total Square Footage: **22,807.70 sq.ft.**

Due to space limitations in the Bradenton Bay C.O. GTE is unable to provide any physical collocation. Bradenton Bay is currently housing a large area of GTE Administrative offices. The space limitations with which GTE is facing are the result of the amount of existing equipment and the planned installation of additional equipment necessary to provide customers service. GTE is submitting a floor plan showing all existing equipment and the future equipment areas.

In an effort to identify space available for physical or virtual collocation. GTE used the following procedure to determine space availability.

1. Totaled square footage of the floor space inside the building.

2. Totaled unavailable space such as air condition rooms, restrooms, hallways, stairs, and storage.

3. Totaled administrative office space and existing equipment such as transmission, switching, power and generator equipment and distribution frames.

4. Totaled space reserved for future equipment area such as transmission, switching equipment and virtual collocation.

5. Totaled unusable space such as air return areas.

6. Then totaled lines 2 thru 5 and subtracted the total from line 1 to determine any available space.

Central Office: BRADENTON BAY

C.O. CLLI Code: BRBAFLXA75H

Total Square Footage: 22,807.70 sq.ft.

NOTE:

These are the totals from page 1.

Total Square Feet	Description
1. 22807.70 sq.ft.	Building (inside)
2. 713.00 sq.ft.	Air Condition Rooms
2755.01 sq.ft.	Restrooms, storage, Hallways, Stairs etc..
3. 11272.07 sq.ft.	Administrative
738.82 sq.ft.	Transmission equipment
2943.55 sq.ft.	Switching equipment
1572.65 sq.ft.	Power and Generator equip.
2201.51 sq.ft.	Distribution Frames
4. 601.51 sq.ft.	Future equipment
9.00 sq.ft.	Collocation equipment
5. 0.00 sq.ft.	Unusable space
6. LINE 1 = 22,807.70 Sq.Ft.	
LINE 2-5 = 22,798.12 Sq.Ft.	
SPACE AVAILABLE = 9.58 Sq.Ft.	

Note: The only space this central office has to offer is the future equipment areas designated for GTE's future growth.

BRADENTON BAY CENTRAL OFFICE

FUTURE BREAKDOWN

Two Year Growth

.....

Description	Total Sq.Ft.
.....
A. Special Engineering (Power / Misc.)	0.00 sq.ft.
B. Switching (Lines / Trunks)	123.75 sq.ft.
C. Transport (High Frequency Systems)	80.00 sq.ft.
D. Virtual Collocation	128.75 sq.ft.

TOTAL =	332.50 SQ.FT.

STATE OF FLORIDA



DIVISION OF THE COMMISSION CLERK & ADMINISTRATIVE SERVICES
BLANCA S. BAYÓ
DIRECTOR

Public Service Commission

M A P S

DOCKET NO.: 990969-TP

DOCUMENT NO.: 06670-99

DESCRIPTION: Bradenton Bay Central
Office Floor Plan where physical collocation has
been denied to Sprint.

***CAN BE LOCATED IN SRC'S
MAPS BOX NO. C00000124344***