


BEFORE THE  
FLORIDA PUBLIC SERVICE COMMISSION

-----  
 In the Matter of : DOCKET NO. 990325-EI  
 :  
 :  
 Petition of Gulf Power :  
 Company to determine :  
 need for proposed :  
 electrical power plant :  
 in Bay County. :  
 -----



VOLUME 2

Pages 125 through 243

PROCEEDINGS: HEARING

BEFORE: CHAIRMAN JOE GARCIA  
 COMMISSIONER J. TERRY DEASON  
 COMMISSIONER SUSAN F. CLARK  
 COMMISSIONER JULIA L. JOHNSON  
 COMMISSIONER E. LEON JACOBS, JR.

DATE: Monday, June 7, 1999

TIME: Commenced at 10:35 a.m.  
 Concluded at 3:45 p.m.

PLACE: Betty Easley Conference Center  
 Room 152  
 4075 Esplanade Way  
 Tallahassee, Florida

REPORTED BY: KIMBERLY K. BERENS, CSR, RPR  
 FPSC Commission Reporter  
 H. RUTHE POTAMI, CSR, RPR  
 FPSC Commission Reporter

APPEARANCES: (As heretofore mentioned.)

DOCUMENT NUMBER - DATE

07141 JUN 10 8

FPSC RECORDS/REPORTING

## I N D E X

## WITNESSES

3	NAME	PAGE NO.
4	WILLIAM F. POPE	
	Cross Examination Continued By Ms. Jaye	127
5	Redirect Examination By Mr. Melson	139
6	MARIA JEFFERS BURKE	
	Direct Examination By Mr. Melson	152
7	Prefiled Direct Testimony Inserted	155
	Cross Examination By Ms. Jaye	171
8	M. W. HOWELL	
9	Direct Examination By Mr. Melson	210
	Prefiled Direct Testimony Inserted	212

## EXHIBITS

12	NUMBER	ID.	ADMTD.
13	5 and 6		152
14	7 and 8		152
15	9 MJB-1 and MJB-2	154	
16	10 MJB-3	154	
17	9 and 10		207
18			
19	11 Errata sheet for Marler depo	210	210
20	1		225
21			
22	CERTIFICATE OF REPORTERS		243

1  
2  
3  
4  
5  
6  
7  
8  
9  
10  
11  
12  
13  
14  
15  
16  
17  
18  
19  
20  
21  
22  
23  
24  
25

P R O C E E D I N G S

(Transcript continues from Volume 1.)

**CHAIRMAN GARCIA:** I think you made us recess so why don't you go ahead.

**MS. JAYE:** Thank you, Mr. Chairman.

**WILLIAM F. POPE**

resumed the stand as a witness on behalf of Gulf Power Company and, having been previously sworn, testified as follows:

**CROSS EXAMINATION CONTINUED**

**BY MS. JAYE:**

**Q** Mr. Pope, if you would please, refer to Staff's Confidential Composite Exhibit starting on Page 2. This is the confidential response to Staff's Interrogatory No. 1 which Gulf calculated the cost-effectiveness of Smith Unit 3 versus the RFP projects. Looking at this particular page, could you tell me what the column entitled "Transmission Grid & Connection Accumulated Present Value" represents? It will be the fourth -- the column fourth from the right.

**A** This column is in all the spreadsheets provided under this confidential agreement. What that is to represent is the cost differential of transmission capital cost -- the capital cost of

1 transmission improvements as compared to the Smith  
2 Unit 3 project for all of the alternatives.

3 Q Mr. Pope, did you perform any of the  
4 analyses of transmission costs which are shown in  
5 these columns?

6 A No, I did not personally do them. No.

7 Q Do you know who did?

8 A Yes. It was performed by Southern Company  
9 Service's transmission planning.

10 Q Can you explain why the cost shown in the  
11 columns are what they are for each of the respondents  
12 and for Smith Unit 3?

13 A Why they are what they are?

14 Q Yes. Why the number shown there is the  
15 same?

16 A On Page 2?

17 Q Yes, sir. It would be the same for all of  
18 them.

19 A Why --

20 Q I'm trying hard not to even mention the  
21 number here.

22 A I understand, but --

23 Q The same number is shown for Smith Unit 3  
24 and all of the RFP respondents and I was trying to ask  
25 you --

1           **CHAIRMAN GARCIA:** Grace, where are you  
2 reading from?

3           **MS. JAYE:** This is on Page 2 of the  
4 confidential information.

5           **CHAIRMAN GARCIA:** Okay.

6           **WITNESS POPE:** I believe you'll have to ask  
7 Ms. Burke those specific questions.

8           **MR. MELSON:** Commissioner, my concern is,  
9 looking at my copy, the numbers in the column on this  
10 sheet for Smith Unit 3 are different from the numbers  
11 in the column of the same title to the other  
12 respondents.

13           **MS. JAYE:** I stand corrected. They are  
14 different.

15           **MR. MELSON:** I guess I'm misunderstanding  
16 the question.

17           **WITNESS POPE:** That makes a little more  
18 sense. Would you repeat the question?

19           **Q (By Ms. Jaye)** Let me see if I can phrase  
20 it in a different way.

21           **A** Okay.

22           **Q** Comparing Smith Unit 3 with the other units  
23 as relates to this column, Transmission  
24 Grid & Connection, how do you explain the difference  
25 in the numbers?

1           **A**     Okay. The differences in the numbers, when  
2 you compare Smith Unit 3 with all of the respondent  
3 spreadsheets, is the numbers in that particular column  
4 represent the differential in revenue requirements --  
5 annual revenue requirements, between the transmission  
6 cost for Smith Unit 3 and those of that particular  
7 respondent's alternative.

8           **Q**     This would be the incremental difference?

9           **A**     Incremental difference.

10          **Q**     Okay. And showing this difference between  
11 the transmission costs of the RFP respondents and the  
12 Smith Unit 3, why did Southern Company Services -- or  
13 perhaps you don't know -- if you could, indicate which  
14 witness may be best to ask this -- why did Southern  
15 Company Services not use the actual cost?

16          **A**     I really don't know why. Ms. Burke may be  
17 able to shed some light on that.

18          **Q**     Continuing to look at these sets of pages,  
19 could you explain what the column entitled  
20 "Transmission Losses Accumulated Present Value"  
21 represents?

22          **A**     Yes. With all alternatives, the location of  
23 the generation carries with it different impacts on  
24 the transmission system. That column represents the  
25 cost, so to speak, for providing losses to the system

1 from the various alternatives. Let me give you just a  
2 brief example.

3 A generator located at Smith plant has a  
4 positive benefit to the transmission losses because it  
5 lowers losses. There is a cost associated with  
6 replacing those kilowatt-hours if that unit weren't  
7 there. Likewise, a unit located in Mobile, Alabama,  
8 would have a different set of impacts on the losses.  
9 That column represents the dollar -- annual dollars of  
10 benefit to the transmission system from the  
11 replacement cost of those losses.

12 Q Looking again at that same column, do the  
13 parenthesis that are around the numbers in the column  
14 indicate the transmission losses were negative?

15 A Compared to the base case, yes. They  
16 actually went down. Therefore, there was a benefit.  
17 The negative, or the parenthesis, means a positive  
18 benefit.

19 Q Looking at this table then in this  
20 particular response, it appears that all RFP projects,  
21 as well as Smith Unit 3, incurred negative losses.  
22 Would you please discuss the primary drivers behind  
23 the differences in transmission losses for each one of  
24 the projects, and why each project would appear to  
25 benefit Southern Company's system from the standpoint

1 of reducing the transmission losses?

2           **A**     The location of the generator does make a  
3 difference to the transmission system. As you pointed  
4 out, all of the RFP responses and Smith 3 had positive  
5 benefits from a loss standpoint on the Southern  
6 electric system. Primarily, and this goes with all of  
7 the responses at Smith 3, the location of those  
8 generators reduced the losses on the Southern  
9 transmission system. That -- to some more than  
10 others. Okay. But that's the benefit. That's the  
11 effect. It reduced the losses to the Southern  
12 electric system, therefore, we assessed the benefit to  
13 them.

14           **Q**     Mr. Pope, would you please explain what  
15 comprises Southern Company's, quote, "base case  
16 generation expansion plan"?

17           **A**     I believe Ms. Burke would be better to  
18 answer that.

19           **Q**     Referring back again to Page 2 of the  
20 confidentiality that we've been looking at, is the  
21 cost of the base case generic expansion plan contained  
22 in the column entitled "Base Case Utility Cost"? It  
23 would be the seventh column in from the left.

24           **A**     I believe Ms. Burke would be better to  
25 answer those questions.

1           Q     Mr. Pope, as a layman, are you generally  
2 familiar with the provision of Section 403.519 Florida  
3 Statutes that requires a proposed unit must be the,  
4 quote, "most cost-effective alternative available"?

5           A     Yes, I am.

6           Q     Is Gulf justifying the proposed Smith Unit 3  
7 as the most cost-effective alternative available to  
8 Gulf or to Southern Company?

9           A     To Gulf, yes.

10          Q     Referring again to Page 2, following with  
11 the confidential information, does the capital and O&M  
12 cost columns on these pages portray the incremental  
13 cost of the new unit addition?

14          A     I believe Ms. Burke needs to answer that one  
15 too. I want to say, yes, but she's the one that needs  
16 to answer that.

17          Q     Continuing on the same page, do the columns  
18 entitled, "Base Case Utility Cost and Proposal Utility  
19 Cost," refer to the total system revenue requirements  
20 associated with the entire Southern Company system,  
21 including all fuel impacts?

22          A     Ms. Burke needs to answer that question  
23 also.

24          Q     How can cost-effectiveness to Gulf for this  
25 unit addition be determined when the cost-effective

1 analysis was performed on a Southern Company system  
2 basis?

3 A Ms. Burke needs to answer that.

4 Q In your opinion, can Smith Unit 3 possibly  
5 be cost-effective to Southern as a whole, but not to  
6 Gulf specifically?

7 A Please repeat that. I don't believe I'm the  
8 witness for that, but I will -- ask it again.

9 Q In your opinion, could Smith Unit 3 possibly  
10 be cost-effective to Southern as a whole, but not to  
11 Gulf specifically?

12 A I think Mr. Howell needs to answer that one.

13 Q I ask you to turn to Pages 19 through 24 in  
14 the composite exhibit identified as Exhibit No. 7.  
15 These are Gulf's responses to Staff's Interrogatories  
16 21 through 25, and Staff's Request for Production of  
17 Documents, 17 through 20. Those are located on Page  
18 33 to 43. Looking at those pages, were Gulf Power's  
19 responses to Staff's Interrogatories 21 through 25 and  
20 Staff's Production of Documents request 17 through 20  
21 prepared under your supervision or direction?

22 A I sponsored them in response to the  
23 interrogatories, yes.

24 Q Could you summarize how Gulf Power  
25 identified the cost to comply with the applicable

1 federal, state and local environmental mandates for  
2 Smith Unit 3?

3           **A**     The cost estimate used in the Smith  
4 evaluation contained the environmental compliance cost  
5 for all known and expected laws and regulations --  
6 environmental regulations. And in the area of air --  
7 compliance -- air emissions compliance, we included  
8 the cost of selected catalytic reduction, which is  
9 actually a higher cost alternative than the chosen  
10 strategy of NOX offsets.

11                   So, in that light, all of the environmental  
12 cost -- compliance costs are included, including a  
13 little premium, a little more conservative estimate in  
14 the air emissions.

15           **Q**     Would that result in the compliance cost  
16 identified in Gulf's response to Staff's  
17 Interrogatories 23 and 24 being a little on the high  
18 side?

19           **A**     Yes.

20           **Q**     And if you would, turn to Page 12 of the  
21 composite exhibit identified as Exhibit 7. This is  
22 Gulf's response to Staff's Interrogatory No. 8. Was  
23 Gulf Power's response to this interrogatory prepared  
24 under your supervision or direction?

25           **A**     Yes.

1           Q     Can you provide the most recent information  
2 with respect to Gulf Power's efforts to provide  
3 natural gas supply to Smith Unit 3?

4           A     Yes. I believe we're planning on doing  
5 that.

6           Q     I understand that there is an agreement  
7 reached for transportation. How about for the  
8 commodity itself? Has there been an agreement  
9 reached?

10          A     No.

11          Q     Turning over now to Pages 13 through 14 of  
12 the composite exhibit, which is Gulf Power Company's  
13 Responses to Staff's Interrogatories 16 and 17. Could  
14 you briefly summarize the reasons for the differences  
15 in natural gas price forecasts among the several  
16 self-build alternatives, specifically with these that  
17 appear on Page 13?

18          A     Are you speaking about the commodity price  
19 basis --

20          Q     Yes.

21          A     -- on the RFP respondents A, B and C?

22          Q     Of the self-build options of Smith, Daniel,  
23 and Mulat Tower?

24          A     Okay. And you're talking about the  
25 commodity price adjustment?

1 Q Yes.

2 A Commodity price adjustment is factored in  
3 because of differences in variable transportation --  
4 variable O&M and differences in locations of where  
5 delivery points are from what the basis is. The  
6 Daniel Project, let's take that as an example, is  
7 sitting basically right on top of the delivery point  
8 for natural gas, whereas, Smith and the Mulat Tower  
9 are not. In fact, the Smith assumption is on a  
10 delivery point in Alabama with very low differential  
11 pricing between the delivery -- the assumed basis  
12 point and that point, whereas, the Mulat Tower is a  
13 pipeline -- separate pipeline company in the Pensacola  
14 area. Those carry different adjustments to them  
15 because of those differences.

16 Q Mr. Pope, you indicated earlier that a  
17 supplier for the commodity of natural gas has not yet  
18 been chosen; no contract has been signed. What was  
19 the capacity cost and commodity cost used in  
20 calculating the cost-effective analysis then?

21 A For the RFP?

22 Q I'm sorry. For Smith Unit 3?

23 A In the RFP or the initial self-build?

24 Q Just going now looking at the Smith Unit 3,  
25 leaving aside now all the RFPs and self-build options.

1           **A**     I understand, but it depends on if it's the  
2 part that Ms. Burke is testifying to, that the gas  
3 assumptions in those vintage of analysis or if it's in  
4 the initial self-build.

5           **Q**     This would be in the initial screening?

6           **A**     The initial screening, it was a gas  
7 commodity price being adjusted from Mobile Bay to the  
8 Atmore area. Remember, the initial self-build called  
9 for construction of a pipeline from the Atmore area  
10 and that was the basis for the commodity price to that  
11 point.

12          **Q**     Mr. Pope, to your knowledge, is there a time  
13 frame for choosing a supplier of natural gas commodity  
14 to the Smith Unit 3?

15          **A**     I'm not aware of a time line on that, no.

16                   **MS. JAYE:** We have no further questions.

17                   **COMMISSIONER DEASON:** Commissioners?

18 Redirect? Sorry.

19                   **COMMISSIONER JACOBS:** We were going to hold  
20 on. They were going to go ahead and ask some  
21 questions on redirect.

22                   **COMMISSIONER DEASON:** We'll cover that on  
23 redirect and then if you need to follow up with some  
24 questions, obviously, we'll do that at that time.

25

## REDIRECT EXAMINATION

1  
2 **BY MR. MELSON:**

3           **Q**     Mr. Pope, staying for a minute on Page 13 of  
4 Exhibit 7, which is the answer to Interrogatory  
5 No. 16, I believe there was a clarification of this  
6 interrogatory answer that was made during the  
7 deposition of Ms. Burke relating to the identification  
8 of Respondents A and C. Can you tell us what change  
9 ought to be made on Page 13 here?

10           **A**     Yes. I apologize. The interrogatory  
11 response mixed and swapped two of the respondents.  
12 Let me clarify that. That when this interrogatory  
13 response refers to Respondent A, those figures to the  
14 right actually correspond to Respondent C. Likewise,  
15 if you look at the interrogatory response referring to  
16 Respondent C, those figures to the right there  
17 actually correspond to Respondent A. So those need to  
18 be swapped as far as either title or figures.

19           **Q**     Let me follow up. There were a few  
20 questions about reserve margin. Could you turn to  
21 your Exhibit WFP-2? It's been identified as hearing  
22 Exhibit No. 6. It was the attachment to your  
23 supplemental testimony.

24           **A**     Okay.

25           **Q**     There were some questions about the

1 difference between 15% reserve margin and a 13.5%  
2 reserve margin on a Southern Company basis. What does  
3 this exhibit reflect about the actual percent reserve  
4 margin Gulf would have on its system following the  
5 installation of Smith Unit 3?

6       **A**       According to schedules for WFP-2, the  
7 reserves beginning in 2002, with the addition of Smith  
8 Unit 3, are well above the 13.5% -- or actually the  
9 Gulf 12.6%, according to the 13.5% Southern system  
10 reserves, until the year 2006.

11               If the reserve margin -- referring back to  
12 the question about Peninsular Florida. If the reserve  
13 margin were 15% on a Southern system basis that would  
14 translate or calculate to a 14.1% Gulf reserve. If  
15 you'll look at the table, the reserves would be above  
16 or equal to that through the year 2005 if the reserve  
17 was 15%. So, essentially, we're above the reserve  
18 margin target from 2002 on into 2005 and 2006.

19               **COMMISSIONER CLARK:** What does the minus 19  
20 mean for 2005? Does that mean you're losing a  
21 contract to purchase power?

22               **WITNESS POPE:** That's correct. We currently  
23 have a cogeneration -- negotiated cogeneration  
24 contract for 19 megawatts that expires May 31st of  
25 2005.

1           Q        **(By Mr. Melson)** Let me go back for a  
2 minute to the series of questions you had about backup  
3 fuel, and I guess a question Commissioner Jacobs asked  
4 at one point -- and I may hop around a little bit  
5 here. Commissioner Jacobs was asking for a screening  
6 analysis that would show how the Southern system  
7 generation operated before and after an outage of  
8 Smith Unit 3 due to a gas supply interruption. Do you  
9 recall that request?

10           A        Yes, I do.

11           Q        Would there be any difference in the way the  
12 Southern system operated, whether that outage of Smith  
13 3 was due to gas supply interruption or was due to any  
14 other type of forced outage that the unit might  
15 experience?

16           A        No. I believe one of the important parts to  
17 remember here is that -- and this is why I was a  
18 little bit confusing at the time, and I apologize.

19                    But whether a unit is forced out because of  
20 a boiler or turbine outage or whether it's a natural  
21 gas supply, the unit is out. And we currently already  
22 plan for expected probable forced outage rates. We  
23 have an assumption of this unit being forced out  
24 because of boiler or turbine outages which forces the  
25 whole unit off. A turbine outage could take the whole

1 unit off. There's an expectation of that.

2 The expectation of those things that we  
3 already cover in our generation reserve margin and  
4 those criteria, in my opinion, would exceed by far the  
5 occurrence of a natural gas pipeline interruption.  
6 So, in that light, we already can -- we already  
7 evaluate the effects of unit outages in what we  
8 already do with regard to gas interruptions.

9 Q And I believe Mr. Moore's Exhibit RCM-1,  
10 which was identified as Exhibit 2, in fact, shows a  
11 3.4% equivalent forced outage rate for Smith Unit 3.  
12 Are you familiar with that number?

13 A That is correct.

14 Q And based on an 8760-hour year, would you  
15 agree that that translates to 297 hours if the unit is  
16 modeled as forced out in all of the reliability and  
17 economic analyses that are done based on the unit?

18 A Subject to doing the math, yes, I will agree  
19 with that.

20 Q So you'll accept subject to check?

21 A Right. I trust your math.

22 Q Thank you. Would you like to borrow my  
23 calculator?

24 A I've got one over here somewhere.

25 Q It's better coming from the witness.

1           **A**     297.84 hours.

2                   **COMMISSIONER CLARK:** That's per year?

3                   **MR. MELSON:** Per year.

4                   **WITNESS POPE:** Per year. On average.

5           **Q**     **(By Mr. Melson)** So on average, if the  
6 combination of turbine outages, gas supply  
7 interruptions, whatever reason there might be for the  
8 outages, was less than 298 hours a year, the economics  
9 of those outages have already been captured in the  
10 analysis that's been done for this need certification;  
11 is that correct?

12           **A**     That's correct.

13           **Q**     How do you -- is the way that Gulf would  
14 expect to cover a forced outage due to a gas supply  
15 interruption any different from the way it would  
16 expect to cover a forced outage due, for example, to a  
17 turbine outage?

18           **A**     No, no different.

19           **Q**     And how would you normally -- you may have  
20 already testified to this, but could you summarize  
21 again how you would expect that type of outage to be  
22 covered?

23           **A**     From a generation planning aspect, reserve  
24 margins are -- the reserve margin criteria is designed  
25 to carry you from a capacity resource aspect to cover

1 things such as forced outages, abnormal weather  
2 conditions and load forecast error. In combination  
3 with that, the transmission system is also planned  
4 under a criteria of loss of a unit and any  
5 transmission element, which could be a line. In  
6 combination, these two provide reliability on the  
7 system where this unit, for whatever reason, if it's  
8 outage, power would continue to flow over the  
9 transmission system from other units, other generating  
10 units, that are planned for in the generation planning  
11 side of it to cover the units -- the customer's power  
12 needs. So in combination, all facets of reliability  
13 are covered under whether it would be a boiler outage  
14 or a natural gas pipeline interruption or a commodity  
15 interruption.

16 **COMMISSIONER CLARK:** Your answer suggests to  
17 me that, going back to Commissioner Deason's question,  
18 that there is no reason to have any fuel switching at  
19 any facility. Is that what your testimony is?

20 **WITNESS POPE:** For this particular case,  
21 yes.

22 **COMMISSIONER CLARK:** That's not what I asked  
23 you. For any facility, the logic of what you're  
24 presenting to us suggests to me that you would not  
25 have any fuel switching capability for any type of

1 plant.

2 **WITNESS POPE:** That's correct.

3 **COMMISSIONER JACOBS:** It assumes the system  
4 reserve, correct; the Southern Company system reserve?

5 **WITNESS POPE:** We're planning to that system  
6 reserve, yes.

7 **COMMISSIONER CLARK:** Is that assumption only  
8 valid if you have good fuel diversity on your entire  
9 system?

10 **WITNESS POPE:** No.

11 **COMMISSIONER CLARK:** So why, as a  
12 Commission, should we ever care if there's fuel  
13 switching capability? Is it your testimony that it's  
14 not something we should be concerned with?

15 **WITNESS POPE:** There may be reasons that you  
16 would be concerned, but I'm just saying that we're  
17 planning both from a generation planning criteria and  
18 transmission planning criteria in combination to where  
19 that is not a problem and diversity of fuel --

20 **COMMISSIONER CLARK:** Why is it not a  
21 problem?

22 **WITNESS POPE:** -- is a benefit, but I don't  
23 think it's one of the things that it depends on. I  
24 can't -- I just don't want to answer for somebody in  
25 Gainesville, Florida or Florida Power & Light or for

1 other circumstances. I'm just saying that from  
2 everything we've done and what we're -- what the  
3 Southern electric system -- and it's a benefit of  
4 being a part of a large system. We can draw on that  
5 large system, whereas, in some cases some others  
6 can't. I don't want to be thinking -- let you think  
7 that I'm answering for every case, but I'm saying that  
8 we plan on the Southern electric system and because of  
9 Southern electric system and its large size and some  
10 of the benefits of being that large and having  
11 multiple interconnections, we can do this without a  
12 problem.

13 **COMMISSIONER CLARK:** Is it because of your  
14 fuel diversity and how you're interconnected that fuel  
15 switching capability at any particular plant is not  
16 necessary?

17 **WITNESS POPE:** It's more of interconnections  
18 than it is fuel diversity. I believe our type of  
19 fuel, being coal, predominantly coal, almost all coal,  
20 is a resource that is not easily interruptible, and  
21 that gives you a tremendous benefit from those units  
22 being on line from a fuel source. They also carry, as  
23 every other unit on the Southern electric system and  
24 others throughout the United States -- have a forced  
25 outage rate, but we plan for that also.

1           **COMMISSIONER CLARK:** Let me ask you it a  
2 different way. If every unit at Smith were gas-fired  
3 and it was that capacity of each was its present  
4 capacity, would your answer be different with respect  
5 to fuel switching? Would you feel you needed to have  
6 the capability to switch fuel if you had an  
7 interruption of natural gas supply to that site?

8           **WITNESS POPE:** I would have to say yes.

9           **COMMISSIONER CLARK:** Okay. Mr. Pope, I take  
10 it -- what I surmise from your answer is that the  
11 reason you really don't need fuel switching units is  
12 because you have diversity on your system and your  
13 system is well interconnected?

14           **WITNESS POPE:** That's correct. Yes, ma'am.

15           **Q**       **(By Mr. Melson)** And Mr. Pope, you were  
16 asked some questions about your answers to  
17 Interrogatories 32 through 35 that are part of Staff's  
18 Exhibit 7. And I don't think you need to turn to them  
19 in particular. They deal in general with the backup  
20 fuel issue. Were there some environmental licensing  
21 concerns, environmental licensing timetable concerns,  
22 associated with the provision of backup fuel at Smith?

23           **A**       That's correct. And that's partially in the  
24 cost figures I was asked about earlier. But, it's  
25 important to note that if the company were required to

1 provide a backup fuel, No. 2 oil, for instance, we'd  
2 also be required to go back and restart the  
3 environmental permitting process because -- and we'd  
4 also have to abandon the NOX offset, because you can't  
5 achieve even the hour-by-hour emissions rate of the  
6 unit, the combined cycle unit, with oil firing. There  
7 would be some assumptions that would have to be made  
8 in the environmental process that would dictate we go  
9 back to the selective catalytic reduction alternative,  
10 which is a more expensive alternative.

11 But more importantly, is that it delays the  
12 project at least a year because of re -- having to go  
13 back and restart the process of the environmental  
14 permitting and modeling those emissions and getting  
15 those emissions included in the application, which we  
16 did file this morning. So there's a year's delay.

17 And on top of that, there's power that we  
18 would have to, for a year or so, secure at whatever  
19 cost, which we expect to be very expensive, to make up  
20 for that year delay.

21 But moreover, it wipes out the positive  
22 benefits of the NOX offset. That on a site basis, a  
23 total site basis, with a combination of doing some  
24 things to Smith 1 to reduce their NOX emissions, and  
25 adding Smith Unit 3, no longer can we say that the

1 site would have a net air emission reduction for NOX.

2 **COMMISSIONER CLARK:** Why not?

3 **WITNESS POPE:** Because you don't have enough  
4 offsets of Smith 1 with oil firing and the higher  
5 emissions of oil firing. You don't have that benefit  
6 of NOX -- the NOX emissions out of the Smith 3 unit.

7 **COMMISSIONER CLARK:** Maybe I misunderstood.  
8 Which site would you add the switching to? Wouldn't  
9 it be the natural gas?

10 **WITNESS POPE:** Excuse me?

11 **COMMISSIONER CLARK:** Maybe I misunderstood  
12 you.

13 **WITNESS POPE:** The fuel switching would be  
14 to Smith 3 only.

15 **COMMISSIONER CLARK:** Which is the natural  
16 gas.

17 **WITNESS POPE:** Which is the natural gas  
18 unit. And even though that unit would only be  
19 expected in our estimation to use that oil source very  
20 rarely, the potential -- the maximum potential, which  
21 is what you file in your permit and what you're  
22 permitted for and what the emissions that they make  
23 you comply with, is what they call the maximum  
24 potential, which could be many, many, many, more hours  
25 than what is really expected from that unit.

1                   **COMMISSIONER CLARK:** And that would offset  
2 the improvements you're making to 1 and 2?

3                   **WITNESS POPE:** To Unit 1.

4                   **COMMISSIONER CLARK:** To Unit 1.

5                   **WITNESS POPE:** Yes. And there are --  
6 currently under the strategy of natural gas on there  
7 is the benefit of a net overall reduction in NOX  
8 emissions from Smith 2 that don't go forward if you  
9 had oil backup, plus the time of delay.

10                  **Q**        **(By Mr. Melson)** And finally, Mr. Pope,  
11 Interrogatory 32 discusses fuel supply strategy for  
12 the Smith unit. To the extent you've testified this  
13 morning about the entry into a firm gas transportation  
14 contract and testified that there is no specific time  
15 table for securing the commodity, should we read that  
16 interrogatory in light of your further explanation  
17 today?

18                  **A**        I would say, yes. At the time it was  
19 answered we did not have that firm natural gas  
20 transportation agreement in hand and efforts are still  
21 going forward to further work on other aspects of the  
22 natural gas supply. But transmission -- excuse me.  
23 Transportation is by far the most critical in our  
24 opinion as far as firmness of the supply fuel to  
25 Smith.

1           **MR. MELSON:** That was all I had.

2           **COMMISSIONER DEASON:** Commissioner Jacobs,  
3 do you have anything to follow up?

4           **COMMISSIONER JACOBS:** No.

5           **COMMISSIONER DEASON:** Okay. Exhibits.

6           **MR. MELSON:** Gulf moves Exhibits 5 and 6.

7           **COMMISSIONER DEASON:** Without objection,  
8 show Exhibits 5 and 6 admitted.

9           (Exhibits 5 and 6 received in evidence.)

10          **COMMISSIONER DEASON:** Staff.

11          **MS. JAYE:** Staff would like to go ahead and  
12 move Exhibits 7 and 8.

13          **COMMISSIONER DEASON:** Let me ask, in  
14 reference to Exhibit 8, you're wanting that entire  
15 confidential exhibit admitted?

16          **MS. JAYE:** Yes, sir.

17          **COMMISSIONER DEASON:** Without objection,  
18 show then Exhibits 7 and 8 admitted.

19          (Exhibits 7 and 8 received in evidence.)

20          **COMMISSIONER DEASON:** Thank you, Mr. Pope.  
21 You're excused.

22          **WITNESS POPE:** Thank you.

23          **MR. MELSON:** Gulf calls Maria Burke.  
24  
25

**MARIA JEFFERS BURKE**

1  
2 was called as a witness on behalf of Gulf Power  
3 Company and, having been duly sworn, testified as  
4 follows:

**DIRECT EXAMINATION****BY MR. MELSON:**

5  
6  
7 **Q** Ms. Burke, state your name and address?

8 **A** My name is Maria Jeffers Burke. I work at  
9 1600 North 18th Street in Birmingham.

10 **Q** And who is your employer and what is your  
11 job title?

12 **A** I work with Southern Company Services. I'm  
13 a project manager in the Generation and Planning and  
14 Development Department.

15 **Q** And have you prefiled in this docket 12  
16 pages of direct testimony?

17 **A** Yes.

18 **Q** And have you also filed three pages of  
19 supplemental testimony?

20 **A** Yes.

21 **Q** And does the supplemental testimony  
22 essentially update your direct to reflect the increase  
23 in the maximum output of the proposed Smith Unit 3?

24 **A** Yes, it does.

25 **Q** And with the updates, if I were to ask you

1 the same questions today that are contained in your  
2 Direct and Supplemental Testimony, would your answers  
3 be the same?

4 **A** Yes, they would.

5 **MR. MELSON:** Commissioner Deason, I ask that  
6 those Direct and Supplemental Testimony be inserted  
7 into the record as though read.

8 **COMMISSIONER DEASON:** Without objection, it  
9 shall be so inserted.

10 **Q** (By Mr. Melson) Ms. Burke, did you have  
11 two exhibits attached to your direct testimony  
12 identified as MJB-1 and MJB-2?

13 **A** Yes, I did.

14 **Q** And were those prepared by you or under your  
15 direction and supervision?

16 **A** Yes, they were.

17 **Q** Do you have any changes or corrections to  
18 those exhibits?

19 **A** No.

20 **MR. MELSON:** Mr. Chairman, I ask that those  
21 be -- MJB-1 and 2 be identified as Composite Exhibit  
22 9.

23 **COMMISSIONER DEASON:** It will be so  
24 identified.

25 (Composite Exhibit 9 marked for

1 identification.)

2 Q (By Mr. Melson) And did you also have an  
3 exhibit, MJB-3, which was attached to your  
4 Supplemental Testimony?

5 A Yes, I did.

6 Q And does that essentially revise and update  
7 one of the schedules that have been attached to your  
8 Direct?

9 A Yes, it does.

10 MR. MELSON: Mr. Chairman, I ask that MJB-3  
11 be identified as Exhibit 10.

12 COMMISSIONER DEASON: It will be so  
13 identified.

14 (Exhibit 10 marked for identification.)

15 Q (By Mr. Melson) And finally, Ms. Burke,  
16 are you sponsoring Chapter 8 and Appendix E of the  
17 Need Study that's previously been identified as  
18 Exhibit 1?

19 A Yes, I am.

20

21

22

23

24

25

Before the Florida Public Service Commission  
Direct Testimony of  
Maria Jeffers Burke  
Docket No. 990325-EI  
Date Filed: April 5, 1999

1  
2  
3  
4  
5  
6 Q. Please state ~~your~~ name, business address and  
7 occupation.

8 A. My name is Maria Jeffers Burke and my address is  
9 Southern Company Services, 600 North 18<sup>th</sup> Street,  
10 Birmingham, Alabama 35202. I am Project Manager in  
11 the Generation Planning and Development Department of  
12 Southern Company Services (SCS). I am currently  
13 responsible for supply side evaluations.

14  
15 Q. Please describe your educational background and  
16 experience.

17 A. I graduated from Auburn University in August 1986 with  
18 a Bachelor of Science degree in Chemical Engineering,  
19 and I am currently completing graduate work toward a  
20 Masters in Business Administration from Samford  
21 University. In 1986, I began my career with the  
22 Southern Company at a research facility in Wilsonville,  
23 Alabama as a process engineer, and then as the  
24 environmental engineer. I continued my environmental  
25 permitting work with Southern Electric International in

1 1990, helping to develop independent power projects 56  
2 both domestically and internationally. I joined the  
3 System Planning Department of SCS in November 1992 and  
4 spent the next six years in various engineering and  
5 supervisory positions. I have been involved in bid  
6 evaluation since December 1996.

7

8 Q. Have you prepared an exhibit that contains information  
9 to which you will refer in your testimony?

10 A. Yes. I have an exhibit consisting of 2 schedules to  
11 which I will refer. This exhibit was prepared under my  
12 supervision and direction. I am also sponsoring  
13 Section 8 and Appendix E of the Need Study filed in  
14 this docket.

15 Counsel: We ask that Ms. Burke's Schedules  
16 1 and 2 be marked for  
17 identification as Exhibit \_\_\_\_\_  
18 (MJB-1).

19

20 Q. Ms. Burke, what is the purpose of your testimony in  
21 this proceeding?

22 A. The purpose of my testimony is to describe the process  
23 employed by SCS in issuing the Gulf Power Request for  
24 Proposals (RFP), in receiving responses, in evaluating  
25 the offers and in comparing those offers to self-build

1 options.

157

2

3 Q. Please describe your role as it relates to  
4 solicitations for capacity resources made on behalf of  
5 the Southern companies.

6 A. In my current position, I am responsible for the  
7 evaluation of both short-term and long-term supply side  
8 offers for the Southern operating companies. This  
9 analysis includes selecting an appropriate production  
10 cost modeling tool, verifying the assumptions used in  
11 the analysis, preparing the final rankings, and  
12 checking all numbers used in the evaluation. However,  
13 my responsibilities usually begin earlier in the  
14 process, understanding the appropriate regulatory  
15 environment and drafting the RFP document for internal  
16 review.

17

18 Q. What solicitations have you been involved in prior to  
19 the one performed on behalf of Gulf Power Company  
20 seeking alternatives for their Smith Unit 3?

21 A. Since assuming responsibility for supply-side  
22 evaluations in December 1996, I have been involved in  
23 two other solicitations: a Southern system solicitation  
24 issued in March 1997 for short-term needs, and an  
25 informal market test for Alabama Power. As a result of

1           these solicitations, Southern became concerned that  
2           large amounts of relatively inexpensive purchased power  
3           were not going to be available much longer, and that  
4           the market would soon begin to extract a premium for  
5           capacity.

6

7   Q.    What role did you play in the Gulf Power solicitation?

8   A.    For the Gulf Power solicitation, I was directly  
9           involved in the early stages of the solicitation,  
10          helping Gulf Power Company draft and issue the RFP  
11          document.  After the proposals were received from those  
12          that responded to the RFP, I was responsible for  
13          distributing copies of the proposals within the  
14          evaluation team, conducting the generation cost  
15          analysis of the proposals, and completing a relative  
16          ranking for the proposals.  I was also responsible for  
17          the comparison of Gulf Power's self-build alternative  
18          to the proposals.

19

20   Q.    How was the RFP distributed?

21   A.    As a normal course of business, SCS maintains a mailing  
22          list of developers who are active in the Southeastern  
23          United States.  This list was updated for Gulf Power  
24          Company's RFP and used by SCS to issue the RFP on  
25          behalf of Gulf Power Company.  The original

1 distribution of the RFP on August 21, 1998 included  
2 approximately 100 potential respondents.

3 Additionally, Gulf Power Company published a  
4 notice in appropriate local and statewide newspapers  
5 and at least one national trade journal. Gulf Power's  
6 objective was to attract any interested developers who  
7 may not have been on Southern's original distribution  
8 list.

9

10 Q. How many proposals were received?

11 A. On October 16, 1998, SCS received, on behalf of Gulf  
12 Power, four offers from three separate respondents.  
13 The proposals were of various terms and MW sizes, but  
14 all offers were in the form of new generating  
15 facilities:

- 16 ♦ A combined cycle unit in Hardee County, FL
- 17 ♦ A combustion turbine facility in Holmes County, FL
- 18 ♦ A combined cycle unit in Holmes County, FL
- 19 ♦ A family of cogeneration facilities in Mobile, AL and  
20 in Santa Rosa County, FL

21

22 Q. What would you regard as your overall objective in  
23 performing the analysis of the alternatives proposed as  
24 they are compared to Gulf Power Company's self-build  
25 option?

1 A. It is my responsibility to ensure that Gulf Power's  
2 customers get to take full advantage of the most cost-  
3 effective supply-side alternative available. One of  
4 our objectives on the bid evaluation team is to ensure  
5 that all respondents are treated consistently and  
6 fairly. To accomplish that objective, SCS used only  
7 the specific information directly provided by the  
8 respondents in evaluating their proposals. In cases  
9 where information was incomplete, an estimate favorable  
10 to the respondent was made in the initial stage of the  
11 evaluation process until the respondent was able to  
12 clarify the specifics of the offer.

13

14 Q. What steps are taken with regard to the security and  
15 confidentiality of the proposals?

16 A. For the Gulf Power RFP, I distributed copies of all  
17 proposals received ONLY to bid evaluation team members.  
18 Distributed copies were numbered, and team members were  
19 requested to make no additional copies. All team  
20 members were required to keep proposals secure, or  
21 return them to me at day's end.

22

23 Q. Please describe how the alternative offers were  
24 initially economically screened?

25 A. After the four proposals passed the responsiveness

1 screening, which verifies that all mandatory components  
2 of the offers were included with the proposal, then the  
3 economic portion of the analysis began. The initial  
4 screening of the offers was a "generation only"  
5 evaluation. All offers were analyzed using PROVIEW®, a  
6 production cost and optimization model. Specifically,  
7 a PROVIEW® case was created for each proposal and  
8 compared to a base case without that generation  
9 facility. The difference between these production cost  
10 simulations was considered the "energy savings" for  
11 that offer. Fixed capital and O&M costs for the  
12 alternative were also totaled and the net cost was  
13 present valued across a twenty-year horizon. These  
14 initial screening results are shown in Schedule MJB-1.

15

16 Q. Prior to the completion of the initial screening of the  
17 various alternatives to Smith Unit 3, did you and the  
18 other SCS employees working on the evaluations have any  
19 questions about the proposals?

20 A. Yes, the initial screening of the proposals is usually  
21 the most difficult because information is not shared  
22 uniformly. In some cases, assumptions had to be made  
23 about an offer to effectively analyze the proposal for  
24 the initial screening. SCS-Generation Planning and  
25 Development and SCS-Transmission Planning reviewed the

1 offers during the initial screening and identified the  
2 additional information they would need to conduct their  
3 detailed analysis.

4

5 Q. The Gulf RFP made reference to transmission impacts and  
6 you mention above that SCS-Transmission Planning  
7 reviewed the offers during the initial screening. At  
8 what point did any transmission system impacts become a  
9 factor in the RFP evaluation process?

10 A. Although SCS-Transmission Planning reviewed the offers  
11 during the initial screening, it was not until the  
12 detailed evaluation phase that the transmission system  
13 impacts were incorporated into the process. For the  
14 Gulf Power RFP, a relative transmission evaluation was  
15 conducted for all of the proposals and any necessary  
16 transmission improvement costs were identified, and  
17 ultimately include in the economic analysis. It was  
18 necessary for Transmission Planning to initiate their  
19 review of the offers during the early part of the  
20 analyses to adequately assess any system impacts  
21 associated with the offers. The initial screening was  
22 a "generation only" analysis based on the information  
23 strictly provided by the respondents in relation to the  
24 RFP issued on Gulf's behalf and, therefore, any  
25 transmission impacts were not included.

1 Q. Did you contact the respondents to the RFP process  
2 asking them to clarify your assumptions about their  
3 proposals?

4 A. Yes, all respondents were contacted in writing on  
5 November 19, 1998 and asked for the additional  
6 information needed to fully evaluate their offer. Most  
7 of the uncertainty at this stage of the analysis  
8 concerned the reliability of the fuel supply, unit  
9 ratings, unit heat rates, and overall availability of  
10 the offers. Therefore, the questions were categorized  
11 into generation, fuel, transmission, and structure  
12 questions.

13

14 Q. As a result of this dialogue with the respondents, were  
15 any of the original proposals modified?

16 A. Yes, most of the original proposals were modified and  
17 two of the respondents made additional proposals for  
18 consideration under this RFP. This resulted in a  
19 total of nine proposals being carried forward in the  
20 final stages of the evaluation.

21

22 Q. After receiving the answers to your clarifying  
23 questions, was there a need to perform the analysis  
24 again to include this additional information?

1 A. Yes, each time a respondent provided updated  
2 information the analysis was repeated to ensure that  
3 the value of that revision was included in the relative  
4 ranking of the offers.

5

6 Q. At what point did you evaluate Gulf's Smith Unit 3  
7 option?

8 A. I received the site specific Smith Unit 3 cost  
9 estimates on October 27, 1998. As I will discuss in a  
10 moment, this submission did not include gas  
11 transportation costs. The evaluation process was  
12 designed so that the evaluation of the self-build  
13 alternative would follow the same evaluation procedure  
14 that the proposals had already been through. This  
15 process design was created to ensure that the analysis  
16 procedure would not have a bias toward or away from the  
17 self-build alternative. The bid evaluation team also  
18 requested additional information from the self-build  
19 team when necessary.

20

21 Q. You mentioned earlier that Gulf's self-build submission  
22 did not include gas transportation costs. How were  
23 these costs factored into the analysis?

24 A. Originally, Gulf Power's plan included an estimated \$90  
25 million cost for construction of a gas pipeline to the

1 Bay County site. In September 1998, SCS issued a  
2 separate RFP for Firm natural gas service to the Smith  
3 site. The offers received in response to that Natural  
4 Gas RFP were generally less costly than Gulf's original  
5 plan. Information from this solicitation was used in  
6 the evaluation of the self-build proposal. Having  
7 multiple fuel supply alternatives allows Gulf Power to  
8 negotiate among the vendors to achieve a significantly  
9 lower pipeline cost for the facility than what was  
10 originally estimated.

11  
12 Q. You mentioned earlier that your overall objective is to  
13 identify the most cost effective supply-side  
14 alternative. Do you consider the results of your  
15 evaluation to have achieved this goal?

16 A. Yes. The evaluation of alternatives for the Gulf Power  
17 solicitation did provide Gulf Power with accurate  
18 relative rankings of the proposals and the self-build  
19 alternative.

20  
21 Q. What were the results of your evaluation?

22 A. The results of the evaluation reveal that the 540 MW  
23 self-build Smith Unit 3 is the most cost-effective  
24 alternative for the customers of Gulf Power Company.  
25 Referring to my Schedule MJB-2, this table outlines all

1 of the final offers and their relative rankings after  
2 the detailed evaluation. One can see from this  
3 schedule that Gulf's Smith Unit 3 had a much lower cost  
4 than any of the competing offers. In fact, these  
5 relative rankings prepared by my team indicate more  
6 than \$90 million accumulated NPV(2002\$) savings over  
7 the next best alternative.

8

9 Q. Does this conclude your testimony?

10 A. Yes it does.

11

12

13

14

15

16

17

GULF POWER COMPANY

Before the Florida Public Service Commission  
Supplemental Direct Testimony of  
Maria Jeffers Burke  
Docket No. 990325-EI  
Date of Filing: May 17, 1999

1  
2  
3  
4  
5  
6  
7  
8  
9  
10  
11  
12  
13  
14  
15  
16  
17  
18  
19  
20  
21  
22  
23  
24

Q. Please state your name and business address.

A. My name is Maria Jeffers Burke and my business address is 600 North 18th Street, Birmingham, Alabama 35202.

Q. Have you previously filed direct testimony in this docket?

A. Yes.

Q. What is the purpose of your supplemental direct testimony?

A. The purpose of my testimony is to present the results of an updated economic evaluation of Smith Unit 3 which takes into account recent design and cost changes for the project. As described by Mr. Moore, the peak output of the unit has increased by 34 MW, the heat rate has changed slightly, and the total nominal cost has increased by \$9.6 million.

1 Q. Have you prepared an exhibit that contains  
2 information on your updated evaluation?

3 A. Yes. I have an exhibit consisting of one schedule to  
4 which I will refer. This exhibit was prepared under  
5 my supervision and direction.

6 Counsel: We ask that Ms. Burke's  
7 Schedule 3 be marked as  
8 Exhibit \_\_\_\_ (MJB-3).

9  
10 Q. Why did you perform a reevaluation of Smith Unit 3?

11 A. Gulf wanted to confirm that the proposed changes  
12 would actually improve the cost-effectiveness of the  
13 project.

14  
15 Q. How did you perform your analysis?

16 A. I analyzed the total costs associated with the  
17 redesigned unit using the same PROVIEW evaluation  
18 methodology that was used in the previous ranking of  
19 Smith Unit 3 and the RFP alternatives.

20  
21 Q. What were the results of your analysis?

22 A. The updated analysis shows that the evaluated NPV  
23 cost of Smith Unit 3 has decreased from \$279/KW to  
24 \$274/KW in 2002 dollars.

1 Q. What conclusions do you draw from this evaluation?

2 A. As shown on Schedule 3, this evaluation shows that  
3 Smith Unit 3 still provides much greater value than  
4 any of the alternatives proposed in response to the  
5 RFP. It also demonstrates that the incremental MWs  
6 resulting from the design change are a cost-effective  
7 capacity resource.

8

9 Q. Does this conclude your testimony?

10 A. Yes.

1           **Q**       **(By Mr. Melson)** All right. With the  
2 preliminaries out of the way, would you give us a  
3 brief summary of your testimony?

4           **A**       Certainly. Good afternoon, Commissioners.  
5                   Consistent with Florida's RFP rules, Gulf  
6 Power has prepared and issued an appropriate RFP;  
7 published that RFP in both local publications and  
8 trade journals; collected and clarified proposals from  
9 multiple respondents and analytically compared those  
10 proposals to Smith Unit 3 across a 20-year evaluation  
11 period.

12                   The results of this analytical comparison  
13 revealed by far that the Smith Unit, 574-megawatt  
14 unit, is the most cost-effective alternative for the  
15 customers of Gulf Power Company. In fact, the  
16 relative ranking comparison, my exhibit MJB-3, shows  
17 that the net evaluated cost of the Smith Unit 3 is  
18 essentially \$274 per kW. The next best alternative is  
19 almost \$200 more, or \$496 per kW. That's the basis  
20 that I used to conclude that Smith Unit 3 is the best  
21 supply-side alternative for Gulf Power's customers.

22                   This concludes my summary.

23           **Q**       Just so we're clear about the unit in which  
24 one of those answers was stated, you talked about  
25 dollars per kW. Is that a dollar per kW of installed

1 cost or is that a dollar per kW net present value over  
2 20 years of all of the costs and savings associated  
3 with the project?

4           **A**     The dollar per kW numbers that I used for  
5 the evaluation is not an installed cost. It's a net  
6 evaluated cost so that you can compare CTs and  
7 combined cycles and different -- a variety of types of  
8 capacity on an equal basis using the installed cost as  
9 one of those components, but it's net of whatever  
10 energy benefits that that alternative brings to the  
11 table as well. So it's a net evaluated cost.

12           **MR. MELSON:** Ms. Burke is available for  
13 cross.

14           **COMMISSIONER DEASON:** Ms. Kamaras.

15           **MS. KAMARAS:** No questions.

16           **COMMISSIONER DEASON:** Staff.

17                           **CROSS EXAMINATION**

18           **BY MS. JAYE:**

19           **Q**     Ms. Burke, I've got some questions about the  
20 confidential information beginning on Page 2. This is  
21 Gulf's confidential response to Staff's Interrogatory  
22 No. 1. I want to reference the number at the top of  
23 the column entitled "Generation & Transmission Total  
24 Cost Accumulated Present Value." Is this number the  
25 same value that's included for Smith Unit 3 in Exhibit

1 MJB-2 of your testimony, and I believe that was  
2 identified as Exhibit 9?

3 A Yes, it is.

4 Q Could you explain why, in your opinion, it  
5 is appropriate to portray a project's  
6 cost-effectiveness in NPV dollars per kilowatt rather  
7 than in total dollars?

8 A Because projects, especially when you're  
9 evaluating projects in an RFP situation, you're going  
10 to get projects that are a variety of sizes. And it's  
11 important to make sure that you try to put them on an  
12 equal basis. We found through the different RFPs that  
13 Southern Company has been through that putting it on a  
14 dollar-per-kilowatt basis really values that project  
15 kind of on a stand-alone basis. A project may be very  
16 small. You don't want to overlook the value that that  
17 small project has or that a large project has. If you  
18 put it on a per kW, what are you getting for your  
19 dollars, we found it to be a better analysis.

20 Q Can total dollars associated with each  
21 project be estimated by multiplying the unit size for  
22 each resource option by dollars per kilowatt values  
23 that are contained in Exhibit 9, MJB-2, of your  
24 testimony?

25 A I'm sorry. Can you repeat the question?

1           Q     Certainly. Can the total dollars that are  
2 associated with each project be estimated by  
3 multiplying the unit size of each resource option by  
4 the dollars per kilowatt values contained in Exhibit  
5 MJB-2 of your testimony?

6           A     Yes. We did that when we calculated the  
7 \$90 million of savings. It's really a conservative  
8 estimate. It doesn't take into account the additional  
9 100 megawatts that Smith Unit 3 brings.

10          Q     Turning now over to Page 90 of the  
11 confidential composite exhibit.

12                   **MR. MELSON:** What was that page number  
13 again, please?

14                   **MS. JAYE:** 90.

15                   **MR. MELSON:** Thank you.

16          Q     **(By Ms. Jaye)** Actually starting at Page  
17 91. This particular page contains Late-filed  
18 Exhibit 4 to Mr. Pope's deposition. Are you the  
19 witness who actually performed the analysis that is  
20 contained in this exhibit?

21           A     Yes, I am.

22          Q     Okay. Ms. Burke, looking at that last  
23 column, Accumulated Present Worth Revenue  
24 Requirements, would you say that this column  
25 represents the true costs that are associated with

1 this project?

2           **A**     This particular page was updated and revised  
3 so I guess I'm a little hesitant to say yes. It does  
4 reflect -- I mean, in principle it does. It has a  
5 small calculational mistake in it, so, I guess, it's  
6 not the final numbers.

7           **Q**     Is the change due to the change up to 574  
8 megawatts for the proposed Smith Unit 3?

9           **A**     Yes, it is. We had not calculated the  
10 losses correctly. We had not taken into account the  
11 dollars appropriately on this page. We did that in an  
12 analysis beyond this one.

13          **Q**     On the page following, on Page 92 -- I'm  
14 sorry. It's on Page 93. There's some numbers outside  
15 of the columns. Do these numbers represent the  
16 present worth revenue savings for Smith Unit 3 over  
17 the proposed RFP options?

18          **A**     Yes, it does.

19          **Q**     Is that savings on a total dollar basis?

20          **A**     Yes, it is.

21          **Q**     Looking at these pages as a whole, does the  
22 revenue requirement data that is contained in them  
23 give a true estimate of the magnitude of  
24 cost-effectiveness for the proposed Smith Unit 3?

25          **A**     On a relative basis it does. Just like you

1 were asking Mr. Pope about the transmission dollars,  
2 the numbers that we put in this analysis for the  
3 transmission cost were all relative to Plant Smith, so  
4 on a total dollars, it's not the absolute dollars, but  
5 in a relative sense it has all the components.

6 Q Were the dollar values shown in this exhibit  
7 the result of rerunning the PROVIEW model?

8 A Yes, it was.

9 Q Could you explain that how that PROVIEW  
10 model is run? Just give a quick overview?

11 A Certainly. The PROVIEW model contains all  
12 of the units for the Southern electric system. We  
13 also put in there what we call a typical week load  
14 shape for every month of the year. That load shape is  
15 divided up into weekend, weekday, weeknight periods  
16 and the units are dispatched on a lowest dispatch  
17 price basis, lowest first basis, and really ranked up  
18 within that dispatch and estimated the utilization of  
19 those units. That PROMOD production cost also takes  
20 into account the forced outage, the scheduled  
21 maintenance. It can take into account fixed cost. We  
22 prefer to use the fixed cost externally in a  
23 spreadsheet so we can show them to you guys in a  
24 format like this so we don't include anything other  
25 than the variable components of the alternatives that

1 we're looking at when we do the production costs.

2           What we do for the analysis that we do for  
3 the dollar-per-kW type of analysis, we really do  
4 exactly what Commissioner Jacobs asked. We run one  
5 without the Smith unit in there as a placeholder type  
6 of case, and then we run it with the Smith unit in  
7 there as a change case, and we take that delta so that  
8 you can actually see what is the production cost with  
9 the unit in there, what is the production cost with  
10 the unit not in there.

11           Q     I'd ask for you to turn back to Page 2 of  
12 the confidential composite exhibit, which has been  
13 identified as Exhibit 8. The tables in this exhibit  
14 refer to a base case plan. Would you tell me what  
15 comprises that plan?

16           A     That base case utility cost is the fuel, the  
17 variable O&M, the emissions cost of all of the  
18 existing units in our fleet. In addition, it includes  
19 whatever expansion plan costs are in that case,  
20 including those fixed costs for the expansion plan,  
21 what we call generic unit additions on the system  
22 through time, and the fuel variable O&M and emissions  
23 from those generic units.

24           Q     What are generic units made up of?

25           A     Southern Company Services' Engineering

1 Department creates a technology data book for us each  
2 year that is a generic -- what's a generic CT cost;  
3 what's a generic combined cycle cost; what's a generic  
4 coal plant cost. And we use those costs and operating  
5 parameters in the model as generic units.

6 Q Referring now to your base case plan, what  
7 generic units are included in the basis case plan that  
8 makes that base case plan different from what was  
9 proposed in the RFPs?

10 A How would the generic units differ from the  
11 RFP units?

12 Q Yes.

13 A I would say that they're very different.  
14 The generic units are usually kind of generically  
15 within -- that we have to create a generic location  
16 within a specific portion of our system, maybe a  
17 Central Alabama or a Central Georgia-type generic  
18 site. But I've imagined that the RFP respondents have  
19 very site-specific information in them. I know that  
20 the fuel information that we used for the production  
21 cost runs were very site-specific. I'm sure that the  
22 respondents also took into account some site-specific  
23 characteristics of their units when they proposed  
24 those to us.

25 Q Is the cost of a base case generic expansion

1 plan contained in the column on these pages entitled  
2 "Base Case Utility Cost"?

3 A Yes, expansion plan costs are included in  
4 that.

5 Q Refer now over to Exhibit 7 on Page 7. This  
6 is Gulf's response to Staff's Interrogatory No. 2.  
7 I'm sorry.

8 A Sorry. I was in the wrong exhibit. Yes.  
9 Glad you found that.

10 Q Give you a chance to have a look at that  
11 Page 7. Do the numbers in these columns refer to the  
12 number of 300-megawatt-block size generic CC and CT  
13 units to be added?

14 A Yes, they do.

15 Q Could you explain how that works, the  
16 300-block size additions?

17 A The Southern electric system is a very large  
18 system from a generation planning perspective. And in  
19 the generation planning group that we work in, we work  
20 very hard to make sure that we are really adding the  
21 right technology that the system needs in a particular  
22 time and not trying to put a CT in there because it  
23 was an exactly 80-megawatt size. We really go for the  
24 economy as a scale rather than, I guess, a convenient  
25 block size of the generation that's available.

1           For that reason, we put CTs and CCs in the  
2 case generically as 300-megawatt-block sizes. The  
3 system does grow 600 to 700 megawatts a year. And so,  
4 usually the model puts in -- one of each is really the  
5 most common one when you're in complete balance.  
6 They'll put one CT and one CC in it, in the mix. But  
7 in the case we use a 300-megawatt-block size to help  
8 make sure that we are adding the right technology and  
9 not necessarily the exact convenient size of a unit  
10 that could be added.

11           **Q**     Where on Southern Company's system are the  
12 generic unit additions located?

13           **A**     I believe they are in -- there's a Central  
14 Alabama and a Central Georgia location.

15           **COMMISSIONER JACOBS:** So help me understand  
16 this. If we get -- now we come to Gulf and they have  
17 a 400-and-some-odd megawatt requirement, would that  
18 300 block -- how would they interplay with one another  
19 for planning purposes?

20           **WITNESS BURKE:** What I did was I took into  
21 account the -- each one of the respondents, and even  
22 in Gulf's self-build case, I basically scaled them up  
23 to a 600-megawatt-block size for the production  
24 costing methodologies. I still had all of the fixed  
25 costs out here, dollars per kW. So in order to

1 capture the energy benefit that that unit brings the  
2 system -- and even under the expansion plan savings so  
3 that I wouldn't disadvantage one of the respondents  
4 over another -- I scaled them all to 600 megawatts.  
5 And that way the cases, the base case and the change  
6 case, are equal megawatt cases and so none of them has  
7 to bear the burden of more cost to account for that  
8 expansion plan unit through time. So for the  
9 production cost purposes, it's really done on an equal  
10 megawatts case.

11 **COMMISSIONER JACOBS:** Now, your view at that  
12 moment is from the Southern Company view; is that  
13 correct?

14 **WITNESS BURKE:** That's right.

15 **COMMISSIONER JACOBS:** That's the RFP  
16 respondents. Then they're going at Gulf's need,  
17 correct?

18 **WITNESS BURKE:** That's correct.

19 **COMMISSIONER JACOBS:** How do you get them to  
20 match up?

21 **WITNESS BURKE:** Because we're one pool, we  
22 have one dispatch pool, I think that my analysis  
23 really accurately reflects how that unit would be  
24 dispatched in the Southern electric system.

25 **COMMISSIONER JACOBS:** Oh, I see.

1           **WITNESS BURKE:** Whether it's a respondent or  
2 it's a self-build or however, it's going to be  
3 dispatched up against all of the units within the  
4 Southern electric system.

5           **COMMISSIONER JACOBS:** Are they -- are they  
6 responding to specifications of a 600 or just to  
7 the -- I'm sorry. I understand. You take what they  
8 give you and you project it in that way.

9           **WITNESS BURKE:** That's right, within the  
10 analysis. We just do that for analysis purposes.

11           **COMMISSIONER JACOBS:** I see.

12           **COMMISSIONER CLARK:** I'm not sure I  
13 understand that, and maybe it would help if you looked  
14 at your Exhibit 2. I don't know what it is. Is it  
15 Exhibit 9, Schedule 2?

16           **MS. JAYE:** Yes, Commissioner.

17           **COMMISSIONER CLARK:** You have the bidders  
18 listed and you indicate their rank and you indicate  
19 how many megawatts, evidently, they bid. For  
20 instance, with Respondent B combustion turbine and a  
21 20-year pricing, they bid in 486 megawatts; is that  
22 right?

23           **WITNESS BURKE:** I'm having trouble finding  
24 that exhibit.

25           **COMMISSIONER CLARK:** It's attached to your

1 first Direct Testimony.

2 **WITNESS BURKE:** Oh, to the first one.

3 That's why.

4 **MR. MELSON:** Commissioner Clark, the version  
5 attached to the Supplemental Testimony contains the  
6 updated unit size for Smith 3, and if you're going to  
7 look at specific numbers, it's the same concept. That  
8 might be the better one to look at.

9 **WITNESS BURKE:** It would help me.

10 **COMMISSIONER CLARK:** It has the --

11 **MR. MELSON:** It has exactly --

12 **COMMISSIONER CLARK:** -- same injection? Is  
13 that what it is? Lose the megawatts a little bit? It  
14 doesn't make any difference for my question.

15 I guess the question I have, what you're  
16 doing is -- for instance, for the 486, you do some  
17 extrapolation up to 400 -- I mean 540, so you're on  
18 the same basis or does everybody get up to 600?

19 **WITNESS BURKE:** I scaled every one -- every  
20 one of the alternatives were scaled to 600 megawatts  
21 and that way it didn't -- because my expansion plan  
22 alternatives were 300-megawatt-block sizes, it  
23 wouldn't change the expansion plan. That's why I  
24 chose one that was the same block size as my expansion  
25 plan unit.

1                   **COMMISSIONER CLARK:** Let me ask you this:  
2 As I understood your revised estimate for Smith,  
3 because you went up in the number of megawatts, you're  
4 actual per-unit cost came down?

5                   **WITNESS BURKE:** That's correct.

6                   **COMMISSIONER CLARK:** Could you -- but you  
7 didn't make the same sort of assessment for any of  
8 these other ones when you scale them up to a larger  
9 megawatt?

10                   **WITNESS BURKE:** The only reason that the  
11 evaluated cost of Plant Smith went down, decreased in  
12 the evaluated cost, was because the size of the  
13 unit -- the actual cost of the unit did actually go  
14 up. It was \$9.2 million, I think, that was actually  
15 added to the cost. So the net present value, the  
16 revenue requirement cost actually went up. But we  
17 reran that also through the production costing method  
18 as well and the energy savings went up as well. So  
19 when the cost went up some; the energy savings went up  
20 some as well.

21                   So if you look at what -- the net evaluated  
22 cost actually came out to be lower than previously.  
23 But even in either one of the production cost methods  
24 that I did for the self-build, either the 574 or the  
25 540-megawatt-slice size in that production cost

1 analysis, I scaled both to 600 megawatts so that they  
2 would be on an equal megawatt case with the base case.

3 **COMMISSIONER CLARK:** I guess my question is,  
4 can you assume the same sort of increase in -- if you  
5 increase the unit size for those people responding,  
6 might they experience the same kind of decrease --

7 **WITNESS BURKE:** Well --

8 **COMMISSIONER CLARK:** -- in the overall cost  
9 or whatever?

10 **WITNESS BURKE:** There's a lot of ways I  
11 could answer this. A CT, for example, is not going to  
12 have a design change like the combined cycle had. So  
13 that's part of my problem. But in the analysis, for  
14 the production cost value of these units, all of these  
15 units were scaled to 600 megawatts.

16 **COMMISSIONER CLARK:** Let me ask you a  
17 different question and I think Mr. Melson was trying  
18 to get you -- trying to somehow explain why there was  
19 such a big difference between No. 1 and 2. He said it  
20 was net of energy?

21 **WITNESS BURKE:** That's true.

22 **COMMISSIONER CLARK:** Explain to me what --  
23 these are capital costs then?

24 **WITNESS BURKE:** No. It is capital cost. If  
25 you sum up all of the capital requirements, what those

1 revenue requirements would be for each one of these  
2 alternatives and you get a total fixed cost, and you  
3 take the delta in the production cost; if I didn't  
4 have this unit this is what my production cost would  
5 be; if I did have this unit, this is what the  
6 production cost would be.

7 I take those total dollars and divide it by  
8 the 600 megawatts that I used in that piece of the  
9 analysis to create \$1 per kW energy savings. And I  
10 think that's actually included in what the Staff has  
11 pulled out for the confidential piece of the  
12 evaluation. And I would be glad to walk you through  
13 that if I can find one in here. Do you know what page  
14 they're on?

15 **MS. JAYE:** I believe it's on Page 2 and  
16 following.

17 **COMMISSIONER CLARK:** Page 2 of the  
18 confidential exhibit?

19 **MS. JAYE:** Yes, Commissioner.

20 **WITNESS BURKE:** Yes. This is a great chance  
21 to walk through and show you exactly how we took into  
22 account all of the fixed components and all of the  
23 variable components of the analysis.

24 Page 2 of the confidential material shows  
25 how we added up all of the fixed costs to get a total

1 fixed cost for this particular alternative. This  
2 particular page covers the 20-year self-build  
3 alternative. There's separate pages for each one of  
4 the respondents and we did the same thing for those  
5 guys as well.

6 **COMMISSIONER CLARK:** Which column shows  
7 total fixed costs?

8 **WITNESS BURKE:** The sixth column over from  
9 the left.

10 **COMMISSIONER CLARK:** Okay.

11 **WITNESS BURKE:** And then the next column  
12 over, the next three columns deal with the capacity --  
13 with the energy savings, the variable cost. And this  
14 is in traditional generation expansion plans, a  
15 combined cycle, for example, is going to cost more,  
16 but it evidently has more energy benefits to your  
17 system or you would never add it. So that's exactly  
18 what I tried to do, is to capture what the energy  
19 benefits are of this particular alternative. Once I  
20 have those total dollars, I divide it by the 600  
21 megawatts that I used for those two columns, the base  
22 case utility cost and the proposal utility cost. That  
23 delta is divided by the 600 megawatts and is shown in  
24 the column that's called "Energy Savings and Expansion  
25 Plan Savings."

1           Then the column that's just to the right of  
2 that is the total cost, and that is simply the column  
3 that was the total fixed cost. And we subtract off  
4 what we just calculated as the energy benefits  
5 associated with this unit. And then all we do with  
6 that total cost column then is to create a net present  
7 value of those revenue requirements to get the total  
8 net present value of the generation cost.

9           **COMMISSIONER JACOBS:** Could you help me  
10 understand again your base case analysis?

11           **WITNESS BURKE:** Yes. The base case analysis  
12 is run with a 600-megawatt placeholder in there so  
13 that it had has no energy benefit. That 600-megawatt,  
14 we basically went with a 600-megawatt placeholder that  
15 has no dispatch capability. So then when you run the  
16 change case, you put a 600-megawatt bid or  
17 600-megawatt self-build alternative in there.

18           **COMMISSIONER JACOBS:** And can you dispatch  
19 or not?

20           **WITNESS BURKE:** That's right. The  
21 self-build alternative or the proposal alternative is  
22 dispatched in that production cost model.

23           **COMMISSIONER JACOBS:** Okay.

24           **COMMISSIONER CLARK:** Which column do you use  
25 to calculate your net present value?

1           **WITNESS BURKE:** The column that is shown as  
2 the total cost there right beside it has a present  
3 value factor. We simply multiple those two together  
4 to get the column that is on, I guess, to the right of  
5 that that's called the Net Present Value of Total  
6 Generation Cost. You can, as a function, just net  
7 present value that column, and we have done that right  
8 under the column -- right under the word you can see  
9 the 383 that is shown there. And then we -- just to  
10 make sure that we're checking the numbers right, we do  
11 an accumulation of those numbers. And at the bottom,  
12 the Generation Total Cost Accumulated Present Value  
13 column that is shown there, the very last number is  
14 also 383, and that way we can check and make sure that  
15 we did present value those correctly.

16           **COMMISSIONER CLARK:** Sorry. Where?

17           **MR. MELSON:** Ms. Burke, you blurted out the  
18 same number twice. I think this particular one in  
19 context is probably not confidential, but you need --  
20 you ought to be careful about numbers.

21           **WITNESS BURKE:** Well, it's the net present  
22 value so --

23           **COMMISSIONER CLARK:** Let me just ask you a  
24 little differently. How do you use this spreadsheet  
25 on Confidential Exhibit Page 2 to come up with the

1 number that you have in the last column on your  
2 Exhibit MJB-3, which is attached to your Supplemental  
3 Testimony?

4           **WITNESS BURKE:** There are additional costs  
5 other than generation costs -- generation production  
6 costs, and that's why I have a section on this Page 2  
7 that deals with transmissions; what are the grid and  
8 connection costs, what are the losses, what's the  
9 total present value of those. And adding those to the  
10 generation costs, I get the column that is on the far  
11 right-hand side that present values to the 274 that we  
12 talked about in that summary, MJB-3, the relative  
13 ranking.

14           **COMMISSIONER CLARK:** Okay. Can you sort of  
15 give a big picture of what you think the costs -- what  
16 were the particular aspects of these proposals that  
17 made them so much higher than the self-build?

18           **WITNESS BURKE:** Each one of the proposals  
19 that were sent to us were different so it's hard to  
20 create one that, like you say, that is what was the  
21 refining factor that made them so much more expensive.

22           I know that the accumulated net present  
23 value of these in terms of cost is very close to what  
24 we published in the RFP, like Attachment C; the costs  
25 associated with what we had expected Plant Smith to

1 come in with.

2           So I don't know if they were targeting a  
3 specific target and they didn't get as low as our  
4 self-build team did when they put the RFP out for  
5 fuel. I'd say there is not one overriding fact like  
6 Gulf picked the best transmission case. They did take  
7 the best transmission site, but they put that in the  
8 RFP. This was a good transmission site. So --

9           **COMMISSIONER CLARK:** You mean in the RFP.  
10 You indicated I think some -- maybe Staff or somebody  
11 indicated the RFP says, you know, best place to locate  
12 this is Panama City.

13           **WITNESS BURKE:** Yes.

14           **COMMISSIONER CLARK:** And you can't -- you  
15 would be uncomfortable saying that a good deal of the  
16 difference in cost is the result of those bidding not  
17 proposing a site in Panama City?

18           **WITNESS BURKE:** If there had been a site in  
19 Panama City, they would have had a significant cost  
20 savings. I mean, that's shown in one of the  
21 transmission interrogatories, I think. Mr. Pope  
22 covered that.

23           **COMMISSIONER CLARK:** Let me ask the question  
24 a little bit differently. When you put out your RFP,  
25 do you -- as I recall, you indicate what you think the

1 price would be if you built it yourself?

2 **WITNESS BURKE:** I understood that was a  
3 requirement of the RFP rules in Florida.

4 **COMMISSIONER CLARK:** What did you put out  
5 for the net present value total cost? What was it?

6 **WITNESS BURKE:** Well, we actually included  
7 the cost of all of these different components. We did  
8 not include a net evaluated cost like we do in the  
9 evaluation, but we did include what the cost of the  
10 equipment itself was going to be, what the cost of the  
11 gas lateral to the facility was.

12 **COMMISSIONER CLARK:** Well, if you did the  
13 calculation, what would you have come up with for a  
14 net present value?

15 **WITNESS BURKE:** I don't have that evaluation  
16 done.

17 **COMMISSIONER CLARK:** Let me ask you this  
18 differently. You indicated that you think the bidders  
19 may have come in around these prices because of what  
20 you put out?

21 **WITNESS BURKE:** That's correct.

22 **COMMISSIONER CLARK:** Well, what did you put  
23 out that caused them to come around those prices?

24 **WITNESS BURKE:** The plan -- the Need  
25 Study -- actually the last page of the Need Study

1 shows Attachment C, what we had in here as far as a  
2 planned unit data, and we did use some generic unit  
3 cost information. I understood Gulf was not really --  
4 they didn't have a lot of different sites, specific  
5 information really developed at that point when we  
6 published the RFP. So we used some generic  
7 information about what the total direct cost would be  
8 to install a combined cycle at that site. We used  
9 some of the site-specific information that we had,  
10 like what it was going to cost to build a gas lateral  
11 to the facility and those types of things. And I  
12 don't know why -- I don't know -- I think the only  
13 component in here that was rather large was the  
14 \$90 million of gas lateral pipeline cost that was  
15 essentially eliminated through time with the RFP that  
16 Gulf put out for the fuel.

17 **COMMISSIONER CLARK:** But the \$90 million  
18 would have been the lateral up to Atmore, Alabama?

19 **WITNESS BURKE:** Yes. That's what I  
20 understood.

21 **COMMISSIONER CLARK:** And by eliminating  
22 that --

23 **WITNESS BURKE:** Gulf was able to  
24 significantly reduce the cost of this unit.

25 **COMMISSIONER CLARK:** But you can't tell me

1 what you actually put out in terms of the net present  
2 value for the self-build?

3 **WITNESS BURKE:** Well, the information that  
4 we needed to publish just wasn't a net present value  
5 figure. So I just don't have that at my fingertips.

6 **COMMISSIONER CLARK:** But couldn't it be  
7 calculated?

8 **WITNESS BURKE:** Yes, ma'am, it could be.

9 **COMMISSIONER CLARK:** You had to put that out  
10 in August of '98? Is that when you went out --

11 **WITNESS BURKE:** I believe that is right.  
12 August 21st. Yes.

13 **COMMISSIONER CLARK:** I would be interested  
14 in knowing what -- using the parameters you put out in  
15 a bid, what would have been the net present value  
16 total cost; what would have been the equivalent figure  
17 to the one you show on MJB-3. And Staff, if you would  
18 make sure that I get that.

19 **MS. JAYE:** Yes, ma'am.

20 **COMMISSIONER CLARK:** But it would be your  
21 testimony it's somewhere around 500 because that's  
22 where all the bids came in?

23 **WITNESS BURKE:** Yes, ma'am, it would be.

24 **COMMISSIONER CLARK:** And is it your  
25 testimony that you think a good deal of that can be

1 attributed to the gas lateral?

2 **WITNESS BURKE:** Yes, I believe it is.

3 **COMMISSIONER CLARK:** Okay. And the fact  
4 that it was -- okay, to the gas lateral. Because your  
5 proposal does show it as being sited in Panama City?

6 **WITNESS BURKE:** Yes, it does.

7 **COMMISSIONER CLARK:** Okay.

8 **MS. JAYE:** I was going to ask, Commissioner  
9 Clark, in what form would you like the exhibit? Would  
10 you like it in a tabular form?

11 **COMMISSIONER CLARK:** No. If you would just  
12 give me, you know, what -- as compared to what you  
13 currently estimate for the Smith Unit 3, what did  
14 your -- what would have been the net present value  
15 total cost for the floor plan given the parameters you  
16 put out in the bid.

17 **WITNESS BURKE:** I know it's in the \$500 kV  
18 range, but I don't have that spreadsheet with me  
19 today.

20 **COMMISSIONER CLARK:** And by someone else  
21 bearing the cost of the gas lateral, you're in better  
22 shape?

23 **WITNESS BURKE:** Well, you're not getting it  
24 for free. They're just embedding it differently in  
25 the pricing, yes.

1           **COMMISSIONER CLARK:** Okay. Thank you.

2           **MS. JAYE:** Commissioner Clark, would you  
3 like a late-filed exhibit number for that?

4           **COMMISSIONER CLARK:** Yes.

5           **MS. JAYE:** Yes. I think we're on Exhibit  
6 No. 11. Call this Late-filed Exhibit 11.

7           **COMMISSIONER DEASON:** Okay.

8           **MR. MELSON:** Commissioner Clark, if we call  
9 our next witness on the stand, we think this number  
10 exists in a way that we probably can get it over the  
11 telephone.

12           **COMMISSIONER CLARK:** That would be fine.

13           **MR. MELSON:** And rather than doing a  
14 late-filed exhibit, I would much prefer to get that  
15 information back verbally during the day today.

16           **COMMISSIONER CLARK:** That's okay with me.

17           **MR. MELSON:** Let me consult with the witness  
18 one minute.

19                   (Brief recess taken.)

20           **Q**       **(By Ms. Jaye)** Ms. Burke, turning to Page 2  
21 on the confidential exhibit. There is a column  
22 entitled Proposal And Utility Cost. Looking at that  
23 column, how does it explain how the expansion plan  
24 differs from the base case plan?

25           **A**       Just by looking at this number you probably

1 couldn't tell how the base case plan and the expansion  
2 plan change. You would have to look at our answer to  
3 Interrogatory No. 2 to pull that. But it is -- the  
4 cost of that change is included in that column.

5 Q In calculating that proposal utility cost,  
6 would the first 600-megawatt block of generic capacity  
7 be replaced by the Smith Unit 3 and RFP respondent,  
8 et cetera?

9 A Yes. The base case is run with a  
10 placeholder of 600 megawatts and that is replaced in  
11 the proposal utility cost case with whichever  
12 proposal, whichever alternative you're doing the  
13 evaluation.

14 Q Do the capital and O&M cost columns on  
15 Page 2 of the confidential exhibit portray the  
16 incremental cost of the new unit addition?

17 A Yes, it does.

18 Q Do the columns entitled "Base Case Utility  
19 Cost" and "Proposal Utility Cost" on this same page  
20 refer to the total system revenue requirements  
21 associated with the entire Southern Company system,  
22 including all fuel impacts?

23 A Yes, it does.

24 Q How can cost-effectiveness to Gulf Power  
25 Company for this unit addition be determined when the

1 cost-effectiveness analysis was performed under a  
2 Southern Company system basis?

3       **A**     I believe that, especially in the case of --  
4 well, in the case of a combined cycle, this particular  
5 combined cycle is going to dispatch numerically really  
6 soon in the Southern Company dispatch. Because the  
7 Southern Company dispatch pool is done on a pool  
8 basis, the units are dispatched up against all of the  
9 Southern Company units. Smith Unit 3 actually has a  
10 very low dispatch price, and, therefore, it's  
11 dispatched very early in the dispatch algorithm.  
12 Because the Southern electric system has a pool  
13 dispatch, I think that this is an appropriate method  
14 to use for an evaluation of any set of alternatives  
15 that you're looking at.

16       **Q**     Remaining with this Page 2 of the  
17 confidential exhibit for awhile, on Page 2 in the  
18 following pages, the Transmission Grid and Connection  
19 Accumulated Present Value column shows a certain  
20 number and it changes relative to the base case. On  
21 the subsequent pages of this analysis, which  
22 represents the cost for the RFP projects and the  
23 respondents, does this same column indicate the  
24 incremental difference between their transmission  
25 costs and the transmission costs associated with the

1 Smith Unit 3?

2           **A**     Yes, that's correct. Plant Smith had the  
3 lowest of all of the costs for the transmission grid  
4 connection costs and that's the way the transmission  
5 planning provided these numbers to me.

6           **Q**     If the actual revenue requirements  
7 associated with transmission costs for Smith Unit 3  
8 and the RFP respondents were shown, would the total  
9 cost differential between the Smith Unit 3 and the RFP  
10 projects change?

11           **A**     The differential between Smith and the other  
12 units wouldn't change because you would just add that  
13 many dollars per kW back into all of the different  
14 respondents, so the relative number between --  
15 differential between those would really not change.

16           **Q**     I'd like to turn now to Composite Exhibit  
17 No. 7, which is the nonconfidential exhibit that Staff  
18 has offered.

19                   **COMMISSIONER DEASON:** Before we leave the  
20 confidential exhibit, I have a question.

21                   **MS. JAYE:** Okay.

22                   **COMMISSIONER DEASON:** The total cost column,  
23 I take it, is a function of the total fixed cost and  
24 the energy savings, and those two numbers are netted  
25 together; is that correct?

1           **WITNESS BURKE:** That's correct.

2           **COMMISSIONER DEASON:** Could you explain to  
3 me again -- and you may already have. And if you  
4 have, could you explain again what the column entitled  
5 "Energy Savings" represents?

6           **WITNESS BURKE:** Yes. It is the difference  
7 between the two columns just to the left of that. You  
8 take the total dollars of the production cost with its  
9 unit in versus the production cost of just the  
10 placeholder in instead, and divide it by the total  
11 number of megawatts, this 600-megawatt placeholder  
12 size that we used in this evaluation, you'll get the  
13 numbers that are shown in that energy savings and  
14 expansion plan number.

15           **COMMISSIONER DEASON:** And you used the same  
16 methodology to evaluate the other alternatives?

17           **WITNESS BURKE:** Yes, I did.

18           **COMMISSIONER DEASON:** I don't want to  
19 divulge any confidential information. Can you just  
20 give me generically why the self-build energy savings  
21 are of the magnitude they are in comparison to the  
22 energy savings of some of the alternatives? Is there  
23 some generic reason for that?

24           **WITNESS BURKE:** Let me see if I can find one  
25 that I can talk you through. The -- I guess Page 10

1 of this is the next best alternative, so that would be  
2 a good one to talk you through.

3           It says the same thing. I guess the  
4 components of this particular proposal really only  
5 included the capacity cost. They didn't break out  
6 fixed O&M and different components. They really just  
7 included one fixed charge. People do it different  
8 ways and we just adapt to that. So, the fixed costs  
9 are all included in that column that we show here  
10 called "Capacity Cost."

11           Then we did the same thing. We ran that  
12 same base utility cost case with the 600-megawatt  
13 placeholder and then we ran this proposal in here,  
14 which was a CT alternative, for 20 years. You can see  
15 that it's really not surprising when you think about  
16 it, that the CT has very little energy savings on a  
17 dollar-per-kW basis. You would expect that a CT would  
18 not have a lot of energy savings over generic units  
19 within your mix, so that's not surprising. You can  
20 see that the numbers start off very low. There is  
21 some --

22           **COMMISSIONER DEASON:** Just because it would  
23 be dispatched very late?

24           **WITNESS BURKE:** That's right. In the  
25 dispatch order, they would be much higher in the

1 dispatch order. There is some -- you see some wiggle  
2 room within the numbers. That really has to do with  
3 the expansion plan changing through time, maybe a  
4 combined cycle was built in the expansion plan to  
5 optimize the fuel, the total cost. So within the  
6 expansion plan, we don't really hold that constant.  
7 We let the expansion plan change with the alternative  
8 that's being proposed. If a CT is proposed, it's not  
9 uncommon for the expansion plan to change somewhere  
10 through time and to add more combined cycles to bring  
11 the mix back into balance.

12           So you can see that the numbers change  
13 through time. I think that what you've got there is  
14 really some more expansion plan changes than just  
15 fixed energy savings.

16           **Q**       **(By Ms. Jaye)** Ms. Burke, in relation to  
17 those confidential items -- you don't have to open  
18 them up again. Is it your opinion that the most  
19 cost-effective alternative, and the fact that Smith  
20 Unit 3 looks to be the most cost-effective alternative  
21 from the runs that were done and included in this  
22 confidential composite exhibit, means the most  
23 cost-effective alternative to all Southern Company  
24 utilities?

25           **A**       I think it's more of a relative ranking,

1 relative to all the other alternatives that you have  
2 on the table. Smith Unit 3 is overwhelmingly the  
3 lowest cost alternative.

4 Q I'd like to refer now to Composite Exhibit 7  
5 offered by Staff. Will you turn to Page 192?

6 COMMISSIONER JACOBS: Can I clarify  
7 something? Does the savings for Smith 3 include the  
8 enhancements?

9 WITNESS BURKE: Yes. I did the analysis for  
10 both a 540-megawatt size and a 574-megawatt size. The  
11 numbers that we were just looking at on Page 2 of the  
12 confidential material does include the 574-megawatt  
13 size.

14 Q (By Ms. Jaye) I'd like for you to take a  
15 look at pages 102 through 230. Could you tell me what  
16 this document is?

17 A This is my deposition from May 11th.

18 Q Do you have any changes or additions to make  
19 to this?

20 A No, I don't.

21 Q I'd like you to turn to Pages 2 through 13,  
22 again of the confidential information. Looking now at  
23 Page 1 and following, this is Gulf's response to  
24 Staff's Interrogatory No. 1. Was this response  
25 prepared under your supervision and direction?

1           **A**     Yes.

2           **Q**     Can you briefly summarize the reasons for  
3 the differences in natural gas price forecasts between  
4 Smith Unit 3 and the RFP alternatives?

5           **A**     Certainly. The RFP alternatives, they're  
6 proposals included a particular pricing or particular  
7 index for the fuel supply. To the extent that we  
8 could model those, we used our own fuel forecasts  
9 through time and tried to figure out what the basis  
10 differential was between our own fuel forecast and  
11 that indexed location that they used in their bids.

12          **Q**     Turning back again to the Composite Exhibit  
13 7, which is the nonconfidential information provided  
14 by Staff, if you would turn to Page 15, please. This  
15 is Gulf Power's response to Staff's Interrogatory No.  
16 18. Was this response prepared under your supervision  
17 and direction?

18          **A**     Yes, I believe it was.

19          **Q**     Can you briefly describe the status of  
20 backup fuel capability for Smith Unit 3 under the RFP  
21 alternatives?

22          **A**     Smith Unit 3 does not have a fuel oil backup  
23 system. They have firm fuel delivery guaranteed from  
24 a particular supplier now. Several of the respondents  
25 to the RFP were in a similar situation. Respondent A

1 proposed in two facilities; one had fuel oil backup,  
2 the other one did not. Both of those were base-load  
3 type of facilities and they were concerned about their  
4 air permit as well. Respondent B did include fuel oil  
5 backup and Respondent C did not include additional  
6 backup.

7 Q Turning now to Pages 16 through 18. These  
8 are Gulf's responses to Staff's Interrogatories 19 and  
9 20. Were responses to Interrogatories 19 and 20  
10 prepared under your supervision or direction?

11 A I did help pull these responses together,  
12 yes.

13 Q What sources did Southern Company use when  
14 it created the price forecast for coal, natural gas  
15 and oil?

16 A The coal price that we used for this  
17 particular exhibit is a Central Appalachia coal. It's  
18 FOB at the mine mouth. The gas is a Mobile Bay price  
19 and the oil is a Gulf Coast price.

20 MS. JAYE: No further questions.

21 CHAIRMAN GARCIA: Okay. Commissioners?  
22 Redirect?

23 MR. MELSON: I've got a few.

24 REDIRECT EXAMINATION

25 Q (By Mr. Melson) Ms. Burke, if you turn

1 back to Interrogatory 18, which we were just looking  
2 at on Page 15 of Exhibit 7, is it fair to say that  
3 Respondent C, who did not provide fuel oil backup, did  
4 quote a firm gas transportation supply?

5 A Yes, they did quote the price. That is  
6 included in their proposal.

7 Q And the respondents who quoted fuel oil  
8 backup, did they have firm gas transportation or were  
9 they relying on some other gas arrangements?

10 A There was one proposal that did include  
11 both.

12 Q You were asked some questions about Pages 91  
13 through 93 of Confidential Exhibit 8, which was a  
14 comparison of Smith to the RFP responses on a total  
15 dollar basis. Could you turn to Pages 117 and 118 of  
16 Exhibit 7 and tell me if that is a summary -- a  
17 nonconfidential summary, if you will, of the  
18 information that Staff was referring to in the  
19 confidential exhibit?

20 A Yes, it is a summary of that same  
21 information. This particular one that I have on Page  
22 117, someone has noted on here 540 megawatts. That's  
23 not true. This is the 574-megawatt size analysis, but  
24 this is before we found the transmission loss  
25 miscalculation. So this is not the final numbers.

1           **Q**     If you turn to Page 118, is Page 118 what  
2 you would regard as the final numbers?

3           **A**     Yes.

4           **Q**     And so based on that method of analysis that  
5 the Staff asked you to perform, that would show the  
6 self-build alternative being roughly \$121 million  
7 better than the next most cost-effective?

8           **A**     That's correct.

9           **MR. MELSON:** That was all I had on redirect.  
10 If we could stand in place for a few seconds. Let me  
11 check on the status of the answer to Commissioner  
12 Clark's question.

13           **COMMISSIONER CLARK:** Mr. Howell can give it  
14 to us.

15           **MR. MELSON:** I think Mr. Pope was the one  
16 who had the phone conversation. I think what we're  
17 going to have -- we're going to ask Ms. Burke, after  
18 she leaves the stand here, to talk with her person  
19 back in Birmingham who has hands-on access to those  
20 numbers and confirm that they, indeed, are looking at  
21 the correct ones before we give you a number. We want  
22 to make sure we got absolutely the right one. If we  
23 could have permission to bring Ms. Burke back here in  
24 a few minutes after we finish with Mr. Howell?

25           **CHAIRMAN GARCIA:** Sure.

1           **MR. MELSON:** And with that, I move Exhibit  
2 Nos. 9 and 10.

3           **CHAIRMAN GARCIA:** There being no objection,  
4 show 9 and 10 admitted.

5           (Exhibits 9 and 10 received in evidence.)

6           **MR. MELSON:** And Gulf Power would call  
7 Mr. Howell.

8           **CHAIRMAN GARCIA:** Let's take 15 minutes.

9           **MR. MELSON:** Great. Thank you.

10          **CHAIRMAN GARCIA:** And we'll start back up at  
11 3:00 p.m.

12          (Brief recess.)

13                                   - - - - -

14          **COMMISSIONER DEASON:** We'll go back on the  
15 record.

16          **MR. MELSON:** Commissioners, I brought  
17 Ms. Burke back on the stand to answer the question  
18 Commissioner Clark had about what number would go on  
19 Exhibit MJB-3. We had run the -- what we call the  
20 Attachment C numbers, which was the numbers that were  
21 published with the RFP.

22           **Q**        **(By Mr. Melson)** Ms. Burke, could you tell  
23 us what that number would be on a total generation and  
24 transmission basis, which is the basis that's  
25 reflected on MJB-3?

1           **A**     Certainly. The total net present value for  
2 generation and transmission is \$325.56 per kilowatt.

3           **Q**     And so rather than the 500 rate that you had  
4 recollected today, it's actually \$325?

5           **A**     Yes. The number that I was using from  
6 memory, we had done at that point a generation-only  
7 type of analysis, and it did not include \$109 a  
8 kilowatt for transmission benefit.

9                     So the generation-only number that I was  
10 remembering is actual \$435 a kW. When you subtract  
11 off that transmission benefit, you get to the number  
12 that we're talking about, the 325.56.

13                    **COMMISSIONER CLARK:** So they weren't even  
14 close to what you put out in the RFP.

15                    **WITNESS BURKE:** That's correct. On a  
16 generation-only basis, they were pretty close, when --  
17 the transmission benefits. Even Attachment C numbers  
18 are better than the next best alternative respondent  
19 in the RFP.

20                    **COMMISSIONER CLARK:** Okay.

21                    **MR. MELSON:** Can Ms. Burke be excused?

22                    **CHAIRMAN GARCIA:** Yes.

23                    **COMMISSIONER CLARK:** Let me just ask: The  
24 325 number you gave me is the same -- is the number  
25 you would enter on your exhibit? We're comparing

1 apples to apples here?

2 WITNESS BURKE: (Nodding head.)

3 COMMISSIONER CLARK: Thank you.

4 (Witness Burke excused.)

5 - - - - -

6 MS. JAYE: Commissioner Clark, does that  
7 therefore obviate the necessity for the late-filed  
8 exhibit -- (inaudible) --

9 COMMISSIONER CLARK: (Inaudible)

10 (Court reporter asked for clarification.)

11 CHAIRMAN GARCIA: That that will now make  
12 the late-filed exhibit unnecessary, that last one. I  
13 don't think we have any late-filed exhibits. Okay.

14 MR. MELSON: And one housekeeping matter,  
15 Commissioners. I have passed out -- it's on the table  
16 in front of you -- the errata sheet to the deposition  
17 of Mr. Marler. His deposition is included in Staff's  
18 Exhibit 7, and when he was on the stand I forgot to  
19 hand out his errata sheet. I'd ask, perhaps, if we  
20 could mark that as Exhibit No. 11 and have it admitted  
21 into the record.

22 CHAIRMAN GARCIA: Do we have an Exhibit 11?

23 MS. JAYE: We do not have an Exhibit 11, no.

24 CHAIRMAN GARCIA: All right. This is  
25 Exhibit 11, then.

1 (Exhibit 11 marked for identification and  
2 received in evidence.)

3 **MR. MELSON:** Also, just as an update, at  
4 Staff's request we have filed the firm transportation  
5 agreement that was entered into on Friday with the  
6 clerk's office, accompanied by a notice of intent to  
7 request confidential classification. My understanding  
8 is Staff may want to make that agreement a formal part  
9 of the record.

10 **MS. JAYE:** Yes. Staff would move to include  
11 in the Composite Exhibit No. 8, this letter.

12 **CHAIRMAN GARCIA:** Very good. That's part of  
13 Composite Exhibit No. 8. Okay.

14 **MR. MELSON:** And we've called Mr. Howell to  
15 the stand.

16 - - - - -

17 **M. W. HOWELL**  
18 was called as a witness on behalf of Gulf Power  
19 Company and, having been duly sworn, testified as  
20 follows:

21 **DIRECT EXAMINATION**

22 **BY MR. MELSON:**

23 **Q** Mr. Howell, would you state your name and  
24 business address, please?

25 **A** My name is M. W. Howell. My business

1 address is One Energy Place, Pensacola, Florida 32501.

2 Q And what is your position with Gulf Power  
3 Company?

4 A Manager of system planning and transmission  
5 control.

6 Q And have you prefiled eight pages of direct  
7 testimony in this docket?

8 A Yes.

9 Q Do you have any changes or corrections to  
10 that testimony?

11 A No.

12 Q And if I were to ask you the same questions,  
13 would your answers be the same?

14 A Yes.

15 MR. MELSON: Mr. Chairman, I'd ask that  
16 Mr. Howell's direct testimony be inserted into the  
17 record as though read.

18 CHAIRMAN GARCIA: Okay.

19 WITNESS HOWELL: Let me correct something I  
20 said. I don't often get that question. My direct  
21 title is manager of transmission and system control.  
22 I think I said it wrong.

23 CHAIRMAN GARCIA: Okay; with that  
24 correction.

25

GULF POWER COMPANY

Before the Florida Public Service Commission  
Direct Testimony of  
M. W. Howell  
Docket No. 990325-EI  
Date of Filing: April 5, 1999

1  
2  
3  
4  
5  
6 Q. Please state your name, business address and  
7 occupation.

8 A. My name is M. W. Howell, and my business address is One  
9 Energy Place, Pensacola, Florida 32520. I am  
10 Transmission and System Control Manager for Gulf Power  
11 Company.

12  
13 Q. Have you previously testified before this Commission?

14 A. Yes. I have testified in various rate case,  
15 cogeneration, territorial dispute, planning hearing,  
16 fuel clause adjustment, and purchased power capacity  
17 cost recovery dockets.

18  
19 Q. Please summarize your educational and professional  
20 background.

21 A. I graduated from the University of Florida in 1966 with  
22 a Bachelor of Science Degree in Electrical Engineering.  
23 I received my Masters Degree in Electrical Engineering  
24 from the University of Florida in 1967, and then joined  
25 Gulf Power Company as a Distribution Engineer. I have

1 since served as Relay Engineer, Manager of  
2 Transmission, Manager of System Planning, Manager of  
3 Fuel and System Planning, and Transmission and System  
4 Control Manager. My experience with the Company has  
5 included all areas of distribution operation,  
6 maintenance, and construction; transmission operation,  
7 maintenance, and construction; relaying and protection  
8 of the generation, transmission, and distribution  
9 systems; planning the generation, transmission, and  
10 distribution systems; bulk power interchange  
11 administration; overall management of fuel planning and  
12 procurement; and operation of the system dispatch  
13 center.

14 I am a member of the Engineering Committees and  
15 the Operating Committees of the Southeastern Electric  
16 Reliability Council and the Florida Reliability  
17 Coordinating Council, and have served as chairman of  
18 the Generation Subcommittee of the Edison Electric  
19 Institute System Planning Committee. I have served as  
20 chairman or member of many technical committees and  
21 task forces within the Southern electric system, the  
22 Florida Electric Power Coordinating Group, and the  
23 North American Electric Reliability Council. These  
24 have dealt with a variety of technical issues including  
25 bulk power security, system operations, bulk power

1 contracts, generation expansion, transmission  
2 expansion, transmission interconnection requirements,  
3 central dispatch, transmission system operation,  
4 transient stability, underfrequency operation,  
5 generator underfrequency protection, and system  
6 production costing.

7

8 Q. What is the purpose of your testimony in this  
9 proceeding?

10 A. The purpose of my testimony is to summarize the  
11 requirement which our customers have for the 540 MW  
12 combined cycle addition at Plant Smith.

13

14 Q. Are you sponsoring any exhibits to supplement your  
15 testimony in this proceeding?

16 A. Yes, I am sponsoring Sections 1, 2, and 9.4, as well as  
17 Appendix A, of the Need Study filed in this docket.

18

19 Q. What is the first data which Gulf examines in  
20 determining a need for future capacity?

21 A. The load forecast is the first major input. The  
22 Company's Witnesses Neyman and Marler have described in  
23 detail what goes into preparing our forecast, the state  
24 of the art computer models we use, and the integration  
25 of expected conservation and other adjustments to

1 develop a sound forecast. The result is a forecast  
2 which predicts with reasonable accuracy what our future  
3 demands will be. The fact that we have a forecasting  
4 accuracy that places us in the top third of state  
5 utilities is testimony to the quality and dependability  
6 of our forecast.

7

8 Q. What is the next step in the process?

9 A. We compare our load forecast to our available capacity.  
10 Our goal is to have enough generation resources to  
11 cover our load with a reasonable reserve margin. As  
12 covered in Mr. Pope's testimony, we will have adequate  
13 capacity through 2001 by using external power purchases  
14 and by relying upon available Southern system reserves.  
15 By 2002, when the purchases expire, we will be 427 MW  
16 short of capacity without additional resources. The  
17 540 MW addition at Smith Plant will be an appropriate  
18 fit for our needs.

19

20 Q. What is the next step in the process?

21 A. Once we know what our load and reserve requirements  
22 are, we must select the appropriate capacity resource.  
23 Mr. Pope has described how we determined what our  
24 reasonable alternative choices were for Gulf Power to  
25 add capacity, how we developed cost estimates for those

1 alternatives, and how we eventually came to the  
2 decision that our best self-build option was the Smith  
3 combined cycle unit.

4

5 Q. Did the plans of other utilities offer you any  
6 confirmation that you had come to the right choice?

7 A. Yes. Other utilities needing capacity are adding the  
8 same type of combined cycle capacity as we are  
9 proposing, primarily for the economics and efficiencies  
10 it offers the customers who use the electricity.

11

12 Q. What was the result of Gulf's analysis?

13 A. As Mr. Pope described, the 540 MW combined cycle  
14 facility at Smith Plant was the most cost-effective  
15 self-build alternative. It is a good match for the  
16 amount of capacity needed. The unit has an excellent  
17 heat rate. Gas is a good, economical fuel choice in  
18 today's energy market, with relatively lower associated  
19 environmental costs. And, most importantly of all, it  
20 resulted in a significantly lower cost than any other  
21 alternative.

22

23 Q. After Gulf determined that the Smith combined cycle  
24 project was the best internal choice, how did it  
25 proceed?

1 A. We prepared a Request For Proposals (RFP) to test the  
2 market for a long term power purchase. Such a market  
3 test is a reasonable way to determine if your project  
4 is the most cost-effective. So, we prepared the RFP,  
5 advertised it in state newspapers and national industry  
6 magazines, and sent unsolicited copies to approximately  
7 100 potential respondents.

8

9 Q. What was the result of Gulf's analysis of the responses  
10 as compared to your self-build option?

11 A. Witness Maria Burke has covered in detail how the  
12 proposed facility at Smith Plant has an NPV savings to  
13 our customers of over \$90 million over the 20-year  
14 evaluation period compared to the best offer received  
15 in response to the RFP. With this overwhelming  
16 economic advantage, Smith Unit 3 was clearly the  
17 Company's most cost-effective alternative.

18

19 Q. What would the consequences be if the Commission did  
20 not find a need for Smith Unit 3?

21 A. As mentioned in Section 3.4.4 of the Need Study, recent  
22 inquiries in the purchased power market have resulted  
23 in fewer and more expensive offers for capacity and  
24 energy. Gulf has demonstrated through steps taken to  
25 date that its selection of Smith Unit 3 is the most

1 cost-effective alternative available for the Company to  
2 meet its customers' load requirements beginning in  
3 2002. Even with some minor delays, Gulf believes that  
4 it can achieve a summer 2002 in-service date for Smith  
5 Unit 3 in order to prevent having to use this high-  
6 priced purchased power. However, if there is a long  
7 delay of Smith Unit 3 that prevents meeting the June  
8 2002 in-service date, at a minimum Gulf's customers  
9 will pay more for their electrical energy than  
10 necessary. The Company is also concerned with the  
11 possibility that without this unit's timely  
12 installation, which helps support Southern system  
13 reserves, there are additional reliability issues that  
14 could affect customer service.

15  
16 Q. What, then, is Gulf asking of this Commission?

17 A. We are asking for a prompt certification of the need  
18 for Smith Unit 3 so we may proceed with the many  
19 remaining steps necessary to get this capacity  
20 installed for our customers' 2002 requirements.

21 We have demonstrated clearly that we need this  
22 additional capacity for our customers' needs in 2002.  
23 We have developed a quality load forecast that  
24 consistently gives good results. We have examined  
25 reasonable generating alternatives and determined that

1 the best self-build candidate for our future generation  
2 needs is Smith Unit 3.

3 We have gone through the formal RFP process to  
4 determine the market economics of long-term power  
5 purchases as opposed to our own construction, performed  
6 a rigorous economic analysis, and demonstrated that  
7 Smith Unit 3 is a clear winner over any other available  
8 alternative. We ask the Commission to certify our need  
9 as soon as practicable.

10

11 Q. Does this conclude your testimony?

12 A. Yes.

1           Q        (By Mr. Melson) And you had no exhibits  
2 attached to your direct testimony; is that correct?

3           A        Correct.

4           Q        You are sponsoring, are you not, Chapters 1,  
5 2, Section 9.4, and Appendix A of the need study  
6 that's previously been identified as Exhibit 1?

7           A        Yes.

8           Q        And do you have any changes or corrections  
9 to your portions of that document?

10          A        No.

11          Q        Mr. Howell, could you briefly summarize your  
12 testimony?

13          A        I'll do it briefly.

14                    Good afternoon, Commissioners. You have  
15 heard our case. We believe we have met your  
16 regulatory standard to establish our need for Smith 3.  
17 By 2002 when Gulf plans to have the capacity in  
18 service, we will need approximately 75% of the maximum  
19 capability of the unit.

20                    Without the unit, we have negative  
21 generation reserves and we have reliability problems  
22 that our customers will face. We feel like we have  
23 done what is required to establish the need. We have  
24 demonstrated that our load forecasting process is  
25 adequate for planning purposes. It uses

1 state-of-the-art models. It gives good results. Our  
2 service territory continues to grow, and we need more  
3 electricity to serve this growing number of customers.

4 Gulf has performed a reasonable screening of  
5 all the alternatives available to us. We have looked  
6 at all the options to meet our growing load. Our  
7 self-build analysis determined that Smith 3 was the  
8 clear winner. It will use gas, a clean, relatively  
9 clean, burning fuel. The combined cycle technology  
10 which we propose has a high efficiency that is  
11 unavailable with any other generation alternative.

12 To ensure that our customers got the best  
13 deal, we issued an RFP. We tested the market to see  
14 if we could buy it cheaper than we could build it  
15 ourselves. We've done that. We've done a thorough  
16 cost-effectiveness analysis of it, and our unit is  
17 easily the winner.

18 What do we ask? We ask that you grant our  
19 request for a prompt approval of our generating unit  
20 so that we can complete all the steps necessary to get  
21 it in service by the summer of 2002.

22 That completes my summary.

23 **CHAIRMAN GARCIA:** Okay.

24 **Q** (By Mr. Melson) Mr. Howell, I've got a  
25 couple of questions for you to follow up on things

1 that have been asked of other witnesses today.

2 From your perspective, has Gulf made a sound  
3 decision in deciding that backup fuel is unnecessary  
4 for Smith Unit 3?

5 A Yes, I believe we have.

6 And one particular thing, Commissioner  
7 Clark, that you asked was were we recommending,  
8 perhaps, that it was not a good policy decision for  
9 backup fuel.

10 And I think Gulf would like to make a clear  
11 distinction between a policy for maybe generating  
12 units in south Florida where many, many generating  
13 units are served off of a single pipeline and there is  
14 a disruption, as was evidenced by the problem at  
15 Perry, as opposed to Gulf Power.

16 We are asking for just one generating unit  
17 at the Smith plant right now on its own lateral. If  
18 we were asking for a number of generating units, then  
19 clearly I think we would evaluate the economics of a  
20 backup fuel supply.

21 **COMMISSIONER CLARK:** Mr. Howell, I'm  
22 satisfied that that question was answered. The  
23 indication to me was because of where -- the other  
24 fuel available to you in your interconnection, it  
25 doesn't make sense to do --

1                   **WITNESS HOWELL:** Okay.

2                   **COMMISSIONER CLARK:** -- the backup fuel.

3                   **WITNESS HOWELL:** Okay. Let me go ahead and  
4 just comment on one other thing about that.

5                   We certainly would have evaluated the  
6 benefits of the backup fuel if we felt like there was  
7 any chance at all that would be an economic issue, but  
8 the reliability of gas pipelines, I think we all know  
9 they say like once in 20 years you're going to have a  
10 problem like that.

11                   In the 20-plus years I've been involved in  
12 system planning, it's the only one I have heard of.  
13 It is a very low probability event. And the fact that  
14 a steam turbine outage would take the unit out anyway,  
15 we have processed all that -- all of that through our  
16 economics and determined that it's really not worth  
17 the backup fuel.

18                   **Q           (By Mr. Melson)** And one other question,  
19 Mr. Howell.

20                   Ms. Burke testified that her economic  
21 evaluations looked at system-wide fuel savings, if you  
22 will, on the Southern system. How can we be sure that  
23 when the project is evaluated on that basis that that  
24 system-wide fuel savings will actually be experienced  
25 by Gulf's customers?

1           A     Well, for sure we cannot say with  
2 100 percent certainty that all of those savings go to  
3 Gulf's customers. But I will tell you that I would  
4 say between 90 and 100% of those, maybe 95 and 100% of  
5 those, go to Gulf's customers.

6                     And the reason is, the way we operate the  
7 system, we dispatch the units on an economic basis,  
8 and right now if we are buying or selling, we sell  
9 within the pool at our system marginal cost. So if  
10 Gulf is able to -- if it's in a buying mode, if it's  
11 able to generate with this lower cost energy rather  
12 than buying at system lambda, all those savings go to  
13 Gulf's customers. We don't have to pay system lambda.

14                    And if we are in a selling mode, then the  
15 additional megawatt hours that this unit generates we  
16 can then sell at the difference between the system  
17 lambda and that unit's dispatch cost, and we get to  
18 keep all of that. And that's the way she ran her  
19 analysis. It was what happens to the total fuel cost  
20 on the system.

21                    So the fact that we dispatch the units on an  
22 economic basis, every company gets to keep the lowest  
23 cost energy for its customers and we buy and sell at  
24 system lambda, you'd be hard-pressed to say that all  
25 those fuel savings don't go to your customers.

1           **MR. MELSON:** Mr. Howell is available for  
2 cross.

3           **MS. KAMARAS:** No questions.

4           **MS. JAYE:** Staff has no questions.

5           **CHAIRMAN GARCIA:** Commissioners? Redirect?  
6 You don't have any. All right.

7                   (Witness Howell excused.)

8                                 - - - - -

9           **MR. MELSON:** And at this point, Chairman  
10 Garcia, I would move Exhibit 1, which is the need  
11 study that's now -- every piece of that has now been  
12 sponsored by the appropriate witness.

13           **CHAIRMAN GARCIA:** There being no objection,  
14 show it into the record as admitted.

15                   (Exhibit 1 received in evidence.)

16           **CHAIRMAN GARCIA:** Anything else?  
17 Commissioner Deason stated -- I wasn't aware of it --  
18 that you wanted us to make a decision, bench decision,  
19 on this today.

20           **COMMISSIONER DEASON:** It is in the  
21 prehearing order that this possibility exists, and the  
22 parties were put on notice that if the Commission  
23 wanted to entertain the possibility of a bench  
24 decision, the parties were put on notice that they  
25 need to be prepared to conduct a closing argument in

1 lieu of filing briefs; but there was no decision made  
2 whether there would or would not be a bench decision.

3 **CHAIRMAN GARCIA:** Would Staff feel  
4 comfortable making a recommendation?

5 **MS. JAYE:** Yes, Chairman Garcia; Staff is  
6 prepared to make an oral recommendation at this point.

7 **CHAIRMAN GARCIA:** All right. Commissioners,  
8 the only thing is I have a problem -- he's at a  
9 conference call.

10 (Discussion off the record between  
11 Commissioners.)

12 **CHAIRMAN GARCIA:** Let's do this. You  
13 organize your thoughts.

14 Do you want to make a --

15 **MR. MELSON:** I'd like to make a brief  
16 closing argument. It takes about five minutes.

17 **CHAIRMAN GARCIA:** Why don't you do that now  
18 so they can think about that and then they can make  
19 their recommendation, and then we're all finished up  
20 and all we require is a vote, if Commissioner Jacobs  
21 is willing to vote with us on this.

22 **MR. MELSON:** Commissioners, I'm going to  
23 urge in closing that you should vote to approve a  
24 determination of need for Smith Unit 3.

25 As you all are aware, Section 403.519

1 establishes four factors that you must take into  
2 account in making your determination, and we believe  
3 that the testimony you've heard today and the written  
4 evidence that's been admitted in this case supports an  
5 affirmative finding on each of those four statutory  
6 factors. I'm going to take them one by one.

7 First: "Has Gulf demonstrated there's a  
8 need for Smith Unit 3 when you take into account the  
9 need for electric system reliability and integrity?"

10 Our answer to that is absolutely yes. The  
11 evidence shows that without Smith Unit 3, Gulf's  
12 reserve margin would dip to a negative 6.3% in 2002.  
13 With the unit, we'll have adequate reserves to ensure  
14 the continuing reliability of Gulf's electric system  
15 when its existing purchase contracts expire in 2002.

16 The evidence also shows that Gulf has now  
17 arranged a firm gas transportation for the project  
18 that will support the reliable operation of the unit.

19 There were questions today about Gulf's  
20 decision not to use -- not to provide a backup fuel  
21 for the unit. We believe when you weigh all that  
22 evidence, when you look at the amount of coal on  
23 Southern's system, when you look at the inter-ties  
24 Southern has, when you look at the fact that Smith 3  
25 is the only unit at this site relying on natural gas,

1 and when you look at the fact that we've got a firm  
2 gas transportation contract and take all those into  
3 account, you should conclude that this unit is  
4 reliable without the need for a backup fuel.

5           **COMMISSIONER CLARK:** Are you going to add  
6 that it's also environmentally better?

7           **MR. MELSON:** It's environmentally better,  
8 and it enables us to get it permitted in the time and  
9 fashion. Thank you. This is part of my closing that  
10 I've actually done on the fly today. (Laughter.)

11           And the evidence also shows, Commissioner,  
12 that building the unit in the Panama City area  
13 balances the transmission and generation on Gulf's  
14 system and contributes to the integrity of the  
15 electric system, which is the other piece of that  
16 first test.

17           The second statutory factor: "Has Gulf  
18 demonstrated that there is a need for the Smith 3 when  
19 you take into account the need for adequate  
20 electricity at a reasonable cost?"

21           Again, we think absolutely we have. Gulf  
22 has submitted a high quality load forecast. It shows  
23 that Gulf needs at least 427 megawatts of additional  
24 resources to achieve its target reserve margin in the  
25 summer of 2002.

1           If you've got any question about whether  
2 that reserve margin ought to be higher, if it were  
3 higher, it would only enhance the need for the unit,  
4 not detract from it.

5           The evidence shows that Smith Unit 3 is a  
6 highly efficient combined cycle design that will  
7 provide adequate electricity to meet the needs of  
8 Gulf's customers, and the cost is significantly lower  
9 than any of the other alternatives.

10           The third statutory factor: "Has Gulf  
11 demonstrated that Smith Unit 3 is the most  
12 cost-effective alternative available?"

13           Again, the answer is absolutely yes. When  
14 it became clear that by the 2002 time frame, purchased  
15 power was going to be expensive and scarce, Gulf  
16 surveyed the waterfront for available self-build  
17 options and identified Smith Unit 3 as the best  
18 self-build alternative.

19           Following that initial identification, Gulf  
20 issued an RFP which sought outside alternatives to the  
21 unit. The evidence shows that process was conducted  
22 fairly and honestly in full compliance with the  
23 Commission's rules.

24           And unlike some other cases you've had, you  
25 don't have any intervenors here representing

1 disappointed bidders. I think that tells you  
2 something about the quality of Gulf's process.

3           As Ms. Burke described, the evaluation of  
4 Smith Unit 3 and those alternatives took into account  
5 all the appropriate cost factors; capital costs, O&M  
6 costs, fuel costs, system fuel savings, transmission  
7 costs, transmission loss savings. And it's the sum of  
8 all of those that is expressed in her number that says  
9 on a dollar-per-kilowatt, net present value basis  
10 Smith Unit 3 comes in at \$274 a kW compared to 496 per  
11 kW for the next best alternative.

12           Now, that's a little different type of way  
13 of expressing the results that you're accustomed to  
14 hearing in some other need cases. Staff asked us to  
15 do an analysis that was more in line with what they've  
16 seen in the past. And the result of that was shown on  
17 Pages 117 and 18, I believe, of the Exhibit 7, which  
18 showed the Smith Unit 3 is \$121 million better than  
19 the next best alternative using the analysis that  
20 Staff asked us to conduct.

21           So no matter whose methodology you decide is  
22 right, the answer is clear; Smith Unit 3 is by far and  
23 away the most cost-effective alternative.

24           The fourth and last statutory factor: "Has  
25 Gulf demonstrated that there are not any conservation

1 measures taken by or reasonably available to it that  
2 would enable the unit to be deferred?"

3 The evidence shows that Gulf has got  
4 existing conservation programs that have already  
5 reduced its summer peak demand by 244 megawatts in  
6 1997. The testimony shows that by 2002 when Smith  
7 Unit 3 is needed, that demand reduction will have  
8 increased 365 megawatts.

9 There's no way that Gulf can reasonably add  
10 another 427 megawatts of conservation on top of the  
11 365 and avoid the need for this unit. Gulf has acted  
12 responsibly in the conservation arena, and even with  
13 those savings, this unit is clearly needed.

14 In summary, Gulf has done a good job.  
15 They've done a thorough analysis. They've answered a  
16 lot of interrogatories and document production  
17 requests. This has been looked at by your Staff.  
18 You've got a lot of information before you in the  
19 record, and we believe that we've proved up every  
20 statutory element.

21 So we're asking you now to find that Gulf  
22 has a need for 427 megawatts of capacity by 2002 and  
23 that Smith Unit 3 at 574 megawatts is the best, most  
24 cost-effective way to meet that need.

25 **CHAIRMAN GARCIA:** All right. Thank you,

1 Mr. Melson.

2 Staff, are you ready to make a  
3 recommendation?

4 I'm sorry, Ms. Kamaras. You've been so  
5 quiet.

6 **MS. KAMARAS:** LEAF has no objection, with  
7 the Commission's approval, of the need for this case.

8 When we entered into this case we had a  
9 number of questions concerning the need. Most of  
10 those questions have been answered by Gulf, either  
11 through interrogatories or through informal  
12 discussions.

13 We have some remaining questions relating to  
14 some of the environmental aspects, but that's not --  
15 (inaudible) --

16 (Court reporter asked for clarification.)

17 **MS. KAMARAS:** So LEAF basically has no  
18 objection to your approving the plant at this time.

19 **CHAIRMAN GARCIA:** Thank you. Staff?

20 **MR. HAFF:** Yes. I'm Michael Haff of the  
21 Commission Staff.

22 In general, Staff recommends that the  
23 Commission grant Gulf Power Company's petition to  
24 determine the need for the proposed Smith Unit 3.  
25 Gulf's proposed unit will contribute to the provision

1 of electric system reliability and integrity as stated  
2 in Section 403.519, Florida Statutes.

3 A large part of Gulf's existing generating  
4 capacity comes from its part ownership of units  
5 outside its service territory. Much of the remaining  
6 capacity on Gulf's system comes from the Crist units  
7 located in the western part of the service territory.  
8 Thus, a generation load mismatch or imbalance  
9 currently exists in the Panama City region.

10 All responses to Gulf's request for  
11 proposals contain projects requiring substantial  
12 transmission system additions and upgrades to supply  
13 their capacity to the Panama City region. The  
14 addition of Smith Unit 3 will minimize the number and  
15 cost of transmission system upgrades and new  
16 construction required.

17 Currently there are no plans for a backup  
18 fuel source for Smith Unit 3. Gulf believes that the  
19 parties to its natural gas contract will guarantee  
20 firm natural gas capacity sufficient to avoid the need  
21 for backup fuel. Further, if natural gas supplied to  
22 the plant is interrupted, Gulf's reliance on the  
23 Southern Company system should not be materially  
24 affected, because Southern's system has very little  
25 natural gas. It's primarily coal and nuclear-fired.

1           As an aside to this subject, because Gulf  
2 has not performed a cost benefit analysis of not  
3 installing backup fuel, Gulf should be made aware that  
4 any future purchased power costs associated with a  
5 natural gas fuel interruption will be reviewed for  
6 prudence at subsequent fuel adjustment proceedings.  
7 In other words, because of a lack of analysis, the  
8 prudence of future cost recovery of dollars associated  
9 with fuel supply interruptions will be investigated if  
10 and when they occur.

11           **COMMISSIONER JACOBS:** Do we know if there  
12 were escalators in their contract or not; firm  
13 contract?

14           **MR. STONE:** There are none. It is fixed; 20  
15 years on transportation.

16           **MR. HAFF:** Staff would also ask for the  
17 Commission's permission to open a rulemaking docket to  
18 explore the policy of dual fuel capability for future  
19 power plants.

20           The need for adequate electricity at a  
21 reasonable cost: Gulf's proposed unit will contribute  
22 to the provision of adequate electricity at a  
23 reasonable cost, as stated in the 403.519, Florida  
24 Statutes.

25           Gulf has incorporated Southern's Company's

1 13.5% system reserve margin as its planning criterion.  
2 This criterion resulted from a study which compared  
3 the trade-off between the customers' cost of outages  
4 and the Southern System's cost to add peaking capacity  
5 to practically eliminate those outages.

6 Gulf's summer reserve margin in 2001, prior  
7 to adding Smith Unit 3, is forecasted to be around  
8 1.4%. After the addition of Smith Unit 3, the 2002  
9 summer peak -- or summer reserve margin is forecasted  
10 to be 17.6%. Staff believes that a 13.5% criterion is  
11 reasonable for Southern Company since the system has a  
12 low percentage of nonfirm load and can import over  
13 5700 megawatts through nine separate utility  
14 interconnections.

15 We heard today that Southern is considering  
16 reevaluating its reserve margin criterion. If it  
17 were -- returned back to 15%, the magnitude of Gulf's  
18 capacity need in 2002 will even been greater than is  
19 shown now, and Smith Unit 3 will still satisfy this  
20 need.

21 Gulf's load forecast appears to be  
22 reasonable. Gulf uses state-of-the-art computer  
23 models to forecast load and energy consumption. Gulf  
24 presents its load forecast as a net of demand savings  
25 from conservation programs, which means that the load

1 forecast used has already incorporated savings from  
2 conservation and demand-side programs.

3           The average forecast error in Gulf's load  
4 forecast over the last five years has been a  
5 relatively low 1.19%. Based on Gulf's load forecast  
6 and its reserve margin criterion, Gulf has identified  
7 a need for at least 427 megawatts of additional  
8 capacity in the year 2002. The proposed Smith Unit 3  
9 will meet Gulf's need for additional capacity.

10           Gulf's proposed unit is an advanced combined  
11 cycle unit with a rated summer capacity of  
12 574 megawatts. Its installed capital cost is  
13 approximately \$197 million, or \$343 per kW installed  
14 cost. This cost is reasonable and is in line with the  
15 cost of combined cycle units recently approved by this  
16 Commission for other utilities.

17           Gulf has demonstrated that the proposed  
18 Smith Unit 3 is the most cost-effective alternative  
19 available as required by Section 403.519, Florida  
20 Statutes.

21           Pursuant to the Commission's bidding rule,  
22 Rule 25-22.082, Florida Administrative Code, Gulf  
23 issued a request for proposals for capacity  
24 alternatives to Smith Unit 3. Staff believes that  
25 Southern Company's subsequent's analyses of RFP

1 responses and Gulf's self-build option was performed  
2 on a consistent basis.

3 This analysis included an evaluation of the  
4 cost of connecting each self-build option and RFP  
5 project to Gulf's transmission system. Staff believes  
6 that Gulf adequately explored and incorporated the  
7 cost of such interconnections for each proposal.

8 The cost-effective analysis also included an  
9 evaluation of the cost to connect each self-build and  
10 RFP project to a natural gas transmission system.  
11 Gulf just signed a gas supply contract for  
12 transportation as of last Friday. Gulf received four  
13 responses to an RFP to supply gas to the project.  
14 Southern Company in its evaluation was conservative by  
15 using the most costly of the four in its  
16 cost-effectiveness evaluation for Smith Unit 3.

17 Staff believes that the fuel price forecasts  
18 used by Gulf in its cost-effectiveness evaluation are  
19 reasonable. Gulf made reasonable site-specific  
20 adjustments to the forecast to account for location  
21 differences among the RFP projects.

22 Staff believes that the financial  
23 assumptions used by Gulf in its cost-effectiveness  
24 analyses are reasonable. These financial assumptions  
25 were uniformly applied by Gulf in its evaluation of

1 self-build options and RFP projects.

2           Incorporating all costs associated with unit  
3 construction, transmission interconnection, and gas  
4 supply, Southern Company found that Smith Unit 3 was  
5 the most cost-effective available to Gulf. Southern  
6 uses a relative ranking system to determine  
7 cost-effectiveness of resource alternatives. This  
8 ranking is given in dollars per kW, but differs from  
9 installed cost.

10           Southern takes the total network element  
11 present value cost of the project over its lifetime.  
12 These costs include capital, operations and  
13 maintenance, transmission, fuel, and other available  
14 costs and divides by the size of the unit. Using  
15 Southern's dollar per kW relative ranking system,  
16 Smith Unit 3 is substantially the most cost-effective  
17 alternative available.

18           The Commission has traditionally determined  
19 the cost-effectiveness of a proposed power plant based  
20 on a total dollar, cumulative present worth revenue  
21 requirements basis. On this basis, Smith Unit 3  
22 offers savings of approximately \$121 million over the  
23 next best alternative.

24           In summary, Gulf's analysis of self-build  
25 and RFP projects resulted in Gulf selecting the most

1 cost-effective alternative available in choosing Smith  
2 Unit 3.

3           There are no conservation measures available  
4 to Gulf which would mitigate the need for the proposed  
5 unit. Gulf's load forecast incorporates the demand  
6 savings from its existing and proposed conservation  
7 measures. Gulf's need for at least 427 megawatts in  
8 the year 2002 is net of conservation program savings.

9           In summary, based on the resolution of the  
10 factual issues discussed today, Staff recommends that  
11 the Commission grant Gulf Power's petition to  
12 determine the need for the proposed Smith Unit 3.

13           **CHAIRMAN GARCIA:** Commissioners?

14           **COMMISSIONER DEASON:** I would move adoption  
15 of Staff's recommendation.

16           **COMMISSIONER CLARK:** Let me ask a few  
17 questions.

18           With respect to the rulemaking, I don't  
19 think -- if Staff thinks we should do rules --  
20 Staff -- I'm not sure we need to do that.

21           **CHAIRMAN GARCIA:** I agree.

22           **COMMISSIONER DEASON:** I have no problem with  
23 that. That can be done -- it doesn't have to be part  
24 of this need determination.

25           **COMMISSIONER CLARK:** With respect to the --

1 the fuel, when were you looking at the fact that they  
2 don't have backup fuel, is what you're saying is for  
3 planning purposes it appears that not providing for  
4 backup fuel is appropriate, but it has to be  
5 constantly reviewed by the company to ensure that it  
6 continues to be the best way to prepare their system  
7 for outages, and should there be an outage occurred by  
8 the interruption of the natural gas supply to this  
9 plant, we would look at whether or not it was prudent  
10 to have continued the policy of not having backup fuel  
11 at that plant? Is that correct?

12 **MR. HAFF:** That's correct.

13 **COMMISSIONER CLARK:** Okay. Then I'm  
14 prepared to agree with the motion.

15 **CHAIRMAN GARCIA:** All right. Me, too. I  
16 also wanted to ask, we are in no way agreeing to their  
17 reserve margin of 13-some percent? Because I'd rather  
18 not do it in this docket. I don't feel comfortable.  
19 I know we recognize that's what they have. I'm not  
20 saying that's good or bad.

21 **COMMISSIONER CLARK:** A 15 and a 13 --

22 **CHAIRMAN GARCIA:** Now, that -- Staff went  
23 further from there. But I don't in any way want to  
24 adopt their criteria of 13.5%.

25 **MS. JAYE:** I do not --

1           **CHAIRMAN GARCIA:** And I want to make sure  
2 that we didn't say that in --

3           **MS. JAYE:** I understand the concern,  
4 Mr. Chairman. However, I do not believe that that is  
5 necessary to actually reach the adoption of that  
6 reserve margin criteria in answering the statutory  
7 elements that are needed to be answered in this  
8 docket. And I believe even with taking that out,  
9 Staff's analysis would not change.

10           **CHAIRMAN GARCIA:** Would the motion mind if  
11 we took that discussion out?

12           **COMMISSIONER DEASON:** I have no objection to  
13 that. I guess there is a point of clarification,  
14 though; and it may be a fine distinction, but I think  
15 that we need to clarify.

16           I understood Staff's recommendation to be  
17 that in future fuel adjustment proceedings, if there  
18 is a curtailment of natural gas supply to this unit  
19 and there has to be replacement power that's at an  
20 incremental cost, that there has to be some  
21 justification shown at that time, not just  
22 justification that in the future they may need to add  
23 a backup supply of fuel.

24           And I understand Commissioner Clark's  
25 comments to be that, well, there wouldn't be a review

1 on the existing costs; there would just be a  
2 forward-looking review if there needs to be --

3 **COMMISSIONER CLARK:** No. At that time we  
4 would again review whether it was prudent for them not  
5 to have had that available.

6 **COMMISSIONER DEASON:** Right. Okay. Very  
7 well.

8 **CHAIRMAN GARCIA:** We have a motion and a  
9 second. All those in favor, signify by saying aye.

10 (Simultaneous votes.)

11 **CHAIRMAN GARCIA:** Aye.

12 **COMMISSIONER CLARK:** Aye.

13 **COMMISSIONER JACOBS:** Aye.

14 **COMMISSIONER DEASON:** Aye.

15 **COMMISSIONER JOHNSON:** Aye.

16 **CHAIRMAN GARCIA:** Thank you very much.

17 **MS. JAYE:** I'm sorry Mr. Chairman. We need  
18 to close the docket. That's the last issue.

19 **UNIDENTIFIED SPEAKER:** So moved.

20 **COMMISSIONER JACOBS:** Second.

21 **CHAIRMAN GARCIA:** There being no objection,  
22 the docket is closed.

23 (Thereupon, the hearing concluded  
24 at 3:45 p.m.)

25

- - - - -

1 STATE OF FLORIDA)  
 2 : CERTIFICATE OF REPORTERS  
 3 COUNTY OF LEON )

4 We, JOY KELLY, CSR, RPR, H. RUTHE POTAMI,  
 5 CSR, RPR, and KIMBERLY K. BERENS, CSR, RPR, FPSC  
 6 Commission Reporters;

7 DO HEREBY CERTIFY that the Hearing in Docket  
 8 No. 990325-EI was heard by the Florida Public Service  
 9 Commission at the time and place herein stated; it is  
 10 further

11 CERTIFIED that we stenographically reported  
 12 the said proceedings; that the same has been  
 13 transcribed by us; and that this transcript,  
 14 consisting of 242 pages, constitutes a true  
 15 transcription of our notes of said proceedings and the  
 16 insertion of the prescribed prefiled testimony of the  
 17 witnesses.

18 DATED this 10th day of June, 1999.

13

14

15

16

17

18

19

20


21


22


23

24

25

  
 JOY KELLY, CSR, RPR  
 Chief Bureau of Reporting  
 (850) 413-6732

  
 H. RUTHE POTAMI, CSR, RPR  
 FPSC Commission Reporter

  
 KIMBERLY K. BERENS, CSR, RPR  
 FPSC Commission Reporter

		8760-hour 142/14
\$	21st 193/12 225 126/20 23 135/17 230 202/15 24 134/13, 135/17 242 243/9 243 125/10, 126/22 244 231/5 25 134/16, 134/19 25-22.082 236/22 274 189/11 297 142/15 297.84 143/1 298 143/8	9
\$1 185/9 \$109 208/7 \$121 206/6, 230/18, 238/22 \$197 236/13 \$200 170/19 \$274 170/18, 230/10 \$325 208/4 \$325.56 208/2 \$343 236/13 \$435 208/10 \$496 170/19 \$500 194/17 \$9.2 183/14 \$90 173/7, 192/14, 192/17		9 126/15, 126/17, 153/22, 153/25, 172/2, 172/23, 181/15, 207/2, 207/4, 207/5 9.4 220/5 90 173/10, 173/14, 224/4 91 173/17, 205/12 92 174/13 93 174/14, 205/13 95 224/4 990325-EI 125/4, 243/5
&		A
& 127/19, 129/24, 145/25, 171/23	3	a.m 125/17 abandon 148/4 abnormal 144/1 absolute 175/4 accept 142/20 access 206/19 accompanied 210/6 account 173/8, 174/10, 175/20, 175/21, 177/22, 179/21, 180/7, 185/22, 227/2, 227/8, 228/3, 228/19, 230/4, 237/20 Accumulated 127/19, 130/20, 171/24, 173/23, 188/12, 189/22, 197/19 accumulation 188/11 accurately 180/23 accustomed 230/13 achieve 148/5, 228/24 acted 231/11 adapt 200/8 add 149/8, 186/17, 198/12, 201/10, 228/5, 231/9, 235/4, 241/22 added 178/13, 179/10, 183/15, 185/25 adding 148/25, 178/20, 179/8, 189/9, 235/7 additions 176/21, 178/16, 179/12, 202/18, 233/12 address 152/7, 210/24, 211/1 adequate 220/25, 227/13, 228/19, 229/7, 234/20, 234/22 adjusted 138/7 adjustment 136/25, 137/2, 234/6, 241/17 adjustments 137/14, 237/20 Administrative 236/22 admitted 151/8, 151/15, 151/18, 207/4, 209/20, 225/14, 227/4 ADMTD 126/12 adopt 240/24 adoption 239/14, 241/5 advanced 236/10 affected 233/24 affirmative 227/5 afternoon 170/4, 220/14 agree 142/15, 142/18, 239/21, 240/14 agreeing 240/16 agreement 127/23, 136/6, 136/8, 150/20, 210/5, 210/8 air 135/6, 135/7, 135/14, 149/1, 204/4 Alabama 131/7, 137/10, 177/17, 179/14, 192/18 algorithm 197/11 alternative 130/7, 133/4, 133/7, 135/9, 148/9, 148/10, 170/14, 170/18, 170/21, 171/10, 186/1, 186/3, 186/19, 187/17, 187/21, 196/12, 200/1, 200/14, 201/7, 201/19, 201/20, 201/23, 202/3, 206/6, 208/18, 221/11, 229/12, 229/18, 230/11, 230/19, 230/23, 236/18, 238/17, 238/23, 239/1 alternatives 128/2, 130/22, 131/1, 136/16, 175/25, 182/20, 182/22, 185/2, 197/14, 199/16, 199/22, 202/1, 203/4, 203/5, 203/21, 221/5, 229/9, 229/20, 230/4, 236/24, 238/7 amount 227/22 analyses 128/4, 142/17, 236/25, 237/24 analysis 134/1, 137/20, 138/3, 141/6, 143/10, 172/19, 173/19, 174/12, 175/2, 176/2, 176/3, 180/22, 181/10, 184/1, 184/13, 185/9, 185/23, 187/10, 187/11, 197/1, 197/21, 202/9, 205/23, 206/4, 208/7, 221/7, 221/16, 224/19, 230/15, 230/19, 231/15, 234/2, 234/7, 237/3, 237/8, 238/24, 241/9 analytical 170/12 analytically 170/9 annual 130/5, 131/9 answer 132/18, 132/25, 133/14, 133/16, 133/22, 134/3, 134/12, 139/4, 139/6, 144/16, 145/24, 147/4, 147/10, 184/11, 196/2, 206/11, 207/17, 227/10, 229/13, 230/22 answered 150/19, 222/22, 231/15, 232/10, 241/7 answering 146/7, 241/6 answers 147/16, 153/2, 170/24, 211/13 apologize 139/10, 141/18 Appalachia 204/17 APPEARANCES 125/25
,		
'98 193/10	4	
1	4 173/18 400 182/17 400-and-some-odd 179/17 403.519 133/2, 226/25, 233/2, 234/23, 236/19 4075 125/20 427 228/23, 231/10, 231/22, 236/7, 239/7 43 134/18 486 181/21, 182/16 496 230/10	
1 126/20, 127/2, 127/15, 148/24, 149/4, 150/2, 150/3, 150/4, 154/18, 171/22, 184/19, 202/23, 202/24, 220/4, 220/6, 225/10, 225/15 1.19% 236/5 1.4% 235/8 10 126/16, 126/17, 154/11, 154/14, 199/25, 207/2, 207/4, 207/5 100 173/9, 224/2 100% 224/4 102 202/15 10:35 125/17 10th 243/11 11 126/19, 195/6, 209/20, 209/22, 209/23, 209/25, 210/1 117 205/15, 205/22, 230/17 118 205/15, 206/1 11th 202/17 12 135/20, 152/15 12.6% 140/9 125 125/10 127 126/4 13 136/11, 136/17, 139/3, 139/9, 202/21, 240/21 13-some 240/17 13.5% 140/1, 140/8, 140/9, 235/1, 235/10, 240/24 139 126/5 14 136/11 14.1% 140/14 15 203/14, 205/2, 207/8, 240/21 15% 140/1, 140/13, 140/17, 235/17 152 125/19, 126/6, 126/13, 126/14 154 126/15, 126/16 155 126/7 16 136/13, 139/5, 204/7 1600 152/9 17 134/17, 134/20, 136/13 17.6% 235/10 171 126/7 18 203/16, 204/7, 205/1, 230/17 18th 152/9 19 134/13, 140/19, 140/24, 204/8, 204/9 192 202/5 1997 231/6 1999 125/16, 243/11	5	
198 193/10		
1	5 126/13, 151/6, 151/8, 151/9 500 193/21, 208/3 540 182/17, 205/22 540-megawatt 202/10 540-megawatt-slice 183/25 5700 235/13 574 174/7, 183/24, 231/23, 236/12 574-megawatt 170/13, 202/10, 202/12, 205/23	
1		
1	6	
1	6 126/13, 139/22, 151/6, 151/8, 151/9 6.3% 227/12 600 179/3, 180/4, 181/6, 182/18, 182/20, 184/1, 184/15, 185/8, 186/20, 186/23, 196/10 600-megawatt 187/12, 187/13, 187/14, 187/16, 187/17, 196/6, 199/11, 200/12 600-megawatt-block 179/23	
1		
1	7	
1	7 125/16, 126/14, 134/14, 135/21, 139/4, 147/18, 151/12, 151/18, 151/19, 178/5, 178/11, 198/17, 202/4, 203/13, 205/2, 205/16, 209/18, 230/17 700 179/3 75% 220/18	
1		
1	8	
1	8 126/14, 135/22, 151/12, 151/14, 151/18, 151/19, 154/16, 176/13, 205/13, 210/11, 210/13 80-megawatt 178/23	

Appendix 154/16, 220/5  
 apples 209/1  
 applicable 134/25  
 application 148/15  
 applied 237/25  
 appropriate 170/6, 172/5, 197/13, 225/12, 230/5, 240/4  
 appropriately 174/11  
 approval 221/19, 232/7  
 approve 226/23  
 approved 236/15  
 approving 232/18  
 area 135/6, 137/14, 138/8, 138/9, 228/12  
 arena 231/12  
 argument 225/25, 226/16  
 arranged 227/17  
 arrangements 205/9  
 aspect 143/23, 143/25  
 aspects 150/21, 189/16, 232/14  
 assessed 132/12  
 assessment 183/7  
 associated 131/5, 133/20, 147/22, 171/2, 172/20, 173/2, 173/25, 187/5, 189/25, 196/21, 197/25, 198/7, 234/4, 234/8, 238/2  
 assumption 137/9, 141/23, 145/7  
 assumptions 138/3, 148/7, 237/23, 237/24  
 Atmore 138/8, 138/9, 192/18  
 attached 153/11, 154/3, 154/7, 181/25, 182/5, 189/2, 220/2  
 attachment 139/22, 189/24, 192/1, 207/20, 208/17  
 attributed 194/1  
 August 193/10, 193/12  
 available 133/4, 133/7, 171/12, 178/25, 221/5, 222/24, 225/1, 229/12, 229/16, 231/1, 236/19, 238/5, 238/13, 238/17, 239/1, 239/3, 242/5  
 average 143/4, 143/5, 236/3  
 avoid 231/11, 233/20  
 aye 242/9, 242/11, 242/12, 242/13, 242/14, 242/15

**B**

backup 141/2, 147/19, 147/22, 148/1, 150/9, 203/20, 203/22, 204/1, 204/5, 204/6, 205/3, 205/8, 222/3, 222/9, 222/20, 223/2, 223/6, 223/17, 227/20, 228/4, 233/17, 233/21, 234/3, 240/2, 240/4, 240/10, 241/23  
 bad 240/20  
 balance 179/5, 201/11  
 balances 228/13  
 base 131/15, 132/15, 132/21, 132/22, 133/18, 176/14, 176/16, 177/6, 177/8, 177/25, 178/2, 180/5, 184/2, 186/21, 187/10, 187/11, 195/24, 196/1, 196/9, 196/18, 197/20, 200/12  
 base-load 204/2  
 based 142/14, 142/17, 206/4, 236/5, 238/19, 239/9  
 basis 134/2, 136/19, 137/5, 137/11, 138/10, 140/2, 140/13, 148/22, 148/23, 170/19, 171/8, 172/12, 172/14, 172/15, 174/19, 174/25, 175/17, 177/7, 182/18, 197/2, 197/8, 200/17, 203/9, 205/15, 207/24, 208/16, 223/23, 224/7, 224/22, 230/9, 237/2, 238/21  
 Bay 125/7, 138/7, 204/18  
 bear 180/7  
 bearing 194/21  
 bench 225/18, 225/23, 226/2  
 benefit 131/4, 131/10, 131/16, 131/18, 131/25, 132/10, 132/12, 145/22, 146/3, 146/21, 149/5, 150/7, 180/1, 187/13, 208/8, 208/11, 234/2  
 benefits 132/5, 146/10, 148/22, 171/10, 186/16, 186/19, 187/4, 208/17, 223/6  
 BERENS 125/22, 243/3  
 Betty 125/19  
 bid 181/19, 181/21, 187/16, 193/15, 194/16  
 bidders 181/17, 191/18, 230/1  
 bidding 190/16, 236/21  
 bids 193/22, 203/11  
 big 184/19, 189/15  
 Birmingham 152/9, 206/19  
 bit 141/4, 141/18, 182/13, 190/24  
 block 178/25, 179/18, 182/24, 196/6  
 blurted 188/17  
 boiler 141/20, 141/24, 144/13  
 book 177/1  
 borrow 142/22  
 bottom 188/11  
 break 200/5  
 brief 131/2, 170/3, 195/19, 207/12, 226/15  
 briefs 226/1  
 bring 201/10, 206/23  
 brings 171/10, 173/9, 180/1  
 brought 207/16  
 build 192/10, 221/14  
 building 228/12  
 built 191/1, 201/4  
 burden 180/7

BURKE 126/6, 151/23, 152/1, 152/8, 179/20, 180/14, 180/18, 180/21, 181/1, 181/9, 181/23, 182/2, 182/9, 182/19, 183/5, 183/10, 184/7, 184/10, 184/21, 184/24, 185/20, 186/8, 186/11, 187/11, 187/20, 188/1, 188/21, 189/4, 189/18, 190/13, 190/18, 191/2, 191/6, 191/15, 191/21, 191/24, 192/19, 192/23, 193/3, 193/8, 193/11, 193/23, 194/2, 194/6, 194/17, 194/23, 199/1, 199/6, 199/17, 199/24, 200/24, 202/9, 208/15, 209/2, 209/4  
 burning 221/9  
 business 210/24, 210/25  
 buy 221/14, 224/23  
 buying 224/8, 224/10, 224/12

**C**

calculate 140/14, 187/25  
 calculated 127/15, 173/6, 174/9, 187/4, 193/7  
 calculating 137/20, 196/5  
 calculation 191/13  
 calculational 174/5  
 calculator 142/23  
 call 149/23, 175/13, 176/21, 195/6, 195/8, 207/6, 207/19, 226/9  
 calls 151/23  
 came 183/4, 183/22, 193/22  
 capability 144/25, 145/13, 146/15, 147/6, 187/15, 203/20, 220/19, 234/18  
 capacity 137/19, 143/25, 147/3, 147/4, 171/8, 186/12, 196/6, 200/5, 200/10, 220/17, 231/22, 233/4, 233/6, 233/13, 233/20, 235/4, 235/18, 236/8, 236/9, 236/11, 236/23  
 capital 127/25, 133/11, 184/23, 184/24, 184/25, 196/14, 230/5, 236/12, 238/12  
 capture 180/1, 186/18  
 captured 143/9  
 care 145/12  
 careful 188/20  
 carries 130/23  
 carry 137/14, 143/25, 146/22  
 case 131/15, 132/15, 132/21, 132/22, 133/18, 144/20, 146/7, 176/6, 176/7, 176/14, 176/16, 176/19, 177/6, 177/7, 177/8, 177/25, 178/2, 179/2, 179/7, 179/22, 180/5, 180/6, 180/10, 184/2, 186/22, 187/10, 187/11, 187/16, 190/6, 195/24, 196/1, 196/9, 196/11, 196/18, 197/3, 197/4, 197/20, 200/12, 220/15, 227/4, 232/7, 232/8  
 cases 146/5, 180/5, 180/6, 229/24, 230/14  
 catalytic 135/8, 148/9  
 caused 191/23  
 CC 178/12, 179/6  
 CCs 179/1  
 Center 125/19  
 Central 177/17, 179/13, 179/14, 204/17  
 certainty 224/2  
 CERTIFICATE 126/22, 243/1  
 certification 143/10  
 CERTIFIED 243/7  
 CERTIFY 243/5  
 CHAIRMAN 125/13, 127/3, 129/1, 129/5, 204/21, 206/25, 207/3, 207/8, 207/10, 208/22, 209/11, 209/22, 209/24, 210/12, 211/18, 211/23, 221/23, 225/5, 225/9, 225/13, 225/16, 226/3, 226/5, 226/7, 226/12, 226/17, 231/25, 232/19, 239/13, 239/21, 240/15, 240/22, 241/1, 241/10, 242/8, 242/11, 242/16, 242/21  
 chance 178/10, 185/20, 223/7  
 change 139/8, 174/7, 176/7, 180/5, 182/23, 184/12, 187/16, 196/2, 196/4, 198/10, 198/12, 198/15, 201/7, 201/9, 201/12, 241/9  
 changes 153/17, 197/20, 201/14, 202/18, 211/9, 220/8  
 changing 201/3  
 Chapter 154/16  
 Chapters 220/4  
 characteristics 177/23  
 charge 200/7  
 cheaper 221/14  
 check 142/20, 188/14, 206/11  
 checking 188/10  
 choosing 138/13, 239/1  
 chose 182/24  
 chosen 135/9, 137/18  
 circumstances 146/1  
 City 190/12, 190/17, 190/19, 194/5, 228/12, 233/9, 233/13  
 clarification 139/5, 209/10, 232/16, 241/13  
 clarified 170/8  
 clarify 139/12, 202/6, 241/15  
 CLARK 125/14, 140/19, 143/2, 144/16, 144/22, 145/7, 145/11, 145/20, 146/13, 147/1, 147/9, 149/2, 149/7, 149/11, 149/15, 150/1, 150/4, 181/12, 181/17, 181/25, 182/4, 182/10, 182/12, 183/1, 183/6, 184/3, 184/8, 184/16, 184/22, 185/17, 186/6, 186/10, 187/24, 188/16, 188/23, 189/14, 190/9, 190/14, 190/23, 191/4, 191/12, 191/17, 191/22, 192/17, 192/21, 192/25, 193/6,

193/9, 193/13, 193/20, 193/24, 194/3, 194/7, 194/9, 194/11, 194/20, 195/1, 195/2, 195/4, 195/8, 195/12, 195/16, 206/13, 207/18, 208/13, 208/20, 208/23, 209/3, 209/6, 209/9, 222/7, 222/21, 223/2, 228/5, 239/16, 239/25, 240/13, 240/21, 242/3, 242/12  
 Clark's 206/12, 241/24  
 classification 210/7  
 clean 221/8, 221/9  
 clear 170/23, 221/8, 222/10, 229/14, 230/22  
 clearly 222/19, 231/13  
 clerk's 210/6  
 close 189/23, 208/14, 208/16, 242/18  
 closed 242/22  
 closing 225/25, 226/16, 226/23, 228/9  
 coal 146/19, 177/4, 204/14, 204/16, 204/17, 227/22, 233/25  
 Coast 204/19  
 Code 236/22  
 cogeneration 140/23  
 collected 170/8  
 column 127/18, 127/20, 127/22, 129/9, 129/11, 129/23, 130/3, 130/19, 130/24, 131/9, 131/12, 131/13, 132/22, 132/23, 171/23, 173/23, 173/24, 178/1, 186/6, 186/8, 186/11, 186/24, 187/1, 187/2, 187/6, 187/24, 188/1, 188/4, 188/7, 188/8, 188/13, 189/1, 189/10, 195/21, 195/23, 196/4, 197/19, 197/23, 198/22, 199/4, 200/9  
 columns 128/5, 128/11, 133/12, 133/17, 174/15, 178/11, 186/12, 186/21, 196/14, 196/18, 199/7  
 combination 143/6, 144/2, 144/6, 144/12, 145/18, 148/23  
 combined 148/6, 171/7, 177/3, 184/12, 186/15, 192/8, 197/4, 197/5, 201/4, 201/10, 221/9, 229/6, 236/10, 236/15  
 combustion 181/20  
 comfortable 226/4, 240/18  
 Commenced 125/17  
 comment 223/4  
 comments 241/25  
 COMMISSION 125/1, 125/22, 125/23, 145/12, 225/22, 232/21, 232/23, 236/16, 238/18, 239/11, 243/4, 243/6  
 Commission's 229/23, 232/7, 234/17, 236/21  
 COMMISSIONER 125/13, 125/14, 125/15, 129/8, 138/17, 138/19, 138/22, 140/19, 141/3, 141/5, 143/2, 144/16, 144/17, 144/22, 145/3, 145/7, 145/11, 145/20, 146/13, 147/1, 147/9, 149/2, 149/7, 149/11, 149/15, 150/1, 150/4, 151/2, 151/4, 151/5, 151/7, 151/10, 151/13, 151/17, 151/20, 153/5, 153/8, 153/23, 154/12, 171/14, 171/16, 176/4, 179/15, 180/11, 180/15, 180/19, 180/25, 181/5, 181/11, 181/12, 181/16, 181/17, 181/25, 182/4, 182/10, 182/12, 183/1, 183/6, 184/3, 184/8, 184/16, 184/22, 185/17, 185/19, 186/6, 186/10, 187/9, 187/18, 187/23, 187/24, 188/16, 188/23, 189/14, 190/9, 190/14, 190/23, 191/4, 191/12, 191/17, 191/22, 192/17, 192/21, 192/25, 193/6, 193/9, 193/13, 193/20, 193/24, 194/3, 194/7, 194/8, 194/11, 194/20, 195/1, 195/2, 195/4, 195/7, 195/8, 195/12, 195/16, 198/19, 198/22, 199/2, 199/15, 199/18, 200/22, 202/6, 206/11, 206/13, 207/14, 207/18, 208/13, 208/20, 208/23, 209/3, 209/6, 209/9, 222/6, 222/21, 223/2, 225/17, 225/20, 226/20, 228/5, 228/11, 234/11, 239/14, 239/16, 239/22, 239/25, 240/13, 240/21, 241/12, 241/24, 242/3, 242/6, 242/12, 242/13, 242/14, 242/15, 242/20  
 Commissioners 138/17, 170/4, 204/21, 207/16, 209/15, 220/14, 225/5, 226/7, 226/11, 226/22, 239/13  
 commodity 136/8, 136/18, 136/25, 137/2, 137/17, 137/19, 138/7, 138/10, 138/13, 144/14, 150/15  
 common 179/5  
 Company 125/5, 127/8, 128/8, 130/12, 130/15, 133/8, 133/20, 134/1, 137/13, 140/2, 145/4, 147/25, 152/3, 152/12, 170/15, 172/13, 176/25, 180/12, 196/21, 196/25, 197/2, 197/6, 197/7, 197/9, 201/23, 204/13, 210/19, 211/3, 224/22, 233/23, 235/11, 237/14, 238/4, 240/5  
 Company's 131/25, 132/15, 136/12, 179/11, 232/23, 234/25, 236/25  
 compare 130/2, 171/6  
 compared 128/1, 131/15, 170/9, 194/12, 230/10, 235/2  
 Comparing 129/22, 208/25  
 comparison 170/12, 170/16, 199/21, 205/14  
 complete 179/5, 221/20  
 completes 221/22  
 compliance 135/4, 135/7, 135/12, 135/15, 229/22  
 comply 134/25, 149/23  
 component 192/13  
 components 171/9, 175/5, 175/25, 185/22, 185/23, 191/7, 200/4, 200/6  
 Composite 127/13, 134/14, 135/21, 136/12, 153/21, 153/25, 173/11, 176/12, 198/16, 201/22, 202/4, 203/12, 210/11, 210/13  
 comprises 132/15, 176/15

computer 235/22  
concept 182/7  
concern 129/8, 241/3  
concerned 145/14, 145/16, 204/3  
concerns 147/21  
conclude 170/20, 228/3  
Concluded 125/18, 242/23  
concludes 170/22  
conditions 144/2  
conduct 225/25, 230/20  
conducted 229/21  
Conference 125/19, 226/9  
Confidential 127/13, 127/14, 127/23, 129/4, 133/11, 151/15, 171/20, 171/21, 173/11, 176/12, 185/11, 185/18, 185/24, 188/19, 188/25, 195/21, 196/15, 197/17, 198/20, 199/19, 201/17, 201/22, 202/12, 202/22, 205/13, 205/19, 210/7  
confidentiality 132/20  
confirm 206/20  
confusing 141/18  
connect 237/9  
connecting 237/4  
Connection 127/19, 129/24, 189/8, 197/18, 198/4  
conservation 230/25, 231/4, 231/10, 231/12, 235/25, 236/2, 239/3, 239/6, 239/8  
conservative 135/13, 173/7, 237/14  
Consistent 170/5, 237/2  
constant 201/6  
constitutes 243/9  
construction 138/9, 233/16, 238/3  
consult 195/17  
consumption 235/23  
contain 233/11  
contained 132/21, 135/4, 153/1, 172/23, 173/4, 173/20, 174/22, 178/1  
contains 173/17, 175/11, 182/5  
context 188/19  
continue 144/8  
Continued 126/4, 127/10, 240/10  
continues 127/2, 221/2, 240/6  
Continuing 130/18, 133/17, 227/14  
contract 137/18, 140/21, 140/24, 150/14, 228/2, 233/19, 234/12, 234/13, 237/11  
contracts 227/15  
contribute 232/25, 234/21  
contributes 228/14  
control 211/5, 211/21  
convenient 178/24, 179/9  
conversation 206/16  
copy 129/9  
correct 140/22, 142/13, 143/11, 143/12, 145/2, 145/4, 147/14, 147/23, 180/13, 180/17, 180/18, 183/5, 191/21, 198/2, 198/25, 199/1, 206/8, 206/21, 208/15, 211/19, 220/2, 220/3, 240/11, 240/12  
corrected 129/13  
correction 211/24  
corrections 153/17, 211/9, 220/8  
correctly 174/10, 188/15  
correspond 139/14, 139/17  
cost 127/24, 127/25, 128/10, 130/6, 130/15, 130/25, 131/5, 131/11, 132/21, 132/22, 133/12, 133/13, 133/18, 133/19, 134/25, 135/3, 135/4, 135/8, 135/9, 135/12, 135/15, 137/19, 147/24, 148/19, 170/17, 171/1, 171/5, 171/6, 171/8, 171/11, 171/24, 175/3, 175/19, 175/21, 175/22, 176/8, 176/9, 176/16, 176/17, 177/2, 177/3, 177/4, 177/21, 177/25, 178/2, 180/7, 180/9, 183/4, 183/11, 183/12, 183/13, 183/15, 183/16, 183/19, 183/22, 183/23, 183/25, 184/8, 184/14, 184/24, 185/2, 185/3, 185/4, 185/6, 186/1, 186/13, 186/15, 186/22, 187/2, 187/3, 187/6, 187/8, 187/22, 188/2, 188/6, 188/12, 189/23, 190/16, 190/19, 191/5, 191/7, 191/8, 191/9, 191/10, 192/3, 192/7, 192/10, 192/14, 192/24, 193/16, 194/15, 194/21, 195/22, 196/4, 196/5, 196/11, 196/14, 196/16, 196/19, 197/22, 198/9, 198/22, 198/23, 199/8, 199/9, 200/5, 200/10, 200/12, 201/5, 202/3, 224/9, 224/11, 224/17, 224/19, 224/23, 228/20, 229/8, 230/5, 233/15, 234/2, 234/8, 234/21, 234/23, 235/3, 235/4, 236/12, 236/14, 236/15, 237/4, 237/7, 237/9, 238/9, 238/11, 241/20  
cost-effective 133/4, 133/7, 133/25, 134/5, 134/10, 137/20, 170/14, 201/19, 201/20, 201/23, 206/7, 229/12, 230/23, 231/24, 236/18, 237/8, 238/5, 238/16, 239/1  
cost-effectiveness 127/16, 133/24, 172/6, 174/24, 196/24, 197/1, 221/16, 237/16, 237/18, 237/23, 238/7, 238/19  
costing 179/24, 183/17  
costly 237/15  
costs 128/4, 130/11, 135/12, 171/2, 173/25, 176/1, 176/19, 176/20, 177/4, 178/3, 179/25, 184/23, 185/25, 186/7, 189/4, 189/5, 189/6, 189/8, 189/10, 189/15, 189/24, 197/25, 198/3, 198/4, 198/7, 200/8, 230/5, 230/6, 230/7, 234/4, 238/2, 238/12, 238/14, 242/1  
County 125/7, 243/2

couple 221/25  
Court 209/10, 232/16  
cover 138/22, 142/3, 143/14, 143/16, 143/25, 144/11  
covered 143/22, 144/13, 190/22  
covers 186/2  
create 177/15, 185/9, 187/6, 189/20  
created 204/14  
creates 177/1  
Crist 233/6  
criteria 142/4, 143/24, 144/4, 145/17, 145/18, 240/24, 241/6  
criterion 235/1, 235/2, 235/10, 235/16, 236/6  
critical 150/23  
Cross 126/4, 126/7, 127/10, 171/13, 171/17, 225/2  
CSR 125/22, 125/23, 243/3, 243/14  
CT 177/2, 178/12, 178/22, 179/6, 184/11, 200/14, 200/16, 200/17, 201/8  
CTs 171/6, 179/1  
cumulative 238/20  
currently 140/22, 141/21, 150/6, 194/13, 233/9, 233/17  
curtailment 241/18  
customer's 144/11  
customers 170/15, 170/21, 220/22, 221/3, 221/12, 223/25, 224/3, 224/5, 224/13, 224/23, 224/25, 229/8  
customers' 235/3  
cycle 148/6, 177/3, 184/12, 186/15, 192/8, 197/4, 197/5, 201/4, 221/9, 229/6, 236/11, 236/15  
cycles 171/7, 201/10

D

Daniel 136/22, 137/6  
data 174/22, 177/1, 192/2  
DATE 125/16  
DATED 243/11  
day 195/15, 243/11  
deal 147/19, 186/12, 190/15, 193/25, 221/13  
deals 189/7  
DEASON 125/13, 138/17, 138/22, 151/2, 151/5, 151/7, 151/10, 151/13, 151/17, 151/20, 153/5, 153/8, 153/23, 154/12, 171/14, 171/16, 195/7, 198/19, 198/22, 199/2, 199/15, 199/18, 200/22, 207/14, 225/17, 225/20, 239/14, 239/22, 241/12, 242/6, 242/14  
Deason's 144/17  
decide 230/21  
deciding 222/3  
decision 222/8, 225/18, 225/24, 226/1, 226/2, 227/20  
decrease 184/6  
decreased 183/11  
deferred 231/2  
delay 148/16, 148/20, 150/9  
delays 148/11  
delivery 137/5, 137/7, 137/10, 137/11, 203/23  
delta 176/7, 185/3, 186/23  
demand 231/5, 231/7, 235/24, 239/5  
demand-side 236/2  
demonstrated 220/24, 227/7, 228/18, 229/11, 230/25, 236/17  
Department 152/14, 177/1  
depends 138/1, 145/23  
depo 126/19  
deposition 139/7, 173/18, 202/17, 209/16, 209/17  
describe 203/19  
described 230/3  
design 184/12, 229/6  
designed 143/24  
determination 226/24, 227/2, 239/24  
determine 125/5, 232/24, 238/6, 239/12  
determined 133/25, 196/25, 221/7, 223/16, 238/18  
detract 229/4  
developed 192/5  
Development 152/14  
dictate 148/8  
differ 177/10  
difference 129/24, 130/8, 130/9, 130/10, 132/3, 140/1, 141/11, 182/14, 184/19, 190/16, 197/24, 199/6, 224/16  
differences 130/1, 131/23, 136/14, 137/3, 137/4, 137/15, 203/3, 237/21  
differential 127/24, 130/4, 137/10, 198/9, 198/11, 198/15, 203/10  
differs 195/24, 238/8  
dip 227/12  
Direct 126/6, 126/7, 126/9, 152/5, 152/16, 152/22, 153/2, 153/6, 153/11, 154/8, 182/1, 192/7, 210/21, 211/6, 211/16, 211/20, 220/2  
direction 134/21, 135/24, 153/15, 202/25, 203/17, 204/10  
disadvantage 180/3  
disappointed 230/1  
discuss 131/22  
discussed 239/10

discusses 150/11  
Discussion 226/10, 241/11  
discussions 232/12  
dispatch 175/16, 175/18, 180/22, 187/15, 187/18, 197/5, 197/6, 197/7, 197/10, 197/11, 197/13, 200/25, 201/1, 224/7, 224/17, 224/21  
dispatched 175/16, 180/24, 181/3, 187/22, 197/8, 197/11, 200/23  
disruption 222/14  
distinction 222/11, 241/14  
diversity 145/8, 145/19, 146/14, 146/18, 147/12  
divide 185/7, 186/20, 199/10  
divided 175/15, 186/23  
divides 238/14  
divulge 199/19  
DOCKET 125/4, 152/15, 211/7, 234/17, 240/18, 241/8, 242/18, 242/22, 243/5  
document 202/16, 220/9, 231/16  
Documents 134/17, 134/20  
doesn't 173/8, 182/14, 222/25, 239/23  
dollar 131/9, 170/25, 171/1, 171/4, 174/19, 175/6, 205/15, 238/15, 238/20  
dollar-per-kilowatt 172/14, 230/9  
dollar-per-kW 176/3, 200/17  
dollars 131/9, 170/25, 172/6, 172/7, 172/19, 172/20, 172/22, 173/1, 173/4, 174/11, 175/1, 175/4, 179/25, 185/7, 186/20, 198/13, 199/8, 234/8, 238/8  
draw 146/4  
drivers 131/22  
dual 234/18  
during 139/6, 195/15

E

easily 146/20, 221/17  
Easley 125/19  
economic 142/17, 223/7, 223/20, 224/7, 224/22  
economics 143/8, 222/19, 223/16  
economy 178/24  
effect 132/11  
effects 142/7  
efficiency 221/10  
efficient 229/6  
efforts 136/2, 150/20  
eight 211/6  
electric 132/6, 132/12, 146/3, 146/8, 146/9, 146/23, 175/12, 178/17, 180/24, 181/4, 197/12, 227/9, 227/14, 228/15, 233/1  
electrical 125/6  
electricity 221/3, 228/20, 229/7, 234/20, 234/22  
element 144/5, 231/20, 238/10  
elements 241/7  
eliminate 235/5  
eliminated 192/15  
eliminating 192/21  
embedding 194/24  
emission 149/1  
emissions 135/7, 135/14, 148/5, 148/14, 148/15, 148/24, 149/5, 149/6, 149/22, 150/8, 176/17, 176/22  
employer 152/10  
energy 171/10, 180/1, 183/18, 183/19, 184/20, 185/9, 186/13, 186/16, 186/18, 186/24, 187/4, 187/13, 198/24, 199/5, 199/13, 199/20, 199/22, 200/16, 200/18, 201/15, 211/1, 224/11, 224/23, 235/23  
Engineering 176/25  
enhance 229/3  
enhancements 202/8  
ensure 221/12, 227/13, 240/5  
enter 208/25  
entered 210/5, 232/8  
entertain 225/23  
entitled 127/18, 130/19, 132/22, 133/18, 171/23, 178/1, 195/22, 196/18, 199/4  
entry 150/13  
environmental 135/1, 135/4, 135/6, 135/11, 147/20, 147/21, 148/3, 148/8, 148/13, 232/14  
environmentally 228/6, 228/7  
equal 140/16, 171/8, 172/12, 180/6, 180/9, 184/2  
equipment 191/10  
equivalent 142/11, 193/16  
Errata 126/19, 209/16, 209/19  
error 144/2, 236/3  
escalators 234/12  
Esplanade 125/20  
establish 220/16, 220/23  
establishes 227/1  
estimate 135/3, 135/13, 173/8, 174/23, 183/2, 194/13  
estimated 172/21, 173/2, 175/18  
estimation 149/19  
evaluate 142/7, 199/16, 222/19  
evaluated 170/17, 171/6, 171/11, 183/11, 183/12, 183/21, 191/8, 223/5, 223/23  
evaluating 172/9

evaluation 135/4, 170/10, 171/5, 185/12, 191/9, 191/15, 196/13, 197/14, 199/12, 230/3, 237/3, 237/9, 237/14, 237/16, 237/18, 237/25  
 evaluations 223/21  
 event 223/13  
 evidence 151/9, 151/19, 207/5, 210/2, 225/15, 227/4, 227/11, 227/16, 227/22, 228/11, 229/5, 229/21, 231/3  
 evidenced 222/14  
 Examination 126/4, 126/5, 126/6, 126/7, 126/9, 127/10, 139/1, 152/5, 171/17, 204/24, 210/21  
 exceed 142/4  
 Excuse 149/10, 150/22  
 excused 151/21, 208/21, 209/4, 225/7  
 Exhibit 127/13, 134/14, 135/21, 136/12, 139/4, 139/21, 139/22, 140/3, 142/9, 142/10, 147/18, 151/14, 151/15, 153/21, 153/25, 154/3, 154/11, 154/14, 154/18, 170/16, 171/25, 172/2, 172/23, 173/4, 173/11, 173/18, 173/20, 175/6, 176/12, 176/13, 178/5, 178/8, 181/14, 181/15, 181/24, 185/18, 188/25, 189/2, 194/9, 195/3, 195/5, 195/6, 195/14, 195/21, 196/15, 197/17, 198/16, 198/17, 198/20, 201/22, 202/4, 203/12, 204/17, 205/2, 205/13, 205/16, 205/19, 207/1, 207/19, 208/25, 209/8, 209/12, 209/18, 209/20, 209/22, 209/23, 209/25, 210/1, 210/11, 210/13, 220/6, 225/10, 225/15, 230/17  
 EXHIBITS 126/11, 151/5, 151/6, 151/8, 151/9, 151/12, 151/18, 151/19, 153/11, 153/18, 207/5, 209/13, 220/1  
 existing 176/18, 227/15, 231/4, 233/3, 239/6, 242/1  
 exists 195/10, 225/21, 233/9  
 expansion 132/16, 132/21, 176/19, 176/20, 177/25, 178/3, 180/2, 180/8, 182/21, 182/23, 182/24, 186/14, 186/24, 195/23, 196/1, 199/14, 201/3, 201/4, 201/6, 201/7, 201/9, 201/14  
 expect 143/14, 143/16, 143/21, 148/19, 200/17  
 expectation 142/1, 142/2  
 expected 135/5, 141/22, 149/19, 149/25, 189/25  
 expensive 148/10, 148/19, 189/21, 229/15  
 experience 141/15, 184/6  
 experienced 223/24  
 expire 227/15  
 expires 140/24  
 explanation 150/16  
 explore 234/18  
 explored 237/6  
 expressed 230/8  
 expressing 230/13  
 externally 175/22  
 extrapolation 182/17

**F**

face 220/22  
 facets 144/12  
 facilities 204/1, 204/3  
 facility 144/19, 144/23, 191/11, 192/11  
 fact 137/9, 142/10, 170/15, 190/5, 194/3, 201/19, 223/13, 224/21, 227/24, 228/1, 240/1  
 factor 188/3, 189/21, 228/17, 229/10, 230/24  
 factored 137/2  
 factors 227/1, 227/6, 230/5  
 factual 239/10  
 fair 205/2  
 fashion 228/9  
 favor 242/9  
 federal 135/1  
 figure 193/5, 193/16, 203/9  
 figures 139/13, 139/16, 139/18, 147/24  
 file 148/16, 149/21  
 filed 152/18, 210/4  
 filing 226/1  
 financial 237/22, 237/24  
 find 185/13, 199/24, 231/21  
 finding 181/23, 227/5  
 fine 195/12, 241/14  
 fingertips 193/5  
 finish 206/24  
 finished 226/19  
 firing 148/6, 149/4, 149/5  
 firm 150/13, 150/19, 203/23, 205/4, 205/8, 210/4, 227/17, 228/1, 233/20, 234/12  
 firmness 150/24  
 five 226/16, 236/4  
 fixed 175/21, 175/22, 176/20, 179/24, 185/2, 185/22, 185/25, 186/1, 186/7, 187/3, 198/23, 200/6, 200/7, 200/8, 201/15, 234/14  
 fleet 176/18  
 floor 194/15  
 FLORIDA 125/1, 125/20, 133/2, 140/12, 145/25, 191/3, 211/1, 222/12, 233/2, 234/23, 236/19, 236/22, 243/1, 243/5  
 Florida's 170/5  
 flow 144/8  
 fly 228/10

FOB 204/18  
 follow 138/23, 139/19, 151/3, 221/25  
 follows 127/9, 152/4, 210/20  
 forced 141/14, 141/19, 141/22, 141/23, 142/11, 142/16, 143/14, 143/16, 144/1, 146/24, 175/20  
 forces 141/24  
 forecast 144/2, 203/10, 204/14, 228/22, 235/21, 235/23, 235/24, 236/1, 236/3, 236/4, 236/5, 237/20, 239/5  
 forecasted 235/7, 235/9  
 forecasting 220/24  
 forecasts 136/15, 203/3, 203/8, 237/17  
 forgot 209/18  
 form 194/9, 194/10  
 formal 210/8  
 format 175/24  
 forward-looking 242/2  
 found 172/12, 172/19, 178/9, 205/24, 238/4  
 four 227/1, 227/5, 237/12, 237/15  
 fourth 127/20, 127/21, 230/24  
 FPSC 125/22, 125/23, 243/3  
 frame 138/13, 229/14  
 free 194/24  
 Friday 210/5, 237/12  
 front 209/16  
 fuel 133/21, 141/3, 144/18, 144/25, 145/8, 145/12, 145/19, 146/14, 146/18, 146/19, 146/22, 147/5, 147/6, 147/11, 147/20, 147/22, 148/1, 149/13, 150/11, 150/24, 176/16, 176/22, 177/20, 190/5, 192/16, 196/22, 201/5, 203/7, 203/8, 203/10, 203/20, 203/22, 203/23, 204/1, 204/4, 205/3, 205/7, 221/9, 222/3, 222/9, 222/20, 222/24, 223/2, 223/6, 223/17, 223/21, 223/24, 224/19, 224/25, 227/20, 228/4, 230/6, 233/18, 233/21, 234/3, 234/5, 234/6, 234/9, 234/18, 237/17, 238/13, 240/1, 240/2, 240/4, 240/10, 241/17, 241/23  
 function 188/6, 198/23  
 future 234/4, 234/8, 234/18, 241/17, 241/22

**G**

Gainesville 145/25  
 GARCIA 125/13, 127/3, 129/1, 129/5, 204/21, 206/25, 207/3, 207/8, 207/10, 208/22, 209/11, 209/22, 209/24, 210/12, 211/18, 211/23, 221/23, 225/5, 225/10, 225/13, 225/16, 226/3, 226/5, 226/7, 226/12, 226/17, 231/25, 232/19, 239/13, 239/21, 240/15, 240/22, 241/1, 241/10, 242/8, 242/11, 242/16, 242/21  
 gas 136/3, 136/15, 137/8, 137/17, 138/2, 138/6, 138/13, 141/8, 141/13, 141/21, 142/5, 142/8, 143/6, 143/14, 144/14, 147/7, 149/9, 149/16, 149/17, 150/6, 150/13, 150/19, 150/22, 191/11, 192/10, 192/14, 194/1, 194/4, 194/21, 203/3, 204/14, 204/18, 205/4, 205/8, 205/9, 221/8, 223/8, 227/17, 227/25, 228/2, 233/19, 233/20, 233/21, 233/25, 234/5, 237/10, 237/11, 237/13, 238/3, 240/8, 241/18  
 gas-fired 147/2  
 generate 224/11  
 generates 224/15  
 generating 144/9, 221/19, 222/11, 222/12, 222/16, 222/18, 233/3  
 generation 130/23, 132/16, 141/7, 142/3, 143/23, 144/10, 145/17, 152/13, 171/23, 178/18, 178/19, 178/25, 186/14, 187/8, 188/6, 188/12, 189/5, 189/10, 207/23, 208/2, 220/21, 221/11, 228/13, 233/8  
 generation-only 208/6, 208/9, 208/16  
 generator 131/3, 132/2  
 generators 132/8  
 generic 132/21, 176/21, 176/23, 176/24, 177/2, 177/3, 177/5, 177/7, 177/10, 177/14, 177/15, 177/17, 177/25, 178/12, 179/12, 192/2, 192/6, 196/6, 199/23, 200/18  
 generically 177/14, 179/2, 199/20  
 Georgia 179/14  
 Georgia-type 177/17  
 Glad 178/9, 185/12  
 Grace 129/1  
 grant 221/18, 232/23, 239/11  
 greater 235/18  
 Grid 127/19, 129/24, 189/7, 197/18, 198/3  
 group 178/19  
 grow 179/3, 221/2  
 growing 221/3, 221/6  
 guarantee 233/19  
 guaranteed 203/23  
 guess 129/15, 141/3, 174/3, 174/5, 178/24, 182/15, 184/3, 188/4, 199/25, 200/3, 241/13  
 Gulf 125/5, 127/7, 127/15, 133/6, 133/8, 133/9, 133/24, 134/6, 134/11, 134/18, 134/24, 135/23, 136/2, 136/12, 140/4, 140/9, 140/14, 143/13, 151/6, 151/23, 152/2, 170/5, 170/15, 170/21, 179/16, 190/6, 192/3, 192/16, 192/23, 196/24, 203/15, 204/19, 207/6, 210/18, 211/2, 220/17, 221/4, 222/2, 222/10, 222/15, 224/10, 227/7, 227/16, 228/17, 228/21, 228/23, 229/10, 229/15, 229/19, 230/25, 231/3, 231/9, 231/11, 231/14, 231/21,

232/10, 232/23, 233/18, 234/1, 234/3, 234/25, 235/22, 235/23, 236/6, 236/17, 236/22, 237/6, 237/11, 237/12, 237/18, 237/19, 237/23, 237/25, 238/5, 238/25, 239/4, 239/11  
 Gulf's 134/15, 135/16, 135/22, 171/21, 178/6, 179/22, 180/16, 202/23, 204/8, 223/25, 224/3, 224/5, 224/13, 227/11, 227/14, 227/19, 228/13, 229/8, 230/2, 232/25, 233/3, 233/6, 233/10, 233/22, 234/21, 235/6, 235/17, 235/21, 236/3, 236/5, 236/9, 236/10, 237/1, 237/5, 238/24, 239/5, 239/7  
 guys 175/23, 186/5

**H**

Haff 232/20  
 hand 150/20, 209/19  
 hands-on 206/19  
 hard 128/20, 178/20, 189/19  
 hard-pressed 224/24  
 head 209/2  
 help 179/7, 179/15, 181/13, 182/9, 187/9, 204/11  
 hesitant 174/3  
 high 135/17, 221/10, 228/22  
 higher 135/9, 149/4, 189/17, 200/25, 229/2, 229/3  
 hold 138/19, 201/6  
 honestly 229/22  
 hop 141/4  
 hour-by-hour 148/5  
 hours 142/15, 143/1, 143/8, 149/24, 224/15  
 housekeeping 209/14  
 HOWELL 126/8, 210/17, 210/25, 211/19, 223/1, 223/3, 225/7

**I**

ID 126/12  
 identification 139/7, 154/1, 154/14, 210/1, 229/19  
 identified 134/14, 134/25, 135/16, 135/21, 139/21, 142/10, 153/12, 153/21, 153/24, 154/11, 154/13, 154/17, 172/2, 176/13, 220/6, 229/17, 236/6  
 imagined 177/18  
 imbalance 233/8  
 impacts 130/23, 131/8, 133/21, 196/22  
 import 235/12  
 improvements 128/1, 150/2  
 inaudible 209/8, 209/9, 232/15  
 incorporated 234/25, 236/1, 237/6  
 incorporates 239/5  
 Incorporating 238/2  
 increase 152/22, 184/4, 184/5  
 increased 231/8  
 incremental 130/8, 130/9, 133/12, 196/16, 197/24, 241/20  
 incurred 131/21  
 index 203/7  
 indexed 203/11  
 indicate 130/13, 131/14, 181/18, 190/25, 197/23  
 indicated 137/16, 190/10, 190/11, 191/18  
 indication 222/23  
 informal 232/11  
 information 129/4, 133/11, 136/1, 171/20, 177/19, 177/20, 192/3, 192/5, 192/7, 192/9, 193/3, 195/15, 199/19, 202/22, 203/13, 205/18, 205/21, 231/18  
 initial 137/23, 138/4, 138/5, 138/6, 138/8, 229/19  
 injection 182/12  
 Inserted 126/7, 126/9, 153/6, 153/9, 211/16  
 insertion 243/10  
 install 192/8  
 installation 140/5  
 installed 170/25, 171/5, 171/8, 236/12, 236/13, 238/9  
 installing 234/3  
 integrity 227/9, 228/14, 233/1  
 intent 210/6  
 inter-ties 227/23  
 interconnected 146/14, 147/13  
 interconnection 222/24, 238/3  
 interconnections 146/11, 146/17, 235/14, 237/7  
 interplay 179/18  
 Interrogatories 134/15, 134/19, 134/23, 135/17, 136/13, 147/17, 190/21, 204/8, 204/9, 231/16, 232/11  
 Interrogatory 127/15, 135/22, 135/23, 139/4, 139/6, 139/10, 139/12, 139/15, 150/11, 150/16, 171/21, 178/6, 196/3, 202/24, 203/15, 205/1  
 interrupted 233/22  
 interruptible 146/20  
 interruption 141/8, 141/13, 142/5, 143/15, 144/14, 144/15, 147/7, 234/5, 240/8  
 interruptions 142/8, 143/7, 234/9  
 intervenors 229/25  
 investigated 234/9  
 issue 147/20, 223/7, 242/18  
 issued 170/6, 221/13, 229/20, 236/23

issues 239/10 items 201/17	marginal 224/9 margins 143/24 MARIA 126/6, 151/23, 152/1, 152/8 mark 209/20 marked 153/25, 154/14, 210/1 market 221/13 Marler 126/19 match 180/20 material 185/24, 202/12 math 142/18, 142/21 Matter 125/4, 209/14, 230/21 maximum 149/20, 149/23, 152/23, 220/18 measures 231/1, 239/3, 239/7 meet 221/6, 229/7, 231/24, 236/9 megawatt 179/17, 180/6, 183/9, 184/2, 224/15 megawatts 140/24, 173/9, 174/8, 179/3, 180/4, 180/10, 181/19, 181/21, 182/13, 182/20, 183/3, 184/1, 184/15, 185/8, 186/21, 186/23, 196/10, 199/11, 205/22, 228/23, 231/5, 231/8, 231/10, 231/22, 231/23, 235/13, 236/7, 236/12, 239/7 memory 208/6 mention 128/20 mentioned 125/25 met 220/15 method 183/17, 197/13, 206/4 methodologies 179/24 methodology 199/16, 230/21 methods 183/23 Michael 232/20 million 173/7, 183/14, 192/14, 192/17, 206/6, 230/18, 236/13, 238/22 mind 241/10 minimize 233/14 minus 140/19 minute 139/3, 141/2, 195/18 minutes 206/24, 207/8, 226/16 miscalculation 205/25 mismatch 233/8 mistake 174/5 misunderstanding 129/15 misunderstood 149/7, 149/11 mitigate 239/4 mix 179/6, 200/19, 201/11 mixed 139/11 MJB-1 126/15, 153/12, 153/21 MJB-2 126/15, 153/12, 172/1, 172/23, 173/5 MJB-3 126/16, 154/3, 154/10, 170/16, 189/2, 189/12, 193/17, 207/19, 207/25 Mobile 131/7, 138/7, 204/18 mode 224/10, 224/14 model 175/7, 175/10, 175/11, 177/5, 179/4, 187/22, 203/8 modeled 142/16 modeling 148/14 models 221/1, 235/23 moment 180/12 Monday 125/16 month 175/14 morning 148/16, 150/13 motion 240/14, 241/10, 242/8 mouth 204/18 move 151/12, 207/1, 210/10, 225/10, 239/14 moved 242/19 moves 151/6 Mr. Chairman 127/5, 153/20, 154/10, 211/15, 241/4, 242/17 MR. HAFF 232/20, 234/16, 240/12 Mr. Howell 134/12, 206/13, 206/24, 207/7, 210/14, 210/23, 220/11, 221/24, 222/21, 223/19, 225/1 Mr. Howell's 211/16 Mr. Marler 209/17 Mr. Melson 126/5, 126/6, 126/9, 129/8, 129/15, 139/2, 141/1, 143/3, 143/5, 147/15, 150/10, 151/1, 151/6, 151/23, 152/6, 153/5, 153/10, 153/20, 154/2, 154/10, 154/15, 170/1, 171/12, 173/12, 173/15, 182/4, 182/11, 184/17, 188/17, 195/8, 195/13, 195/17, 204/23, 204/25, 206/9, 206/15, 207/1, 207/6, 207/9, 207/16, 207/22, 208/21, 209/14, 210/3, 210/14, 210/22, 211/15, 220/1, 221/24, 223/18, 225/1, 225/9, 226/15, 226/22, 228/7, 232/1 Mr. Moore's 142/9 Mr. Pope 127/12, 128/3, 132/14, 133/1, 137/16, 138/12, 139/3, 147/9, 147/15, 150/10, 151/20, 175/1, 190/21, 206/15 Mr. Pope's 173/18 MR. STONE 234/14 Ms. Burke 129/7, 130/16, 132/17, 132/24, 133/14, 133/22, 134/3, 138/2, 139/7, 152/7, 153/10, 154/15, 171/12, 171/19, 173/22, 188/17, 195/20, 201/16, 204/25, 206/17, 206/23, 207/17, 207/22, 208/21, 223/20, 230/3 Ms. Jaye 126/4, 126/7, 127/5, 127/11, 129/3, 129/13, 129/19, 138/16, 151/11, 151/16, 171/18, 173/14,	173/16, 181/16, 185/15, 185/19, 193/19, 194/8, 195/2, 195/5, 195/20, 198/21, 201/16, 202/14, 204/20, 209/6, 209/23, 210/10, 225/4, 226/5, 240/25, 241/3, 242/17 Ms. Kamaras 171/14, 171/15, 225/3, 232/4, 232/6, 232/17 Mulat 136/23, 137/8, 137/12 multiple 146/11, 170/9, 188/3 multiplying 172/21, 173/3
J		N
JACOBS 125/15, 138/19, 141/3, 141/5, 145/3, 151/2, 151/4, 176/4, 179/15, 180/11, 180/15, 180/19, 180/25, 181/5, 181/11, 187/9, 187/18, 187/23, 202/6, 226/20, 234/11, 242/13, 242/20 JEFFERS 126/6, 152/1, 152/8 Job 152/11, 231/14 JOE 125/13 JOHNSON 125/14, 242/15 Journals 170/8 JOY 243/3, 243/14 JULIA 125/14 June 125/16, 243/11 justification 241/21, 241/22 justifying 133/6		NAME 126/3, 152/7, 152/8, 210/23, 210/25 natural 136/3, 136/15, 137/8, 137/17, 138/13, 141/20, 142/5, 144/14, 147/7, 149/9, 149/15, 149/17, 150/6, 150/19, 150/22, 203/3, 204/14, 227/25, 233/19, 233/20, 233/21, 233/25, 234/5, 237/10, 240/8, 241/18 necessary 146/16, 221/20, 241/5 necessity 209/7 need 125/6, 138/23, 139/17, 143/10, 147/11, 147/18, 154/17, 180/16, 188/19, 191/24, 191/25, 220/5, 220/16, 220/18, 220/23, 221/2, 225/10, 225/25, 226/24, 227/8, 227/9, 228/4, 228/18, 228/19, 229/3, 230/14, 231/11, 231/22, 231/24, 232/7, 232/9, 232/24, 233/20, 234/20, 235/18, 235/20, 236/7, 236/9, 239/4, 239/7, 239/12, 239/20, 239/24, 241/15, 241/22, 242/17 needed 147/5, 193/4, 231/7, 231/13, 241/7 needs 133/14, 133/15, 133/22, 134/3, 134/12, 144/12, 178/21, 228/23, 229/7, 242/2 negative 131/14, 131/17, 131/21, 220/20, 227/12 negotiated 140/23 net 149/1, 150/7, 170/17, 171/1, 171/5, 171/9, 171/11, 183/15, 183/21, 184/20, 187/6, 187/8, 187/25, 188/5, 188/6, 188/21, 189/22, 191/5, 191/8, 191/14, 193/1, 193/4, 193/15, 194/14, 208/1, 230/9, 235/24, 239/8 netted 198/24 network 238/10 new 133/13, 196/16, 233/15 nine 235/13 Nodding 209/2 nonconfidential 198/17, 203/13, 205/17 nonfirm 235/12 normally 143/19 North 152/9 Nos 207/2 note 147/25 notes 243/9 notice 210/6, 225/22, 225/24 NOX 135/10, 148/4, 148/22, 148/24, 149/1, 149/6, 150/7 NPV 172/6 nuclear-fired 233/25 NUMBER 126/12, 128/14, 128/21, 128/23, 142/12, 171/22, 171/24, 173/12, 178/12, 183/3, 188/13, 188/18, 189/1, 195/3, 195/9, 195/25, 197/20, 198/14, 199/11, 199/14, 206/21, 207/18, 207/23, 208/5, 208/9, 208/11, 208/24, 221/3, 222/18, 230/8, 232/9, 233/14 numbers 129/9, 129/10, 129/25, 130/1, 130/3, 131/13, 171/4, 174/6, 174/14, 174/15, 175/2, 178/11, 182/7, 188/10, 188/11, 188/20, 198/5, 198/24, 199/13, 200/20, 201/2, 201/12, 202/11, 205/25, 206/2, 206/20, 207/20, 208/17 numerically 197/5
K		O
KELLY 243/3, 243/14 kilowatt 172/6, 172/22, 173/4, 208/2, 208/8 kilowatt-hours 131/6 KIMBERLY 125/22, 243/3 knowledge 138/12 known 135/5 kV 194/17 kW 170/18, 170/19, 170/25, 171/1, 171/4, 172/18, 179/25, 185/9, 198/13, 208/10, 230/10, 230/11, 236/13, 238/8, 238/15		O&M 133/11, 137/4, 176/17, 176/22, 196/14, 200/6, 230/5 objection 151/7, 151/17, 153/8, 207/3, 225/13, 232/6, 232/18, 241/12, 242/21 obviate 209/7 occurrence 142/5 offered 198/18, 202/5 offers 238/22 office 210/6 offset 148/4, 148/22, 150/1 offsets 135/10, 149/4 oil 148/1, 148/6, 149/4, 149/5, 149/19, 150/9, 203/22, 204/1, 204/4, 204/15, 204/19, 205/3, 205/7 open 201/17, 234/17 operate 224/6 operated 141/7, 141/12 operating 177/4 operation 227/18 operations 238/12 opinion 134/4, 134/9, 142/4, 150/24, 172/4, 201/18 opposed 222/15 optimize 201/5 option 172/22, 173/3, 237/1, 237/4 options 136/22, 137/25, 174/17, 221/6, 229/17, 238/1 oral 226/6 order 179/25, 200/25, 201/1, 225/21 organize 226/13
L		
lack 234/7 lambda 224/12, 224/13, 224/17, 224/24 large 146/4, 146/5, 146/9, 146/10, 172/17, 178/17, 192/13, 233/3 larger 183/8 Late-filed 173/17, 195/3, 195/6, 195/14, 209/7, 209/12, 209/13 lateral 191/11, 192/10, 192/14, 192/18, 194/1, 194/4, 194/21, 222/17 Laughter 228/10 laws 135/5 layman 133/1 LEAF 232/6, 232/17 leave 198/19 leaves 206/18 leaving 137/25 left 132/23, 186/9, 199/7 LEON 125/15, 243/2 letter 210/11 licensing 147/20, 147/21 lifetime 238/11 light 130/17, 135/11, 142/6, 145/25, 150/16 line 138/15, 144/5, 146/22, 230/15, 236/14 listed 181/18 little 129/17, 135/13, 135/17, 141/4, 141/18, 174/3, 182/13, 188/24, 190/24, 200/16, 230/12, 233/24 load 144/2, 175/13, 175/14, 220/24, 221/6, 228/22, 233/8, 235/12, 235/21, 235/23, 235/24, 235/25, 236/3, 236/5, 239/5 local 135/1, 170/7 locate 190/11 located 131/3, 131/7, 134/17, 179/12, 233/7 location 130/22, 132/2, 132/7, 177/15, 179/14, 203/11, 237/20 locations 137/4 logic 144/23 Lose 182/13 losing 140/20 loss 132/5, 144/4, 205/24, 230/7 Losses 130/20, 130/25, 131/4, 131/5, 131/8, 131/11, 131/14, 131/21, 131/23, 132/1, 132/8, 132/11, 174/10, 189/8 low 137/10, 190/3, 197/10, 200/20, 223/13, 235/12, 236/5 lower 183/22, 224/11, 229/8 lowers 131/5 lowest 175/16, 175/17, 198/3, 202/3, 224/22		
M		
magnitude 174/23, 199/21, 235/17 maintenance 175/21, 238/13 manager 152/13, 211/4, 211/21 mandates 135/1 margin 139/20, 140/1, 140/2, 140/4, 140/11, 140/13, 140/18, 142/3, 143/24, 227/12, 228/24, 229/2, 235/1, 235/6, 235/9, 235/16, 236/6, 240/17, 241/6		

outage 141/7, 141/12, 141/14, 141/20, 141/22, 141/25, 142/11, 143/14, 143/16, 143/17, 143/21, 144/8, 144/13, 146/25, 175/20, 223/14, 240/7  
outages 141/24, 142/7, 143/6, 143/8, 143/9, 144/1, 235/3, 235/5, 240/7  
output 152/23  
overlook 172/16  
overriding 190/5  
overview 175/10  
ownership 233/4

**P**

p.m 125/18, 207/11, 242/24  
Pages 125/10, 130/18, 133/12, 134/13, 134/18, 136/11, 152/16, 152/18, 174/21, 178/1, 186/3, 197/18, 197/21, 202/15, 202/21, 204/7, 205/12, 205/15, 211/6, 230/17, 243/9  
Panama 190/12, 190/17, 190/19, 194/5, 228/12, 233/9, 233/13  
parameters 177/5, 193/14, 194/15  
parenthesis 131/13, 131/17  
part 138/2, 146/4, 147/17, 184/13, 210/8, 210/12, 228/9, 233/3, 233/4, 233/7, 239/23  
parties 225/22, 225/24, 233/19  
parts 141/16  
passed 209/15  
pay 224/13  
peak 231/5, 235/9  
peaking 235/4  
Peninsular 140/12  
Pensacola 137/13, 211/1  
per-unit 183/4  
percentage 235/12  
perform 128/3, 206/5  
performed 128/8, 134/1, 173/19, 197/1, 221/4, 234/2, 237/1  
period 170/11  
periods 175/15  
permission 206/23, 234/17  
permit 149/21, 204/4  
permitted 149/22, 228/8  
permitting 148/3, 148/14  
Perry 222/15  
personally 128/6  
perspective 178/18, 222/2  
Petition 125/5, 232/23, 239/11  
phone 206/16  
phrase 129/19  
picked 190/6  
picture 189/15  
piece 185/8, 185/11, 225/11, 228/15  
pipeline 137/13, 138/9, 142/5, 144/14, 192/14, 222/13  
pipelines 223/8  
PLACE 125/19, 190/11, 206/10, 211/1, 243/6  
placeholder 176/5, 187/12, 187/14, 196/10, 199/10, 199/11, 200/13  
plan 132/16, 132/21, 141/22, 146/8, 146/25, 176/14, 176/15, 176/19, 176/20, 177/6, 177/7, 177/8, 178/1, 178/3, 180/2, 180/8, 182/21, 182/23, 182/25, 186/25, 191/24, 194/15, 195/23, 195/24, 196/1, 196/2, 199/14, 201/3, 201/4, 201/6, 201/7, 201/9, 201/14  
planned 144/3, 144/10, 192/2  
planning 128/9, 136/4, 143/23, 144/10, 145/5, 145/17, 145/18, 152/13, 178/18, 178/19, 179/19, 198/5, 211/4, 220/25, 223/12, 235/1, 240/3  
plans 186/14, 220/17, 233/17  
plant 125/6, 131/3, 145/1, 146/15, 175/3, 177/4, 183/11, 189/25, 198/2, 222/17, 232/18, 233/22, 238/19, 240/9, 240/11  
plants 234/19  
plus 150/9  
point 137/7, 137/10, 137/12, 138/11, 141/4, 192/5, 208/6, 225/9, 226/6, 241/13  
pointed 132/3  
points 137/5  
policy 222/8, 222/11, 234/18, 240/10  
pool 180/21, 180/22, 197/7, 197/12, 224/9  
POPE 126/4, 127/6, 129/6, 129/17, 140/22, 143/4, 144/20, 145/2, 145/5, 145/10, 145/15, 145/22, 146/17, 147/8, 147/14, 149/3, 149/10, 149/13, 149/17, 150/3, 150/5, 151/22  
portion 177/16  
portions 220/9  
portray 133/12, 172/5, 196/15  
position 211/2  
positive 131/4, 131/17, 132/4, 148/21  
possibility 225/21, 225/23  
POTAMI 125/23, 243/3  
potential 149/20, 149/24  
Power 125/5, 125/6, 127/7, 134/24, 136/12, 140/21, 144/8, 144/11, 145/25, 148/17, 152/2, 170/6, 170/15, 196/24, 207/6, 210/18, 211/2, 222/15, 229/15, 232/23,

234/4, 234/19, 238/19, 241/19  
Power's 134/18, 135/23, 136/2, 170/21, 203/15, 239/11  
predominantly 146/19  
prefer 175/22, 195/14  
Prefiled 126/7, 126/9, 152/15, 211/6, 243/10  
prehearing 225/21  
preliminaries 170/2  
premium 135/13  
prepare 240/6  
prepared 134/21, 135/23, 153/14, 170/6, 202/25, 203/16, 204/10, 225/25, 226/6, 240/14  
prescribed 243/10  
presenting 144/24  
presents 235/24  
pretty 208/16  
price 136/15, 136/18, 136/25, 137/2, 138/7, 138/10, 175/17, 191/1, 197/10, 203/3, 204/14, 204/16, 204/18, 204/19, 205/5, 237/17  
prices 191/19, 191/23  
pricing 137/11, 181/21, 194/25, 203/6  
primary 131/22  
principle 174/4  
probability 223/13  
problem 145/19, 145/21, 146/12, 184/13, 222/14, 223/10, 226/8, 239/22  
problems 220/21  
PROCEEDINGS 125/11, 234/6, 241/17, 243/8, 243/9  
process 148/3, 148/8, 148/13, 220/24, 229/21, 230/2  
processed 223/15  
Production 134/16, 134/20, 175/19, 176/1, 176/8, 176/9, 177/20, 179/23, 180/9, 183/17, 183/23, 183/25, 184/14, 185/3, 185/4, 185/6, 187/22, 189/5, 199/8, 199/9, 231/16  
program 239/8  
programs 231/4, 235/25, 236/2  
project 128/2, 131/24, 137/6, 148/12, 152/13, 171/3, 172/14, 172/15, 172/17, 172/21, 173/2, 174/1, 181/8, 223/23, 227/17, 237/5, 237/10, 237/13, 238/11  
project's 172/5  
projects 127/17, 131/20, 131/24, 172/8, 172/9, 172/10, 197/22, 198/10, 233/11, 237/21, 238/1, 238/25  
PROMOD 175/19  
prompt 221/19  
Proposal 133/18, 186/22, 187/21, 194/5, 195/22, 196/5, 196/11, 196/12, 196/19, 200/4, 200/13, 205/6, 205/10, 237/7  
proposals 170/8, 170/10, 189/16, 189/18, 203/6, 233/11, 236/23  
propose 221/10  
proposed 125/6, 133/3, 133/6, 152/23, 174/8, 174/17, 174/24, 177/9, 177/23, 201/8, 204/1, 232/24, 232/25, 234/21, 236/8, 236/10, 236/17, 238/19, 239/4, 239/6, 239/12  
proposing 190/17  
proved 231/19  
provide 136/1, 136/2, 144/6, 148/1, 205/3, 227/20, 229/7  
PROVIEW 175/7, 175/9, 175/11  
provision 133/2, 147/22, 232/25, 234/22  
prudence 234/6, 234/8  
prudent 240/9, 242/4  
PUBLIC 125/1, 243/5  
publications 170/7  
publish 193/4  
published 170/7, 189/24, 192/6, 207/21  
pull 196/3, 204/11  
pulled 185/11  
purchase 140/21, 227/15  
purchased 229/14, 234/4  
purposes 179/19, 180/9, 181/10, 220/25, 240/3  
put 172/11, 172/18, 175/2, 175/13, 178/22, 179/1, 179/6, 187/16, 190/4, 190/7, 190/24, 191/4, 191/20, 191/22, 192/16, 193/1, 193/9, 193/14, 194/16, 208/14, 225/22, 225/24  
puts 179/4  
putting 172/13

**Q**

quality 228/22, 230/2  
question 129/16, 129/18, 133/22, 140/12, 141/3, 144/17, 172/25, 182/14, 182/15, 184/3, 184/17, 190/23, 198/20, 206/12, 207/17, 211/20, 222/22, 223/18, 229/1  
questions 129/7, 132/25, 138/16, 138/21, 138/24, 139/20, 139/25, 141/2, 147/16, 153/1, 171/15, 171/19, 204/20, 205/12, 211/12, 221/25, 225/3, 225/4, 227/19, 232/9, 232/10, 232/13, 239/17  
quick 175/10  
quiet 232/5  
quote 132/15, 133/4, 205/4, 205/5  
quoted 205/7

**R**

ran 200/11, 200/13, 224/18  
range 194/18  
rank 181/18  
ranked 175/17  
ranking 170/16, 189/13, 201/25, 238/6, 238/8, 238/15  
rate 142/11, 146/25, 148/5, 208/3  
rated 236/11  
rates 141/22  
RCM-1 142/9  
re 148/12  
reach 241/5  
reached 136/7, 136/9  
read 150/15, 153/7, 211/17  
reading 129/2  
reason 143/7, 144/7, 144/18, 147/11, 179/1, 183/10, 199/23, 224/6  
reasonable 221/4, 228/20, 234/21, 234/23, 235/11, 235/22, 236/14, 237/19, 237/24  
reasons 136/14, 145/15, 203/2  
recall 141/9, 190/25  
received 151/9, 151/19, 207/5, 210/2, 225/15, 237/12  
recess 127/3, 195/19, 207/12  
recommendation 226/4, 226/6, 226/19, 232/3, 239/15, 241/16  
recommending 222/7  
recommends 232/22, 239/10  
record 153/7, 207/15, 209/21, 210/9, 211/17, 225/14, 226/10, 231/19  
recovery 234/8  
Redirect 126/5, 138/18, 138/21, 138/23, 139/1, 204/22, 204/24, 206/9, 225/5  
reduce 148/24, 192/24  
reduced 132/8, 132/11, 231/5  
reducing 132/1  
reduction 135/8, 148/9, 149/1, 150/7, 231/7  
reevaluating 235/16  
reference 151/14, 171/22  
refining 189/21  
reflect 140/3, 152/22, 174/4  
reflected 207/25  
reflects 180/23  
region 233/9, 233/13  
regulations 135/5, 135/6  
regulatory 220/16  
relates 129/23  
relation 201/16  
relative 170/16, 174/25, 175/3, 175/5, 189/12, 197/20, 198/14, 201/25, 202/1, 238/6, 238/15  
reliability 142/16, 144/6, 144/12, 220/21, 223/8, 227/9, 227/14, 233/1  
reliable 227/18, 228/4  
reliance 233/22  
relying 205/9, 227/25  
Remaining 197/16, 232/13, 233/5  
Remember 138/8, 141/17  
remembering 208/10  
repeat 129/18, 134/7, 172/25  
replaced 196/7, 196/10  
replacement 131/11, 241/19  
replacing 131/6  
REPORTED 125/22, 243/7  
Reporter 125/22, 125/23, 209/10, 232/16  
REPORTERS 126/22, 243/1, 243/4  
represent 127/24, 130/4, 174/15  
representing 229/25  
represents 127/20, 130/21, 130/24, 131/9, 173/25, 197/22, 199/5  
Request 134/16, 134/20, 141/9, 210/4, 210/7, 221/19, 233/10, 236/23  
requests 231/17  
require 226/20  
required 147/25, 148/2, 220/23, 233/16, 236/19  
requirement 174/22, 179/17, 183/16, 191/3  
requirements 130/4, 130/5, 133/19, 173/24, 184/25, 185/1, 187/7, 196/20, 198/6, 238/21  
requires 133/3  
requiring 233/11  
reran 183/17  
rerunning 175/7  
reserve 139/20, 140/1, 140/2, 140/3, 140/11, 140/12, 140/14, 140/16, 140/17, 142/3, 143/23, 143/24, 145/4, 145/6, 227/12, 228/24, 229/2, 235/1, 235/6, 235/9, 235/16, 236/6, 240/17, 241/6  
reserves 140/7, 140/10, 140/15, 220/21, 227/13  
resolution 239/9  
resource 143/25, 146/20, 172/22, 173/3, 238/7  
resources 228/24  
respect 136/2, 147/4, 239/18, 239/25  
respondent 130/2, 139/13, 139/14, 139/16, 139/17, 181/1, 181/20, 196/7, 203/25, 204/4, 204/5, 205/3, 208/18

respondent's 130/7  
 respondents 128/11, 128/24, 129/12, 130/11, 136/21,  
 139/8, 139/11, 170/9, 177/18, 177/22, 179/21, 180/3,  
 180/16, 186/4, 197/23, 198/8, 198/14, 203/24, 205/7  
 responding 181/6, 184/5  
 response 127/14, 131/20, 134/22, 135/16, 135/22,  
 135/23, 139/11, 139/13, 139/15, 171/21, 178/6, 202/23,  
 202/24, 203/15, 203/16  
 responses 132/4, 132/7, 134/15, 134/19, 136/13,  
 204/8, 204/9, 204/11, 205/14, 233/10, 237/1, 237/13  
 responsibly 231/12  
 restart 148/2, 148/13  
 result 135/15, 175/7, 190/16, 230/16  
 results 170/12, 221/1, 230/13  
 resumed 127/7  
 returned 235/17  
 revealed 170/13  
 revenue 130/4, 130/5, 133/19, 173/23, 174/16,  
 174/22, 183/16, 185/1, 187/7, 196/20, 198/6, 238/20  
 review 241/25, 242/2, 242/4  
 reviewed 234/5, 240/5  
 revise 154/6  
 revised 174/2, 183/2  
 RFP 127/16, 128/24, 130/11, 131/20, 132/4, 136/21,  
 137/21, 137/23, 170/5, 170/6, 170/7, 172/9, 174/17,  
 177/11, 177/18, 180/15, 189/24, 190/4, 190/8, 190/9,  
 190/11, 190/24, 191/3, 192/6, 192/15, 196/7, 197/22,  
 198/8, 198/9, 203/4, 203/5, 203/20, 203/25, 205/14,  
 207/21, 208/14, 208/19, 221/13, 229/20, 236/25, 237/4,  
 237/10, 237/13, 237/21, 238/1, 238/25  
 RFPs 137/25, 172/12, 177/9  
 right-hand 189/11  
 Room 125/19, 201/2  
 RPR 125/22, 125/23, 243/3, 243/14  
 rule 236/21, 236/22  
 rulemaking 234/17, 239/18  
 rules 170/5, 191/3, 229/23, 239/19  
 run 175/10, 176/4, 176/6, 187/12, 187/15, 196/9,  
 207/19  
 runs 177/21, 201/21  
 RUTHE 125/23, 243/3

S

satisfied 222/22  
 satisfy 235/19  
 savings 171/2, 173/7, 174/16, 174/19, 180/2, 183/18,  
 183/19, 185/9, 186/13, 186/24, 186/25, 190/20, 198/24,  
 199/5, 199/13, 199/20, 199/22, 200/16, 200/18, 201/15,  
 202/7, 223/21, 223/24, 224/2, 224/12, 224/25, 230/6,  
 230/7, 231/13, 235/24, 236/1, 238/22, 239/6, 239/8  
 scale 178/24, 183/8  
 scaled 179/22, 180/4, 182/19, 182/20, 184/1, 184/15  
 scarce 229/15  
 Schedule 181/15  
 scheduled 175/20  
 schedules 140/6, 154/7  
 screening 138/5, 138/6, 141/5, 221/4  
 second 228/17, 242/9, 242/20  
 seconds 206/10  
 Section 133/2, 189/6, 220/5, 226/25, 233/2, 236/19  
 secure 148/18  
 securing 150/15  
 selected 135/8  
 selecting 238/25  
 selective 148/9  
 self-build 136/16, 136/22, 137/23, 137/25, 138/4,  
 138/8, 179/22, 181/2, 183/24, 186/2, 187/17, 187/21,  
 189/17, 190/4, 193/2, 199/20, 206/6, 221/7, 229/16,  
 229/18, 237/1, 237/4, 237/9, 238/1, 238/24  
 sell 224/8, 224/16, 224/23  
 selling 224/8, 224/14  
 sense 129/18, 175/5, 222/25  
 sent 189/19  
 separate 137/13, 186/3, 235/13  
 series 141/2  
 serve 221/3  
 served 222/13  
 SERVICE 125/1, 220/18, 221/2, 221/21, 233/5,  
 233/7, 243/5  
 Service's 128/9  
 Services 130/12, 130/15, 152/12  
 Services' 176/25  
 set 131/8, 197/14  
 sets 130/18  
 seventh 132/23  
 shape 175/14, 194/22  
 shed 130/17  
 sheet 126/19, 129/10, 209/16, 209/19  
 show 141/6, 151/8, 151/18, 175/23, 185/21, 193/17,  
 194/5, 200/9, 206/5, 207/4, 225/14  
 shows 142/10, 170/16, 185/24, 186/6, 192/1, 197/19,  
 227/11, 227/16, 228/11, 228/22, 229/5, 229/21, 231/3,

231/6  
 side 135/18, 144/11, 189/11  
 signed 137/18, 237/11  
 signify 242/9  
 Simultaneous 242/10  
 single 222/13  
 site 147/7, 148/22, 148/23, 149/1, 149/8, 177/18,  
 190/7, 190/8, 190/17, 190/18, 192/8, 227/25  
 site-specific 177/19, 177/21, 177/22, 192/9, 237/19  
 sited 194/5  
 sites 192/4  
 sitting 137/7  
 situation 172/9, 203/25  
 sixth 186/8  
 size 146/9, 172/21, 173/3, 178/12, 178/16, 178/23,  
 178/25, 179/7, 179/9, 179/23, 182/6, 182/24, 183/12,  
 183/25, 184/5, 199/12, 202/10, 202/13, 205/23, 238/14  
 sizes 172/10, 179/2, 182/22  
 small 172/16, 172/17, 174/5  
 Smith 127/16, 128/1, 128/12, 128/23, 129/10, 129/22,  
 130/2, 130/6, 130/12, 131/3, 131/21, 132/4, 132/7,  
 133/6, 134/4, 134/9, 135/2, 135/3, 136/3, 136/22,  
 137/8, 137/9, 137/22, 137/24, 138/14, 140/5, 140/7,  
 141/8, 141/12, 142/11, 147/2, 147/22, 148/24, 148/25,  
 149/4, 149/6, 149/14, 150/8, 150/12, 150/25, 152/23,  
 170/10, 170/13, 170/17, 170/20, 171/25, 173/9, 174/8,  
 174/16, 174/24, 175/3, 176/5, 176/6, 182/6, 183/2,  
 183/11, 189/25, 194/13, 196/7, 197/9, 198/1, 198/2,  
 198/7, 198/9, 198/11, 201/19, 202/2, 202/7, 203/4,  
 203/20, 203/22, 205/14, 220/16, 221/7, 222/4, 222/17,  
 226/24, 227/8, 227/11, 227/24, 228/18, 229/5, 229/11,  
 229/17, 230/4, 230/10, 230/18, 230/22, 231/6, 231/23,  
 232/24, 233/14, 233/18, 235/7, 235/8, 235/19, 236/8,  
 236/18, 236/24, 237/16, 238/4, 238/16, 238/21, 239/1,  
 239/12  
 sort 183/7, 184/4, 189/14  
 sought 229/20  
 sound 222/2  
 source 146/22, 149/19, 233/18  
 sources 204/13  
 south 222/12  
 Southern 128/8, 130/12, 130/14, 131/25, 132/5,  
 132/8, 132/11, 132/15, 133/8, 133/20, 134/1, 134/5,  
 134/10, 140/2, 140/9, 140/13, 141/6, 141/12, 145/4,  
 146/3, 146/8, 146/9, 146/23, 152/12, 172/13, 175/12,  
 176/25, 178/17, 179/11, 180/12, 180/24, 181/4, 196/21,  
 197/2, 197/6, 197/7, 197/9, 197/12, 201/23, 204/13,  
 223/22, 227/24, 233/23, 235/4, 235/11, 235/15, 236/25,  
 237/14, 238/4, 238/5, 238/10  
 Southern's 227/23, 233/24, 234/25, 238/15  
 SPEAKER 242/19  
 specifications 181/6  
 sponsored 134/22, 225/12  
 sponsoring 154/16, 220/4  
 spreadsheet 175/23, 188/24, 194/18  
 spreadsheets 127/22, 130/3  
 Staff 151/10, 151/11, 171/16, 185/10, 190/10, 193/17,  
 198/17, 202/5, 203/14, 205/18, 206/5, 210/8, 210/10,  
 225/4, 226/3, 226/5, 230/14, 230/20, 231/17, 232/2,  
 232/19, 232/21, 232/22, 234/16, 235/10, 236/24, 237/5,  
 237/17, 237/22, 239/10, 239/19, 239/20, 240/22  
 Staff's 127/13, 127/14, 134/15, 134/16, 134/19,  
 134/20, 135/16, 135/22, 136/13, 147/17, 171/21, 178/6,  
 202/24, 203/15, 204/8, 209/17, 210/4, 239/15, 241/9,  
 241/16  
 stand 127/7, 129/13, 195/9, 206/10, 206/18, 207/17,  
 209/18, 210/15  
 stand-alone 172/15  
 standard 220/16  
 standpoint 131/25, 132/5  
 start 200/20, 207/10  
 starting 127/13, 173/16  
 state 135/1, 152/7, 210/23, 243/1  
 state-of-the-art 221/1, 235/22  
 States 146/24  
 Statues 133/3  
 status 203/19, 206/11  
 Statutes 233/2, 234/24, 236/20  
 statutory 227/5, 228/17, 229/10, 230/24, 231/20,  
 241/6  
 staying 139/3  
 steam 223/14  
 stenographically 243/7  
 steps 221/20  
 strategy 135/10, 150/6, 150/11  
 Street 152/9  
 Study 154/17, 191/25, 220/5, 225/11, 235/2  
 Subject 142/18, 142/20, 234/1  
 submitted 228/22  
 subsequent's 236/25  
 subtract 187/3, 208/10  
 sufficient 233/20  
 sum 184/25, 230/7

summarize 134/24, 136/14, 143/20, 203/2, 220/11  
 summary 170/3, 170/22, 189/12, 205/16, 205/17,  
 205/20, 221/22, 231/14, 238/24, 239/9  
 summer 221/21, 228/25, 231/5, 235/6, 235/9, 236/11  
 supervision 134/21, 135/24, 153/15, 202/25, 203/16,  
 204/10  
 supplemental 139/23, 152/19, 152/21, 153/2, 153/6,  
 154/4, 182/5, 189/2  
 supplied 233/21  
 supplier 137/17, 138/13, 203/24  
 supply 136/3, 141/8, 141/13, 141/21, 143/6, 143/14,  
 147/7, 150/11, 150/22, 150/24, 203/7, 205/4, 222/20,  
 233/12, 234/9, 237/11, 237/13, 238/4, 240/8, 241/18,  
 241/23  
 supply-side 170/21  
 support 227/18  
 supports 227/4  
 surveyed 229/16  
 SUSAN 125/14  
 swapped 139/11, 139/18  
 switch 147/6  
 switching 144/18, 144/25, 145/13, 146/15, 147/5,  
 147/11, 149/8, 149/13  
 sworn 127/8, 152/3, 210/19  
 system 130/24, 130/25, 131/10, 131/25, 132/3, 132/6,  
 132/9, 132/12, 133/19, 133/20, 134/1, 140/4, 140/9,  
 140/13, 141/6, 141/12, 144/3, 144/7, 144/9, 145/3,  
 145/4, 145/5, 145/9, 146/3, 146/4, 146/5, 146/8, 146/9,  
 146/23, 147/12, 147/13, 175/12, 176/21, 177/16,  
 178/17, 178/18, 178/21, 179/3, 179/11, 180/2, 180/24,  
 181/4, 186/17, 196/20, 196/21, 197/2, 197/12, 203/23,  
 211/4, 211/21, 223/12, 223/22, 224/7, 224/9, 224/12,  
 224/13, 224/16, 224/20, 224/24, 227/9, 227/14, 227/23,  
 228/14, 228/15, 230/6, 233/1, 233/6, 233/12, 233/15,  
 233/23, 233/24, 235/1, 235/11, 237/5, 237/10, 238/6,  
 238/15, 240/6  
 System's 235/4  
 system-wide 223/21, 223/24

T

table 131/19, 140/15, 150/15, 171/11, 202/2, 209/15  
 tables 176/13  
 tabular 194/10  
 talk 199/25, 200/2, 206/18  
 talked 170/24, 189/12  
 talking 136/24, 208/12  
 Tallahassee 125/20  
 target 140/18, 190/3, 228/24  
 targeting 190/2  
 team 190/4  
 technology 177/1, 178/21, 179/8, 221/9  
 telephone 195/11  
 terms 189/23, 193/1  
 territory 221/2, 233/5, 233/7  
 TERRY 125/13  
 test 228/16  
 tested 221/13  
 testified 127/8, 143/20, 150/12, 150/14, 152/3,  
 210/19, 223/20  
 testifying 138/2  
 Testimony 126/7, 126/9, 139/23, 144/19, 145/13,  
 152/16, 152/19, 152/21, 153/2, 153/6, 153/11, 154/4,  
 170/3, 172/1, 172/24, 173/5, 182/1, 182/5, 189/3,  
 193/21, 193/25, 211/7, 211/10, 211/16, 220/2, 220/12,  
 227/3, 231/6, 243/10  
 Thank 127/5, 142/22, 151/20, 151/22, 173/15, 195/1,  
 207/9, 209/3, 228/9, 231/25, 232/19, 242/16  
 Thereupon 242/23  
 they've 230/15, 231/15  
 third 229/10  
 three 152/18, 186/12  
 TIME 125/17, 138/12, 138/15, 138/24, 141/18, 150/9,  
 150/14, 150/18, 176/22, 178/22, 180/8, 192/15, 201/3,  
 201/10, 201/13, 203/9, 228/8, 229/14, 232/18, 241/21,  
 242/3, 243/6  
 timetable 147/21  
 title 129/11, 139/18, 152/11, 211/21  
 top 137/7, 148/17, 171/22, 231/10  
 Tower 136/23, 137/8, 137/12  
 trade 170/8  
 trade-off 235/3  
 traditional 186/14  
 traditionally 238/18  
 transcribed 243/8  
 Transcript 127/2, 243/8  
 transcription 243/9  
 translate 140/14  
 translates 142/15  
 Transmission 127/18, 127/25, 128/1, 128/4, 128/9,  
 129/23, 130/5, 130/11, 130/20, 130/24, 131/4, 131/10,  
 131/14, 131/23, 132/1, 132/3, 132/9, 144/3, 144/5,  
 144/9, 145/18, 150/22, 171/23, 175/1, 175/3, 190/6,

<p>190/7, 190/8, 190/21, 197/18, 197/24, 197/25, 198/3, 198/4, 198/7, 205/24, 207/24, 208/2, 208/8, 208/11, 208/17, 211/4, 211/21, 228/13, 230/6, 230/7, 233/12, 233/15, 237/5, 237/10, 238/3, 238/13  transmissions 189/7  transportation 136/7, 137/3, 150/13, 150/20, 150/23, 205/4, 205/8, 210/4, 227/17, 228/2, 234/15, 237/12  trouble 181/23  true 173/25, 174/23, 184/21, 205/23, 243/9  trust 142/21  turbine 141/20, 141/24, 141/25, 143/6, 143/17, 181/20, 223/14  turn 134/13, 135/20, 139/20, 147/18, 176/11, 198/16, 202/5, 202/21, 203/14, 204/25, 205/15, 206/1  Turning 136/11, 173/10, 195/20, 203/12, 204/7  two 139/11, 144/6, 153/11, 186/21, 188/3, 198/24, 199/7, 204/1  type 141/14, 143/21, 144/25, 146/18, 176/3, 176/5, 204/3, 208/7, 230/12  types 171/7, 192/11</p>	<p style="text-align: center;"><b>W</b></p> <p>walk 185/12, 185/21  waterfront 229/16  weather 144/1  week 175/13  weekday 175/15  weekend  weeknight  weigh 227/21  western 233/7  WFP-2 139/21, 140/6  wiggle 201/1  WILLIAM 126/4, 127/6  willing 226/21  winner 221/8, 221/17  wipes 148/21  witness 127/7, 129/6, 129/17, 130/14, 134/8, 140/22, 142/25, 143/4, 144/20, 145/2, 145/5, 145/10, 145/15, 145/22, 146/17, 147/8, 147/14, 149/3, 149/10, 149/13, 149/17, 150/3, 150/5, 151/22, 152/2, 173/19, 179/20, 180/14, 180/18, 180/21, 181/1, 181/9, 181/23, 182/2, 182/9, 182/19, 183/5, 183/10, 184/7, 184/10, 184/21, 184/24, 185/20, 186/8, 186/11, 187/11, 187/20, 188/1, 188/21, 189/4, 189/18, 190/13, 190/18, 191/2, 191/6, 191/15, 191/21, 191/24, 192/19, 192/23, 193/3, 193/8, 193/11, 193/23, 194/2, 194/6, 194/17, 194/23, 195/9, 195/17, 199/1, 199/6, 199/17, 199/24, 200/24, 202/9, 208/15, 209/2, 209/4, 210/18, 211/19, 223/1, 223/3, 225/7, 225/12  WITNESSES 126/2, 222/1, 243/10  word 188/8  words 234/7  work 150/21, 152/8, 152/12, 178/19  works 178/15  Worth 173/23, 174/16, 223/16, 238/20  written 227/3  wrong 178/8, 211/22</p>	
<p style="text-align: center;"><b>U</b></p> <p>unavailable 221/11  uncomfortable 190/15  uncommon 201/9  UNIDENTIFIED 242/19  uniformly 237/25  Unit 127/16, 128/2, 128/12, 128/23, 129/10, 129/22, 130/2, 130/6, 130/12, 131/6, 131/7, 131/21, 133/3, 133/6, 133/13, 133/25, 134/4, 134/9, 135/2, 136/3, 137/22, 137/24, 138/14, 140/5, 140/8, 141/8, 141/14, 141/19, 141/21, 141/23, 141/25, 142/1, 142/7, 142/11, 142/15, 142/17, 144/4, 144/7, 146/23, 147/2, 148/6, 148/25, 149/6, 149/18, 149/25, 150/3, 150/4, 150/12, 152/23, 170/10, 170/13, 170/14, 170/17, 170/20, 170/23, 171/25, 172/21, 173/3, 173/9, 174/8, 174/16, 174/24, 176/5, 176/6, 176/9, 176/10, 176/21, 179/9, 179/12, 180/1, 180/8, 180/23, 182/6, 182/25, 183/13, 184/5, 185/4, 185/5, 187/5, 192/2, 192/24, 194/13, 196/7, 196/16, 196/25, 197/9, 198/1, 198/7, 198/9, 199/9, 201/20, 202/2, 203/4, 203/20, 203/22, 220/19, 220/20, 221/16, 221/19, 222/4, 222/16, 223/14, 224/15, 226/24, 227/8, 227/11, 227/13, 227/18, 227/21, 227/25, 228/3, 228/12, 229/3, 229/5, 229/11, 229/17, 229/21, 230/4, 230/10, 230/18, 230/22, 231/2, 231/7, 231/11, 231/13, 231/23, 232/24, 232/25, 233/14, 233/18, 234/21, 235/7, 235/8, 235/19, 236/8, 236/10, 236/11, 236/18, 236/24, 237/16, 238/2, 238/4, 238/14, 238/16, 238/21, 239/2, 239/5, 239/12, 241/18  unit's 224/17  United 146/24  units 129/22, 144/9, 144/10, 144/11, 146/21, 147/11, 175/12, 175/16, 175/19, 176/18, 176/23, 176/24, 177/5, 177/7, 177/10, 177/11, 177/14, 177/23, 178/13, 181/3, 184/14, 184/15, 197/8, 197/9, 198/12, 200/18, 222/12, 222/13, 222/18, 224/7, 224/21, 233/4, 233/6, 236/15  unlike 229/24  unnecessary 209/12, 222/3  update 152/22, 154/6, 210/3  updated 174/2, 182/6  updates 152/25  upgrades 233/12, 233/15  urge 226/23  utilities 201/24, 236/16  Utility 132/22, 133/18, 176/16, 178/2, 186/22, 195/22, 196/5, 196/11, 196/18, 196/19, 200/12, 235/13  utilization 175/18</p>	<p style="text-align: center;"><b>X</b></p> <p>X 126/1</p>	
<p style="text-align: center;"><b>V</b></p> <p>valid 145/8  Value 127/19, 130/20, 171/1, 171/24, 171/25, 172/16, 183/15, 184/14, 187/7, 187/8, 187/25, 188/3, 188/5, 188/7, 188/12, 188/15, 188/22, 189/9, 189/23, 191/5, 191/14, 193/2, 193/4, 193/15, 194/14, 197/19, 208/1, 230/9, 238/11  values 172/14, 172/22, 173/4, 175/6, 189/11  variable 137/3, 137/4, 175/25, 176/17, 176/22, 185/23, 186/13  variety 171/7, 172/10  verbally 195/15  version 182/4  view 180/11, 180/12  vintage 138/3  VOLUME 125/9, 127/2  vote 226/20, 226/21, 226/23  votes 242/10</p>	<p style="text-align: center;"><b>Y</b></p> <p>year 140/10, 140/16, 142/14, 143/2, 143/3, 143/4, 143/8, 148/12, 148/18, 148/20, 175/14, 177/2, 179/3, 236/8, 239/8  year's 148/16  years 171/2, 200/14, 223/9, 223/11, 234/15, 236/4</p>	

BEFORE THE FLORIDA PUBLIC SERVICE COMMISSION

In re: Petition of Gulf Power Company to  
Determine Need for Proposed Electrical  
Power Plant in Bay County, Florida

Docket No.: 990325-EI  
Filed: May 17, 1999

**SUPPLEMENT TO PETITION TO DETERMINE NEED  
FOR ELECTRICAL POWER PLANT**

Gulf Power Company ("Gulf Power", "Gulf", or "the Company"), by and through its undersigned attorneys, hereby supplements the Company's petition to the Florida Public Service Commission ("Commission") pursuant to Section 403.519, Florida Statutes, and Rule 25-22.081, Florida Administrative Code asking the Commission to determine the need for the Company's proposed electrical power plant, and to file its order making that determination with the Department of Environmental Protection ("DEP") pursuant to Section 403.507(2)(a)(2), F.S.

The Company's petition and supporting documentation, as filed on March 15, 1999, referred to the proposed electrical power plant as a 540 MW combined cycle generating facility, to be constructed at the existing Lansing Smith generating plant site located in Bay County, Florida. The new unit, to be known as Smith Unit 3, consists of two "F" class combustion turbine generators and two heat recovery steam generators that will drive a single steam turbine generator. As noted in the attached Supplement to Gulf Power Company Need Study and the supplemental direct testimony of Gulf's witnesses R. G. Moore, W. F. Pope and M. J. Burke filed contemporaneously with this supplement to the Company's petition to determine need for electrical power plant, Gulf has continued to refine the engineering design and cost estimate for Smith Unit 3 in an effort to achieve the best overall value for the proposed electrical power plant.

As a result of design changes identified through this ongoing engineering process, the proposed Smith Unit 3 is now more appropriately referred to as a 574 MW combined cycle generating facility.

WHEREFORE, Gulf Power Company respectfully requests that the Florida Public Service Commission determine that there is a need for the proposed electrical power plant described in this supplement to the Company's petition to determine need for electrical power plant, and that the Commission file its order making such determination with the DEP pursuant to Section 403.507(2)(a)2., F.S.

RESPECTFULLY SUBMITTED this 17th day of May, 1999.

By: 

JEFFREY A. STONE  
Fla. Bar No. 325953  
RUSSELL A. BADDERS  
Fla. Bar No. 007455  
Beggs & Lane  
P.O. Box 12950  
Pensacola, FL 32576-2950  
(850)432-2451

RICHARD D. MELSON  
Fla Bar No. 201243  
Hopping Green Sams & Smith, P.A.  
Post Office Box 6526  
Tallahassee, Florida 32314  
(850) 222-7500

Attorneys for Gulf Power Company

## SUPPLEMENT TO GULF POWER COMPANY NEED STUDY

Since the filing of Gulf Power Company's Need Study on March 15, 1999, Gulf has continued to refine the engineering design and cost estimate for Smith Unit 3 in an effort to achieve the overall best value.

As a result of design changes identified through this ongoing engineering process, Gulf has been able to increase the summer peak capacity of the unit from approximately 540 MW to approximately 574 MW. This increase is accomplished by adding the capability to produce a higher mass steam flow through the steam turbine generator. The changes associated with this 6.3% increase in maximum unit capability result in a slight reduction in the average annual output of the unit, from 521 MW to 519 MW, and a slight increase in the average annual heat rate for the unit from 6,741 Btu/KWH to 6,761 Btu/KWH.

The total nominal cost estimate for the Smith Unit 3 has increased by \$9,670,000, or 5.2%, to \$196,922,000. On a per KW basis, the total nominal cost has decreased from approximately \$347/KW to approximately \$343/KW.

To confirm that the cost-effectiveness of the project has been improved on a net present value (NPV) of total cost basis, Gulf has analyzed the total revenue requirements associated with the larger unit using the same PROVIEW evaluation methodology that was used in the previous ranking of Smith Unit 3 and the RFP alternatives. The results of

this study are presented in the attached table which updates the information previously provided in Table 8-2 of the Need Study.

This updated analysis shows that the evaluated NPV cost of Smith Unit 3 has decreased from \$279/KW to \$274/KW in 2002 dollars. This indicates that the incremental MWs resulting from the design change are a cost-effective capacity resource.

Based on this analysis, Gulf has concluded that the design changes to Smith Unit 3 represent a cost-effective means of providing 34 MW of additional capacity under summer peak conditions. Gulf therefore requests the Commission to determine a need for 574 MW of capacity and to find that Smith Unit 3 is the most cost-effective means of meeting that need.

**TABLE 8-2 (Revised 5/17/99)**

Gulf RFP 2002 Supply

Relative Ranking - Detailed Evaluation

<b>Rank</b>	<b>MW</b>	<b>Bidder</b>	<b>NPV Total Cost \$/kW (2002\$)</b>
1	574	Smith Unit 3	274
2	486	Respondent B CT (20 Year Pricing)	496
3	500	Respondent B CC (10 Year Pricing)	505
4	532	Respondent C	511
5	500	Respondent B CC (7 Year Pricing)	522
6	486	Respondent B CT (10 Year Pricing)	527
7	486	Respondent B CT (7 Year Pricing)	539
8	500	Respondent B CC (20 Year Pricing)	553
9	351.5	Respondent A	592
10	532	Respondent C (Fixed Energy)	616

BEFORE THE FLORIDA PUBLIC SERVICE COMMISSION

In re: Petition of Gulf Power Company )  
to determine need for proposed )  
electrical power plant in Bay County )  
\_\_\_\_\_ )

Docket No. 990325-EI

Certificate of Service

I HEREBY CERTIFY that a copy of the foregoing has been furnished  
this 17<sup>th</sup> day of May 1999 by U.S. Mail or hand delivery to the following:

Grace A. Jaye, Esquire  
Staff Counsel  
FL Public Service Commission  
2540 Shumard Oak Boulevard  
Tallahassee FL 32399-0863

Gail Kamaras  
LEAF  
1114 Thomasville Road, Suite E  
Tallahassee FL 32303



JEFFREY A. STONE  
Florida Bar No. 325953  
RUSSELL A. BADDERS  
Florida Bar No. 0007455  
Beggs & Lane  
P. O. Box 12950  
Pensacola FL 32576  
850 432-2451  
Attorneys for Gulf Power Company

Florida Public Service Commission  
Docket No. 990325-EI  
**GULF POWER COMPANY**  
Witness: Robert G. Moore  
Exhibit 2 (RGM-1)  
Schedule 1

**SMITH UNIT 3 OPERATING CHARACTERISTICS**

Forced outage rate	3.4%
Scheduled maintenance outage (Avg.)	2 wks/yr
Equivalent availability	92%
Expected average capacity factor	62%
Fuel consumption (full load)	3,900 MMBtu/hr
Annual fixed O & M (98\$)	\$2.84/KW-yr.
Variable O & M (98\$)	\$1.89/mWh

FLORIDA PUBLIC SERVICE COMMISSION  
EXHIBIT  
NO. 990325-EI EXHIBIT NO. 2  
COMPANY/  
WITNESS: Moore  
DATE: 6-7-99

Florida Public Service Commission

Docket No. 990325-EI

**GULF POWER COMPANY**

Witness: Robert G. Moore

Exhibit \_\_\_\_\_ (RGM-1)

Schedule 2

**INSTALLED COST ESTIMATE FOR SMITH UNIT 3**

<u>DESCRIPTION:</u>	<u>AMOUNT (2002\$)</u>
Indirects	\$ 23,661,966
Site, General	2,701,846
Steam Generator Area	36,741,570
Turbine & Generator Area	91,143,505
Fuel Facilities (metering only)	856,111
Plant Water Systems	13,443,351
Electrical Distribution & Switchyard	12,177,183
Plant Instrumentation & Controls	2,591,303
Other	<u>3,935,190</u>
TOTAL	\$187,252,025

**INSTALLED COST ESTIMATE FOR SMITH UNIT 3**

<u>DESCRIPTION:</u>	<u>AMOUNT (2002\$)</u>
Indirects	\$ 25,661,966
Site, General	6,701,846
Heat Recovery Steam Generator Area	39,741,570
Turbine & Generator Area	91,143,505
Fuel Facilities (metering only)	856,111
Plant Water Systems	13,443,351
Electrical Distribution & Switchyard	12,847,183
Plant Instrumentation & Controls	2,591,303
Other	<u>3,936,065</u>
TOTAL	\$196,922,900

FLORIDA PUBLIC SERVICE COMMISSION  
DOCKET  
NO. 990325-EI EXHIBIT NO. 3  
COMPANY/  
WITNESS: Moore  
DATE: 6-7-99

DOCUMENT NUMBER-DATE

06216 MAY 17 88

FPSC-RECORDS/REPORTING

Florida Public Service Commission  
Docket No. 990325-EI  
Gulf Power Company  
Witnesses: Margaret D. Neyman  
Michael J. Marler  
Exhibit No. 4 (MDN/MJM-1)  
Schedule 1

History and Forecast Summary							
	1989 History	1998 History	2003 Forecast	2008 Forecast	CAAG <sup>1</sup> 1989-1998	CAAG <sup>1</sup> 1998-2003	CAAG <sup>1</sup> 1998-2008
Population	662,784	810,649	891,566	960,867	2.3%	1.9%	1.7%
Residential Customers	250,038	304,413	337,784	367,016	2.2%	2.1%	1.9%
Customer Gains					54,375	33,371	62,603
Kwh / Customer	13,173	14,577	14,677	14,995	1.1%	0.1%	0.3%
Energy (GWh)	3,294	4,438	4,958	5,503	3.4%	2.2%	2.2%
Commercial Customers	33,500	45,510	51,208	55,836	3.5%	2.4%	2.1%
Kwh / Customer	64,761	68,379	68,275	69,507	0.6%	0.0%	0.2%
Energy (GWh)	2,169	3,112	3,496	3,881	4.1%	2.4%	2.2%
Net Energy for Load (GWh)	8,378	10,402	11,658	12,661	2.4%	2.3%	2.0%
Summer Peak Demand (MW)	1,698	2,154	2,280	2,466	2.7%	1.1%	1.4%
Winter Peak Demand (MW)	1,554	1,692	2,139	2,258	0.9%	4.8%	2.9%
Load Factor (%)	56.3%	55.1%	58.4%	58.6%			

NOTES: <sup>1</sup> CAAG stands for Compound Average Annual Growth

FLORIDA PUBLIC SERVICE COMMISSION  
DOCKET  
NO. 990325-EI EXHIBIT NO. 4  
COMPANY/  
WITNESS: Neyman/ Marler  
DATE: 6-7-99

### Demand Side Management Programs

#### Residential Programs:

1. GoodCents New Home
2. Heat Pump Upgrade
3. Resistance Heat to Heat Pump Upgrade
4. Air Conditioning Upgrade
5. Residential Energy Audit
6. Residential Mail-In Audit
7. *In Concert With The Environment*
8. Geothermal Heat Pump
9. Advanced Energy Management
10. Outdoor Lighting Conversion

#### Commercial Programs:

1. Commercial GoodCents Building
2. Commercial Energy Audit
3. Technical Assistance Audit
4. Commercial Mail-In Audit
5. Real Time Pricing Pilot
6. Outdoor Lighting Conversion

#### Street Lighting Conversion

Florida Public Service Commission  
Docket No. 990325-EI  
Gulf Power Company  
Witnesses: Margaret D. Neyman  
Michael J. Marler  
Exhibit No. \_\_\_\_\_ (MDN/MJM-1)  
Schedule 3

CONSERVATION PROGRAMS  
CUMULATIVE ANNUAL REDUCTIONS AT GENERATOR

	Summer Peak (MW)			Winter Peak (MW)			Net Energy for Load (GWH)		
	Existing	New	Total	Existing	New	Total	Existing	New	Total
1997	214	30	244	263	6	269	514	9	523
2002	252	112	365	295	128	423	573	77	650
2008	290	199	489	335	256	590	625	146	770

Florida Public Service Commission  
Docket No. 990325-EI  
**GULF POWER COMPANY**  
Witness: William F. Pope  
Exhibit No. 5 (WFP-1)  
Schedule 1

**SUMMARY OF ECONOMIC ANALYSIS**

<u>SELF-BUILD ALTERNATIVE</u>	<u>NET PRESENT VALUE OF COSTS (98\$ MIL)</u>
Smith Unit 3	117.1
Smith Combustion Turbine	158.5
Daniel Combined Cycle	236.7
Mulat Tower (cogeneration)	239.0

FLORIDA PUBLIC SERVICE COMMISSION  
DOCKET  
NO. 990325-EI EXHIBIT NO. 5  
COMPANY/  
WITNESS: Pope  
DATE: 6-7-99

**GULF POWER COMPANY**

Witness: William F. Pope

Exhibit No. \_\_\_\_\_ (WFP-1)

Schedule 2

**GULF'S FUTURE RESERVES BEGINNING  
IN 2002 WITH THE ADDITION OF SMITH UNIT 3**

<u>YEAR</u>	<u>PEAK DEMAND (MW)</u>	<u>STARTING CAPACITY (MW)<sup>1</sup></u>	<u>CAPACITY ADDITION (MW)</u>	<u>ENDING CAPACITY (MW)</u>	<u>PERCENT</u>
<u>RESERVES</u>					
2002	2,265	2,123	540	2,663	17.6%
2003	2,280	2,663	0	2,663	16.8%
2004	2,309	2,663	0	2,663	15.3%
2005	2,347	2,663	-19	2,644	12.7%
2006	2,383	2,644	0	2,644	11.0%
2007	2,425	2,640	148	2,788	15.0%
2008	2,466	2,784	0	2,784	12.9%

Footnotes: <sup>1</sup> The beginning capacity figures have interruptible load embedded into them in the amounts of: 34 MW for 1999 - 2006, 30 MW for 2007, and 26 MW for 2008.

Florida Public Service Commission  
Docket No. 990325-EI  
**GULF POWER COMPANY**  
Witness: William F. Pope  
Exhibit No. 6 (WFP-2)  
Schedule 3

**GULF'S FUTURE RESERVES BEGINNING  
IN 2002 WITH THE ADDITION OF SMITH UNIT 3**

<u>YEAR</u>	<u>PEAK DEMAND (MW)</u>	<u>STARTING CAPACITY CAPACITY<sup>1</sup> (MW)</u>	<u>CAPACITY ADDITION (MW)</u>	<u>ENDING CAPACITY (MW)</u>	<u>PERCENT RESERVES</u>
2002	2,265	2,123	574	2,697	19.1%
2003	2,280	2,697	0	2,697	18.3%
2004	2,309	2,697	0	2,697	16.8%
2005	2,347	2,697	-19	2,678	14.1%
2006	2,383	2,678	0	2,678	12.4%
2007	2,425	2,674	148	2,822	16.4%
2008	2,466	2,818	0	2,818	14.3%

Footnotes: <sup>1</sup> The beginning capacity figures have interruptible load embedded into them in the amounts of: 34 MW for 1999 - 2006, 30 MW for 2007, and 26 MW for 2008.

FLORIDA PUBLIC SERVICE COMMISSION  
DOCKET  
NO. 990325-EI EXHIBIT NO. 6  
COMPANY/  
WITNESS: Pope  
DATE: 6-7-99

DOCUMENT NUMBER-DATE

06214 MAY 17 2000

FPSC-RECORDS/REPORTING

EXHIBIT NO. \_\_\_\_\_

Docket No: 990325-EI

Party: Gulf Power Company

Description: COMPOSITE EXHIBIT

- (1) Gulf's Response to Staff Interrogatory Nos. 1-2, 4, 8, 16-25, 27, 32-35
- (2) Gulf's Response to Staff Request for Production of Documents Nos. 17-19, 21c
- (3) Late-filed Exhibit #3 from Deposition of William Pope
- (4) Summary of Late-filed Exhibit #4 from Deposition of William Pope
- (5) Transcript from Deposition of William Pope
- (6) Transcript from Deposition of Maria Burke
- (7) Transcript from Deposition of Michael Marler

Proffered By: Commission Staff

FLORIDA PUBLIC SERVICE COMMISSION  
DOCKET  
NO. 990325-EI EXHIBIT NO. 7  
COMPANY  
WITNESSED BY FPSC Staff  
DATE 6-7-99

STAFF COMPOSITE EXHIBIT  
TABLE OF CONTENTS

**Gulf Power Company's Response to Staff Interrogatories**

Interrogatory #1 (Non-confidential portion) . . . . .	1
Interrogatory #2 . . . . .	6
Interrogatory #4 . . . . .	8
Interrogatory #8 . . . . .	12
Interrogatory #16 . . . . .	13
Interrogatory #17 (Non-confidential portion) . . . . .	14
Interrogatory #18 . . . . .	15
Interrogatory #19 . . . . .	16
Interrogatory #20 . . . . .	18
Interrogatory #21 . . . . .	19
Interrogatory #22 . . . . .	20
Interrogatory #23 . . . . .	21
Interrogatory #24 . . . . .	22
Interrogatory #25 . . . . .	24
Interrogatory #27 . . . . .	25
Interrogatory #32 . . . . .	28
Interrogatory #33 . . . . .	29
Interrogatory #34 . . . . .	30
Interrogatory #35 . . . . .	31

**Gulf Power Company's Response to Staff Request for Production of Documents**

POD #17 . . . . . 33  
POD #18 . . . . . 36  
POD #19 . . . . . 39  
POD #21c . . . . . 44

**Late-filed Deposition Exhibits**

Late-filed Exhibit #3 from Deposition of William Pope . . . . 115  
(Non-confidential) Summary of Late-filed Exhibit #4 from  
Deposition of William Pope . . . . . 116

**Deposition Transcripts**

Transcript from Deposition of William Pope (73 pages) . . . . 119  
Transcript from Deposition of Maria Burke (39 pages) . . . . 192  
Transcript from Deposition of Michael Marler (28 pages) . . . 231

CONFIDENTIAL

FLORIDA PUBLIC SERVICE COMMISSION

DOCKET

NO. 990325-EI EXHIBIT NO. 8

COMPANY/

WITNESS: FPSC Staff

DATE

6-7-99

**CONFIDENTIAL**

**REDACTED**

**EXHIBIT NO.** \_\_\_\_\_

8

**Docket No:** 990325-EI

**Party:** Gulf Power Company

**Description:** COMPOSITE EXHIBIT

- (1) Gulf's **CONFIDENTIAL** Response to Staff Interrogatory Nos. 1 & 17
- (2) **CONFIDENTIAL** Late-filed Exhibit Nos. 1, 2, and 4 from Deposition of William Pope

**Proffered By:** Commission Staff

STAFF COMPOSITE EXHIBIT  
TABLE OF CONTENTS

<b><u>CONFIDENTIAL</u></b> Gulf's Response to Staff Interrogatory #1 . . . . .	1
<b><u>CONFIDENTIAL</u></b> Gulf's Response to Staff Interrogatory #17 . . . . .	14
<b><u>CONFIDENTIAL</u></b> Late-filed Exhibit #1 from Deposition of William Pope (61 pages) . . . . .	22
<b><u>CONFIDENTIAL</u></b> Late-filed Exhibit #2 from Deposition of William Pope (7 pages) . . . . .	83
<b><u>CONFIDENTIAL</u></b> Late-filed Exhibit #4 from Deposition of William Pope (11 pages) . . . . .	90

## Gulf Power Company

### RFP Initial Screening Results

Summer Rating MW	Proposal	Location	NPV Total Cost \$/kW (2002\$)
500	Combined Cycle	Holmes County, FL	273.8
486	Combustion Turbine	Holmes County, FL	332.1
350	Family of Cogeneration Facilities	Mobile, AL and Santa Rosa County, FL	432.3
532	Combined Cycle	Hardee County, FL	565.2

FLORIDA PUBLIC SERVICE COMMISSION

DOCKET

NO. 990325-EI EXHIBIT NO. 9

COMPANY/

WITNESS: Burke

DATE: 6-7-99

## **Gulf Power Company**

### **RFP Relative Ranking – Detailed Evaluation**

<b>Rank</b>	<b>MW</b>	<b>Bidder</b>	<b>NPV Total Cost \$/kW (2002\$)</b>
1	540	Smith Unit 3	279
2	486	Respondent B CT (20 Year Pricing)	496
3	500	Respondent B CC (10 Year Pricing)	505
4	532	Respondent C	511
5	500	Respondent B CC (7 Year Pricing)	522
6	486	Respondent B CT (10 Year Pricing)	527
7	486	Respondent B CT (7 Year Pricing)	539
8	500	Respondent B CC (20 Year Pricing)	553
9	350	Respondent A	592
10	532	Respondent C (Fixed Energy)	616

Florida Public Service  
 Commission  
 Docket No. 990325-EI  
 Gulf Power Company  
 Witness: Maria Jeffers Burke  
 Exhibit No. 10 ( MJB-3)  
 Schedule 3

## Gulf Power Company

### RFP Relative Ranking – Detailed Evaluation

Rank	MW	Bidder	NPV Total Cost \$/kW (2002\$)
1	540	Smith Unit 3	274
2	486	Respondent B CT (20 Year Pricing)	496
3	500	Respondent B CC (10 Year Pricing)	505
4	532	Respondent C	511
5	500	Respondent B CC (7 Year Pricing)	522
6	486	Respondent B CT (10 Year Pricing)	527
7	486	Respondent B CT (7 Year Pricing)	539
8	500	Respondent B CC (20 Year Pricing)	553
9	350	Respondent A	592
10	532	Respondent C (Fixed Energy)	616

FLORIDA PUBLIC SERVICE COMMISSION  
 DOCKET  
 NO. 990325-EI EXHIBIT NO. 10  
 COMPANY/  
 WITNESS: Burke  
 DATE: 6-7-99

DOCUMENT NUMBER-DATE

06215 MAY 17 99

FPSC-RECORDS/REPORTING

AFFIDAVIT

STATE OF ALABAMA        )  
                                  )  
COUNTY OF JEFFERSON    )

Docket No. 990325-EI

Before me the undersigned authority, personally appeared Maria Jeffers Burke, who being first duly sworn, deposes, and says that she is a Project Manager in the Generation Planning And Development of Southern Company Services, an Alabama corporation, that the foregoing is true and correct to the best of his knowledge, information, and belief. She is personally known to me.

Maria Jeffers Burke  
Maria Jeffers Burke  
Project Manager – SCS Generation Planning  
And Development

Sworn to and subscribed before me this 13<sup>th</sup> day of

May, 1999.

Priscilla K. Daly  
Notary Public, State of Alabama at Large

NOTARY PUBLIC STATE OF ALABAMA AT LARGE.  
MY COMMISSION EXPIRES: Feb. 7, 2001.  
BOUNDED THRU NOTARY PUBLIC UNDERWRITERS.

1  
2  
3  
4  
5  
6  
7  
8  
9  
10  
11  
12  
13  
14  
15  
16  
17  
18  
19  
20  
21  
22  
23  
24  
25

## REPORTER'S DEPOSITION CERTIFICATE

STATE OF FLORIDA     )  
COUNTY OF LEON     )

I, NANCY S. METZKE, Certified Shorthand Reporter and Registered Professional Reporter, certify that I was authorized to and did stenographically report the deposition of MICHAEL J. MARLER; that a review of the transcript was requested; and that the transcript is a true and complete record of my stenographic notes.

I FURTHER CERTIFY that I am not a relative, employee, attorney or counsel of any of the parties, nor am I a relative or employee of any of the parties' attorney or counsel connected with the action, nor am I financially interested in the action:

DATED this 11th day of May, 1998.

  
\_\_\_\_\_  
NANCY S. METZKE, RPR, CCR

CERTIFICATE OF DEPONENT

1  
2  
3  
4  
5  
6  
7  
8  
9  
10  
11  
12  
13  
14  
15  
16  
17  
18  
19  
20  
21  
22  
23  
24  
25

This is to certify that I, MICHAEL J. MARLER, have read the foregoing transcription of my testimony, Page 1 through 24, given on May 11, 1999, in Docket Number 990325-EI, and find the same to be true and correct, with the exceptions, and/or corrections, if any, as shown on the errata sheet attached hereto.

\_\_\_\_\_  
MICHAEL J. MARLER

Sworn to and subscribed before me this \_\_\_\_\_ day of \_\_\_\_\_, 19\_\_\_\_

\_\_\_\_\_  
NOTARY PUBLIC  
State of \_\_\_\_\_  
My Commission Expires: \_\_\_\_\_

257

1 STATE OF FLORIDA )  
2 COUNTY OF LEON )

CERTIFICATE OF OATH

3  
4  
5  
6  
7  
8  
9  
10  
11  
12  
13  
14  
15  
16  
17  
18  
19  
20  
21  
22  
23  
24  
25

I, the undersigned authority, certify that  
MICHAEL J. MARLER personally appeared before me and  
was duly sworn.

WITNESS my hand and official seal this 11th day  
of May, 1999.

*Nancy S Metzke*  
\_\_\_\_\_  
NANCY S. METZKE  
Notary Public - State of Florida



Nancy S. Metzke  
MY COMMISSION # CC677518 EXPIRES  
September 13, 2001  
BONDED THRU TROY FAIR INSURANCE INC

ERRATA SHEET

DOCKET NUMBER 990325-EI  
MICHAEL J. MARLER  
MAY 11, 1999

- 1
- 2
- 3
- 4
- 5
- 6
- 7
- 8
- 9
- 10
- 11
- 12
- 13
- 14
- 15
- 16
- 17
- 18
- 19
- 20
- 21
- 22
- 23
- 24
- 25

1 don't want him to go out on a limb if it's something  
2 better left to her.

3 MS. JAYE: Okay. Certainly.

4 THE WITNESS: My experience with it has been  
5 strictly from an analysis of the load data and what  
6 type of demand response that we have seen actually  
7 occur, to the extent that I can expect those demand  
8 reductions to occur in the forecast period. Beyond  
9 that I can't speak.

10 MS. JAYE: We have no more questions.

11 MR. MELSON: No, I don't have any questions.

12 (WHEREUPON, THE DEPOSITION WAS CONCLUDED)

13

14

15

\* \* \* \*

16

17

18

19

20

21

22

23

24

25

1 same time period in the summer peak demand table.

2 Q Okay. Looking then at Footnote 2 on Table B-15,  
3 it appears that Gulf treats interruptable as a supply side  
4 resource. Is this also true of the Southern System?

5 A Yes, I believe so. I am not familiar with that  
6 though because I don't get involved in that aspect of the  
7 Southern System modeling. I develop the territorial load  
8 forecast and provide that to the system planners, and I  
9 also provide them with our interruptable amounts, and I  
10 identify that as not embedded in the demand side load  
11 forecast.

12 Q Okay.

13 A So that they can handle it appropriately.

14 Q Remaining with Table B-15 for a moment, Column 7,  
15 where it speaks of residential conservation. Is the  
16 GoodCents New Home conservation program represented there  
17 in Column 7?

18 A Yes.

19 Q Okay. Could you summarize Gulf's experience with  
20 the experimental real-time pricing pilot program?

21 MR. MELSON: I don't know whether this is within  
22 the scope of his testimony or more properly in the  
23 scope of Ms. Naman's (phonetics). They filed joint  
24 testimony, and she really deals with conservation  
25 issues. To the extent he knows, that's fine; but I

1 energy forecasts under. Again, all of those individual  
2 resulting 87, 60 load shape projections are then summed  
3 together to build the total industrial demand forecast. A  
4 similar process occurs for wholesale, and all of these  
5 individual resulting load shapes are then summed together  
6 to model the total company, 87-, 60-hour demand forecast.

7 Q All right. I need to turn over to Tables B-15  
8 and B-16 which are also in the need study.

9 A Okay.

10 Q I was wondering if you could explain why the  
11 Column 1 for the summer peak and the winter peak report  
12 different reference years.

13 A Well, they actually don't. Column 1 begins in  
14 1989 and goes through 1998 on the summer peak, Table B-15.  
15 On the winter peak, Table B-16, the year is described as a  
16 dual number, '88-'89 through '97-'98. And, basically,  
17 that's because the actual winter peak period encompasses  
18 two different fiscal years. It begins in November and goes  
19 through March, and our actual winter peak demand is  
20 expected to occur in January typically.

21 So January of '89 would be the actual time in the  
22 forecast that the peak demand would occur in, and -- or  
23 generally '99 would be more appropriate, I guess. All the  
24 forecast years, January is the winter peak month. And so  
25 all of these years in this table actually do go for the

1 would be the outputs from the REEPS model which comprise  
2 the heating and air conditioning, energy consumptions,  
3 water heating, things of that nature. Each of those energy  
4 forecasts are modeled under the appropriate end-use load  
5 shape to develop an 87-, 60-hour load shape forecast that  
6 are all summed together within the residential model itself  
7 and result in an 87-, 60-hour per year residential load  
8 forecast.

9           Similarly, the commercial demand forecast is  
10 developed feeding it all of the individual demand output  
11 energy projections for all of the building types, and  
12 within each building type the end-use consumptions for  
13 heating, air conditioning, cooking, water heating, et  
14 cetera. Each of those energy projections is modeled under  
15 its appropriate load shape, and the load shapes are then  
16 summed to build a total commercial demand forecast.

17           Within the industrial sector, each of the  
18 individual hand-build industrial customers are modeled in  
19 the energy forecast separately. Those energy projections  
20 are individually modeled where load data is available for  
21 the specific customers. Some of them are grouped into like  
22 categories, such as the oil and gas, or some of the more  
23 general military accounts possibly. And so in the  
24 industrial sector there's a lot of intensive individual  
25 load shape data that's utilized to model specific customer

1 categories that we have identified here. Things like dry  
2 cleaners.

3 Q What economic factors would explain the increase  
4 of "miscellaneous" over the forecast period?

5 A Again, it would be the growth in commercial  
6 services to meet the needs of the growing population. All  
7 of that is part of the interactive model developed by RFA  
8 that encompasses the growth in residential population,  
9 commercial, building floor stock, as well as the industrial  
10 shipments in the industrial sector, and falls out, again,  
11 as part of the calibration process.

12 Q The next set of questions, we'll turn back to the  
13 need study itself. The first questions come from Page 94  
14 of the study.

15 A Okay.

16 Q Does the hourly electric load model, or HELM,  
17 generate peak demand forecast using a neural network  
18 architecture?

19 A No, it does not.

20 Q How does it then develop the peak forecast?

21 A The HELM model uses load research, load shape  
22 data for all of the end uses that are modeled within our  
23 different long-term modeling. For instance, in the  
24 residential sector, the residential load shape would be  
25 developed in HELM by feeding it -- or the inputs to it

1 to staff's Request for Production Number 7. I apologize.  
2 I'll give you a chance to turn there.

3 (WITNESS REVIEWED DOCUMENTS)

4 Q The question was what economic factors explain  
5 the increase of "other" over the forecast period?

6 A "Other" would be capturing the long-term economic  
7 indicators such as income growth, population growth, the  
8 basic increases in the base load usage patterns in the  
9 residential sector. The model development part of it goes  
10 through a calibration process, and the assumption portions  
11 that are not explainable in each of the other end uses is  
12 left in the "other" term. And so part of the driver is  
13 population, and the remaining drivers would be the economic  
14 indicators.

15 Q Turning now to the commercial electric sales  
16 forecast in that same request for production. Do electric  
17 sales to Pensacola NAS come under the heading of "offices?"

18 A No, our military sector is actually in the  
19 industrial forecast.

20 Q Okay. And looking again on the commercial page,  
21 what comes under the category of "miscellaneous?"

22 A "Miscellaneous" would cover a lot of the small  
23 commercial businesses such as gas stations, possibly.  
24 Right off the top of my head I'm having difficulty thinking  
25 of those, but it would not fall in these measured

1 request, we'll honor it.

2 MS. JAYE: We'll just title this one parameter  
3 coefficients. Is that good enough? Okay. And I  
4 understand if there's some kind of a proprietary  
5 problem with EPRI and they cannot, you know, release  
6 that or whatever, just get back with us and we'll go  
7 from there.

8 MR. MELSON: Okay.

9 BY MS. JAYE (Continuing):

10 Q Does the forecast for air conditioning end-use  
11 sales represent a composite figure for both central air and  
12 wall units?

13 A Yes.

14 Q Okay. I was wondering if you could explain what  
15 comes under the category of "other" in the end-use sales  
16 forecast.

17 A "Other" would be the all-encompassing variables  
18 that capture all of the non-specifically modeled end uses,  
19 things like clock radios, all the other electrical loads  
20 within a residential that's non-heating and cooling,  
21 non-cooking, non-water heating type loads. It's basically  
22 the base load energy usage of a home. ✓

23 Q Okay. Do you know what economic factors explain  
24 the increase of "other" over the forecast period? This is  
25 the information that was provided, I believe, in response

1 other words, a cooking load, for instance, would also cause  
2 additional cooling to take place and things of that nature,  
3 and these coefficients are from a nationally developed  
4 model that's provided by EPRI.

5 Q Would it be possible to get a late-filed  
6 deposition exhibit which gives these coefficients?

7 A I believe so. I'm not positive. I don't have  
8 direct access to those coefficients, but I can look and  
9 see, so subject to check.

10 MR. MELSON: Yeah, do you know whether -- and I  
11 don't know whether EPRI regards any of those as  
12 proprietary since they are interpreting the model.

13 THE WITNESS: I don't know either.

14 MR. MELSON: Why don't we identify it and we'll  
15 check, and if we can get them for you, we will; and if  
16 there's a reason that we either cannot get them from  
17 EPRI or there's a confidentiality concern, we'll give  
18 that to you as a response.

19 MS. JAYE: Okay.

20 MR. MELSON: Tell me again exactly what it is you  
21 want so I --

22 MS. JAYE: The parameter coefficients which were  
23 used for the multinomial logit appliance model.

24 MR. MELSON: Since half those words don't make  
25 any sense to me, if my witness understands the

1 body heat and change the energy response equation  
2 slightly. The breakpoints, for instance, in commercial on  
3 heating degree hours and cooling degree hours for Gulf are  
4 54 degree and 62 degrees as compared to the residential  
5 breakpoints of 65 and 70. That indicates that because of  
6 the body heat heating energy is not required in commercial  
7 buildings until you reach a much lower temperature than in  
8 a residential building. Similarly on cooling, because of  
9 the body heat, cooling energy is required much sooner than  
10 it would be in the residential sector.

11 Q Okay. Now we are going to go back to the need  
12 study. Turn to Page 87, if you will, please. I've got a  
13 couple of questions about this.

14 A Okay.

15 Q On Page 87, the need petition references a  
16 multinomial logit appliance model. Where in the petition  
17 are the model's parameter coefficients?

18 A The parameter coefficients for the model, these  
19 are developed by EPRI and are internal to the REEPS model.  
20 I don't have available to me the coefficients for the end  
21 use parameters specifically. The multinomial logit is a  
22 term to describe the interaction between each of the  
23 equations within the REEPS model, each of which tries to  
24 describe different end-use energy consumption and capture  
25 the interaction between these end-use energy variables. In

1 dummy variables are merely picking up a little bit of an  
2 extra component that I guess can be considered similarly to  
3 a partial constant term during those months.

4 Q Turning now over to the commercial short-term  
5 energy model of the coefficients. I was wondering if you  
6 could provide an econometric interpretation of the  
7 coefficients for commercial heating degree days, commercial  
8 cooling degree days, commercial price in this model.

9 A Again, these are heating degree hours per billing  
10 day and cooling degree hours per billing day.

11 Interpretation of the coefficients, the heating degree  
12 hours and cooling degree hours, as you can see, the sign on  
13 the coefficient is positive. This is an indication of the  
14 amount of additional energy sales that occur in that sector  
15 due to heating degree hours or cooling degree hours. The  
16 sign on the price term is negative, and this also indicates  
17 that as price increases the energy sales for that sector  
18 would decrease.

19 In this case the signs in front of the monthly  
20 dummy variables are negative for January, May, November,  
21 December, which are the only statistically significant  
22 monthly dummy variables that were available to the model.  
23 In commercial, the energy consumption characteristics are  
24 somewhat different from residential in that there's a lot  
25 of people, bodies in commercial buildings that contribute

1 price?

2 A Could you please restate that?

3 Q Yes. There's a coefficient for the residential  
4 price, and I was wondering if the dummy variable tracks  
5 that in any way, if there is a relationship between the  
6 two.

7 A Well, all of the variables are interrelated  
8 because they all are trying to explain part of the  
9 variability in the data. Each of these monthly dummy  
10 variables is merely picking up a component of the energy  
11 consumption pattern that is above and beyond those that  
12 fall out normally through the heating and cooling degree  
13 hour variables and the price variables, meaning that, for  
14 instance, in January there's some extra energy consumption  
15 that takes place above and beyond that which is explained  
16 in, say, a more shoulder month as a result of a heating  
17 degree hour. That shoulder month being a month in  
18 transition from mild weather period, just beginning into  
19 the heating season where customers will be less likely to  
20 immediately turn on their heat in response to a particular  
21 temperature. Whereas, in January, they're more apt to  
22 already have their heating system on, and the electricity  
23 consumption for that same temperature would show up a  
24 little more intense than in the other months. Similarly,  
25 this happens in the summer months, and so these monthly

1 heating degree hours, meaning that all of the hours in  
2 which the temperature is below 65 degrees is designated as  
3 a heating hour. And for cooling, Gulf uses a 70-degree  
4 breakpoint, meaning that all the hours in which the actual  
5 temperature is above 70 degrees is assumed to be a cooling  
6 hour with a dead band area between 65 and 70 in which  
7 neither heating nor cooling takes place.

8 Gulf transformed the heating degree hours and  
9 cooling degree hours to a per billing day basis to make a  
10 better fit with the model and put it on the same terms with  
11 the actual dependent variable, which is residential billed  
12 energy sales per billing day. The price variable shown  
13 here is a 12-month rolling average of real price for the  
14 residential sector.

15 Q Could you explain the economic rationale for  
16 including the six monthly dummy variables in this table?

17 A In development of my models, I look at all of the  
18 monthly dummy variables that are available in the software  
19 package. I include or leave in only those that offer  
20 statistically significant explanatory capabilities. In  
21 this case, January, June, July, August, September, and  
22 October were the only variables that remained in the  
23 model.

24 Q Okay. So Mr. Marler, would you say then that the  
25 dummy variable follows the coefficient on residential

1 Q So, Mr. Marler, in your opinion, income of the  
2 customer would have no explanatory effect or impact on  
3 sales of electricity?

4 A I can't answer its impact on the modeling  
5 capability. I just know that I've got over 98% of the  
6 variability explained with price and weather variables and  
7 don't -- I have never experimented with the income figures  
8 to see if it would add explanation enough.

9 Q Okay. I've got a few questions about the  
10 residential heating degree days and cooling degree days  
11 now. There's a page further on over in the same POD.

12 A Okay.

13 Q Could you provide an economic interpretation for  
14 the regression coefficients residential heating degree days  
15 and the residential cooling degree days, residential price  
16 and the residential short-term model that was provided?

17 A Yes, the variables that you see here, we actually  
18 use heating degree hours per billing day and cooling degree  
19 hours per billing day. These are defined as the results  
20 from analysis of actual hourly weather on a monthly basis  
21 looking at the 21 billing cycles that Gulf uses when it  
22 reads the meters, and the average number of billing days  
23 for those 21 cycles is divided into the total heating  
24 degree hours or cooling degree hours that result in that  
25 month. Gulf uses a 65-degree reference temperature for

1 take place outside of the areas in which we actually  
2 provide service. Currently we still have some growth  
3 taking place in northern Escambia County, but beyond the  
4 mid to -- and into the long-term range, most of that growth  
5 starts taking place outside of the areas where we actually  
6 provide service.

7 Q The next series of questions comes from Gulf's  
8 response to the staff Request for Production of Documents  
9 Number 7. I'll give you a chance to turn there.

10 (WITNESS REVIEWS DOCUMENTS)

11 A Okay.

12 Q These questions have to do with the residential  
13 short-term energy model. I believe it's one of those pages  
14 that's appended.

15 A Okay.

16 Q In this particular model, the reported  
17 coefficients exclude an income variable. I'd like to  
18 understand why that variable was excluded.

19 A Well, the variable itself didn't -- I have  
20 never actually used it in the past. I was able to explain  
21 virtually all the model variance with price and weather  
22 variables, and the price response pretty much captures the  
23 ability of the customers to -- or willingness to pay a  
24 certain amount for electricity, and so I've never used an  
25 income variable because it wasn't necessary.

1           A       Well, the purpose of the end-of-year data that's  
2 used by our district marketing personnel is primarily for  
3 development of the short-term customer projections, and we  
4 develop those by projecting first the annual expected  
5 customer additions, which is what we call gains; and the  
6 total number of customers in the projection can be built by  
7 adding those gains to the most recent actual annual number  
8 of customers. Those figures that we end up with are  
9 monthly number of customers from which you can calculate  
10 annual average number of customers or any other kind of  
11 customer statistics you're interested in.

12                   The long-term models use annual average customers  
13 in their energy projection because they're an annual model  
14 basis; whereas, my short-term models are monthly models and  
15 require monthly number of customers.

16           Q       If you would turn to the sheet provided with the  
17 response to staff's Request for Production Number 6. It's  
18 the title "Gulf B99 Long-term Customers" at the very top.  
19 The sheet looks like this (indicates).

20           A       Okay.

21           Q       Could you explain why the forecast ratio for  
22 Gulf-served residential customers to service area  
23 households, which is Column 5, declines after 2005?

24           A       This is a reflection of Gulf's assumption that  
25 the majority of the long-term customer growth is going to

1 reference is made to the Gulf economic model. I was  
2 wondering if you could summarize some of the basic  
3 equations used in this model and perhaps briefly discuss  
4 how frequently these forecasts are updated.

5 A My knowledge of this model is essentially similar  
6 to what I mentioned previously as we were discussing the  
7 previous tables. RFA, Regional Financial Associates, is  
8 our economic services provider and they model the  
9 Gulf-specific service area. They have two different  
10 methods. One models our internal economy, the businesses,  
11 industry, internal population growth; and it also models a  
12 competitive model with the reason surrounding our service  
13 area that takes into account the in-migration and  
14 out-migration of business and industrial goods and things  
15 of that nature. The two together comprise our total  
16 economic forecast, and they update this information  
17 annually.

18 Q I have a few questions now on Gulf's response to  
19 the staff's Request for Production of Documents Number 6.  
20 I'll give you a minute to turn there.

21 (WITNESS REVIEWED DOCUMENTS)

22 Q My first question is more or less just for my own  
23 education. Could you please explain why the residential  
24 and commercial customer projections use the end-of-year  
25 data as opposed to an annual average?

1 the annual population -- average annual population growth.  
2 Is this a weighted average for all eight Florida counties  
3 in Gulf's service territory, or just the three most  
4 populous ones?

5 A This would be all eight counties, and the average  
6 is for the ten-year period stated in the title there.

7 Q We do have a question about some of the  
8 information on Table 4-2. What is the average employment  
9 growth for Gulf Service territory from the years 1998 to  
10 2008?

11 A The average employment growth?

12 Q Yes, sir.

13 A I would believe -- I believe that would be  
14 equivalent to the labor force growth figure. *error*

15 Q Okay.

16 A Of 1.5%.

17 Q So the labor force growth would mirror the actual  
18 numbers of jobs and employment that would be available?

19 A Yes, I believe that's correct. *error*

20 Q Okay. So numbers of workers would equal numbers  
21 of jobs?

22 A Yes, I believe so. I'm not directly involved in  
23 development of RFA's forecast, but this is one of their  
24 indicators that comes out of their economic projections.

25 Q Turning now to Page 29 of the need study. A

1 forecast are the base rate prices from the previous year's  
2 budget forecast as contained in the financial model files.  
3 They are the results of the previous forecasts.  
4 Additionally, they contain the adders, such as fuel  
5 purchase power capacity cost, ECR, and ECCR adders that are  
6 from the most recent Southern Company Services fuel panel.

7 Q Mr. Marler, looking at the tables on Page 28,  
8 I've got a couple of questions. On Table 4-1 of the need  
9 petition, it looks as if one of the economic assumptions  
10 cited is the GDP growth, and my question is why wasn't  
11 consideration made for the gross state products? Because  
12 the two figures can differ.

13 A Well, these indicators in this table are national  
14 indicators, and they're just meant to be a summary of the  
15 overall economic outlook. The gross state product comes  
16 into play in RFA's economic forecast development. They  
17 model Gulf-specific service area, and their model is  
18 comprised of two modeling techniques. One looks at our  
19 in-service economy -- our in-service area economy and the  
20 expected growth within our in-service businesses, and the  
21 other modeling technique looks at the surrounding areas and  
22 models the competition with the surrounding areas; and  
23 that's how they develop their in-migration and  
24 out-migration estimates.

25 Q Looking at Table 4-2 now, I have a question about

1 Whereupon,

2 MICHAEL J. MARLER

3 was called as a witness by the FPSC Staff and, after being  
4 first duly sworn, was examined and testified as follows:

5 DIRECT EXAMINATION

6 BY MS. JAYE:

7 Q Nancy, would you please insert all the usual  
8 stipulations? Thank you.

9 Good morning, Mr. Marler.

10 A Good morning.

11 Q I have a few questions to ask you just as  
12 background. How long have you been with Gulf?

13 A I joined Gulf Power in January of 1982.

14 Q Okay. What positions have you held with the  
15 company?

16 A I began in the load research section as a load  
17 research engineer, and I transferred to the forecasting  
18 section in 1988, and I've been in forecasting since then.

19 Q Okay. We'll jump right in here, and I ask you to  
20 turn to Page 27 of the need study, the very last sentence  
21 which carries over to Page 28. The study here makes  
22 reference to Gulf's recent electric price assumptions.  
23 Could you explain what these assumptions are about electric  
24 price?

25 A The major components of the electric price

INDEX OF EXHIBITS

1  
2  
3  
4  
5  
6  
7  
8  
9  
10  
11  
12  
13  
14  
15  
16  
17  
18  
19  
20  
21  
22  
23  
24  
25

NUMBER	PAGE NO.
#1 (Late-filed) Parameter coefficients . . . . .	18

235

INDEX

1  
2  
3  
4  
5  
6  
7  
8  
9  
10  
11  
12  
13  
14  
15  
16  
17  
18  
19  
20  
21  
22  
23  
24  
25

PAGE NO.

STIPULATION . . . . .	3
ERRATA SHEET . . . . .	25
CERTIFICATE OF OATH . . . . .	26
CERTIFICATE OF DEPONENT . . . . .	27
CERTIFICATE OF REPORTER . . . . .	28
Examination by Ms. Jaye . . . . .	6

STIPULATION

1  
2  
3  
4  
5  
6  
7  
8  
9  
10  
11  
12  
13  
14  
15  
16  
17  
18  
19  
20  
21  
22  
23  
24  
25

IT IS STIPULATED that this deposition was taken pursuant to notice in accordance with the applicable Florida Rules of Civil Procedure; that objections, except as to the form of the question, are reserved until hearing in this cause; and that reading and signing was not waived.

IT IS ALSO STIPULATED that any off-the-record conversations are with the consent of the deponent.

1  
2  
3  
4  
5  
6  
7  
8  
9  
10  
11  
12  
13  
14  
15  
16  
17  
18  
19  
20  
21  
22  
23  
24  
25

APPEARANCES:

GRACE A. JAYE, ESQUIRE, FPSC, 2540 Shumard Oak  
Boulevard, Suite 370, Tallahassee, Florida 32399-0850.

RICHARD D. MELSON, ESQUIRE, Gulf Power, Hopping,  
Green, Sams & Smith, 123 South Calhoun Street, Tallahassee,  
Florida 32301.

JEFFREY STONE, ESQUIRE, Gulf Power, Post Office Box  
12950, Pensacola, Florida 32576.

ALSO PRESENT:

- MICHAEL HAFF, FPSC Staff.
- BILL DICKENS, FPSC Staff.
- LEE COLSON, FPSC Staff.
- TODD BOHRMAN, FPSC Staff.
- ROBERT MOORE, Gulf Power.
- MARIA JEFFERS BURKE, Gulf Power.
- ELAINE KWARCINSKI, Gulf Power.

\* \* \* \*

1  
2  
3  
4  
5  
6  
7  
8  
9  
10  
11  
12  
13  
14  
15  
16  
17  
18  
19  
20  
21  
22  
23  
24  
25

BEFORE THE FLORIDA PUBLIC SERVICE COMMISSION

In Re: Petition of Gulf Power Company ) DOCKET NO.990325-EI  
to determine need for proposed )  
electrical power plant in Bay County )

DEPOSITION OF: MICHAEL J. MARLER  
  
TAKEN AT THE  
INSTANCE OF: FPSC Staff  
  
DATE: Tuesday, May 11, 1999  
  
TIME: Commenced at 9:00 a.m.  
Concluded at 9:50 a.m.  
  
PLACE: FPSC  
2540 Shumard Oak Boulevard  
Room 362  
Tallahassee, Florida  
  
REPORTED BY: NANCY S. METZKE, RPR, CCR

C & N REPORTERS  
REGISTERED PROFESSIONAL REPORTERS  
POST OFFICE BOX 3093  
TALLAHASSEE, FLORIDA 32315-3093  
(850)697-8314 / FAX (850)697-8715  
BUREAU OF REPORTING

RECEIVED 5-20-99

231

## 1 REPORTER'S DEPOSITION CERTIFICATE

2 STATE OF FLORIDA )  
3 COUNTY OF LEON )4  
5 I, NANCY S. METZKE, Certified Shorthand Reporter  
6 and Registered Professional Reporter, certify that I was  
7 authorized to and did stenographically report the  
8 deposition of MARIA JEFFERS BURKE; that a review of the  
9 transcript was requested; and that the transcript is a true  
10 and complete record of my stenographic notes.11  
12 I FURTHER CERTIFY that I am not a relative,  
13 employee, attorney or counsel of any of the parties, nor am  
14 I a relative or employee of any of the parties' attorney or  
15 counsel connected with the action, nor am I financially  
16 interested in the action.17  
18 DATED this 14th day of May, 1999.19  
20  
21   
22 NANCY S. METZKE, RPR, CCR

CERTIFICATE OF DEPONENT

1  
2  
3  
4  
5  
6  
7  
8  
9  
10  
11  
12  
13  
14  
15  
16  
17  
18  
19  
20  
21  
22  
23  
24  
25

This is to certify that I, MARIA JEFFERS BURKE, have read the foregoing transcription of my testimony, Page 1 through 35, given on May 11, 1999, in Docket Number 990325-EI, and find the same to be true and correct, with the exceptions, and/or corrections, if any, as shown on the errata sheet attached hereto.

\_\_\_\_\_  
MARIA JEFFERS BURKE

Sworn to and subscribed before me this \_\_\_\_\_ day of \_\_\_\_\_, 19\_\_\_\_

\_\_\_\_\_  
NOTARY PUBLIC  
State of \_\_\_\_\_  
My Commission Expires:

1  
2  
3  
4  
5  
6  
7  
8  
9  
10  
11  
12  
13  
14  
15  
16  
17  
18  
19  
20  
21  
22  
23  
24  
25

STATE OF FLORIDA )  
                          :  
COUNTY OF LEON    )

CERTIFICATE OF OATH

I, the undersigned authority, certify that  
MARIA JEFFERS BURKE personally appeared before me and  
was duly sworn.

WITNESS my hand and official seal this 14th day  
of May, 1999.

*Nancy S. Metzke*  
\_\_\_\_\_  
NANCY S. METZKE  
Notary Public - State of Florida



Nancy S. Metzke  
MY COMMISSION # CC677518 EXPIRES  
September 13, 2001  
BONDED THRU TROY FAIN INSURANCE, INC.

ERRATA SHEET

DOCKET NUMBER 990325-EI  
MARIA JEFFERS BURKE  
MAY 11, 1999

- 1
- 2
- 3
- 4
- 5
- 6
- 7
- 8
- 9
- 10
- 11
- 12
- 13
- 14
- 15
- 16
- 17
- 18
- 19
- 20
- 21
- 22
- 23
- 24
- 25

1  
2  
3  
4  
5  
6  
7  
8  
9  
10  
11  
12  
13  
14  
15  
16  
17  
18  
19  
20  
21  
22  
23  
24  
25

2, I think.

MS. JAYE: Two is what I have.

MR. MELSON: And that's the Southern IRP material.

MS. JAYE: Right. Okay. Well, that's all the questions I have. Thank you so much.

MR. MELSON: Thank you.

(WHEREUPON, THE DEPOSITION WAS CONCLUDED)

\* \* \* \*

1 have to go back and study it further to give you, you know,  
2 any better answer than that, but that's my suspicion.

3 Q What is that reserve margin target where PROVIEW  
4 allowed the generic unit?

5 A It's 13.5.

6 Q All right. Going back to the answer to POD 2 on  
7 Page 1 of 1 --

8 MR. MELSON: Interrogatory 2?

9 MS. JAYE: I'm sorry, yes.

10 BY MS. JAYE (Continuing):

11 Q I was wondering if the number of units and the  
12 number of megawatts that are used in the base case are a  
13 result of the Southern Company IRP?

14 A In general, it is for the Gulf expansion, for the  
15 Gulf analysis. Gulf had a re-powering, I believe, of Plant  
16 Crist further out in the expansion plan because that was a  
17 decision that I felt like the company had not made for  
18 certain what the date was, what the time was, a commitment  
19 to those resources. For this analysis we removed that  
20 uncertainty from the case, and so our case would differ  
21 from the IRP by that amount.

22 Q Staff had previously requested in request for  
23 Production 1 a copy of the IRP for Southern. I was  
24 wondering if we could get that again as a late-filed.

25 MR. MELSON: Sure. It will be Late-filed Number

1 number of CCs and CTs which will be added on to the  
2 Southern System?

3 A I'm not sure I understand the question.

4 MS. JAYE: We need to go off the record.

5 (DISCUSSION OFF THE RECORD)

6 MS. JAYE: Let's go back on the record.

7 BY MS. JAYE (Continuing):

8 Q We notice that in the Late-filed Deposition  
9 Exhibit 4 of Mr. Pope the Respondent B for each one of the  
10 different years, 7, 10 and 20, shows a delta that changes  
11 dramatically between year 4 and year 5 in the far  
12 right-hand column. We were wondering if there's a driver  
13 for that.

14 (WITNESS REVIEWED DOCUMENTS).

15 A It looks to me like that's an artifact of having  
16 an exact size unit in there because, if you look at the  
17 reserve margin, you can see that in that fifth year the  
18 reserve margin climbed as high as 14.2%, .21. You'll  
19 notice that that's the highest reserve margin with the  
20 exception of the first year that that case has, adding a  
21 lot of combined cycles; and using the 500 megawatts exact  
22 size of that alternative, PROVIEW case has a minimum  
23 reserve margin target. If it's below that minimum reserve  
24 margin target by even the slightest number of megawatts, it  
25 has to add another 300-megawatt slice size in there. I'd

1 load growth. Southern System gross approximately 700  
2 megawatts a year.

3 Q Are the numbers under the "Total Megawatts"  
4 column proprietary?

5 A They shouldn't be.

6 Q Okay.

7 MR. MELSON: I don't believe so.

8 MS. JAYE: Okay.

9 BY MS. JAYE (Continuing):

10 Q I'd like for you to look at the number for 2020  
11 and compare that to the one in 2021. That's quite a jump.  
12 I was wondering if there was a particular reason. And, in  
13 general, why they're so much larger than what we see in the  
14 earlier stages of the evaluation at the top where you see  
15 2003 and 2004, relatively small numbers.

16 A In the event that you have -- and I imagine that  
17 in the model that there's some unit retirements such as  
18 happened in 2021 that requires some additional unit  
19 additions. You'll probably notice that in other  
20 alternatives that same amount of megawatts is added in each  
21 case, so I believe that's something that's just inherent in  
22 the base case itself. A resources change is happening, and  
23 I would imagine that out that far it's probably some unit  
24 retirement assumptions.

25 Q Does every 300 megawatts correspond to the actual

1 exhibit illustrating cost of each project in total dollars  
2 and wanted to know if you were the witness who performed  
3 the analysis compromising (sic) this exhibit.

4 A Yes, I created the numbers for Mr. Pope.

5 Q Okay. We've got some questions for you about  
6 this exhibit then since you're the one who did the numbers.

7 MR. MELSON: And this is Late-filed Exhibit 4 to  
8 Mr. Pope's deposition.

9 MS. JAYE: Yes.

10 BY MS. JAYE (Continuing):

11 Q The first question deals with the very first page  
12 of the exhibit where it says "20-year self-build" at the  
13 top. There's a column heading "Transmission Losses." Why  
14 are transmission losses only evaluated for ten years?

15 A That's just the way that they do the analysis.  
16 There's a lot of uncertainty in that analysis about what  
17 kinds of units are added to the system and specifically  
18 where they're added, a lot of the definitions. The clarity  
19 of that information is really lost after ten years, and  
20 transmission planning just performs that analysis to that  
21 extent.

22 Q Looking at the same page here, why do unit  
23 additions increase up to six times of the present rate by  
24 the year 2021? It's under the "Total Megawatts" heading.

25 A The most common reason for megawatt additions is

1 in the economic sense, when you have a limited resource  
2 like kilowatts or megawatts, it's not an inappropriate  
3 analysis to do the net present value across that limited  
4 resource.

5 Q Can total dollars associated with each project be  
6 estimated by multiplying the unit size of each project by  
7 the dollars per kilowatt values contained in Exhibit MJB-2  
8 of your testimony?

9 A That is, in fact, how we calculated the 90  
10 million dollars of savings. Where is my exhibit? It  
11 didn't make it in my package.

12 MR. MELSON: Just one minute.

13 (DOCUMENT TENDERED TO THE WITNESS)

14 A Yeah. That is exactly how we calculated the 90  
15 million dollars worth of savings that we showed in  
16 Interrogatory Number 14. Another approach could be to take  
17 the 279 and the 496 and use a 600-megawatt slice size just  
18 like we did in the production costing. To be on the  
19 conservative side, we used the size that was shown in that  
20 schedule and again in Table 8-2 of the need study.

21 Q Would the true savings then be actually greater  
22 than what is shown?

23 A I believe that the true savings could be higher  
24 than the 90 million.

25 Q Yesterday we asked Witness Pope for a late-filed

1 used instead of the size of the unit, for instance, 574  
2 megawatts?

3 A Although an analysis can be done with exact size  
4 units, it's very difficult to compare a base case, change  
5 case scenario because each one of those cases have a  
6 different number of megawatts that it's costing out. In  
7 the event that you had a 350-megawatt alternative that you  
8 were evaluating, my PROVIEW case would have added  
9 300-megawatt slice sizes all around it, and that unit would  
10 have suffered a disadvantage because it was that  
11 50-megawatt size. So we've tried to do what we can to make  
12 sure the analysis is non-biased by the size of the  
13 alternative that's being proposed but rather provides a  
14 relative value of the alternatives that we're ranking.

15 Q Could you explain why it's appropriate to portray  
16 a project's cost effectiveness in NPV per kilowatt rather  
17 than total dollars?

18 A One of our challenges, as we try to rank  
19 proposals, is to make sure that things like a size bias is  
20 not driving the answer. We really prefer to make sure that  
21 we are putting on -- adding a unit to the system that has  
22 the most value, so we always do the analysis. Most of the  
23 fixed costs are provided in dollars per kilowatt month, so  
24 we convert those to dollars per kilowatt year and provide a  
25 net present value on dollar per kilowatt basis. It really,

1 expansion plan will probably change in that first year or  
2 two to mostly CTs. Those are reflected in answer to  
3 Interrogatory Number 2, and they're shown -- they're  
4 included, the cost for those are included in each one of  
5 the alternative spread sheets that you're looking at in  
6 Interrogatory Number 1.

7 Q If you could, please, elaborate on the cause for  
8 the cost difference between the base case plan and the  
9 project specific plan?

10 A Depending on the proposal under evaluation at the  
11 time, the facilities actually dispatched into all of the  
12 resources available to the Southern Electric system, so it  
13 may actually displace some units that have a higher  
14 dispatch cost. The fuel cost is included in this proposal  
15 utility cost for the new unit as well as all of the  
16 existing units. Additionally, any variable O&M costs are  
17 calculated up, and the expansion plan cost is included in  
18 there as well.

19 Q Was a 600-megawatt block size used to calculate  
20 the energy savings column in this table?

21 A A 600-megawatt block size was used for all of the  
22 respondents and self-build alternative for this analysis to  
23 make sure that all projects were put and compared to the  
24 same exact base case.

25 Q Just for clarification, why was a 600-block size

1 response to Number 1?

2 A The answer to your question is yes, but the way  
3 that your question was phrased just concerns me a little.  
4 PROVIEW creates the expansion plan. We didn't put these  
5 expansion plans into PROVIEW. This is a result of the  
6 PROVIEW run.

7 Q Thank you for the clarification.

8 Do you know where on the Southern Company's  
9 system the generic unit additions that comprise the base  
10 case will be located?

11 A To create a base case scenario, we create some  
12 generic kind of central locations to the Southern Electric  
13 system type of sites. We usually do that really as a, I  
14 believe a central Alabama type location rather than a  
15 central Georgia.

16 Q Looking again at the response to Staff  
17 Interrogatory Number 1 -- I'm sorry, just a moment.

18 Okay. Start again. This is, again, the  
19 confidential response to Interrogatory 1. There is a  
20 column called "Proposal Utility Cost." How does the  
21 expansion plan differ from the base case plan?

22 A When a 600-megawatt slice size of the specific  
23 bid alternative is included in the PROVIEW case, we expect  
24 that the expansion plan will change through time. For  
25 example, if a respondent bid in a combined cycle, the

1           Q     The tables in Gulf's response to staff  
2 Interrogatory Number 1, which is the confidential  
3 information, refer to a base case plan. Do you know if  
4 this plan consists of generic capacity additions shown in  
5 Gulf's response to Staff Interrogatory Number 2?

6           A     I'm assuming by your question that you're talking  
7 about the PROVIEW base case that's shown in Column 6, base  
8 case utility cost and proposal utility cost.

9           Q     Yes, that's the one.

10          A     And, yes, there are generic unit additions that  
11 are included in that cost.

12          Q     Looking now at the Gulf response to staff  
13 Interrogatory Number 2, do the numbers in those columns  
14 refer to the number of CC and CT units to be added?

15          A     Yeah, these reflect the cumulative expansion plan  
16 additions as a result of these proposals being incorporated  
17 in our case.

18          Q     What is the size of these units?

19          A     Each one of the CTs and CCs reflected or shown in  
20 these columns represent a three hundred megawatt slice  
21 size.

22          Q     Is this the plan shown on the base case column,  
23 on the response to Interrogatory 2, what was run through  
24 PROVIEW to come up with the answer for base case utility  
25 costs and for proposal utility costs in the confidential

1 Losses, Accumulated Present Value." I think it's around  
2 Column 15. Did you perform any of the analyses of the cost  
3 of transmission losses shown in the column?

4 A No, just like the grid and connection costs,  
5 those were provided directly by Southern Company Services  
6 transmission planning.

7 Q Was it your role just to incorporate those costs  
8 then -- those transmission losses rather into the cost  
9 effective analysis?

10 A That's correct.

11 Q To your knowledge, has the analysis of the cost  
12 of transmission losses been provided to staff in any  
13 response to request for production of documents?

14 A I don't know that they have or haven't. I  
15 really --

16 Q Okay. My next question then would be do you know  
17 how the analysis of the cost of transmission losses would  
18 be calculated or be determined?

19 A Most likely Witness Pope would be a better person  
20 to help you with that.

21 Q Okay.

22 MS. JAYE: We need to go off the record for a  
23 minute.

24 (DISCUSSION OFF THE RECORD)

25 BY MS. JAYE (Continuing):

1 others -- the numbers for the other respondents, for the  
2 proposals that we evaluated were net of the Smith costs.

3 Q For instance then, turning over one page to the  
4 page that is simply labeled Respondent A, the number that  
5 appears in the transmission grid and connection column  
6 would be the difference between it and Plant Smith?

7 A Yes, that's correct.

8 Q Could you explain why the relative ranking was  
9 chosen over some absolute numbers or real numbers?

10 A Certainly. The real goal in evaluation of  
11 generation alternatives is to make sure that you're putting  
12 the best alternative on the ground, that you're  
13 recommending the best alternative, you know, be made  
14 available to customers. So your ultimate goal is to create  
15 a relative ranking so that you know which alternatives have  
16 more value and how much value they have over the other  
17 alternatives that are on your plate. So in this particular  
18 circumstance it really was not a problem in the event --  
19 because all the numbers were going to roll into a relative  
20 ranking table, the numbers would all change by whatever the  
21 amount of transmission grid and connection costs for Plant  
22 Smith that there were, so it did not change the relative  
23 ranking to put the numbers in with Smith as a zero.

24 Q Staying with the response to staff Interrogatory  
25 Number 1, there is a column which is labeled "Transmission

1 transmission, total cost, accumulative present value,  
2 dollars per kilowatt year column?

3 A Yes, that column would change.

4 Q Would it change for all of the RFP respondents as  
5 well as the self-build?

6 A It would change all of the RFP respondents by the  
7 same amount.

8 MS. JAYE: We need to take a minute and go off  
9 the record.

10 (DISCUSSION OFF THE RECORD)

11 BY MS. JAYE (Continuing):

12 Q In the generation and transmission total cost  
13 column, there is a number of 279.15 shown there. What is  
14 included in that number?

15 A That is what we call the net evaluated cost. It  
16 takes -- that's what we use for our relative ranking  
17 table. It shows how the total costs of Plant Smith rank  
18 relative to other alternatives.

19 Q What costs have been excluded from that number?

20 A In the column with the heading transmission grid,  
21 and connection, accumulated present value, dollar per  
22 kilowatt year, the numbers for Plant Smith appear as zeros.  
23 That's because the numbers that were provided by  
24 transmission were all provided relative to Plant Smith, so  
25 the numbers that are really zeros for Plant Smith and the

1 these calculations were done?

2 A Yes, I do.

3 Q Okay. Even though you say that you did not  
4 actually perform the analyses, was it your role to  
5 incorporate these transmission costs into the cost  
6 effectiveness analysis contained in Gulf's response to  
7 Staff Interrogatory 1?

8 A Yes.

9 Q Okay. Looking again at the column in question,  
10 does the column indicate the cost of transmission additions  
11 and upgrades associated with Smith Unit 3 in each RFP  
12 project?

13 A The costs are the relative costs and not the  
14 absolute dollar values. The numbers that were provided by  
15 transmission were netted basically by the cost of the Smith  
16 Unit 3.

17 Q Do you believe that it is appropriate to show  
18 transmission cost impact of Smith Unit 3 as zero if, in  
19 fact, there are costs involved?

20 A I think in the relative ranking it doesn't make a  
21 difference whether you include a capital cost in there for  
22 Smith and include that same capital cost for every other  
23 project. The relative ranking should be the same.

24 Q If the true costs were contained in this table,  
25 would that then change the answer on generation

1 three columns, the very first one that shows -- These  
2 numbers (indicates).

3 A Right.

4 Q Okay.

5 MR. MELSON: None of the column headings are  
6 proprietary, so if it makes it easier just to read the  
7 column headings, that's great.

8 MS. JAYE: Okay. Great then. And that would be  
9 the transmission grid and connection accumulated  
10 present value, dollars per kilowatt year.

11 BY MS. JAYE (Continuing):

12 Q Did you perform any analyses on the transmission  
13 costs shown in this column?

14 A The transmission numbers were provided directly  
15 by Southern Company Services transmission.

16 Q Do you know if the costs in the column were  
17 taken from Gulf's response to the staff Request for  
18 Production Number 2?

19 A In -- well --

20 MS. JAYE: Okay. We need to go off the record  
21 for a minute.

22 (DISCUSSION OFF THE RECORD).

23 MS. JAYE: Back on the record.

24 BY MS. JAYE (Continuing):

25 Q Ms. Burke, do you have an understanding of how

1 need to pay that fixed fuel transportation reservation up  
2 front, but you do pay for it when you use it; and,  
3 therefore, you have a higher fuel cost delivered to your  
4 site for CT than for CC.

5 Q I'd also like to compare information on  
6 Respondent B, CC, 20-year pricing sheet, to that for  
7 Respondent C. Again, we'll be looking at the far  
8 right-hand set of columns and the center of those columns.

9 A There are two Respondent C sheets. Are you  
10 looking at the one with the levelized energy price or the  
11 one that's just marked Respondent C?

12 Q The one just marked Respondent C.

13 A The difference in these two fuel pricing really  
14 relate to how the bidders bid in the fuel price that we  
15 would actually pay for the fuel at their facility.  
16 Respondent B bid a City Gate index, and Respondent C bid a  
17 Henry Hub plus 4%, so that the two different pricings are  
18 associated with the respondents themselves and what they  
19 proposed that the company would pay for fuel.

20 Q All right. Ms. Burke, the next set of questions  
21 are going to deal with transmission. Those are going to  
22 deal mainly with the transmission grid and connection  
23 accumulated present value costs which are to be found in  
24 confidential response to Staff Interrogatory 1. Looking at  
25 the table, it will be in the main table, the middle set of

1 commodity price of gas. In the self-build alternative,  
2 this particular supplier that responded to the fuel RFP  
3 provided a, almost a contract type of price for the  
4 commodity that was below what the Henry Hub type price  
5 would be. That's why those numbers are lower.

6 Q All right. We're now going to look at the  
7 confidential information that was identified in Gulf's  
8 response to Staff's Interrogatory 1. We'll be comparing  
9 fuel prices that appear on two different pages. One is  
10 Respondent B, CC, 20-year pricing. The other is Respondent  
11 B, CT proposal, 20-year pricing. On the far right hand  
12 there are three columns in a separate box. I was wondering  
13 if you could compare the numbers in the center of those  
14 three columns between the first sheet mentioned and the  
15 second.

16 A Surely. The numbers for the CT represent a fuel  
17 price with additional pricing volatility in there and  
18 additional transportation components for that delivered  
19 fuel price cost. If you look back at the combined cycle  
20 alternatives, you'll see that we have included earlier in  
21 the table, Column 2 or 3, a fixed fuel transportation cost;  
22 so you paid a lot of that variable transportation component  
23 up front in your fixed fuel reservation charge. Because  
24 you're going to utilize a CT much differently than you  
25 would utilize a combined cycle, there's really not much

1           for any actual information, but let's go off the  
2           record.

3                       (BRIEF RECESS)

4 BY MS. JAYE (Continuing):

5           Q       Ms. Burke, while we were off the record, we  
6           identified some confidential documents as TB-1 and TB-2,  
7           and I wanted to ask you a series of questions about those  
8           in general terms if you can respond to those. There's some  
9           concern that the variable transportation component between  
10          what is shown on sheet TB-1 and what is shown on sheet TB-2  
11          are extremely different, and I was wondering if you could  
12          explain the divergence. One looks to be almost twice as  
13          much as the other.

14          A       The costs that are shown on TB-1 are for the  
15          Smith unit. Those costs were supplied by a particular  
16          respondent to the gas RFP that was published, so the  
17          variable transportation costs that are shown there relate  
18          directly to that respondent's bid.

19          Q       All right. There are columns included on both  
20          TB-1 and TB-2 which fall under the label FGT, and I believe  
21          it is in the first column under that label. There are some  
22          numbers that from one sheet to the other are quite  
23          different, and I was wondering if you could explain the  
24          dollar difference between those numbers.

25          A       Certainly. Those columns should represent the

1 proposed for outside vendors. We only used this RFP  
2 to vary the different fuel alternatives for the  
3 self-build alternative.

4 BY MS. JAYE (Continuing):

5 Q Turning now to the response to staff's  
6 Interrogatory Number 17. I was hoping you could help me  
7 clarify my understanding of this response. Is this  
8 response indicating Gulf Power assumed that Southern  
9 Company Services would supply the natural gas for the  
10 Holmes County combined cycle unit? I believe we're  
11 actually referencing the confidential information that was  
12 provided.

13 A Oh, okay.

14 Q It's the page with the title "Southern Electric  
15 System 1998 Projections of Generic Nominal Natural Gas  
16 Prices."

17 A They all say that.

18 Q That's helpful.

19 A Are you talking about the combustion turbine  
20 project or the combined cycle projection?

21 Q Combined cycle.

22 MR. STONE: If we're going to talk about the  
23 confidential, can we just go off the record first and  
24 make sure we get things clear?

25 MS. JAYE: Well, I'm certainly not going to ask

1 QUESTION)

2 MR. MELSON: I'm not sure I understand the  
3 question, unfortunately.

4 MS. JAYE: The question is seeking to understand  
5 if information that was obtained in the separate RFP  
6 for the natural gas service, and evidently firm supply  
7 and the commodity itself bundled, if that information  
8 was applied across the board to all of the nine  
9 finals.

10 MR. MELSON: In other words, was each respondent  
11 modeled as though he had the benefit of that  
12 particular firm gas transportation number?

13 MS. JAYE: Yes.

14 THE WITNESS: Oh.

15 MS. JAYE: Yes.

16 THE WITNESS: Oh, that's a different question.  
17 Okay. Because it was a packaged deal, there is really  
18 no way to apply those gas prices to other sites that  
19 were involved in the solicitation. We applied the  
20 numbers that were provided from fuel. We applied them  
21 uniformly to the self-build alternative the same way  
22 we would have applied those numbers for a bid in the  
23 event that a respondent outside the company had made  
24 that for their electricity generation, but we  
25 maintained the integrity of the bids the way they were

1 outlined in the RFP, in Attachment C of the RFP; and they  
2 understood that going to some of these gas suppliers there  
3 was a possibility that some of those gas suppliers could  
4 package the commodity with some of the transportation and  
5 maybe reduce the cost that we thought was there.

6 Q In what form is information obtained in response  
7 to the September 1998 RFP?

8 A Respondents supplied written responses to the  
9 RFP.

10 Q Okay. How were those used in evaluating the  
11 self-build alternative?

12 A Southern Company Services' fuel department  
13 provided the initial screening of the proposals, and they  
14 sent to us, the evaluation team, four respondents and a  
15 self-build cost; so we evaluated five self-build  
16 alternatives.

17 Q Was the additional information obtained in the  
18 separate RFP for the firm natural gas service applied  
19 consistently among all nine proposals that were evaluated  
20 for the final stages?

21 A Yes.

22 Q Okay.

23 MR. MELSON: I missed that. Could I get that  
24 question read back?

25 (WHEREUPON, THE COURT REPORTER REREAD THE

1 associated with that: What's the incremental cost of debt?  
2 What's the incremental cost of capital? And it will create  
3 the declining revenue requirement stream for that.

4 MR. MELSON: Can we go off the record for a  
5 minute?

6 MS. JAYE: Certainly.

7 (DISCUSSION OFF THE RECORD)

8 MS. JAYE: Okay. Go back on the record.

9 BY MS. JAYE (Continuing):

10 Q Ms. Burke, how many of the RFPs that were  
11 received in response were for 20 years?

12 A Besides the self-build, we had three proposals  
13 that were 20-year proposals.

14 Q Okay. The next question is going to come from  
15 your direct testimony, Page 11, Lines 1 through 10. It's  
16 the sentence beginning, "In September, 1998."

17 MR. MELSON: What's the page number?

18 THE WITNESS: Eleven.

19 MS. JAYE: Page 11.

20 BY MS. JAYE (Continuing):

21 Q In the September 1998 RFP that's referenced on  
22 Lines 1 and 2 here, was Gulf attempting to purchase natural  
23 gas commodity or natural gas transportation?

24 A Actually both. They were working hard to reduce  
25 some of the gas lateral costs to the facility that were

1           A     I have, I guess, made an assumption that putting  
2 this unit in rate base would inherently create a 30-year  
3 declining revenue requirement type of cash flow of revenue  
4 to the company for the unit. What we did instead for this  
5 analysis was to compress that recovery time frame across 20  
6 years so that all of the costs had to be recovered in a  
7 20-year time cycle instead of in a 30-year time cycle.  
8 That really produced higher declining revenue requirements  
9 because you had to fully recover the unit across 20 years  
10 instead of recovering the unit across 30 years or longer,  
11 depending on what Florida's regulations require.

12           Q     Did this result in interest savings?

13           A     Interest savings. Like the rate of interest?

14           Q     Uh-huh. Between the 20- and 30-year time frame.

15           A     No, we used the same interest rate that we used  
16 for generic units.

17           Q     So the interest that would have been accumulated  
18 between year 21 and year 30 goes away, the cost of money  
19 over the last ten years of the 30-year cycle versus the  
20 20-year cycle?

21           A     Goes away. I guess I hadn't -- I'm having  
22 trouble understanding what you're saying. We took the 187  
23 million for the 540-megawatt size facility and basically  
24 put it in -- we have a little spread sheet model called Rev  
25 Req that finance has written for us to take the cost

1 increment.

2 Q Okay.

3 MS. JAYE: I'm going to need a moment here. Go  
4 off the record.

5 (DISCUSSION OFF THE RECORD)

6 MS. JAYE: Okay. Back on the record.

7 BY MS. JAYE (Continuing):

8 Q I've got some questions about statements  
9 appearing on Page 65 of the need study. For this  
10 particular need study, did Gulf and, you know, by extension  
11 Southern Company, choose to make cost comparisons of all  
12 the RFP respondents and of the self-build option on a  
13 20-year period of cost basis?

14 A It is very important in the analysis to make sure  
15 that you're comparing alternatives across an equal time  
16 period, and the best way to do that is to pick one time  
17 frame. Gulf selected a 20-year analysis period, and that's  
18 what we used.

19 Q Okay. Could you explain what that next sentence  
20 means where it says, "Theoretically the cost of any new  
21 generating facility constructed by Gulf would be recovered  
22 from its customers using declining revenue requirements  
23 over 30-year or longer time frame?" Is that what you would  
24 normally do, and how does this differ as far as the  
25 interest savings to customers, et cetera?

1 THE WITNESS: Well, hold on because I just told  
2 you the answer for Respondent C. I apologize. I got  
3 confused. I thought we were talking about Respondent  
4 C.

5 (WITNESS REVIEWED DOCUMENTS)

6 THE WITNESS: Respondent B was locating a  
7 facility in Holmes County, Florida that is within  
8 Gulf's service territory, and the cost for the  
9 improvements was 104.6 million.

10 BY MS. JAYE (Continuing):

11 Q Okay. Do you know how many circuit miles that  
12 location would be from Gulf's proposed facilities in Bay  
13 County?

14 A I do not know.

15 Q Okay. Or the cost per circuit mile?

16 A I do not know.

17 Q Okay. Is it true that Gulf scaled each RFP  
18 respondent's proposal to a 600-megawatt generic unit to do  
19 a production costing analysis?

20 A That's true.

21 Q Was this cost spread over 20 years?

22 A There's no need to spread production costs across  
23 different years. The production cost model annualizes the  
24 total cost, and so I had a total dollars cost for every  
25 year, simply divided that cost by the 600-megawatt

1 Q Okay. Do you know how many circuit miles this  
2 location -- the location for the Holmes County respondents  
3 would be from Gulf's proposed facilities in Bay County?

4 A No, I don't know that.

5 Q Okay. Do you know what the transmission cost was  
6 that Gulf applied to Respondent B's RFP?

7 (WITNESS REVIEWED DOCUMENTS)

8 Q I believe that some of this response, and you may  
9 have found it, but, you know, I apologize for not being  
10 able to direct you exactly where in the discovery these  
11 questions are coming from. This is actually on the  
12 response to Interrogatory 4. I believe that this had been  
13 summarized there, and I'm just trying to get a handle on  
14 the information.

15 A The confusion could be really because I knew that  
16 the Southern Company, that the price -- that the price that  
17 Respondent C offered was inclusive of the transmission cost  
18 to the interconnection point, Southern Company's  
19 interconnection point. After that point, our transmission  
20 planners assess a total cost of 104 million dollars to this  
21 project -- 112.6, I apologize.

22 MR. STONE: The question was about Respondent B,  
23 was it not?

24 MS. JAYE: Yes, Respondent B.

25 MR. MELSON: I'm sorry.

1 MR. MELSON: All right. Yeah.

2 MS. JAYE: We can go off the record.

3 (DISCUSSION OFF THE RECORD)

4 MR. MELSON: Yes, go back and identify it as a  
5 late-filed exhibit.

6 THE WITNESS: Yes, I don't believe we'll have a  
7 problem complying with the late-filed exhibit request.

8 MS. JAYE: All right. This will be Late-filed  
9 Exhibit Number 1. We'll call this the correspondence  
10 between Gulf and the RFP respondents.

11 BY MS. JAYE (Continuing):

12 Q Do you know if the Respondent C would use the  
13 same power plant technology as Gulf would use in a  
14 self-build option?

15 (WITNESS REVIEWED DOCUMENTS)

16 A This particular respondent outlined information  
17 about their 750-megawatt facility. They did mention two  
18 manufacturers' names, but not necessarily -- one of them is  
19 one that Southern Company deals with a lot; one of them is  
20 not. So in their design, I would expect that their design  
21 would differ somewhat from Southern Company's design of a  
22 self-build unit.

23 Q Are you familiar with the results of the fatal  
24 flaw study which was conducted by Respondent C?

25 A No, I'm not.

200

1 not confidential, but I don't know. So I want her to  
2 think about that before she answers the question.

3 MS. JAYE: Okay.

4 (WITNESS REVIEWED DOCUMENT)

5 THE WITNESS: This particular respondent  
6 estimated that across the six-year maintenance cycle  
7 that the availability would exceed 94%, but the annual  
8 forced outage rate was estimated, or would have been  
9 guaranteed at two and a half percent.

10 BY MS. JAYE (Continuing):

11 Q Okay. Do you know what the interconnections were  
12 for this particular respondent with the Florida Electrical  
13 Grid?

14 A I don't know. They actually provided a good bit  
15 of information that they had a consultant do with the  
16 interconnections. Because they were outside of the  
17 Southern Company service territory, they -- the  
18 interconnection cost was not really a part of our scope.

19 Q Okay. I believe we had some information provided  
20 pursuant to the staff's Request for Production Number 3  
21 which has subsequently been returned to the company, some  
22 confidential information that showed correspondence between  
23 Gulf and the RFP respondents, and I was wondering if we  
24 could get that as a late-filed deposition exhibit, get that  
25 filed again.

1 after I married and worked as a research engineer for a  
2 while and joined system planning not too long after that.

3 Q I'm going to jump right in here and start asking  
4 you some questions about the different respondents. Pretty  
5 much of this information can be found in the need study  
6 around Page 64 or 65, in this area. We're going to be all  
7 over the lot for a while. I'll go ahead and give you the  
8 heads up.

9 A Okay.

10 Q I've got a question about Respondent C's RFP.  
11 Was that to provide 532 megawatts of dispatchable capacity  
12 for a proposed 750-megawatt project to be located in Hardee  
13 County?

14 A That's on Page 64.

15 Q It's all within this area. I believe the actual  
16 numbers are over on Page 67 for that in the Table 8-1.

17 A Yeah, Respondent C provided 532 megawatts or  
18 proposed 532 megawatts of a larger facility in Hardee  
19 County, Florida.

20 Q Okay. Do you know what the availability factor  
21 for this plant would be?

22 A I can look that up. It's not in this text.

23 Q Okay.

24 MR. MELSON: Now let me ask, before she answers  
25 the question -- I assume the availability factor is

1 Whereupon,

2

MARIA JEFFERS BURKE

3 was called as a witness by the Plaintiff and, after being  
4 first duly sworn, was examined and testified as follows:

5

6

EXAMINATION

7 BY MS. JAYE:

8 Q Nancy, go ahead and insert the usual  
9 stipulations. Thank you.

10 Good morning, Ms. Burke.

11 A Good morning.

12 Q I'm just going to ask you a little bit about your  
13 background with the Southern Company. How long have you  
14 been with Southern Company?

15 A Almost 13 years.

16 Q And during those 13 years, what positions have  
17 you held?

18 A A variety of positions. I began the company as a  
19 research engineer at a research plant in Wilsonville,  
20 Alabama, and I had a variety of positions there. The  
21 company that actually operated that facility was Southern  
22 Electric International at the time. I went to Atlanta and  
23 was the environmental engineer for that development office  
24 for new projects, just like the folks that are bidding into  
25 this solicitation. From there I went back to Birmingham

137

INDEX OF EXHIBITS

1  
2  
3  
4  
5  
6  
7  
8  
9  
10  
11  
12  
13  
14  
15  
16  
17  
18  
19  
20  
21  
22  
23  
24  
25

NUMBER		PAGE NO.
#1	(Late-filed) Correspondence between Gulf and the RFP respondents . . . . .	9
#2	(Late-filed) Southern IRP material . . . . .	35

INDEX

1  
2  
3  
4  
5  
6  
7  
8  
9  
10  
11  
12  
13  
14  
15  
16  
17  
18  
19  
20  
21  
22  
23  
24  
25

PAGE NO.

STIPULATION	. . . . .	3
ERRATA SHEET	. . . . .	36
CERTIFICATE OF OATH	. . . . .	37
CERTIFICATE OF DEPONENT	. . . . .	38
CERTIFICATE OF REPORTER	. . . . .	39

MARIA JEFFERS BURKE		
Examination by Ms. Jaye	. . . . .	6

## STIPULATION

1  
2  
3 IT IS STIPULATED that this deposition was taken  
4 pursuant to notice in accordance with the applicable  
5 Florida Rules of Civil Procedure; that objections, except  
6 as to the form of the question, are reserved until hearing  
7 in this cause; and that reading and signing was not waived.

8 IT IS ALSO STIPULATED that any off-the-record  
9 conversations are with the consent of the deponent.  
10  
11  
12  
13  
14  
15  
16  
17  
18  
19  
20  
21  
22  
23  
24  
25

1  
2  
3  
4  
5  
6  
7  
8  
9  
10  
11  
12  
13  
14  
15  
16  
17  
18  
19  
20  
21  
22  
23  
24  
25

APPEARANCES:

GRACE A. JAYE, ESQUIRE, FPSC, 2540 Shumard Oak  
Boulevard, Suite 370, Tallahassee, Florida 32399-0850.

RICHARD D. MELSON, ESQUIRE, Gulf Power, Hopping,  
Green, Sams & Smith, 123 South Calhoun Street, Tallahassee,  
Florida 32301.

JEFFREY STONE, ESQUIRE, Gulf Power, Post Office Box  
12950, Pensacola, Florida 32576.

ALSO PRESENT:

MICHAEL HAFF, FPSC Staff.

TODD BOHRMAN, FPSC Staff.

ROBERT MOORE, Gulf Power.

ELAINE KWARCINSKI, Gulf Power.

\* \* \* \*

1  
2  
3  
4  
5  
6  
7  
8  
9  
10  
11  
12  
13  
14  
15  
16  
17  
18  
19  
20  
21  
22  
23  
24  
25

BEFORE THE FLORIDA PUBLIC SERVICE COMMISSION

In Re: Petition of Gulf Power Company ) DOCKET NO.990325-EI  
to determine need for proposed )  
electrical power plant in Bay County )

DEPOSITION OF: MARIA JEFFERS BURKE

TAKEN AT THE  
INSTANCE OF: FPSC Staff

DATE: Tuesday, May 11, 1999

TIME: Commenced at 10:00 a.m.  
Concluded at 2:00 p.m.

PLACE: FPSC  
2540 Shumard Oak Boulevard  
Room 362  
Tallahassee, Florida

REPORTED BY: NANCY S. METZKE, RPR, CCR


C & N REPORTERS  
REGISTERED PROFESSIONAL REPORTERS  
POST OFFICE BOX 3093  
TALLAHASSEE, FLORIDA 32315-3093  
(850)697-8314 / FAX (850)697-8715

BUREAU OF REPORTING

RECEIVED 5-30-99

192

## 1 REPORTER'S DEPOSITION CERTIFICATE

2 STATE OF FLORIDA )  
3 COUNTY OF LEON )  
45 I, NANCY S. METZKE, Certified Shorthand Reporter  
6 and Registered Professional Reporter, certify that I was  
7 authorized to and did stenographically report the  
8 deposition of WILLIAM F. POPE; that a review of the  
9 transcript was requested; and that the transcript is a true  
10 and complete record of my stenographic notes.  
1112 I FURTHER CERTIFY that I am not a relative,  
13 employee, attorney or counsel of any of the parties, nor am  
14 I a relative or employee of any of the parties' attorney or  
15 counsel connected with the action, nor am I financially  
16 interested in the action.  
1718 DATED this 10th day of May, 1999.  
1920   
21 \_\_\_\_\_  
22 NANCY S. METZKE, RPR, CCR  
23  
24  
25

CERTIFICATE OF DEPONENT

1  
2  
3  
4  
5  
6  
7  
8  
9  
10  
11  
12  
13  
14  
15  
16  
17  
18  
19  
20  
21  
22  
23  
24  
25

This is to certify that I, WILLIAM F. POPE, have read the foregoing transcription of my testimony, Page 1 through 69, given on May 10, 1999, in Docket Number 990325-EI, and find the same to be true and correct, with the exceptions, and/or corrections, if any, as shown on the errata sheet attached hereto.

\_\_\_\_\_

WILLIAM F. POPE

Sworn to and subscribed before me this \_\_\_\_\_ day of \_\_\_\_\_, 19\_\_\_\_

\_\_\_\_\_  
NOTARY PUBLIC  
State of \_\_\_\_\_  
My Commission Expires: \_\_\_\_\_

1 STATE OF FLORIDA )  
2 COUNTY OF LEON )

CERTIFICATE OF OATH

3  
4  
5  
6  
7  
8  
9  
10  
11  
12  
13  
14  
15  
16  
17  
18  
19  
20  
21  
22  
23  
24  
25

I, the undersigned authority, certify that  
WILLIAM F. POPE personally appeared before me and  
was duly sworn.

WITNESS my hand and official seal this 10th day  
of May, 1999.

*Nancy S. Metzke*  
\_\_\_\_\_  
NANCY S. METZKE  
Notary Public - State of Florida



Nancy S. Metzke  
MY COMMISSION # CC677518 EXPIRES  
September 13, 2001  
BONDED BY TROY FAIR INSURANCE INC

ERRATA SHEET

DOCKET NUMBER 990325-EI  
WILLIAM F. POPE  
MAY 10, 1999

- 1
- 2
- 3
- 4
- 5
- 6
- 7
- 8
- 9
- 10
- 11
- 12
- 13
- 14
- 15
- 16
- 17
- 18
- 19
- 20
- 21
- 22
- 23
- 24
- 25

1  
2  
3  
4  
5  
6  
7  
8  
9  
10  
11  
12  
13  
14  
15  
16  
17  
18  
19  
20  
21  
22  
23  
24  
25

(DISCUSSION OFF THE RECORD)

MS. JAYE: Okay. Back on the record.

MR. MELSON: Apparently the spread sheets at this point are almost final.

MS. JAYE: Okay.

MR. MELSON: What we would like to do is go ahead and identify them if we could as a late-filed exhibit for Mr. Pope. We'll try to get those filed this afternoon, if we can, with a notice of intent for confidentiality. And then to the extent you've got questions about them, Ms. Burke ought to be able to answer those questions tomorrow.

MS. JAYE: Very good. That sounds great.

Okay. That's all the questions we have then. We'll reserve the rest for Ms. Burke.

MR. MELSON: Gail.

MS. KAMARAS: I've got no questions.

MR. MELSON: No redirect.

(WHEREUPON, THE DEPOSITION WAS CONCLUDED)

\* \* \* \*

1 when those type of more efficient and lower cost units are  
2 put into the mix, they do displace higher cost units to the  
3 benefit of all and Gulf Power Company.

4 Q Okay. The next set of questions deal with cost  
5 effectiveness. Staff has prepared a spread sheet, and we  
6 apologize for the small type, but we have indicated several  
7 columns, and we would appreciate it if you could fill it in  
8 for us and return it as a Late-filed Deposition Exhibit  
9 Number 4. And we'll title that revenue requirements spread  
10 sheet. This, I believe, staff has provided to your  
11 counsel.

12 MR. MELSON: Right, and my recollection is that  
13 when we had the informal meeting and discussed this  
14 there were some changes, I think, in the reserve  
15 margin presentation that we agreed to. I assume you  
16 want what we have talked about during that meeting as  
17 opposed to the columns that are shown here.

18 MS. JAYE: Yes.

19 MR. MELSON: Actually, this is probably a  
20 document that will be produced by Ms. Burke rather  
21 than by Mr. Pope. I don't mind identifying it.  
22 However you want to handle that mechanically, I don't  
23 care, but she would ultimately be the one to speak to  
24 the numbers.

25 Go off the record.

1           A     Yes. The benefit as determined in those columns,  
2 and there are benefits, basically demonstrates how Gulf,  
3 being a part of the Southern Electric system, and any  
4 alternative that it may consider or evaluate that would be  
5 a lower cost and displace higher cost generation has direct  
6 benefits from a marginal energy cost on an hour-by-hour  
7 basis directly to, not only Southern Company, but Gulf  
8 Power Company as part of the Southern dispatch pool.

9                     Let me clarify that a little further. What I'm  
10 saying is that any alternative that we evaluate,  
11 according -- and stacked up against the base case, that  
12 displaces a higher cost unit has direct benefits on a  
13 dollar per megawatt basis directly to that option that is  
14 lower cost. That's what is tried or we attempted to  
15 capture and did capture in that analysis in the PROVIEW  
16 cases.

17           Q     So in your opinion, the development of the  
18 proposed Smith Unit 3 would replace older dirtier, less  
19 efficient units and, thereby, be a net benefit to Southern  
20 and to Gulf?

21           A     Well, you only -- Let me just respond to the  
22 fact that the higher cost units were displaced and would be  
23 displaced by the Smith CC or Smith Unit 3; and, of course,  
24 some of the other alternatives did have some lower energy  
25 costs as well because they were like type of units. But

1 Number 3 would still be the same, no matter which one was  
2 used.

3 Q Okay.

4 MS. JAYE: We need to go off the record a minute.

5 (DISCUSSION OFF THE RECORD)

6 MS. JAYE: Go back on the record.

7 BY MS. JAYE (Continuing):

8 Q Looking, again, at the Gulf response to staff  
9 Interrogatory Number 1, there were two columns here called  
10 "Base Case Utility Cost" and "Proposal Utility Cost."  
11 These appear to be derived from Southern Company numbers.  
12 Is this the case?

13 A It's a Southern -- total Southern Company is  
14 modeled in that PROVIEW model that we ran these cases on,  
15 that's correct.

16 Q Okay. Does the IIC factor into these two  
17 columns?

18 A The IIC, intercompany interchange contract or  
19 IIC, is not a factor and not any part of those calculations  
20 whatsoever.

21 Q Could you explain how the addition of a unit  
22 which would be cost effective to Southern could be cost  
23 effective to Gulf as well? In addressing the question,  
24 would you speak to the nature of the unit being a CC and  
25 the sort of fuel that will be used, et cetera?

1 requirements, et cetera, that were provided.

2           A       Certainly. When looking at any of these  
3 alternatives, the Smith Unit 3 option and any response or  
4 offer, the company looks at the total cost impacts to the  
5 company based on those offers, the transmission associated  
6 and energy and O&M costs. You take all of those factors,  
7 all of those numbers and you add them up and present value  
8 them to 2002 dollars, which gives you a -- in our case -- a  
9 dollar per kilowatt total evaluated cost to Gulf Power  
10 Company for those projects.

11                   Although a Southern financial assumption was used  
12 to come up with the cost effectiveness dollars, it would  
13 matter not for the ranking purposes whether that was a 12%  
14 return on equity or a 14% return on equity as far as the  
15 ranking goes. The dollar amount, the raw dollar amounts  
16 may change. No, they will change. If, for instance, the  
17 assumed return on equity were 12%, the numbers, all the  
18 numbers would go up slightly, but Gulf's differential  
19 between its next best alternative would increase because it  
20 would have a lower cost risk capital and a higher dis -- or  
21 a lower discount rate. That's why all numbers would go up,  
22 because your cumulative present values would all go up; but  
23 Gulf's cost to construct transmission and generation would  
24 go down more, so the differential in the two would get  
25 greater. The cost effectiveness is still the same. Smith

1 between the column "Grid and Connection Accumulative  
2 Present Value Dollars per Kilowatt Year," and how that  
3 would impact the general and transmission total cost column  
4 at the end of that row?

5 A If it were calculated and filled in --

6 Q If it had its numbers.

7 A It would increase those dollars per kw figures  
8 individually by year and, of course, the total. Likewise,  
9 if the others were likewise included, they would increase  
10 their numbers too. The ranking would still stay the same.

11 Q Okay. I'm going to move on and ask some  
12 questions on the cost effectiveness. As a layman, are you  
13 generally familiar with the provision in Section 403.519 of  
14 Florida Statutes that requires a proposed unit to be the  
15 most cost effective alternative available?

16 A Yes.

17 Q Okay. Do you know if Gulf is justifying the  
18 proposed Smith Unit Number 3 as the most cost effective  
19 alternative available to Gulf or to Southern Company?

20 A To Gulf.

21 Q Okay. Could you explain how that is determined  
22 when the analyses that were done were based upon Southern  
23 Company?

24 A You talking about financial assumptions?

25 Q Yes. We're talking about the revenue

1           A     And there are zeros there. And your question  
2 is?

3           Q     If the information that you just explained would  
4 go under that column.

5           A     Correct, that's where you'll see it on all of the  
6 spread sheets that are associated with the RFP. The reason  
7 this one is zero is because we take -- we assume Smith Unit  
8 3 to be the base, so we extract its annual dollar per  
9 kilowatt year cost from the others and basically say Smith  
10 is the base so we're just going to say it's zero. The  
11 others have numbers in there, but that's the difference  
12 between what Smith's improvements would cost and their  
13 improvements would cost.

14          Q     Okay. Do you believe that it is appropriate to  
15 show the transmission cost impact of Smith Unit 3 as zero  
16 if, in fact, there are costs?

17          A     I think it's just a choice of representation. It  
18 could just as appropriately be shown, as opposed to being  
19 zeros and taken the difference for the others, it could  
20 just as appropriately be shown as its cost alone and then  
21 the total cost of the others. The same result is going to  
22 occur.

23          Q     Mr. Pope, if you could reference the response to  
24 staff's Interrogatory Number 1 again, the same page we were  
25 looking at before. Could you speak to the relationship

1 of the cost effectiveness. But you present value those,  
2 and you present value revenue requirements.

3           There are some O&M implications from  
4 transmission. Those were added in on an annual basis and  
5 present valued in like manner. What that gives you for all  
6 the transmission improvements is a present worth revenue  
7 requirements of their capital and O&M, which are added into  
8 the cost effectiveness from a total cost basis.

9           Q     There was some information provided in response  
10 to staff's first set of interrogatories, Number 1. There's  
11 a column heading here, and I would just for like for you to  
12 tell me if what you've discussed belongs under this  
13 heading. It's called "Transmission Grid and Connection  
14 Accumulative Present Value." Those are dollars per  
15 kilowatt per year. Is that --

16           A     That's in response to Interrogatory 1?

17           Q     One.

18           A     And which one is that so that I'm making sure  
19 that I'm on the same page as you are.

20           Q     A page that looks like that.

21           A     Yeah, this is the spread sheet for Smith, the  
22 Smith 3 in the RFP process. And you're talking about the  
23 column that says "Transmission Grid and Connection  
24 Accumulative Present Value in Dollars Per Kilowatt Year."

25           Q     Yes.

1 transmission additions and upgrades were incorporated into  
2 the cost effectiveness analysis for each self-build option  
3 and RFP project?

4 A Excuse me. Could you please repeat that?

5 Q Certainly. What staff is looking for in this  
6 question is an understanding of how the costs for  
7 transmission additions and upgrades were actually  
8 incorporated into the cost effectiveness analysis for each  
9 self-build option and RFP project. What we would like is a  
10 discussion of the conversion of capital cost to revenue  
11 requirements, et cetera.

12 A Okay, I got you now. I just wanted to make sure  
13 I got the full scope of it.

14 Q Okay.

15 A The transmission improvements, and all cases have  
16 some transmission improvement, the capital cost of the  
17 transmission improvements are used to calculate a present  
18 worth revenue requirement, standard declining revenue  
19 requirement stream. So you add those up for each case, all  
20 the revenue requirement streams for all the transmission  
21 improvements and you present value them to 2002 in the case  
22 of the RFP.

23 In the case of the self-builds, we present value  
24 that same number to or like number to 1998 dollars. That's  
25 one difference between the two. But it's still reflective

1 correct information?

2 A The omission was from the standpoint that it  
3 said -- the petition said that there are no transmission  
4 facilities directly associated with this unit, and I  
5 believe that need petition will be amended to reflect that  
6 there are, and those lines will be listed. I want to point  
7 out though, however, the costs of those improvements in the  
8 RFP analysis evaluation were included, so the costs, as far  
9 as cost effectiveness goes, were included; but it just was  
10 omitted from the petition itself as an oversight.

11 Q Okay. In Gulf's response to staff's  
12 Interrogatory Number 4, it appears that the self-build  
13 option, which is Case Number 3, and the RFP Case Number 4,  
14 both pertain to a Smith combined cycle unit. Could you  
15 explain why the costs are so different for these two  
16 options when they appear to pertain to the same plant?

17 A Okay. For one thing, in the self-build option,  
18 self-constructed case of the initial evaluation, we were  
19 looking at smaller unit and, therefore, there were less  
20 impacts in the Panama City area from the local  
21 transmission. When you raised the capacity of the unit  
22 addition to nearly twice what was initially evaluated, you  
23 added some other incremental improvements in the Panama  
24 City area.

25 Q Could you briefly explain how the cost of

1 various alternative solutions to those, and then you  
2 generate costs associated with those and select the most  
3 cost effective. But, yes, they did.

4 Q In determining the cost for each new line and  
5 upgrade for the self-build option, RFP options, were the  
6 costs determined using some standard method or by a special  
7 method?

8 A Each improvement has to be looked at individually  
9 because some can be a conversion of an existing smaller  
10 line, say on existing right of way. Well, you need to  
11 treat that differently than if you bought new right of way  
12 with a new construction, so I'd have to say they're all  
13 special. There's no, there's no -- you know, five miles of  
14 line is a million dollars. No, it's -- there are some  
15 common assumptions for certain areas having certain -- or  
16 certain size lines having certain dollars per mile to  
17 install. Substations, depending on what they have in them  
18 are a certain cost, but you have to still treat it  
19 individually as to what kind of addition it's going to be.

20 Q Okay. On the last page of Gulf's response to  
21 staff's Interrogatory Number 4, there's a discussion that  
22 some transmission costs were inadvertently omitted from the  
23 need petition.

24 A Correct.

25 Q Will Gulf amend the need petition with the

1 units, et cetera, so on and so forth.

2 Q What percentage in general of the reserve would  
3 be allocated to tie assistance?

4 A Probably in the one and a half percent range.

5 Q In order to allow staff to better evaluate and  
6 understand the differences between EAF and EFOR, staff  
7 would request that you provide a late-filed exhibit -- the  
8 one, I believe, will be Number 3 -- which will provide  
9 Southern Company's historic and forecasted system EAF for  
10 each year from 1994 to 2004, and we'll give this a title  
11 system wide EAF, 1994 to 2004.

12 A Okay.

13 Q All right. Thank you.

14 MS. JAYE: I think we need to go off the record  
15 and take about a five-minute break and let staff  
16 regroup here.

17 (BRIEF RECESS)

18 BY MS. JAYE (Continuing):

19 Q These questions pertain to Gulf's response to  
20 staff's Interrogatory Number 4. The response to  
21 Interrogatory Number 4 contains the cost for each new line  
22 and upgrade for each self-build and RFP option. Did these  
23 costs come from the transmission study?

24 A Yes, the lines were identified in this study,  
25 okay? And then as I mentioned earlier, you look at the

1 forecast error, forced outages, and abnormal weather.

2 Q Could you elaborate a little on this ties?

3 A Your ties or tie lines or interconnections are  
4 the power lines that you have with neighboring utilities.  
5 The Southern Electric system is interconnected with the  
6 Entergy system, the TVA system, the Duke system, the  
7 Virginia/Carolina systems, and Peninsular Florida. So we  
8 have five basic sources that at any point in time, if we  
9 were to lose a large generating unit, that powers would --  
10 power flows would change. Because of the generation in  
11 those areas and their generators having a certain amount of  
12 inertia, they will pick up, power will flow where it needs  
13 to flow until generation, additional generation can be  
14 either brought on the Gulf system or the Southern system or  
15 we can make arrangements with others to pick up their  
16 generation to help us through depending on the condition.

17 That's what we call tie systems. That's where  
18 our interconnections will help us from a reliability  
19 standpoint. On a planning basis, we can look at it both  
20 short term and near term. We also look at our generators  
21 as having certain types of reliability responses. Some of  
22 our generators are what they call quick-start capability,  
23 can be on line in ten minutes. That meets the NERC  
24 criteria as a reserve, a spending reserve. So tie systems  
25 is something we look at to analyze the effects of losses of

1 cover that from a reserve standpoint.

2           There are load forecast errors. Your load  
3 forecasts for tomorrow may be very accurate; but three  
4 years, five years down the road when you'd would have to  
5 make commitments for today to build, they may not be as  
6 accurate. Economic conditions could change, change in the  
7 pattern of use. So we try to account for load forecast  
8 errors with reserves.

9           There's also abnormal weather conditions. Most  
10 forecasts are produced on a weather normal basis, which for  
11 the summertime -- which Gulf is a summer peaker -- we  
12 assume a 95-degree ambient temperature as a weather normal  
13 or 94-degree weather normal temperature for a summer peak  
14 day. Well, if it's 102 for five days in a row, your demand  
15 is going to be higher. That's an abnormal weather  
16 condition.

17           Ways that we can meet those reserves are with  
18 additional generation or outside sources. Operationally --  
19 That's on a planning basis. Operationally, on a  
20 day-to-day basis, we have a certain amount of our  
21 interfaces that we depend on, depending on what they're  
22 being used -- how they're being used on a day-to-day basis.  
23 So there is some reliance on outside sources, or what we  
24 call tie systems, as well as generation resources above  
25 that of our normally expected demand to take care of load

1 way of looking at things is not an indicator of things that  
2 you unexpectedly have happen. A unit could be a hundred  
3 percent available and have a 100% equivalent availability  
4 factor in one year, but never be called on to generate,  
5 never crank itself up; therefore, you don't know if it  
6 could have run if called upon or not.

7           So that's an indicator where it would say that  
8 you don't need to do anything for this unit; however, the  
9 next day after the new year that this equivalent  
10 availability factor was a hundred percent, they call it up  
11 to run, and it can't run. But was it really available?  
12 Well, at that point it's a forced outage, and that's the  
13 thing, is you are trying to cover for the unexpected things  
14 which are measured by equivalent forced outage rate and not  
15 equivalent availability factor. Like I said, from a  
16 reliability standpoint, it is not what we consider to be  
17 the thing that we want to protect against.

18           Q       What are some other things which Southern Company  
19 would look to in order to analyze its reliability factor  
20 besides the EFOR and EAF?

21           A       In all instances reliability is to cover things  
22 you didn't plan on. Your equivalent forced outage rate is  
23 something you'd like to have your units run all the time,  
24 but there is going to be some likelihood they're going  
25 forced out. That means that probablistically you need to

1 for a moment?

2 A Okay.

3 (DISCUSSION OFF THE RECORD)

4 MS. JAYE: Okay. We're back on the record now.

5 BY MS. JAYE (Continuing):

6 Q Turning now to the response to Staff  
7 Interrogatory Number 28, Gulf has provided historic  
8 equivalent forced outage rates on the Southern Company  
9 System. We understand that EFOR is a better measure of the  
10 frequency and duration of outages, but we would like to  
11 understand why it is better for this purpose than the  
12 equivalent availability factor or EAF?

13 A The equivalent forced outage rate is, it tracks  
14 and calculates your forced outages. Forced outages are  
15 surprises. They are unplanned, unexpected. They are a  
16 demonstration of what the unit can be expected to be off  
17 line for unexpected reasons. The Southern Electric system,  
18 I guess along with some other utilities, look at the  
19 equivalent forced outage rate as a better indicator of a  
20 need to cover reliability. You need to cover for this  
21 unexpected outage of a unit, therefore, use EFOR.

22 The equivalent availability factor or EAF, only  
23 demonstrates what a unit is available or, you know, is  
24 demonstrated or shown to be available. Not demonstrated,  
25 but they can report they're available. Availability in my

1 comes primarily because when they're adding capacity  
2 resources, it's large units to meet their needs, which are  
3 large needs. And Gulf and the size it is with a growth of  
4 about 30 to 40 megawatts a year, easily a short excess from  
5 them, which is a big amount of capacity, takes care of  
6 Gulf's little bitty needs; and typically the larger --  
7 like I said, the larger companies are the ones with the  
8 excesses.

9           Now how are reserves allocated? Roughly in the  
10 planning arena, under a 13.5% reserve margin, all  
11 individual operating companies, because of diversity,  
12 should have, and carry 12.6% reserves. If, for instance,  
13 Georgia Power Company in one year had 15% reserves, that  
14 leaves a large chunk of megawatt to be reallocated to other  
15 companies that are short of their 12.6. Basically those  
16 with the lower reserve margin, individual reserve margins  
17 get a varied proportion of those excess reserves.

18           Q     Does this mean that Gulf plans its system  
19 additions to meet a 12.6% individual utility reserve  
20 margin?

21           A     That's correct. That's what we consider to be  
22 our reasonable share of Southern's reserves based on 13 and  
23 a half percent.

24           Q     The next question goes to the response to Staff's  
25 Interrogatory Number 28. We also need to go off the record

1 it Gulf's turn to add capacity because Gulf is a primary  
2 driver for Southern's 2002 capacity need?

3 A No, Gulf is not necessarily the sole driver for  
4 Southern's needs, but a number of companies are now needing  
5 to add capacity. Gulf has not added capacity in a number  
6 of years because it's enjoyed the benefits of both relying  
7 on the Southern Electric system and its short-term excesses  
8 of capacity plus purchases, cost-effective purchases; and  
9 now cost-effective purchases, because recent market tests  
10 appear not to be available, we have found them out there.  
11 We have gone out and asked people to provide us quotes and  
12 information which have not been as cost effective as the  
13 generation, but it's because Gulf and other companies in  
14 Southern Electric system are all having to add capacity.  
15 And Gulf has no other recourse than to go negative with  
16 reserves, but it can't rely on the Southern Electric system  
17 without them adding or us adding, which still costs us; and  
18 this is the most cost effective alternative we found.

19 Q Could you explain how the Southern Company  
20 members share their system reserves, i.e., how the reserves  
21 are allocated, which utilities are primary suppliers of  
22 reserves and that sort of thing?

23 A Primarily your larger companies, which are  
24 Georgia Power Company and Alabama Power Company, typically  
25 have, more often than others, excess reserves; and that

1 13.5%?

2 A Excuse me. Ask that again.

3 Q How much capacity will Gulf Power need on its  
4 system in the year 2002 in order to meet its reliability  
5 criteria?

6 A In 2002, Gulf itself is 427 megawatts short of  
7 meeting its capacity and reserve obligations according to  
8 the 13.5% Southern target reserve margin.

9 Q How much capacity would Gulf need in the year  
10 2002 if its reserve margin criteria were 15%?

11 A Can I take a minute to calculate that?

12 Q Certainly.

13 MR. MELSON: Before he finishes his calculation,  
14 how much for Gulf to meet a stand-alone 15% reserve,  
15 or how much for Gulf to meet its share of a Southern  
16 15% reserve?

17 MS. JAYE: Stand-alone 15%.

18 MR. MELSON: Okay.

19 THE WITNESS: 482 megawatts.

20 BY MS. JAYE (Continuing):

21 Q How much new capacity does the Southern Company  
22 system typically need to add each year?

23 A At this time it's currently about 600 megawatts a  
24 year.

25 Q Among the Southern Company member utilities, is

1 Q Looking again at this graph on page 47 that we've  
2 been discussing, it appears that it remains flat for quite  
3 sometime around the 13 or 14% level. What does that mean  
4 in terms of cost? Would it matter then if you picked 13,  
5 14, or 15%?

6 A You're right. The curve, as it comes down to the  
7 13 and a half to 14% range, it gets flat and looks to be  
8 fairly flat on up to around 15 and a half, 16%. And the  
9 reason it comes down steeper to the left to that point is  
10 because generation is very sensitive to the loss of energy  
11 to the left, but since there's a low cost of generation out  
12 beyond that point, you don't gain much from your  
13 reliability as you get beyond 13 and a half, 14, 15% as far  
14 as reduction in EUE cost for the same -- for an increment  
15 of generation. So, yeah, it says reliability wise, 13 to  
16 15%, the reason you pick 13 and a half percent is because  
17 that costs you less money. It's less investment for  
18 relatively the same reliability cost. In other words, you  
19 still -- you wouldn't go build the extra dollar if it  
20 doesn't buy you anything.

21 Q Does Gulf Power Company have its own planning  
22 criteria?

23 A Not a stand-alone criteria, no.

24 Q Okay. How much capacity will Gulf Power need on  
25 its system in 2002 to meet the reliability criteria of

1 curve. It's what we call the bathtub curve. It looks kind  
2 of like a bathtub. Where that total curve reaches zero or  
3 a zero slope or reaches its minimum is the area you want to  
4 have -- that's your optimum reserve point.

5 Q Mr. Pope, if you look at the center of the graph  
6 where it is calculating reserve margin, there appear to be  
7 two 14%. I was wondering if you could explain that. Is it  
8 14 and perhaps it should have been 14.5? I don't quite  
9 understand. It looks to be at the minimum point on the  
10 curve?

11 A I can say it's a consistent error because it's on  
12 Page 51 as well. I believe there may be another curve  
13 somewhere here that clarifies it, but -- Good point.

14 Q Also, I didn't see on here a point on the graph  
15 that corresponds to a 13.5% reserve margin, and I was  
16 wondering if perhaps one of those was supposed to be the  
17 13.5 instead of 14.

18 A Possibly. I'm just going to have to clarify that  
19 to find out. If I don't find it here in a minute, we can  
20 find that out.

21 MS. JAYE: We can go off the record for a second  
22 if that would be all right with everyone.

23 (DISCUSSION OFF THE RECORD)

24 MS. JAYE: All right. Back on the record.

25 BY MS. JAYE (Continuing):

1 outages. It means that you can build a lot of generation  
2 without worrying about it, but the cost of what you avoid  
3 goes down. And that -- those counterbalances went to the  
4 left rather than in the center or to the right.

5 Q Mr. Pope, I want to be sure I understand this.  
6 There are two curves involved in setting the reserve  
7 margin, and I was wondering if you could explain to me what  
8 they represent. Is it EUE and cost of generation? You  
9 were discussing if one goes up, the other one goes down,  
10 and --

11 A Yeah. Let's refer to a page in the POD response,  
12 the July 1997 document, Page 47. This is a graph of total  
13 cost as it relates to reserve margin. The dark colored  
14 lines -- Starting at the left around 9%, you'll see that's  
15 a solid dark line. That represents the amount of expected  
16 unserved energy times the cost of that unserved energy at  
17 \$4.34 a kilowatt hour, okay? That's the dark line.

18 Moving to the right, you'll see a straight line  
19 that's lighter colored on that bar that starts to inch up.  
20 That's the cost of adding reliability generation to avoid  
21 lost energy. Now you'll see your dark line not only in  
22 total, as the total sum of those two comes down; but as an  
23 increment per reserve margin it gets smaller and smaller.  
24 But it's a summation of both the cost of unserved energy  
25 and the generation to avoid it, which describes the total

1           A       Let's start with the initial one, 1991, that used  
2 the cost of reliability generation as a factor to reduce  
3 loss of load or loss of energy. There is a loss of energy  
4 and a cost of that loss of energy, what we call expected  
5 unserved energy. The '91 case identified the cost of  
6 expected unserved energy, or EUE, to be priced at \$7.31 a  
7 kilowatt hour. So that establishes a cost that you would  
8 basically assign for the power that a customer loses. Then  
9 you would build units at a cost of that construction to  
10 avoid that.

11                   That's what the 1991 study started with. It  
12 changed from '91 to '94. It's primarily the cost of that  
13 unserved energy going from 7.31 to I believe \$8.34 per  
14 kilowatt hour. The cost of generation actually goes down.  
15 The cost of incremental generation to avoid goes down. We  
16 chose in that time to not make a change because it looked  
17 like the curve stayed in the same place.

18                   The change from '94 to '97 was a further  
19 reduction in the cost of incremental reliability generation  
20 and a review of what customers would actually be outaged  
21 for generation resource shortages, which lowered the number  
22 in dollars per kwh moving the curve further from 15%, which  
23 was the target reserve margin prior, downward toward around  
24 the 13.5% range. Those two counteract each other. The  
25 lower cost -- I have a lower cost of generation to avoid

1 Q How long do you anticipate the need for new  
2 transmission lines into the area to be delayed because of  
3 the unit?

4 A Let me look, please.

5 (WITNESS REVIEWED DOCUMENTS)

6 A I would say at least seven years.

7 Q My next set of questions are concerning the  
8 system reserve margin and how aggregate reserve margin  
9 appears in each Southern Company member's individual  
10 system. And we're going to be turning to Gulf's response  
11 to Staff's Request for Production of Documents Number 21.

12 MR. MELSON: 21?

13 MS. JAYE: Yes.

14 BY MS. JAYE (Continuing):

15 Q This would be the July of 1997 Economic Study of  
16 the Optimum System Planning Reserve Margin for the Southern  
17 Electric System. Were the documents provided in Gulf's  
18 response to Staff's Request for Production Number 21 used  
19 to justify the company's selection of a 13.5% system  
20 reserve margin?

21 A That's correct.

22 Q Three documents contained in Response 21 appear  
23 to be three evolving versions of the same reserve margin  
24 study. What are the primary differences in the conclusions  
25 reached in each of these three studies?

1           A       That's correct, that's Respondent A. Their  
2 capacity is not sufficient to meet Gulf's needs in that  
3 year or any subsequent year.

4           Q       Okay. Earlier you had indicated there was an  
5 imbalance between generation and load in the Panama City  
6 area. Could you clarify and tell what is the approximate  
7 amount of this imbalance?

8           A       I'm going to have to draw on memory from a couple  
9 of years back when we added it up, but in what we call the  
10 Panama City area, back in '96 it was like 75 megawatts. Of  
11 course 2002 is six years down the road. We are growing at  
12 around 2% a year, so it's going to grow to greater than a  
13 hundred.

14          Q       Is the capacity from the proposed Smith CC unit  
15 expected to postpone the need for new transmission lines in  
16 the Panama City region, and how long would it be postponing  
17 them if it were?

18          A       The Smith addition is primarily postponing  
19 transmission line improvements into Gulf's territory and  
20 from the Pensacola area to the Panama City area. There are  
21 some additions, minor additions in the Panama City area  
22 that result from the Smith generation. It is a rather  
23 large amount of addition; but, yes, it avoids or postpones  
24 significantly transmission lines coming to the Panama City  
25 area to transport power which it will take the place of.

1 any of these offers add to or be sufficient for the  
2 reliability of the system? Yes.

3 Q All right.

4 MS. JAYE: We need to go off the record for a  
5 moment, I guess.

6 (DISCUSSION OFF THE RECORD)

7 MS. JAYE: Back on the record.

8 BY MS. JAYE (Continuing):

9 Q Mr. Pope, if you could clarify the ranking of the  
10 different respondents and self-build options as far as  
11 their ability to meet electric system reliability and  
12 integrity, I'd appreciate it.

13 A The question of whether these respondents,  
14 ignoring the cost of transmission and assuming those  
15 transmission improvements being installed and then dealing  
16 with that response and ignoring its cost, there are some  
17 that can meet the reliability needs, capacity resource  
18 needs of Gulf Power Company. There is one that because of  
19 the size of its offer would not be sufficient in the year  
20 of 2002, which is when we are going to install or want to  
21 install this Smith Unit 3 or any of the other respondents,  
22 is insufficient to meet Gulf's resource needs because it's  
23 a smaller size.

24 Q Could you tell me if that is Respondent A in the  
25 rankings?

1 Q Focusing in on that fix piece of the statute,  
2 just in your opinion, dealing with systems all the time as  
3 a layman.

4 A Before I can formulate an answer, let me just  
5 maybe ask a question in clarification because, when you say  
6 to ignore cost, there are some costs that directly relate  
7 to the reliability of the system but are not associated  
8 directly with a response or an offer from a respondent, for  
9 instance, transmission improvements.

10 Q Right.

11 A Absent the cost, am I to assume that absent those  
12 improvements? Because if I ignore the cost of those  
13 improvements and ignore his cost but assume that they are  
14 there, then I can answer the question, yes; but without  
15 those improvements and their -- without their cost and the  
16 improvements, then I'd have to say no to some and yes to  
17 some.

18 Q Just for clarification, it would be assuming that  
19 any additions that would be necessary to transmission, for  
20 instance, would already be in place, already be -- you  
21 know, they would be there, or they would be added but you  
22 wouldn't factor in the cost of that in ranking the  
23 different respondents or the self-build options, would your  
24 opinion change?

25 A And the question, as far as my opinion is, would

1 yeah, sometime, because growth is going to occur, they  
2 would be needed. But we tried to keep things down to, if  
3 this unit were here or not here, what are the incremental  
4 improvements in the planning horizon?

5 Q As a layman, are you generally familiar with  
6 Section 403.519 of Florida Statutes?

7 A Yes, as a layman.

8 Q Ignoring any cost implications, would any of the  
9 self-build options in RFP projects have sufficiently, in  
10 your layman's opinion, provided for Gulf's electric system  
11 reliability and integrity as stated in Section 403.519?

12 A Would you please repeat the question?

13 Q Certainly. It is rather long. If you ignore any  
14 cost implications, just take those out of the mix for a  
15 moment, would any of the self-build options in the RFP  
16 projects in your layman's opinion have sufficiently  
17 provided for Gulf's electric system reliability and  
18 integrity as provided for in Section 403.519 of Florida  
19 Statutes?

20 MR. MELSON: Grace, the question is, putting cost  
21 aside, would any of these have met that criteria?

22 MS. JAYE: Yes, electric system reliability and  
23 integrity.

24 MR. MELSON: Okay.

25 BY MS. JAYE (Continuing):

1 as opposed to another. Sometimes it's more economical to  
2 go ahead and put in a new line although up front it's a lot  
3 more dollars, but long-term it's still the most cost  
4 effective way.

5 That is the reason why some things are  
6 reconducted or conductor replaced and some are new lines,  
7 because it was most cost effective. Also, if you choose to  
8 put in a conductor upgrade, there's still a project that  
9 may have shown up as a first year addition in one  
10 particular option that eventually still has to be built in  
11 another, and that's why the different timing. You'll see  
12 the different timing in some of the lines because  
13 ultimately that particular line will be needed for any of  
14 the alternatives. That's why the different timing.

15 Q Mr. Pope, then would some of these transmission  
16 upgrades mentioned in the response to Interrogatory 4, or  
17 the additions, depending, have been required regardless of  
18 whether the proposed unit was added to Gulf's system?

19 A Once again, it's the not-for philosophy.

20 Q Okay.

21 A If not for this addition or if not for this  
22 option, that unit would not be needed in the time frame,  
23 the planning horizon.

24 Q Okay.

25 A Ultimately I could say on any of these, that

1 In this response to Interrogatory Number 4, does this  
2 contain Gulf's summary of all transmission additions and  
3 upgrades required as a result of the self-build options in  
4 the RFP project?

5 A That is correct.

6 Q Okay. Referring again to POD 4, if you could,  
7 please describe briefly the timing of these different  
8 additions. You know, I see some are 2002 improvements here  
9 for the various transmission lines, and then there's 2009,  
10 2005, et cetera. Why did each option that Gulf reviewed  
11 have different transmission system impacts, and why were  
12 new lines needed instead of upgrading old lines in certain  
13 cases?

14 A First, and let's talk about any individual  
15 analysis, whether it be Respondent A, B, or C or Gulf Smith  
16 Unit 3. When you identify a constraint in transmission,  
17 there are a number of different alternative solutions, some  
18 are just putting up different conductor on existing lines,  
19 some are building new lines. The Company always looks far  
20 enough out to see whether a particular improvement, such as  
21 changing the conductor, would last long enough because that  
22 buys you a little bit of capacity but maybe it does not buy  
23 you enough long-term; and you have to add up all the -- if  
24 you choose one route, you have to add up all those  
25 particular costs and find out what their present value is

1 the analysis. So, yes, it does; but that's just by nature  
2 of the way we studied it.

3 Q Okay. This would have been in response to  
4 staff's Request for Production of Documents Number 2.  
5 There were some documents that were filed which have been  
6 returned to the company, and we would like to get those  
7 provided again as a late-filed exhibit.

8 MR. MELSON: This will be confidential late-filed  
9 Exhibit Number 2?

10 MS. JAYE: Yes. We'll give it the title of  
11 transmission studies if that comports.

12 MR. MELSON: Now do you want the -- all the  
13 detail supporting studies, or would the summary sheets  
14 be sufficient?

15 MS. JAYE: We can go off the record for a moment  
16 and give you a chance to --

17 (DISCUSSION OFF THE RECORD)

18 MS. JAYE: Go back on the record.

19 BY MS. JAYE (Continuing):

20 Q This Late-filed Deposition Exhibit Number 2, for  
21 further clarification for the title will be transmission  
22 study summaries.

23 If you'd turn to Gulf's response to Staff  
24 Interrogatory Number 4. There is a listing here of the  
25 transmission improvements required. Does this contain --

1 you'll look at generation, basically between Jacksonville  
2 and Mobile, there's a great disparity, and power is going  
3 to flow wherever it needs to to get to the load.

4           As I mentioned earlier, the ideal situation is  
5 where you have load is to put a like amount of generation,  
6 and that's not the case today; so, therefore, the  
7 generation that is in the Mississippi, Gulf Coast, Florida  
8 Gulf Coast area, large amounts of it predominantly has to  
9 flow toward the east to make up flows in that direction.  
10 There are power sales also to Florida which help to cause  
11 that, not a major portion because a lot of that comes from  
12 north Georgia down through a five hundred kv system.

13           Q     Did Gulf perform any transmission studies on how  
14 each of its self-build options in the RFP projects impacted  
15 the Southern Company transmission system?

16           A     Could you repeat that one more time?

17           Q     Did Gulf perform any transmission studies on how  
18 each of the self-build options in the RFP responses  
19 impacted the Southern Company transmission system?

20           A     The transmission analysis that we performed by  
21 nature will identify all transmission impacts on the  
22 Southern Electric system. Our model contains the entire  
23 Southern Company system even though we may only print out  
24 those areas that are adjacent to Gulf and including Gulf.  
25 The listing of all overload conditions will be listed on

1 amount of generation if you add all that together; and  
2 loads and flows that typically go from those areas, the  
3 west, toward the east, also add to the aggravation of the  
4 transmission system between basically Pensacola or Mobile  
5 and the Apalachicola River. As I said, the load in the  
6 Panama City area has exceeded Panama City and the -- I  
7 guess east of Ft. Walton area has exceeded what's generated  
8 there plus other flow. So adding generation in Panama City  
9 helps both of those factors, not just necessarily the load  
10 generation mismatch.

11 Q Is part of the mismatch that occurs and part of  
12 the reason why putting the generation in Panama City due to  
13 the nature of the flow of electricity?

14 A Yes.

15 Q Okay. Could you elaborate on that, please?

16 A The nature of the flow?

17 Q Flow of electricity, yes.

18 A Even today, without additional generation being  
19 located in the Mississippi, Gulf Coast, Mobile area or to  
20 the west of here, the predominant flow pattern is from the  
21 west toward the east. In southwest Georgia, south Georgia  
22 there is very little generation. Panama City, very little  
23 generation. No generation in the Ft. Walton Beach area.  
24 There's still considerable amounts of load in those areas.  
25 There is a large nuclear plant in Dothan, Alabama; but if

1 different locations. Many of the locations carried with it  
2 a tremendous amount of transmission improvements because of  
3 not being located near the load. Gulf Power Company today  
4 with its existing generation and load is deficient because  
5 we own generation facilities already outside of Gulf's  
6 territory, so we are already bringing in significant  
7 portions of our load. This is further aggravated when you  
8 install other generation or newer generation outside of  
9 Gulf's territory when there's still a significant amount of  
10 load for them to meet. The transmission system, because of  
11 the load conditions, would require improvements for all  
12 generation not located in the Panama City area. It's  
13 because of these costs of the transmission that Panama City  
14 was the best location, and transmission improvements drove  
15 that, a lot of that.

16 Q In general then would you agree that there would  
17 be a disparity between load and generation in the Panama  
18 City area?

19 A It's not necessarily the load specifically in the  
20 Panama City area, although that is a major portion of it.  
21 As I mentioned earlier, there is load to be served and  
22 there is generation.

23 Currently, and in the future, generation is  
24 located in the Mississippi Gulf Coast area, the Mobile  
25 area, also in the Pensacola area, because there is a large

1 to be stressful to the system, we will analyze -- well, not  
2 we, but the system operators will analyze the system that  
3 day with what they call a security package and determine if  
4 there are any problems from a unit out, or the next line  
5 out. And they will formulate operating procedures if need  
6 be or have a plan of action for moving customers if need  
7 be. So planning identifies most of those situations, but  
8 sometimes they don't from an operational standpoint. The  
9 operating procedures we identify in the planning side of it  
10 are provided to and agreed to by the operating folks and in  
11 a manual where when those conditions exist they know what  
12 to do.

13 Q Mr. Pope, could you describe why Gulf picked  
14 Panama City, Florida for location of a new unit?

15 A Panama City, Florida, from a transmission -- from  
16 a cost basis, is the best. One of the major factors of  
17 cost is transmission improvement. A key factor in the  
18 power industry is that you have load obligations to meet  
19 with generation. It's best to put the generation where the  
20 load is. That can't always be done, so you put generation  
21 where it can be installed and build transmission facilities  
22 to meet the load, to get the power to the load, under  
23 reasonable reliability constraints.

24 In evaluating Gulf's need to have generation on  
25 the ground, physical facilities, we looked at a number of

1 What's the probability that that combination of units and  
2 lines would occur? What is the consequence of it? Is it a  
3 situation where the next thing that happens brings the  
4 system into complete collapse or brings serious concern?  
5 What is the severity of it? Does it put a large amount of  
6 megawatts or customers at risk? Is it something that is  
7 critical for the company's customer service aspects? We  
8 look at those risks and consequences -- Oh, also, is there  
9 some way we can operate the system differently or at that  
10 time to eliminate the problem?

11 And you take all those into consideration and you  
12 make a determination of, yes, we can live with that, or we  
13 can afford that risk; or, no, we can't, and we need to  
14 spend money to fix it. Many times we have operating  
15 procedures that we can take from a planning basis, we'll  
16 take these facilities out, we'll run the model again with  
17 those conditions, and if it alleviates the problem and that  
18 those conditions are not too risky, that's the way we'll  
19 operate the system.

20 That brings me over into the operation of the  
21 system. Dynamically, day by day, the system is operated  
22 under the conditions that exist at the time. Those may or  
23 may not be what we plan the system for. Strange things  
24 happen on a day-to-day, real-world basis; but on a daily  
25 basis, if the system is in a configuration that is thought

1 for this unit, then don't worry about it.

2 Q Okay. Could you give a general description of  
3 the operation of Gulf's transmission system; that is, the  
4 power flow system constraints, generation load imbalances?

5 A Yes, from a -- I'll give it in two ways.

6 Q Okay.

7 A There's a transmission planning aspect of it, and  
8 I'll give a brief overview of the operational aspects of it  
9 which are very similar. The planning of the Gulf Power  
10 Company in the Southern Electric system is conducted now  
11 assuming what we call a two element contingency. That's  
12 any line and a unit, any auto transformer and a unit, or  
13 any auto transformer and a line.

14 We plan the system at peak conditions. We also  
15 look at it at off peak periods to see how unit maintenance  
16 occurs, but predominantly we try to meet peak. Peak is  
17 when our toughest times from a transmission standpoint  
18 occurs. We assume the system over a number of years is at  
19 peak. We take critical units out, and then we outage or  
20 take out every line with this system and identify all  
21 overloaded facilities.

22 Once that study is completed, that portion of the  
23 study is completed and those overloaded facilities and low  
24 voltage conditions are identified, we secondly take those  
25 conditions and analyze the risk and consequences of them.

1 say, in Georgia or in Alabama?

2 A I'm trying to remember because we have some  
3 answers to interrogatories -- you referred to the need  
4 study -- and we may have to refer to those. There are some  
5 impacts to -- in some of the evaluations, particularly the  
6 self-build evaluations, the initial self-constructed, which  
7 also had cost impacts for lines in the Alabama territory  
8 that would be caused by Gulf's generation.

9 Q Right. I understand that under Interrogatory 4,  
10 but how far would Gulf carry that, I guess is what I'm  
11 trying to get at. How far away would Gulf carry that in  
12 evaluating the impacts on transmission need forced by  
13 different additions?

14 A The only transmission impacts that Gulf would  
15 include as a cost would be those that are totally  
16 associated with the increment of generation that Gulf would  
17 participate or build in any instance, not anything outside  
18 that has nothing to do with that.

19 Q Okay.

20 A I believe, if I can carry that on just a little  
21 bit further to make it clearer, it's kind of like the  
22 not-for analysis. If not for this unit, this would not be  
23 needed.

24 Q Right.

25 A So that's the kind of approach we take. If not

1           A     The prices that Gulf will ultimately come down to  
2 with whichever supplier they choose will be no more than  
3 what has been assumed. It will likely be less.

4           Q     All right. Mr. Pope, the next series of  
5 questions that I wanted to ask you refer to the impact of  
6 the proposed unit, other self-build options, and the RFP  
7 projects on the transmission system at the Southern  
8 Company. When transmission studies are performed  
9 concerning the impact of proposed generating unit additions  
10 for Gulf, does Gulf perform these studies or does Southern  
11 Company?

12          A     Southern Company Services performs the studies.

13          Q     Okay. Are the analyses based on impacts on Gulf  
14 Power service territory or on the entire Southern Company  
15 system?

16          A     The impacts -- the study will identify impacts to  
17 the entire Southern Electric system from any various  
18 generation additions. The ones that we are concerned with  
19 are the ones that are directly related to generation  
20 additions that we would participate -- and the increment of  
21 generation that we would participate in.

22          Q     Okay. So the only transmission upgrades that  
23 are -- that show up in the need study as being necessary,  
24 given the various options and as they are screened, are  
25 those that directly affect Gulf, not those that may start,

1 self-build, self constructed evaluation, that particular  
2 option was discarded because of the reliability concerns.

3 That being concluded then we move on to the RFP  
4 process where we were provided with offers subject to a  
5 separate natural gas transportation RFP issue by Southern  
6 Company Services, all of which deal with firm natural gas  
7 supply that we evaluated along with our construction of a  
8 pipeline. All of these are firm supplies. All the  
9 respondents to that RFP that were not firm have been  
10 discarded. So all that we are dealing with now are firm  
11 natural gas supplies and no secondary non-firm supplies for  
12 this unit.

13 Q Could you tell me, what are the numbers of  
14 suppliers that you are dealing with now?

15 A I believe we still have four suppliers that we  
16 are continuing to talk with or keeping negotiations open  
17 with.

18 Q Okay. Have you entered into final negotiations  
19 with any of these suppliers yet?

20 A Not to my knowledge at this time.

21 Q Would you expect that the price that is finally  
22 accepted by Gulf in negotiations with these four suppliers  
23 would be comparable to or cheaper than the prices that were  
24 used by Gulf in evaluating the different proposals in the  
25 need study itself.

1 MS. JAYE: Okay. Could we go off the record a  
2 minute, please?

3 (DISCUSSION OFF THE RECORD)

4 MS. JAYE: Back on the record.

5 BY MS. JAYE (Continuing):

6 Q Does the information provided in the need study  
7 include the most up-to-date information that Gulf has  
8 received on purchase of capacity for natural gas to fire  
9 the proposed unit?

10 A Yes, in portions of the need study. I want to  
11 make sure that we're clear. You asked a question about the  
12 latest and the final analysis and evaluations.

13 Q Yes.

14 A I need to explain the phases of our evaluation  
15 that dealt with different natural gas assumptions. For  
16 instance, what we did in the initial phase, the self-build  
17 evaluations, that were concerned with self-construction  
18 options, were to look at a number of various natural gas  
19 supply alternatives. One was the natural gas pipeline from  
20 the Atmore area. Another one that has a more attractive  
21 economic picture is to use release firm or a non-firm type  
22 of gas transportation. That particular option of the  
23 release firm or non-firm type of transportation was very  
24 comparable to the natural gas pipeline; however, it's not  
25 firm, it's not reliable. And at the conclusion of the

1 but Exxon permitted a pipeline, about a 58-mile pipeline,  
2 from the Destin Dome wells, a number of wells that would  
3 feed into this pipeline and bring that gas on shore into  
4 the Mobile area. That's the Destin Dome pipeline.

5 Q On Page 57 there is a discussion of Gulf  
6 constructing its own pipeline to the Atmore, Alabama area.  
7 What is in Atmore, Alabama? Is there a major gas  
8 transmission line there?

9 A There are two major natural gas pipelines,  
10 transmission lines that are in the Atmore, Alabama area.  
11 One is owned by Florida Gas Transmission, the other by  
12 Koch. That's K-o-c-h.

13 Q Referring now to Page 73 of the need study, does  
14 Gulf Power have a firm transportation agreement with FGT?

15 A Not at this time.

16 Q Okay. Does Gulf Power plan on purchasing 100%  
17 firm capacity off the secondary market if it does not get  
18 that capacity from FGT?

19 A I don't believe so. Our entire focus is from a  
20 natural gas supply strategy, and all efforts have been  
21 secure, and we've been involved in conversations and  
22 negotiations with various suppliers for a firm natural gas  
23 supply. We have had offers of firm natural gas supply. I  
24 am not aware and don't believe that we have even considered  
25 a secondary non-firm supply.

1           A     Go ahead.

2           Q     All right. Now these interrogatories appear to  
3 itemize capital and O&M cost for SCR system and closed  
4 cycle cooling tower system. Do you expect Gulf Power to  
5 seek recovery of these costs through the environmental cost  
6 recovery clause?

7           A     I don't know. Once again, our focus in this  
8 proceeding is for cost effectiveness purposes, and I'm not  
9 certain as to what may come as far as recovery for these.

10          Q     Okay.

11           MS. JAYE: Would it be all right if we took about  
12 a two-minute break?

13                   (BRIEF RECESS)

14           MS. JAYE: Ready to go back on the record.

15 BY MS. JAYE (Continuing):

16          Q     On Page 56 of the need study there are some  
17 discussions of various gas suppliers and gas transmission  
18 possibilities. Could you please explain, what is Destin  
19 Dome pipeline?

20          A     There is an area offshore of the Alabama and  
21 Florida, northwest Florida coast that is commonly referred  
22 to as the Destin Dome. It's a large area out in the Gulf  
23 where there are significant natural gas supplies, and  
24 they've called or dubbed that the Destin Dome.

25                   I forget if it's been three or four years ago,

1 discharge canal is going to depend on the ambient  
2 temperature or ambient conditions at any time. But it  
3 means that whatever the situation is at the time, if you  
4 take the Smith 3 cooling water design, you will slightly  
5 decrease what otherwise would be there without it.

6 Q Okay. You answered both the questions. I now  
7 have four questions referring to Gulf Power's response to  
8 staff's Request for Production of Documents Number 18.

9 A Okay.

10 Q In response to this request for production, Gulf  
11 provided a letter to Mr. Greg Worley of the U.S. EPA in  
12 Atlanta, from G. Dewayne Waters. This letter is dated  
13 April 6, 1999. Mr. Pope, are you familiar with this  
14 letter?

15 A I'm not intimately familiar with it, but I am  
16 aware of it and kind of know what it says.

17 Q Okay. Do you know if Gulf Power has received a  
18 response from the EPA yet regarding --

19 A I'm not aware of any formal response yet. I  
20 believe this is just a letter of notification to them of  
21 what we plan to do.

22 Q Okay. The next question is referring to Gulf  
23 Power's response to staff's Interrogatories Number 23 and  
24 24. Give you a chance to look those up quickly.

25 (WITNESS REVIEWED DOCUMENTS)

114

1 strategy, go on and put SCR. I mean that would be  
2 different than -- We may not have a choice. They may tell  
3 us. We don't think that's going on happen. We think  
4 there's a high likelihood if not a very positive attitude  
5 or likelihood that we are going to have the NOx offset  
6 accepted without SCR.

7 To answer your question as far as having to,  
8 we'll -- Gulf Power Company is going to do whatever is  
9 required of it to meet all state, federal laws and  
10 regulations with regard to the environment.

11 Q My next two questions are taken from Gulf Power's  
12 response to staff's Interrogatory Number 25. In this  
13 interrogatory the response states in part, "Because the  
14 blow down from Smith Unit 3 will be taken from the cold  
15 side of the cooling tower, there will be a slight decrease  
16 in the overall temperature of the discharge water entering  
17 West Bay."

18 My first question is when Gulf Power claims a  
19 slight decrease in the overall temperature of the discharge  
20 water will result, does a slight decrease refer to a  
21 decrease from the current temperature of the discharge  
22 water?

23 A It means a slight decrease as opposed to without  
24 the Smith Unit 3 being there, or without -- with some other  
25 means of cooling because the temperature coming out of the

1 (DISCUSSION OFF THE RECORD).

2 MS. JAYE: Let's go back on the record now.

3 BY MS. JAYE (Continuing):

4 Q Okay. I have three -- I'm sorry, the following  
5 two questions will refer to the first full paragraph on  
6 Page 76 of the need study, the paragraph which begins, "As  
7 mentioned above."

8 A Okay, I found that paragraph.

9 Q Okay. Does Gulf Power plan to install the SCR  
10 only if the low NOx burner technology and GNOCIS fail to  
11 reduce the NOx emissions at Smith Unit 1 to approximately  
12 28 hundred tons per year?

13 A The determination of environmental compliance is  
14 going to be determined by the environmental folks, and I  
15 think it's safe to say that it's our strategy and our  
16 proposal that the offset by having a total NOx reduction  
17 strategy at Smith should not only be accepted but should  
18 be, I guess, welcomed. It's a total -- it actually reduces  
19 overall NOx emissions, and we believe, pretty confidently  
20 that that will be accepted so that the burners and the  
21 GNOCIS would be accepted and installed.

22 Now you asked, you know, would we only do this if  
23 we didn't meet it? Well, the environmental -- the  
24 environmental process may go or change things to where they  
25 say, that's all well and good, but we don't accept your

1 SCR. The GNOCIS system and the burners cost about two  
2 million dollars. The SCR cost about three million plus  
3 about a million dollars a year in O&M. In a conservative  
4 nature, we put the SCR cost, both capital and O&M in the  
5 cost effectiveness analysis knowing that the better  
6 alternative would probably be accepted at a lesser cost, so  
7 we have erred in the conservative nature of actually a  
8 higher cost, it's an either or. So, no, it's, not  
9 specifically included, but it's well covered.

10 Q Okay. Mr. Pope, there would be a reduction of  
11 emissions, according to your analysis, if a low NOx burner  
12 technology and the GNOCIS system are used on the Smith  
13 unit. Could you go into some detail and explain what the  
14 current emissions are and how the low NOx burner technology  
15 and GNOCIS will help reduce that in relation to the SCR  
16 that is included in the cost effective analysis for the  
17 Unit 3?

18 A I can respond to that in, I guess, an overview or  
19 overall fashion. I cannot tell you the exact NOx emissions  
20 out of the existing units, Smith 1 and 2.

21 Q Right.

22 A But we can take a hypothetical if you'd like and  
23 show how this would work.

24 MS. JAYE: Could we go off the record a moment,  
25 please?

1 in reference to Gulf Power's response to Staff  
2 Interrogatory Number 22. About midway down Gulf's response  
3 there is a sentence which reads, "Gulf Power will  
4 accomplish the reductions through installing low NOx burner  
5 technology and GNOCIS, a generic NOx control intelligent  
6 system on Unit 1." Have you located that sentence?

7 A Uh-huh.

8 Q Okay. Are the costs associated with the low NOx  
9 burner technology and GNOCIS included in Smith Unit 3's  
10 cost estimate?

11 A Not specifically.

12 Q Okay.

13 A We -- in looking at the cost effectiveness of the  
14 Smith option, you are either going to install selected  
15 catalytic reduction equipment for NOx or some other  
16 alternative, which in this case would be the low NOx  
17 burners and the GNOCIS system on Smith 1. The selected  
18 catalytic reduction system, or SCR which I'll refer to from  
19 here on out, will reduce the emissions of Smith 3, the new  
20 unit; but the overall NOx emissions from Smith plant will  
21 go up.

22 Gulf's strategy with this new addition was to  
23 offer a little better alternative; and that is, to reduce  
24 the NOx emissions from Smith 1 to the extent that it more  
25 than accounted for the emissions of the new unit without

1 Q Okay. Returning again to the table in response  
2 to POD 16, staff noted that Respondent A has under  
3 commodity price basis column Henry Hub plus 4%. Does this  
4 indicate that Respondent A's bid was evaluated based upon a  
5 natural gas commodity forecast which is 4% higher than the  
6 Henry Hub index itself?

7 A We have no idea of knowing what assumption caused  
8 that respondent to add a 4% premium to his Henry Hub  
9 index. That was his quote to us.

10 Q Okay.

11 A Their quote to us.

12 Q Okay. Looking at the table again, the self-build  
13 Smith option, commodity price adjustment is a negative  
14 .06. Does this indicate that the self-build Smith option's  
15 bid was evaluated based upon natural gas commodity forecast  
16 which is six cents less than Henry Hub?

17 A That's correct.

18 Q Okay. In looking at the respondents indicated in  
19 the column, if two alternatives which appear here have the  
20 same commodity price basis and the same commodity price  
21 adjustment, you know, Column A and Column B are the same,  
22 would these alternatives have the same natural gas price  
23 forecast?

24 A For commodity, yes.

25 Q Okay. The next three questions are going to be

1           A       Between the self-build evaluation, which were  
2 self-constructed options only, and the RFP response, there  
3 were different opportunities from a natural gas supply that  
4 came available. In the initial phase, which is your  
5 self-build, self-constructed evaluation, the primary  
6 winner, I guess, or primary cost effective natural gas  
7 supply dealt with construction of a natural gas pipeline of  
8 some miles to the Smith plant that we would be willing to  
9 under take. It carried with it a certain set of  
10 assumptions. In the RFP evaluation, with the same Smith  
11 construction, it had different natural gas supply  
12 opportunity, not the construction of the pipeline; and so  
13 it carries a different set of assumptions.

14           Q       Did the self-build Smith option then include Gulf  
15 self-construction of pipeline to carry natural gas down to  
16 the proposed plant?

17           A       The self-build option, the initial phase?

18           Q       Yes.

19           A       Yes, it did.

20           Q       Okay. And --

21           A       In the form of constructing a pipeline from near  
22 Atmore or Brewton, Alabama, to the Smith site.

23           Q       And the RFP Smith option then included having a  
24 third party construct a pipeline to carry the gas?

25           A       That is correct.

1 or in eastern Texas, but I can give you a better answer if  
2 allowed to.

3 Q Okay. We'll move on then.

4 For purpose of evaluating the most cost effective  
5 alternative, how does Gulf Power define "Commodity Price  
6 Adjustment" as found in the last column?

7 A The commodity price adjustment are things that  
8 will be added to or should be added to a commodity price  
9 because of a premium, for instance. People may want to  
10 charge you a premium from, say, Henry Hub or some other  
11 basis place to a certain point where you are going to take  
12 it off the natural gas pipeline. There may be some O&M or  
13 compression charges that may go along with that because of  
14 compression services that go in between that point and  
15 there, not transportation, but compression services, or  
16 other increments that would be added to that fuel commodity  
17 not associated with transmission, just that are associated  
18 with the fuel commodity itself.

19 Q Noticing the numbers that fall under the  
20 commodity price adjustment in the response to Staff  
21 Interrogatory 16, some of them are in brackets. What does  
22 that indicate?

23 A That's a negative number.

24 Q Okay. How does Gulf Power distinguish between  
25 the self-build Smith option and the RFP Smith option?

1 effective alternative, how does Gulf Power define  
2 "commodity price basis?"

3 A Where is that in the --

4 Q It's at the very bottom. It's one of the middle  
5 columns. It's titled "Commodity Price Basis."

6 A Oh, okay. In either the self-build options or in  
7 the offers, people are given the opportunity to choose an  
8 index basis. Like in oil it could be the Portland, Oregon  
9 received -- has received Number 2 oil price, or it could be  
10 the Number 6 oil price as received at Savannah Port. For  
11 natural gas these are on-shore type of indices, and there  
12 are some common ones. In this area of the country, one of  
13 the most common ones is Henry Hub, and that's where you  
14 base -- you can say, okay, as-delivered price to that point  
15 plus all transportation, taxes, O&M, and other things; but  
16 they have to give a basis for what commodity price point  
17 they want things to be delivered to, to use as a basis for  
18 delivery point.

19 Q Okay. Could you please explain where Henry Hub  
20 is in relation to Gulf Power Company? Is this something in  
21 the midwest or --

22 A I can't give you that exactly, but I could  
23 provide it later.

24 Q Okay.

25 A I believe -- I believe it's either in Louisiana

1 MR. MELSON: Could you list again what it is you  
2 are looking for?

3 MS. JAYE: Certainly.

4 MR. MELSON: It's the fuel assumptions for --

5 MS. JAYE: What we would like is information, the  
6 confidential information which would be in response to  
7 staff's Request for Production of Documents Number  
8 15.

9 THE WITNESS: Okay, that's '95 IRP, 1996 update?

10 BY MS. JAYE (Continuing):

11 Q Right, 1997 IRP update, 1997 capacity  
12 solicitation, 1998 full IRP, and 1999 IRP update. And what  
13 staff is looking for are documents which the fuel panel  
14 relied upon to create the Southern Company generic fuel  
15 price forecast which was used in those years.

16 A Oh, okay.

17 MR. MELSON: Off the record a minute.

18 (DISCUSSION OFF THE RECORD)

19 BY MS. JAYE (Continuing):

20 Q I have six questions -- Back on the record. I'm  
21 sorry.

22 I'm now going to ask six questions in response to  
23 Staff Interrogatory Number 16.

24 A Okay.

25 Q For purposes of evaluating the most cost

1           A     The assumptions on Page 51 of the need study are  
2 based on 1996 financial assumptions. They're also reported  
3 in response to Interrogatory Number 13 along with the '97  
4 and '98 information which we relied upon.

5           Q     Okay. And the financial assumptions for 1996 and  
6 1997, we note that Gulf used DRI Trendlong forecast to  
7 project out financial information, but in 1998 the company  
8 switched to Regional Financial Associates. Do you know why  
9 this was done?

10          A     I don't know the specific reason why that was  
11 done.

12          Q     All right. Mr. Pope, I'm now going to ask you  
13 some questions in order to clarify responses received  
14 regarding Gulf's fuel price forecast assumptions. Do you  
15 have the documents which the fuel panel relied upon to  
16 create the Southern Company generic fuel price forecast  
17 used in the 1995 full IRP, 1996 IRP update, 1997 IRP  
18 update, 1997 capacity solicitation, 1998 full IRP, and the  
19 1999 IRP update?

20          A     No, I don't have. I have some '98 information  
21 with me.

22          Q     Okay. Could you please provide this information  
23 in a late-filed exhibit? We will call this the IRP  
24 exhibit. We'll amend that name and call it IRP fuel  
25 exhibit.

1 Q Do you know the benchmark for the consumer price  
2 index or any of those things that went into the need study?

3 A No, I don't. Not specifically, no.

4 Q Mr. Pope, do you know the year that the rates  
5 applied these CPI, GDP, et cetera? Were they using '97,  
6 '98?

7 A Not specifically, no, but I do know they used the  
8 latest information. I don't know if it would be third  
9 quarter or second quarter information from those sources.

10 Q In 1996 and 1997 Gulf used the DRI Trendlong  
11 Forecast, but in 1998 the company used the Regional  
12 Financial Associates. Could you explain why Gulf switched  
13 services?

14 A Are you talking about the -- you're talking about  
15 forecast information there, the load forecast?

16 Q Yes.

17 A I do not know. If you're talking about load  
18 forecast, that would be Mike Marlar.

19 MS. JAYE: Could we go off the record for a  
20 moment?

21 (DISCUSSION OFF THE RECORD)

22 MS. JAYE: Let's go back on the record then.

23 BY MS. JAYE (Continuing):

24 Q Mr. Pope, could you please tell what year these  
25 assumptions on Page 51 of the need study are based on?

1 in five years. These people in Atlanta gather this  
2 information. They're analyzing it and trying to put some  
3 regional factors into place for the southern, southeastern  
4 United States to come up with what they think are the  
5 reasonable escalation and construction -- or inflation and  
6 construction escalation would be.

7 The inflation comes directly from those people in  
8 Atlanta. The construction escalation is derived by the  
9 people in Southern Company Services engineering in  
10 Birmingham. They take basically the information from the  
11 economic people in Atlanta, they look at what recent  
12 equipment and salary or labor rate increases have been, and  
13 they come up with a construction escalation. So that's the  
14 how from what I know.

15 Q Okay. Do you have any idea of whether the  
16 escalation rate of 3.02% that is a product of the people,  
17 Southern Company Services in Atlanta was derived from  
18 Moody's or from DRI, do you know which they rely on?

19 A They don't rely on just one, they rely on a  
20 number of indicators and factors that are provided and  
21 brought together and discussed, and it's not just one, no.  
22 It's not one.

23 Q Do you know what was the benchmark for the  
24 general inflation rate that was used in the need study?

25 A No. No, I don't.

1 you're consistent. And the reason 13 and a half percent  
2 was selected as opposed to 12, which is our center range,  
3 is because we looked at this as a Southern System type of  
4 evaluation, for cost effectiveness purposes.

5 Q Mr. Pope, if you could please turn to Page 51 of  
6 the need study.

7 A Okay.

8 Q On this particular page, the Company reports a  
9 construction escalation rate of 3.02% and a general  
10 inflation rate of 2.78%. Could you please explain how  
11 these rates were derived?

12 A The details of how I -- I can just give an  
13 overview.

14 Q Okay.

15 A We have a group of people in Atlanta with  
16 Southern Company Services that put together, I guess, all  
17 of the economic indicators from all economic sources. I  
18 can't remember if these are all the right ones now, but the  
19 DRI and people similar, Moody's and Standard and Poors.  
20 They all have predictions of what near-term and long-term  
21 bond rates would be and what certain other earnings would  
22 be. They also give indicators of your general deflators,  
23 your inflation, your escalation, your other indicators that  
24 are expected because of what the economy is doing at any  
25 point in time and what they expect it to do, particularly

1 self-build and the authorized ROE of Gulf which ranged  
2 between 11 and 13% during the time the valuations were  
3 done?

4       A     As I mentioned earlier, the view of these  
5 analyses from the very beginning was from a Southern view  
6 as far as cost effectiveness, try and see what it brings  
7 from a Southern Electric System or Southern Company type  
8 view. We're determining cost effectiveness of these  
9 alternatives, and Gulf's self-build option, Smith Unit 3,  
10 is part of it. It's cost effectiveness, and the reason  
11 that we don't necessarily think that we need to do it based  
12 on Gulf's allowed return, the center range is 12% which  
13 allows us to earn between 11 and 13% before refund or  
14 before other things happen is because it's not an issue of  
15 recovery or what the rates would be. We're not looking at  
16 what rate impacts would be which we would analyze the  
17 allowed rate of return. It's an issue of cost  
18 effectiveness, and that's why it's really, even though it  
19 is different, it's not invalid or unreasonable; and it is a  
20 correct way of analyzing cost effectiveness, as long as you  
21 treat everyone consistent. Like I said, it actually gives  
22 Gulf's self-build option a slight disadvantage by assuming  
23 a higher rate of return, but that's why. It's not -- the  
24 cost effectiveness evaluation does not necessarily have to  
25 be predicated on your allowed rate of return but as long as

1 the discount at which you discount in present worth your  
2 numbers. The rationale there was we could use 12 and a  
3 half percent or 13% or 13 and a half or 14%, and when  
4 you're talking about evaluating things all at the same  
5 time, you want to use a consistent basis more than  
6 anything; and we chose the Southern System because it was  
7 more or less a Southern type of an evaluation.

8 We carried that philosophy and that assumption  
9 forward into, when we moved to the 1998 assumptions and did  
10 the RFP evaluations. Understanding that the 13 and a half  
11 percent equity rate would raise the cost, the capital --  
12 revenue requirement stream for Gulf self-build option. It  
13 also lowers the discount rate, but if you do the same for  
14 Gulf self-build as you do for all others, you are still  
15 treating everybody equal; and actually you are giving Gulf  
16 a hit on its self-build by its present worth revenue  
17 requirements being higher. And it was still considered to  
18 be a Southern evaluation, and that's why we did it.

19 MS. JAYE: We need to go off the record for a  
20 moment.

21 (DISCUSSION OFF THE RECORD)

22 BY MS. JAYE (Continuing):

23 Q Mr. Pope, if you could please explain the  
24 relationship between the 13.5% that you used as a cost of  
25 equity for evaluating all of the Gulf proposals in

1 the cost effectiveness of this project?

2 A That's correct. That's the calculation for  
3 calculating the after-tax weighted average cost of capital,  
4 and that is what we used.

5 Q Okay. What is the overall cost of capital  
6 factored into the calculation of the cost effectiveness of  
7 this project now?

8 A For cost effective purposes, it's still the same.  
9 It's 8.465%. That's according to the '98 -- 1998 financial  
10 assumptions.

11 Q Okay. So Gulf used the 1998 data to calculate  
12 the overall cost of capital?

13 A Correct. Correct, that's for all of those RFP  
14 responses which is Gulf self-build and all of the offers  
15 that came out of the RFP.

16 Q Would you please explain why Gulf used a 13.5% as  
17 the cost of equity in its financial assumptions?

18 A The analysis and evaluations were performed by  
19 Southern Company Services, and the initial phase, which was  
20 the self-build option phase evaluation, we -- because we  
21 were looking at participating in sister units and because  
22 this is a Southern System type of evaluation, we at that  
23 time deemed that we would use the Southern System assumed  
24 rate of return to calculate the after-tax weighted average  
25 cost of capital. The key element there for that factor is

1           A     Not the early or initial self-build evaluations.  
2     As I mentioned earlier, the final determination, as you  
3     asked, the final determination of cost-effective  
4     alternatives were those that were evaluated in the RFP  
5     process. All of those in the RFP process use the 1998  
6     assumptions. The self-build analysis, which was the  
7     initial phase of identifying Gulf's self-build option or  
8     best self-build option, used the '97, 1997 financial  
9     assumptions because it was conducted starting in 1997; and  
10    that involved the evaluation of about four  
11    self-construction options. And we went through that  
12    process using those and have not gone back at this time and  
13    updated those because, once you've gotten to that point and  
14    moved to where of all your construction options this one is  
15    the one you want to move forward with and see if there are  
16    other alternatives, then there is no need to go back and do  
17    that. Now Smith 3, which was the selected self-build  
18    option was carried forward, it has been updated, but all of  
19    those others we evaluated were not.

20           Q     In Gulf's response to staff POD Number 11, we are  
21    told, "See the response to Production of Documents Number  
22    10 and the sample calculation contained in response to  
23    Interrogatory 14b." Looking now at interrogatory 14b, I'd  
24    like for you to please explain, is this the way that Gulf  
25    actually calculated the discount rate used in evaluating

1 Q In Gulf's response, there is the statement that  
2 unfortunately the need study only included the financial  
3 assumptions from 1996, and it goes on to say that Gulf will  
4 provide all three sets of financial assumptions to  
5 demonstrate their similarity and consistency. My first  
6 question regarding these, is upon which of these three sets  
7 of data did Gulf base its final evaluation of the cost  
8 effectiveness of the self-build option?

9 A It would be the financial assumptions for 1998.

10 Q Okay. Did Gulf use the same financial  
11 assumptions in evaluating all of these alternatives?

12 A In the final evaluations?

13 Q Yes.

14 A Yes.

15 Q Has Gulf revised all of the cost estimates of the  
16 project to reflect the most recent rates as of 1998?

17 A I'm not sure I understand the question.

18 Q Could we go off the record for a minute?

19 A Sure.

20 (DISCUSSION OFF THE RECORD)

21 MS. JAYE: Go back on the record.

22 BY MS. JAYE (Continuing):

23 Q I'll ask the question again. Has Gulf revised  
24 all the cost estimates of the project to reflect the most  
25 recent rates as of 1998?

1 Company power plant for six years. I was then given the  
2 opportunity to be supervisor of system planning up until  
3 about May of 1993 when I became the coordinator of bulk  
4 power planning.

5 Q In the position as coordinator of bulk power  
6 planning, do you deal with a lot of the need determinations  
7 and need filings for Gulf and by extension Southern?

8 A This is our first one in many, many years; but in  
9 my position it would be the position that's normally  
10 associated with need determinations for the company.

11 Q Okay. So you're the person to ask questions  
12 concerning most of the overview of need and need  
13 determination cases?

14 A Need planning aspects, yes.

15 Q Okay. Very good.

16 I'm going to ask you a few questions now  
17 regarding Issue Number 6 from the issue identification  
18 conference. The first one is to clarify the responses that  
19 staff received regarding the financial assumptions backing  
20 Gulf's responses. Do you have a copy of the Gulf responses  
21 to staff interrogatories with you?

22 A I certainly do.

23 Q Okay. If you would please turn to the response  
24 to Interrogatory Number 13?

25 A I have it.

1 Whereupon,

2

WILLIAM F. POPE

3 was called as a witness by the FPSC Staff and, after being

4 first duly sworn, was examined and testified as follows:

5

6

DIRECT EXAMINATION

7

BY MS. JAYE:

8

Q Good morning.

9

Nancy, could you please insert all the usual  
10 stipulations language there? Thank you.

11

Good morning, Mr. Pope.

12

A Good morning.

13

Q Could you please state your name for the record

14

please?

15

A William F. Pope, Gulf Power Company.

16

Q And what is your current position with Gulf Power

17

Company?

18

A I'm the coordinator of bulk power planning.

19

Q Okay. And have you held other positions

20

previously with Gulf Power?

21

A Yes, I have.

22

Q What are those positions?

23

A I've been a plant engineer on my first assignment

24

with Gulf Power Company. I was a superintendent of

25

engineering and administration at another Gulf Power

INDEX OF EXHIBITS

1  
2  
3  
4  
5  
6  
7  
8  
9  
10  
11  
12  
13  
14  
15  
16  
17  
18  
19  
20  
21  
22  
23  
24  
25

NUMBER		PAGE NO.
#1	(Late-filed) IRP fuel exhibit . . . . .	17
#2	(Late-filed) Transmission study summaries . . . . .	39
#3	(Late-filed) System wide EAF, 1994 to 2004 . . . . .	58
#4	(Late-filed) Revenue requirements spread sheet . . . . .	68

\* \* \* \*

INDEX

PAGE NO.

1  
2  
3  
4  
5  
6  
7  
8  
9  
10  
11  
12  
13  
14  
15  
16  
17  
18  
19  
20  
21  
22  
23  
24  
25

STIPULATION	. . . . . 3
ERRATA SHEET	. . . . .70
CERTIFICATE OF OATH	. . . . .71
CERTIFICATE OF DEPONENT	. . . . .72
CERTIFICATE OF REPORTER	. . . . .73

WILLIAM F. POPE	
Examination by Ms. Jaye	. . . . . 6

## STIPULATION

1  
2  
3 IT IS STIPULATED that this deposition was taken  
4 pursuant to notice in accordance with the applicable  
5 Florida Rules of Civil Procedure; that objections, except  
6 as to the form of the question, are reserved until hearing  
7 in this cause; and that reading and signing was not waived.

8 IT IS ALSO STIPULATED that any off-the-record  
9 conversations are with the consent of the deponent.

10  
11  
12  
13  
14  
15  
16  
17  
18  
19  
20  
21  
22  
23  
24  
25

121

1  
2  
3  
4  
5  
6  
7  
8  
9  
10  
11  
12  
13  
14  
15  
16  
17  
18  
19  
20  
21  
22  
23  
24  
25

APPEARANCES:

GRACE A. JAYE, ESQUIRE, FPSC, 2540 Shumard Oak  
Boulevard, Suite 370, Tallahassee, Florida 32399-0850.

RICHARD D. MELSON, ESQUIRE, Gulf Power, Hopping,  
Green, Sams & Smith, 123 South Calhoun Street, Tallahassee,  
Florida 32301.

RUSSELL BADDERS, ESQUIRE and JEFFREY STONE, ESQUIRE,  
Gulf Power, Post Office Box 12950, Pensacola, Florida  
32576.

GAIL KAMARAS, ESQUIRE, LEAF, 1114 Thomasville Road,  
Suite E, Tallahassee, Florida 32303.


ALSO PRESENT:

- EVA SAMAN, FPSC Staff.
- MICHAEL HAFF, FPSC Staff.
- ANDREW MAUREY, FPSC Staff.
- WAYNE MAKIN, FPSC Staff.
- TODD BOHRMAN, FPSC Staff.
- ROBERT MOORE, Gulf Power.

\* \* \* \*

BEFORE THE FLORIDA PUBLIC SERVICE COMMISSION

In Re: Petition of Gulf Power Company ) DOCKET NO.990325-EI  
to determine need for proposed )  
electrical power plant in Bay County )



DEPOSITION OF: WILLIAM F. POPE  
TAKEN AT THE INSTANCE OF: FPSC Staff  
DATE: Monday, May 10, 1999  
TIME: Commenced at 9:00 a.m.  
Concluded at 12:00 Noon  
PLACE: FPSC  
2540 Shumard Oak Boulevard  
Room 362  
Tallahassee, Florida  
REPORTED BY: NANCY S. METZKE, RPR, CCR

C & N REPORTERS  
REGISTERED PROFESSIONAL REPORTERS  
POST OFFICE BOX 3093  
TALLAHASSEE, FLORIDA 32315-3093  
(850)697-8314 / FAX (850)697-8715

119

BUREAU OF REPORTING

RECEIVED 5-20-99

**Commission Requested Analysis - - TOTAL Dollars**

574 MW

		Gen. & Trans. Accum. PW. Total Cost (000\$)	Total Cost Above Self Build (000\$)
<u>Respondent/Alternative</u>			
1	20 Year Self-Build	49,533,716	
2	Respondent B - CT Proposal (20 Year Pricing)	49,654,712	120,997
3	Respondent B - CC Proposal (10 Year Pricing)	49,661,133	127,417
4	Respondent C	49,670,498	136,782
5	Respondent B - CT Proposal (10 Year Pricing)	49,674,115	140,399
6	Respondent B - CC Proposal (7 Year Pricing)	49,675,986	142,270
7	Respondent A - 2 Cogen Facilities	49,676,695	142,979
8	Respondent B - CC Proposal (20 Year Pricing)	49,683,824	150,108
9	Respondent B - CT Proposal (7 Year Pricing)	49,686,555	152,839
10	Respondent C Proposal with Fixed and Levelized Energy Price	49,727,135	193,419

**Commission Requested Analysis - - TOTAL Dollars**

540 MW

	Gen. & Trans. Accum. PW. Total Cost (000\$)	Total Cost Above Self Build (000\$)
1	Smith Unit 3 - 20 year	49,538,320
2	Respondent B - CT Proposal (20 Year Pricing)	49,654,712
3	Respondent B - CC Proposal (10 Year Pricing)	49,661,133
4	Respondent C	49,670,498
5	Respondent B - CT Proposal (10 Year Pricing)	49,674,115
6	Respondent B - CC Proposal (7 Year Pricing)	49,675,986
7	Respondent A - 2 Cogen Facilities	49,676,695
8	Respondent B - CC Proposal (20 Year Pricing)	49,683,824
9	Respondent B - CT Proposal (7 Year Pricing)	49,686,555
10	Respondent C Proposal with Fixed and Levelized Energy Price	49,727,135

Summary of Late-filed Exhibit #4 from  
Deposition of William Pope

(Non-Confidential)

HISTORY AND FORECAST OF  
SOUTHERN EQUIVALENT AVAILABILITY FACTOR  
1994 THROUGH 2004

YEAR	ACTUAL HISTORY	FUTURE PROJECTION
1994	84.87%	
1995	87.08%	
1996	85.75%	
1997	86.39%	
1998	83.69%	
1999		(1)
2000		(1)
2001		(1)
2002		(1)
2003		(1)
2004		(1)


(1) The Southern electric system does not project Equivalent Availability Factors (EAF) for its units. Southern uses Equivalent Forced Outage Rate (EFOR) in consideration of reliability.

**Exhibit A.5 - New Peaking CT Failure Rates and Reliabilities**

Run Time Hours	Failure Rate	Hourly Reliability	Cumulative Reliability
1	0.013807	0.986288	0.986288
2	0.008725	0.991313	0.977720
3	0.006670	0.993352	0.971220
4	0.005513	0.994502	0.965881
5	0.004756	0.995256	0.961298
6	0.004215	0.995794	0.957255
7	0.003806	0.996202	0.953619
8	0.003484	0.996522	0.950303
9	0.003222	0.996783	0.947245
10	0.003005	0.996999	0.944403
11	0.002821	0.997183	0.941743
12	0.002663	0.997340	0.939238
13	0.002526	0.997477	0.936869
14	0.002405	0.997598	0.934618
15	0.002297	0.997705	0.932474
16	0.002201	0.997801	0.930423

NOTE: Run time is measured in hours, and failure rate units are number of forced outages per service hour.

**Exhibit A.6**




**Exhibit A.3 - Other Peaking CT Failure Rates and Reliabilities**

Run Time Hours	Failure Rate	Hourly Reliability	Cumulative Reliability
1	0.027588	0.972789	0.972789
2	0.017435	0.982716	0.955976
3	0.013330	0.986758	0.943317
4	0.011018	0.989042	0.932980
5	0.009505	0.990540	0.924154
6	0.008424	0.991611	0.916402
7	0.007607	0.992422	0.909457
8	0.006963	0.993061	0.903147
9	0.006441	0.993580	0.897348
10	0.006007	0.994011	0.891974
11	0.005640	0.994376	0.886958
12	0.005324	0.994690	0.882248
13	0.005049	0.994964	0.877805
14	0.004807	0.995204	0.873595
15	0.004593	0.995418	0.869592
16	0.004401	0.995609	0.865774

NOTE: Run time is measured in hours, and failure rate units are number of forced outages per service hour.

**Exhibit A.4**

**Other Peaking CTs  
Failure Rates and Reliabilities**




**Exhibit A.1 - Wilson / McManus Peaking CT Failure Rates and Reliabilities**

Run Time Hours	Failure Rate	Hourly Reliability	Cumulative Reliability
1	0.016558	0.983578	0.983578
2	0.010464	0.989591	0.973340
3	0.008000	0.992032	0.965584
4	0.006613	0.993409	0.959220
5	0.005704	0.994312	0.953764
6	0.005056	0.994957	0.948955
7	0.004565	0.995445	0.944632
8	0.004179	0.995830	0.940693
9	0.003865	0.996142	0.937064
10	0.003605	0.996402	0.933692
11	0.003384	0.996621	0.930538
12	0.003195	0.996810	0.927570
13	0.003030	0.996975	0.924763
14	0.002885	0.997119	0.922099
15	0.002756	0.997248	0.919562
16	0.002641	0.997363	0.917136

NOTE: Run time is measured in hours, and failure rate units are number of forced outages per service hour.

**Exhibit A.2**



hour, the running reliability for each hour, and the cumulative running reliability through that hour for peaking CT missions of up to 16 hours (tabulated) and up to 150 hours (graphed). Note that time is measured in hours, and failure rate units are number of forced outages per service hour.

$$\text{Wilson/McManus } \lambda_t = 10^{-0.66213 \times \log(t) - 1.78099}$$

$$\text{Other CTs } \lambda_t = 10^{-0.66207 \times \log(t) - 1.55928}$$

Peaking CT running reliability is the probability of the CT completing its mission. The probability of a CT running through each individual hour of its mission is found by using the following equations:

$$\text{New CTs } R_t = e^{-(\lambda_t \times 1)}$$

$$= e^{-10^{-0.66226 \times \log(t) - 1.85989}} \times (1)$$

$$= e^{-10^{-0.66226 \times \log(t) - 1.85989}}$$

$$\text{Wilson/McManus } R_t = e^{-(\lambda_t \times 1)}$$

$$= e^{-10^{-0.66213 \times \log(t) - 1.78099}} \times (1)$$

$$= e^{-10^{-0.66213 \times \log(t) - 1.78099}}$$

$$\text{Other CTs } R_t = e^{-(\lambda_t \times 1)}$$

$$= e^{-10^{-0.66207 \times \log(t) - 1.55928}} \times (1)$$

$$= e^{-10^{-0.66207 \times \log(t) - 1.55928}}$$

The probability of a peaking CT running from a start at time  $t=0$  through different points of its mission is the cumulative product of the running reliabilities for each hour to that point as shown below:

$$\text{Cumulative } R_t = (R_1 \times R_2 \times R_3 \times \dots \times R_t)$$

For these three types of CT characteristics modeled - Wilson/McManus CTs, Other CTs, and New CTs - the following tables and graphs, Exhibits A.1- A.6 show failure rate values for each

## Combustion Turbine Failure Rates and Reliabilities

### ITEM # 1

Following a start failure or a forced outage event, the probability of the CT being in the available state on each day following the event:

<u>Day</u>	<u>New CTs Probability Available</u>	<u>Wilson/McManus Probability Available</u>	<u>Other CTs Probability Available</u>
Day 1	72%	89%	89%
Day 2	9%	4%	3%
Day 3	9%	3%	4%
Day 4	10%	4%	4%

(100% Totals)

Note: Some high-impact, low-probability events could last longer than four days.

### ITEM # 2

Peaking CT starting reliability is defined as the probability that the machine will be brought on-line within 30 minutes of the time that it is called upon to run.

<u>New CTs Starting Reliability</u>	<u>Wilson/McManus Starting Reliability</u>	<u>Other CTs Starting Reliability</u>
98%	98%	98%

### ITEM # 3

Peaking CT failure rate ( $\lambda$ ) is estimated to be a function of run time (t) during each individual mission. This means that the failure rates for the CTs change for each hour of their mission as shown by the equations below:

$$\text{New CTs } \lambda_t = 10[-0.66226 \times \log(t) - 1.85989]$$

*An Economic Study  
of the  
Optimum System Planning Reserve Margin  
for the  
Southern Electric System*

**APPENDIX A**


**July 1997**

## V. SUMMARY

In summary, after a very thorough and detailed analysis of the current and near-term projected generation reliability state of the Southern electric system, it is concluded that the system should transition from the existing minimum 15% system planning reserve margin to a minimum 13.5% system planning reserve margin by 1999. There are two significant changes that contributed to this result (1) modeling techniques which decreased the EUE and LOLH output from the Monte Carlo Frequency and Duration (MCFRED) model compared to previous studies; and, (2) reducing the 1989/1990 cost of EUE estimate from \$8.72 per kilowatt-hour to \$4.34 per kilowatt hour, both in 1996 dollars.

However, it should be noted that an economic analysis is only one piece of information used to determine an optimum generation reliability level. No decision of this importance should be made solely with a series of mathematical models. Industry experience, system operations input, perceptions of acceptable risks, and an understanding of the strengths, weaknesses, and biases of the mathematical models must all be considered in determining the amount of capacity which should be added to the system in the late 1990s and the early 2000s.

**Optimum Reserve Margin for Average Weather  
Minimum Cost Calculation at 8.0% 3-Year Lead Time**



**Exhibit IV.E1**

Exhibit IV.D1

<i>Cost of EUE (\$/kWh)</i>	<i>Reserve Margin</i>
\$2.18	12.00%
\$4.36	13.50%
\$8.72	15.00%
\$13.07	16.00%
\$15.25	16.25%

**Optimum System Planning Reserve Margin  
As a Function of the Cost of EUE**





Exhibit IV.D2

**E. Weather Variation**

If there are no variations in weather, that is, if all years had the weather matching the average weather of the last 20-40 years, then fewer reserves would be needed. Exhibit IV.E1 shows the optimum system planning reserve margin would drop to around 8.0%.

**Optimum System Planning Reserve Margin  
As a Function of Capacity Cost - 3 Year Lead Time**



**Exhibit IV.C1**

**D. Cost of Expected Unserved Energy**

The base assumptions of the study uses an cost of EUE based on a weighted average cost of \$4.34 per kilowatt-hour. While the reserve margin as a function of the cost of EUE was previously shown in Section III.A, Exhibit III.A1, the following table and graph (see Exhibits IV.D1 and IV.D2, respectively) illustrate how the margin would change if the cost of EUE was varied (decreased and increased). Based on the economics of developing such a margin, one would expect the margin to shift to the right (or increase) if the cost of EUE increases. For a cost of EUE of \$2.18 per kilowatt-hour which is 50% less than the cost used, the optimum reserve margin would decrease to 12.0%. For an increase to approximately \$15 per kilowatt-hour, the optimum margin would increase to the 16% range and began to level off. As stated in Section I.S of the report, this evaluation of system reserve margin requirements utilizes an update to the cost of EUE used in previous studies. By weighting customer outages more heavily to the residential customers, this value was reduced by approximately 50% from a value of \$8.72 per kilowatt-hour (in 1996 dollars) to \$4.34 per kilowatt-hour. To go to an even lower cost of EUE and still use the 1989/90 survey cost estimates, the contribution of the residential segment would have to be even higher. And vice-versa for a higher cost of EUE which would drive the margin upwards. This would require more weighting on the commercial and industrial segments that have a higher, associated cost of EUE than the residential customers, according to the survey results.

MW system, 1% reserves is about 320 MW which represents a capital cost savings of approximately \$73 million (in 1996 dollars).

### **B. Unit Forced Outage Rates**

The unit outage data is actual data for the previous five years with no adjustments. It encompasses the last five years of data for more than 100 thermal units, tapping a diverse database. Future revisits to this study will automatically incorporate improvement or degradation of unit performance. There appears to be no need to test changes in outage rates in the model now.

One conclusion that can be drawn from earlier results is that there is virtually no EUE from October to May; increasing unit availability during that period will have little reliability benefit. Alternately, it can be presumed that a one point reduction in the June-September forced outage rate of a 100 MW unit will increase effective system capacity by 1 MW.

### **C. CT Capacity Cost**

Simple-cycle combustion turbine (CT) technology is used as the current measure of generating capacity cost in the economic evaluation of optimum reserve margins. However, the actual cost for a CT in the future may be more or less than the costs projected today. As an example, in the late 1990's and early 2000's, there is a possibility that increased emissions restrictions or some other factor could increase the cost. It is also possible that the improvements in materials or other factors could decrease the cost.

Exhibit IV.C1 is a graph of the target reserve margin as a function of the CT capacity cost. As shown, the target reserve margin will increase to 14.25% (from 13.5%) if the cost of a CT drops to 70% of the current projection. The margin decreases to 13.0% if the cost of a CT rises by 30%. This shows that that the margin is not overly sensitive to the capacity cost.

**IV. SENSITIVITY RESULTS**


A variety of alternate assumptions were evaluated to determine the sensitivity of the 13.5% target reserve margin. Some alternate assumptions require analytical work to evaluate; others become intuitively obvious after sufficient discussion. The sensitivities to cost of EUE and dispatch order were quantified earlier.

**A. Load Forecast Uncertainty**

The estimate of load forecast uncertainty in this study assumes the difference between the projection and the actual (weather-normalized) load for the summer three years into the future will have a triangular distribution around zero ranging from negative to positive 4%. As previously stated and shown in Section III.B of the report, if the load forecast could be projected with greater certainty, fewer reserves would be needed. If there were no (or "zero") load forecast uncertainty (i.e., perfect prophecy), Exhibit IV.A1 shows the target reserve margin would drop to about 12.5%. This is in line with Exhibit III.A3 which showed that load forecast uncertainty contributes approximately one percentage point to the target reserve margin.

**Exhibit IV.A1**


**Optimum System Planning Reserve Margin Minimum  
Cost Calculation 12.5% 0-Year Lead Time**



The value of a drop in the reserve margin from 13.5% to 12.5% (while holding system generation reliability constant) is the cost of maintaining the additional one percent reserves. For a 32,000


range of +/-2%. (Note, Section IV of this report discusses other sensitivity type analysis centering around economic reserve margin calculations including an optimum reserve margin assuming "zero" load forecast uncertainty.) As shown in the exhibit, the optimum reserve margin for a 2-year lead-time is 13.25% while for a one-year out look, the margin is 12.75%.

**Optimum System Planning Reserve Margin Minimum Cost Calculation 13.25% 2-Year Lead Time**




**Exhibit III.B1**

**Optimum System Planning Reserve Margin Minimum Cost Calculation 12.75% 1-Year Lead Time**



**Exhibit III.B2**




**Exhibit III.A4**

If reserves are significantly lower than the target of 13.5%, additional firm load curtailments may occur; customers would rather pay slightly higher bills and not suffer as many outages. If the reserves are significantly higher than the target then customers' bills may be too high due to the excess reserves and they would prefer slightly lower bills and slightly more risk of firm load curtailments.

The 13.5% minimum system planning reserve margin recommended for the system reflects the results of the economic study and a variety of other information available and is very important in planning to best meet customer needs. It will not be possible nor is it expected that the system will always stay at this target. The load forecast error alone could push the reserve margin higher or lower than the target.

**B. Reserve Margins with Different Lead Times**

Exhibits III.B1 and III.B2 display the optimum system planning reserve margins for 2-year and one-year lead times, respectively, using a fixed cost of EUE of \$4.34 per kilowatt-hour and generating capacity cost of \$24.63 per kilowatt-hour. The primary driver for these reduced reserve margins is the reduced load forecast uncertainty associated with more near-term planning. The assumption is made that for a one-year lead-time, load forecast uncertainty is appropriately represented by a range of +/-1%. Likewise, for a two-year out window or lead-time, load forecast uncertainty would be increased and is appropriately represented assuming a



**Exhibit III.A3**


Of course, this type of study is only one piece of information which goes into the decision of the appropriate level of reserves as a planning target. Industry experience, system operations input, perceptions of risk, and an understanding of the strengths, weaknesses, and biases of mathematical models all influence capacity addition decisions. Also, the minimum "target reserve margin" is simply a convenient way to discuss the desired reliability, which might more technically be defined in loss of load hours or expected unserved energy. The optimum reserve margin for other levels of cost of EUE are shown Exhibit III.A4 and given by the equation:

$$y^{0.5} = a + bLN(x), \text{ where}$$

$$a = 0.3214$$

$$b = 0.0304$$

$$x = \text{Cost of EUE}$$




**Exhibit III.A2**

Another representation of the optimum reserve margin utilizes marginal cost and marginal benefit information instead of total cost. The incremental change in dollars per change in capacity (kW) is plotted for the societal benefits of reducing EUE and the capital costs of carrying additional reserves (capacity). The optimum reserve margin occurs where these two lines intersect, that is, the point at which the incremental cost is equal to the incremental benefit derived as shown in Exhibit III.A3. As an explanation of the exhibit, at a 10% reserve margin EUE is reduced by approximately 34 Megawatt-hours per 1 MW of generating capacity added. Thus the incremental benefit is equal to 34 Megawatt-hours times the cost of EUE (\$4.34 per kilowatt-hour) or approximately \$150,000 in 1996 dollars. As the reserve margin increases, the incremental benefit diminishes. At a 13.5% reserve margin, one MW of additional capacity only reduces EUE by about 6 Megawatt-hours resulting in an incremental benefit of approximately \$26,000 per MW corresponding with the incremental cost of adding one MW of CT generating capacity.

### III. RESULTS

#### A. Optimum System Planning Reserve Margin

Utilizing a \$4.34 per kilowatt-hour cost of EUE, a generating capacity deferral cost of \$24.63 per kilowatt-year, and the other assumptions listed above, the optimum system planning minimum reserve margin for a three-year window (e.g., 1999) is 13.5% based on the economic, reliability analysis. This conclusion is exemplified in Exhibit III.A1 in what is referred to as a "bathtub curve." The graph shows that at a 13.5% reserve margin, the sum of the two curves, the cost of capacity and cost of EUE curves, is at its minimum or optimal point.




**Exhibit III.A1**

The total (outage and electricity) cost of being higher or lower than the optimum reserve margin is also shown in Exhibit III.A1. If reserves dropped three percentage points to 10.5%, the annual cost increase is about \$29 million in 1996 dollars. If the margin increases to 16.5%, the cost increase is \$10 million.

Exhibit III.A2 shows how each of the primary components: weather and hydro; unit performance; and, load-forecast uncertainty, contribute to the overall required system planning reserve margin.

**Cost of Expected Unserved Energy  
as a Function of Reserve Margin**



**Exhibit II.D6**

## LOLH as a Function of Reserve Margin




Exhibit II.D4

## Generating Capacity Cost as a Function of Reserve Margin





Exhibit II.D5

Likewise, an expected value of EUE and loss of load hours was calculated for all five reserve margin points (9%, 11%, 13%, 15%, & 17%). By applying regression analysis to the expected values, a curve predicting EUE and LOLH as a function of reserve margin can be developed as shown in Exhibits II.D3 and II.D4. The calculation of both components of annual reliability cost can now be accomplished. The incremental annual capacity carrying cost at any given reserve margin can be determined by multiplying the incremental capacity (kW) by \$24.63/kW-year. This will be represented, as shown in Exhibit II.D5, by a straight line with a positive slope when graphed as a function of reserve margin. The cost of EUE at each reserve margin can be determined by multiplying the amounts of EUE at each reserve level created in the above mentioned regression analysis by the assumed cost of EUE. Exhibit II.D6 illustrates this calculation. The sum of these two curves is plotted on a graph. The minimum point on the resultant curve represents the economically optimum reserve margin. Examples of this type of graph, often referred to as a "bathtub curve," are presented in the Results section of the report.

### EUE as a Function of Reserve Margin



**Exhibit II.D3**

**Exhibit II.D2 - Calculation of Expected LOLH for June - Sept at 15% Reserve Margin Based on Model Results**

(1) Weather Year	(2) Hydro Forecast	(3) Load Forecast Uncertainty	(4) LOLH	(5) Probability	(4 X 5) Weighted LOLH	(1) Weather Year	(2) Hydro Forecast	(3) Load Forecast Uncertainty	(4) LOLH	(5) Probability	(4 X 5) Weighted LOLH
1980	Dry	-2%	8.2	0.0017	0.01	1985	Wet	-2%	0.0	0.0183	0.00
		-4%	1.1	0.0003	0.00			-4%	0.0	0.0031	0.00
		0%	28.8	0.0031	0.09			0%	0.1	0.0336	0.00
		+2%	55.3	0.0017	0.09			+2%	0.7	0.0183	0.01
		+4%	90.3	0.0003	0.03			+4%	5.4	0.0031	0.02
1980	Normal	-2%	7.4	0.0033	0.02	1986	Dry	-2%	0.0	0.0167	0.00
		-4%	0.8	0.0006	0.00			-4%	0.0	0.0028	0.00
		0%	26.0	0.0061	0.16			0%	0.1	0.0305	0.00
		+2%	51.4	0.0033	0.17			+2%	0.4	0.0167	0.01
		+4%	84.6	0.0006	0.05			+4%	7.6	0.0028	0.02
1980	Wet	-2%	3.6	0.0017	0.01	1986	Normal	-2%	0.0	0.0333	0.00
		-4%	0.2	0.0003	0.00			-4%	0.0	0.0056	0.00
		0%	13.0	0.0031	0.04			0%	0.0	0.0611	0.00
		+2%	29.5	0.0017	0.05			+2%	0.3	0.0333	0.01
		+4%	60.8	0.0003	0.02			+4%	5.2	0.0056	0.03
1983	Dry	-2%	0.0	0.0183	0.00	1986	Wet	-2%	0.0	0.0167	0.00
		-4%	0.0	0.0031	0.00			-4%	0.0	0.0028	0.00
		0%	0.5	0.0336	0.02			0%	0.0	0.0305	0.00
		+2%	3.8	0.0183	0.07			+2%	0.4	0.0167	0.01
		+4%	13.6	0.0031	0.04			+4%	3.8	0.0028	0.01
1983	Normal	-2%	0.0	0.0367	0.00	1990	Dry	-2%	0.0	0.0033	0.00
		-4%	0.0	0.0061	0.00			-4%	0.0	0.0006	0.00
		0%	0.2	0.0672	0.01			0%	0.0	0.0061	0.00
		+2%	2.1	0.0367	0.08			+2%	0.3	0.0033	0.00
		+4%	9.5	0.0061	0.06			+4%	4.5	0.0006	0.00
1983	Wet	-2%	0.0	0.0183	0.00	1990	Normal	-2%	0.0	0.0067	0.00
		-4%	0.0	0.0031	0.00			-4%	0.0	0.0011	0.00
		0%	0.2	0.0336	0.01			0%	0.0	0.0122	0.00
		+2%	1.8	0.0183	0.03			+2%	0.1	0.0067	0.00
		+4%	7.0	0.0031	0.02			+4%	3.1	0.0011	0.00
1985	Dry	-2%	0.0	0.0183	0.00	1990	Wet	-2%	0.0	0.0033	0.00
		-4%	0.0	0.0031	0.00			-4%	0.0	0.0006	0.00
		0%	0.2	0.0336	0.01			0%	0.0	0.0061	0.00
		+2%	1.8	0.0183	0.03			+2%	0.1	0.0033	0.00
		+4%	8.2	0.0031	0.03			+4%	2.7	0.0006	0.00
1985	Normal	-2%	0.0	0.0367	0.00						
		-4%	0.0	0.0061	0.00						
		0%	0.0	0.0672	0.00						
		+2%	0.8	0.0367	0.03						
		+4%	5.5	0.0061	0.03						
<b>Sum of all Weighted LOLH = Expected LOLH</b>											<b>1.333</b>

**Exhibit II.D1 - Calculation of Expected Unserved Energy (EUE in MWH) for June - Sept at 15% Reserve Margin Based on Model Results**

(1) Weather Year	(2) Hydro Forecast	(3) Load Forecast Uncertainty	(4) EUE	(5) Probability	(4 X 5) Weighted EUE	(1) Weather Year	(2) Hydro Forecast	(3) Load Forecast Uncertainty	(4) EUE	(5) Probability	(4 X 5) Weighted EUE
1980	Dry	-2%	6869.3	0.0017	11.45	1985	Wet	-2%	0.0	0.0183	0.00
		-4%	712.8	0.0003	0.20			-4%	0.0	0.0031	0.00
		0%	34248.1	0.0031	104.59			0%	26.9	0.0336	0.90
		+2%	92284.2	0.0017	153.78			+2%	286.7	0.0183	5.26
		+4%	178109.7	0.0003	49.67			+4%	3645.8	0.0031	11.18
1980	Normal	-2%	5548.3	0.0033	18.49	1986	Dry	-2%	0.0	0.0167	0.00
		-4%	405.6	0.0006	0.23			-4%	0.0	0.0028	0.00
		0%	29399.5	0.0061	179.57			0%	12.5	0.0305	0.38
		+2%	83486.0	0.0033	278.24			+2%	159.2	0.0167	2.65
		+4%	164126.3	0.0006	91.53			+4%	5168.5	0.0028	14.41
1980	Wet	-2%	2014.8	0.0017	3.36	1986	Normal	-2%	0.0	0.0333	0.00
		-4%	71.6	0.0003	0.02			-4%	0.0	0.0056	0.00
		0%	11553.5	0.0031	35.28			0%	1.8	0.0611	0.11
		+2%	35055.3	0.0017	58.42			+2%	108.8	0.0333	3.62
		+4%	91708.2	0.0003	25.57			+4%	3100.8	0.0056	17.29
1983	Dry	-2%	1.3	0.0183	0.02	1986	Wet	-2%	0.0	0.0167	0.00
		-4%	0.0	0.0031	0.00			-4%	0.0	0.0028	0.00
		0%	304.2	0.0336	10.22			0%	4.6	0.0305	0.14
		+2%	2966.4	0.0183	54.38			+2%	137.7	0.0167	2.29
		+4%	15426.0	0.0031	47.32			+4%	2054.2	0.0028	5.73
1983	Normal	-2%	2.2	0.0367	0.08	1990	Dry	-2%	0.0	0.0033	0.00
		-4%	0.0	0.0061	0.00			-4%	0.0	0.0006	0.00
		0%	76.8	0.0672	5.16			0%	0.0	0.0061	0.00
		+2%	1325.6	0.0367	48.60			+2%	180.4	0.0033	0.60
		+4%	8434.1	0.0061	51.74			+4%	3886.7	0.0006	2.17
1983	Wet	-2%	1.9	0.0183	0.03	1990	Normal	-2%	0.0	0.0067	0.00
		-4%	0.0	0.0031	0.00			-4%	0.0	0.0011	0.00
		0%	83.5	0.0336	2.80			0%	0.3	0.0122	0.00
		+2%	909.4	0.0183	16.67			+2%	47.2	0.0067	0.31
		+4%	5493.1	0.0031	16.85			+4%	1977.5	0.0011	2.21
1985	Dry	-2%	0.0	0.0183	0.00	1990	Wet	-2%	0.0	0.0033	0.00
		-4%	0.1	0.0031	0.00			-4%	0.0	0.0006	0.00
		0%	105.6	0.0336	3.55			0%	0.0	0.0061	0.00
		+2%	1228.5	0.0183	22.52			+2%	49.1	0.0033	0.16
		+4%	7861.9	0.0031	24.12			+4%	1649.0	0.0006	0.92
1985	Normal	-2%	2.2	0.0367	0.08						
		-4%	0.0	0.0061	0.00						
		0%	12.3	0.0672	0.83						
		+2%	380.4	0.0367	13.95						
		+4%	3700.7	0.0061	22.70						
<b>Sum of all Weighted EUE = Likely EUE</b>											<b>1422.3</b>

92

Weather Years	Hydro Outlook	Load Forecast Uncertainty
1963	Normal	+4.0%
1982		+2.0%
1984		0.0%
1985		-2.0%
		-4.0%

**Total # of cases = 4 \* 1 \* 5 = 20**

Note, historically during the winter season the availability of hydro energy is not a concern thus only the normal hydro scenario is modeled in the winter analysis.

For each of the 95 cases (75 for summer and 20 for winter), each hour in the month was modeled with 100 iterative draws from the distribution of generating unit outage and duration data to determine if there exists a deficiency of generating capacity to meet load demand. A deficiency of generating capacity in a given hour is recorded as a loss of load hour. The magnitude of the outage during that hour can be described by EUE. Based upon the model simulations, an average LOLH and EUE are determined for each case across all hours in the month. Then, the average LOLH and EUE in each case are multiplied by the probability of occurrence for that case and the result for all cases is summed to determine an expected value of LOLH and EUE for the study year.

Exhibits II.D1 and II.D2 illustrates an example of likely EUE and expected loss of load hour calculations, respectively, for the study year, the summer season, and one reserve margin (15%) based on modeling results:

$$\text{Expected } Y = \sum_{i=1}^{75} (Y_i \times \text{Probability}_i)$$

(column 4) x (column 5)

where, Y = EUE or LOLH and, i = number of cases

#### D. Reliability Model Simulations

Generation reliability simulations are conducted using a model that incorporates Monte Carlo techniques. Monte Carlo analysis uses a random number generator to determine generating unit availability for the system. For each iteration, the model simulations will randomly select the state of a generating unit as fully operational, partially failed or completely failed and determine if the system experiences loss of load and associated EUE. Historical information concerning load-forecast uncertainty, weather, and hydro energy is used to construct numerous cases that could occur for a future year.

For a single reserve margin, a set of 75 cases was developed using the following table of weather, hydro, and load forecast uncertainty combinations to represent the summer season:

Weather Years	Hydro Outlook	Load Forecast Uncertainty
1980	Dry	+4.0%
1983	Normal	+2.0%
1985	Wet	0.0%
1986		-2.0%
1990		-4.0%

**Total # of cases = 5 \* 3 \* 5 = 75**

Likewise, for a single reserve margin a set of 20 cases was developed using the following table of weather, hydro, and load forecast uncertainty combinations to represent the winter season:

Using probabilistic evaluation techniques requires each of these variables to have a designated probability of occurrence. Exhibit II.C1 depicts the probabilities assigned to each weather year, each hydro pattern, and each load forecast uncertainty. A total probability associated with a combination of these three variables can be calculated using the three associated probabilities. The probabilities for both the summer and winter analyses are included.

Probabilities Assigned to Various Input Variables						
	Weather Year	Probability	Hydro Pattern	Probability	LFE	Probability
<b>Summer</b>	1980	0.0278	Dry	0.25	+4%	0.0401
	1983	0.2778	Normal	0.50	+2%	0.2400
	1986	0.1667	Wet	0.25	0%	0.4398
	1990	0.0833			-2%	0.2400
	1985	0.1111			-4%	0.0401
<b>Winter</b>	1963	0.1667	Normal	1.00	+4%	0.0401
	1982	0.1667			+2%	0.2400
	1984	0.1389			0%	0.4398
	1985	0.1944			-2%	0.2400
					-4%	0.0401

**Exhibit II.C1**

As shown, the probabilities assigned for the weather years for each season, summer and winter, do not sum to 1.0 or 100%. As previously mentioned, the model simulations were made for those weather years which were projected to yield periods of EUE and LOLH. However, equal probability is given (on a year-by-year basis) to those years that did not project to have generation reliability problems. These years make up the difference, in probability, between the probability shown for the above years and an expected total of 1.0.

## **B. PEST Case Specification**

The hourly EUE profiles from the set of 95 cases were each subjected to tie assistance evaluation, assuming the system had equal access to ETA with other neighboring utilities.

PEST was also used to test the availability of the input economy purchases. An initial set of runs was made to test the assumptions of economy purchase availability. A strict application of PEST reveals there may be some hours in which more economy purchases are assumed to be available in the input data than can be shown to be available from MCFRED outputs. There are three reasons:

- 1) Minimum flow hydro energy, which was excluded from earlier calculations, could be considered a source of additional economy ties;
- 2) Transmission constraints used in calculating ETA and in the PEST validity test are based on first contingency transfer limits. That is, they assume a major transmission line is already out-of-service; and,
- 3) During the morning and late evening hours, when the economy ties are assumed to be available, there is more transmission capacity and more generating capacity (due to the lower ambient temperatures) than are reflected in MCFRED. (For example, the maximum electrical output of CTs increases when the temperature drops from 95 to 88 degrees and there are several thousand MWs of CT capacity in the Southeast.

## **C. Probabilities of Occurrence for Input Variables**

As has been discussed in the previous sections, the chronological variable inputs into the model, excluding the unit outage data, are used to represent appropriate ranges of data. For example, the weather years selected to exemplify load variations due to temperature changes represent over 30 years of historical data. Likewise for the hydro patterns developed. The low, likely, and high hydro scenarios are representative of the variation of hydro availability. And finally, the implementation of load forecast uncertainty into the evaluation is representative of the potential (supported by historical information) load forecasting problems when looking out into the future.

**Exhibit II.A3**

**Annual Loss of Load Hours (LOLH) for Various Reserve Levels with Tie Assistance**

**- Assumes 0% Load Forecast Uncertainty -**

	Weather Year	Hydro Pattern	9% Reserves LOLH	11% Reserves LOLH	13% Reserves LOLH	15% Reserves LOLH	17% Reserves LOLH
<b>Summer</b>	<b>1980</b>	<b>Dry</b>	144.53	81.17	52.16	28.80	13.74
		<b>Normal</b>	133.63	74.45	49.30	26.02	13.31
		<b>Wet</b>	93.50	51.86	30.70	12.96	6.08
	<b>1983</b>	<b>Dry</b>	33.72	16.66	5.70	0.48	0.03
		<b>Normal</b>	26.41	11.33	3.65	0.21	0.02
		<b>Wet</b>	18.29	8.47	2.99	0.18	0.01
	<b>1985</b>	<b>Dry</b>	32.15	9.15	2.14	0.18	0.02
		<b>Normal</b>	24.88	5.66	1.04	0.06	0.01
		<b>Wet</b>	17.51	4.03	0.81	0.03	0.00
	<b>1986</b>	<b>Dry</b>	30.91	7.35	1.04	0.05	0.00
		<b>Normal</b>	23.16	4.32	0.82	0.03	0.00
		<b>Wet</b>	15.86	3.52	0.70	0.02	0.00
<b>1990</b>	<b>Dry</b>	13.13	2.47	0.17	0.00	0.00	
	<b>Normal</b>	8.54	1.43	0.11	0.00	0.00	
	<b>Wet</b>	7.55	1.12	0.09	0.00	0.00	
<b>Winter</b>	<b>1985</b>	<b>Normal</b>	2.67	1.66	1.25	0.10	0.10
	<b>1963</b>	<b>Normal</b>	0.03	0.01	0.00	0.00	0.00
	<b>1983</b>	<b>Normal</b>	0.01	0.00	0.00	0.00	0.00
	<b>1984</b>	<b>Normal</b>	0.00	0.00	0.00	0.00	0.00

**Exhibit II.A2**

**Annual MWHs of EUE for Various Reserve Levels with Tie Assistance**

**- Assumes 0% Load Forecast Uncertainty -**

	Weather Year	Hydro Pattern	9% Reserves EUE	11% Reserves EUE	13% Reserves EUE	15% Reserves EUE	17% Reserves EUE
<b>Summer</b>	<b>1980</b>	<b>Dry</b>	314,435.3	155,760.4	89,909.4	34,248.1	13,137.4
		<b>Normal</b>	283,667.8	142,455.0	83,033.1	29,399.5	12,206.9
		<b>Wet</b>	173,092.7	81,659.1	38,889.4	11,553.5	3,977.1
	<b>1983</b>	<b>Dry</b>	52,931.7	20,935.5	4,939.2	304.2	17.3
		<b>Normal</b>	34,478.6	11,226.7	2,473.4	152.3	8.7
		<b>Wet</b>	21,337.6	7,012.0	1,865.7	83.5	4.8
	<b>1985</b>	<b>Dry</b>	41,324.3	7,264.6	1,713.9	105.6	6.0
		<b>Normal</b>	26,378.4	2,987.0	436.7	26.9	1.5
		<b>Wet</b>	14,691.8	2,165.3	387.5	12.3	0.7
	<b>1986</b>	<b>Dry</b>	34,131.4	5,060.0	499.1	12.5	4.2
		<b>Normal</b>	20,882.9	2,334.1	292.0	1.8	0.6
		<b>Wet</b>	12,936.2	1,927.3	291.2	4.6	0.1
<b>1990</b>	<b>Dry</b>	13,196.7	1,820.4	67.3	1.0	0.0	
	<b>Normal</b>	6,188.1	800.7	36.9	0.3	0.0	
	<b>Wet</b>	5,088.6	542.2	31.1	0.0	0.0	
<b>Winter</b>	<b>1985</b>	<b>Normal</b>	2,886.6	1,201.7	834.9	39.3	36.8
	<b>1963</b>	<b>Normal</b>	8.7	2.3	0.0	0.0	0.0
	<b>1983</b>	<b>Normal</b>	3.3	0.0	0.0	0.0	0.0
	<b>1984</b>	<b>Normal</b>	0.0	0.0	0.0	0.0	0.0

Prior to introduction of load forecast uncertainty, the total number of combinations for the summer analysis is five times three times five, or 75 cases. For the winter analysis, the case representation prior to introducing load forecast uncertainty into the equation, is four times one time five, or 20 cases. (Notes: (1) Hydro was proven not to be a "player" in the non-summer months thus only the "normal" hydro scenario or pattern was used in the winter analysis. (2) Furthermore, it is also assumed that the spring and fall seasons are not yet critical in determining system reserve margin requirements thus are not included in this reliability evaluation.) Estimating EUE for each of the 95 cases through a rigorous application of MCFRED and PEST provides sufficient data for regression analysis of other combinations not specifically calculated in the detailed models.

Only results for normal and hotter-than-normal weather and underestimation of load were specifically calculated. This does not imply that the EUE is therefore overestimated. In each case, the likelihood of cool summers and warm winters and subsequently overestimated loads is given equal weighting with the likelihood of hot summers and cold winters and subsequently underestimated loads. Seeking more accuracy in the higher EUE cases increases the accuracy of all the final results by providing better estimates of the situations that have the greatest impact on the final results. (In practice, no model is needed to estimate the EUE for highly reliable situations such as 21% planned reserves and -4.0% load forecast error; the EUE rounds to zero.)

Exhibits IIA2 and IIA3, respectively, lists the EUE and LOLH, without inclusion of load forecast uncertainty, for the 95 cases after emergency tie assistance (ETA) is applied. From the exhibit, for example, at 13% reserves, 1983 (very hot) weather, dry hydro pattern and no load forecast error the expected unserved energy is about 5,000 Megawatt-hours. This could be interpreted as dropping 5,000 MWs of load for one hour, 2,500 MWs of load for two hours, or some other combination that equals 5,000 Megawatt-hours. Also for the same scenario, the expected or likely annual loss of load hours, of which the majority is in the summer months, is approximately six (6) hours.

**II. SIMULATION PROCEDURE**

**A. MCFRED Case Specification**

The simulations were designed to estimate system generation reliability across a range of weather conditions, load forecast errors, and reserve margins. To increase confidence in the regression analyses used to interpolate and extrapolate results, the reserve margin variables were set to five discrete points. The weather variable was set to cover both the summer and winter seasons and over 30 years of weather data was represented by five points (summer) and four points (winter). The hydro patterns were set at three points for the summer and one point for the winter analysis.

Specific weather years -- 1980, 1990, 1986, 1985, and 1983 -- were selected for the summer reliability analysis. These years are significant in terms of observed weather patterns as confirmed by an evaluation of annual peaks and energies and the cooling degree day calculations with specific reference temperatures of 72 and 92 degrees F, for thirty-one years of historical weather data. When this data was normalized, the results yielded the selection of the five specific weathers above with 1980 being the hottest. Likewise for the winter reliability analysis, four colder than normal weather years -- 1963, 1982, 1984, and 1985 -- were selected to represent those conditions that could produce EUE and LOLH during the winter months.

Thus the simulation variables were as depicted in Exhibit IIA.1:

**Exhibit IIA.1 - MCFRED Case Variables**

<i>Summer Weather Years</i>	<i>Winter Weather Years</i>	<i>Hydro Patterns</i>	<i>Reserve Margins</i>
1980	1963	Wet	9.0%
1983	1982	Normal	11.0%
1986	1984	Dry	13.0%
1990	1985		15.0%
1985			17.0%

weighting of the customer classes. But as also stated in the report, future studies may give consideration to weighing the residential cost of EUE more heavily into the calculation. After surveying various operating companies' divisions as to what percentages each customer segment contributes to a generic block of load that would be shed in such times of need, the cost of EUE was adjusted by the weight each customer class would contribute in such a load shed scenario. The cost of EUE (in 1996 dollars) using the original weightings is estimated at \$8.72 per kilowatt-hour. By using increased weighting on the residential segment, the cost of EUE is estimated at \$4.34 per kilowatt-hour. This is the cost of EUE that will be used in this study.

1. Provide a 20-year, present worth revenue requirements (PWRR) analysis of Gulf's proposed Smith Unit 3, the other self-build options, and all respondents to Gulf's Request for Proposals (RFP). Provide both on an annual and a cumulative PWRR basis, and separate capital, fixed operations and maintenance (O&M), and variable costs for each year. Include all financial assumptions for the self-build options and the respondents.

**RESPONSE:**

The values requested for the four self-build analysis options are attached. The financial assumptions used for the Self-build analysis are those shown for 1997 in the answer to Interrogatory No. 13. The response for the figures pertaining to the RFP analyses have been filed with a Letter of Intent to request Confidential treatment.

TABULATION OF ANNUAL AND CUMULATIVE PRESENT VALUE COST DATA FOR SMITH CC SELF-BUILD OPTION

Year	Nominal \$1,000					Present Worth 1998 \$1,000					Accumulated Present Worth 1998 \$1,000				
	Capital	Fixed O&M	Fuel + VO&M	Fuel Savings	Total	Capital	Fixed O&M	Fuel + VO&M	Fuel Savings	Total	Capital	Fixed O&M	Fuel + VO&M	Fuel Savings	Total
2001	20,528	780	19,273	23,712	16,869	15,239	559	13,820	17,003	12,616	15,239	559	13,820	17,003	12,616
2002	33,226	1,377	35,916	44,891	25,629	22,698	909	23,699	29,621	17,685	37,937	1,468	37,520	46,624	30,301
2003	31,798	1,420	36,883	47,084	23,016	19,989	862	22,396	28,590	14,657	57,927	2,330	59,915	75,215	44,958
2004	30,445	1,463	37,042	48,673	20,277	17,612	818	20,698	27,197	11,930	75,539	3,148	80,613	102,412	56,888
2005	29,135	1,508	35,907	46,651	19,898	15,509	775	18,463	23,988	10,760	91,048	3,923	99,076	126,399	67,648
2006	27,865	1,554	32,465	42,758	19,126	13,650	735	15,361	20,232	9,515	104,698	4,658	114,437	146,631	77,163
2007	26,631	1,602	30,158	40,216	18,174	12,005	697	13,131	17,511	8,322	116,703	5,356	127,569	164,142	85,485
2008	25,432	1,651	28,424	38,433	17,074	10,550	661	11,389	15,399	7,201	127,252	6,017	138,957	179,541	92,686
2009	24,253	1,701	30,804	41,599	15,159	9,258	627	11,358	15,338	5,905	136,510	6,644	150,315	194,879	98,590
2010	23,077	1,753	33,343	45,135	13,038	8,106	595	11,313	15,314	4,700	144,616	7,239	161,628	210,193	103,290
2011	21,902	1,807	34,551	46,944	11,316	7,080	564	10,788	14,657	3,774	151,695	7,804	172,416	224,850	107,065
2012	20,729	1,862	35,827	48,962	9,457	6,166	535	10,294	14,067	2,927	157,861	8,339	182,709	238,917	109,992
2013	19,557	1,919	37,362	51,199	7,640	5,353	507	9,878	13,536	2,202	163,214	8,846	192,587	252,453	112,195
2014	18,387	1,978	38,816	53,314	5,867	4,631	481	9,444	12,971	1,585	167,846	9,327	202,031	265,424	113,780
2015	17,217	2,039	40,067	55,291	4,033	3,991	456	8,971	12,379	1,039	171,836	9,784	211,002	277,803	114,819
2016	16,050	2,101	41,394	57,431	2,113	3,423	433	8,528	11,832	552	175,260	10,217	219,530	289,635	115,371
2017	14,883	2,166	40,589	55,473	2,164	2,921	411	7,695	10,517	510	178,181	10,627	227,225	300,152	115,881
2018	13,718	2,232	38,535	52,099	2,386	2,478	389	6,723	9,089	501	180,658	11,017	233,948	309,241	116,381
2019	12,555	2,300	36,713	49,106	2,462	2,087	369	5,894	7,884	466	182,745	11,386	239,842	317,125	116,848
2020	11,393	2,371	37,782	50,448	1,098	1,742	350	5,582	7,453	222	184,488	11,736	245,423	324,578	117,069
2021	4,416	1,018	15,965	21,309	89	621	138	2,170	2,897	33	185,109	11,875	247,594	327,475	117,103

TABULATION OF ANNUAL AND CUMULATIVE PRESENT VALUE COST DATA FOR SMITH CT SELF-BUILD OPTION

Attachment 1-2  
 Staffs 1st set of Interrogatories - No. 1  
 Docket No. 990325-EI

Year	Nominal \$1,000					Present Worth 1998 \$1,000					Accumulated Present Worth 1998 \$1,000				
	Capital	Fixed O&M	Fuel + VO&M	Fuel Savings	Total	Capital	Fixed O&M	Fuel + VO&M	Fuel Savings	Total	Capital	Fixed O&M	Fuel + VO&M	Fuel Savings	Total
2001	16,348	673	0	0	17,020	12,136	482	0	0	12,618	12,136	482	0	0	12,618
2002	26,041	1,188	0	0	27,229	17,790	784	0	0	18,574	29,926	1,267	0	0	31,192
2003	24,886	1,225	0	0	26,110	15,644	744	0	0	16,388	45,570	2,010	0	0	47,580
2004	23,905	1,262	0	0	25,167	13,828	705	0	0	14,534	59,398	2,716	0	0	62,114
2005	22,957	1,301	0	0	24,258	12,221	669	0	0	12,890	71,619	3,385	0	0	75,003
2006	22,041	1,341	0	0	23,382	10,797	634	0	0	11,431	82,416	4,019	0	0	86,435
2007	21,153	1,382	0	0	22,535	9,535	602	0	0	10,137	91,951	4,621	0	0	96,572
2008	20,293	1,424	0	0	21,717	8,418	571	0	0	8,988	100,369	5,191	0	0	105,560
2009	19,449	1,468	0	0	20,917	7,424	541	0	0	7,965	107,793	5,732	0	0	113,525
2010	18,609	1,513	0	0	20,121	6,536	513	0	0	7,050	114,330	6,246	0	0	120,575
2011	17,770	1,559	549	551	19,328	5,744	487	172	172	6,230	120,074	6,732	172	172	126,806
2012	16,935	1,607	579	605	18,516	5,037	462	166	174	5,491	125,111	7,194	338	346	132,297
2013	16,101	1,656	602	623	17,736	4,407	438	159	165	4,839	129,518	7,632	497	511	137,136
2014	15,270	1,707	626	643	16,960	3,846	415	152	156	4,257	133,364	8,047	650	667	141,394
2015	14,441	1,759	661	662	16,198	3,347	394	148	148	3,741	136,711	8,441	797	815	145,134
2016	13,614	1,813	0	0	15,427	2,904	373	0	0	3,277	139,615	8,814	797	815	148,412
2017	12,790	1,868	0	0	14,659	2,510	354	0	0	2,865	142,125	9,169	797	815	151,276
2018	11,969	1,926	0	0	13,895	2,162	336	0	0	2,498	144,287	9,505	797	815	153,774
2019	11,151	1,984	0	0	13,135	1,853	319	0	0	2,172	146,140	9,823	797	815	155,946
2020	10,335	2,045	0	0	12,380	1,581	302	0	0	1,883	147,721	10,125	797	815	157,829
2021	4,081	878	0	0	4,960	574	119	0	0	694	148,296	10,245	797	815	158,523

TABULATION OF ANNUAL AND CUMULATIVE PRESENT VALUE COST DATA FOR DANIEL CC SELF-BUILD OPTION

Attachment 1-3  
 Staffs 1st set of Interrogatories - No. 1  
 Docket No. 990325-EI

Year	Nominal \$1,000					Present Worth 1998 \$1,000					Accumulated Present Worth 1998 \$1,000									
	Capital	Fixed O&M	Fuel	VO&M	Fuel Savings	Total	Capital	Fixed O&M	Fuel	VO&M	Fuel Savings	Total	Capital	Fixed O&M	Fuel	VO&M	Fuel Savings	Total		
2001	36,048	324	20,004	25,716	30,661	26,761	233	14,344	18,440	22,898	26,761	233	14,344	18,440	22,898	26,761	233	14,344	18,440	22,898
2002	56,095	573	34,481	45,696	45,453	38,321	378	22,753	30,153	31,298	65,082	611	37,097	48,593	54,196	38,321	378	22,753	30,153	31,298
2003	53,885	591	34,620	47,084	42,011	33,874	359	21,022	28,590	26,664	98,955	970	58,118	77,183	80,860	33,874	359	21,022	28,590	26,664
2004	51,914	609	34,763	48,673	38,612	30,031	340	19,424	27,197	22,598	128,987	1,310	77,543	104,380	103,459	30,031	340	19,424	27,197	22,598
2005	50,013	627	37,345	50,306	37,680	26,624	323	19,202	25,867	20,282	155,610	1,632	96,745	130,247	123,740	26,624	323	19,202	25,867	20,282
2006	48,179	647	35,061	47,706	36,182	23,601	306	16,590	22,573	17,924	179,211	1,938	113,335	152,820	141,665	23,601	306	16,590	22,573	17,924
2007	46,407	667	31,733	43,998	34,809	20,919	290	13,817	19,158	15,869	200,131	2,229	127,152	171,977	157,534	20,919	290	13,817	19,158	15,869
2008	44,693	687	29,567	41,734	33,213	18,539	275	11,847	16,722	13,940	218,670	2,504	138,999	188,699	171,473	18,539	275	11,847	16,722	13,940
2009	43,014	708	32,197	45,214	30,706	16,419	261	11,871	16,671	11,881	235,089	2,765	150,870	205,370	183,354	16,419	261	11,871	16,671	11,881
2010	41,346	730	33,921	47,908	28,090	14,523	248	11,509	16,255	10,026	249,613	3,012	162,380	221,625	193,380	14,523	248	11,509	16,255	10,026
2011	39,685	752	34,937	49,556	25,819	12,828	235	10,908	15,472	8,498	262,440	3,247	173,288	237,097	201,878	12,828	235	10,908	15,472	8,498
2012	38,031	775	35,806	51,186	23,426	11,312	223	10,288	14,707	7,116	273,753	3,470	183,575	251,804	208,994	11,312	223	10,288	14,707	7,116
2013	36,384	799	37,246	53,338	21,090	9,959	211	9,847	14,102	5,915	283,712	3,681	193,423	265,906	214,910	9,959	211	9,847	14,102	5,915
2014	34,745	823	38,468	55,279	18,757	8,751	200	9,359	13,449	4,862	292,463	3,881	202,782	279,355	219,771	8,751	200	9,359	13,449	4,862
2015	33,113	848	40,279	57,869	16,371	7,675	190	9,018	12,956	3,927	300,138	4,071	211,800	292,311	223,698	7,675	190	9,018	12,956	3,927
2016	31,489	874	41,708	60,096	13,975	6,716	180	8,593	12,381	3,108	306,854	4,251	220,393	304,692	226,806	6,716	180	8,593	12,381	3,108
2017	29,873	901	41,330	58,560	13,544	5,863	171	7,836	11,102	2,768	312,718	4,422	228,228	315,794	229,574	5,863	171	7,836	11,102	2,768
2018	28,266	929	38,712	54,552	13,354	5,105	162	6,754	9,517	2,504	317,823	4,584	234,982	325,311	232,078	5,105	162	6,754	9,517	2,504
2019	26,667	957	37,764	52,409	12,980	4,432	154	6,063	8,414	2,235	322,255	4,738	241,045	333,725	234,313	4,432	154	6,063	8,414	2,235
2020	25,078	986	38,595	53,543	11,117	3,836	146	5,702	7,910	1,773	326,091	4,884	246,746	341,635	236,086	3,836	146	5,702	7,910	1,773
2021	10,027	424	16,510	22,861	4,099	1,411	58	2,244	3,108	605	327,502	4,941	248,991	344,743	236,691	1,411	58	2,244	3,108	605

TABULATION OF ANNUAL AND CUMULATIVE PRESENT VALUE COST DATA FOR MULAT TOWER COGEN SELF-BUILD OPTION

Attachment 1-4  
 Staffs 1st set of Interrogatories - No. 1  
 Docket No. 990325-EI

Year	Nominal \$1,000					Present Worth 1998 \$1,000					Accumulated Present Worth 1998 \$1,000				
	Capital	Fixed O&M	Fuel + VO&M	Fuel Savings	Total	Capital	Fixed O&M	Fuel + VO&M	Fuel Savings	Total	Capital	Fixed O&M	Fuel + VO&M	Fuel Savings	Total
2001	28,867	5,180	20,851	25,750	29,148	21,430	3,715	14,952	18,465	21,632	21,430	3,715	14,952	18,465	21,632
2002	44,679	8,904	35,856	45,696	43,743	30,522	5,875	23,660	30,153	29,904	51,952	9,590	38,612	48,618	51,536
2003	42,940	8,928	35,969	47,084	40,753	26,994	5,421	21,841	28,590	25,666	78,945	15,012	60,452	77,208	77,202
2004	41,404	8,953	36,086	48,673	37,770	23,952	5,003	20,164	27,197	21,921	102,897	20,014	80,616	104,405	99,123
2005	39,925	8,979	38,602	50,306	37,199	21,253	4,617	19,849	25,867	19,852	124,150	24,631	100,465	130,272	118,974
2006	38,498	9,006	40,713	52,102	36,115	18,859	4,261	19,264	24,653	17,731	143,009	28,892	119,729	154,925	136,705
2007	37,121	9,033	39,869	51,054	34,968	16,733	3,933	17,359	22,230	15,796	159,742	32,825	137,088	177,154	152,501
2008	35,790	9,061	36,347	47,235	33,964	14,846	3,631	14,563	18,926	14,114	174,588	36,456	151,652	196,080	166,615
2009	34,488	9,090	39,099	50,984	31,693	13,165	3,352	14,416	18,798	12,134	187,753	39,808	166,068	214,879	178,750
2010	33,194	9,120	40,850	53,738	29,427	11,660	3,094	13,860	18,233	10,382	199,413	42,902	179,928	233,111	189,131
2011	31,907	9,151	41,653	55,165	27,546	10,314	2,857	13,005	17,224	8,952	209,726	45,759	192,933	250,335	198,083
2012	30,626	9,183	42,595	56,877	25,527	9,110	2,638	12,238	16,341	7,645	218,836	48,397	205,171	266,677	205,728
2013	29,351	9,215	44,385	59,420	23,531	8,034	2,436	11,735	15,710	6,495	226,869	50,834	216,906	282,387	212,223
2014	28,082	9,249	45,806	61,609	21,528	7,073	2,250	11,144	14,989	5,479	233,943	53,084	228,051	297,376	217,702
2015	26,821	9,284	47,036	63,651	19,490	6,217	2,079	10,531	14,251	4,575	240,159	55,163	238,581	311,627	222,277
2016	25,566	9,320	48,734	66,194	17,425	5,453	1,920	10,040	13,638	3,776	245,613	57,083	248,622	325,264	226,053
2017	24,319	9,357	46,469	62,784	17,360	4,773	1,774	8,810	11,903	3,454	250,386	58,857	257,431	337,167	229,506
2018	23,078	9,395	45,456	60,527	17,403	4,168	1,639	7,930	10,560	3,178	254,554	60,496	265,362	347,727	232,685
2019	21,846	9,434	43,676	57,347	17,609	3,631	1,515	7,012	9,207	2,951	258,185	62,010	272,374	356,933	235,635
2020	20,621	9,474	43,920	57,842	16,174	3,154	1,400	6,488	8,545	2,497	261,339	63,410	278,862	365,478	238,132
2021	8,271	3,965	18,876	24,826	6,287	1,164	539	2,566	3,375	894	262,503	63,949	281,428	368,853	239,027

01

2. Provide a side-by side comparison of Gulf's base case generation expansion plan, the expansion plans resulting from the other self-build options, and the expansion plans resulting from each RFP respondent's project. If the RFP respondent's proposal is for less than twenty years, include the type and timing of the resources added by Gulf to meet its reliability criteria in later years of the plan. For all expansion plan cases, give the resulting annual summer and winter reserve margin on Gulf's system.

**RESPONSE:**

There was no remix of capacity resources in the original self-build evaluation process. For both the self-build and the RFP evaluation process, an allocated Southern expansion plan (specifically for Gulf Power) was not created in the evaluation of each of these supply side resources. Correspondingly, no operating company reserve margin information is available for each of these cases. However, the expansion plan information from each alternative PROVIEW<sup>®</sup> case in the RFP evaluation has been compiled and is attached.

**Cummulative Expansion Plan's from PROVIEW Analysis**

	Base Case		
	CI	CC	TOTAL
2002	1	1	2
2003	2	3	5
2004	2	5	7
2005	5	9	14
2006	6	10	16
2007	10	10	20
2008	10	12	22
2009	11	15	26
2010	11	15	26
2011	13	17	30
2012	14	21	35
2013	14	26	40
2014	18	28	46
2015	19	33	52
2016	20	38	58
2017	22	45	67
2018	25	49	74
2019	26	55	81
2020	27	61	88
2021	32	68	100

	SBO-Smith Unit 3		
	CI	CC	TOTAL
2002	2	0	2
2003	3	2	5
2004	3	4	7
2005	6	8	14
2006	6	10	16
2007	10	10	20
2008	11	11	22
2009	13	13	26
2010	13	13	26
2011	15	15	30
2012	16	19	35
2013	16	24	40
2014	18	28	46
2015	21	31	52
2016	23	35	58
2017	25	42	67
2018	27	47	74
2019	27	54	81
2020	29	59	88
2021	34	66	100

	Respondent A		
	CI	CC	TOTAL
2002	2	0	2
2003	3	2	5
2004	3	4	7
2005	6	8	14
2006	6	10	16
2007	10	10	20
2008	11	11	22
2009	13	13	26
2010	13	13	26
2011	14	16	30
2012	16	19	35
2013	16	24	40
2014	18	28	46
2015	20	32	52
2016	21	37	58
2017	24	43	67
2018	27	47	74
2019	28	53	81
2020	29	59	88
2021	35	65	100

	Respondent B CC(10yr)		
	CI	CC	TOTAL
2002	2	0	2
2003	3	2	5
2004	3	4	7
2005	6	8	14
2006	6	10	16
2007	10	10	20
2008	11	11	22
2009	13	13	26
2010	13	13	26
2011	14	16	30
2012	16	21	37
2013	16	26	42
2014	19	29	48
2015	21	33	54
2016	22	38	60
2017	25	44	69
2018	27	49	76
2019	28	55	83
2020	30	60	90
2021	34	68	102

	Respondent B CC(7yr)		
	CI	CC	TOTAL
2002	2	0	2
2003	3	2	5
2004	3	4	7
2005	6	8	14
2006	6	10	16
2007	10	10	20
2008	11	11	22
2009	13	15	28
2010	13	15	28
2011	15	17	32
2012	16	21	37
2013	16	26	42
2014	19	29	48
2015	21	33	54
2016	22	38	60
2017	25	44	69
2018	27	49	76
2019	28	55	83
2020	30	60	90
2021	34	68	102

	Respondent B CC(20yr)		
	CI	CC	TOTAL
2002	2	0	2
2003	3	2	5
2004	3	4	7
2005	6	8	14
2006	6	10	16
2007	10	10	20
2008	11	11	22
2009	13	13	26
2010	13	13	26
2011	14	16	30
2012	16	19	35
2013	16	24	40
2014	18	28	46
2015	19	33	52
2016	21	37	58
2017	24	43	67
2018	27	47	74
2019	27	54	81
2020	29	59	88
2021	34	66	100

	Respondent B CT(10yr)		
	CI	CC	TOTAL
2002	1	1	2
2003	1	4	5
2004	1	6	7
2005	5	9	14
2006	6	10	16
2007	10	10	20
2008	10	12	22
2009	12	14	26
2010	12	14	26
2011	13	17	30
2012	16	21	37
2013	16	26	42
2014	19	29	48
2015	21	33	54
2016	22	38	60
2017	25	44	69
2018	27	49	76
2019	28	55	83
2020	30	60	90
2021	34	68	102

	Respondent B CT(7yr)		
	CI	CC	TOTAL
2002	1	1	2
2003	1	4	5
2004	1	6	7
2005	5	9	14
2006	6	10	16
2007	10	10	20
2008	10	12	22
2009	13	15	28
2010	13	15	28
2011	15	17	32
2012	16	21	37
2013	16	26	42
2014	19	29	48
2015	21	33	54
2016	22	38	60
2017	25	44	69
2018	27	49	76
2019	28	55	83
2020	30	60	90
2021	34	68	102

	Respondent B CT(20yr)		
	CI	CC	TOTAL
2002	1	1	2
2003	1	4	5
2004	1	6	7
2005	5	9	14
2006	6	10	16
2007	10	10	20
2008	10	12	22
2009	12	14	26
2010	12	14	26
2011	13	17	30
2012	15	20	35
2013	16	24	40
2014	17	29	46
2015	19	33	52
2016	20	38	58
2017	23	44	67
2018	25	49	74
2019	26	55	81
2020	28	60	88
2021	32	68	100

	Respondent C		
	CI	CC	TOTAL
2002	2	0	2
2003	3	2	5
2004	3	4	7
2005	6	8	14
2006	6	10	16
2007	12	10	22
2008	12	12	24
2009	13	15	28
2010	13	15	28
2011	15	17	32
2012	16	21	37
2013	16	26	42
2014	19	29	48
2015	21	33	54
2016	22	38	60
2017	25	44	69
2018	27	49	76
2019	28	55	83
2020	30	60	90
2021	34	68	102

	Respondent C (Fixed Energy)		
	CI	CC	TOTAL
2002	1	1	2
2003	2	3	5
2004	2	5	7
2005	5	9	14
2006	6	10	16
2007	12	10	22
2008	12	12	24
2009	13	15	28
2010	13	15	28
2011	15	17	32
2012	16	21	37
2013	16	26	42
2014	19	29	48
2015	21	33	54
2016	22	38	60
2017	25	44	69
2018	27	49	76
2019	28	55	83
2020	30	60	90
2021	34	68	102

4. Provide a breakdown of all transmission-related costs associated with each self-build option and all respondents to Gulf's RFP.

**RESPONSE:**

The Company has decided to group the responses to interrogatories 4, 11, and 12 together because they are all related to transmission impacts and plans. Also, the Company does not perform a 20-year transmission plan as requested in Interrogatories 11 and 12.

The following is a tabulation of the specific transmission improvements and their costs (98\$) that are associated with each alternative that Gulf evaluated in either the self-build or RFP process:

**SBO Case No. 1 - Daniel Combined Cycle Participation**

Construct N. Brewton - Shoal River 230 kV	\$ 60.0M
Shoal River - Laguna 230 kV line	\$ 46.5M
Daniel CC connection (includes GSU)	\$ 4.1M
41.88% share of Ellicott-N.Brewton 230kV	\$ 24.1M
8.88% share of Daniel-Big Creek 230 kV	\$ 2.1M
TOTAL	\$136.8M

**SBO Case No. 2 - Mulat Tower Cogeneration Unit**

Cogeneration unit connection (Includes GSU)	\$ 17.0M
Shoal River - Laguna 230 kV line	\$ 46.5M
Crist - Shoal River 230 kV line	\$ 20.3M
Ellicott - Crist #2 230 kV line	\$ 36.0M
TOTAL	\$119.8M

**SBO Case No. 3 - Smith CT or CC Units**

Smith connection costs (Includes GSU)	\$ 4.6M
Ellicott - Crist #2 230 kV line (2003)	\$ 36.0M
TOTAL	\$ 40.6M

**RFP Case No. 1 - Respondent A**

**2002 improvements:**

Construct Shoal River - Laguna 230kv	\$46.0M
Construct N. Brewton- Shoal River 230 kV	\$45.6M
Facility Connection - Santa Rosa	\$6.2M
Facility Connection - Mobile	\$1.9M
TOTAL	\$ 99.7M

**RFP Case No. 2 - Respondent B**

2002 improvements:

Reconductor Chickasaw - S. Hill #1	\$ 6.0M
Reconductor Chickasaw - S. Hill #2	\$ 6.4M
Reconductor Big Creek - Chickasaw 230 kV	\$ 2.1M
Reconductor Blakely Is. - Spanish Fort	\$ 2.4M
Reconductor Barry - Crist 230 kV	\$ 7.2M
Reconductor Barry - Chickasaw 230 kV	\$ 6.5M
Construct Facility - Laguna 230 kV	\$26.0M
Facility Connections	\$ 2.4M

2009 Improvements:

Construct N. Brewton - Shoal River 230 kV	<u>\$45.6M</u>
TOTAL	\$104.6M

**RFP Case No. 3 - Respondent C**

2002 improvements:

Reconductor Chickasaw - S. Hill #1	\$6.0M
Reconductor Chickasaw - S. Hill #2	\$6.4M
Reconductor Big Creek - Chickasaw 230 kV	\$2.1M
Construct Shoal River - Laguna 230 kV	\$46.0M
Construct N. Brewton - Shoal River 230 kV	\$45.6M

2005 Improvements:

Reconductor Barry - Chickasaw 230 kV	<u>\$6.5M</u>
TOTAL	\$112.6M

**RFP Case No. 4 - Smith Unit 3**

2002 improvements:

Reconductor Chickasaw - S. Hill #1	\$ 6.0M
Reconductor Chickasaw - S. Hill #2	\$ 6.4M
Reconductor Big Creek - Chickasaw 230 kV	\$ 2.1M
Reconductor Blakely Is - Spanish Fort	\$ 2.4M
Reconductor Barry - Crist 230 kV	\$ 7.2M
Reconductor Barry - Chickasaw 230 kV	\$ 6.5M
Smith - Greenwood 115 kV reconductor	\$ 1.2M
Smith - Highland City 115 kV reconductor	\$ 1.2M
Highland City-Callaway 115 kV reconductor	\$ 0.7M
Smith Connections	\$ 2.2M
Replace 6 Smith Circuit Breakers	\$ 1.2M
Replace 1 Brkr. at Laguna & Highland City	\$ 0.3M

2009 Improvements:

Construct N. Brewton - Shoal River 230 kV	<u>\$ 45.6M</u>
TOTAL	\$ 83.0M

FPSC Staff's First Set  
 Of Interrogatories  
 Docket No. 990325-EI  
 GULF POWER COMPANY  
 April 19, 1999  
 Item No. 4

The following transmission system improvements are those which are contained in Gulf's Capital Budget. These items are compared on the basis of their status both before and after the decision to pursue Smith Unit 3. As shown below, the addition of Smith Unit 3 does not have a significant impact on the transmission plan. However, there would have been significant impacts had a different alternative been chosen. Two of the items are associated specifically with generation in the Bay County area.

<u>ITEM DESCRIPTION</u>	<u>BEFORE SMITH 3</u>		<u>AFTER SMITH 3</u>	
	<u>IN-SERVICE DATE</u>	<u>CAPITAL COST K\$</u>	<u>IN-SERVICE DATE</u>	<u>CAPITAL COST K\$</u>
Crist-Blackwater 115 kV reconductor	2001	7,900	2001	7,900
Shoal River-ValP 115 kV reconductor	2001	2,900	2001	2,900
Highland City-Callaway 115 kV reconductor(1)	N/A	N/A	2006	1,200
Holmes Creek-Scholz 115kV reconductor	1999	7,206	1999	6,206
Crist-Pace 115 kV reconductor	2001	1,600	2001	1,600
ValP-Niceville 115 kV reconductor	2001	720	2001	720
Smith-Highland City 115 kV reconductor (1)	2001	N/A	2001	1,200
Smith-Greenwood 115 kV reconductor (1)	2001	N/A	2001	1,200
Shoal River-Glendale Tap new line	2001	2,400	2001	2,900
Callaway Capacitor bank addition	2001	490	2005	490
Scholz Capacitor bank addition	1999	450	1999	450
Smith-Laguna Bch. line upgrade (2)	N/A	N/A	2006	160
Laguna Bch.-Lullwater line upgrade (2)	N/A	N/A	2006	520
Smith & Laguna Bch. breaker replacement (1)	N/A	N/A	2002	2,210

FPSC Staff's First Set  
Of Interrogatories  
Docket No. 990325-EI  
GULF POWER COMPANY  
April 19, 1999  
Item No. 4

- Notes:**
- (1) This improvement is directly associated with additional generation located in Bay County and was inadvertently omitted from the Petition for Need Determination. Amended figures will be subsequently filed to correct this oversight. The costs associated with these improvements were included in the Smith Unit 3 cost used in the RFP evaluation process. No change in the relative cost-effectiveness occurs from this change.
  - (2) This improvement is a local area problem and is not associated with the addition of generation in the Bay County area.

8. Discuss the current status of negotiation with the RFP respondents "with the best offers", as stated at page 69 of the Need Study. Explain the chances that an RFP project will be signed and build instead of Smith Unit 3.

**RESPONSE:**

The reference on page 69 of the Need Study was relative to the gas supply Request for Proposals (RFP), not the capacity RFP. Gulf is continuing to pursue natural gas supply offers in order to achieve the best fuel costs for Smith Unit 3.

16. On page 49 of the Need Study, it states, in part, "if necessary, adjustments were made to reflect any cost differences due to natural gas supply at a point other than the Henry Hub, and any differences due to the specifics of the proposal, such as a commodity price adder." Indicate the amount of the adjustment (\$/MMBtu), if any, that was made during the evaluation of all self build alternatives and all RFP respondents. (State whether costs are in nominal or in real dollars.)

**RESPONSE:**

All prices are given in nominal dollars. There is an assumed basis difference of \$0.06 per MMBtu was used when comparing Henry Hub Index Prices to Florida Gas Transmission - Zone 3 Index Prices. An additional \$0.05 per MMBtu basis difference was used for gas delivered at Mobile Bay Plants from FGT - Zone 3. The adjustment to the commodity price depends on the assumed point of delivery location from the Henry Hub. The tabulation below shows the adjustments made to the gas commodity prices for the various alternative options based on the delivery from Henry Hub.

An additional \$.02 premium was applied to all of the Self-build prices as a fee to secure gas availability. This was not done in the RFP process since the respondents were making quotes to Southern and were specifying its firmness.

To all the natural gas commodity prices, the appropriate transportation cost was added to determine delivered fuel cost.

<u>SELF-BUILD/RESPONDENT</u>	<u>COMMODITY PRICE BASIS</u>	<u>COMMODITY PRICE ADJUSTMENT</u>
Self-Build Smith option	Henry Hub	<\$ .06>
Self-Build Daniel option	Henry Hub	\$ .00
Self-Build Mulat Tower option	Henry Hub	<\$ .11>
Respondent A	Henry Hub +4%	\$ .00
Respondent B	Henry Hub	\$ .00
Respondent C	Henry Hub	\$ .00
RFP Smith option	Henry Hub	<\$ .06>

17. Identify and provide the forecast of all fixed and variable costs (\$/MMBtu) for transporting natural gas for all self build alternatives and all RFP respondents from 2002 to 2021. Include any charge, fee, tax, levy or any other monetary or non-monetary consideration to transport natural gas. State all assumptions. (State whether costs are in nominal or real dollars.)

**RESPONSE:**

There were no fuel estimates performed for self-build option "Mulat Tower" since this concerned a cogeneration facility that had a delivered gas price and annual escalation provided as part of the input assumptions. Likewise, the fuel for Respondent C of the RFP analysis was assumed to be that which was quoted. The fuel projections used for Respondents A and B of the RFP analysis also had backup oil components added to their natural gas prices to account for those hours the gas would not be available under the terms of their non-firm gas proposal.

The remainder of this response was filed with Letter of Intent to request Confidential treatment.

18. For all self build generation alternatives and all RFP respondents, indicate how Gulf Power or the RFP respondent plans to replace the capacity, energy, or both when the primary fuel is not available.

**RESPONSE:**

All self-build options included dedicated firm natural gas supply as well as gas storage. In the event that no gas supply is available the unit will not run, and any necessary replacement energy will be procured from the market. Respondent A had fuel oil backup at only one of the facilities, gas storage was included, but firm gas transportation was not offered. Respondent B included fuel oil backup at the site and eventually included dedicated firm gas transportation for their combined cycle proposals. No fuel oil backup was provided by Respondent C, but additional cost was itemized in their proposal for dedicated firm natural gas delivery.

19. Provide Gulf Power's system-wide forecast for delivered coal prices from 2002 to 2021 in dollars per million BTU (\$/MMBtu) and dollars per ton (\$/ton). State whether costs are in nominal or real dollars. Also include the following assumptions: type of coal; origin of coal; heat content; ash content; moisture content; and sulfur content.

**RESPONSE:**

There is no Gulf Power system-wide forecast for delivered coal (interrogatory #19) or delivered oil (interrogatory #20). In an effort to provide relative fuel cost information, Gulf has expanded the commodity (non-delivered) information originally provided in Table 5-1 of the Need Study to include additional years and quality information. These prices are the basis of delivered fuel prices in the planning studies. Site-specific delivery costs can be added to determine the total delivered fuel costs. All Prices are in Nominal Dollars.

	<u>COAL</u>		<u>NAT. GAS</u>		<u>OIL</u>	
	<u>\$/MMBtu</u>	<u>\$/Ton</u>	<u>\$/MMBtu</u>	<u>\$/MCF</u>	<u>\$/MMBtu</u>	<u>\$/Bbl</u>
1999	1.071	25.71	2.28	2.35	3.94	28.75
2000	1.080	25.92	2.28	2.35	4.06	29.64
2001	1.089	26.13	2.28	2.35	4.18	30.54
2002	1.098	26.34	2.28	2.35	4.30	31.47
2003	1.107	26.56	2.28	2.35	4.43	32.43
2004	1.115	26.77	2.28	2.35	4.58	33.43
2005	1.125	26.99	2.47	2.54	4.72	34.78
2006	1.134	27.21	2.62	2.70	4.87	36.18
2007	1.143	27.43	2.79	2.87	5.02	37.64
2008	1.152	27.65	2.96	3.05	5.18	39.17
2009	1.162	27.88	2.98	3.07	5.34	40.75
2010	1.171	28.10	3.00	3.09	5.57	42.42
2011	1.180	28.33	3.07	3.16	5.80	44.13
2012	1.190	28.57	3.15	3.26	6.04	45.87
2013	1.200	28.80	3.22	3.32	6.29	47.68

2014	1.210	29.03	3.30	3.40	6.55	49.57
2015	1.220	29.27	3.38	3.48	6.82	52.01
2016	1.230	29.51	3.45	3.55	7.10	54.56
2017	1.240	29.76	3.71	3.82	7.39	57.25
2018	1.250	30.00	3.98	4.10	7.69	60.06
2019	1.260	30.25	4.28	4.41	8.00	63.02
2020	1.271	30.50	4.42	4.55	8.40	66.12
2021	1.282	30.76	4.58	4.72	8.82	69.22
2022	1.292	31.01	4.74	4.88	9.26	72.32

- (1) Coal is Central Appalachia FOB Price, 12,740 Btu, 1.0% Sulfur, 9.0 Ash, 8% Moisture.
- (2) Gas is FOB Mobile Bay, 1.030 MMBtu/MCF.
- (3) Oil is FOB Gulf Coast, 140,620 Btu/gal, 0.45% Sulfur, 0% Ash.

20. Provide Gulf Power's system-wide forecast for delivered oil prices from 2002 to 2021 in dollars per million BTU (\$/MMBtu) and dollars per barrel (\$/barrel). State whether costs are in nominal or real dollars. Also include the following assumptions: heat content; ash content; and sulfur content.

**RESPONSE:**

See tabular response to Interrogatory number 19

21. Indicate the annual level of NOx emissions that Gulf Power expects from the proposed Smith Unit 3 from 2002 through 2021. State assumptions.

**RESPONSE:**

The maximum potential NOx emissions from Smith Unit 3 are estimated to be 760 tons of NOx per year. This estimate is based on a 100% capacity factor assumption for Smith Unit 3 for the years 2002 through 2021. EPA requires the use of maximum potential emission estimates for all air environmental impact statements. No other emission estimates are available.

22. Page 76 of the Need Study states, in part, "Gulf is pursuing an air emission strategy that will reduce NOx emissions from one of the existing Smith generating units leading to a net reduction in total NOx emissions for the entire plant." Discuss Gulf Power's plans to reduce total NOx emissions for its Smith Plant.

**RESPONSE:**

Gulf Power proposes to offset new NOx emissions from Smith Unit 3 by reducing emissions at Smith Unit 1 to amounts necessary to obtain a net reduction in NOx at the facility. Smith Unit 1 is a coal-fired boiler with annual emissions of 3594 tons of NOx. Gulf Power's plan is to cap NOx emissions on Smith Unit 1 at 2832 tons per year. This amount is equal to or less than potential emissions (760 tons) at the maximum capacity of Unit #3 at Smith. Gulf Power will accomplish the reductions through installing low NOx burner technology and GNOCIS, a Generic NOx Control Intelligent System on Unit 1. The low NOx burner technology on Smith Unit 1 will reduce emissions by reducing the amount of oxygen available for the combustion process and GNOCIS assists in this reduction by operating the total burner system more efficiently through neural network technology.

23. Itemize the capital and O&M costs of the Selective Catalytic Reduction (SCR) system that Gulf Power used while evaluating the cost-effectiveness of its self-build options and RFP responses.

**RESPONSE:**

SELECTIVE CATALYTIC REDUCTION COSTS

<u>Capital Costs</u>	<u>(\$1998)</u>
Direct Vendor - Materials D&E	\$2,919,140
Indirects (10%)	<u>\$291,914</u>
Total Installed Equipment	\$3,211,054
<u>Annual O &amp; M Costs</u>	<u>(\$1998)</u>
Ammonia	\$115,676
Maintenance	\$29,620
O&M Labor	\$185,500
Station Service	\$13,808
Pressure Drop Penalty	\$318,856
SCR Catalyst Replacement	<u>\$306,872</u>
Total O&M Costs	\$970,332

24. The Need Study states, in part, "(c)ondenser cooling for Smith Unit 3 will be accomplished by a closed-cycle cooling tower system, which will minimize cooling water withdrawals and discharges." Itemize the capital and O&M costs for the closed-cycle cooling tower system, discussed on page 76 of the Need Study, that Gulf Power will use for Smith Unit 3.

**RESPONSE:**

**Cooling Tower Chemical Feed System Equipment Cost**

Nonoxidizing Biocide Skid	\$	12,000
Dispersant Skid	\$	12,000
Corrosion Inhibitor Skid	\$	10,000
Sulfuric Acid Skid	\$	30,000
Sodium Hypochlorite Skid	\$	20,000
Cooling Tower Feed Skid Enclosure	\$	20,000
Chemical Containment	\$	10,000
Bulk Tank Pads	\$	10,000
Installation Labor	\$	51,000
		<hr/>
TOTAL	\$	175,000

**Cooling System Equipment Cost Data**

Circulating Water Piping, Valves Thrust Blocks, Excavation, etc.	\$1,181,000
Circulating Water Pump Structure	\$ 46,000
Circulating Water Pumps (CWP)	\$ 524,000
Circulating Water Pump Motors	\$ 229,000
Cooling Tower Foundation	\$ 132,000
Cooling Tower Basin	\$ 302,000
Cooling Tower	\$2,800,000
Cooling Tower Motor Control Center(MCC)	\$ 97,000
Cooling Tower MCC Building	\$ 39,000
Cooling Tower MCC Cable/Conduit	\$ 169,000
Cooling Tower Blowdown Piping	\$ 13,000
Cooling Tower Basin Outlet	\$ 105,000
Condenser	\$2,477,000
Condenser Vacuum Pumps	\$ 277,000
Condenser Vac. Sys. Piping/Valves	\$ 23,000
Chemical Feed House	\$ 53,000
	<hr/>
TOTAL	\$8,467,000

FPSC Station First Set  
Of Interrogatories  
Docket No. 990325-EI  
GULF POWER COMPANY  
April 19, 1999  
Item No. 24

The following shows the estimated operating and maintenance requirements for the cooling system:

Cooling Tower Station Service Operating Requirements:

10 Fans @ 200 BHP/Fan (2,000 BHP) ~ 1500 kW

Circulating Water Pump (CWP) Station Service Operating Requirements:

2 CWPs @ 63,000 GPM/Pump (2,680 BHP) ~ 2000 kW

Condenser Vacuum Pump Station Service Operating Requirements:

2 Vacuum Pumps @ 150 BHP/pump (300 BHP) ~ 224 kW

Cooling system maintenance costs (tower, condenser, pumps, etc.) are currently estimated to be approximately \$50,000 to \$100,000/year.

25. Page 76 of the Need Study states, in part, "(f)rom an environmental standpoint, the proposed facility will have a net positive impacts." Please elaborate further on this statement.

**RESPONSE:**

As stated in the Need Study, the two principal environmental issues associated with operation of Smith 3 are NOx emissions and thermal impacts from the discharge of cooling water.

Cooling tower blowdown from Smith Unit 3 will join with the existing cooling water discharge of Smith Units 1 and 2 before ultimately being discharged into West Bay. Because the blow-down from Smith Unit 3 will be taken from the cold-side of the cooling tower, there will be a slight decrease in the overall temperature of the discharge water entering West Bay.

Gulf Power plans to offset new NOx emissions from Smith Unit 3 by reducing NOx emissions at the existing Smith Unit 1. This will be accomplished by installing low NOx burner technology and a neural network software package on Smith Unit 1. The NOx emission reduction from Smith Unit 1 will more than offset the proposed NOx emissions from Smith Unit 3.

FPSC Staff First Set  
Of Interconnection  
Docket No. 990325-EI  
GULF POWER COMPANY  
April 19, 1999  
Item No. 27

27. Provide a description of each of Southern's interconnection points with other utilities or utility systems. Include the import capability, in megawatts (MW) and megavars (MVAR), of each of these interconnection points individually and of the Southern Company system as a whole.

**RESPONSE:**

See Attachment 27-1.

**TABULATION OF SOUTHERN SYSTEM INTERFACES & IMPORT CAPABILITY**

Attachement 27-1  
 Staff's 1st set of Interrogatories  
 Item No. 27  
 Docket No. 990325-EI

<u>Interfaces with Indicated Control Areas</u>	<u>Interface Composed of Following Transmission Lines</u>	<u>Thermal Rating</u>	<u>1999 OASIS TTC Imports Into Southern</u>
		<u>MVA</u>	<u>MW</u>
Duke Power Company	Norcross-Oconee 500kv	2439	1049
	Bio-ANP Hartwell-Hartwell Dam 230kv	664	
South Carolina Electric & Gas	Vogtle-Savannah River Plant 230kv	756	229
	McIntosh-McIntosh Tap 115kv	240	
	Acadia Tap-Urquhart 115kv (Normally Open)	151	
	South Augusta-Urquhart 115kv (Normally Open)	151	
South Carolina Public Service Authority	McIntosh-Bluffton 230kv	829	507
Tennessee Valley Authority	Bowen-Sequoyah 500kv	2598	1204
	Rock Spring-Oglethorpe 161kv	446	
	East Dalton-Widows Creek 230kv	602	
	Miller-Bellefonte 500kv	1732	
	Miller-Lowndes 500kv	1732	
	Attalla-Albertville 161kv	192	
	Blountsville-guntersville 115kv	94	
	Haleyville-Wilson 161kv	282	
	S. Vernon Tap-Lowndes 161kv	180	
	SEPA (Connections to VACAR)	Evans-Thurmond Dam 115kv #1	
Evans-thurmond Dam 115kv #2		135	
Double Branches-thurmond Dam 115kv		57	
Lexington-Russell Dam 230kv		497	
Entergy	Logtown-slidell 230kv	797	1078
	Hattiesburg SW-Bogalusa 230kv	458	
	Collins-magee 115kv	76	
	NWForest-Morton 115kv	120	
	Daniel-McKnight 500kv	1800	
Florida	Hatch-Duval 500kv	2598	1276
	Thalman-Duval 500kv	2598	
	Kingsland-Yulee 230kv	497	
	Pinegrove-Sterling-Swannee 230kv	509	
	Pinegrove-Wrights Chapel-Jasper 115kv	43	

10  
03

Twin Lakes-Suwannee 115kv	124
Tarver-Jasper 115kv	60
Scholz-Woodruff 115kv	124
Callaway-Port St. Joe 230kv	433
South Bainbridge-Sub 20 230kv	497

Alabama Electric Cooperative

West Point Dam(SEPA)-Opelika 115kv	216
George Dam (SEPA)-Capps SW 115kv	155
George Dam (SEPA)-Judson Tap 115kv	79
R.F. Henry Dam (SEPA)-Gordonsville Jct 115kv	137
Greenville-Belleville 230kv	602
Boise Cascade-Lowman 115kv	212
McIntosh-McIntosh (AEC) 115kv	424
W. McIntosh-McIntosh 115kv	415
W. McIntosh-Lowman 230kv	602
Pinkard-Opp 230kv	349
N. Brewton-Opp 230kv	349
Flomation-Atmore 115kv	212
Perdido-Atmore 115kv	212
Boise Cascade Tap-Lowman 115kv	212
Niceville-Blue Water 115kv	216
Scholz-Gaskin 115kv	100
Cristal Beach-Blue Water 115kv	161
Callaway-Gaskin 115kv	100
Bonifay-Bonifay (AEC) 115kv	209
Monroe-Belleville 230kv	502
Monroe-Arn 230kv	502

393

Southern Mississippi Electric Power Authority

Purvis 230/115kv Transformer Ckt 1	168
Purvis 230/115kv Transformer Ckt 2	168

0

27

FPSC Staff's Second Set  
Of Interrogatories  
Docket No. 990325-EI  
GULF POWER COMPANY  
June 2, 1999  
Item No. 32

32. Please explain the reasons why Gulf does not plan to use a backup fuel source for the proposed Lansing Smith Unit 3?

**RESPONSE:**

From a system planning perspective, based on the Company's reliability criteria, the proposed Smith Unit 3 does not need a backup fuel source. Gulf will use a firm supply of natural gas (including firm transportation) as the exclusive fuel source for Smith Unit 3. The Southern electric system, of which Gulf is part, has a large amount of generating capacity that does not rely on natural gas. In the unlikely event of an interruption of the natural gas supply, the Southern electric system resources provide sufficient reserves to Gulf.

Although Smith Unit 3 is a significant capacity resource relying on a single fuel source, according to Gulf's planning criteria, the Company will continue to serve its customers in the event of a reasonably foreseeable interruption in the natural gas supply. Other Southern operating companies are adding combined cycle units of greater capacity than that of Smith Unit 3 and are not providing for backup fuel supplies. The other Southern operating companies, like Gulf, will use firm gas supplies and transportation as well as off-site natural gas storage capacity.

In addition, there are environmental benefits from utilizing natural gas as the exclusive fuel source. Providing backup fuel capability for Smith Unit 3 would be a cost that the customers would have to bear without an associated benefit from a reliability standpoint.

FPSC Staff's Second Set  
Of Interrogatories  
Docket No. 990325-EI  
GULF POWER COMPANY  
June 2, 1999  
Item No. 33

33. How would an interruption of the natural gas supply to the proposed Lansing Smith Unit 3 impact reliability in both the Panama City, Florida, region of Gulf's service territory, and throughout all of Gulf's territory?

**RESPONSE:**

An interruption of the natural gas supply to Smith Unit 3 that causes the loss of the unit would not result in a corresponding loss in service to the customers in either the Panama City area or anywhere in Gulf's service area. Gulf's planning criteria calls for maintaining service to its customers for the loss of any generating unit and any transmission element (line or autotransformer). Therefore, even if there were a total gas supply interruption causing Smith Unit 3 to come off line at the same time as a loss of a transmission facility, the Company would still be able to provide service to its customers.

It is important to note that outages due to gas supply problems, although possible, occur with far less frequency than other outages, such as those caused by problems with boiler or auxiliary equipment associated with the unit. A backup fuel source would do nothing to prevent outages associated with these other events that are much more likely to occur than a gas supply interruption.

FPSC Staff's Second Set  
Of Interrogatories  
Docket No. 990325-EI  
GULF POWER COMPANY  
June 2, 1999  
Item No. 34

34. If Gulf were to have a backup fuel source for the proposed Smith Unit 3, please describe the type of fuel to be chosen (commodity and storage) and the expected amount of fuel stored (number of days at 100% dispatch).

**RESPONSE:**

The fuel would likely be No.2 low sulfur fuel oil stored in an atmospheric tank. At full load, assuming no duct burning in the HRSG, the unit would consume approximately 674,000 gallons per day. A minimum 3-day supply would require slightly more than 2 million gallons of useable storage. Given the difficulty in getting a sufficient quantity of trucks to the site to keep up with the demand, a 5-day supply (3.4 million gallons) might be preferable.

Unfortunately, fuel oil cannot be stored indefinitely. Long term storage requires the use of stabilizers and inhibitors. Many users have found that it is better to burn oil occasionally and thereby turn the tank volume over. Having to burn the fuel oil at times when it is not necessary, for the purpose of preventing its deterioration, would increase the operating cost of the unit. Also, this periodic use of fuel oil on other than an emergency basis has an adverse cost impact on Gulf and its customers through a change in environmental permitting and operating requirements.

FPSC Staff's Second Set  
Of Interrogatories  
Docket No. 990325-EI  
GULF POWER COMPANY  
June 2, 1999  
Item No. 35

35. Please provide an estimate of the cost of the backup fuel storage for the proposed Lansing Smith Unit 3 using the assumptions made by Gulf in responding to Interrogatory #34. Please provide the estimate in both a Net Present Value Cost per Kilowatt-year (NPC\$/kw-yr) and in total dollars, both nominal and in present worth revenue requirements. Include the capital, operations and maintenance (O&M), and any other variable costs associated with maintaining the backup fuel source for the unit.

**RESPONSE:**

Assuming a 3-day supply, the expected capital cost would be approximately \$6 million. This estimate further assumes that the added facilities necessary to support on-site oil storage and related backup fuel burning capability could be installed without the need for additional wetland mitigation. The specific amounts of O&M increases necessary to support back-up fuel capability have not been determined. However, it is known that the number of fired hours on oil will impact combustion turbine maintenance. There will also be labor costs associated with scheduling and receiving oil. Added to this will be the carrying costs for the fuel inventory, estimated to be \$400,000 per year.

As pointed out in Gulf's Need Study, the environmental strategy for NOx emissions is to provide offsets of NOx emissions from existing Smith Plant units. If Gulf is required to provide fuel oil as a backup fuel for Smith Unit 3, then the maximum potential emissions on oil must enter into the environmental permitting process. The two major impacts of this change are (1) the additional cost for NOx compliance and (2) the cost associated with delaying the project beyond the needed June 2002 in-service date. Because the use of fuel oil as a backup negates the NOx offset strategy, there would be additional environmental compliance costs and there will no longer be the benefit of a total reduction in the NOx output of the generating units at the Smith site.

The \$6 million capital cost referred to above does not include the additional cost to comply with air emission standards for NOx based on consideration of the maximum potential use of #2 low-sulfur fuel oil as a backup fuel. The capital cost for Selective Catalytic Reduction (SCR) is estimated at just over

FPSC Staff's Second Set  
Of Interrogatories  
Docket No. 990325-EI  
GULF POWER COMPANY  
June 2, 1999  
Item No. 35

\$2,000,000 and the O&M for SCR is approximately \$1,000,000 per year.

The environmental permitting process will be delayed as a result of going to fuel oil as a backup fuel for Smith Unit 3. This delay will postpone the in-service date for the unit by approximately one year and require Gulf to purchase replacement power at prices that are clearly higher than that of Smith Unit 3. Under the market conditions known today, this replacement power could cost tens of millions of dollars for that one-year delay.

This additional cost of providing backup fuel capability is of particular concern since there is no reliability benefit to be derived. Gulf's customers are not going to suffer a loss of service as a result of an outage caused by a natural gas pipeline interruption. However, the environment would suffer as a result of having to provide backup fuel for Smith Unit 3.

Staff's First Request for  
Production of Documents  
Docket No. 990325-EI  
GULF POWER COMPANY  
April 19, 1999  
Item No. 17

17. Provide all documents which Gulf Power used to evaluate NOx, SO2, and particulate emission levels from the proposed Smith Unit 3.

**RESPONSE:**

See the Self-Build Emissions (Case 1-5) and Smith Unit 1 PSD Netting Out Worksheet attached.

# Smith Unit 1 PSD Netting Out Worksheet

03/29/99 Revised

Baseline Heat Input Calculation	
<b>1996 Smith 1</b>	
Coal	520,766 tons @ 23.55 MBTU/ton = 12264039 MBTUs
Oil	65.9 K gallons @ 138.5 MBTU/Kgallon = 9127 MBTUS
<b>Total</b>	<b>(Coal MBTUs + Oil MBTUS = 12273166 MBTUS)</b>
<b>1998 Smith I</b>	
Coal	522,256.50 tons @ 23.53 MBTU/ton = 12288695 MBTUs
Oil	70.76 K gallons @ 138.48 MBTU/Kgallon = 9799 MBTUS
<b>Total</b>	<b>(Coal MBTUs + Oil MBTUS = 12298494 MBTUS)</b>
<b>1996-98 Avg. (12273166 + 12298494)/2 = 12285830</b>	
<i>Note: 1997 not used in averaging plan as representative due to 37 day outage during year.</i>	
<i>1996-98 agreed on by Clair Fancy as baseline years for this project 1/25/99</i>	

Baseline NOx Emissions	
1996 Smith I	12273166 MBTUs x .614 lbs/MBTUs (CEMS data)/2000 = 3768 NOx Tons
1998 Smith I	12298494 MBTUs x .557 lbs/MBTUs (CEMS data)/2000 = 3425 NOx Tons
<b>1996-98 Avg</b>	<b>(3768 + 3425)/2 = 3597 NOx tons</b>

FDEP/Gulf Power Agreement to use 1996 + 1998 Avg for Baseline PSD Netting Calculation.	
1996+98 Avg Tons =	3597 NOx
1996+98 NOx Avg Rate =	.586 lbs/mbtu
1996+98 NOx Avg Rate @ 21.3% Control =	.461 or 2832 NOx tons
1996+98 NOx Avg Rate @ 30% Control =	.410 or 2519 NOx tons
1996+98 Avg Heat Input =	12285830 MBTUs

NOx CCCT Emissions	NOx Tons	CO Tons	Part Tons	VOC Tons
1000 hours Power Aug. at 13.7 ppm or 116 lb/hr(2) =	116	124	33	20
7760 hours at 10.4 ppm or 83 lb/hr per CT (2) =	644	585	162	79
<b>total per yr =</b>	<b>760</b>	<b>709</b>	<b>195</b>	<b>99</b>

Smith 1 NOx Ton Reduction using 1996+98 Avg Baseline		
@21.3% Reduction =	3597-2832	765 Tons
@30% Reduction =	3597-2519	1078 Tons

Net NOx Reduction (Smith I less CCCT Estimates)		
@21.3% Reduction Scenario =	765-760 =	5 Tons
@30% Reduction Scenario =	1078-760 =	318 Tons

Future Year Impact Analysis							
Year	Annual Heat Input mmBtu	Actual NOx Rate	Actual NOx Tons	Estimated	Estimated	Estimated	Estimated
				NOx Tons @21.3%	NOx Tons Reduction	NOx Tons @30%	NOx Tons Reduction
SMITH HC 1	1994	8798530					
SMITH HC 1	1995	12562424	0.635	3989			
SMITH HC 1	1996	12273166	0.614	3768			
SMITH HC 1	1997	10776657	0.612	3298			
SMITH HC 1	1998	12298494	0.557	3425			
SMITH HC 1	2000	9252020			2133		1897
SMITH HC 1	2001	8864413			2043		1817
SMITH HC 1	2002	8125687			1873	964	1666
SMITH HC 1	2003	6949575			1602	1235	1425
SMITH HC 1	2004	7213593			1663	1174	1479
SMITH HC 1	2005	6816910			1571	1266	1397
SMITH HC 1	2006	7285515			1679	1158	1494
SMITH HC 1	2007	5646277			1301	1536	1157
SMITH HC 1	2008	6984874			1610	1227	1432
SMITH HC 1	2009	9447624			2178	659	1937
SMITH HC 1	2010	8904809			2053	784	1825

Gulf Self-Build Emissions  
(Revised 4/9/99)

CT Emissions @ Duct Burner Inlet (vol. %)	Case 1	Case 2	Case 3	Case 4	Case 5	Case 6
O2	12.08	12.08	11.04	12.29	12.29	12.57
CO2	3.84	3.84	3.84	3.89	3.89	3.87
H2O	10.31	10.31	15.24	8.91	8.91	7.57
N2	72.9	72.9	69.06	74.03	74.03	75.09
Ar	0.87	0.87	0.82	0.88	0.88	0.9
NOx	0.001	0.001	0.0014	0.001	0.001	0.001
CO	0.0013	0.0013	0.0013	0.0014	0.0014	0.0014
VOC (non-methane/non-ethane)	0.0003	0.0003	0.0003	0.0003	0.0003	0.0003
Part. PM-10	0.0013	0.0013	0.0012	0.0012	0.0012	0.0011

CT Emissions (ppmvd @ 15%O2)	Case 1	Case 2	Case 3	Case 4	Case 5	Case 6
NOx	9.1	9.1	12.1	9	9	9
CO	12	12	11.4	12.1	12.1	12.2
VOC (non-methane/non-ethane)	2.4	2.4	2.5	2.5	2.5	
Part. PM-10 (Mg/N-M3)	6.8	6.8	6.4	6.5	6.5	5.9

Case Summary

- Case 1 - 95 deg ambient w/o supplemental firing
- Case 2 - 95 deg ambient over pressure
- Case 3 - 95 deg ambient power augmentation
- Case 4 - 65 deg ambient w/o supplemental firing
- Case 5 - 65 deg ambient over pressure
- Case 6 - 0 deg ambient over pressure

Note: All VOC given as non-methane, non-ethane

Case 1 Combustion Products

Burner inlet (lb/hr)	Burner outlet (lb/hr)	Burner outlet (ppmvd @ 15%O2)	Duct burner heat input (MMBtu/lb LHV)
O2	460428	460428	0
CO2	201292	201292	
H2O	221239	221239	
N2	2432507	2432507	
Ar	41396	41396	
NOx	56	56	9.1
CO	45	45	12
VOC	5.2	5.2	2.4
Part. PM-10	18	18	6.8 Mg/N-M3 (actual O2)
Total	3357000	3357000	

Case 2 Combustion Products

Burner inlet (lb/hr)	Burner outlet (lb/hr)	Burner outlet (ppmvd @ 15%O2)	Duct burner heat input (MMBtu/lb LHV)
O2	460428	424722	
CO2	201292	226290	194.4
H2O	221239	241177	
N2	2432507	2432709	
Ar	41396	41398	
NOx	56	73.3	10.6
CO	45	66.6	15.8
VOC	5.2	8.7	3.6
Part. PM-10	18	19.1	7.2 Mg/N-M3 (actual O2)
Total	3357000	3366485	

Case 3 Combustion Products

Burner inlet (lb/hr)	Burner outlet (lb/hr)	Burner outlet (ppmvd @ 15%O2)	Duct burner heat input (MMBtu/lb LHV)
O2	443584	393457	272.85
CO2	212197	247282	
H2O	344746	372730	
N2	2429182	2429431	
Ar	41131	41132	
NOx	79	103	13.6
CO	45	106	22.9
VOC	5.6	15.3	5.8
Part. PM-10	18	19.5	6.9 Mg/N-M3 (actual O2)
Total	3471000	3484315	

Case 4 Combustion Products

Burner inlet (lb/hr)	Burner outlet (lb/hr)	Burner outlet (ppmvd @ 15%O2)	Duct burner heat input (MMBtu/lb LHV)
O2	489002	489002	0
CO2	212868	212868	
H2O	199593	199593	
N2	2578683	2578683	
Ar	43710	43710	
NOx	59	59	9
CO	48	48	12.1
VOC	5.6	5.6	2.5
Part. PM-10	18	18	6.5 Mg/N-M3 (actual O2)
Total	3524000	3524000	

Case 5 Combustion Products

Burner inlet (lb/hr)	Burner outlet (lb/hr)	Burner outlet (ppmvd @ 15%O2)	Duct burner heat input (MMBtu/lb LHV)
O2	489002	455093	184.62
CO2	212868	236608	
H2O	199593	218527	
N2	2578683	2578879	
Ar	43710	43712	
NOx	59	75.4	10.4
CO	48	68.5	15.5
VOC	5.6	8.9	3.5
Part. PM-10	18	19	6.8 Mg/N-M3 (actual O2)
Total	3524000	3533014	

Case 6 Combustion Products

Burner inlet (lb/hr)	Burner outlet (lb/hr)	Burner outlet (ppmvd @ 15%O2)	Duct burner heat input (MMBtu/lb LHV)
O2	548160	517598	166.9
CO2	232105	253566	
H2O	185856	202973	
N2	2866728	2867206	
Ar	48996	49002	
NOx	64	78.8	10.1
CO	53	71.5	15
VOC	6	9.3	3.4
Part. PM-10	18	18.9	6.2 Mg/N-M3 (actual O2)
Total	3882000	3890547	

EMISSION ESTIMATES & OPERATIONAL RECOMMENDATION

New Optional Scenario	Case 5	Case 3
	# Hours	# Hours
Normal Operation of COCT with Over Pressure & Over Sized Duct Burner	Base Load	Power Aug
Plus Power Augmentation Mode with Over Pressure & Over Sized Duct Burner	With DB	Plus DB
Recommended Operating Scenario is 7760 hours/1000hours =	8260	500
	7760	1000
	7260	1500
	6860	1900

NOX tons *	% Reduction Required @	CO tons *	VOC tons *	Part 2.5 tons *
742	20.6%	681	89	183
757	21.0%	701	93	184
772	21.5%	722	96	184
784	21.8%	738	99	184

\* All calculations based at 110% of Case values above.

Staff's First Request for  
Production of Documents  
Docket No. 990325-EI  
GULF POWER COMPANY  
April 19, 1999  
Item No. 18

18. Provide all documents which Gulf Power used to evaluate proposed Smith Unit 3's impact of NOx, SO2, particulate compliance levels for the Smith Plant, Gulf Power, and the Southern Company.

**RESPONSE:**

See the Gulf Power memo to Gregg M. Worley (EPA) 4/5/99 attached.

Certified Mail



April 6, 1999

Mr. Gregg M. Worley  
EPA Region IV Federal Center  
Air and Radiation Technology Branch  
61 Forsyth St. , SW  
Atlanta, GA 30303-8960

Dear Mr. Worley:

RE: Lansing Smith Electric Generating Plant  
Oris Code: 643

Thank you for reviewing Gulf Power's proposed new combined cycle electric generating project at Lansing Smith located near Panama City, Florida. As previously discussed, Gulf Power believes the project as proposed would not be applicable to PSD for nitrogen oxides (NOx) due to offsets obtained from reductions on Lansing Smith Unit 1. The proposed control strategy for Lansing Smith Unit 1 is low NOx burner control technology and GNOICS, a Generic NOx Control Intelligent System.

EPA's initial review of this project revealed no restrictions regarding the use of nitrogen oxide reductions at Lansing Smith Unit 1 for offset consideration, but identified concern on how the project would effect the Southern Company NOx Averaging Plan under the Acid Rain program. More specifically, how Gulf Power would assure EPA that credits incurred for the PSD offset would not be double counted under the NOx Averaging Plan. To address this issue, Gulf Power proposes to evaluate the margin of compliance of the Southern Company NOx Averaging Plan each year and determine if the margin of compliance is within the influence of Lansing Smith Unit 1. Should the plan's margin of compliance be less than .001 lbs/mbtu, a default value equal to the unit's pre-offset emission rate would be substituted for actual emissions for Lansing Smith Unit 1 for that year and the Southern Company NOx Averaging Plan would be re-calculated using the default value. If the plan's margin of compliance is greater than .001 lbs/mbtu, then no change would be made to the actual emissions recorded for Lansing Smith Unit 1 and the compliance evaluation would stand "as is".

April 6, 1999

100 10

Gulf Power believes this review is a fair method to evaluate the influence of Lansing Smith because Unit 1 accounts for less than 1% of the total weighted average of the Southern Company NOx Averaging Plan. One percent of the weighted average is equivalent to less than .001 lbs/mbtu of the compliance margin. Attached is suggested permit language outlining the above evaluation scenario with a copy of the Southern Company NOx Averaging Plan Worksheet.

Please provide confirmation of EPA's previous PSD evaluation of this project and comment on Gulf Power's NOx averaging evaluation plan so the permitting of this project will remain on a timely basis.

If you have any questions or need further information regarding this project, please call or email me at (850) 444-6527 or [gdwaters@southerco.com](mailto:gdwaters@southerco.com), respectively.

Sincerely,

 Q.E.P.

G. Dwain Waters, Q.E.P.  
Air Quality Programs Coordinator

- cc: Tom Turk, Gulf Power Company
- Al Linero, Florida Department of Environmental Protection
- Danny Herrin, Southern Company Services
- Jim Vick, Gulf Power Company
- Tom Davis, Environmental Consulting & Technology, Inc.
- Angela Morrison, Hopping Green Sams & Smith

Staff's First Request for  
Production of Documents  
Docket No. 990325-EI  
GULF POWER COMPANY  
April 19, 1999  
Item No. 19

19. Page 76 of the Need Study states in part, "[c]ondenser cooling for Smith Unit 3 will be accomplished by a closed-cycle cooling tower system, which will minimize cooling water withdrawals and discharges." Provide all documents which Gulf Power used to support this statement.


**RESPONSE:**

See (1) Lansing Smith combined Cycle Project - Closed Loop Cooling System/Service Water Cycle Schematic (2 pages), (2) Blowdown requirements, and (3) Impact on Plant Discharge Temperature - Estimated for the response to this request.

# LANSING SMITH COMBINED CYCLE PROJECT

## Closed Loop Cooling System / Service Water Cycle Schematic

*Preliminary*







**Preliminary**  
**Lansing Smith Combined Cycle**  
**Closed Loop Cycle - Impact on Plant Discharge Temperature - Estimated**

<b>Unit 1 Condenser Flow</b>	<b>90,600 GPM</b>	
<b>Unit 1 Condenser Heat Load - MMBtu/Hr</b>	<b>880 MBtu/Hr</b>	
<b>Unit 1 Condenser Range - Deg.F</b>	<b>19.43 DEG.F</b>	
<b>Unit 2 Condenser Flow</b>	<b>90,600 GPM</b>	
<b>Unit 2 Condenser Heat Load - MMBtu/Hr</b>	<b>880 MBtu/Hr</b>	
<b>Unit 2 Condenser Range - Deg.F</b>	<b>19.43 DEG.F</b>	
<b>Total Units 1 &amp; 2 Condenser Discharge Flow</b>	<b>181,200 GPM</b>	
<b>Condenser Inlet Temperature - Deg.F</b>	<b>90.00 DEG.F</b>	<b>@ 95 Deg.F Ambient</b>
<b>Condenser Outlet Temperature - Deg.F</b>	<b>109.43 DEG.F</b>	
<b>Combined Cycle Tower Makeup Flow - GPM</b>	<b>4,464 GPM</b>	<b>@ 2.0 Cycles</b>
<b>Total Units 1&amp;2 Condenser Discharge Flow after makeup withdrawal</b>	<b>176,736 GPM</b>	
<b>Units 1 &amp; 2 Condenser Discharge Temp.</b>	<b>109.43 DEG.F</b>	
<b>Combined Cycle Tower Blowdown Flow - GPM</b>	<b>2,226 GPM</b>	<b>@ 2.0 Cycles</b>
<b>Combined Cycle Tower Blowdown Temp - Deg.F</b>	<b>86.00 DEG.F</b>	<b>@ 95 Deg.F Ambient</b>
<b>Total Plant Discharge Flow (Condenser + Tower Makeup)</b>	<b>178,962 GPM</b>	
<b>Plant Discharge Flow Temperature - Deg. F (mixed)</b>	<b>109.13 DEG.F</b>	
<b>Differential in Plant Discharge Flow Temperature - Deg. F</b>	<b>0.29 DEG.F</b>	<b>Lower</b>
<b>Differential in Plant Discharge Flow - GPM</b>	<b>2,238 GPM</b>	<b>Lower</b>

twrevap

FCU - 11

Staff's First Request for  
Production of Documents  
Docket No. 990325-EI  
GULF POWER COMPANY  
April 19, 1999  
Item No. 21

21. Please provide all support documentation, data, and analysis which Gulf used to determine the cost of expected unserved energy.

**RESPONSE:**

The response to this request is contained in the following documents:

- a. An Economic Study of the Optimum Reserve Margin and associated Reliability Indices for the Southern Electric System - March 1991, attached;
- b. An Economic Study of the Optimum Reserve Margin and associated Reliability Indices for the Southern Electric System - March 199, attached;
- c. An Economic Study of the Optimum System Planning Reserve Margin for the Southern Electric System - July 1997, attached;
- d. Survey of Customer Outages (RCG Hagler/Bailly), March 1991, filed under a Letter of Intent for Confidential Treatment.

*An Economic Study  
of the  
Optimum System Planning Reserve Margin  
for the  
Southern Electric System*

July 1997



## EXECUTIVE SUMMARY

The objective of this study was to review and redefine, if necessary, the optimum system planning reserve margin for the Southern electric system ("system"). This planning reserve margin is, in general, defined as the appropriate level of generation resource reserves required to provide for an acceptable level of system generation reliability. This study which results in a recommended optimum or appropriate level of generation reserves for planning purposes is based on economics. Basically, the attempt is to balance the cost of building or procuring new generation resources for reserve purposes with the cost of outages associated with firm load curtailments caused by a lack of reserves. This type of study has been conducted on more than one occasion in the past. This report documents a review of system generation reliability based on new assumptions and improved techniques. It should be noted that an economic analysis is only one piece of information used to determine an optimum generation reliability level. No decision of this importance should be made solely with a series of mathematical models. Industry experience, system operations input, perceptions of acceptable risks, and an understanding of the strengths, weaknesses, and biases of the mathematical models must all be considered in determining the amount of capacity which should be added to the system in the late 1990s and the early 2000s.

Due to construction costs, it may be prohibitively expensive in terms of customers' electric bills to build a power system that would never experience a firm load curtailment due to a deficiency in generating unit capacity. Conversely, it may also be prohibitively expensive in terms of the cost of customers experiencing periods of expected unserved energy to build a power system which often experiences firm load curtailments caused by deficiency in generating unit capacity. As previously stated, for this study, the appropriate level of reserves is defined as the level which balances the cost of total electric service with the cost of outages resulting from firm load curtailments due to generation deficiency.

"Reserves" or reserve margin is commonly understood and is a method utility planners use to discuss system generation reliability. The analyses performed in this study deal with the rigorous calculation of the effect and number of firm load curtailments as embodied in expected unserved energy (EUE) and loss of load hours (LOLH) statistics. More specifically, it deals with the extent to which one additional block of capacity can reduce EUE or LOLH and compares the cost of that block of capacity with the cost of outages due to generation deficiencies. This cost of outages can also be referred to as (1) value of service reliability; (2) societal cost of outages;

or, (3) the cost of EUE. From this point on, reference to such a cost will be made using the term "cost of EUE."

Using projections of future load growth including probability distributions of load forecast uncertainty; hydro, weather, and generating unit outage variations; estimates of the cost of EUE; and, a variety of other assumptions, a level of EUE was identified at which the change in the cost of EUE was equal to the change in the cost of increasing generating capacity reserves. This information, when combined with other less-quantifiable considerations, led to the current projection of approximately 15% to 20% reserve margin guideline for the mid-to-late 1990s.

**This new study resulted in a recommendation to transition from the existing minimum 15% system planning reserve margin to a minimum 13.5% planning reserve margin by 1999.** There were two significant changes that produced this result. First, modeling techniques that decreased the EUE and LOLH outputs (compared to previous studies) from the Monte Carlo Frequency and Duration (MCFRED) model were implemented. Secondly, the 1989/1990 cost of EUE estimate was reduced from \$8.72/kWh to \$4.34/kWh, both in 1996 dollars. The changes to the MCFRED model included improvements to the hydro logic to more accurately simulate actual hydro use. The model was enhanced to allow hydro to be placed in storage for up to three days and reserved (by making economy purchases in non-peak or shoulder peak hours) for peak hour use during a hot summer weekday. This change resulted in lower EUE/LOLH estimates from the simulation model. A value of service reliability (cost of EUE) estimate from a 1989/90 survey of system customers - residential, commercial, and industrial - was based on an almost equal energy distribution between these three customer segments during peak periods. After reviewing the automatic load shedding procedures in place across the system for rotating outages during a time when demand exceeds available generation capacity, the distributions used to develop a single cost of EUE estimate representative of all customer segments were found to be heavily weighted toward the residential segment. Given that the aforementioned survey results showed the cost of EUE associated with the residential customer responses was much lower than for either the commercial or industrial segments, the cost of EUE estimate was lowered significantly. We believe this distribution of automatic load shed is better suited for determining such a cost as opposed to looking at the energy usage levels.

This study was not designed to estimate the appropriate reserve margin for the next 20 or more years. It recognizes that the appropriate reserve margin associated with the optimum minimization of LOLH and EUE can and likely will change over time as the mixture of capacity

and load shape characteristics change. This study was designed to estimate the appropriate reserve margin for the late 1990s and early 2000s given this is the period for which capacity commitment or similar decisions must be made. The reliability indices estimated here should be considered valid as we move into the 21st century.

## TABLE OF CONTENTS

I. ASSUMPTIONS .....	1
A. Reliability Simulation Model .....	1
B. Steam Unit Full Forced Outage Data .....	2
C. Steam Unit Partial Forced Outage Data .....	6
D. Combustion Turbine Forced Outage Rate and Capacity Rating .....	8
E. System-Owned Conventional Hydro Generation .....	11
F. SEPA Conventional Hydro .....	14
G. Pumped Storage Hydro.....	14
H. Load Management and Steam Peaking Capacity .....	15
I. Emergency Tie Assistance .....	17
J. Economy Purchases .....	18
K. Commitment .....	21
L. Weather Years.....	22
M. Response of System Load to Weather Conditions .....	23
N. Development of Hydro Patterns .....	23
O. Load Forecast Uncertainty .....	27
P. Study Year.....	28
Q. Capacity Cost .....	28
R. Dispatch Order.....	29
S. Cost of Expected Unserved Energy .....	31
II. SIMULATION PROCEDURE .....	33
A. MCFRED Case Specification.....	33
B. PEST Case Specification .....	37
C. Probabilities of Occurrence for Input Variables.....	37
D. Reliability Model Simulations .....	39
III. RESULTS.....	47
A. Optimum System Planning Reserve Margin .....	47
B. Reserve Margins with Different Lead Times .....	50
IV. SENSITIVITY RESULTS .....	52
A. Load Forecast Uncertainty .....	52

B. Unit Forced Outage Rates..... 53  
C. Combustion Turbine Capacity Cost ..... 53  
D. Cost of Expected Unserved Energy..... 54  
E. Weather Variation..... 55  
V. SUMMARY ..... 57  
APPENDIX  
Appendix A - Combustion Turbine Failure Rates and Reliability..... 58

**List of Exhibits Included in the Report**

<b><u>Exhibit</u></b> .....	<b><u>Page</u></b>
I.B1 Example of Time to Failure and Time to Repair Data.....	3
I.B2 Service Time Between Failure Distribution.....	5
I.C1 1991-1995 GADS Data / Unit Deratings.....	7
I.D1 Wilson/McManus CT Failure Rates .....	9
I.D2 Non-Wilson/McManus CT Failure Rates .....	9
I.D3 New Peaking CT Failure Rates .....	10
I.D4 System CT Ratings (MW).....	11
I.E1 Average Hydro Flow for System-Owned Hydro Generation .....	13
I.E2 Graph – Average Annual Hydro Energy Availability .....	14
I.H1 Load Management Resources – Amounts.....	16
I.H2 Load Management Resources – Availability .....	16
I.J1 Graph – Available Hourly Economy Capacity (Jan-Mar).....	19
I.J2 Graph – Available Hourly Economy Capacity (Apr-Jun).....	20
I.J3 Graph – Available Hourly Economy Capacity (Jul-Sep).....	20
I.J4 Graph – Available Hourly Economy Capacity (Oct-Dec).....	21
I.K1 Dispatchers Peak Load Estimate Error .....	22
I.N1 Graph - July and August Historical Hydro Patterns .....	24
I.N2 Dry Hydro Scenario Input Data .....	25
I.N3 Normal Hydro Scenario Input Data .....	25
I.N4 Wet Hydro Scenario Input Data .....	26
I.O1 Graph - Load Forecast Error Distribution.....	27
I.R1 Order of Dispatch Chart – Normal State vs. Reliability State .....	31
II.A1 MCFRED Case Variables.....	33
II.A2 Annual EUE as a Function of Reserve Levels.....	35
II.A3 Annual LOLH as a Function of Reserve Levels.....	36
II.C1 Input Variables Probabilities.....	38
II.D1 Calculation of EUE Based on Model Results.....	41
II.D2 Calculation of LOLH Based on Model Results.....	42
II.D3 Graph – EUE (in GWH) as a Function of Reserve Margin .....	43
II.D4 Graph – LOLH as a Function of Reserve Margin.....	44
II.D5 Graph – Capacity Cost as a Function of Reserve Margin.....	44
II.D6 Graph – Cost of EUE as a Function of Reserve Margin.....	45
III.A1 Graph – “Bathtub Curve” 3-Year Out Optimum Reserve Margin .....	47
III.A2 Components of the Reserve Margin .....	48
III.A3 Graph - Incremental Cost/Benefits of Optimal Reserve Margin .....	49
III.A4 Graph – Reserve Margin as a Function of Cost of EUE .....	50
III.B1 Graph – “Bathtub Curve” 2-Year Out Optimum Reserve Margin.....	51
III.B2 Graph – “Bathtub Curve” 1-Year Out Optimum Reserve Margin.....	51
IV.A1 Graph – “Bathtub Curve” Optimum Reserve Margin without Load Forecast Error .....	52
IV.C1 Graph – Reserve Margin as a Function of Capacity Cost .....	54
IV.D1 Reserve Margin as a Function of Cost of EUE .....	55
IV.D2 Graph – Reserve Margin as a Function of Cost of EUE .....	55
IV.E1 Graph – “Bathtub Curve” Optimum Reserve Margin with Normal Weather.....	56
A.2 Graph - Wilson/McManus CT Failure Rates and Reliabilities .....	62
A.4 Graph - Non-Wilson/McManus CT Failure Rates and Reliabilities .....	63
A.6 Graph - New Peaking CT Failure Rates and Reliabilities.....	64

## I. ASSUMPTIONS

The following sections of this report (A - S) provide detailed discussions related to the input assumptions associated with a review of Southern electric system ("system") generation reliability. These discussions include:

- an overview of the simulation model used;
- the representation of the performance of generating resources including hydro, steam and peaking units as well as load management and power purchase performance;
- the development of load representation adjusted for weather variations;
- the applicable study year; and,
- appropriate costs to be utilized in the economic analyses of system generation reliability.

### **A. Reliability Simulation Model**

Most commercially available production cost and reliability models use convolution techniques to simulate system operations. These techniques typically combine curves of unit outage rates and loads but neglect the associated chronology of such variables. For many applications, the use of such models is acceptable. However, these models were almost exclusively designed to estimate production costing and fuel budgeting costs, not system reliability. For example, programs based on convolution methods typically assume all units can start and operate in any given hour to serve outages of other units. But there are many hours when units are not operating due to a perceived lack of need and will require hours to start (that is, there are units on "reserve shutdown"). Thus, for many capacity deficiency situations, reserve shutdown units can not be counted on to help serve the load during times of extreme or sudden need. But, again, traditional convolution programs would incorrectly assume this "reserve shutdown" capacity could be used to serve the load and assist in avoiding service interruptions due to a generation deficiency.

Furthermore, convolution-based programs have a limited ability to combine the more technically troublesome features of unit outage profiles and load management programs. It is extremely difficult to adequately model energy-limited resources or devices such as pumped storage hydro (PSH) and conventional hydro with convolution techniques. These types of units have greater potential to increase system generation reliability than would be estimated in deterministic peak

shaving applications and a lesser potential than would be estimated using round-the-clock availability. Finally, convolution techniques can be very difficult to visualize and explain.

The decision was made in 1989 to develop a model that uses a distribution of times to repair (TTR) and times to fail (TTF) for individual generating units. The Monte Carlo Frequency and Duration (MCFRED) model was developed to use the historical and projected data concerning how often and for how long, respectively, existing and future generating units fail for estimating the expected number of firm load curtailments at various reserve levels. MCFRED has been continuously undergoing rigorous testing for several years.

Monte Carlo analysis uses a random number generator to determine generating unit availability. For each iteration, the simulation will randomly generate the state of a unit as operating, partially failed, or completely failed and thereby determines if firm load curtailments and associated expected unserved energy (EUE). Repeating the calculation for a series of "iterations" or "draws" causes the rolling average of EUE to converge to a solution (i.e., an expected or likely value). It also provides probability distribution information on the capacity shortages needed to determine the effect of emergency tie assistance. Monte Carlo analytical techniques are by far the best available for estimating system generation reliability.

## **B. Steam Unit Full Forced Outage Data**

Generating units typically operate for a period of time, fail and are repaired, and then operate again. For example, a unit may run from 500 to 1500 hours before it fails, take from 5 to 500 hours to repair, then run again for 500 to 1500 hours.

Data are available which reflect each system generating unit's historical operating performance. An analysis of the data revealed that the steam units are approximately 25% more reliable in July and August than the rest of the year. The increased reliability stems from the high emphasis placed during the summer months on keeping the units running due to the increased demand. In off-peak months, units might be more quickly placed on forced outage because the need for extraordinary efforts to keep them operating is diminished. These reasons for the higher summertime reliability are only conjecture, but actual higher availability (reliability) has been observed and documented. This study used 1991 through 1995 actual operating history data for each existing generating unit. These years reflect the recent excellent availability of the system generating units. However, it may be that this level of performance will not be maintained in the

future as the generating facilities age. When this study is periodically revised in the future with input data appropriately updated, changing trends in unit reliability will continue to be incorporated automatically.

The July and August data were used for estimating forced outages for June through September because it is believed that the July and August data represented the best estimate of unit availability during peak periods when the capacity is needed to avoid firm load curtailments. The June historical data showed higher forced outage rates, possibly because June is often not as capacity constrained and there is a willingness to bring units down in June to insure they are prepared to run during the typically hotter stretch in July and August. Another factor giving more forced outages in June is that all units are inspected before the summer; therefore, many "small" maintenance items may be identified and repaired in early June. MCFRED simulation of the remaining months (October through May) used the data for all months excluding June - September.

Typical data for a unit might have 8-12 entries in the time-to-fail (TTF) input data record ranging from 25 to 1000 hours and 8-12 entries in the time-to-repair (TTR) ranging from 3 to 150 hours. As MCFRED processes chronologically, it will randomly choose TTF duration from the first data record and then randomly choose TTR duration. Individual unit operation is therefore a direct reflection of what has happened over the previous five years. Since units are independent of each other it is possible that many units can be down at once. An example of this type of input data is given in Exhibit I.B1.

Examples of Time to Failure Data and Time to Repair for Bowen Unit 1							
Type of Data	Unit Name	Hours					
Full Outage Time-to-Failure Data	BOWEN 1	2087	1860	1195	11	419	68
Full Outage Time-to-Failure Data	BOWEN 1	1360	976	3	2474	1357	184
Full Outage Time-to-Repair Data	BOWEN 1	58	19	74	2	26	16
Full Outage Time-to-Repair Data	BOWEN 1	2	2	5	14	9	4

**Exhibit I.B1**

Although most steam units have their own specific history that is used in MCFRED, some similar units at one site were grouped for efficient outage data purposes. A forced outage event that occurs at some generating plant's Unit 1, for example, could happen at Unit 2. A larger sample size of forced outage events from which MCFRED can randomly sample is developed for some

units using this logic. Forced outage rates, ratios of failed hours to operating hours, or ratios of failed hours to total hours, are outputs of MCFRED rather than inputs. Exhibit I.B2 below displays mean-time-between-failures data for peak and off-peak time periods by unit name. This table is provided for summary purposes; it is not used for data development or modeling purposes.

Exhibit I.B2

FACTORS TO MODIFY THE SERVICE TIME BETWEEN FAILURE DISTRIBUTION							
Unit Name	Summer Mean Time Between Failures	Winter Mean Time Between Failures	Off-Peak Mean Time Between Failures	Annual Mean Time Between Failures	Summer Peak Factor	Winter Peak Factor	Off-Peak Factor
ARKWRIGHT	549.21	741.00	650.00	597.13	0.91974	1.24093	1.08854
ATKINSON	232.95	36.00	133.21	185.64	1.25484	0.19392	0.71757
BARRY 1-2	4632.00	9046.00	1648.35	2193.87	2.11134	4.12331	0.75134
BARRY 3	3601.00	5867.00	1759.43	2218.18	1.62341	2.64497	0.79319
BARRY 4	3504.50	1568.25	1755.36	1893.25	1.85105	0.82834	0.92717
BARRY 5	566.67	491.73	421.28	473.23	1.19744	1.03908	0.89022
BOWEN 1-2	855.00	694.21	980.26	935.38	0.91406	0.74217	1.04797
BOWEN 3-4	839.65	810.76	798.67	836.30	1.00401	0.96947	0.95501
BRANCH 1	1034.57	1589.67	2479.40	1840.50	0.56211	0.86371	1.34713
BRANCH 2	1798.75	790.80	928.04	1041.12	1.72770	0.75957	0.89139
BRANCH 3	640.18	497.36	805.69	703.63	0.90983	0.70686	1.14505
BRANCH 4	1190.83	361.93	499.84	532.41	2.23670	0.87981	0.93883
CHICKASAW 3	99.69	381.00	597.00	252.40	0.39498	1.50951	2.36529
CRIST 1-3	447.67	76.75	261.93	342.75	1.30610	0.22392	0.76421
CRIST 4-5	1389.10	544.83	1379.23	1141.95	1.21643	0.47711	1.20779
CRIST 6	1145.67	1052.20	868.29	942.31	1.21580	1.11661	0.92145
CRIST 7	830.25	202.74	515.00	438.09	1.89518	0.46279	1.17557
DANIEL	2250.17	866.13	1366.70	1399.55	1.60778	0.61886	0.97658
EATON	2554.33	3251.00	4840.00	3251.00	0.78581	1.00000	1.42725
FARLEY	2948.20	2031.14	2094.91	2345.50	1.25696	0.86597	0.89316
GADSDEN	1714.71	557.50	2462.67	1787.05	0.95952	0.31197	1.37806
GASTON 1-4	1424.65	970.60	1044.70	1128.07	1.26291	0.86041	0.92609
GASTON 5	357.89	227.77	329.48	312.78	1.14423	0.72822	1.05340
GORGAS 10	766.78	751.75	397.13	475.70	1.61190	1.58031	0.81382
GORGAS 6-7	1601.11	1423.33	2523.29	2058.25	0.77790	0.69153	1.22594
GORGAS 8-9	1811.63	1158.92	1340.26	1391.98	1.30147	0.83257	0.96284
GREENE CO.	950.60	882.67	1224.66	1094.73	0.86834	0.80629	1.11868
HAMMOND 1-3	2047.78	2853.33	978.70	1279.70	1.60020	2.22968	0.76478
HAMMOND 4	295.15	654.57	438.32	406.75	0.72563	1.60951	1.07762
HATCH	4904.33	4766.33	1487.83	2046.03	2.39700	2.32955	0.72718
KRAFT 1-2	1007.22	98.60	781.74	763.34	1.31949	0.12917	1.02410
KRAFT 3	688.00	574.00	681.53	680.19	1.01148	0.84388	1.00197
KRAFT 4	214.75	51.50	208.91	206.79	1.03848	0.24904	1.00057
MCDONOUGH	14752.00	2004.33	1808.89	2277.62	6.47694	0.88001	0.79420
MCINTOSH 1	1280.00	487.50	1088.80	1074.71	1.19102	0.45361	1.01311
MCMANUS 1	444.11	482.92	567.25	482.92	0.91963	1.00000	1.17462
MCMANUS 2	444.11	482.92	567.25	482.92	0.91963	1.00000	1.17462
MILLER	3645.75	3259.71	2061.53	2413.10	1.51082	1.35084	0.85431
MITCHELL 1-2	637.73	187.00	396.57	531.88	1.19902	0.35158	0.74581
MITCHELL 3	1958.67	1270.00	1044.18	1331.43	1.47110	0.95386	0.78426
RIVERSIDE	203.32	203.32	203.32	203.32	1.00000	1.00000	1.00000
SCHERER	1757.73	1434.50	2179.05	1944.86	0.90378	0.73758	1.12042
SCHOLZ	9476.00	4928.00	3716.25	4928.00	1.92289	1.00000	0.75411
SMITH 1	788.56	6349.00	1627.47	1577.79	0.49978	4.02398	1.03148
SMITH 2	557.75	3214.50	1004.35	979.22	0.56959	3.28273	1.02567
SWEATT	8651.00	8651.00	8651.00	8651.00	1.00000	1.00000	1.00000
VOGTL	2893.80	7350.00	3311.60	3584.18	0.80738	2.05068	0.92395
WANSLEY	7383.00	2029.00	1453.33	1872.85	3.94212	1.08338	0.77600
WATSON 1-3	1184.27	1727.20	3058.25	1727.20	0.68568	1.00000	1.77064
WATSON 4	850.13	2136.00	732.44	868.18	0.97920	2.46031	0.84365
WATSON 5	491.64	363.14	458.51	459.32	1.07037	0.79061	0.99824
YATES 1-3	746.23	469.79	548.88	603.89	1.23570	0.77794	0.90890
YATES 4-5	635.42	290.57	607.70	599.65	1.05965	0.48457	1.01342
YATES 6-7	1020.54	398.92	959.49	856.67	1.19129	0.46567	1.12002

### C. Steam-Unit Partial Forced Outage Data

Generating units periodically experience equipment failures which require the units to operate at reduced output. These partial outages are generally much less significant than full forced outages but must still be considered when determining system generation reliability.

In contrast to the results of the full forced outage, units were found to have slightly lower reliability in the summer months in terms of measuring partial outages only. Partial outages occurred more frequently and were repaired more quickly in the summer. One possible explanation for the difference may be that partial deratings are not as often reported in the non-summer months because the units are not called on for economic dispatch as often during that period. On that assumption, the higher level of partial outages is representative of periods when unserved energy will occur. The decision was made to use data based on June through September daytime hours only because this is representative of the time period when partial outages will alter EUE.

For each system generating unit, three data inputs were developed: (1) mean-time-to-failure (MTTF); (2) mean-time-to-repair (MTTR); and, (3) percent duration. MCFRED randomly simulates partial outages based on unit service hours, MTTF, and MTTR. Exhibit I.C1 is an example of the data used. As shown in the exhibit, every 1376 hours of operation for a typical Arkwright unit would be derated by 23.3% for 2.5 hours during the summer peak period. There was little perceived need for a distribution of partial outages due to their anticipated relatively small effect within the analyses.

**Exhibit I.C1**

1991-1995 GADS Data on Unit Deratings for Use in MCFRED							
Unit Name	Summer Mean Time To Repair	Summer Percent Reduction	Winter Mean Time To Repair	Winter Percent Reduction	Off-Peak Mean Time To Repair	Off-Peak Percent Reduction	Mean Service Time Between Deratings
ARKWRIGHT	2.465	23.3266	9.195	22.8385	2.29	39.3357	1376.0
ATKINSON	51.704	11.7702	51.704	11.7702	21.94	31.7460	7240.0
BARRY 1-2	0.663	53.8793	14.340	15.6904	13.24	39.0633	2056.8
BARRY 3	67.643	4.0901	3.190	10.9718	2.92	42.7838	3428.1
BARRY 4	8.267	10.8871	1.514	36.7925	27.80	34.0100	860.6
BARRY 5	9.209	8.9043	4.050	44.4444	31.08	20.0222	1046.8
BOWEN 1-2	27.650	18.0585	32.731	11.1873	36.39	11.1440	561.2
BOWEN 3-4	9.919	15.7525	10.046	25.8818	19.31	26.8185	511.1
BRANCH 1	12.592	13.3016	19.097	35.9574	14.34	18.2731	1673.2
BRANCH 2	35.105	45.2381	17.992	30.0642	9.03	18.8564	424.2
BRANCH 3	4.455	25.1403	21.154	36.1634	17.48	20.4768	677.1
BRANCH 4	8.410	35.3321	15.787	16.9760	22.37	28.2420	608.5
CHICKASAW 3	51.704	11.7702	51.704	11.7702	21.94	31.7460	5048.0
CRIST 1-3	51.704	11.7702	51.704	11.7702	21.94	31.7460	548.4
CRIST 4-5	3.503	22.4080	3.614	20.8057	4.30	15.4747	76.3
CRIST 6	5.450	29.3230	2.390	24.7699	10.74	25.2283	79.3
CRIST 7	6.495	16.5852	4.323	27.5818	6.74	24.8533	44.9
DANIEL	5.522	16.5636	14.739	15.2651	12.06	18.0391	126.9
EATON	51.704	11.7702	51.704	11.7702	21.94	31.7460	13004.0
FARLEY	42.338	31.7285	19.822	24.4173	37.61	36.3374	2421.2
GADSDEN	2.465	23.3266	9.195	22.8385	2.29	39.3357	37528.0
GASTON 1-4	8.598	14.1512	13.137	22.5598	12.21	26.7754	382.8
GASTON 5	3.613	25.8788	16.238	27.4973	8.71	23.7901	212.0
GORGAS 10	3.047	8.2034	9.570	38.4013	27.70	10.4847	1205.1
GORGAS 6-7	5.324	58.2269	27.250	31.1927	21.22	32.1238	4704.6
GORGAS 8-9	65.467	53.5132	14.699	15.9189	25.73	30.4147	1763.2
GREENE CO	41.440	35.8752	90.287	2.9628	47.83	27.6911	2159.1
HAMMOND 1-3	24.872	14.1554	5.689	19.8393	17.64	21.8331	248.8
HAMMOND 4	22.859	12.9978	30.949	15.9401	36.50	26.2462	133.2
HATCH	69.977	14.8145	60.564	18.7698	50.79	25.2767	368.3
KRAFT 1-2	44.600	7.1749	24.467	4.2234	27.24	4.9550	2714.1
KRAFT 3	8.223	26.6752	109.480	27.1282	54.55	41.8748	855.0
KRAFT 4	401.625	11.5365	664.000	9.3373	1155.01	8.0446	496.3
MCDONOUGH	18.839	23.8113	199.120	20.8058	31.74	23.6485	2346.6
MCINTOSH 1	54.625	14.3937	34.500	9.5652	49.19	34.9499	290.0
MCMANUS 1	51.704	11.7702	51.704	11.7702	21.94	31.7460	6278.0
MCMANUS 2	51.704	11.7702	51.704	11.7702	21.94	31.7460	6278.0
MILLER	2.484	46.4842	5.509	20.1581	8.38	28.2478	750.2
MITCHELL 1-2	7.639	39.1527	7.639	39.1527	36.13	22.9726	671.8
MITCHELL 3	17.137	26.6756	187.060	4.8288	15.97	28.6251	380.4
RIVERSIDE	177.480	24.2140	72.440	16.1510	72.44	16.1510	924.2
SCHERER	5.940	21.6742	6.246	21.0813	6.92	11.4183	641.7
SCHOLZ	5.152	14.2329	5.152	14.2329	32.99	21.4770	724.7
SMITH 1	2.719	21.6092	13.723	19.6474	3.72	32.3812	233.7
SMITH 2	6.261	16.9293	2.315	21.8551	9.21	11.3944	312.3
SWEATT	34.870	19.0898	34.870	19.0898	34.87	19.0698	1235.9
VOGTL	35.367	31.4554	85.110	9.0706	52.94	25.2603	3285.5
WANSLEY	3.277	13.9494	48.881	1.9042	8.83	8.8588	780.4
WATSON 1-3	23.426	17.1474	74.373	15.8883	20.73	13.5593	164.0
WATSON 4	59.780	4.0010	18.974	22.8887	16.55	13.7328	85.5
WATSON 5	27.057	8.2075	22.536	16.0718	20.96	13.1101	64.3
YATES 1-3	17.947	38.9463	139.315	21.0520	44.81	33.8774	560.0
YATES 4-5	15.830	45.1306	30.067	44.3170	7.14	42.5250	495.4
YATES 6-7	22.772	17.2725	18.208	20.2863	17.72	15.1910	580.3

#### **D. Combustion Turbine Forced Outage Rate and Capacity Rating**

The reliability of combustion turbines (CTs) is based on three factors:

- 1) the probability that the unit is in an available state;
- 2) the probability that the unit starts if called; and,
- 3) the probability that the unit continues to run once started.

Appendix A of the report includes a description of the assumptions regarding the availability and expected performance of system peaking capacity resources (i.e., CT units). In summary, the existing system CTs prior to 1993 either had basically the same performance characteristics of the Wilson and McManus CTs (located in the Georgia Power Company service territory) or as a group defined as "other" or non-Wilson/McManus CTs. The CT units installed after 1993 are referred to as the "new " CTs and have, in general, better performance and availability characteristics than the pre-1993 units. Exhibits I.D1 - I.D3 provide patterns, respectively, of hour-by-hour probabilities that a CT will: (1) start, and if it starts; (2) the probability that it will run through the first hour; (3) through the second hour; (4) through the third hour; and, (5) so on through 100 hours of operation. Note, if the CT fails, it is assumed to be unavailable until the next day.

**Exhibit I.D1**

<b>Wilson/McManus CT Failure Rates and Reliabilities</b>							
<b>Hour</b>	<b>Probability</b>	<b>Hour</b>	<b>Probability</b>	<b>Hour</b>	<b>Probability</b>	<b>Hour</b>	<b>Probability</b>
1	0.9836	26	0.8972	51	0.8644	76	0.8417
2	0.9733	27	0.8956	52	0.8633	77	0.8409
3	0.9656	28	0.8939	53	0.8623	78	0.8402
4	0.9592	29	0.8923	54	0.8613	79	0.8394
5	0.9538	30	0.8908	55	0.8603	80	0.8386
6	0.9490	31	0.8893	56	0.8593	81	0.8379
7	0.9446	32	0.8878	57	0.8583	82	0.8371
8	0.9407	33	0.8863	58	0.8573	83	0.8364
9	0.9371	34	0.8849	59	0.8564	84	0.8356
10	0.9337	35	0.8835	60	0.8554	85	0.8349
11	0.9305	36	0.8822	61	0.8545	86	0.8342
12	0.9276	37	0.8808	62	0.8536	87	0.8335
13	0.9248	38	0.8795	63	0.8527	88	0.8328
14	0.9221	39	0.8782	64	0.8518	89	0.8320
15	0.9196	40	0.8770	65	0.8509	90	0.8313
16	0.9171	41	0.8757	66	0.8500	91	0.8307
17	0.9148	42	0.8745	67	0.8491	92	0.8300
18	0.9126	43	0.8733	68	0.8483	93	0.8293
19	0.9104	44	0.8721	69	0.8474	94	0.8286
20	0.9084	45	0.8710	70	0.8466	95	0.8279
21	0.9064	46	0.8698	71	0.8458	96	0.8273
22	0.9044	47	0.8687	72	0.8449	97	0.8266
23	0.9025	48	0.8676	73	0.8441	98	0.8259
24	0.9007	49	0.8665	74	0.8433	99	0.8253
25	0.8990	50	0.8654	75	0.8425	100	0.8246

**Exhibit I.D2**

<b>Non-Wilson/McManus CT Failure Rates and Reliabilities</b>							
<b>Hour</b>	<b>Probability</b>	<b>Hour</b>	<b>Probability</b>	<b>Hour</b>	<b>Probability</b>	<b>Hour</b>	<b>Probability</b>
1	0.9728	26	0.8347	51	0.7844	76	0.7504
2	0.9560	27	0.8321	52	0.7828	77	0.7492
3	0.9433	28	0.8296	53	0.7812	78	0.7481
4	0.9330	29	0.8271	54	0.7797	79	0.7469
5	0.9242	30	0.8247	55	0.7782	80	0.7458
6	0.9164	31	0.8224	56	0.7767	81	0.7447
7	0.9095	32	0.8201	57	0.7752	82	0.7436
8	0.9031	33	0.8179	58	0.7738	83	0.7425
9	0.8973	34	0.8157	59	0.7723	84	0.7414
10	0.8920	35	0.8136	60	0.7709	85	0.7403
11	0.8870	36	0.8115	61	0.7695	86	0.7393
12	0.8822	37	0.8094	62	0.7681	87	0.7382
13	0.8778	38	0.8074	63	0.7668	88	0.7371
14	0.8736	39	0.8054	64	0.7654	89	0.7361
15	0.8696	40	0.8035	65	0.7641	90	0.7351
16	0.8658	41	0.8016	66	0.7628	91	0.7340
17	0.8621	42	0.7998	67	0.7615	92	0.7330
18	0.8586	43	0.7979	68	0.7602	93	0.7320
19	0.8553	44	0.7961	69	0.7589	94	0.7310
20	0.8520	45	0.7944	70	0.7577	95	0.7300
21	0.8489	46	0.7926	71	0.7564	96	0.7291
22	0.8459	47	0.7909	72	0.7552	97	0.7281
23	0.8429	48	0.7893	73	0.7540	98	0.7271
24	0.8401	49	0.7876	74	0.7528	99	0.7262
25	0.8374	50	0.7860	75	0.7516	100	0.7252

**Exhibit I.D3**

New Peaking CT Failure Rates and Reliabilities							
Hour	Probability	Hour	Probability	Hour	Probability	Hour	Probability
1	0.9863	26	0.9136	51	0.8856	76	0.8662
2	0.9777	27	0.9121	52	0.8847	77	0.8655
3	0.9712	28	0.9108	53	0.8838	78	0.8649
4	0.9659	29	0.9094	54	0.8829	79	0.8642
5	0.9613	30	0.9081	55	0.8821	80	0.8635
6	0.9573	31	0.9068	56	0.8812	81	0.8629
7	0.9536	32	0.9055	57	0.8804	82	0.8623
8	0.9503	33	0.9043	58	0.8796	83	0.8616
9	0.9472	34	0.9031	59	0.8788	84	0.8610
10	0.9444	35	0.9019	60	0.8780	85	0.8604
11	0.9417	36	0.9008	61	0.8772	86	0.8597
12	0.9392	37	0.8996	62	0.8764	87	0.8591
13	0.9369	38	0.8985	63	0.8756	88	0.8585
14	0.9346	39	0.8974	64	0.8748	89	0.8579
15	0.9325	40	0.8963	65	0.8741	90	0.8573
16	0.9304	41	0.8953	66	0.8733	91	0.8567
17	0.9285	42	0.8942	67	0.8726	92	0.8561
18	0.9266	43	0.8932	68	0.8718	93	0.8555
19	0.9248	44	0.8922	69	0.8711	94	0.8549
20	0.9230	45	0.8912	70	0.8704	95	0.8544
21	0.9213	46	0.8902	71	0.8697	96	0.8538
22	0.9197	47	0.8893	72	0.8690	97	0.8532
23	0.9181	48	0.8883	73	0.8683	98	0.8527
24	0.9165	49	0.8874	74	0.8676	99	0.8521
25	0.9150	50	0.8865	75	0.8669	100	0.8515

As previously stated, it is assumed that the new CTs will be more reliable than the average of the existing units. Increased reliability results from installation of combustion turbines with improved controls and auxiliary equipment and place them at primary CT sites where maintenance will be superior. As an example, the "new" CTs are expected to have a 3 to 4 percent forced outage rate rather than the 10% in older CTs at coal plants. It is expected that the new machines entering utility service will increase the industry reliability statistics, and consequently, the increased reliability will automatically be incorporated in future updates of the reserve margin study accordingly.

Maximum unit capacity ratings for system combustion turbines (CTs) are determined at the point on the heat rate curve where the ambient air inlet temperature is 95 degree F. Exhibit LD4 identifies the approximate ratings of existing system CTs.

**Exhibit I.D4**

<b>System CT Ratings (MW)</b>	
<b>Unit Name</b>	<b>Rating at 95°F</b>
ARKWRIGHT 5A	15.1
ARKWRIGHT 5B	13.6
ATKINSON 5A	34.5
ATKINSON 5B	34.5
BOULEVARD 1	15.5
BOULEVARD 2	16.2
BOULEVARD 3	14.7
BOWEN 6A	32.0
GASTON A (100%)	17.0
GREENE COUNTY	333.8
GREENE COUNTY	417.3
MCDONOUGH 3A	34.5
MCDONOUGH 3B	34.5
MCINTOSH	159.2
MCINTOSH	159.2
MCINTOSH	318.5
MCMANUS 3A	50.8
MCMANUS 3B	50.8
MCMANUS 3C	50.8
MCMANUS4B	50.8
MCMANUS4C	50.8
MCMANUS4D	50.8
MCMANUS4E	50.8
MCMANUS4F	50.8
MITCHELL4A	33.1
MITCHELL4B	33.1
MITCHELL4C	33.1
PRATT WHITNEY	16.1
SMITH A	31.6
SWEATT A	35.0
WANSLEY5A	54.0
WATSON A	35.2
WILSON 5A	49.2
WILSON 5B	49.2
WILSON 5C	49.2
WILSON 5D	49.2
WILSON 5E	49.2
WILSON 5F	49.2

**E. System-Owned Conventional Hydro Generation**

The determination of the reliability impact of conventional hydro generation is one of the major reasons for converting to a chronological, Monte Carlo-based model for system simulation.

The operational flexibility of the conventional hydro is very complex to model. The logic and data in the MCFRED simulations have been designed to balance some conservative assumptions (underestimating hydro's ability to reduce EUE) with some optimistic assumptions (overestimating hydro's ability to reduce EUE) that result in a valid estimation of the impact of the conventional hydro.

A system-owned hydro capacity of 2391 MW (projected for the year 1999) was divided into three components: (1) run-of-river (ROR); (2) scheduled hydro; and, (3) emergency or "unloaded" hydro. The run of river capacity operates in every hour. It varies from a high of 958 MW in March to a low of 30 MW in any summer month (June - September).

Dispatchers refer to scheduled hydro as Block 1 hydro. The sum of ROR hydro and Block 1 hydro was modeled to always equal a maximum available capacity of 1511 MW. The Block 1 hydro is dispatchable to meet system needs.

Emergency or "unloaded" hydro is referred to as Block 2 hydro. This block composes the remaining 880 MW (2391 MW minus 1511 MW) of system hydro capacity. As will be described later, it is reserved for emergencies in the reliability model. During normal system operations when there are fewer concerns about system reliability, reserving the Block 2 hydro generally represents a more efficient use of the water and the overall generating system.

The major constraint in dispatching conventional hydro involves the assumptions concerning how willing dispatchers are to "hold back" the conventional hydro generation. If, for example, the weather forecasts indicate a heat wave will move in later in a summer week and if the capacity situation is tight, the dispatchers will consider restricting operation of the conventional hydro early in the week. MCFRED calculates the conventional hydro energy available in each day, due to natural in-flow. That amount of hydro is available every day if needed for reliability purposes. MCFRED also looks back three days to see if some of the natural in-flow was not used in that period. (Note that the three-day period was designed to represent storage capacity behind the dams and flexibility available in building up or draining ponds as reliability needs dictate.) The daily hydro limit is the sum of today's natural in-flow and any energy not used in the previous three days. Therefore, the maximum conventional hydro energy available on any day under any situation is four days of energy. For a series of capacity constrained days, only the normal in-flow energy will be available near the end of the series each day. This modeling approach resulted in much lower and more accurate EUE projections than the traditional production cost approach of simply adjusting loads for scheduled hydro operation. Simply adjusting the loads is acceptable for production cost programs, but not for reliability analysis.

Block 1 hydro is assumed to be available twice as many hours per week as the Block 2 hydro within the overall weekly energy constraint. In normal weather, for example, Block 1 hydro is


available in August for about 30 hours per week and Block 2 hydro is available for about 15 hours per week. Since dispatchers have more flexibility than this fixed ratio recognizes, this assumption could slightly overestimate EUE.

Exhibit I.E1 is a table that depicts average flow information that can be expected over twelve (12) months for the three major components of system-owned hydro generation. Because the system-owned hydro capacity of 2391 MW and the emergency (or Block 2) hydro of 880 MW are fixed amounts, the ROR and scheduled hydro are adjustable within the 1511 MW parameter. The table illustrates how that adjustment may typically occur in an average year when comparing the run of river and Block 1 capacity columns. When ROR capacity has been determined, the ROR energy is a simple calculation. The total monthly energy is the sum of ROR and dispatchable energy. The dispatch energy is the sum of Block 1 and Block 2 hydro energies.

Average Flow Hydro - System-Owned Hydro Generation (SEPA Excluded)											
Mon	Maximum		Run-of-River		Avail Hours		Block 1 Cap	Block 2 Cap	Block 1 Energy GWH	Block 2 Energy GWH	Total Energy GWH
	Cap	Energy GWH	Cap	Energy GWH	Block 1	Block 2					
1	2391	791	653	470	216	108	858	880	185	95	751
2	2391	771	757	545	210	105	754	880	158	92	796
3	2391	904	957	689	196	98	554	880	109	86	884
4	2391	786	523	377	264	132	988	880	261	116	754
5	2391	598	312	232	188	94	1199	880	225	83	540
6	2391	399	111	80	133	66	1400	880	186	58	324
7	2391	385	74	55	133	66	1437	880	191	58	304
8	2391	343	30	22	122	61	1481	880	181	54	257
9	2391	322	38	27	111	55	1473	880	164	48	239
10	2391	342	70	28	110	55	1441	880	159	48	235
11	2391	451	175	126	144	72	1336	880	192	63	382
12	2391	591	450	335	140	70	1061	880	149	62	545

**Exhibit I.E1**

Exhibit I.E2 graphs the hydro energy availability by month to view the differences for peak versus off-peak hydro conditions.



**Exhibit I.E2**

The development of appropriate hydro probabilistic patterns that encompass over 30 years of hydro energy availability data is included in Section I.N of the report.

**F. SEPA Conventional Hydro**

The Southeastern Power Administration (SEPA) conventional hydro is less flexible in its operation than the system-owned hydro and its operation is simulated differently. The system has a contractual right to 1045 Megawatt-hours per weekday of SEPA hydro from the large projects, with a maximum operation of 522 MW. This energy was modeled as an adjustment to the system load shape by "clipping" the peak, maintaining both the capacity and energy constraints. SEPA conventional hydro also consists of a number of small projects that were spread over 11 hours for a total of 24 MW.

The option to retain SEPA conventional hydro for use later in the week is sometimes available but it is not a dependable option. This option is ignored and to the extent that it might be available, this modeling method is conservative (overestimating EUE).

**G. Pumped Storage Hydro**

The pumped storage units are dispatched in reliability order; that is, units with larger ponds are dispatched first. Pumping should and will occur anytime energy is available. In keeping with the goal of calculating EUE, there are no economic tests associated with PSH operation. Alternately, it could be viewed that it is always economic to build up the reservoirs of storage

units with any generating asset available if that is what is required to have the units available to operate to avoid unserved energy.

#### H. Load Management and Steam Peaking Capacity

Approximately 2800 megawatts of load management and steam peaking capacity are included in the analysis. The load management resources include such rates as Interruptible Service (IS) contracts; Real-Time Pricing (RTP); Direct Load Control (DLC), Stand-by Generation (SBG), and Excess Generation (XG) programs; and, a Supplemental Energy (SE) rate. Exhibits I.H1 and I.H2 depict four such Alabama Power Company contracts, two Georgia Power Company contracts, one Mississippi Power Company, three Savannah Electric and Power Company, and one block of steam peaking capacity with varying limitations on their operation. Exhibit I.H1 differentiates between the amount of generation capacity (in MW) in each of these resources as represented in the 1995 Integrated Resource Plan (IRP) and the actual contract amount of capacity (in MW) associated with each. Since the MCFRED model includes the physical constraints (e.g., hours per year, days per week, and hours per day) for these energy-limited resources, the IRP amounts must be adjusted accordingly. This includes making adjustments to the contract amount then accounting for availability and energy loss factors. The equation used within the exhibit for appropriate adjustment is:

$$IRP\ Amount * (ICE * Availability * Losses) / ICE$$

The "ICE" factor included in the above equation refers to "incremental capacity equivalent" factors. In general, ICE factors are defined for use in representing the worth of load management resources, such as an interruptible service contract, relative to the value of incremental generating capacity that can be added to the system. Although these resources are a valuable supply-side resource, limitations on their availability have to be considered in studies such as a generation reliability analysis.

Exhibit I.H2 represents the aforementioned contract constraints required by MCFRED in terms of the time periods that these resources are available.

The steam peaking capacity represents additional output available from steam units above their normal ratings that could be used for short periods of time. Of note, the steam peaking capacity

(382 MW) is not included in Exhibit I.H1 since no adjustments are required but it is shown in the second exhibit thus the totals differ by the 382 MW associated with the steam peaking resource.

### Exhibit I.H1

IRP and ADJUSTED CAPACITY AMOUNTS FOR LOAD MANAGEMENT RESOURCES - 1999														
1995 IRP AMOUNTS														
	APC						GPC			MPC	SAV			
Year	RTP	200 Hour	600 Hour	Load Cntrl	SBG	XG	240 Hour	RTP	SE	SBG	IL	8760 Hour	SBG	Total
1999	75	539	634	50	94	3	441	410	5	81	8	24	31	2395
ADJUSTMENTS FACTORS														
ICE	0.848	0.833	0.848	1.000	0.848	1.000	0.840	1.000	1.000	0.848	1.000	1.000	1.000	
Avail	1.000	0.930	0.930	1.000	1.000	1.000	0.930	1.000	1.000	1.000	1.000	1.000	1.000	
Loss	1.050	1.050	1.050	1.118	1.118	1.050	1.062	1.000	1.000	1.062	1.000	1.000	1.000	
ADJUSTMENT AMOUNTS (MW)														
	4	-13	-15	6	11	0	-6	0	0	5	0	0	0	-7
MCFRED INPUTS (MW)														
	79	527	619	56	105	3	435	410	5	86	8	24	31	2388

### Exhibit I.H2

Load Management and Steam Peaking Description	Availability				
	Adjusted Capacity MW	Hours per Year	Hours per Week	Hours per Day	Days per Week
Alabama Power Interruptible Service	527	200	40	8	5
Alabama Power Interruptible Service	619	600	40	8	5
Alabama Real Time Pricing (Day Ahead)	79	8760	72	24	3
Alabama Power Stand-by-Generators	105	600	40	8	5
Alabama Power Direct Load Control	56	8760	168	24	7
Alabama Power Excess Generation	3	200	40	8	5
Georgia Power Interruptible Service	435	240	40	8	5
Georgia Power Real Time Pricing (Day Ahead) (1)	335	8760	168	24	7
Georgia Power Real Time Pricing (Hour Ahead) (1)	75	8760	168	24	7
Georgia Power Stand-by-Generators	86	240	40	8	5
Georgia Power Supplemental Energy	5	8760	168	24	7
Mississippi Power Stand-by-Generators	8	240	40	8	5
Savannah Electric Interruptible Service	24	8760	168	24	7
Savannah Electric Stand-by-Generators	31	240	40	8	5
System Steam Peaking (similar to Interruptible Load)	382	263	168	24	7
<b>Total</b>	<b>2770</b>	<b>(2388 MW without steam peaking)</b>			

(1) Georgia's RTP contracts are divided into two categories, day ahead and hour ahead, to simulate how the contracts are used in dispatch. The day ahead and hour ahead categories are subdivided into unconstrained and constrained to further simulate contract availability.

These resources occupy specific positions in the dispatch order. The position in dispatch affects their ability to reduce expected unserved energy and alters the frequency with which they are called.

Various load management rates, sometimes referred to as active demand-side options ("active" DSOs), such as interruptible load, cool storage, and direct load control, have gained interest in the past decade. The interruptible load is being handled explicitly in the study, but DSOs that are not dispatchable ("passive" DSOs) are included in the load forecasts and are more difficult to identify discretely.

In general, passive DSOs "flatten" the system load shape, decreasing the gap between the peak load and shoulder loads on hot summer afternoons. Because more reserves are needed to serve the flatter load shapes, an increased emphasis on DSOs can generally be expected to increase the target reserve margin percentage slightly. Viewed another way, a DSO which decreases the load in the afternoon hours but not the early evening will not be as capable in reducing EUE as a CT which is relatively unconstrained in its operation.

Because passive DSO impacts are expected to be relatively small and ramp up over time, it is unlikely the system reserve margin will vary substantially with more "passive DSOs" and as this study is revisited in future years, additional DSOs will be incorporated in the calculations automatically.

### **I. Emergency Tie Assistance**

The key assumption in the incorporation of tie assistance in the simulation is that neighboring utility systems resemble our system.

In addition to determining the probability distribution of system unserved energy by hour, MCFRED also determines the distribution of tie assistance available from the system to other utilities under two different assumptions. Because neighboring systems are assumed to mirror the system, the probability distribution of tie assistance that the system can provide is expected to be a good estimate of the probability distribution tie assistance the system can receive.

MCFRED can estimate the tie assistance available from up to four neighboring systems. The three systems to the "non-South" resemble our system in that they have pumped and conventional hydro capability. The emergency tie assistance (ETA) available from a neighboring system in any hour is defined as any excess (above system load) committed steam generation plus available CTs (derated for starting failures) plus the available Block 1 hydro and pumped storage (derated

for pond exhaustion). The ETA available from the South is calculated the same as the North, except conventional hydro is not included. (The pond levels are not checked to reflect the lack of energy limited generation in Florida.)

For the purpose of this study, one utility from the North and one from the South were assumed to be able to supply emergency tie assistance.

There will be many hours when the system cannot supply ETA and does not have unserved energy. This occurs anytime interruptible load or Block 2 hydro has been called. In other words, the system will not interrupt customers or run emergency hydro to provide ETA but also may not buy ETA before taking these two steps.

A subroutine of MCFRED, the Probabilistic Evaluation System for Ties (PEST), uses convolution techniques to combine the unserved energy of neighboring systems with the tie assistance from neighboring systems for each hour of the year. It determines the likelihood that the neighboring systems can supply ETA when the system needs it and incorporates both transmission limits and the probability that both our system and a neighbor may need more ETA than the remaining neighbor can provide.


#### **J. Economy Purchases**

If inexpensive energy is available from neighbors, dispatchers will hold back on conventional hydro and pumped storage (which may be needed later) and buy economy energy. By examining historical load shapes, estimates of available economy energy were developed. These estimates were used in MCFRED and then checked for reasonableness with PEST and modified where needed.

Economy purchases were not assumed to be available across the peak hours of any day. The amount of capacity available through economy ties is exemplified in Exhibits LJ1 - LJ4 (each graph containing three months of the year). These assumptions are designed to represent a balance between the need to reflect the existence of economy ties and the need to not rely too heavily on these economy ties to meet demand in critical periods. The true benefit of these non-peak hour purchases is as stated below.

In the final analysis, the economy purchases were more beneficial in reducing EUE than emergency ties due to the synergy between economy ties and the energy-limited hydro. That is, the combination of pumped and conventional hydro available in the summer afternoons and the economy ties available in the morning and late evening is an optimum technique in utilizing available resources to reduce periods and magnitudes of EUE.

**Hourly Economy Capacity Available - MW**



**Exhibit LJ1**

### Hourly Economy Capacity Available - MW




Exhibit LJ2

### Hourly Economy Capacity Available - MW





Exhibit LJ3

## Hourly Economy Capacity Available - MW



**Exhibit I.J4**

### K. Commitment

Steam resources in MCFRED were committed to match the current operating practices. A target level was calculated by the following formula:

Target Level =

$$\begin{aligned}
 & (MW \text{ level of the territorial peak hour of the next 48 hours} + \text{expected off system sales}) * \\
 & (1 + \text{Dispatchers' Peak Load Estimate Error}) \text{ minus (Block 1 Hydro) plus 1200 MW}
 \end{aligned}$$

The system carries operating reserves of approximately 1800 MW. This is approximately one and one-half (1.5) times the largest system-owned generating unit used to serve territorial load. The 1200 MW of steam included in the above equation are less than this operating reserve. However, the total of the 1200 MW of steam and 880 MW of emergency or Block 2 hydro exceeds this system imposed operating reserve requirement. In actual practice this commitment level will vary across the year with variations in the confidence in the daily load forecasts, hydro availability, and specific situations with the large generating units. This 1200 MW is a reasonable approximation for a variety of situations. During the periods when load is high and EUE is most likely, all steam units will generally be committed. The inclusion of off-system

sales in determining the level of commitment increases the service hours of intermediate and higher generating units slightly and therefore increases the frequency of their outages.

The Dispatchers' Peak Load Estimate Error is modeled in MCFRED as a 20-step probability distribution of the error in the dispatchers' projection of the peak expected across the next two days. The error was developed from a comparison of actual loads to the dispatchers' short-term projections and is presented in Exhibit I.K1.

Dispatchers Peak Load Estimate Error																				
% Energy (1)	6.96	3.67	3.30	3.14	3.02	2.38	1.75	1.17	0.80	0.51	0.09	0.06	-0.36	-0.90	-1.10	-1.50	-2.24	-3.29	-4.42	-5.08
Probability(2)	0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.05

Notes:  
 (1) The percent that the forecasted peak differed from the actual peak  
 (2) The probability that the forecasted peak would differ from the actual peak by the specified percentage

**Exhibit I.K1**

It is not likely that the input commitment level would have a significant effect on EUE. Within a range of reasonable commitment levels, all steam units would be committed on days when EUE is likely.

**L. Weather Years**

The unpredictability of weather impacts generation reliability. Historical weather patterns for the last 35 years (1961-1995) and their associated probabilities of occurrence are utilized in the reliability analyses. In general, if weather remains normal over time, concerns for system generation reliability are minimized. However, if the system experiences many days recording abnormal temperatures, system demand would increase significantly. Naturally, extended abnormal temperatures (on the high side in the summer period, and on the low side in the winter period) would increase the risks and potential for system generation related reliability problems.

The historical weather patterns for both summer and winter were analyzed to determine which patterns were more likely to produce EUE and LOLH. For both summer and winter, the weather patterns in 11 of the 35 years would yield essentially zero EUE or LOLH. Abnormal (hotter in the summer or colder in the winter than normal) weather years were modeled to represent the remaining 24 years. A probability of occurrence is assigned to each weather year (for each season analyzed) as well as those weather years when there are no generation reliability concerns.

Refer to Section II.A of the report for a list of the weather years selected for modeling abnormal weather conditions and temperatures for both the summer and winter reliability analyses.

### **M. Response of System Load to Weather Conditions**


A weather normalized load shape or base shape is the starting point for generation reliability modeling. However, to simulate the occurrence of abnormal weather, the base shape is modified to reflect the effect of temperature for weather years chosen to represent abnormal weather patterns (i.e., hot summer months for the summer reliability analysis and cold winter months for the winter reliability analysis). Load files that incorporate the abnormal weather patterns were developed to correspond with the weather years specified in the previous section.

### **N. Development of Hydro Patterns**

Typically, the summer months yield varying weather and hydro conditions in the southeastern United States that influence the peak and energy demands across the system. Being a summer-peaking utility system, the system has significantly higher peaks and energy demand, and subsequently potential for periods of EUE during the hotter summer months due to the higher temperatures. While studying the effects of weather on the generation reliability of the system, a correlative relationship was discovered between temperature and available hydro energy. This study further investigated this interdependence of weather on the availability of hydro energy within the system. By better quantifying this relationship, weather scenarios were expanded to incorporate the effects on hydro. For example, a summer that has extremely hot temperatures and a lack of hydro energy will create the potential for more generation reliability problems than a summer that has extremely hot temperatures and an excess of hydro energy.

As with the weather data, the availability of hydro can vary year-to-year and impacts generation reliability. Three hydro scenarios -- wet, normal and dry -- were developed from over 30 years of actual hydro data. These three scenarios resulted from graphical development of the amounts of historical hydro energy generated versus the actual load demand. The hydro years with similar energy availability were grouped together. Regression analysis was used to produce a curve for high (wet), likely (normal), and low (dry) generation scenarios for any weather and load pattern. A probability of occurrence is assigned to each hydro generation scenario.

Exhibits I.N1 illustrates how regression analysis was used to create three hydro patterns to represent over 30 years of hydro energies. Obviously, the upper curve represents a high or wet hydro pattern while the lower curve represents a low or dry hydro scenario.



**Exhibit I.N1**

Exhibits I.N2-I.N4 reflect how these curves were used to create a corresponding hydro year for a selected weather year. These exhibits depict how a 1980-type weather year can be adjusted from a normal hydro availability pattern to one that reflects both a dry and wet pattern.

**Exhibit I.N2 - System-Owned Hydro Generation  
Hydro Input Data for MCFRED - 1980 Weather Scenario**

**Dry or Low Hydro Scenario**

Month	Maximum		Run-of-River		Block 1	Block 2	Block 1	Block 2
	Cap MW	Energy GWH	Cap MW	Energy GWH	Energy GWH	Energy GWH	Monthly Hrs Avail	Monthly Hrs Avail
1	2391	758	653	485	178	95	207	108
2	2391	751	757	508	150	92	199	105
3	2391	900	958	712	101	86	183	98
4	2391	743	523	376	251	116	254	132
5	2391	534	312	232	219	83	183	94
6	2391	169	60	43	98	28	67	32
7	2391	183	60	45	110	28	76	32
8	2391	198	60	45	125	28	86	32
9	2391	95	60	43	38	14	26	16
10	2391	256	70	45	155	49	107	55
11	2391	377	176	126	187	64	140	72
12	2391	331	450	335	143	62	107	70

**Exhibit I.N3 - System-Owned Generation Hydro  
Hydro Input Data for MCFRED - 1980 Weather Scenario**

**Normal or Likely Hydro Scenario**

Month	Maximum		Run-of-River		Block 1	Block 2	Block 1	Block 2
	Cap MW	Energy GWH	Cap MW	Energy GWH	Energy GWH	Energy GWH	Monthly Hrs Avail	Monthly Hrs Avail
1	2391	758	653	485	178	95	207	108
2	2391	751	757	508	150	92	199	105
3	2391	900	958	712	101	86	183	98
4	2391	743	523	376	251	116	254	132
5	2391	534	312	232	219	83	183	94
6	2391	315	95	68	219	28	155	32
7	2391	215	90	67	120	28	84	32
8	2391	233	90	67	138	28	97	32
9	2391	124	80	58	52	14	37	16
10	2391	256	70	52	155	49	107	55
11	2391	377	176	126	187	64	140	72
12	2391	331	450	335	143	62	107	70

**Exhibit LN4 - System-Owned Generation Hydro  
Hydro Input Data for MCFRED - 1980 Weather Scenario**


**Wet of High Hydro Scenario**

Month	Maximum		Run-of-River		Block 1	Block 2	Block 1	Block 2
	Cap MW	Energy GWH	Cap MW	Energy GWH	Energy GWH	Energy GWH	Monthly Hrs Avail	Monthly Hrs Avail
1	2391	758	653	485	178	95	207	108
2	2391	751	757	508	150	92	199	105
3	2391	900	958	712	101	86	183	98
4	2391	743	523	376	251	116	254	132
5	2391	534	312	232	219	83	183	94
6	2391	413	125	90	295	28	213	32
7	2391	312	120	89	195	28	140	32
8	2391	338	120	89	221	28	159	32
9	2391	275	125	90	157	28	113	32
10	2391	256	70	52	155	49	107	55
11	2391	377	176	126	187	64	140	72
12	2391	331	450	335	143	62	107	70

## O. Load Forecast Uncertainty

Even ignoring all variation from normal weather, there remains considerable uncertainty in the load projections for two or three years into the future. Planning to have a minimum 13.5% reserve margin three years into the future will probably result in a reserve margin either less or more than 13.5%. If load grows more quickly than expected, it will be less than 13.5% and the risk of firm load curtailment is greater. Unexpected strength or weakness in the economy can be a source of load forecast error. Structural changes in the way electricity is used is also a source of load forecast error. Load forecast uncertainty three years into the future (the length of time required to get a new combustion turbine on-line) was estimated using historical data. This estimate was found to be a range of approximated by  $\pm 4\%$ . A graph showing the resulting load forecast uncertainty distribution is included in Exhibit I.O1. For example, this  $\pm 4\%$  uncertainty distribution would equate to a description of the cumulative load growth over three years as a maximum of 11.198%, an expected cumulative load growth of 7.198%, and a minimum of 3.198%. (Note, the expected cumulative load growth is based on the assumption that there exists a one-percent uncertainty in the first year, a 2% uncertainty in the second, and a 4% uncertainty in the third year. The maximum and minimum values are + and - 4 percentage points of the expected value.) Thus the change from the expected compounded load growth is  $\pm 4\%$ . A triangular distribution, as graphed in the exhibit, was used to estimate the probability distribution for load forecast error. Using this triangular distribution, the EUE across a probability distribution of load forecast uncertainty is estimated.

Exhibit I.O1



## P. Study Year

As mentioned in the executive summary, target reliability studies should not have the goal of determining the one optimum reserve margin across the next 20 or 30 years. It is not necessary to select one long-term goal; the system should not be constrained to keep one constant reliability index. Furthermore, the results of long-term, constant reliability constraints can be clouded by projected changes in load shapes, unit costs, hydro availability, thermal unit availability, and other factors. The decision at hand is the determination of capacity needs for the late 1990s and early 2000s.

For the analyses necessary to determine the incremental change in EUE per additional kilowatt (kW) of capacity installed, **1999 was selected as the test year for the study.** Three years out is approximately the amount of time required to make a decision to install new capacity in terms of design, certification, construction, and operating and maintaining a new generating unit. Although the focus of this study is three years out which is consistent with the planning criteria, it examines the target reserve margins for one and two years out as well (see Results, Section III.A).

## Q. Capacity Cost

Simple-cycle combustion turbine (CT) technologies are typically utilized for meeting peaking capacity needs. Therefore, the cost associated with advancing a CT one year is the cost of capacity used in the analysis. This cost is also known as the "economic carrying cost" or one-year deferral method. The CT cost model is a green-field site of three 120 MW units rated at 95 degrees ambient. In 1996 dollars, the cost of advancing a CT used in the study was about \$24.63 per kilowatt-year. It includes the following components:

CT Overnight Cost (1996):	\$227.13 \$/kW
times the deferral rate	9.39 %
Capital cost of advancing a CT:	21.31 \$/kW
plus fixed operations and maintenance, capital modifications, and fuel inventory carrying cost:	3.32
Total Cost	\$24.63 \$/kW-year

## R. Dispatch Order

System dispatchers have flexibility regarding the order in which generating units are called to operate. Steam units are committed as described in Section I.K, generally beginning with the least expensive in terms of operating cost. When steam units are insufficient to or are not the most economical way to meet the electrical demand, the dispatchers can call on a combination of the following options: economy purchases, normally scheduled hydro, pumped storage hydro, combustion turbines, load management, and emergency hydro. The combination and the order of the options called vary with system conditions and projections of the near future -- two or three days.

The following "resources" will be operated or called in this order during most periods of the year, although there are often times when economy and hydro are used before some steam units are dispatched:

- (1) all steam units,
- (2) economy ties if available,
- (3) block 1 hydro,
- (4) pumped storage,
- (5) combustion turbines,
- (6) load management, and
- (7) block 2 hydro.

If, however, system conditions are tighter than normal, the pumped storage units might be run before the conventional hydro. If system conditions are tighter still, the CTs can be called before the conventional and pumped hydro. To reflect these options, MCFRED checks the next two days to estimate how tight the system capacity situation is expected to be. If system peak is expected to be between 85% and 95% of available capacity (including all committed, hydro, and quick start units), the dispatch order is revised to move the pumped storage units (with their less-constrained ponds) down, as shown below:

- (1) all steam units,
- (2) economy ties if available,
- (3) pumped storage,                    } Order
- (4) block 1 hydro,                    } Reversed

- (5) combustion turbines,
- (6) load management, and
- (7) block 2 hydro.


If the system peak is expected to be above 95% of available capacity (including all committed, hydro, and quick start units), the dispatch order is changed to the generation reliability dispatch (or non-economic dispatch) as listed below:

- (1) all steam units,
- (2) economy ties if available,
- (3) combustion turbines,            } moved up from (5)
- (4) pumped storage,
- (5) block 1 hydro,
- (6) load management, and
- (7) block 2 hydro.

Operating the CT units before the energy-limited hydro reduced EUE in earlier test runs by 80%, resulting in a substantial savings in the need for capacity additions.

Because MCFRED switches dispatch orders dynamically over time, this procedure is called the "dynamic dispatching option." Exhibit LR1 shows the "stack" under the two extremes of the dispatch.

## Order of Dispatch



**Exhibit I.R1**

### S. Cost of Expected Unserved Energy

The cost of EUE has been one of the most important and most uncertain of all the assumptions. The payment which one customer is willing to make to avoid an hour of sudden, unexpected firm load curtailment on a hot, summer afternoon is difficult for the customer to estimate. The payment which one customer is willing to take to suffer an hour of sudden, unexpected firm load curtailment on a hot summer afternoon is also difficult to estimate. This information is developed primarily through surveys.

As previously mentioned, this type of study has been conducted in the past. In a report entitled, "An Economic Study of the Optimum Reserve Margin and Associated Reliability Indices for the Southern Electric System, March 1994," the cost of EUE or in the report referred to as the value of service reliability was estimated at \$7.31 per kilowatt-hour. This estimate is \$8.24 inflated to 1994 dollars. As stated in the aforementioned report, this cost or value is based on equal