State of F	Iorida RECEIVED-FPSC Image: Contract Circle Office Center • 2540 Shumard Dar Boulevand 10: 59 Capital Circle Office Center • 2540 Shumard Dar Boulevand 10: 59 Tallahassee, Florida 32399-0850 -M-E-M-O-R-A-N-D-U-M-	
DATE:	September 15, 2011	
то:	Diamond Williams, Commission Deputy Clerk I Office of Commission Clerk	
FROM:	Thomas J. Walden, Utinties System/Engineering Specialist, Division of Economic Regulation	

RE:	Docket No. 090424-WS; Application for certificates to provide water and
	wastewater service in Polk County by Bimini Bay Corporation

Please include the attached correspondence from the Polk Health Department in the docket file.

TW attachments

DOCUMENT NUMBER-CATE 06662 SEP 16 = FPSC-COMMISSION CLERK



Rick Scott Governor

H. Frank Farmer, Jr., M.D., Ph.D. State Surgeon General

April 11, 2011

CS/ BIMINI BAY PWS 6535727

FOUR POINTS UTILITIES 101 GOLDEN MALAY PALM WAY DAVENPORT, FL 33897

Dear Water System Owner:

Following a field inspection conducted on April 6, 2011 we have determined that you water system should be regulated by the Polk County Health Department as a Consecutive Community water system in accordance to the Safe Drinking Water Act and <u>Chapter 62-550 and 62-555</u> of the Florida Administrative Code. You will be required to comply with the following items:

- 1. You must submit a bacteriological sampling plan to this office for approval. This plan must be written in accordance with <u>Chapter 62-550.518</u> of the Florida Administrative code.
- 2. You must begin conducting monthly bacteriological monitoring in accordance with the bacteriological sampling plan approved by the Department and <u>Chapter 62-550.518 FAC</u>.
- 3. You must submit a lead and copper sampling plan for approval in accordance with <u>Chapter62-550.800 FAC</u> and <u>40CFR Part 141 of the Federal Register</u>.
- 4. You must monitor for lead and copper during two consecutive six month periods according to your approved lead and copper sampling plan.
- 5. You must monitor for asbestos in accordance with <u>Chapter 62-550.511 FAC</u> or, if asbestos pipe is not present in the distribution system a waiver from asbestos testing may be obtained by certifying in writing, using form 62-555.900(10) FAC, that the system is without asbestos-containing components and is essentially asbestos free. Form 62-555.900(10) may be located at <u>http://www.dep.state.fl.us/water/drinkingwater/forms.htm</u>.
- 6. You must prepare and submit on a monthly basis Monthly Operation Reports for Consecutive Public Water Systems that do not treat their water, DEP Form 62.555.900(4) which may be located at <u>http://www.dep.state.fl.us/water/drinkingwater/forms.htm</u>.

POLK COUNTY HEALTH DEPARTMENT

Daniel O. Haight, MD, FACP Director Environmental Engineering Division 2090 East Clower Street, Bartow, FL 33830-6741 Phone (863) 519-8330 Fax (863) 534-0245 www.mypoikchd.org Hillory Register, Jr., MPH Interim Assistant Director

and Ministry

11

<u>9</u>

SEP

 \sim

Q

Q

ഗ

- You must prepare and Submit a Consumer Confidence Report each year in accordance with <u>Chapter 62-550.824 FAC</u> and <u>40CFR Part 141</u>, <u>Subpart O</u>, <u>section 151-155 and</u> <u>Appendix A</u>. Your first Consumer Confidence Report will be due in 2009.
- You must maintain a minimum free chlorine residual of 0.2 mg/l or a combined chlorine residual of 0.6 mg/l throughout the water distribution system at all times as required in <u>Chapter 62-555-.350(6)</u>. The chlorine residual must be measured a minimum of twice a week and recorded on a monthly operation report.
- 9. All security related incidents must be reported to the State Warning Point at 1-800-320-0519 with your PWS # 6535727 in accordance with <u>Chapter 62-555.350(2) FAC</u>.
- 10. All dead end water mains must be flushed quarterly or in accordance with a written flushing plan as per <u>Chapter 62-555.350(2)</u>.
- 11. You must begin maintaining system records as required by <u>Chapter 62-555.720</u>. Please use the following table as reference.

Record	Retention period
Bacteriological Analysis pursuant to Chapter 62-550	Not less than 5 years
Chemical Analysis pursuant to Chapter 62-550	Not less than 10 years
Records of action taken by the system to correct a violation of primary drinking water standards	Not less than 3 years after the last action taken with respect to the particular violation involved
Written reports, summaries, or communications relating to cross connection control programs or sanitary surveys of the system conducted by any local, state, or federal agency	Not less than 10 years after completion of the sanitary survey
Records concerning a variance or exemption granted to the system	Not less than 5 years following the expiration of the variance or exemption
Water plant operation reports	Not less than 5 years
Any system subject to the requirements of the Lead and Copper Rule shall retain original records of all sampling data and analysis, reports, surveys, letters, evaluations, schedules, Department determinations, and any other information required by this rule.	Not less than 12 years

- 12. <u>Chapter 62-555.350(14)</u> requires the supplier of water to have an updated map of the drinking water system. The map must show the location and size of water mains if known, location of valves and fire hydrants, pumping facilities and any interconnections with other public water systems.
- 13. <u>Chapter 62-555.360(2)</u> requires all community water systems to establish and **implement** a routine cross-connection control program to detect and control cross-connections and prevent backflow of contaminants into the water system. This program shall include a written plan that is developed using recommended practices of American Water Works Association set forth in *Recommended Practice for Backflow Prevention and Cross-Connection Control, AWWA Manual M14*, as incorporated into Rule <u>62-555.330 FAC</u>.

BIMINI BAY Page 3

14. The water system must also comply with all applicable rules regarding Public Water Systems. These rules may be found at http://www.dep.state.fl.us/water/rulesprog.htm#dw.

Please take the necessary steps to correct these deficiencies within thirty (30) days of the date of this notice, unless otherwise specified and **notify the Department in writing**. If the deficiencies cannot be corrected within the thirty (30) day period, a written schedule stating when the deficiencies will be corrected must be submitted to this office within the thirty (30) day time frame. Failure to comply will result in referral to the enforcement section for further action and the possible imposition of a fine.

If you have any questions, please contact me at (863) 519-8330 ext. 12148.

Sincerely,

Youceb Ban

Daniela Sloan Environmental Specialist II



ļ

Rick Scott Governor

H. Frank Farmer, Jr., M.D., Ph.D. State Surgeon General

July 27, 2011

CS/BIMINI BAY PWS: Id. No. 6535727

FOUR POINTS UTILITIES 101 GOLDEN MALAY PALM WAY DAVENPORT, FL 33897

Dear Water System Owner:

Following the annual inspection of your water system on April 6, 2011 you were mailed a letter on April 11, 2011 listing all the monitoring and sampling requirements that Bimini Bay has to comply with (see attached letter).

We have not received a response letter from your office within the stipulated 30 days and to the best of our knowledge none of the bacteriological and chemical sampling was conducted.

Please contact our office regarding all these issues by August 10th, otherwise you will be referred for enforcement.

If you have any questions, please contact me at (863) 519-8330 ext. 12148.

Sincerely,

muelo Chan

Daniela Sloan Environmental Specialist II

Daniel O. Haight, MD, FACP Director

.

POLK COUNTY HEALTH DEPARTMENT Environmental Engineering Division 2090 East Clower Street, Bartow, FL 33830-6741 Phone (863) 519-8330 Fax (863) 534-0245 www.mypolkchd.org

Hillory Register, Jr., MPH Interim Assistant Director



Rick Scott Governor

H. Frank Farmer, Jr., M.D., Ph.D. State Surgeon General

August 17, 2011

Sent Certified U.S. Mail

Return Receipt No.: 7010 2780 0000 3974 1362

Bimini Bay Utilities Corporation c/o David M. Meadows 101 Golden Malay Palm Way Davenport, FL 33897

RE: Bimini Bay Resort & Spa Water System PWS ID No. 6535727

Warning Notice No. 11-653PW5727A

Dear Public Water System Owner:

This letter is to advise you of the violations of law for which the above mentioned facility's public water system may be responsible and to seek your cooperation in resolving the matter. A review of the facility's drinking water records indicates that violations of Florida Statutes and Rules may exist at the facility. FDOH letters dated April 11, 2011 & July 17, 2011 cited that you may have potential violations for failing to meet the operational and monitoring requirements of a consecutive community water system as required by Chapters 62-550 and 62-655 of the Florida Administrative Code (F.A.C). The following are violation which currently exist with your system:

- System failed to monitor for bacteriological contaminants as required by <u>Chapter 62-550.518(2)</u> of the Florida Administrative Code (F.A.C.).
- System failed to provide a written bacteriological sampling plan in accordance with <u>Chapter</u> 62-550.518 of the Florida Administrative Code (F.A.C.). This plan shall addresses location, timing, frequency, and rotation period for bacteriological sampling.
- System failed to monitor for lead and copper during two consecutive six month periods in accordance with <u>Chapter62-550.800 FAC</u> and <u>40CFR Part 141 of the Federal Register</u>.
- System failed to provide a lead and copper sampling plan for approval in accordance with <u>Chapter62-550.800 FAC</u> and <u>40CFR Part 141 of the Federal Register</u>.

Daniel O. Haight, MD, FACP Director POLK COUNTY HEALTH DEPARTMENT Environmental Engineering Division 2090 East Clower Street, Bartow, FL 33830-6741 Phone (863) 519-8330 FAX (863) 534-0245 www.mvpolkchd.org

Hillory Register, Jr., MPH Interim Assistant Director

Page 2 Bimini Bay Utilities Corporation - David M. Meadows

- System failed to monitor for asbestos in accordance with <u>Chapter 62-550.511 FAC</u> or, if asbestos pipe is not present in the distribution system a waiver from asbestos testing may be obtained by certifying in writing, using form 62-555.900(10) FAC, that the system is without asbestos-containing components and is essentially asbestos free.
- System failed to provide public notice that your system failed to monitor in accordance with Chapter 62-550 and Chapter 62-560 of the Florida Administrative Code.
- The Department has not received required Monthly Operation Reports. <u>Chapter 62-555.350(12)(b)</u> requires public water systems to complete and submit Monthly Operation Reports to the Department within ten (10) days after the end of each month.
- System failed to prepare and provide a consumer confidence report to customers and the Department in accordance with <u>Chapter 62-550.824(3) (e) 1.b of the Florida Administrative Code (F.A.C.)</u>
- The Department has not received Form 62-555.900(19), Certification of Delivery of Consumer Confidence Report, to the Department in accordance with <u>Chapter 62-550.824(3)</u> (e) 1.b of the Florida Administrative Code (F.A.C.)
- The system is not maintaining its records as required by <u>Chapter 62-550.720 of the Florida</u> Administrative Code (F.A.C.).
- The system does not have an adequate cross connection control plan. <u>Chapter 62-555.360(2)</u> requires all community water systems to establish and implement a routine cross connection control program to detect and control cross-connections that create or may create an imminent and substantial danger to public health. This program shall include a written plan that is developed using recommended practices of American Water Works Association set forth in *Recommended Practice for Backflow Prevention and Cross-Connection Control, AWWA Manual M14*, as incorporated into Rule <u>62-555.330, F.A.C.</u>
- System failed to measure/record the residual disinfectant concentration in the distribution system in accordance with <u>Chapter 62-555.350(6)(b) of the Florida Administrative Code (F.A.C.)</u>.
- System failed to provide a written flushing program in accordance with <u>62-555.350(2) of the Florida Administrative Code (F.A.C.)</u>.
- System failed to flush dead-end mains quarterly or in accordance with a written flushing program established by the supplier of water in accordance with <u>62-555.350(2) of the Florida Administrative Code (F.A.C.)</u>

Page 3 Bimini Bay Utilities Corporation - David M. Meadows

- System failed to provide a written valve exercise program in accordance with <u>Chapter 62-555.350(2) of the Florida Administrative Code (F.A.C.)</u>.
- System failed to maintain an operation and maintenance log in accordance with <u>Chapter 62-555.350(12)(a) of the Florida Administrative Code (F.A.C.)</u>.
- System failed to maintain an up-to-date map of the drinking water distribution system in accordance with <u>Chapter 62-555.350(14) of the Florida Administrative Code (F.A.C.)</u>.

You are requested to contact Owen Devine at (863) 519-8330 Ext. 1151 within Ten (10) days of receipt of this Warning Letter to arrange a meeting to discuss this matter. The Department is interested in reviewing any facts you may have that will assist in determining whether any violations have occurred. You may bring anyone with you to the meeting that you feel could help resolve this matter.

Please be advised that this Warning Letter is part of an agency investigation, preliminary to agency action in accordance with Section 120.57(5), Florida Statutes. We look forward to your cooperation in completing the investigation and resolution of this matter.

Sincerely.

Donald R. Ehlenbeck, P.E. Administrator Environmental Engineering

DRE/od

Copy to:

Roland Reis, Legal Counsel Polk County Health Department 1290 Golfview Avenue, 4th floor Bartow, Florida 33830

Email copy to:

[Robert Treanor] btreanor@islandhideaway.net

[C. Franklin] cfranklin@islandhideway.net

[Tom Walden - Florida Public Service Commission] twalden@psc.state.fl.us



Rick Scott Governor

H. Frank Farmer, Jr., M.D., Ph.D. State Surgeon General

August 24, 2011

Sent Certified U.S. Mail

Return Receipt No.: 7010 2780 0000 3974 1393

Bimini Bay Utilities Corporation c/o David M. Meadows 101 Golden Malay Palm Way Davenport, FL 33897

RE: Bimini Bay Resort & Spa Water System PWS ID No. 6535727

Warning Notice No. 11-653PW5727B

Dear Public Water System Owner:

The purpose of this letter is to advise you of the violations of law for which the above mentioned facility's public water system may be responsible, and to seek your cooperation in resolving the matter. A review of the facility's drinking water records indicates that violations of Florida Statutes and Rules may exist at the facility.

- System failed to prepare and provide a consumer confidence report to customers and the Department in accordance with <u>Chapter 62-550.824(3)(a) of the Florida Administrative</u> <u>Code (F.A.C.)</u>.
- System failed to submit Form 62-555.900(19), Certification of Delivery of Consumer Confidence Report, to the Department in accordance with <u>Chapter 62-550.824(3)(e)1.b of</u> the Florida Administrative Code (F.A.C.).

You are requested to contact Owen Devine at (863) 519-8330 Ext. 1151 within Ten (10) days of receipt of this Warning Letter to arrange a meeting to discuss this matter. The Department is interested in reviewing any facts you may have that will assist in determining whether any violations have occurred. You may bring anyone with you to the meeting that you feel could help resolve this matter.

Please be advised that this Warning Letter is part of an agency investigation, preliminary to agency action in accordance with Section 120.57(5), Florida Statutes. We look forward to your cooperation in completing the investigation and resolution of this matter.

Daniel O. Haight, MD, FACP Director POLK COUNTY HEALTH DEPARTMENT Environmental Engineering Division 2090 East Clower Street, Bartow, FL 33830-6741 Phone (863) 519-8330 FAX (863) 534-0245 www.mypolkchd.org

Hillory Register, Jr., MPH Assistant Director Page 2 Bimini Bay Utilities Corporation - David M. Meadows

Sincerely,

Donald R. Ehlenbeck, P.E. Administrator Environmental Engineering

DRE/od

Copy to:


Roland Reis, Legal Counsel Polk County Health Department 1290 Golfview Avenue, 4th floor Bartow, Florida 33830

Email copy to:

[Robert Treanor] btreanor@islandhideaway.net

[C. Franklin] cfranklin@islandhideway.net

[Tom Walden - Florida Public Service Commission] twalden@psc.state.fl.us



ICW - Bimini Bay Meeting

Page 1 of 2

Jom Walden

From:	Owen_Devine@doh.state.fl.us	
Sent:	Friday, September 02, 2011 1:59 PM	
То:	btreanor@islandhideaway.net	
Cc:	david@icrd123.net; Donald_Ehlenbeck@doh.state.fl.us; Ronald_Stadelbacher@doh.state.fl.us; Tom Walden; dmeadows@islandhideaway.net	
Subject:	RE: ICW - Bimini Bay Meeting	

Attachments: WN 082411 no ccr.doc; WN 090111.pdf; Bimini Bay WN 081711.pdf; WN 082411 no ccr.pdf Robert,

As indicated in the last email the only thing I need on the day of the meeting is written approval from the owner that you are representing them in regard to enforcement cases (which now total 4) 11-653PW5704A; 11-653PW5704B; 11-653PW5727A and 11-653PW5727B all of which have been attached.

Owen Devine

Environmental Specialist 11

Polk County Health Department Environmental Engineering Division 2090 East Clower Street Bartow, FL 33830-6741 (863) 519-8330 Ext. 12151 Owen_Devine@doh.state.fl.us

From: Robert treanor [mailto:btreanor@islandhideaway.net]
Sent: Friday, September 02, 2011 11:37 AM
To: Devine, Owen F
Cc: david@icrd123.net; Ehlenbeck, Don; Stadelbacher, Ron; twalden@psc.state.fl.us
Subject: RE: ICW - Bimini Bay Meeting

hi this is Robert Treanor I still work at bimini bay resort but I am part time due to personal reasons

thank you Robert Treanor

From: Owen_Devine@doh.state.fl.us [mailto:Owen_Devine@doh.state.fl.us]
Sent: Friday, September 02, 2011 11:13 AM
To: dmeadows@islandhideaway.net
Cc: btreanor@islandhideaway.net; Donald_Ehlenbeck@doh.state.fl.us;
Ronald_Stadelbacher@doh.state.fl.us; twalden@psc.state.fl.us
Subject: ICW ~ Bimini Bay Meeting

Mr. Meadows,

Mr. Treanor indicated that he was willing to come into the office and discuss both Bimini Bay Resorts and Island Club West/Four Points Utilities. As gathered from my conversation with Mr. Treanor and now confirmed through Mr. Walden of the Florida Public Service Commission it appears Mr. Treanor no longer works for you company. In light of this I am still prepared to hold the Enforcement Meeting on September 9, 2011 at 10:00 am and request your presence. If this is not possible whoever is present to represent you, must have your written authorization allowing them to discuss the issues at hand. It is imperative

9/8/2011

ICW - Bimini Bay Meeting

that you understand that both Bimini Bay Resorts and Island Club West/Four Points Utilities have been identified by FDEP as significant non-compliance systems as well as the Florida Public Service Commission Mr. Walden. If you have any questions please do not hesitate to contact me. All previous correspondence in regard to your systems can be found under the Public Access site <u>http://wrmedms.dep.state.fl.us/Oculus/servlet/login</u>. Log in is netuser/netuser. Please let me know of your intentions.

Thank you

Owen Devine Environmental Specialist II

Polk County Health Department Environmental Engineering Division 2090 East Clower Street Bartow, FL 33830-6741 (863) 519-8330 Ext. 12151 Owen Devine@doh.state.fl.us

Sent: Friday, September 02, 2011 10:47 AM

To: Devine, Owen F

Subject: Declined: ICW - Bimini Bay Meeting

When: Friday, September 09, 2011 10:00 AM-10:30 AM (GMT-05:00) Eastern Time (US & Canada).

Where: EE

It was the PSC's understanding that Mr. Treanor no longer worked for Mr. Meadows at either Bimini Bay or Island Club West/Four Points Utility Corp.

From: Tom Walden [mailto:TWalden@PSC.STATE.FL.US]

JCW - Bimini Bay Meeting

Tom Walden

From: Lowenstine, Mark [MarkLowenstine@polk-county.net]

Sent: Thursday, September 08, 2011 11:34 AM

To: 'Owen_Devine@doh.state.fl.us'

Cc: Donald_Ehlenbeck@doh.state.fl.us; Ronald_Stadelbacher@doh.state.fl.us; Tom Walden; dmeadows@islandhideaway.net; btreanor@islandhideaway.net; Fries, Gary; Rohrich, Jake; Azzarella, Krystal

Subject: RE: ICW - Bimini Bay Enforcement Meeting

Owen,

I will be there at 10:00am at your building tomorrow.

Thank you,

Mark Lowenstine Utilities Water and Wastewater Treatment Manager 1011 Jim Keene Blvd. Winter Haven, FL. 33880 Phone: (863)298-4260 Fax: (863)298-4226

From: Owen_Devine@doh.state.fl.us [mailto:Owen_Devine@doh.state.fl.us]
Sent: Wednesday, September 07, 2011 4:22 PM
To: Lowenstine, Mark
Cc: Donald_Ehlenbeck@doh.state.fl.us; Ronald_Stadelbacher@doh.state.fl.us; twalden@psc.state.fl.us; dmeadows@islandhideaway.net; btreanor@islandhideaway.net
Subject: RE: ICW - Bimini Bay Enforcement Meeting

Keeps getting kicked back - not sure if it went though - please provide info that email went through.

Owen

From: Devine, Owen F Sent: Wednesday, September 07, 2011 3:00 PM To: 'marklowenstine@polk-county.net' Cc: Ehlenbeck, Don; Stadelbacher, Ron; 'twalden@psc.state.fl.us'; 'dmeadows@islandhideaway.net'; 'btreanor@islandhideaway.net' Subject: ICW - Bimini Bay Enforcement Meeting

Mark,

The reason for this email is to inform you of open enforcement cases which are ongoing with Bimini Bay Utilities and Island Club West/Four points. They have agreed to a meeting which has been scheduled for this Friday at 10:00. Just wanted to ensure the County was aware of two open enforcement cases for which the County supplies water to the system for. If a representative from PCU would like to attend Friday please do so otherwise I'll keep you in the loop as well as the public service commission.

Thank you

Owen

JCW - Bimini Bay Meeting

From: Devine, Owen F
Sent: Friday, September 02, 2011 1:59 PM
To: 'Robert treanor'
Cc: <u>david@icrd123.net</u>; Ehlenbeck, Don; Stadelbacher, Ron; <u>twalden@psc.state.fl.us</u>; 'dmeadows@islandhideaway.net'
Subject: RE: ICW - Bimini Bay Meeting

Robert,

As indicated in the last email the only thing I need on the day of the meeting is written approval from the owner that you are representing them in regard to enforcement cases (which now total 4) 11-653PW5704A; 11-653PW5704B; 11-653PW5727A and 11-653PW5727B all of which have been attached.

Owen Devine Environmental Specialist II

Polk County Health Department Environmental Engineering Division 2090 East Clower Street Bartow, FL 33830-6741 (863) 519-8330 Ext. 12151 <u>Owen_Devine@doh.state.fl.us</u>

From: Robert treanor [mailto:btreanor@islandhideaway.net]
Sent: Friday, September 02, 2011 11:37 AM
To: Devine, Owen F
Cc: david@icrd123.net; Ehlenbeck, Don; Stadelbacher, Ron; twalden@psc.state.fl.us
Subject: RE: ICW - Bimini Bay Meeting

hi this is Robert Treanor I still work at bimini bay resort but I am part time due to personal reasons

thank you Robert Treanor

From: <u>Owen Devine@doh.state.fl.us</u> [mailto:Owen Devine@doh.state.fl.us] Sent: Friday, September 02, 2011 11:13 AM To: <u>dmeadows@islandhideaway.net</u> Cc: <u>btreanor@islandhideaway.net</u>; <u>Donald Ehlenbeck@doh.state.fl.us</u>; <u>Ronald Stadelbacher@doh.state.fl.us</u>; twalden@psc.state.fl.us Subject: ICW - Bimini Bay Meeting

Mr. Meadows,

Mr. Treanor indicated that he was willing to come into the office and discuss both Bimini Bay Resorts and Island Club West/Four Points Utilities. As gathered from my conversation with Mr. Treanor and now confirmed through Mr. Walden of the Florida Public Service Commission it appears Mr. Treanor no longer works for you company. In light of this I am still prepared to hold the Enforcement Meeting on September 9, 2011 at 10:00 am and request your presence. If this is not possible whoever is present to represent you, must have your written authorization allowing them to discuss the issues at hand. It is imperative that you understand that both Bimini Bay Resorts and Island Club West/Four Points Utilities have been identified by FDEP as significant non-compliance systems as well as the Florida Public Service Commission Mr. Walden. If you have any questions please do not hesitate to contact me. All previous correspondence in regard to your systems can be found under the Public Access site <u>http://wrmedms.dep.state.fl.us/Oculus/servlet/login</u>. Log in is netuser/netuser. Please let me know of your intentions.

9/8/2011

JCW - Bimini Bay Meeting

Thank you

Owen Devine Environmental Specialist II

Polk County Health Department Environmental Engineering Division 2090 East Clower Street Bartow, FL 33830-6741 (863) 519-8330 Ext. 12151 <u>Owen Devine@doh.state.fl.us</u>

From: Tom Walden [mailto:TWalden@PSC.STATE.FL.US]

Sent: Friday, September 02, 2011 10:47 AM

To: Devine, Owen F

Subject: Declined: ICW - Bimini Bay Meeting

When: Friday, September 09, 2011 10:00 AM-10:30 AM (GMT-05:00) Eastern Time (US & Canada).

Where: EE

It was the PSC's understanding that Mr. Treanor no longer worked for Mr. Meadows at either Bimini Bay or Island Club West/Four Points Utility Corp.

Please Note: Florida has a very broad Public Records Law. Most written communications to or from State and Local Officials regarding State or Local business are public records available to the public and media upon request. Your email communications may therefore be subject to public disclosure.

Tom Walden

Subject:	Updated: ICW - Bimini Bay Meeting
Location:	EE
Start:	Tue 9/13/2011 9:00 AM
End:	Tue 9/13/2011 9:30 AM
Show Time As:	Tentative
Recurrence:	(none)
Meeting Status:	Not yet responded

Ms. Vido from Bimini Bay/ICW called to reschedule the meeting. New meeting time has been sheduled for Tuesday September 13 9:00AM

Owen

Mr. Bob Treanor has been in contact with me and has agreed to a meeting next Friday 9/9/11 at 10:00. Topics to include outstanding violations for both water systems.

Thank you

Owen Devine Environmental Specialist II

Polk County Health Department Environmental Engineering Division 2090 East Clower Street Bartow, FL 33830-6741 (863) 519-8330 Ext. 12151 Owen_Devine@doh.state.fl.us