

**BEFORE THE FLORIDA  
PUBLIC SERVICE COMMISSION**

**DOCKET NO. 110389 -EI  
FLORIDA POWER & LIGHT COMPANY**

**IN RE: FLORIDA POWER & LIGHT COMPANY'S  
PETITION TO DETERMINE NEED FOR  
MODERNIZATION OF PORT EVERGLADES PLANT**

**DIRECT TESTIMONY & EXHIBIT OF:**

**PEDRO MODIA, P.E.**

COM 5  
APA  
ECR 7  
GCL 2  
MAD  
SRC  
ADM  
OPC  
CLK & Ref

DOCUMENT NUMBER-DATE

08532 NOV 21 =

FPSC-COMMISSION CLERK

1                   **BEFORE THE FLORIDA PUBLIC SERVICE COMMISSION**

2                   **FLORIDA POWER & LIGHT COMPANY**

3                   **DIRECT TESTIMONY OF PEDRO MODIA, P.E.**

4                   **DOCKET NO. \_\_\_\_\_-EI**

5                   **NOVEMBER 21, 2011**

6

7   **Q.     Please state your name and business address.**

8   A.     My name is Pedro Modia, P.E. My business address is 4200 W. Flagler Street,  
9           Miami, Florida 33134.

10 **Q.     By whom are you employed and what position do you hold?**

11 A.     I am employed by Florida Power & Light Company (“FPL” or the “Company”) as  
12           Director of Transmission Services and Planning.

13 **Q.     Please describe your duties and responsibilities in that position.**

14 A.     I am responsible for the transmission planning aspects of new generator and  
15           utility interconnections, transmission and substation expansion planning, and  
16           transmission service-related activities, including contract negotiations, legal and  
17           regulatory proceedings, and contract interpretations.

18 **Q.     Please describe your educational background and professional experience.**

19 A.     I received a Bachelor’s degree in Electrical Engineering Technology from Florida  
20           International University. I am a Registered Professional Engineer in the State of  
21           Florida. Prior to assuming my present role in 2009, I served as FPL’s Director of  
22           Power Supply. I began my career with FPL in 1977 and have 33 years of service  
23           with the Company including the following positions: Director of Substations,

1 General Manager Generation, Director of Transmission, and Director of  
2 Protection and Control.

3 **Q. Are you sponsoring an exhibit in this case?**

4 **A.** Yes. I am sponsoring Exhibit PM-1, Summary of Required Facilities for the Port  
5 Everglades Next Generation Clean Energy Center (PEEC), which is attached to  
6 my direct testimony.

7 **Q. What is the purpose of your testimony?**

8 **A.** My testimony presents three aspects related to FPL's transmission system and the  
9 PEEC Project. First, I present a general overview of the FPL transmission  
10 system, the Southeast Florida area, and in particular the Miami-Dade and  
11 Broward County area. Second, I describe the overall transmission evaluation  
12 process and the results of transmission system-related cost studies for the PEEC  
13 Project and its alternatives. Finally, I discuss the reliability benefits of the PEEC  
14 Project.

15 **Q. Please summarize your testimony.**

16 **A.** FPL has analyzed its transmission capability to reliably serve its customers in the  
17 future. These analyses have identified concerns with maintaining a regional  
18 balance between customer demand and generating capacity in the general  
19 Southeast Florida area. Most recently, these concerns are focused on the Miami-  
20 Dade and Broward County area and FPL continues to monitor these concerns.

21

22 The balance between customer demand and generating capacity in an area is  
23 maintained by the capability of the transmission system to make up the

1 differences, however the transmission system capability is finite. While FPL  
2 could construct new transmission facilities to import more generation into the  
3 area, such construction would be very costly and not without significant risk,  
4 including uncertainty regarding approvals for siting, licensing, and permitting for  
5 the construction of major transmission facilities necessary to maintain adequate  
6 reliability for FPL's customers. FPL estimates that these transmission facilities  
7 would cost approximately \$638 million (2016\$) and would be required by 2020,  
8 in order to maintain reliability. Alternatively, FPL could locate new generation in  
9 the area such as the PEEC Project that FPL is proposing.

10  
11 The FPL Transmission Planning group also has performed an evaluation of the  
12 FPL transmission system under my direction and control that provided inputs to  
13 FPL's Resource Assessment and Planning (RAP) department to support the  
14 economic evaluation of the competing alternatives for meeting FPL's generation  
15 need in 2016, including the PEEC Project, and also identified the transmission  
16 related requirements for the interconnection and integration of the PEEC Project.  
17 The total transmission cost of both interconnection and integration facilities for  
18 the PEEC Project is estimated to be approximately \$32.5 million (2016\$).

19  
20 FPL's proposal to modernize the existing Port Everglades plant adequately  
21 provides for FPL system reliability by siting efficient, base load generation in  
22 Broward County, a location within FPL's service area with a high concentration

1 of customer load, and postpones the need for significant transmission investment  
2 to increase import capability.

3

4 **FPL'S TRANSMISSION SYSTEM AND THE SOUTHEAST FLORIDA AREA**

5

6 **Q. Please describe FPL's transmission system.**

7 A. FPL is part of the nation's Eastern Interconnection transmission network. It has  
8 multiple points of interconnection with other utilities that enable power to be  
9 exchanged among utilities. The FPL transmission system is comprised of  
10 approximately 6,721 circuit miles of transmission lines. Integration of the  
11 generation, transmission and distribution system is achieved through FPL's 586  
12 substations.

13

14 The FPL transmission system is designed to integrate all of FPL's generation  
15 resources to serve FPL's retail customers and to meet FPL's firm long-term  
16 transmission service obligations in a reliable and cost effective manner. It is  
17 planned and designed consistent with reliability standards and criteria established  
18 by the North American Electric Reliability Corporation (NERC) and the Florida  
19 Reliability Coordinating Council (FRCC).

20

21

22

1 **Q. In previous need determination regulatory proceedings, FPL has addressed**  
2 **the need for siting generation in or increasing the transmission capability to**  
3 **the Southeast Florida area. What does FPL consider to be the Southeast**  
4 **Florida area?**

5 A. The Southeast Florida area of FPL's transmission system has been described as  
6 the region south and east of, and including FPL's Corbett Substation;  
7 geographically, this includes a portion of southern Palm Beach County and all of  
8 Broward and Miami-Dade Counties.

9 **Q. Please describe FPL's transmission concerns for the Southeast Florida area.**

10 A. The concern originated from transmission assessments performed by FPL as far  
11 back as 2002, which identified the growing load-to-generation imbalance in  
12 Southeast Florida, as well as the finite capability of the transmission system to  
13 import power into Southeast Florida in the future. As the load in the area  
14 continues to grow, FPL must either build new generation within the Southeast  
15 Florida area or make transmission system improvements to increase the  
16 transmission import capability, or both, at some time in the near future. This was  
17 the load-to-generation imbalance concern that FPL had previously identified in  
18 prior need determination proceedings before the Commission.

19 **Q. How did the additions of Turkey Point Unit 5 and West County Units 1, 2,**  
20 **and 3 impact FPL's transmission system and the load-to-generation**  
21 **imbalance in the Southeast Florida area?**

22 A. The additions of Turkey Point Unit 5 in 2007 and West County Units 1, 2, and 3  
23 in 2009, 2010, and 2011 mitigated but did not entirely eliminate the load-to-

1 generation imbalance concern in the Southeast Florida area. Two other projects  
2 that are currently in progress -- the uprates to the Turkey Point nuclear units in  
3 2012 and 2013 and the addition of the Riviera Beach Energy Center in 2014 --  
4 will also help to mitigate the Southeast Florida area imbalance.

5 **Q. Is there currently an imbalance between load and generation in the**  
6 **Southeast Florida area?**

7 A. Yes. Although the generating capacity additions discussed above have helped to  
8 mitigate the imbalance issue, the benefits are partly offset by the fact that old,  
9 inefficient generating capacity existing within the area will be retired or have been  
10 placed on Inactive Reserve status and eventually retired, as witness Enjamio  
11 explains in his direct testimony. Cutler Units 5 and 6 are planned to be retired by  
12 the end of 2012, and Port Everglades Units 1-4 and Turkey Point Unit 2 have  
13 been placed on Inactive Reserve. If all the units that are retired or placed in  
14 Inactive Reserve are not returned to service or replaced with generation in this  
15 area, the generating capacity within the Southeast Florida area will be reduced by  
16 approximately 1800 MW. In addition, Turkey Point Unit 1 is planned to be  
17 placed on Inactive Reserve in 2016, as witness Enjamio explains in his direct  
18 testimony. This will be a total reduction of approximately 2200 MW. Since the  
19 potential reduction in Southeast Florida capacity is primarily in the central and  
20 southernmost portion of the area (Miami-Dade and Broward Counties), and the  
21 recent generation additions at West County are primarily in the north portion of  
22 the area (Palm Beach County), these changes have resulted in a shift in the  
23 imbalance to a smaller geographic area of concern within the Southeast Florida

1 area. The area of concern regarding an imbalance between load and generation is  
2 now confined to Miami-Dade and Broward Counties.

3 **Q. Please explain the specific concerns for the Miami-Dade and Broward**  
4 **County area.**

5 A. Miami-Dade and Broward Counties are the most populated counties in FPL's  
6 territory with the highest concentration of customer load. The two counties  
7 together represent approximately 44% of FPL's total load, based on recent  
8 history. Based on this trend, by 2016, FPL projects it will have about 10,000 MW  
9 of peak load in the Miami-Dade and Broward County area, and the peak load in  
10 this area is estimated to grow by about 150-200 MW per year. With the planned  
11 retirements of old, inefficient units such as Cutler Units 5 and 6, and with Port  
12 Everglades Units 1-4 and Turkey Point Units 1 and 2 placed on Inactive Reserve,  
13 FPL will have only 4,896 MW of active installed capacity in Miami-Dade and  
14 Broward Counties (this includes approximately 1,260 MW of 1970's vintage  
15 aero-derivative gas turbine generation which is primarily utilized for emergency  
16 reserves). As the load in Miami-Dade and Broward Counties continues to grow,  
17 FPL will need to rely upon its transmission system to import greater amounts of  
18 power into the area to serve the load. However, the existing transmission  
19 capability to import power into Miami-Dade and Broward Counties is limited to  
20 about 6,400 MW. Later in my testimony I discuss how the transmission import  
21 capability was determined in the transmission assessment.

22



1 Another concern related to the power import capability of the area is the need for  
2 voltage support. In areas of high concentrations of load, the voltage must be  
3 supported by either generation close to the loads or additional facilities installed  
4 on the system to maintain adequate voltage while importing the power.  
5 Generators inherently provide voltage support to the transmission systems to  
6 which they are connected. For this reason, the Turkey Point Unit 2 generator was  
7 modified to operate as a “synchronous condenser” when it was placed on Inactive  
8 Reserve status. A synchronous condenser is a term used to define a generator that  
9 is connected to the system to provide voltage support without using fuel or  
10 generating power. The Turkey Point nuclear switchyard has voltage requirements  
11 that necessitated the use of Turkey Point Unit 2 as a synchronous condenser to  
12 maintain adequate voltage in this area. When Turkey Point Unit 1 is removed  
13 from generation service for economic reasons, it will be modified to also operate  
14 as a synchronous condenser for voltage support at the Turkey Point switchyard.

15  
16 If the inefficient generation at Port Everglades that has been placed in Inactive  
17 Reserve is not returned to service or replaced with generation sited within the  
18 Miami-Dade and Broward County area, the imbalance between customer demand  
19 versus generation capacity in the area will require an investment of approximately  
20 \$638 million (2016\$) in transmission infrastructure build out by 2020, in order to  
21 maintain reliability. FPL would have to construct transmission facilities to move  
22 power from remote locations into the area. Aside from the significant cost  
23 associated with these transmission infrastructure additions, it is not clear that the

1 needed enhancements could be completed by 2020 because the siting, licensing,  
2 permitting, and construction of major transmission facilities can take a significant  
3 amount of time; in fact, in some instances major transmission facilities could take  
4 as long as 5 to 7 years to put in service. For this reason, the decision to proceed  
5 with such an infrastructure build out would have to be made as early as 2013.

6  
7 If there is a delay beyond 2016 in either returning the inefficient generation at  
8 Port Everglades to service, or constructing the PEEC Project, there is an increased  
9 transmission reliability risk. This is due to the increased reliance upon the 1970's  
10 vintage aero-derivative gas turbine generation (which is primarily utilized for  
11 emergency reserves and not designed to run on a long term continuous basis) to  
12 mitigate transmission constraints in the Miami-Dade and Broward County area.  
13 To illustrate this potentially serious transmission reliability concern, we assume  
14 the possibility that one of the large generating units in the Miami-Dade and  
15 Broward County area (i.e. Turkey Point Unit 3, 4 or 5) is unavailable due to a  
16 forced outage. In this circumstance, the aero-derivative gas turbine generation  
17 would be utilized to replace the outaged generation in the area and maintain the  
18 balance between generation and load in the Miami-Dade and Broward area, and  
19 also meet the Turkey Point voltage requirements. After 2016, the amount of gas  
20 turbine generation required to maintain the balance approaches the available  
21 capacity of gas turbines in the area, leaving little margin available for mitigation  
22 of potential transmission contingencies. If the available transmission and  
23 generation capacity to serve the Miami-Dade and Broward county area is

1 exhausted, the only remaining remedy to maintain transmission system reliability  
2 is to curtail electric service to FPL's customers in this scenario. By 2020 the  
3 margin is negative and significant transmission upgrade is required as discussed  
4 above. However, delaying the addition of generation into the area beyond 2016  
5 carries a significant risk and is a serious concern, and therefore is not  
6 recommended from a system reliability perspective.

7  
8 To summarize, the existing transmission system import capability into the Miami-  
9 Dade and Broward County area is 6,400 MW. Unless adequate generation is  
10 added in this area to replace the generation that will be retired, and that which will  
11 be in Inactive Reserve, by either bringing the Port Everglades units back into  
12 generation service, or preferably by modernizing the Port Everglades Plant,  
13 significant transmission upgrades will be required by no later than 2020 to  
14 increase the area's transmission import capability. If there is a delay beyond 2016  
15 in adding generation to the area there is a serious concern, and therefore is not  
16 recommended from a system reliability perspective.

17 **Q. Would the proposed Turkey Point 6 & 7 nuclear units mitigate the**  
18 **generation to load imbalance in Miami-Dade and Broward Counties?**

19 A. Yes, the new baseload capacity associated with these two new units will improve  
20 the generation to load imbalance in the region. However, because the projected in-  
21 service dates of those units are 2022 and 2023, respectively, these new units will  
22 be unable to mitigate the imbalance that will occur by 2020. Consequently, either

1 new transmission facilities, or new generation capacity in the area (such as  
2 PEEC), will be needed before Turkey Point 6 & 7 will be added.

3 **Q. Will the PEEC Project improve the Miami-Dade and Broward County**  
4 **imbalance between generation and load?**

5 A. Yes. For the reasons discussed above, the PEEC Project reduces the imbalance  
6 between generation and load in the Miami-Dade and Broward County area and  
7 also provides voltage support, when compared to the case of not utilizing Port  
8 Everglades as a generating site.

9

#### 10 **TRANSMISSION ASSESSMENT AND SYSTEM REQUIREMENTS FOR PEEC**

11

12 **Q. Please describe FPL's evaluation process for transmission interconnection**  
13 **and integration of new generation resources.**

14 A. The evaluation process considers many factors, as outlined below, in order to  
15 develop an effective transmission interconnection and integration plan. In some  
16 instances, the determination of the plan is relatively straightforward; however, at  
17 other times it requires an iterative assessment of various factors and a substantial  
18 amount of time to perform appropriate studies. The resultant plan must be in  
19 compliance with NERC and FRCC Reliability Standards.

20

21 Generally, the first step in the process is to evaluate the proposed generating plant  
22 site location to determine its proximity to existing transmission facilities. To the  
23 extent there are existing transmission facilities nearby, those facilities are assessed

1 to determine their capabilities for reliably interconnecting and integrating the  
2 proposed new generation into the transmission system as a firm FPL generation  
3 resource. Next, other factors such as those listed below are considered (as  
4 applicable):

- 5 • Compliance with NERC and FRCC Reliability Standards;
- 6 • Amount of generation (MW) being added at the new generation site, and  
7 the dispatch profile of the new generation resource relative to FPL's  
8 other generation resources in serving FPL's load;
- 9 • Capabilities to upgrade existing facilities (can the conductor on an  
10 existing transmission line be upgraded on the existing structures or  
11 would the entire transmission line have to be rebuilt?);
- 12 • Need for new transmission lines, right-of-way requirements, existing  
13 right-of-way capabilities, siting of new right-of-way, permitting  
14 requirements, and expected time-frame to acquire right-of-way and  
15 necessary permits;
- 16 • Ability to transport power efficiently (would using higher voltages be  
17 more efficient by reducing the amounts of transmission losses incurred  
18 when moving large amounts of power over long distances?);
- 19 • Existing and new substation requirements, capabilities, and availability;
- 20 • Impact on existing facilities (does the proposed interconnection and  
21 integration plan result in an overload on an existing facility or does it  
22 result in a material adverse impact somewhere else on the transmission  
23 system?);

- 1 • Constructability (can the necessary transmission facilities be constructed  
2 without having to take existing operating facilities out of service during  
3 periods that would result in an adverse reliability impact?);
- 4 • Overall compatibility with the system (do the new facilities require new  
5 material stocking requirements or the need for new tools to maintain?);
- 6 • Operating considerations (what are the maintenance requirements of the  
7 proposed interconnection and integration facilities and how will they  
8 impact the on-going operation of the system?);
- 9 • The timing and amount of power needed for testing of equipment such  
10 as pumps and motors;
- 11 • Expected in-service testing and commercial operations dates for new  
12 generation (which transmission facilities necessary for interconnection  
13 and integration need to be in-service prior to the commercial operation  
14 in-service date for testing?);
- 15 • The need for procuring transmission service from a third party;
- 16 • Material adverse impacts on third party transmission owner; and,
- 17 • Initial and recurring costs of facilities and operations.

18  
19 The next step in the interconnection and integration evaluation process is to  
20 perform power flow studies for a proposed transmission interconnection and  
21 integration plan. These power flow studies are used to evaluate the performance  
22 of the system and to converge on specific new system facilities and upgrades that

1 would be needed to reliably interconnect and integrate the new generation into the  
2 transmission system.

3 **Q. Was this the process FPL used to evaluate transmission interconnection and**  
4 **integration requirements for the PEEC Project?**

5 A. Yes.

6 **Q. What was the result of FPL's evaluation?**

7 A. The evaluation determined that most of the existing facilities in and around the  
8 Port Everglades switchyard are adequate to reliably integrate the PEEC Project  
9 and some facilities will require upgrading. This is primarily due to the higher  
10 winter capability of the PEEC generator's combined cycle technology.

11 **Q. Please summarize the transmission facilities and costs associated with the**  
12 **PEEC Project.**

13 A. The interconnection facilities required for the PEEC Project consist of four string  
14 busses needed to connect the three combustion turbine generators and the steam  
15 generator to the Port Everglades switchyard at a cost of approximately \$6.9  
16 million (2016\$). These costs do not include the generator step-up transformers  
17 (GSU), which are considered part of the generator power block.

18  
19 The facilities required in order to fully integrate the PEEC Project into the FPL  
20 transmission system include upgrading four existing 138 kV line sections in close  
21 proximity to the Port Everglades plant switchyard to accommodate the proposed  
22 PEEC unit. In addition, the Port Everglades switchyard requires an upgrade to  
23 increase the fault-withstanding capability for faults on, or in close proximity to,

1 the switchyard busses. The cost of all the required integration facility upgrades is  
2 estimated to be about \$25.6 million (2016\$). These upgrades are necessary due to  
3 thermal overloads under various contingencies, primarily in winter conditions  
4 when the output of the unit is higher, and under fault conditions, due to the higher  
5 fault current available from the new generators.

6  
7 The total transmission cost of both interconnection and integration facilities for  
8 the PEEC Project is estimated to be approximately \$32.5 million (2016\$). The  
9 specific facility upgrades and estimated costs of each are listed in Exhibit PM-1  
10 Summary of Required Facilities for PEEC. These transmission costs are included  
11 in the projected total cost of the PEEC Project presented by FPL Witness Gnecco  
12 in his direct testimony.

13 **Q. Did FPL also assess the potential transmission-related costs to a third party**  
14 **to interconnect to the FPL transmission system from a site other than Port**  
15 **Everglades within the Miami-Dade or Broward area?**

16 A. Yes. Using the process described above, FPL performed a hypothetical  
17 assessment for the interconnection and integration of a generation project of the  
18 same size and scope as the PEEC Project located at a potential site in western  
19 Broward County that could be acquired by a third party with zoning for industrial  
20 use, suitable for power generation. Interconnection costs were estimated to be  
21 approximately \$75 million (2016\$), and generic integration costs were essentially  
22 in the range of \$290-\$406 million (2016\$). These transmission costs are  
23 significantly higher than the PEEC Project costs because there are no locations on



1 the transmission system in the Miami-Dade or Broward County area that have  
2 existing capacity to integrate the generation from a project similar in size to the  
3 PEEC Project.

4 **Q. Please generally describe the impact on transmission losses of the location of**  
5 **generating resources in the transmission system.**

6 A. Transmission losses occur in transmission facilities as the electrical current flows  
7 from generators to loads. The farther the generator is from the load, the higher  
8 the losses. Since there are numerous generators, transmission elements, and loads  
9 distributed on the system, losses vary as a function of what generation is  
10 dispatched and the load level.

11

12 Power flows and the losses in the transmission system are affected whenever a  
13 generating resource is dispatched. Therefore, the impact on losses of an  
14 alternative will depend both on where the resource is located and the dispatch  
15 characteristic of the resource. While low cost resources may operate and impact  
16 transmission losses most of the time, less efficient generating resources are  
17 needed to serve higher load levels and generally tend to operate and impact losses  
18 during these times.

19

20 In this case, one of the alternatives to the PEEC Project was to return existing  
21 units to service (at Port Everglades). The generation in both of these alternatives  
22 is located in the same area, in fact mostly at the same site. Therefore the

1 difference in losses between the two options is minimal and was not included in  
2 the economic analysis described by FPL witness Enjamio in his direct testimony.

3

4 The other generation alternative to PEEC is the construction of a greenfield  
5 combined cycle (CC) unit outside the Southeast Florida area. This greenfield CC  
6 alternative would most likely have higher system transmission losses. However,  
7 since a specific site has not been identified for this unit, losses have not been  
8 quantified nor included in the economic analysis of the PEEC Project.

9 **Q. Is the Miami-Dade/Broward import limit an input in the economic analysis?**

10 A. Yes.

11 **Q. Please discuss the methodology used to determine the Miami-Dade/Broward  
12 import limit.**

13 A. Calculation of the transmission import limit into the Miami-Dade and Broward  
14 County area is performed by load flow analysis. In this case, the load flow  
15 analysis indicated potential for the limit to be set by either thermal overload  
16 conditions that are system operating limits, or voltage requirement limits at the  
17 Turkey Point switchyard. In order to establish which type of condition would be  
18 reached first in any case, two types of load flow analysis were used. For  
19 determination of a thermal overload limit, incremental transfer capability power  
20 flow analysis was used. To determine if a voltage limit is reached, Power/Voltage  
21 (P/V) analysis techniques were used. The limiting conditions for both analyses  
22 converged on a value of 6400 MW of power being reliably imported into the  
23 Miami-Dade and Broward County area, without observing either thermal

1 overloads on facilities in the area or the voltage limit at the Turkey Point  
2 switchyard being reached.

3 **Q. How is the import limit used in the economic analysis of the PEEC Project**  
4 **and its alternatives?**

5 A. The import limit value discussed above is an input to the production costing  
6 model used by RAP. RAP uses this import limit to determine the impact on costs  
7 of any out of economic dispatch of existing FPL generating units in the Miami-  
8 Dade and Broward County area that would be needed to avoid exceeding the  
9 limit. Witness Enjamio discusses the results of the production costing model in  
10 more detail in his direct testimony.

11

12 **TRANSMISSION RELIABILITY BENEFITS OF THE PEEC PROJECT**

13

14 **Q. How will the PEEC Project improve reliability to FPL's customers?**

15 A. The PEEC Project will result in a more reliable power supply to FPL's customers  
16 in two ways. First, a generation source that is geographically and electrically  
17 close to the load is not as dependent upon the transmission system to transfer  
18 power over long distances to reach the load. As a result, adding generation close  
19 to the load contributes to system stability and reliability. This is because in  
20 general, areas of concentrated load have multiple transmission lines serving  
21 densely populated centers. Having more lines disperses the amount of power  
22 flowing on each line, and in turn reduces the criticality of any particular line.  
23 Also, the lines in a densely populated area are typically shorter and therefore have

1 less exposure to natural elements which may cause interruptions (lightning, etc.)  
2 While FPL always strives to plan and operate its transmission system in a reliable  
3 manner, from a reliability perspective, it is preferable to have generation located  
4 in close proximity to major load centers whenever possible. Generation located  
5 close to the load also adds a level of operating flexibility and margin that  
6 contributes to increased reliability. Operating flexibility allows for improved  
7 maintainability.

8  
9 Second, since the new unit is very efficient, it will be base load dispatched, which  
10 means it will reduce the use of imported power from the grid and which will in  
11 turn eliminate or postpone the need for new transmission investment to increase  
12 import capability. Conversely, if the PEEC Project is not built and instead, the  
13 existing Port Everglades units are returned to service from Inactive Reserve, they  
14 will not normally dispatch very often because these older and less efficient units  
15 have higher operating costs. Power imported via the transmission system would  
16 have lower operating costs, so imported power will be relied upon more  
17 frequently, except when the existing Port Everglades Units are required to be  
18 dispatched out of economics as “must-run” units to maintain reliability. Over  
19 time, as loads continue to grow, this situation will be exacerbated, and this area  
20 will require more frequent out-of-economic dispatch of the Port Everglades Units  
21 1-4 to maintain reliability during both peak and off peak periods in order to  
22 maintain an adequate level of reliability, increasing costs to customers.

23


1

2 **Q. Why is the Port Everglades site location preferred over other potential sites**  
3 **for new generation?**

4 A. From a transmission perspective, the Port Everglades site has several advantages  
5 over other potential new sites. The transmission system has been planned and  
6 designed for the Port Everglades site to be a generation source. Since the Port  
7 Everglades site already has an existing transmission switchyard, the infrastructure  
8 necessary to transfer the power from the generators to the distribution system is  
9 already in place. Further, the Port Everglades switchyard has transformation to  
10 support injecting the output of PEEC into FPL's transmission system at both 230  
11 kV and 138 kV voltage levels. This flexibility is valuable because the ability to  
12 split the output of PEEC between the 138 kV and 230 kV voltage levels will defer  
13 the need to upgrade the 138 kV transmission system in the local area. The ability  
14 to connect at the 230 kV level also increases FPL's options for serving the local  
15 area, providing for the bulk transfer of power to other areas, and backing up the  
16 500 kV backbone of FPL's transmission system.

17 **Q. Does this conclude your direct testimony?**

18 A. Yes.



### Summary of Required Facilities for PEEC

<b>Transmission Facility Item #</b>	<b>Voltage Level (kV)</b>	<b>Description</b>	<b>Cost 2016\$ (000s)</b>
PEEC TF - 1	138	2-138 kV String Buses w/ fiber optic to connect generators A and B to Port Everglades switchyard	\$ 1,074
PEEC TF - 2	230	2-230 kV String Buses w/ fiber optic to connect generators C and STM to Port Everglades switchyard	\$ 1,074
PEEC TF - 3	138/230	Port Everglades System Yard - Upgrade 2-138 kV, 2-230 kV terminals, associated equipment	\$ 4,777
<b>Subtotal Interconnection</b>			\$ 6,924
PEEC TF - 4	138	Port Everglades 138 kV System Yard - Replace 10 - 138 kV breakers w/ 63 kA, 2-cycle	\$ 6,509
PEEC TF - 5	230	Port Everglades 230 kV System Yard - Replace 8 - 230 kV breakers w/ 63 kA, 2-cycle	\$ 5,377
PEEC TF - 6	138	Port Sub - Upgrade Port Tap terminal to 2000 amps	\$ 737
PEEC TF - 7	230	Port Everglades System Yard - Upgrade 230 kV bus due to fault current	\$ 1,957
PEEC TF - 8	138	Port Everglades System Yard - Upgrade 138 kV bus due to fault current	\$ 828
PEEC TF - 9	138	Hollywood Substation - Upgrade terminal to Port Everglades circuit	\$ 122
PEEC TF - 10	138	Dania Substation - Upgrade terminal to Port Everglades circuit	\$ 557
PEEC TF - 11	138	Transmission circuits - Upgrade Port Tap1-Dania - Hollywood to 1695 amps	\$ 7,201
PEEC TF - 12	138	Transmission circuits - Upgrade Port-Port Tap-Port Tap 2 to 1905 amps	\$ 1,581
PEEC TF - 13	138/230	OHGW Replacements due to Fault Current	\$ 719
<b>Subtotal Integration</b>			\$ 25,588
<b>Total</b>			<b>\$ 32,513</b>