

AUSLEY & McMULLEN

ATTORNEYS AND COUNSELORS AT LAW

123 SOUTH CALHOUN STREET
P.O. BOX 391 (ZIP 32302)
TALLAHASSEE, FLORIDA 32301
(850) 224-9115 FAX (850) 222-7560

September 12, 2012

HAND DELIVERED

RECEIVED FPSC
12 SEP 12 PM 2:26
COMMISSION
CLERK

Ms. Ann Cole, Director
Division of Commission Clerk
Florida Public Service Commission
2540 Shumard Oak Boulevard
Tallahassee, FL 32399-0850

120234-EI

Re: Tampa Electric Company's Petition to Determine Need
for Polk 2-5 Combined Cycle Conversion

Dear Ms. Cole:

Enclosed for filing on behalf of Tampa Electric Company are the original and fifteen (15) copies of each of the following:

1. Tampa Electric Company's Petition to Determine Need for Polk 2-5 Combined Cycle Conversion
2. Tampa Electric Company's Determination of Need for Electrical Power: Polk 2-5 Combined Cycle Conversion
3. Prepared Direct Testimony and Exhibit of Mark J. Hornick
4. Prepared Direct Testimony and Exhibit of Lorraine L. Cifuentes
5. Prepared Direct Testimony and Exhibit of Howard T. Bryant
6. Prepared Direct Testimony and Exhibit of J. Brent Caldwell
7. Prepared Direct Testimony of David M. Lukcic
8. Prepared Direct Testimony and Exhibit of S. Beth Young
9. Prepared Direct Testimony and Exhibit of R. James Rocha
10. Prepared Direct Testimony and Exhibit of Alan S. Taylor

COM 5
AFD 1
APA 1
ECO 1
~~ENG~~ (6 + c)
GCL 1
IDM 1
TEL 1
CLK 1

DOCUMENT NUMBER-DATE
06137 SEP 12 02
FPSC-COMMISSION CLERK


Ms. Ann Cole
September 12, 2012
Page Two

Also enclosed is one CD containing pdf versions of all of the foregoing.

Please acknowledge receipt and filing of the above by stamping the duplicate copy of this letter and returning same to this writer.

Thank you for your assistance in connection with this matter.

Sincerely,

A handwritten signature in black ink, appearing to read "James D. Beasley", written in a cursive style.

James D. Beasley

JDB/pp
Enclosures

cc: Office of Public Counsel (w\encls.)

BEFORE THE FLORIDA PUBLIC SERVICE COMMISSION

In re: Tampa Electric Company's Petition to)
Determine Need for Polk 2-5 Combined)
Cycle Conversion.)
_____)

DOCKET NO. 120234-E1

FILED: SEPTEMBER 12, 2012

PETITION

Pursuant to Sections 366.04 and 403.519, Florida Statutes, and Rules 25-22.080, 15-22.081 and 28-106.201, Florida Administrative Code ("F.A.C."), Tampa Electric Company ("Tampa Electric" or "company") petitions the Florida Public Service Commission ("Commission") for an affirmative determination of need for the waste heat recovery conversion of its existing Polk combustion turbines ("CTs") 2 through 5 electrical power plant and associated facilities ("Project" or "Polk 2-5").

In support of this Petition, Tampa Electric States as follows:

1. The Petitioner's name and address are:

Tampa Electric Company
Post Office Box 111
Tampa, Florida 33601

2. The names and addresses of Tampa Electric's representatives to receive communications regarding this docket are:

James D. Beasley
jbeasley@ausley.com
J. Jeffrey Wahlen
jwahlen@ausley.com
Ausley & McMullen
Post Office Box 391
Tallahassee, FL 32302
(850) 224-9115
(850) 222-7560 (fax)

Paula K. Brown
Manager Regulatory Coordination
pkbrown@tecoenergy.com
Tampa Electric Company
Post Office Box 111
Tampa, FL 33601
(813) 228-1444
(813) 228-1770 (fax)

DOCUMENT NUMBER-DATE

06137 SEP 12 09

FPSC-COMMISSION CLERK

3. Tampa Electric is a Commission regulated investor-owned utility with its principal offices located at 702 North Franklin Street, Tampa, Florida 33602. Tampa Electric is a utility as defined in Section 366.82(1), Florida Statutes, and is an applicant as defined in Section 403.503(4), for purposes of Section 403.519, Florida Statutes. Tampa Electric is the primarily affected utility within the meaning of Rule 25-22.081, F.A.C.

I. Introduction

4. Tampa Electric proposes to license, construct and operate Polk 2-5, a natural gas combined cycle ("NGCC") power plant at Polk Power Station, a 2,800-acre site located in Polk County, Florida, 40 miles southeast of Tampa. The site currently consists of Polk Unit 1, a 220 MW IGCC plant, and four CTs totaling a net 604 MW in the summer. Polk 2-5 is expected to generate a net 1,195 MW of electricity in winter and 1,063 MW in the summer. Polk 2-5 will result from the conversion of Tampa Electric's four existing CT generating units, Polk 2 through 5, at Polk Power Station into a modern NGCC generating facility, thereby making efficient and economic use of what is otherwise waste heat exhausted from the existing CTs. The energy from this waste heat is captured in four new heat recovery steam generators ("HRSGs"). The steam created in the HRSGs is directed to a single steam turbine generator. With additional supplemental firing of the HRSGs the single steam turbine will generate 459 MW of summer capacity and 463 MW of winter capacity. This generation will allow Tampa Electric to meet a projected need for additional generating resources that begins in 2017 and increases each year thereafter.

5. The Polk Power Station site was originally selected as the result of Tampa Electric's extensive Power Plant Site Selection Assessment Program, which set out in 1989 to

select the most suitable location for meeting the company's future power supply requirements. An integral part of the Polk site selection process was the formation and participation of a Siting Task Force composed of 17 private citizens from environmental groups, businesses and universities in Tampa Electric's service area and throughout Florida. The Polk site was developed to allow for generation expansion in the future.

6. Converting the existing CTs at Polk Power Station to a NGCC facility will enable Tampa Electric to meet its forthcoming electric generating needs through a project that will maximize generation efficiency and cost effectiveness and at the same time minimize impacts on the environment. Through the addition of HRSGs at Polk Power Station the company will be able to harness what otherwise is waste heat and use that essentially free energy source to meet its generating needs beginning in 2017. The addition of heat recovery will provide a 37 percent increase in the generating efficiency of the four CTs incorporated into Polk 2-5, thereby significantly reducing fuel costs. The inherent efficiencies associated with this opportunity will inure to the economic benefit of Tampa Electric's customers, and will do so in a manner that has improved environmental impacts.

7. The Polk 2-5 project, as the company's next unit addition, will provide significant savings to Tampa Electric's customers as compared to the other "self-build" options evaluated by the company. In addition, the project will provide savings over the most cost-effective alternative from among the various responses received in a request for proposal ("RFP") process conducted by the company in advance of filing this petition. Customers will save approximately \$132.4 million in cumulative present worth revenue requirements ("CPWRR") in 2012 dollars over the most favorable proposal from the RFP responses the company received.

8. Polk 2-5 will also improve Tampa Electric's environmental profile. The improvement in power generating efficiency from waste heat as an energy source will result in a direct reduction in the emissions rate for all pollutants on a pounds per MW hour basis and reduce CO₂ emission rates by approximately 37 percent. Polk 2-5 will meet, if not exceed, all applicable local, state and federal environmental requirements. These benefits will be achieved using an existing permitted plant site and utilizing reclaimed water to provide the majority of the water needed for the expansion in lieu of further groundwater extraction.

9. Polk 2-5 is needed to provide sufficient generating capacity to maintain electric system reliability at a reasonable cost. As is later explained, that need cannot be satisfied by incremental demand side management ("DSM") measures, conservation or other non-generating alternatives.

10. The Polk 2-5 conversion creates additional dual fuel capacity and improves fuel diversity on Tampa Electric's system. Having dual fuel capability also increases power supply reliability through the added assurance of available fuel. This assurance is particularly valuable during times of potential natural gas disruptions such as those caused by hurricanes. A secondary fuel source also helps reduce the company's reliance on high cost market power during those disruptions, resulting in lower energy costs for customers.

11. Polk 2-5 is the most cost-effective alternative to meet the additional capacity needs of Tampa Electric's system.

12. Tampa Electric requests that the Commission, in its final Order granting a determination of need for Polk 2-5 and its associated facilities, find that the decision to construct the Project is prudent, based on the cost and performance estimates as well as the other relevant assumptions including all applicable statutory and Commission Rule criteria.

II. The Utility Primarily Affected (Rule 25-22.081(1)(a))

13. Tampa Electric is the utility primarily affected by the proposed Project. Tampa Electric is an investor-owned electric utility and the principal subsidiary of TECO Energy, Inc.

14. Tampa Electric is charged with serving its current customer base of over 680,000 customer accounts, as well as new customers that locate in its service territory of approximately 2,000 square miles covering Hillsborough and portions of Polk, Pinellas and Pasco Counties in Florida. The current population in the company's service area is approximately 1.25 million.

15. Tampa Electric is part of the nation's Eastern Interconnection Transmission Network. It has multiple points of interconnection with other utilities that enable power to be exchanged among them. The Tampa Electric bulk transmission system is comprised of 1,322 miles of transmission lines. Integration of the generation, transmission and distribution system is achieved through Tampa Electric's 219 substations.

16. The company has three primary generating stations that include steam, coal fueled and IGCC base load units, NGCC intermediate load units and natural gas and oil fired combustion turbine peaking load units. The total net system generating capacity in the winter of 2011 was 4,684 MW and on an energy basis generated 56 percent solid fuel, 43 percent natural gas and less than 1 percent oil.

17. Polk 2-5 helps contribute to the state's reserve margin criterion and helps alleviate the Florida Reliability Coordinating Council (FRCC) concern regarding the degree to which the peninsular Florida system is becoming increasingly dependent upon demand side management to meet its reserve margin criterion.

III. The Proposed Electrical Power Plant (Rule 25-22.081(1)(b))

18. The proposed Project consists of the construction and operation of Polk 2-5, a NGCC power plant at Polk Power Station, the site of Tampa Electric's existing IGCC facility. The company will utilize its experience with NGCC technology to convert the existing CT Units 2 through 5 at Polk Power Station into a NGCC facility.

19. Polk 2-5 will be a NGCC facility consisting of four CTs, four HRSGs with incremental supplemental firing and a single steam turbine arranged such that each of the four existing CTs will be coupled with a HRSG, with the output of the four HRSGs driving a single steam generator (referred to as a 4x4x1 configuration). The technology is a combination of a combustion turbine (Brayton) cycle and a traditional steam (Rankine) cycle technologies. The combination of these two technologies allows for thermal efficiency of almost 50 percent. This is a proven system for power generation and one with which Tampa Electric has significant experience designing, constructing and operating.

20. Capturing waste heat from the existing Polk CTs 2-5 will generate an incremental net 352 MW of electricity in winter at 32 degrees Fahrenheit and 339 MW in the summer at 92 degrees Fahrenheit. The HRSGs installed at Polk 2-5 will also utilize supplemental firing of natural gas, also known as duct burners, to generate additional steam and provide 120 MW (summer) and 111 MW (winter) of cost-effective peaking capacity that will offset the need for future peaking unit capacity.

21. The Project is being designed with the ability to incorporate approximately 30 MW of solar energy in the form of steam from solar thermal collectors located at the Polk Power Station site. The integration of steam produced via solar collectors into a combined cycle plant is known as a solar hybrid system as it uses the existing combined cycle steam turbine rather

than a separate turbine dedicated to solar use. This is more cost-effective than stand-alone solar and the HRSG supplemental firing creates a back-up and improves reliability.

22. The existing cooling reservoir at the Polk Power Station will be used for cooling the steam from the new steam turbine on Polk 2-5. Use of the existing cooling reservoir infrastructure reduces costs and will allow Polk 2-5 to operate with lower water consumption and lower parasitic load than if a stand-alone cooling tower were used for the steam turbine heat rejection system.

23. A new small cooling tower will be constructed to provide equipment for auxiliary cooling for Polk 2-5 as well as Polk Unit 1. This is needed to optimize the heat loading on the existing cooling reservoir and mitigate operational impacts that could occur due to increased water temperature in the cooling reservoir.

24. The Project is being designed to allow operation of each CT in either simple cycle or combined cycle mode. This will provide considerable operating flexibility and will allow the facility to serve both intermediate and peaking load requirements.

Fuel and Fuel Supply Considerations

25. Polk CTs 2 and 3 have dual fuel capability, meaning that they are able to utilize either natural gas or distillate oil. Polk CTs 4 and 5 will be permitted to have dual fuel capability. Dual fuel capability improves power supply reliability by significantly minimizing, if not eliminating, fuel supply risk.

26. The Project will utilize Tampa Electric's existing natural gas commodity portfolio, storage, pipeline capacity and infrastructure along with backup oil capability and storage. The use of these existing assets reduces costs and increases overall efficiency of fuel supply. Power generated using the waste heat from the existing CTs does not create additional fuel use.

Operation of the new combined cycle at times when the existing CTs would not otherwise be operating also reduces overall system fuel and purchased power costs due to the high efficiency of the new combined cycle unit.

27. Tampa Electric's portfolio of natural gas fuel supply assets and generation units combined with the company's experience and capability in managing its natural gas fuel supply will enhance the reliability and cost-effectiveness of the fuel supply for Polk 2-5.

28. Tampa Electric currently possesses both physical and contractual flexibility for gas delivery in its portfolio. This provides significant flexibility in procuring and allocating natural gas using both the Florida Gas Transmission ("FGT") pipeline system and Gulfstream Pipeline, LLC ("Gulfstream"). Polk Power Station is physically connected to the FGT system as a Primary Delivery Point. Tampa Electric's H. L. Culbreath Bayside Power Station can be supplied from either FGT or Gulfstream and Tampa Electric currently has multiple agreements with both FGT and Gulfstream.

29. Tampa Electric is sponsoring its fuel price forecasts in support of this Petition. Those forecasts are based on sound industry-respected publications, indices, forecasts and escalators. Tampa Electric will demonstrate that its fuel price forecasts are reasonable for planning purposes and for use as a basis for committing to proceed with Polk 2-5.

Fuel Diversity Considerations

30. The addition of Polk 2-5 will maintain Tampa Electric's already well-balanced fuel portfolio. The company will be adding one of the most efficient, economical, and environmental friendly energy sources to its existing well diversified fuel mix of solid fuel and natural gas.

Water Requirements of the Project

31. Polk 2-5's water requirements will be met primarily with reclaimed water from the City of Lakeland. This will minimize the use of ground water.

Transmission Integration and Interconnection Requirements

32. Associated facilities of the Project include new and upgraded transmission facilities with which Polk 2-5 will be interconnected and integrated into Tampa Electric's transmission system. These additions will increase the import and export capability of the Tampa Electric transmission system and provide more source options during planned and unplanned generation outages. Upgrades to the existing 230 KV facilities will also reduce exposure to multi-circuit structure outages, increasing the reliability of the transmission system. The addition of the new transmission facilities will also improve the reliability of the central Florida region for Tampa Electric customers and the entire Florida Reliability Coordinating Council ("FRCC") region.

Project Costs

33. The total in-service costs estimate for Polk 2-5 is \$706.6 million, which includes overnight construction costs as well as escalation, transmission costs and AFUDC. Owner's costs include: Project development costs such as technology development and environmental permitting; Project management and operational support and training; legal and other professional services costs; and insurance.

34. Cost estimates are based on a preliminary design completed by the engineering firm of Black and Veatch, which has obtained multiple quotations from major equipment manufacturers and has validated current pricing for commodities and labor in the central Florida area.

35. Tampa Electric plans to competitively bid all the major equipment required for Polk 2-5. The company envisions using multiple prime contractors with contracts containing an appropriate mix of incentives and penalties to align the various contractors with the Project goals.

Environmental Attributes

36. From an environmental perspective, Polk 2-5 will utilize a proven technology that will not only meet, but will likely surpass all applicable environmental regulatory requirements. The selection of NGCC technology over other alternatives will minimize emissions while simultaneously providing cost-effective and reliable energy. By taking advantage of the waste heat from existing Polk CTs 2 through 5, the Project will provide additional generation with minimal additional fuel requirements, thereby reducing air emissions on a pounds per MWH basis. The Project will also take advantage of existing site infrastructure and reclaimed water resources, thereby greatly reducing the need for ground water consumption in the operation of the new facility.

IV. Need for Polk 2-5 (Rule 25-22.081(1)(c))

37. Tampa Electric's need for additional capacity is compelling. After taking into account existing power plant unit capacity, firm purchased power agreements ("PPAs"), and the most recent Ten Year Site Plan load forecast that considers DSM, conservation and renewable energy alternatives, Tampa Electric requires an addition of 294 MW of generating capacity to maintain Tampa Electric's system reliability requirements beginning in 2017. Without any additional capacity to maintain its 20 percent reserve margin reliability criterion, Tampa Electric's 2017 summer reserve margin is projected to decrease to 12.5 percent. Utilizing a

recently updated load, DSM and fuel forecast, and all of the aforementioned considerations, Tampa Electric still requires an additional 205 MW of generating capacity to maintain system reliability requirements beginning in 2017. Polk 2-5 is, therefore, needed to maintain the electric system reliability and integrity for Tampa Electric while addressing the need for reliability and fuel diversity in Florida.

38. Tampa Electric forecasts continued growth of customers in its service territory. The company's recently updated forecast projects approximately 60,000 new customers by 2017 and 103,000 new customers by 2021, with the total number of customers exceeding 735,000 by 2017 and 778,000 by 2021. Peak demand for the summer of 2012 is forecasted to be 3,993 MW, increasing to 4,331 MW in 2021, an average increase of 38 MW per year. Tampa Electric will need to invest in new infrastructure to keep pace with the increasing demand for adequate and reliable power to meet the needs of its growing customer base.

39. Tampa Electric meets its resource needs through generating units, purchased power and DSM. As stated earlier, Tampa Electric's generating resources are located at three primary sites distributed geographically throughout its service territory and as of summer 2012, they along with firm PPAs totaled approximately 4,909 MW (summer) of capacity.

40. Tampa Electric has PPAs with a variety of suppliers totaling 594 MW (summer) for 2012. Tampa Electric also has a contract to purchase firm cogeneration capacity totaling 23 MW in 2012.

41. Tampa Electric requires additional supply resources by 2017 to replace the purchased power contracts as all but one 121 MW contract expire prior to January 2017.

42. Tampa Electric determined in its 2012 integrated resource plan ("IRP") and communicated in its 2012 Ten Year Site Plan that it will need significant additional resources

starting in 2017 to meet its 20 percent reserve margin criterion approved by the Commission in Order No. PSC-99-2507-S-EU. To accomplish this, Tampa Electric will need a minimum of 294 MW of new supply from either power plant installation, purchased power or additional DSM to meet its 2017 reserve margin requirement.

43. New generating capacity, including the associated facilities described herein, built in Tampa Electric's service area is the most cost-effective option to maintain system reliability. After conducting a RFP and considering alternative technologies, Tampa Electric determined that the addition of Polk 2-5 into Tampa Electric's system is the best available option for meeting the company's system reliability needs.

44. Polk 2-5 will add highly efficient and cost-effective generation that, as a utility-owned plant, will be committed to Florida's retail customers and subject to Commission oversight. As shown in the accompanying Need Study, Polk 2-5 will produce adequate electric capacity, improve system efficiency, lower system environmental emissions and maintain system reliability all at a reasonable cost.

V. Tampa Electric's Analysis of Generating Alternatives (Rule 25-22.081(1)(d))

45. Tampa Electric considered a variety of generating options prior to identifying NGCC technology, in the form of Polk 2-5, as the best option for Tampa Electric and its customers. The company's screening process evaluated an array of natural gas, solid fuel and renewable technologies.

46. Strategic considerations in the company's analysis of generating alternatives included fuel price stability, fuel diversity, environmental impacts, technology viability,

construction lead times and site availability. The company's screening analysis narrowed the focus to NGCC or CT technologies for further analysis.

47. Tampa Electric considered simple cycle aero-derivative engines similar to Bayside Unit 3 and simple cycle CTs similar to the existing CTs at Polk Power Station. The company also considered a brownfield 2-on-1 combined cycle unit in addition to converting the existing four Polk CTs into a 4-on-1 combined cycle unit.

48. The company's screening analysis of the various alternatives compared the levelized annual cost of each technology at various capacity factors. Tampa Electric selected NGCC technology as a viable intermediate option and CT technology as a peaking option.

49. Tampa Electric's final integrated resource plan confirmed the need for additional firm purchases in each year from 2012 through 2017 and the addition of Polk 2-5 in 2017. The final plan also demonstrated a CPWRR savings of \$65.4 million when Polk 2-5 was compared to the 2011 TYSP with updated fuel forecasts and updated demand and energy and DSM projections.

VI. RFP Process

50. In March 2012, Tampa Electric issued a request for proposal soliciting firm offers for cost-effective alternatives to Polk 2-5. From the initial drafting of the RFP document forward, this process was conducted under the guidance of a very reputable independent third party evaluator, Alan S. Taylor, President of Sedway Consulting, Inc., to keep the process as open and inviting to potential bidders as possible. The RFP process was extensively noticed with pre- and post-RFP release meetings, with website posting of questions from the potential and actual bidders and answers provided to all participants without disclosing the identity of the

participants posing the questions. Tampa Electric's RFP process was open to all potential providers of all or portions of the company's 2017 resource needs, including respondents submitting existing resources, proposing new construction, or offering PPAs.

51. There was robust participation in both the pre-release conference and the post-relief workshop with over 70 questions and answers posted to the company's website. Ultimately, Tampa Electric received four proposals, each of which was opened by the independent third party evaluator and accepted as a qualifying bid for further evaluation.

52. Sedway Consulting was involved in each step of the bid evaluation process including opening the sealed proposals received from each respondent. Sedway Consulting incorporated pricing and operational information from each proposal received into its own analytical model. After cross checking all key modeling assumptions for both the proposals and Tampa Electric's system Sedway Consulting performed and finalized their own initial, independent evaluation.

53. Sedway Consulting later met with Tampa Electric to discuss the evaluation results of the original proposals and agreed that all offers should be short listed. After clarification conference calls in which Sedway Consulting participated, the short listed respondents were provided an opportunity to provide best-and-final offers.

54. Using their own model, Sedway Consulting compared the economics of Tampa Electric's next planned generating unit, Polk 2-5, and each of the proposed resource options (both the original bids and the best-and-final offers). Sedway Consulting's evaluation revealed that Polk 2-5 was \$148 million less expensive on a net present value basis than the next cost-effective

RFP compliant proposal.¹ Tampa Electric's internal analysis of the most cost-effective RFP compliant proposal indicated that Polk 2-5 was \$132.4 million (NPV) less expensive.

55. After a thorough and detailed evaluation of the available alternatives, Sedway Consulting concluded that Tampa Electric's Polk 2-5 project is the most cost-effective resource for meeting the company's 2017 capacity needs and concurred with Tampa Electric's decision to move forward with that Project. Sedway Consulting's analysis concluded that the solicitation process yielded the best results for Tampa Electric's customers while treating respondents fairly.

VII. Tampa Electric Analysis of Non-Generating and "Self-Build" Generating Alternatives (Rule 25-22.081(1)(e))

56. Tampa Electric has long been a leader in offering its customers cost-effective DSM programs coupled with a comprehensive educational emphasis of the efficient use of energy. Those efforts began in the mid-1970's. Following the 1980 enactment of the Florida Energy Efficiency and Conservation Act, Tampa Electric has filed for and gained Commission approval of numerous DSM programs designed to promote new energy efficient technologies and to change customer behavioral patterns such that energy savings occur with minimal effect on customer comfort.

57. The company has experienced great success with its DSM initiatives. From the inception of its programs in 1980 through the end of 2011, Tampa Electric has achieved 719 MW on winter peak demand reduction, 306 MW of summer peak demand reduction and 770 GWH of annual energy savings. This amount of peak load reduction has eliminated the need for the equivalent of four 180 MW power plants of winter capacity.

¹ The respondent of this RFP compliant proposal also put forth two non-RFP compliant scenarios that Sedway Consulting examined and determined to be \$131 million and \$69 million (NPV) more expensive than Polk 2-5.

58. The company's DSM program results compare quite favorably to other utilities across the nation, with Tampa Electric's national average ranking for cumulative conservation at the 89th percentile and at the 85th percentile for load management achievement.

59. Tampa Electric reviewed the addition of other generating alternatives as well as potential demand-side programs in determining the most appropriate expansion plans.

60. Tampa Electric's existing DSM programs represent the company's most recently assessed, and most recently Commission approved, collection of available cost-effective DSM alternatives. Tampa Electric included all of these DSM programs in its preliminary demand and energy forecast which effectively reduced system peaks and energy requirements. Since the projected results of those recently approved programs were factored into the assessment for this determination of need, there are no additional cost-effective DSM alternatives or viable renewable options that would defer the need for additional generating capacity in 2017.

61. Similarly, all anticipated cost-effective generating capacity that will be available from renewable resources and qualifying facilities through 2017 has been reflected in Tampa Electric's resource plan. In the future non-firm renewable resources that could cost-effectively provide energy to Tampa Electric would complement the benefits Tampa Electric's customers will receive from Polk 2-5.

62. Taking these benefits into consideration, the interests of Tampa Electric's customers are best served by placing Polk 2-5 in commercial operation in January 2017.

VIII. Adverse Consequences of Delay (Rule 25-22.081(f))

63. In the event Polk 2-5 is delayed by one year or longer, project costs would likely increase and customers would lose the fuel savings benefits for 2017 through the duration of the

delay. In addition to typical factors such as inflation and project management expenses, there is a risk of higher than normal cost increases due to equipment demand. For the past several years there has been somewhat of a lull in generating unit additions due to the broad economic downturn and reduction in energy use. As the economy picks up and energy use increases, it is likely that most utilities will choose gas fired combined cycle technology. The potential rapid increase in demand and the focus on one generating technology by the industry could create a sharp increase in prices for combined cycle equipment and skilled construction labor.

64. The potential for an equipment demand spike would translate to significantly higher costs for customers. Under a scenario where such demand spikes materialize, the result would be higher costs for customers of \$100 million on a cumulative present worth revenue requirement basis.

65. In the event of the denial of Tampa Electric's application for a determination of need for Polk 2-5, the company most likely would construct a simple cycle peaking unit in 2017. This would result in higher costs for customers compared to the costs of the proposed Project. Tampa Electric's customers would be denied the efficiencies and economies associated with utilizing waste heat to generate incremental capacity and the environmental attributes associated with Polk 2-5 would not be realized.

IX. Need Study and Prefiled Testimony

66. Tampa Electric submits in support of this Petition and incorporates herein by reference its detailed Need Study and appendices that develop more fully the information required by Rule 25-22.081, Florida Administrative Code. Tampa Electric is also submitting the

testimony of eight witnesses supporting Tampa Electric's request that the Commission grant an affirmative finding of need for Polk 2-5 and its associated facilities.

X. Disputed Issues of Material Fact

67. Tampa Electric presently is unaware of any disputed issues of material fact affecting this proceeding. Tampa Electric will demonstrate during the course of the proceeding that approving a determination of need for Polk 2-5 beginning in 2017 will best serve Tampa Electric's customers by meeting their growing electric supply needs while at the same time providing substantial economic benefits as well as substantial environmental benefits through the efficient use of currently available waste heat as an energy source, an existing generation station site and other existing committed resources. Tampa Electric will demonstrate that there are no reasonably available renewable resources, DSM or other non-generation alternative that would significantly mitigate the need for Polk 2-5.

CONCLUSION

68. Tampa Electric's proposed Polk 2-5 Project is a highly efficient, cost-effective and reliable choice to meet the growing electric needs of Tampa Electric's customers in a very environmentally friendly way. The construction and operation of Polk 2-5 offers Tampa Electric and its customers a number of significant advantages over any other alternative. The Project will deliver major cost savings for the benefit of Tampa Electric's customers, will enable Tampa Electric to reliably meet the electric power needs of its growing customer base and provide Tampa Electric customers and, indeed, all Floridians with key environmental benefits through reduced emissions. Polk 2-5 is consistent with the Peninsular Florida capacity needs and reduces

the dependency on DSM programs to meet reserve criterion. All of this will be achieved using as a base for the Project existing generation plant on an already permitted power plant site.

69. Based upon all of these considerations and the greater level of detail provided in the prepared direct testimony and exhibits of Tampa Electric's witnesses and the need study submitted with this Petition, Tampa Electric respectfully requests that the Commission grant the company an affirmative determination of need for Polk 2-5 and its associated facilities beginning in 2017. Upon approval of this Project Tampa Electric will periodically report to the Commission updated information on the budgeted and actual costs of the Project, compared to the estimated total in-service costs presented in this Petition.

WHEREFORE, Tampa Electric respectfully requests that the Commission grant an affirmative determination of need for Polk 2-5 and its associated facilities beginning in 2017. In so doing, the Commission should:

(a) find that Polk 2-5 is needed to maintain electric system reliability and integrity and to provide adequate electricity at reasonable cost, taking into account the need for fuel diversity and supply reliability;


(b) find that Polk 2-5 is the most cost-effective option for providing efficient fuel diverse generation capacity needed to meet the needs of Tampa Electric's customers beginning in 2017;

(c) find that there is no reasonably available DSM, renewable or other non-generation alternative that would mitigate the need for Polk 2-5;

(d) find that the decision to construct Polk 2-5 is reasonable and prudent, based on the estimated installed costs as well as the other relevant assumptions;


(e) affirm that after Polk 2-5 is placed in service, all prudently incurred non-fuel costs of the Project shall be recoverable through base rates.

Respectfully submitted this 12th day of September 2012.



JAMES D. BEASLEY
J. JEFFRY WAHLEN
Ausley & McMullen
Post Office Box 391
Tallahassee, Florida 32302
(850) 224-9115

ATTORNEYS FOR TAMPA ELECTRIC COMPANY



**Tampa Electric Company's
Determination of Need for
Electrical Power: Polk 2-5
Combined Cycle Conversion**

Filed: September 12, 2012

Table of Contents

I.	Executive Summary	1
II.	Introduction and IRP Process Overview	5
	A. Introduction	5
	B. Tampa Electric’s Integrated Resource Planning Process	6
III.	Background and Assumptions	7
	A. Description of Tampa Electric’s System.....	7
	1. Transmission and Distribution	9
	2. Firm Purchased Power Capacity	10
	3. Demand-Side Management.....	10
	4. Renewable Energy	12
	5. Tampa Electric’s Current Energy and Capacity Mix by Fuel Type.....	13
	B. Assumptions	13
	1. Forecast Assumptions	14
	2. Forecast Methodology	16
	3. Energy Forecast Models.....	18
	4. Demand Forecast Models	21
	5. Demand and Energy Forecasts	22
	C. Fuel Forecast.....	24
	1. Natural Gas	25
	2. Solid Fuels.....	25
	3. Transportation	26
	4. Fuel Price Forecasts.....	26
	D. Environmental.....	27
	E. General Financial Assumptions	28
	F. Technology Assumptions.....	29
	1. Demand Side Programs	29
	2. Supply Technologies	29
IV.	Need for Capacity in 2017	30
	A. Reliability Assessment.....	30
	1. Demand-Side Management.....	32
	B. Tampa Electric’s Reliability Assessment Results.....	32
	C. FRCC Reliability Assessment Results	33
V.	Screening of Potential Technologies	34
	A. Qualitative Screening.....	35
	B. Quantitative Screening.....	36
VI.	Detailed Economic Analysis	39
	A. Description of Analysis.....	39
	B. Economic Analysis Results.....	40
	1. Tampa Electric Selected Alternative.....	41
	2. Qualitative Factors and Benefits of the Selected Alternative	41
	3. Consistency with Florida Needs	42
VII.	Sensitivity analysis	43
	1. Capital Cost Sensitivity.....	43

2. Fuel Price Sensitivity	44
3. Load Sensitivity	44
VIII. RFP for Capacity as per Bid Rule	45
A. Initial Screening	46
B. Economic Evaluation of Individual Proposals/Bids	47
C. Present Value Economic Screen	48
D. Final Evaluation of Total System Costs	48
E. Non-Economic Evaluation.....	50
F. Final Selection	50
IX. Tampa Electric’s Proposed Unit.....	51
A. Overview.....	51
B. Description.....	52
1. Location.....	52
2. Design	53
3. Systems.....	55
C. Environmental.....	56
D. Transmission Facilities.....	57
E. Cost	59
F. Schedule.....	60
X. June 2012 Assumptions Update.....	60
XI. Adverse Consequences If Polk 2-5 Is Delayed Or Denied.....	61
XII. Conclusion	62
XIII. Appendices	64
Appendix A: Residential DSM Programs.....	65
Appendix B: Commercial/Industrial DSM Programs.....	66
Appendix C: Retail Customers by Customer Class	67
Appendix D: Retail Energy Sales by Customer Class	68
Appendix E: Retail Peak Demand Forecast	69
Appendix F: High and Low Retail Peak Demand Used in Sensitivity	70
Appendix G: June 2012 Update Used in Sensitivity	71
Appendix H: Fuel Forecast.....	72
Appendix I: Low Fuel Forecast Used in Sensitivity Analysis	73
Appendix J: High Fuel Forecast Used in Sensitivity Analysis.....	74
Appendix K: Tampa Electric Reliability Analysis	75
Appendix L: Tampa Electric Final Reliability Analysis	76
Appendix M: FRCC Reliability Analysis.....	77
Appendix N: FRCC Reliability Sensitivity Analysis	78
Appendix O: Technology Assumptions	79
Appendix P: RFP Qualitative Factors.....	80
Appendix Q: Polk 2-5 Preliminary Project Schedule	81
Appendix R: Polk 2-5 Environmental Permit Requirements	82
Appendix S: Transmission Interconnection and Integration Diagrams	84

Index of Figures:

Figure 1: Fuel Forecast for Final Analysis	27
Figure 2: Peaking Technology Screening Curve	37
Figure 3: Intermediate and Base Screening Curve	38
Figure 4: RFP – Initial Screening of Proposals	48
Figure 5: Polk 2-5 Overall Process	54

Index of Tables:

Table 1: Tampa Electric System Installed Capacity.....	9
Table 2: Tampa Electric's Energy Mix by Fuel Type.....	13
Table 3: Tampa Electric's Capacity Mix by Fuel Type	13
Table 4: 2017 Firm Peak Requirements	33
Table 5: Detailed Economic Analysis Resource Plan	40
Table 6: Results of Final Economic Analysis	41
Table 7: CPWRR Based on Capital Cost Sensitivities (\$ million)	44
Table 8: CPWRR Based on Fuel Pricing Sensitivities (2012 \$ million).....	44
Table 9: CPWRR Based on Load Sensitivities (\$ million).....	45
Table 10: RFP Summary of Proposals	47
Table 11: Resource Plans of RFP Portfolios	49
Table 12: RFP CPWRR Results in 2012 (\$ million).....	50
Table 13: Economic Evaluation with Consideration of June 2012 Updated Assumptions	61

I. EXECUTIVE SUMMARY

Tampa Electric Company ("Tampa Electric" or "company") has determined through its integrated resource planning ("IRP") process a need for the Polk 2-5 combined cycle project ("Polk 2-5"), with a targeted commercial operation date of January 2017. The existing Polk 2 through 5 combustion turbines ("CTs") will be converted to a natural gas combined cycle ("NGCC") facility located at Polk Power Station by integrating a new steam turbine with an additional capacity of 459 MW summer and 463 MW winter. This incremental capacity is derived from waste heat from the four existing combustion turbines of 339 MW summer and 352 MW winter, as well as 120 MW summer and 111 MW winter from supplemental natural gas duct-firing in the four Heat Recovery Steam Generators ("HRSGs").

Prospectively, Tampa Electric's firm load is expected to grow approximately 1.2 percent annually winter (1.0 percent summer) or 40-45 MW of firm demand per year. Tampa Electric will continue to meet capacity requirements with the most economical combination of demand-side management ("DSM"), conservation, renewable energy, purchased power, and generating capacity additions. In addition to normal load growth, Tampa Electric requires additional supply resources by 2017 to replace the purchased power contracts of 183 MW expiring on December 31, 2015, 117 MW expiring on December 31, 2016, and an additional 121 MW expiring on December 31, 2018.

Tampa Electric's IRP process incorporated an on-going evaluation of demand and supply resources and conservation measures to maintain system reliability. By 2017, Tampa Electric's DSM programs will have produced summer and winter customer demand and energy reductions of 376.4 MW and 752.1 MW, respectively and energy conservation of 1,000.7 GWH. The reliability analysis determined that Tampa Electric will have capacity needs by 2017 of 294 MW. In

order to develop the optimum expansion plan, the company researched current technologies for feasible options. The resulting list of supply resources was screened for technical feasibility, reliability and relative economics. The initial screening resulted in the narrowing of technology alternatives to simple-cycle natural gas and NGCC for further detailed analysis.

Tampa Electric evaluated these technologies utilizing standard IRP techniques. Some of the economic and non-economic factors that were considered included resource reliability, efficiency, range of fuel capability and availability, capital and operating costs, ability to meet current and potential future environmental requirements, water use, and overall site benefits. As a result of this detailed analysis, Tampa Electric determined that NGCC technology is the best option to meet the 2017 need, and conversion of the four existing combustion turbines at Polk Power Station to an NGCC is the most cost-effective alternative.

Once this need was identified, Tampa Electric solicited market alternatives to its next planned generating unit as directed by the resource bid rule. The company issued a Request For Proposals (“RFP”), and considered price and non-price attributes, operational performance, dispatchability, reliability, and environmental compliance, and other issues. After carefully considering and integrating Tampa Electric’s DSM load reduction and energy conservation programs and other supply resources, Polk 2-5 was selected as the most cost-effective, reliable means of serving Tampa Electric’s customers for the following reasons:

1. It is the most cost-effective next addition to the Tampa Electric system, when compared with all of the “self-build” alternatives.
2. It is the most cost-effective alternative, and the project results in a savings of \$132.4 million Cumulative Present Worth Revenue Requirements (“CPWRR”) compared to the next best proposal in the RFP process.

3. It achieves significant energy efficiency savings by capturing the waste heat from four existing combustion turbines to generate up to 352 MW of net electrical output with no additional fuel input.
4. It provides up to 120 MW of additional low cost peaking capacity from supplemental natural gas duct-firing in the four HRSGs. This supplemental firing eliminates the need for future higher-cost simple cycle CT peaking units.
5. The retention of simple cycle operating capability of the four existing combustion turbines provides operating flexibility and improves system reliability.
6. It achieves dramatic reduction in emission rates from new environmental control equipment and efficiency improvements. The resulting NO_x emission rate is reduced by 86 percent, while the CO₂ emission rate is reduced 37 percent.
7. It conserves fresh water resources by using waste water from the City of Lakeland, and reduces nitrogen loading to Tampa Bay.
8. It enables the potential integration of solar thermal renewable capacity and energy in the future.
9. The existing Polk Power Station site and supporting infrastructure for natural gas is uniquely compatible with Polk 2-5.
10. The transmission upgrade portion of the project will provide much needed infrastructure to reduce transmission congestion, improve grid reliability and reduce losses.

In summary, the selection of Polk 2-5 was supported by subsequent economic analyses of viable supply alternatives, demonstrating that Polk 2-5 is the most cost-effective option compared to other technologies and available supply capacity from the Florida market. After consideration of all existing, new and modified DSM programs and renewable energy initiatives, the construction of Polk 2-5 with a January 2017 in-service date should not be deferred. A two-year

deferral of the recommended plan could increase costs to customers by \$100 million. Tampa Electric also determined that fuel diversity is a key objective and the addition of natural gas combined cycle technology in 2017 still maintains a prudent balance in Tampa Electric's capacity and energy mix. Finally, when considering the viability of uncommitted resources, the risk of emerging environmental regulations, and the uncertainty of voluntary DSM programs, Polk 2-5 is needed as a firm resource within the FRCC region.

Polk 2-5 is the best of the "self-build" alternatives and provides significant savings of \$132.4 million to Tampa Electric's customers when compared to the second most cost-effective alternative in the RFP while providing additional benefits in the areas of reliability, fuel diversity, environmental impacts, and generating system efficiency. The results of these scenarios reinforce Tampa Electric's selection of Polk 2-5 as the best alternative for Tampa Electric and its customers.

II. INTRODUCTION AND IRP PROCESS OVERVIEW

A. Introduction

This Need Study supports Tampa Electric's petition to the Florida Public Service Commission ("Commission" or "FPSC") for an affirmative determination of need for the proposed Polk 2-5 NGCC rated at 459 MW summer and 463 MW winter net incremental capacity once the integration with the four existing simple cycle combustion turbines is completed by 2017. As required by Rule 25-22.081, F.A.C., Tampa Electric provides the information that will "allow the Commission to take into account the need for electric system reliability and integrity, the need for adequate reasonable cost electricity, the need for fuel diversity and supply reliability, the need to determine whether the proposed plant is the most cost-effective alternative available, and the need to determine whether renewable energy sources and technologies, as well as conservation measures, are utilized to the extent reasonably available." This information supports Tampa Electric's selection of Polk 2-5 as the most cost-effective, reliable, and fuel diverse option to meet its supply resource need in 2017.

The Need Study is composed of twelve major sections. Section I is an "Executive Summary" of Tampa Electric's overall IRP process and the results. Section II "Introduction and IRP Process Overview" provides a more detailed explanation of the company's IRP process and an explanation of the specific process used for this Need Study. Section III entitled "Background and Assumptions" provides a description of Tampa Electric's existing generating system and the assumptions, data, and information utilized. This includes demand and energy forecasts, fuel forecasts, environmental assumptions, financial assumptions and technology assumptions. Section IV "Need for Capacity in 2017" discusses the calculation of Tampa Electric's 2017 need including the impact of DSM load reduction and energy conservation programs. Section V describes the screening of potential supply technologies and results

and Section VI includes the detailed economic analysis where the supply alternatives were narrowed based on feasibility and evaluated in greater detail. Section VI also includes qualitative factors that were considered in the selection of Polk 2-5. Section VII describes sensitivity cases and results related to fuel pricing, demand and energy, and construction costs. Section VIII describes the RFP process and results. Section IX describes Polk 2-5 in detail including design, permitting, location, cost and schedule, Section X examines the results with updated assumptions, and Section XI describes the adverse consequences if Polk 2-5 is not approved or is delayed. Finally, Section XII provides the conclusions of the Need Study.

B. Tampa Electric's Integrated Resource Planning Process

Tampa Electric's IRP process, which is the basis of the selection of Polk 2-5, is a planning process that determines the timing, type, and amount of additional demand reduction, energy conservation and supply resources required to maintain system reliability in a cost-effective manner. The process considers the existing customer demand and energy mix, expected growth and changes in the customer demand and energy requirements, existing and future DSM and energy conservation programs, existing Tampa Electric generating units and purchased power, future traditional and renewable supply resources, existing and future bulk transmission system for Tampa Electric and the Florida grid, and potential renewable energy resources appropriate for the Florida energy market. The process used to develop the Polk 2-5 Need Study was conducted as an integral component of Tampa Electric's ongoing IRP process. The primary steps in the process include:

1. Identify additional DSM load reduction alternatives and cost-effective energy conservation alternatives to reduce demand and energy requirements utilizing avoided costs from an initial resource plan;

2. Forecast demand and energy including the impact of existing and potential demand alternatives;
3. Identify the amount and timing of Tampa Electric's incremental resource needs to maintain system reliability criteria;
4. Identify the types of technologies that have the greatest potential for meeting the required resource need and perform an initial economic screen.
5. Conduct detailed economic analysis and consider non-economic factors to decide on the best supply alternatives;
6. Conduct sensitivity analyses to evaluate the impact of potential load forecast and economic variations;
7. Conduct an RFP process and/or business plan development as required based on the recommended resource plan.
8. Incorporate any updated assumptions and confirm the recommended resource plan.
9. Based on the recommended resource plan, determine the avoided costs for deferral of supply resources and implement additional cost-effective DSM resources in the next business planning cycle.

III. BACKGROUND AND ASSUMPTIONS

A. Description of Tampa Electric's System

Tampa Electric, an investor-owned electric utility, is the largest subsidiary of TECO Energy. The service area for Tampa Electric spans approximately 2,000 square miles and consists of Hillsborough County, western Polk County and parts of Pasco and Pinellas counties. Tampa Electric served approximately 676,000 customers in 2011. Tampa Electric has three large generating stations and one peaking station that include fossil steam units, combined cycle units, combustion turbine peaking units, aero-derivative engine units, diesel engine units and an integrated coal gasification combined cycle unit.

Big Bend Power Station: The station contains four pulverized coal-fired steam units equipped with additional environmental controls including selective catalytic reduction, de-sulfurization scrubbers, and electrostatic precipitators. Big Bend Power Station also contains one dual fuel (natural gas or oil), quick-start (full load in less than 15 minutes) aero-derivative peaking unit that could provide black-start capability for the station and the system.

H. L. Culbreath Bayside Power Station: The station contains two natural gas-fired combined cycle units and four quick-start aero-derivative peaking units with black-start capability. Bayside Unit 1 utilizes three combustion turbines, three HRSGs and one steam turbine. Bayside Unit 2 utilizes four combustion turbines, four HRSGs and one steam turbine. Bayside Units 3 through 6 are natural gas-fired aero-derivative peaking units that are quick-start and provides black-start capability for the station and the system.

Polk Power Station: Polk Power Station includes one base load and four peak load generating units. Polk Unit 1 is a dual fuel integrated gasification combined cycle (“IGCC”) unit primarily fired with synthesis gas produced from a blend of low-sulfur coal and petroleum coke (“petcoke”). Distillate oil is a secondary fuel which is used for both start-up and shut-down of the power block, and can be used to operate the combined cycle at times when the gasification system is unavailable. Polk Units 2 through 5 are simple cycle combustion turbines primarily fired by natural gas, and Units 2 and 3 are capable of firing distillate oil as a secondary fuel.

J. H. Phillips Sebring Power Station: Phillips Sebring Power Station includes two diesel oil-fired peaking units located in Sebring, Florida.

These two units were placed on long-term reserve stand-by (“LTRS”) status on September 4, 2009 due to the relative higher cost of heavy oil compared to natural gas and coal. These units will remain on LTRS until the operating costs are competitive with other supply resources. These units also have the potential to utilize liquid biofuels and operate as a renewable energy resource in the future.

Other Facilities: Tampa Electric owns two 3 MW diesel engines converted to use natural gas located at the City of Tampa’s McKay Bay Refuse to Energy Facility.

The following table lists Tampa Electric’s generating assets as of January 1, 2012.

Table 1: Tampa Electric System Installed Capacity

Plant Name	Number of Units	Summer Net MW	Winter Net MW
Big Bend Power Station	5	1608	1643
Bayside Power Station	6	1854	2083
Polk Power Station	5	824	952
Phillips Sebring Power Station ¹	2	36	36
Other Facilities	2	6	6
TOTAL	20	4,292	4,684

1. Transmission and Distribution

Tampa Electric’s transmission and distribution system is comprised of 219 substations, 1,322 miles of transmission and 10,998 miles of distribution lines. Tampa Electric’s transmission system is interconnected to the Florida

¹ Phillips Sebring Power Station was placed on long-term standby on September 4, 2009 and net capacities are not included in the system total.

transmission grid through ties with Lakeland Electric, Florida Power & Light, Orlando Utilities Commission, Seminole Electric Cooperative, and Progress Energy Florida.

2. Firm Purchased Power Capacity

Tampa Electric currently has a number of firm purchased power agreements (“PPA”) with cogeneration facilities, other investor-owned utilities and merchant power providers. Listed below are long term purchase power contracts for capacity and energy ordered by expiration date:

- 441 MW winter and 356 MW summer from the Hardee Power Station through December 2012.
- 23 MW Non-Utility Generator Orange Cogen through December 2015.
- 160 MW from Southern Power from January 2013 through December 2015. Tampa Electric has an option to extend.
- 117 MW from Auburndale Peaking Energy Center through December 2016.
- 121 MW from the Pasco Cogen facility through December 2018.

Tampa Electric expects 499 MW of cogeneration capacity in its service area in 2012. Self-service capacity of 268 MW is used by cogenerators to serve internal load requirements, 23 MW are purchased by Tampa Electric on a firm contract basis, and 19 MW are purchased on a non-firm, as-available basis. The remaining 189 MW of cogeneration capacity is exported out of Tampa Electric’s system.

3. Demand-Side Management

DSM is the planning, development, implementation, monitoring and evaluation of energy conservation and load management programs designed

to cost-effectively reduce customers' peak demand and overall energy consumption on the company's system. Tampa Electric measures the cost-effectiveness of DSM programs by using the Commission-approved methodology. The methodology consists of three tests: the Rate Impact Measure ("RIM") Test, the Participants' Test and the Total Resource Cost ("TRC") Test.

Tampa Electric has long been a leader in offering its customers cost-effective DSM programs coupled with a comprehensive educational emphasis on the wise use of energy. This effort began in the mid-1970s when Tampa Electric offered its first DSM program, the Energy Answer Home, to curb heating and air-conditioning requirements in new homes by encouraging the use of high-efficiency heat pumps instead of conventional air-conditioning with resistance heating. Within two years, the company introduced a computer-based home energy audit well in advance of the legislation that ultimately required this level of home energy analysis.

In 1980, the Florida Energy Efficiency Conservation Act ("FEECA") was passed by the Florida legislature. In response to that legislation, Tampa Electric filed its DSM plans with the Commission and became the first Florida utility to have its DSM programs for both residential and commercial customers approved. Subsequent to that first DSM plan, Tampa Electric has filed and gained Commission approval of numerous DSM programs designed to promote new energy-efficient technologies to encourage energy savings. Additionally, the company has modified existing DSM programs over time to promote new technologies and maintain program cost-effectiveness.

Through 2011, Tampa Electric's successful DSM initiatives have achieved 719 MW of winter peak demand reduction, 306 MW of summer peak demand

reduction and 770 GWH of annual energy savings. Peak load reduction has eliminated the need for the equivalent of four 180 MW power plants.

Furthermore, Tampa Electric's DSM program results compare quite favorably to other utilities across the nation. The Energy Information Administration ("EIA") of the United States Department of Energy ("DOE") reports annually on the effectiveness of utility DSM initiatives. Based on national data reported for the last decade, Tampa Electric ranked as high as the 89th percentile for cumulative conservation and the 85th percentile for load management achievements. Also, of the eight regional entities of NERC, the FRCC ranks third in terms of DSM as a percentage of regional peak.

4. Renewable Energy

Tampa Electric continues to be active in supporting the development of renewable energy resources. The company recognizes renewable energy will advance the utilization of a diverse fuel mix for the production of electricity and the company will demonstrate sound environmental stewardship. Tampa Electric has actively evaluated various renewable energy developers over the years, and continues to investigate ways to structure agreements with consideration of the FPSC avoided cost standard.

Tampa Electric's renewable Standard Offer Contract ("SOC") includes the following features: 1) the customer can select any of the fossil fuel generating units in the company's 10-year expansion plan; 2) the renewable SOC is continuously available; 3) there is no subscription limit; 4) the renewable generator can select the term of the contract; and 5) flexibility on capacity and energy payments to the customer.

5. Tampa Electric's Current Energy and Capacity Mix by Fuel Type

The energy and capacity mix for Tampa Electric's generation can significantly affect the cost of electricity. Too much reliance on fuel types with volatile fuel prices can result in significant volatility in the ultimate cost of electricity. Tampa Electric's fuel type mix to meet system demand and energy requirements for 2011 actuals and projections for 2017 are shown below.

Table 2: Tampa Electric's Energy Mix by Fuel Type

	2011	2017
Total System	Actual	Forecast
Solid Fuel	56%	59%
Natural Gas	43%	39%
Oil / Other	1%	2%
System Net Energy for Load (GWH)	19,325	20,772

Table 3: Tampa Electric's Capacity Mix by Fuel Type

	2011	2017
Total System	Actual	Forecast
Solid Fuel	36.1%	36.3%
Natural Gas	63.9%	63.7%
Oil / Other	0%	0%
System Capacity (MW)	4,909	4,856

B. Assumptions

Demand and Energy Forecasts - The customer demand and energy forecast is the foundation of the integrated resource plan. Tampa Electric utilizes multiple databases and sophisticated analytical tools and methods to develop the forecast. The primary objective of this procedure is to blend proven statistical

techniques with practical forecasting experience to develop the most probable demand and energy forecast over a 20-year planning period.

1. Forecast Assumptions

The economic assumptions used in the forecast models are derived from forecasts from Economy.com (Moody's Analytics) and the University of Florida's Bureau of Economic and Business Research ("BEBR"). Numerous assumptions entered into the MetrixND models, an advanced statistics program for analysis and forecasting, of which the more significant ones are listed below.

Population and Households

The population forecast is the starting point for developing the customer and energy projections. BEBR and Economy.com supply population projections for Hillsborough County and Florida. The population forecast is based upon the projections of BEBR in the short term and a blend of BEBR and Economy.com in the long term. Through 2021, the average annual population growth rate for Hillsborough County is expected to be 1.4 percent. In addition, Economy.com provides household data as an input to the residential average use model.

Commercial, Industrial and Governmental Employment

Commercial and industrial employment assumptions are utilized in computing the number of customers in their respective sectors. Over the next ten years, commercial employment is projected to rise at a 2.3 percent average annual rate and industrial employment is projected to decline slowly at an annual rate of -1.2 percent. Government employment is used in combination with government output to estimate energy sales to public authorities. Economy.com projects government employment to rise at a 0.7 percent average annual rate.

Commercial, Industrial and Governmental Output

In addition to employment, output in terms of real gross domestic product by employment sector is utilized in computing energy usage by sector. Over the next ten years Economy.com projects output for the entire employment sector to rise at a 3.4 percent average annual rate.

Real Household Income

Economy.com supplies the assumptions for Hillsborough County's real household income growth. During 2012-2021, real household income for Hillsborough County is expected to increase at a 2.9 percent average annual rate.

Price of Electricity

Forecasts for the price of electricity by customer class are supplied by Tampa Electric's Regulatory Affairs department. The price of electricity is included in each per-customer consumption model. The price variable was primarily used to capture long term impacts of the real price of electricity.

Appliance Efficiency Standards

Another factor influencing energy consumption is the movement toward more efficient appliances. The forces behind this development include market pressures for more energy-saving devices and the appliance efficiency standards enacted by the state and federal governments.

Also influencing energy consumption is the saturation levels of appliances. The saturation trend for heating appliances is increasing through time; however, overall electricity consumption actually declines over time as less efficient heating technologies such as room heating and furnaces are replaced with more efficient technologies such as heat pumps. Similarly,

cooling equipment saturation will continue to increase, but is offset by heat pump and central air conditioning efficiency gains.

Improvements in the efficiency of other non-weather related appliances also helps to lower electricity growth; however, any efficiency gains are offset by the increasing saturation trend of electronic equipment and appliances.

Weather

Since weather is the most difficult input to project, historical data is the major determinant in developing temperature profiles. Monthly profiles used in calculating energy consumption are based on twenty years of historical data. In addition, the temperature profiles used in projecting the winter and summer peak are based on an examination of the minimum and maximum temperatures for the past twenty years and the temperatures on peak days for the past twenty years.

High and Low Economic Sensitivities

The base case sensitivity is tested for sensitivity to varying economic conditions and customer growth rates. The high and low peak demand and energy sensitivities represent alternatives to the company's base case outlook. Compared to the base case, the expected economic growth rates are 0.5 percent higher in the high sensitivity and 0.5 percent lower in the low sensitivity. High and Low firm peak demands are shown in Appendix F.

2. Forecast Methodology

MetrixND was used to develop customer, demand and energy forecasts. The software provides a platform for the development of dynamic and fully

integrated models. The phosphate demand and energy is forecasted separately and then combined in the total forecast. Likewise, the effect of Tampa Electric's conservation, load management, and cogeneration programs is incorporated into the process by subtracting the expected reduction in demand and energy from the forecast.

Customer Forecast Models

The customer multi-regression forecasting model is a seven-equation model. The equations forecast the number of customers by seven major categories.

Residential Customer Model

Customer projections are a function of Hillsborough County's population. Since a strong correlation exists between historical changes in customers and historical changes in the county's population, Hillsborough County population estimates for 2012-2021 were used to forecast the future growth patterns in residential customers.

Commercial Customer Model

Total commercial customers include commercial customers and temporary service customers (temporary poles on construction sites); therefore, two models are used to forecast total commercial customers. The commercial customer model is a function of residential customers. An increase in the number of households provides the need for additional services, restaurants, and retail establishments. The amount of residential activity also plays a part in the attractiveness of the Tampa Bay area as a place to relocate or start a new business. Projections of employment in the construction sector are a good indicator of expected increases and decreases in local construction activity. Therefore, the temporary service model projects the number of customers as a function of construction

employment.

Industrial General Service Customer Model

Industrial customers include two rate classes that have been modeled individually: General Service (“GS”) and General Service Demand (“GSD”). The GS customer model is a function of Hillsborough County commercial employment.

Industrial GSD Customer Model

The industrial GSD customer model is a function of recent growth trends in the sector.

Public Authority Customer Model

Customer projections are a function of Hillsborough County’s population. The need for public services will depend on the number of people in the region; therefore, consistent with the residential customer model, county level population projections are used to determine future growth in the public authorities sector.

Street & Highway Lighting Customer Model

Recent growth trends in this sector are the basis for the street & highway lighting customer model.

3. Energy Forecast Models

There are a total of seven energy models. All of these models represent average usage per customer (kWh/customer), except for the Temporary Services model which represents total kWh sales. The average usage models interact with the customer models to arrive at total sales for each class.

The energy models are based on an approach known as Statistically Adjusted Engineering (“SAE”). SAE entails specifying end-use variables, such as heating, cooling and base use appliance/equipment and incorporating these variables into regression models. This approach allows the models to capture long term structural changes that end-use models are known for, while also performing well in the short term, as do econometric regression models.

Residential Energy Model

The residential forecast model is made up of three major components: (1) the end-use equipment index variables, which capture the long term net effect of equipment saturation and equipment efficiency improvements; (2) the second component serves to capture changes in the economy such as household income, household size, and the price of electricity; and (3) the third component is made up of weather variables, which serve to allocate the seasonal impacts of weather throughout the year.

Commercial Energy Model

The model framework for the commercial sector is the same as the residential model; it also has three major components and utilizes the SAE model framework. The differences lie in the type of end-use equipment and in the economic variables used. The end-use equipment variables are based on commercial appliance/equipment saturation and efficiency assumptions. The economic drivers in the commercial model are commercial productivity measured in terms of dollar output and the price of electricity for the commercial sector. The third component, weather variables, is the same as in the residential model.

Temporary Service Energy Model

The model is a subset of the total commercial sector and is a rather small percentage of the total commercial sector. Although small in nature, it is

still a component that needs to be included. A simple regression model is used with the primary driver being temporary service customer growth.

Industrial-GS Energy Model

Industrial energy forecasts include two rate classes that have been modeled individually: GS and GSD. The Industrial-GS energy model utilizes the same SAE model framework as the commercial energy model. The weather component is consistent with the residential and commercial models.

Industrial-GSD Energy Model

The GSD model is based on industrial employment, the price of electricity in the industrial sector, cooling degree-days and the number of days billed. Unlike the previous models discussed, heating load does not impact this sector.

Public Authority Sector Model

Within this model, the equipment index is based on the same commercial equipment saturation and efficiency assumptions used in the commercial model. The economic component is based on government sector productivity and the price of electricity in this sector. Weather variables are consistent with the residential and commercial models.

Street & Highway Lighting Sector Model

The street and highway lighting sector is not impacted by weather; therefore; it is a rather simple model and the SAE modeling approach does not apply. The model is a linear regression model where street & highway lighting energy consumption is a function of the number of billing

days in the cycle, and the number of daylight hours in a day for each month.

The energy models described above plus an exogenous interruptible and phosphate forecast are added together to arrive at the total retail energy sales forecast.

4. Demand Forecast Models

After the total retail energy sales forecast is complete, it is integrated into the peak demand model as an independent variable along with weather variables. The energy variable represents the long term economic and appliance trend impacts. The volatility of the phosphate load is removed to stabilize the peak demand data series and improve model accuracy. To further stabilize the data, the peak demand models project on a per customer basis.

The weather variables provide the monthly seasonality to the peaks. The weather variables used are heating and cooling degree days for both the temperature at the time of the peak and the 24-hour average on the day of the peak. By incorporating both temperatures, the model is accounting for the fact that cold/heat buildup contributes to determining the peak day.

The non-phosphate per customer kW forecast is multiplied by the final customer forecast. This result is then aggregated with a phosphate coincident peak forecast to arrive at the final projected peak demand.

Phosphate Demand and Energy Forecasts

Because Tampa Electric's phosphate customers are relatively few in number, each customer's energy consumption is forecasted individually

based on historical usage patterns and detailed information obtained by customer surveys. The Commercial/Industrial Customer Service department's familiarity with industry dynamics, their close working relationship with phosphate company representatives and the surveys are used to determine future energy and demand requirements. This survey is the foundation upon which the phosphate forecast is based, and further inputs are provided by trend analysis of historical usage patterns.

Demand-Side Management and Cogeneration Forecasts

Tampa Electric incorporates the impacts of conservation, load management and cogeneration programs into the demand and energy forecasts. This is done by reducing the forecasts by the incremental annual savings associated with conservation and load management programs. In addition, demand and energy projections are adjusted for any projected incremental changes in cogeneration programs that impact the amount of capacity and energy Tampa Electric provides to these customers.

Wholesale Load

Tampa Electric's long-term firm sales are served through contracts with the City of St. Cloud. Future sales for a given year are based on the specific terms of their contracts with Tampa Electric. The City of St. Cloud contract will expire December 31, 2012.

5. Demand and Energy Forecasts

The analysis that resulted in the selection of Polk 2-5 incorporated the June 2011 base demand and energy forecast. In June 2012, an updated demand and energy forecast was completed.

Customer Forecasts

Based on the Demand and Energy forecast, Tampa Electric is projecting an annual average increase of 9,597 new customers over the next ten years from 2012-2021. This average annual increase of 1.3 percent is slightly lower than the average annual growth rate of 1.5 percent during the past ten years from 2002-2011. The number of retail customers by customer class are shown in Appendix C.

Retail Energy Sales Forecasts

The primary driver behind the increase in the energy sales forecast is the average annual increase in customers of 1.3 percent. In addition, average per-customer consumption is expected to decrease at an average annual rate of 0.5 percent. Combining the growth in customers and decline in per-customer consumption, retail energy sales are expected to increase at an average annual rate of 0.8 percent. Excluding the phosphate sector, which has recently been declining, retail energy sales are expected to increase at an average annual rate of 1.0 percent. The amount of retail energy sales by customer class are shown in Appendix D.

Retail Peak Demand Forecasts

Summer and winter retail peak usage per-customer is projected to decrease at an average annual rate of 0.4 percent, which is consistent with historical growth rates as well as per-customer energy consumption. The increase in customers and the decrease in per-customer demand results in an average annual growth rate of 1.0 percent for the winter peak and a 0.9 percent growth rate for the summer peak. Total peak demand for the summer 2012 is forecasted to be 3,993 MW and increase to 4,331 MW in 2021, an average increase of 38 MW per year. The 2012 winter peak was forecasted to be 4,081 MW and increase to 4,453 MW in 2021, an average increase of 41 MW per year. Winter and summer total and firm peak demands are shown in Appendix E. High and low winter and

summer firm peak demands are calculated for high and low economic sensitivities and are shown in Appendix F.

June 2012 Customer, Demand and Energy Update

An updated forecast of customers, demand and energy was completed in June of 2012 as part of Tampa Electric's annual planning process. The most current forecast of customers is higher than the forecast presented in the Need Determination Study. However, the current energy sales and peak demand forecasts are lower than the forecasts presented in the Need Study. The primary factor that is driving the changes in the load forecasts is the slower than expected economic recovery and continued reduction in per-customer consumption. The updated retail peak demands are shown in Appendix G.

C. Fuel Forecast

Annual fuel price forecasts developed for the 2012 Fuel and Purchased Power Cost Recovery Clause projection filing and the 2012 Ten Year Site Plan filing were used to analyze supply alternatives for the 2017 need. The coal and natural gas forecasts are provided in Appendix H. These fuel price forecasts were utilized in the detailed economic analysis. Tampa Electric also prepared low and high price forecasts for the sensitivity analyses which are provided in Appendix I and Appendix J, respectively.

Tampa Electric developed a 30-year fuel price forecast utilizing published market pricing indexes and long-term forecasts from independent energy consultants. Refinements were made to the market indexes or consultant prices to align the forecasts to Tampa Electric's physical quality requirements and/or receipt location. For example, most natural gas forecasts are based on the Henry Hub, a recognized market center for trading natural gas. Since much of the natural gas Tampa Electric purchases is delivered into Zone 3 of the Florida Gas

Transmission (“FGT”) pipeline, Tampa Electric’s natural gas price reflects the typical price difference between Henry Hub and FGT Zone 3.

1. Natural Gas

The foundation for the natural gas price forecast is the 10-year New York Mercantile Exchange (“NYMEX”) natural gas futures monthly contract closing prices for the five consecutive business days between July 5, 2011 and July 11, 2011. Since the NYMEX natural gas futures contract is based on physical delivery of natural gas to the Henry Hub in southern Louisiana, Tampa Electric adds a “basis” cost to account for the company receiving its natural gas delivered into FGT Zone 3 instead of into the Henry Hub. This establishes the first 10 years of the forecast. The remaining twenty years of the natural gas forecast are derived by escalating the prior year’s price by the projected annual escalation of the Consumer Price Index Less Energy.

2. Solid Fuels

The foundation of the coal price forecast is a combination of various published index prices for like-quality coal for the first two to four years. The publications include Coal Daily and ICAP, an online energy broker and information service. For the subsequent years through 2018, a weighted average price is developed using Argus Coal Daily and index prices, along with the coal prices from an independent, published forecast from Wood Mackenzie Energy Consultants (“Wood Mac”). The company utilizes a weighted average method where Tampa Electric’s final coal forecast blends the published market indices with the Wood Mac forecast. The market indices are a high percentage of the blend in the near term and Wood Mac is a low percent. Over time the market indices percentage decreases until the Wood Mac forecast is 100

percent of the forecasted price. Beyond 2018 the coal commodity price is escalated annually consistent with the escalation of the other commodities.

3. Transportation

Tampa Electric has bi-modal transportation to receive fuel for the five solid fuel units, and convey coal to Big Bend Power Station and utilize trucking to deliver blended low sulfur coal and petcoke to the Polk Power Station. Tampa Electric can receive its entire coal supply from either water transportation or rail transportation. These bi-modal transportation services provide reliability and cost-effectiveness.

For natural gas transportation, Tampa Electric has long-term firm pipeline capacity reserved on the FGT pipeline and the Gulfstream Pipeline Company, LLC (“Gulfstream”) pipeline. Both the Bayside Power Station and the Polk Power Station are listed as Primary Delivery Points on the FGT Firm Service Agreement which allows for flexible and reliable delivery of natural gas to either station using the same agreement. Also, Bayside Power Station and Big Bend Power Station are connected to both FGT and Gulfstream. Thus, depending on conditions, Tampa Electric can deliver natural gas via different pipelines to different plants.

4. Fuel Price Forecasts

The fuel commodity prices used for the Need Determination Analysis are shown in the following table:

Tampa Electric Fuel Prices Forecast 2013 - 2040			
Year	Natural Gas \$/MMBtu	No. 2 Oil \$/Gallon	Illinois Basin Coal \$/ton
2013	\$5.12	\$3.33	\$55.57
2014	\$5.39	\$3.51	\$56.45
2015	\$5.67	\$3.69	\$58.88
2016	\$5.95	\$3.88	\$55.48
2017	\$6.23	\$4.06	\$55.24
2018	\$6.51	\$4.24	\$52.26
2019	\$6.79	\$4.42	\$55.94
2020	\$7.07	\$4.60	\$59.64
2021	\$7.34	\$4.78	\$63.20
2022	\$7.63	\$4.97	\$66.81
2023	\$7.80	\$5.08	\$69.16
2024	\$7.97	\$5.19	\$71.55
2025	\$8.14	\$5.30	\$73.96
2026	\$8.31	\$5.41	\$76.40
2027	\$8.49	\$5.53	\$78.85
2028	\$8.67	\$5.64	\$81.35
2029	\$8.85	\$5.76	\$83.89
2030	\$9.03	\$5.88	\$86.48
2031	\$9.22	\$6.00	\$89.11
2032	\$9.41	\$6.13	\$91.79
2033	\$9.61	\$6.26	\$94.52
2034	\$9.80	\$6.38	\$97.31
2035	\$10.01	\$6.52	\$100.14
2036	\$10.21	\$6.65	\$103.03
2037	\$10.42	\$6.79	\$105.97
2038	\$10.64	\$6.93	\$108.97
2039	\$10.85	\$7.07	\$112.03
2040	\$11.08	\$7.21	\$115.15

Figure 1: Fuel Forecast for Final Analysis

D. Environmental

Environmental requirements considered in Tampa Electric's analysis of supply alternatives include environmental permitting requirements which are defined by current environmental regulations and planning for future environmental requirements. Environmental permitting requirements are often well established by the permitting of similar units and/or through

interpretation of existing regulations. An example is the expected Polk 2-5 environmental permitting requirements discussed in Section VII.C.

Future environmental requirements include currently promulgated rules that have future requirements defined, currently promulgated rules that have future requirements undefined and potential environmental requirements that are currently being considered in federal and/or state legislature. The primary requirements considered by Tampa Electric in this study include future water restrictions in the Southwest Florida Water Management District (“SWFWMD”) Southern Water Use Caution Area (“SWUCA”), Mercury Air Toxic and Standards (“MACT”), Clean Air Interstate Rule (“CAIR”), Green House Gas New Source Performance Standards (“GHGNSPS”), New Source Performance Standards (“NSPS”), and 316 (b).

E. General Financial Assumptions

In addition to the fuel, load, environmental and other assumptions described, Tampa Electric utilized certain financial assumptions to conduct its detailed economic analysis. Major financial assumptions used in the Ten Year Site Plan (“TYSP”) analysis include:

- Discount rate of 7.95 percent;
- Tax rate of 38.575 percent;
- Property tax of 1.27 percent;
- Escalation rate for capital expenditures of 3.0 percent;
- Escalation rate for fixed and variable O&M of 2.4 percent; and
- AFUDC rate of 8.16 percent.

F. Technology Assumptions

1. Demand Side Programs

Tampa Electric's current DSM plan consists of 30 comprehensive residential, commercial, and industrial programs which provide customers with a variety of program offerings to better manage their energy consumption. Tampa Electric reviews its existing DSM programs for cost-effectiveness and examines the potential for new offerings and program modifications on an annual basis. Appendix A and Appendix B contain a listing of Tampa Electric's current residential and commercial DSM programs, respectively.

2. Supply Technologies

Solid Fuel Technologies

In the screening process, Tampa Electric considered all feasible technologies including IGCC, super-critical pulverized coal ("SCPC"), and circulating fluidized bed combustion ("CFB"). These technologies were evaluated as base load power derived from a blend of bituminous coal that meets current emission standards and limits. Solid fuel technologies typically are characterized as higher construction cost with traditionally lower operating costs when compared to natural gas technologies. The current and near term projections of natural gas prices have reduced operating costs of natural gas technologies compared to solid fuel technologies.

Natural Gas Technologies

Tampa Electric considered a number of natural gas technologies including simple cycle combustion turbine and combined cycle alternatives. The simple cycle combustion turbines ranged from GE 7FA type units to more modern GE LMS100 type units. The combined cycle units considered included 2x1 GE 7FA type units, 2x1 M501G units and the Polk Power Station repower

project involving four HRSGs and a single steam turbine or four HRSGs and two steam turbines.

In comparison to other generating technologies, NGCC technologies are typically characterized by relatively lower capital costs, low heat rates and low environmental emissions. The same combustion turbines implemented in simple cycle configurations are characterized by lower capital costs, higher heat rates than combined cycle technologies and typically higher emission rates. The primary reason for the differences between combined cycle and simple cycle efficiencies is the recovery of exhaust heat from the combustion turbine in the combined cycle configuration.

Other Technologies

Renewable technologies tend to have lower or no fuel costs but have significant fixed costs. In addition, technologies such as geothermal and hydroelectric have limited practical application in Florida. Similarly, wind and solar have limited and unpredictable operating hours due to the intermittent nature of their energy source. In the absence of stored energy capability, intermittent renewables are best considered as energy resources and not as firm capacity for planning purposes. However, some renewable energy such as biomass can be considered as a firm resource if sufficient biomass material is stored and available.

IV. NEED FOR CAPACITY IN 2017

A. Reliability Assessment

Tampa Electric utilizes a twenty percent firm reserve margin reliability criteria above the system firm peak, as required by the Florida Public Service Commission (“Commission” or “FPSC”) in Order No. PSC-99-2507-S-EU issued on December 22, 1999, and a minimum seven percent supply reserve margin.

The firm reserve margin consists of both supply and non-firm demand resources to maintain an allowance for unexpected variances in system demand, generating unit availability, and purchased power availability and deliverability. The minimum supply reserve margin criterion maintains an important qualitative component of firm reserves for reliability purposes to minimize the impact of the loss of a supply resource at the time of peak. If the firm reserve margin consisted of only non-firm demand reserves (whereby total firm supply equals total load), then the frequency of use of demand resources in a given year would increase significantly. The firm system peak is determined by including all firm wholesale agreements and excluding non-firm customer demand from the total system demand. Non-firm demand includes all interruptible service customers and customer load reduction programs. Customers who continue to participate in these voluntary programs help defer the need for additional supply resources by reducing firm peak demands. These customers may request to become a firm customer or be excluded from a DSM program with appropriate notification.

Utilizing the June 2011 Tampa Electric demand and energy forecast, a reliability analysis determined the amount of any incremental resources needed to maintain a 20 percent margin above the winter and summer system firm peaks. The seasonal system firm peaks include firm retail load and firm wholesale load and exclude all non-firm retail load and as-available wholesale load. The minimum reserve margin for each year is calculated by multiplying the seasonal system firm peak by 20 percent. The net available capacity is determined by combining all installed generating capacity and firm power purchases less the seasonal system firm peak. If the net available capacity is less than the firm reserve margin in any year, incremental capacity is added in that year to achieve the minimum reserve margin requirement. Incremental capacity identified in a given year is included in subsequent years in order to determine the discrete incremental capacity required in each subsequent year.

1. Demand-Side Management

Tampa Electric conducted an extensive evaluation of all conservation measures reasonably available. The company's current 2010-2019 DSM goals were established utilizing a comprehensive set of DSM measures. Through the company's efforts, these goals are being exceeded. Tampa Electric has identified all reasonably achievable DSM demand and energy reductions in its Need Study. There are no DSM alternatives that will cost-effectively defer the need for additional generating capacity in 2017.

B. Tampa Electric's Reliability Assessment Results

The results of the 2012 TYSP final reliability assessment indicate that Tampa Electric will have a summer 2017 need of 294 MW. Table 3 identifies the firm peak demand of 3,940 MW in the summer of 2017 and illustrates the addition of the 20 percent reserve margin requirement to the firm peak to determine the total firm capacity requirement. Tampa Electric's 2017 summer total firm capacity requirement is 4,728 MW. Tampa Electric's net available firm capacity is subtracted from the total firm capacity requirement to determine the summer 2017 incremental capacity need of 294 MW. Details for each year are shown in Appendix K.

Table 4: 2017 Firm Peak Requirements

	Summer 2017 (MW)
Forecasted Firm Retail	3,940
Forecasted Firm Wholesale	<u>0</u>
Total Firm Peak Demand	3,940
Total Firm Capacity Required for 20% Reserve Margin	4,728
Net Available Firm Capacity	<u>4,433</u>
Incremental Capacity Needed¹	294

The reliability analysis was based on existing generating unit operating data and projected system firm peak and energy requirements which were developed in summer 2011. This data supported the development of Tampa Electric's 2012 TYSP filed with the Commission in April 2012. This analysis indicated incremental supply resources are needed in 2017 to meet the 20 percent reserve margin criteria and 7 percent minimum supply criteria. Without additional firm supply resources the summer firm reserve margin is 12.5 percent and the supply component would fall to 6.8 percent in summer 2017.

C. FRCC Reliability Assessment Results

Tampa Electric specific data in conjunction with similar information from other Florida electric utilities is included in the aggregate 2012 FRCC Load and Resource Plan. The FRCC shows that the existing planned demand and supply resource additions by Florida utilities will meet the minimum reliability of 15 percent through 2021, as shown in Appendix M. However, the initial reliability assessment should remove all planned and proposed unit additions and review potential modifications to existing generating capacity.

¹ May not add due to rounding

In addition, the FRCC has analyzed the increasing dependency on DSM programs to provide these reserves. During the 2012 FRCC TYSP workshop on August 13, 2012, it was reported that of the eight NERC reliability regions, the FRCC is among the highest in DSM as a percentage of regional peak. This increased dependency on DSM programs combined with the uncertainty of planned yet uncommitted supply additions as well as existing resources at risk of retirement due to emerging environmental regulations or other factors raise questions regarding future reserve margin calculations. If future additions do not materialize and some existing resources in the region are retired in response to costly mandatory retrofits, the FRCC reserve margin could drop below the minimum required from 2016 through 2019. This sensitivity analysis is reflected in Appendix N. When considering the viability of uncommitted resources, the risk of emerging environmental regulations, and the uncertainty of voluntary DSM programs, firm resources are needed within the FRCC region toward the end of the decade.

V. SCREENING OF POTENTIAL TECHNOLOGIES

Electric utilities have a wide range of potential supply technologies which may be considered for future load requirements. Tampa Electric conducted an initial screening of potential supply technologies (including solid fuel, natural gas fired and renewable resources), based on economic viability and qualitative factors such as technical feasibility, commercial availability, construction timing, and environmental impacts and permitting.

Tampa Electric's supply analysis was conducted first through a qualitative and quantitative screening followed by updated economic analysis.

The screening step is intended to narrow the range of alternatives to focus on the most viable options. Then Tampa Electric conducted a detailed analysis to

determine the selection of the most cost-effective option. The objective of the screening was to determine the most viable and applicable technologies for further analysis. The first step in the screening process was a qualitative screening which relied on widely accepted information sources such as the DOE and trade publications, along with engineering judgment, to assess the viability of various technologies. Further screening was conducted using quantitative screening methods by means of a comparison of the levelized total cost (\$/kW-yr) for technologies not screened out in the qualitative analysis. This financial parameter considers fuel costs, heat rates, outage rates, and capacity of the generating unit to calculate the nominal cost per unit of capacity for a given operating capacity factor. The primary technology assumptions are shown in Appendix O.

A. Qualitative Screening

Traditional technologies and renewable technologies including wind, solar and biomass were included in the initial screening. Tampa Electric has experience utilizing a diverse range of fuels, including, coal, oil, gas, and biomass, and is always searching for the best option with which to reliably meet our customer need for power.

Renewable technologies, such as wind and solar were looked at as one option to meet our 2017 need. However, the siting difficulty along with inability to meet the requirement for firm capacity eliminated these as viable options for Tampa Electric. It is important to note that Tampa Electric currently employs use of solar power at a number of sites in our service territory and that we continue to evaluate opportunities and proposals on renewable technologies as they fit into our portfolio, while also continuing to maintain our system reliability.

Biomass was also considered as an option. Tampa Electric periodically purchases renewable energy from biomass energy producers in support of its renewable energy program. Tampa Electric secures renewable energy from

technologies such as landfill gas generation and energy from the waste of exothermic processes. Tampa Electric also encourages additional renewable energy through its renewable standard offer contract approved by the Commission.

Other technologies such as ocean thermal and tidal are not considered commercially available, and there are no significant geothermal sources in Florida. Finally, there are no fuel cells of sufficient size commercially available to offset the 2017 need.

Qualitatively, solid fuel based units were also considered. Siting for solid fuel based units require more than five years to permit and construct. A solid fuel unit would not be able to be in service by the company's target date in 2017, and could possibly put the reliability of Tampa Electric's system in jeopardy of not meeting customer needs.

B. Quantitative Screening

As part of the initial screening process, Tampa Electric performed a more detailed economic evaluation of the viable technologies available. In this step of Tampa Electric's analysis, the levelized annual cost of each technology was calculated and compared at various capacity factors. The screening curves below illustrate the cost of these technologies over a range of capacity factors.




Figure 2: Peaking Technology Screening Curve

Figure 2 shows the low capacity factor technology screen curves. The high cost shown in the curves above further solidifies that wind and solar are not viable options to meet our need in 2017.

In an effort to continue to screen potential technologies and consider a wide range of fuels and capacity factors, Figure 3 includes more traditional technologies over the full range of capacity factors.




Figure 3: Intermediate and Base Screening Curve

As a result of the screening analysis, Tampa Electric concluded that simple cycle gas-fired CTs and NGCC were the most viable technologies for further consideration of the company's 2017 intermediate need. Because the cost of Aero type CTs and 7FA type CTs are similar on a \$/kW-year basis, Tampa Electric determined that due to our experience and our need for power in excess of 60 MWs in 2017, CTs and an NGCC unit were the two alternatives to further consider.

VI. DETAILED ECONOMIC ANALYSIS

A. Description of Analysis

Tampa Electric next conducted detailed economic analysis of the leading supply alternatives. The detailed analysis involved the development of a resource plan for each technology case that was evaluated. In the construction of resource plans for each technology case, new units were added to each case to maintain a 20 percent reserve margin.

There were numerous resource plans that included various in-service dates and various combinations of simple cycle combustion turbines, combined cycle units and the Polk 2-5 conversion. The results of the detailed production costing analyses were combined with the capital revenue requirements to produce results on a CPWRR basis. However, the top eight (lowest cost) plans and fifteen out of the top twenty plans selected the Polk 2-5 conversion in 2017.

Two higher cost plans shown in Table 5 are compared to the Polk 2-5 expansion plan. Alternative 1 is a plan that excludes the Polk 2-5 NGCC conversion and adds only simple cycle natural gas combustion turbines to maintain system reliability. Alternative 2 is a plan that delays the in-service date of the Polk 2-5 NGCC conversion until 2025 and adds simple cycle natural gas combustion turbines to maintain system reliability.

Table 5: Detailed Economic Analysis Resource Plan

Polk 2-5		Resource Plans Alternative 1		Alternative 2	
Year	Portfolio Additions	Year	Portfolio Additions	Year	Portfolio Additions
2012	Peaker PPA 117 MW	2012	Peaker PPA 117 MW	2012	Peaker PPA 117 MW
2013	Peaker PPA 117 MW Peaker PPA 160 MW	2013	Peaker PPA 117 MW Peaker PPA 160 MW	2013	Peaker PPA 117 MW Peaker PPA 160 MW
2014	Peaker PPA 117 MW Peaker PPA 160 MW	2014	Peaker PPA 117 MW Peaker PPA 160 MW	2014	Peaker PPA 117 MW Peaker PPA 160 MW
2015	Peaker PPA 117 MW Peaker PPA 160 MW	2015	Peaker PPA 117 MW Peaker PPA 160 MW	2015	Peaker PPA 117 MW Peaker PPA 160 MW
2016	Peaker PPA 117 MW Peaker PPA 160 MW	2016	Peaker PPA 117 MW Peaker PPA 160 MW	2016	Peaker PPA 117 MW Peaker PPA 160 MW
2017	(1) Polk 2-5 NGCC 463/459 MW	2017	(2) 7FA CT 354/298 MW	2017	(2) 7FA CT 354/298 MW
2018		2018	(1) 7FA CT 177/149 MW	2018	(1) 7FA CT 177/149 MW
2019	(1) 7FA CT 177/149 MW	2019	(1) 7FA CT 177/149 MW	2019	(1) 7FA CT 177/149 MW
2020		2020		2020	
2021		2021		2021	
2022	(1) 7FA CT 177/149 MW	2022	(1) 7FA CT 177/149 MW	2022	(1) 7FA CT 177/149 MW
2023		2023		2023	
2024		2024		2024	
2025	(1) 7FA CT 177/149 MW	2025	(1) 7FA CT 177/149 MW	2025	(1) Polk 2-5 NGCC 463/459 MW
2026		2026		2026	
2027	-	2027	-	2027	-
2028	-	2028	-	2028	-
2029	(1) 7FA CT 177/149 MW	2029	(1) 7FA CT 177/149 MW	2029	-
2030	-	2030	-	2030	-
2031	-	2031	-	2031	-
2032	-	2032	-	2032	-

B. Economic Analysis Results

The results of the Tampa Electric’s analysis are illustrated in the Table 6. Polk 2-5 provides a CPWRR savings of \$284 million and \$231 million when compared to the Alternative 1 plan that did not include the Polk 2-5 conversion and the Alternative 2 plan that delayed the Polk 2-5 conversion from 2017 to 2025.

Table 6: Results of Final Economic Analysis

Total System Costs (2012 \$ million)

	Polk 2-5 Conversion	Alternative 1	Alternative 2
CPWRR	18,232	18,516	18,463
Delta		284	231

1. Tampa Electric Selected Alternative

Tampa Electric selected NGCC technology as the best supply alternative to meet its 2017 need based on the results of the levelized cost analysis, detailed economic analysis and consideration of qualitative factors. Important qualitative factors were considered in the selection of NGCC technology including efficiency, dual fuel capability, transmission reliability and voltage support, dispatchability, low environmental emissions, and renewable integration. The levelized cost analysis and initial screening confirmed that the Polk 2-5 conversion was lower cost compared to a stand-alone NGCC. As a result of the lower cost associated with the Polk 2-5 Conversion as well as the factors listed above, the Polk 2-5 Conversion in 2017 was deemed the most cost-effective, reliable, dispatchable, and environmentally beneficial option. The reliability analysis of this recommended expansion plan is reflected in Appendix L.

2. Qualitative Factors and Benefits of the Selected Alternative

The selection of Polk 2-5 provides a number of qualitative benefits to Tampa Electric's customers. The use of natural gas for Polk 2-5 will ensure a diverse energy mix for Tampa Electric and its customers. The existing Polk 2 and 3 CTs have existing dual-fuel capability, thus further improving reliability to our customers. In addition, the resulting availability of these units is expected to be upwards of 96 percent.

Polk 2-5 will be connected directly to Tampa Electric's transmission network. This will provide higher reliability of delivery and the most ancillary benefits to the company's system. The conversion of our existing units also provides additional power with no added fuel consumption (and thereby no increase in emissions) by capturing waste heat from existing CTs which lowers emissions rates. In addition, after the Polk 2-5 conversion to NGCC, the HRSGs are designed to allow the existing combustion turbines to operate independently in simple cycle mode in the event the steam turbine is unavailable, providing significant system reliability and operating flexibility. The conversion also provides the capability for future integration of renewable energy options.

From a qualitative perspective, Polk 2-5 NGCC was favored due to its overall reliability, system emissions rate, and dispatchability.

3. Consistency with Florida Needs

Polk 2-5 does not significantly increase Tampa Electric's reliance on natural gas on a capacity and energy basis and is therefore consistent with state policy actions that encourage fuel diversity. The Polk 2-5 conversion significantly improves the efficiency of the four existing combustion turbines units and the Tampa Electric system overall by lowering the heat rate and dispatching ahead of other less efficient units. It should also be noted that load management and interruptible customer DSM programs are voluntary, so customers have a choice to withdraw from programs at any time with proper notification.

Tampa Electric's need for additional natural gas-fired combined cycle capacity in January 2017 is consistent with the peninsular Florida capacity needs in this same period, as identified by the FRCC and reported in the FRCC 2012 Regional Load and Resource Plan. The FRCC 2012 plan uses Tampa Electric specific data in conjunction with similar information from other

Florida electric utilities. In addition, there are concerns regarding continued operation of existing solid fuel assets due to emerging environmental regulations. If future additions do not materialize and some existing resources in the region are retired in response to costly mandatory retrofits, the FRCC reserve margin could drop below the minimum required from 2016 through 2019.

VII. SENSITIVITY ANALYSIS

A. Approach

As the final step in our process to select the most cost-effective resource addition as the basis for soliciting requests for power proposals, the company conducted sensitivity analyses comparing uncertainty factors of capital costs, fuel prices, and load growth. To evaluate the sensitivities of these factors, high and low price forecasts were established for capital construction costs and fuel price variations, and in addition, high and low load forecasts were also evaluated for Polk 2-5 and the two selected alternatives.

B. Results of Sensitivity

The results of the capital costs, fuel, and load sensitivities are presented in CPWRR for the Polk 2-5 conversion case in 2017 and the alternative plans described above.

1. Capital Cost Sensitivity

Recognizing that the estimated in-service costs for the Polk 2-5 Conversion are based on preliminary estimates, capital cost sensitivities were analyzed. The high and low cases were established utilizing higher and lower in-service cost for each of the technologies. The results of the capital cost sensitivity analysis are provided in table below:

Table 7: CPWRR Based on Capital Cost Sensitivities (\$ million)

	Polk 2-5 Conversion	Alternative 1	Alternative 2
Low Capital Cost	17,951	18,417	18,229
Delta		466	278
High Capital Cost	18,135	18,592	18,425
Delta		457	290

2. Fuel Price Sensitivity

To evaluate fuel price fluctuations, Tampa Electric prepared high and low price forecasts for coal, natural gas and oil. Appendices G and H include the low and high fuel forecasts, respectively. The high case for natural gas and oil is 35 percent higher than the base case and the low case is 35 percent lower than the base case. Solid fuel commodity pricing is 20 percent higher and lower than the base case, respectively. The results of the fuel sensitivity analysis are provided below:

Table 8: CPWRR Based on Fuel Pricing Sensitivities (2012 \$ million)

	Polk 2-5 Conversion	Alternative 1	Alternative 2
Low Fuel Cost	15,550	15,656	15,716
Delta		106	166
High Fuel Cost	21,972	22,454	22,274
Delta		482	302

3. Load Sensitivity

The base case load sensitivity is tested for sensitivity to varying economic conditions and customer growth rates. The high and low peak demand and energy sensitivities represent alternatives to the company's base case outlook. Compared to the base case, the expected economic growth rates

are 0.5 percent higher in the high sensitivity and 0.5 percent lower in the low sensitivity. The results of the load sensitivity analysis are provided in the following table:

Table 9: CPWRR Based on Load Sensitivities (\$ million)

	Polk 2-5 Conversion	Peaking Only	CC Alt
Low Load Cost	16,857	17,141	17,169
Delta		284	312
High Load Cost	19,792	20,357	19,867
Delta		565	76

These sensitivities demonstrated that Polk 2-5 in 2017 was still the most cost-effective alternative for Tampa Electric’s customers.

VIII. RFP for Capacity as per Bid Rule

On March 23, 2012, Tampa Electric issued an RFP to solicit competitive offers to satisfy the company’s projected capacity and energy requirements for comparison to Tampa Electric’s Polk 2-5. In accordance with the Chapter 25.22.082 Selection of Generating Capacity (“Bid Rule”) of the Florida Administrative Code, the RFP provided a detailed description of the Polk 2-5 site, fuel types and costs, estimated costs of the proposed project, and other major financial assumptions. The RFP also detailed the minimum requirements, including but not limited to a minimum 10-year term for purchase power agreements, a maximum of 500 MW and minimum of 50 MW of capacity, and the requirement for firm capacity and energy. The RFP also described the company’s objective to maintain a balanced generation mix, while also inviting proposals from renewable generating facilities.

To further ensure the proposals were evaluated on an even and fair basis, Tampa Electric retained the services of Sedway Consulting, Inc. (Sedway Consulting) as an independent evaluator to assist with the development of the RFP and evaluation of the responses. Alan S. Taylor, President of Sedway Consulting, was the primary independent evaluation consultant for the solicitation and has provided testimony in this filing.

On March 16, 2012, the company notified the market of the company's intent to issue an RFP by publishing notices in the Wall Street Journal, the Tampa Tribune, and energy industry publications. An informational meeting was held at Tampa Electric's headquarters on March 21, 2012, prior to the release of the RFP to educate potential bidders on the RFP process and how they could obtain a copy of the RFP. A second meeting was held after the issuance of the RFP, on April 4, 2012, to provide a more in-depth review of the RFP, the Polk 2-5 project, and to answer any questions. Tampa Electric also established a web site that granted access to the RFP documents and allowed potential bidders to submit questions. Both the questions and answers were posted on a "FAQ" page for all to view.

A. Initial Screening

On May 22, 2012, the published due date for proposals, Sedway Consulting facilitated the receipt and opening of all proposals delivered to the company's corporate headquarters. Tampa Electric received a total of four proposals from three bidders, and the table below summarizes these four proposals:

Table 10: RFP Summary of Proposals

Proposal	Type & Term	Technology
A	PPA	Existing CC
B	Sale of Facility	Existing CTs
C	PPA	New CT
D	PPA	New CT

Following the initial screening process described in Section III A.1. of the RFP document, Sedway Consulting, along with Tampa Electric personnel reviewed the proposals to ensure they met the general and specific minimum requirements set forth in the RFP. Tampa Electric, along with Sedway Consulting, contacted bidders whenever there was any missing data, or a need to clarify submitted data.

B. Economic Evaluation of Individual Proposals/Bids

Tampa Electric began the economic evaluation of the above four proposals to determine the relative economic impact on Tampa Electric's system over the study period. The initial rankings of the bid proposals, based on levelized cost curves at the expected capacity factor, indicated A as the most cost effective bid. Bid proposals C and D were initially the least economic for several reasons. Both C and D proposals had higher capacity payments (on a \$/kW-month basis) and less efficient heat rates compared to bid proposal A.




Figure 4: RFP – Initial Screening of Proposals

C. Present Value Economic Screen

Using preliminary system cost assumptions, all four bid proposals were passed to the present value economic screen evaluation process where each was evaluated using the CPWRR. This phase of the analysis took into account fixed and variable costs of production for the bid proposals as well as Tampa Electric system impacts. Neither proposal C or D met the 294 MW need in 2017 without the need to add peaking CTs in the 2017 time period.

D. Final Evaluation of Total System Costs

Tampa Electric short-listed all proposals and invited the bidders to submit their best and final offers to the company no later than July 13, 2012. Only the bidder

for Proposal B provided modifications to their initial offer. Tampa Electric used the information provided in the best and final offers, as well as transmission integration cost estimates, net equity adjustment for purchase obligations, and fuel infrastructure costs to determine the final total system cost for each proposal.

Table 11: Resource Plans of RFP Portfolios

Year	Polk 2-5	Proposal A	Proposal B	Proposal C	Proposal D
2012					
2013			Proposal B		
2014					
2015					
2016					
2017	Polk 2-5	Proposal A		Proposal C 7FA CT	Proposal D 7FA CT
2018			Polk 2-5		
2019	7FA CT	7FA CT		(2) 7FA CTs	(2) 7FA CTs
2020					
2021					
2022	7FA CT	7FA CT			
2023				Polk 2-5	Polk 2-5
2024					
2025	7FA CT	7FA CT			
2026			7FA CT		
2027		Polk 2-5			
2028					
2029	7FA CT	7FA CT	7FA CT	7FA CT	
2030					
2031					
2032					7FA CT

Analyzing the above resource plans with the revised data provided by the bidders, yielded the following results:

Table 12: RFP CPWRR Results in 2012 (\$ million)

CPWRR (\$ million)					
	Polk 2-5	Proposal A	Proposal B	Proposal C	Proposal D
Capital	\$1,575.2	\$1,253.3	\$1,400.1	\$1,430.9	\$1,416.6
O&M	\$1,099.7	\$1,064.6	\$1,068.7	\$1,111.2	\$1,109.2
Fuel & Purchased Power	<u>\$15,566.1</u>	<u>\$16,143.0</u>	<u>\$15,904.5</u>	<u>\$15,909.9</u>	<u>\$15,954.9</u>
Total	\$18,241.0	\$18,460.9	\$18,373.4	\$18,452.0	\$18,480.8
Delta		\$219.9	\$132.4	\$210.9	\$239.7

As seen above, Polk 2-5 is the lowest cost option against all proposals. Proposal B, which Tampa electric evaluated as the next best option shows a \$132.4 million CPWRR additional cost to Polk 2-5.

E. Non-Economic Evaluation

Tampa Electric understands that while the cost-effectiveness of its selection is important, there are many other qualitative impacts that must be considered. Therefore, thirteen unique, non-economic qualitative factors were developed and evaluated across Polk 2-5 and the proposals.. After review of all of these factors, Polk 2-5 was favored due to its overall reliability, emission rate, and dispatchability. The factors considered and a summary of how each proposal was judged is shown in Appendix P.

F. Final Selection

The results of the RFP analysis indicate that Polk 2-5 is the most economic plan to meet the 2017 capacity needs by \$132.4 million CPWRR compared to the next best proposal. Based on these economic results, and consideration of the non-economic impacts relative to the other proposals and technologies considered,

Polk 2-5 was selected as the best solution for Tampa Electric's customers in meeting its 2017 need.

IX. TAMPA ELECTRIC'S PROPOSED UNIT

A. Overview

The existing Polk 2 through 5 combustion turbines will be converted to a NGCC facility located at Polk Power Station by integrating a new steam turbine with an additional capacity of 459 MW summer and 463 MW winter, incrementally with a planned in-service date of January 2017. This incremental capacity is derived from waste heat from the four existing combustion turbines of 339 MW summer and 352 MW winter, as well as 120 MW summer and 111 MW winter from supplemental natural gas duct-firing in the four HRSGs. This supplemental firing eliminates the need for two future aero-derivative peaking units due to the expiration of a 121 MW PPA on December 31, 2018. In addition, after the Polk 2-5 conversion to NGCC, the HRSGs are designed to allow the existing combustion turbines to operate independently in simple cycle mode in the event the steam turbine is unavailable, providing significant system reliability and operating flexibility. The NGCC configuration also enables the potential integration of solar thermal renewable capacity and energy in the future.

The total in-service cost of the project (including transmission, but without AFUDC) is expected to be \$610.4 million. This includes the direct overnight engineering and procurement costs for the project of \$424.4 million. It also includes transmission costs, owner's costs, allowance for indeterminates and escalation.

B. Description

Tampa Electric plans to make use of its experience with NGCC technology to construct Polk 2-5 at Polk Power Station. Polk Power Station occupies over 2,800 acres on State Road 37 in Polk County, Florida, approximately 40 miles southeast of Tampa and about 60 miles southwest of Orlando. The primary fuel for Polk 2-5 will be natural gas and two of the four units will utilize distillate oil for backup.

Polk 2-5 is expected to generate a net 1,195 MW of electricity in winter at 32 degrees Fahrenheit and 1,063 MW in the summer at 92 degrees Fahrenheit. The average annual net heat rate, higher heating value is expected to be about 7,062 Btu/kWh.

The existing units 2-5 are General Electric 7FA combustion turbines installed in a simple cycle configuration. Units 2 and 3 have the ability to use distillate oil for backup and units 4 and 5 are natural gas only. Simple cycle units have a relatively low capital cost and are able to dispatch rapidly to meet peaking needs, but a significant amount of energy is lost in the exhaust.

After conversion, with no additional fuel consumption, Polk 2-5 will generate an incremental net electrical output of 352 MW in the winter at 32 degrees Fahrenheit and 339 MW in the summer at 92 degrees Fahrenheit. In addition, Polk 2-5 will utilize supplemental firing, also known as duct burners, to provide up to 120 MW of additional cost effective peaking capacity that will offset the need for future peaking unit construction.

1. Location


By co-locating Polk 2-5 at Polk Power Station, there are numerous benefits including but not limited to:

- An existing site that has already been developed with future expansion in mind.
- An existing 750 acre cooling reservoir that has adequate capacity to handle a large portion of the cooling needs for Polk 2-5.
- Existing natural gas pipeline infrastructure that already serves the existing units 2-5 and has adequate capacity to serve the incremental need for the supplemental firing system.
- The existing on-site substation can be readily expanded to accommodate the new steam turbine generator interconnection.
- The site has an existing administration building, control room, warehouse, maintenance shop and other facilities that are capable of serving the new unit.
- An existing operations staff experienced in operating this type of generation equipment with minimal training.

2. Design

Tampa Electric is currently in the preliminary engineering stage of design for Polk 2-5. At this stage of the project a preliminary concept of the plant has been developed. This preliminary conceptual design provides sufficient information for estimation of the expected performance, and general arrangement of the plant and high level estimates of the projects schedules and costs. The plant can be broken down into several sections, as described in the following sections. A process diagram is provided in Figure 7 below.

Figure 5: Polk 2-5 Overall Process



POLK 2 COMBINED CYCLE PROJECT
 POLK 2-5 COMBINED CYCLE PROJECT
 PROCESS FLOW DIAGRAM

175634-08-2001

3. Systems

a. Natural Gas Delivery

Natural gas will be delivered via an existing FGT pipeline already on the Polk site. The pipeline already serves the existing units 2-5 and has adequate capacity to serve the incremental needs of the supplemental firing system. In addition, the Gulfstream Natural Gas Company's pipeline is close to the Polk site and could be extended in the future for added natural gas delivery diversity.

b. Water Use

The primary consumption of water will be for makeup to the cooling reservoir and cooling tower to replace water lost by evaporation. To a much lesser extent, water will also be used to provide demineralized water for makeup to the HRSGs. The majority of the makeup water needs will be from reclaimed water from the City of Lakeland. In addition, by using the existing cooling reservoir to the maximum extent possible, water use from evaporative losses will be reduced relative to using a cooling tower.

c. Heat Recovery Steam Generators (HRSGs)

Polk 2-5 will utilize triple pressure HRSGs with reheat. This design is the standard for domestic combined cycles and is a very proven and reliable technology. In addition, the HRSGs for Polk 2-5 will include diverter dampers and supplemental firing capability. The diverter dampers provide increased reliability by allowing the combustion turbine to remain in operation in the event the associated HRSG or steam turbine is unavailable. The diverter dampers will also allow Polk 2-5 to retain the current rapid response capability if needed for peaking

service. The supplemental firing system will add up to 120 MW (30 MW per HRSG) of relatively low cost and high efficiency peaking capacity when compared to simple cycle combustion turbines.

d. Steam Turbine Generator (“STG”)

Polk 2-5 will utilize a modern STG which will be designed with the flexibility to allow cycling, intermediate or base load operation depending on the system’s needs and economics. The expected Equivalent Availability Factor for Polk 2-5 is 96.1 percent.

C. Environmental

Tampa Electric is required to obtain federal, state, and regional environmental approvals and permits. The principal environmental approval is certification under Florida’s Electrical Power Plant Siting Act (“PPSA”) codified in 403.500 Florida Statutes. This is a comprehensive review of all environmental aspects of Polk 2-5, coordinated through the FDEP and involving all state and regional agencies with environmental responsibility and those potentially affected by Polk 2-5.

Polk 2-5 will require federal and federally delegated permits. This includes an approval by the U.S. Army Corp of Engineers (“ACOE”) for impacts to wetlands, a Prevention of Significant Deterioration (“PSD”)/Air Construction Permit by the FDEP, a National Pollutant Discharge Elimination System (“NPDES”) and an Underground Injection Control (“UIC”) Permit from FDEP.

The ACOE permit is required under Section 404 of the Clean Water Act and includes a demonstration that impacts to wetlands have been minimized and compensatory wetland mitigation has been provided as needed. Since Polk 2-5 will be located at the existing site of Polk Unit 1, minimal impacts to wetlands will

occur. Appendix R contains a detailed list of environmental permitting activities that are currently in process by Tampa Electric for Polk 2-5.

Under the federally authorized PSD program, Polk 2-5 will be required to install Best Available Control Technology (“BACT”) and demonstrate that the project will comply with all air quality standards including those applicable to the PSD Class I Areas. FDEP PSD rules are codified in Rule 62-212 F.A.C. An important aspect of PSD review is the determination of BACT.

The Polk 2-5 site was selected at a location that provides the needed infrastructure and minimizes environmental impacts. The Polk Power Station site includes sufficient land area, which has been previously certified to minimize any additional environmental impacts. Water use will be minimized by utilizing reclaimed water for the makeup to the cooling reservoir. Lakeland’s Water Treatment Facility currently discharges its reclaimed water into the Alafia River which ends up in Tampa Bay. Polk is taking this water from Lakeland and treating it removing any nutrients before discharging into Little Pane Creek which aids in improving the water quality in Tampa Bay. Using the treated water will minimize additional consumptive use withdrawals to the greatest extent possible and will assist in accelerating the removal of nutrients from Tampa Bay.

Air emissions from Polk Power Station will be minimized by use of Selective Catalytic Reduction (“SCRs”) equipment in each HRSG to reduce nitrogen oxide emissions. The SCRs in combination with cycle efficiency improvements will provide an 86 percent reduction in the NO_x emission rate.

D. Transmission Facilities

Polk 2-5 will require the construction of transmission infrastructure as shown in Appendix S. The infrastructure/facilities required are described below:

1. Two new 230 kV transmission lines, three new 230 kV circuit breakers and

- a generator step-up transformer are required at Polk to interconnect the Polk 2-5 to the transmission system.
2. A new 230 kV transmission switching station (Aspen Substation) west of Mines Substation.
 3. The following new 230 kV transmission lines:
 - Polk Substation to Mines Substation
 - Mines Substation to Aspen Substation
 - Two lines from Aspen Substation to FishHawk Substation
 4. Upgrade segments of existing 230 kV transmission lines to create a 230 kV transmission line from Polk Power Substation to Aspen Substation.
 5. Interconnect and rerate existing 230 kV transmission line from Big Bend Power Station Substation to Mines Substation into Aspen Substation.
 6. Upgrade 16-230 kV circuit breakers at Polk Power Substation, Pebbledale Substation, Mines Substation and Big Bend Power Station Substation.
 7. Reroute and upgrade the first Polk Power Substation to Pebbledale Substation 230 kV transmission line.
 8. Rerate the second Polk Power Substation to Pebbledale Substation 230 kV transmission line.
 9. Install a switched reactor at Davis Substation.
 10. Upgrade the bus for the State Road 60 North 230/69 kV Transformer.
 11. Upgrade the bus and low side circuit breaker for the Dale Mabry West 230/69 kV Transformer.

The total project costs are approximately \$147.2 million. The Polk interconnection/integration work would begin in January 2013 and would be completed by November 2016. The Polk Power Substation to Aspen Substation to FishHawk Substation transmission line construction must begin by October 2014 in order to make an in-service date of November 2016. The remainder of the work will be completed prior to November 2016. This ensures that all

transmission facilities are in-service prior to any testing of Polk 2-5 and its equipment prior to its commercial date.

Polk 2-5 will be interconnected with Tampa Electric with 4 transmission lines to the existing Polk Power Substation. The Polk Power Substation is currently connected to the Tampa Electric bulk electric system through four 230 kV lines, two to Pebbledale Substation, one to Mines Substation and one line to the Hardee Power Station. With the new construction, a 230 kV line will be added to the Aspen Substation, eventually running to the FishHawk Substation.

FRCC Transmission Working Group and Stability Working Group have evaluated the proposed interconnection and integration of the Polk 2-5 project and determined it is reliable and does not adversely impact the transmission system in the FRCC region.

E. Cost

The overnight construction cost for Polk 2-5 is \$424.4 million. The estimate represents the following pricing components: engineering, equipment procurement, direct and indirect construction, commissioning and owner's costs in 2012 dollars. This estimate was developed by Black & Veatch and reflects current equipment and labor pricing. This project estimate does not include related transmission upgrades or AFUDC. Owner's costs include project development costs such as environmental permitting, project management, operation support and training, legal and other professional services costs. Tampa Electric estimated the owner's costs for Polk 2-5 based on its experience developing and constructing generating units in Florida.

The total in-service cost estimate for Polk 2-5 is \$610.4 million, which includes the aforementioned overnight construction costs as well as transmission costs and escalation.

F. Schedule

Conceptual design began in late 2011, and the preliminary engineering package development began in February 2012 and was completed in May 2012. The Site Certification Application will be filed with the FDEP in September 2012. The detailed design and procurement will begin January 2013. Detailed design and procurement activities are expected to continue through November 2014. Construction activities are expected to begin in the first quarter 2014 with general site work. Commissioning of the equipment is expected to begin in February 2016 and the unit is expected to begin commercial operation in January 2017.

The preliminary project schedule is shown in Appendix Q.

X. JUNE 2012 ASSUMPTIONS UPDATE

During the course of this RFP, Tampa Electric, as part of its annual IRP process, developed an updated customer demand & energy forecast, as well as a new fuel pricing forecast. In order to assess the effects of these new forecasts and to ensure it would not alter the selection of the most economical option, another economic evaluation of Polk 2-5 and the most competitive proposal from the RFP process and Alternative 2 was completed utilizing these new forecasts. The results of this analysis is shown in the table below. Even considering newer forecast data developed as part of the on-going IRP process, Tampa Electric determined Polk 2-5 is still the most cost effective alternative compared to the lowest RFP bid proposal.

Table 13: Economic Evaluation with Consideration of June 2012 Updated Assumptions

	CPWRR (\$ million)		
	Polk 2-5	Alternative 2	Proposal B
Capital	\$1,557.2	\$1,520.4	\$1,357.5
O&M	\$845.2	\$897.5	\$815.1
Fuel & Purchased Power	<u>\$13,631.7</u>	<u>\$13,882.9</u>	<u>\$13,623.5</u>
Total	\$16,034.1	\$16,300.8	\$16,131.5
Delta		\$266.7	\$97.4

As can be seen in the table, Polk 2-5 is still the best option compared to Alternative 2 and Proposal B, which are \$266.7 million and \$97.4 million more costly with the latest demand and energy and fuel cost forecasts considered.

XI. Adverse Consequences If Polk 2-5 Is Delayed Or Denied

In the event that Polk 2-5 is delayed by two years, project costs would increase, and customer fuel savings for 2017 and 2018 would not be realized. Tampa Electric would construct simple cycle peaking units in 2017 to cover the reserve margin requirement in 2017 and 2018. System energy requirements would be served by peaking capacity resulting in higher fuel costs. This would result in higher costs for customers of \$65.4 million on a CPWRR basis. Witness Hornick described the potential for an equipment demand spike scenario if there is a delay. If an equipment demand spike scenario materializes, this could result in higher costs for customers of \$100.0 million on a CPWRR basis.

If Tampa Electric's proposed Polk 2-5 is denied, Tampa Electric would not be able to satisfy its minimum 20 percent Reserve Margin and minimum 7 percent supply planning criteria by the summer of 2017 in the most reliable and cost-effective manner. This would expose Tampa Electric's customers to a greater

risk of interruption of service in the event of unanticipated forced outages or other contingencies for which Tampa Electric maintains reserves. Even without an interruption in service, without Polk 2-5 the company's customers would be subject to higher fuel costs as the company would have to rely on less efficient simple cycle generation to meet its need.

XII. CONCLUSION

Tampa Electric, through its IRP process, incorporated an on-going evaluation of demand and supply resources and conservation measures to maintain system reliability. The reliability analysis determined that Tampa Electric will have capacity needs by 2017 of 294 MW in order to meet the Commission-approved 20 percent reserve margin criteria. Despite Tampa Electric's utilization of all cost-effective DSM programs and the associated increase in load reductions, the company will not be able to defer its need.

Tampa Electric conducted a detailed evaluation of various supply alternatives, including natural gas-fired and solid fuel-fired. After an initial screening process of a variety of viable technologies and fuels, a detailed economic analysis demonstrated that Polk 2-5 is the most cost-effective means of meeting Tampa Electric's 2017 need compared to other technologies and available supply capacity from the Florida market. Tampa Electric's analysis demonstrated Polk 2-5 provides \$284 million in savings compared to peaking technology and \$231 million in savings compared to peaking then NGCC technology.

After consideration of all existing, new and modified DSM programs and renewable energy initiatives, the construction of Polk 2-5 with a January 2017 in-service date should not be deferred. A two-year deferral of the recommended plan could increase costs to customer by \$100 million. Tampa Electric also determined that fuel diversity is a key objective and the addition of natural gas

combined cycle technology in 2017 still maintains a prudent balance in Tampa Electric's capacity and energy mix.

In conclusion, Polk 2-5 provides significant savings of \$132.4 million to Tampa Electric's customers when compared to the next higher cost alternative while providing additional benefits in the areas of reliability, fuel diversity, environmental impacts, and generating system efficiency. All these reasons reinforce Tampa Electric's selection of Polk 2-5 as the best alternative for Tampa Electric and its customers.

XIII. APPENDICES

- Appendix A: Residential DSM Programs
- Appendix B: Commercial/Industrial DSM Programs
- Appendix C: Retail Customers by Customer Class
- Appendix D: Retail Energy Sales by Customer Class
- Appendix E: Retail Peak Demand Forecast
- Appendix F: High and Low Retail Peak Demand Used in Sensitivity
- Appendix G: June 2012 Update Used in Sensitivity
- Appendix H: Fuel Forecast
- Appendix I: Low Fuel Forecast Used in Sensitivity Analysis
- Appendix J: High Fuel Forecast Used in Sensitivity Analysis
- Appendix K: Tampa Electric Reliability Analysis
- Appendix L: Tampa Final Electric Reliability Analysis
- Appendix M: FRCC Reliability Analysis
- Appendix N: FRCC Reliability Sensitivity Analysis
- Appendix O: Technology Assumptions
- Appendix P: RFP Qualitative Factors
- Appendix Q: Polk 2-5 Preliminary Project Schedule
- Appendix R: Polk 2-5 Environmental Permit Requirements
- Appendix S: Transmission Interconnection and Integration Diagrams

Appendix A: Residential DSM Programs

Residential Programs	Measures	Brief Description
Walk-Through Audit	Customer is given eight CFLs	Free audit conducted on-site by trained analyst
On-Line Audit	Customer is given eight CFLs	Free on-line audit available at customer's convenience
Paid Audit	Customer is given eight CFLs	Paid computer assisted audit conducted on-site by trained analyst
Telephone Audit	Customer is given eight CFLs	Free audit conducted by telephone; uses on-line audit tool for evaluation
Heating & Cooling	High-efficiency heat pumps or high-efficiency cooling with natural gas heating	Incentives are \$400 for heat pumps replacing strip heat; \$275 for heat pumps replacing strip heat; \$275 for straight cool with gas heat
Duct Repair	Duct repair	Customer cost to participate is \$50 for repairs and sealing of ductwork.
Residential Building Envelope Improvement	Ceiling insulation	Incentive up to \$350
	Wall Insulation	Incentive of \$0.31 per sq. ft.
	Window Replacement	Incentive of \$2.65 per sq. ft.
	Window Film	Incentive of \$2.00 per sq. ft.
New Construction Program	Duct Sealing With Mastic	Incentive of \$100
	High-efficiency heat pumps or high-efficiency cooling with natural gas heating	Incentive of \$275 per unit
	Ceiling insulation	Incentive of \$150
	Window upgrades	Incentive of \$400
	Water heating	Incentive of \$150
	HERs certification	Incentive of \$100
Energy Planner	Price responsive load management	Uses programmable thermostat in conjunction with time-of-use pricing tiers to reduce weather sensitive peak loads.
Electronically Commutated Motors	Air handler fan motor upgrade	Incentive of \$135
HVAC Re-commissioning	HVAC equipment tune-up and maintenance	Incentive of \$75
Energy Education Outreach	CFLs, low-flow items and filter whistles	Program is designed to establish opportunities for energy-efficiency related discussions in an organized setting
Weatherization and Agency Outreach	Weatherization - Installation of the following applicable measures: eight CFLs, water heater wrap, water temp cards, low-flow showerheads, wall plate thermometer, refrigeration coil brush, weather-stripping and caulking, R-13 ceiling insulation and duct repair	Low income weatherization through either direct customer request or by the utilization of census data
	Agency Outreach - Customer is given four CFLs, water temp card, low-flow aerators and change air filter whistles	The delivery of energy efficiency kits to educate agency clients on practices that help reduce energy consumption
Prime Time	Direct load control of HVAC equipment, water heating and pool pumps.	This program has been closed to new customers since 2005

Appendix B: Commercial/Industrial DSM Programs

Commercial Programs	Measures	Brief Description
Free Audit	Customer is given eight CFLs	Free audit conducted on-site by trained analyst
Paid Audit	Customer is given eight CFLs	Paid audit conducted by analyst; includes specific data collection
Duct Repair	Duct repair	Incentive of \$300
Building Envelope Improvement	Ceiling insulation	Incentive of \$0.25 per sq. ft.
	Roof insulation	Incentive of \$0.15 per sq. ft.
	Wall insulation	Incentive of \$0.40 per sq. ft.
	Window film	Incentive of \$1.25 per sq. ft.
Energy Efficient Motors	Motor upgrades	Incentive of \$6.00 per HP
Commercial Cooling	High-efficiency cooling equipment	Incentives are \$50 per ton for DX units and \$37.50 per ton for PTAC units
Chillers	High-efficiency chilled water HVAC	Incentive of \$175 per kW reduction
Lighting	High-efficiency lighting in conditioned or unconditioned space	Incentive of \$175 per kW reduction
	High-efficiency exit signs	Incentive of \$25 per sign
Occupancy Sensors	Installation of occupancy sensors for lighting	Incentive of \$25 per sensor
Standby Generator	Load reduction through emergency generation	Incentive of \$4.00 per kW reduction
Refrigeration (anti-condensate controls)	Installation of anti-condensate heat controls	Incentive of \$0.65 per linear ft.
Water Heating	Water heating upgrades	Incentive of \$0.0116 per btu
Conservation Value	Customer specific measures with reductions greater than 5 kW	Incentive of \$175 per kW reduction
Commercial Load Management	Direct load control of HVAC equipment, water heating	Incentive for cyclic control (summer only) \$3.00 per kW; Incentive for extended control (summer and winter) \$3.50 per kW
Demand Response	Price responsive load management	Turn-key program providing price incentives for demand reduction
Industrial Load Management	Load reduction for facilities 500 kW and greater	Approved annual incentive per FPSC cost-effectiveness methodology
Electronically Commutated Motors	Air handler fan and refrigeration motors upgrade	Incentives range from \$125 to \$180 per HP
HVAC Re-commissioning	HVAC equipment tune-up and maintenance	Incentive of \$25 per ton
Cool Roof	Roof systems to reduce cooling demand	Incentive of \$0.60 per sq. ft.
Energy Recovery Ventilation	HVAC ventilation systems to reduce cooling demand	Incentives range from \$1.32 to \$2.26 per cfm of system

Appendix C: Retail Customers by Customer Class

	Residential	Commercial	Industrial	Phosphate	Public Authorities	Street&Hwy Lighting	Total Retail Sales
2002	518,554	64,665	904	44	5,812	220	590,199
2003	531,257	66,041	1,159	44	6,188	211	604,900
2004	544,313	67,488	1,260	39	6,226	209	619,535
2005	558,601	69,027	1,300	37	6,447	209	635,621
2006	575,111	70,205	1,448	37	6,706	199	653,706
2007	586,776	70,891	1,458	36	6,992	201	666,354
2008	587,602	70,770	1,385	36	7,271	202	667,266
2009	587,396	70,182	1,392	32	7,521	227	666,750
2010	591,554	70,176	1,405	29	7,607	220	670,991
2011	595,914	70,522	1,465	28	7,666	203	675,798
2012	599,454	71,418	1,464	32	7,746	201	680,315
2013	606,320	72,252	1,475	32	7,802	202	688,083
2014	614,152	73,176	1,486	32	7,863	204	696,913
2015	622,637	74,183	1,494	32	7,929	206	706,481
2016	632,012	75,278	1,501	32	8,002	208	717,033
2017	641,161	76,346	1,508	32	8,073	210	727,330
2018	650,099	77,398	1,516	32	8,141	213	737,399
2019	659,014	78,447	1,523	32	8,210	215	747,441
2020	667,793	79,491	1,531	32	8,278	217	757,342
2021	676,073	80,484	1,539	32	8,342	220	766,690
Average Annual Growth Rates							
2002-2011	1.6%	1.0%	5.5%	-4.8%	3.1%	-0.9%	1.5%
2012-2021	1.3%	1.3%	0.6%	0.0%	0.8%	1.0%	1.3%
Average Absolute Growth							
2002-2011	8,596	651	62	-2	206	-2	9,511
2012-2021	8,513	1,007	8	0	66	2	9,597

Appendix D: Retail Energy Sales by Customer Class

Tampa Electric Company
Retail Energy Sales
(GWH)

	Residential	Commercial	Industrial	Phosphate	Public Authorities	Street&Hwy Lighting	Total Retail Sales
2002	8,046	5,832	1,234	1,378	1,380	55	17,925
2003	8,265	5,843	1,303	1,277	1,481	57	18,225
2004	8,293	5,988	1,327	1,229	1,542	58	18,437
2005	8,558	6,234	1,329	1,149	1,582	60	18,912
2006	8,721	6,357	1,343	936	1,607	61	19,025
2007	8,871	6,542	1,316	1,050	1,692	63	19,533
2008	8,546	6,399	1,236	969	1,776	64	18,990
2009	8,666	6,274	1,088	906	1,771	68	18,774
2010	9,185	6,221	1,058	952	1,724	73	19,213
2011	8,718	6,207	1,072	731	1,761	74	18,564
2012	8,904	6,346	1,121	777	1,822	74	19,044
2013	9,003	6,412	1,131	706	1,833	74	19,158
2014	9,095	6,484	1,135	568	1,844	75	19,201
2015	9,174	6,557	1,133	530	1,856	76	19,326
2016	9,272	6,640	1,128	540	1,871	77	19,528
2017	9,376	6,727	1,122	529	1,887	77	19,719
2018	9,486	6,814	1,117	529	1,903	78	19,927
2019	9,600	6,901	1,112	529	1,919	79	20,141
2020	9,716	6,985	1,107	529	1,935	80	20,352
2021	9,826	7,063	1,102	529	1,949	81	20,550
Average Annual Growth Rates							
2002-2011	0.9%	0.7%	-1.5%	-6.8%	2.7%	3.3%	0.4%
2012-2021	1.1%	1.2%	-0.2%	-4.2%	0.8%	1.0%	0.8%
Average Absolute Growth							
2002-2011	75	42	-18	-72	42	2	71
2012-2021	102	80	-2	-28	14	1	167

Appendix E: Retail Peak Demand Forecast

Tampa Electric Company Total Retail Peak Demand (MW)			Tampa Electric Company Firm Retail Peak Demand (MW)		
	<u>Winter</u>	<u>Summer</u>		<u>Winter</u>	<u>Summer</u>
2002	3612	3634	2002	3259	3318
2003	3881	3623	2003	3455	3351
2004	3344	3737	2004	2936	3445
2005	3686	3968	2005	3287	3725
2006	3736	4010	2006	3523	3769
2007	3398	4123	2007	3127	3876
2008	3709	3952	2008	3443	3723
2009	4080	4015	2009	3754	3799
2010	4512	3917	2010	4246	3710
2011	4037	3976	2011	3735	3699
2012	4081	3993	2012	3777	3748
2013	4112	4023	2013	3819	3784
2014	4141	4049	2014	3864	3823
2015	4180	4082	2015	3910	3859
2016	4224	4125	2016	3955	3900
2017	4269	4165	2017	4003	3940
2018	4315	4207	2018	4050	3980
2019	4361	4250	2019	4097	4022
2020	4408	4292	2020	4146	4064
2021	4453	4331	2021	4194	4103
Average Annual Growth Rates			Average Annual Growth Rates		
2002-2011	1.2%	1.0%	2002-2011	1.5%	1.2%
2012-2021	1.0%	0.9%	2012-2021	1.2%	1.0%
Average Absolute Growth			Average Absolute Growth		
2002-2011	47	38	2002-2011	53	42
2012-2021	41	38	2012-2021	46	39

Appendix F: High and Low Retail Peak Demand Used in Sensitivity

	High Load Scenario		Low Load Scenario		
	Tampa Electric Company Firm Retail Peak Demand (MW)		Tampa Electric Company Firm Retail Peak Demand (MW)		
	<u>Winter</u>	<u>Summer</u>	<u>Winter</u>	<u>Summer</u>	
2002	3259	3318	2002	3259	3318
2003	3455	3351	2003	3455	3351
2004	2936	3445	2004	2936	3445
2005	3287	3725	2005	3287	3725
2006	3523	3769	2006	3523	3769
2007	3127	3876	2007	3127	3876
2008	3443	3723	2008	3443	3723
2009	3754	3799	2009	3754	3799
2010	4246	3710	2010	4246	3710
2011	3735	3699	2011	3725	3699
2012	3802	3778	2012	3758	3725
2013	3868	3836	2013	3779	3740
2014	3936	3897	2014	3802	3758
2015	4003	3955	2015	3825	3773
2016	4072	4017	2016	3849	3791
2017	4142	4080	2017	3874	3810
2018	4212	4144	2018	3898	3827
2019	4284	4209	2019	3922	3847
2020	4358	4276	2020	3947	3866
2021	4431	4341	2021	3972	3882
	Average Annual Growth Rates		Average Annual Growth Rates		
2002-2011	1.5%	1.2%	2002-2011	1.5%	1.2%
2012-2021	1.7%	1.6%	2012-2021	0.6%	0.5%
	Average Absolute Growth		Average Absolute Growth		
2002-2011	53	42	2002-2011	52	42
2012-2021	70	63	2012-2021	24	17

Appendix G: June 2012 Update Used in Sensitivity

Tampa Electric Company Total Retail Peak Demand (MW)			Tampa Electric Company Firm Retail Peak Demand (MW)		
	<u>Winter</u>	<u>Summer</u>		<u>Winter</u>	<u>Summer</u>
2002	3612	3634	2002	3259	3318
2003	3881	3623	2003	3455	3351
2004	3344	3737	2004	2936	3445
2005	3686	3968	2005	3287	3725
2006	3736	4010	2006	3523	3769
2007	3398	4123	2007	3127	3876
2008	3709	3952	2008	3443	3723
2009	4080	4015	2009	3754	3799
2010	4512	3917	2010	4246	3710
2011	4037	3931	2011	3725	3699
2012	3523	3916	2012	3237	3677
2013	3970	3893	2013	3699	3667
2014	3999	3928	2014	3731	3701
2015	4043	3969	2015	3778	3741
2016	4095	4017	2016	3832	3788
2017	4147	4065	2017	3887	3835
2018	4200	4112	2018	3941	3881
2019	4251	4159	2019	3993	3927
2020	4301	4203	2020	4045	3971
2021	4349	4244	2021	4095	4012
Average Annual Growth Rates			Average Annual Growth Rates		
2002-2011	1.2%	0.9%	2002-2011	1.5%	1.2%
2012-2021	1.1%	0.9%	2012-2021	1.3%	1.0%
Average Absolute Growth			Average Absolute Growth		
2002-2011	47	33	2002-2011	52	42
2012-2021	47	36	2012-2021	50	37

Appendix H: Fuel Forecast

Tampa Electric has forecasted the commodity price of fuels through 2041.

Natural gas is forecasted for the Henry Hub.

Nominal \$/MMBtu for Fuel

	No. 2 Oil	NG	Coal
2012	\$25.68	\$4.92	\$2.22
2013	\$26.88	\$5.30	\$2.42
2014	\$27.98	\$5.58	\$2.45
2015	\$29.44	\$5.86	\$2.56
2016	\$30.84	\$6.12	\$2.41
2017	\$32.06	\$6.39	\$2.40
2018	\$33.34	\$6.67	\$2.27
2019	\$34.63	\$6.93	\$2.43
2020	\$35.98	\$7.19	\$2.59
2021	\$37.39	\$7.44	\$2.75
2022	\$38.89	\$7.70	\$2.90
2023	\$39.75	\$7.87	\$3.01
2024	\$40.61	\$8.04	\$3.11
2025	\$41.49	\$8.21	\$3.22
2026	\$42.37	\$8.39	\$3.32
2027	\$43.27	\$8.56	\$3.43
2028	\$44.17	\$8.74	\$3.54
2029	\$45.09	\$8.93	\$3.65
2030	\$46.03	\$9.11	\$3.76
2031	\$46.99	\$9.30	\$3.87
2032	\$47.96	\$9.49	\$3.99
2033	\$48.96	\$9.69	\$4.11
2034	\$49.97	\$9.89	\$4.23
2035	\$50.99	\$10.09	\$4.35
2036	\$52.04	\$10.30	\$4.48
2037	\$53.11	\$10.51	\$4.61
2038	\$54.20	\$10.72	\$4.74
2039	\$55.31	\$10.94	\$4.87
2040	\$56.44	\$11.16	\$5.01

Appendix I: Low Fuel Forecast Used in Sensitivity Analysis

Tampa Electric has forecasted the commodity price of fuels through 2041.

Natural gas is forecasted for the Henry Hub.

Nominal \$/MMBtu for Fuel			
	No. 2 Oil	NG	Coal
2012	\$14.52	\$3.09	\$2.22
2013	\$15.63	\$3.33	\$1.93
2014	\$16.46	\$3.51	\$1.96
2015	\$17.30	\$3.69	\$2.05
2016	\$18.17	\$3.87	\$1.93
2017	\$19.01	\$4.05	\$1.92
2018	\$19.88	\$4.23	\$1.82
2019	\$20.72	\$4.41	\$1.97
2020	\$21.56	\$4.59	\$2.14
2021	\$22.42	\$4.77	\$2.30
2022	\$23.29	\$4.96	\$2.46
2023	\$23.80	\$5.07	\$2.55
2024	\$24.32	\$5.18	\$2.65
2025	\$24.85	\$5.29	\$2.75
2026	\$25.38	\$5.40	\$2.84
2027	\$25.91	\$5.52	\$2.94
2028	\$26.45	\$5.63	\$3.04
2029	\$27.00	\$5.75	\$3.14
2030	\$27.57	\$5.87	\$3.25
2031	\$28.14	\$5.99	\$3.35
2032	\$28.72	\$6.12	\$3.46
2033	\$29.32	\$6.24	\$3.57
2034	\$29.92	\$6.37	\$3.68
2035	\$30.54	\$6.50	\$3.80
2036	\$31.17	\$6.64	\$3.91
2037	\$31.81	\$6.77	\$4.03
2038	\$32.46	\$6.91	\$4.15
2039	\$33.12	\$7.05	\$4.28
2040	\$33.80	\$7.20	\$4.40

Appendix J: High Fuel Forecast Used in Sensitivity Analysis

Tampa Electric has forecasted the commodity price of fuels through 2041.

Natural gas is forecasted for the Henry Hub.

	Nominal \$/MMBtu for Fuel		
	No. 2 Oil	NG	Coal
2012	\$30.15	\$6.42	\$2.22
2013	\$32.46	\$6.91	\$2.90
2014	\$34.18	\$7.28	\$2.95
2015	\$35.93	\$7.65	\$3.07
2016	\$37.74	\$8.04	\$2.89
2017	\$39.49	\$8.41	\$2.88
2018	\$41.28	\$8.79	\$2.73
2019	\$43.04	\$9.17	\$2.91
2020	\$44.79	\$9.54	\$3.10
2021	\$46.55	\$9.92	\$3.29
2022	\$48.37	\$10.30	\$3.48
2023	\$49.43	\$10.53	\$3.59
2024	\$50.51	\$10.76	\$3.70
2025	\$51.60	\$10.99	\$3.81
2026	\$52.70	\$11.23	\$3.93
2027	\$53.81	\$11.46	\$4.04
2028	\$54.94	\$11.70	\$4.16
2029	\$56.09	\$11.95	\$4.28
2030	\$57.25	\$12.19	\$4.40
2031	\$58.44	\$12.45	\$4.52
2032	\$59.66	\$12.71	\$4.65
2033	\$60.89	\$12.97	\$4.78
2034	\$62.15	\$13.24	\$4.91
2035	\$63.43	\$13.51	\$5.04
2036	\$64.73	\$13.79	\$5.18
2037	\$66.06	\$14.07	\$5.32
2038	\$67.41	\$14.36	\$5.46
2039	\$68.79	\$14.65	\$5.60
2040	\$70.20	\$14.95	\$5.75

Appendix K: Tampa Electric Reliability Analysis

Forecast of Capacity and Demand at Time of Summer Peak												
Year	Total Installed Capacity	Net Firm Capacity Purchases	Total Capacity Available	System Firm Peak Demand	System Total Peak Demand	Firm Reserve Margin w/o Planned Additions			Supply-Side Reserve Margin w/o Planned Additions			
	MW	MW	MW	MW	MW	MW	% of Peak	Shortfall for 20% MW	MW	% of Peak	Shortfall for 7% MW	
2012	4,292	617	4,909	3,763	4,008	1,146	30.5%	N/A	901	23.9%	N/A	
2013	4,312	421	4,733	3,784	4,023	949	25.1%	N/A	710	18.8%	N/A	
2014	4,312	421	4,733	3,823	4,049	910	23.8%	N/A	684	17.9%	N/A	
2015	4,312	421	4,733	3,859	4,082	874	22.7%	N/A	651	16.9%	N/A	
2016	4,312	398	4,710	3,900	4,125	810	20.8%	N/A	585	15.0%	N/A	
2017	4,312	121	4,433	3,940	4,165	493	12.5%	294	268	6.8%	8	
2018	4,312	121	4,433	3,980	4,207	453	11.4%	343	226	5.7%	53	
2019	4,312	0	4,312	4,022	4,250	290	7.2%	515	62	1.5%	220	
2020	4,312	0	4,312	4,064	4,292	248	6.1%	565	20	0.5%	264	
2021	4,312	0	4,312	4,103	4,331	209	5.1%	612	(19)	-0.5%	306	

Appendix L: Tampa Electric Final Reliability Analysis


Forecast of Capacity and Demand at Time of Summer Peak

Year	Total Installed Capacity MW	Net Firm Capacity Purchases MW	Total Capacity Available MW	System Firm Peak Demand MW	System Total Peak Demand MW	Reserve Margin			Supply-Side Reserve Margin		
						MW	% of Peak	Shortfall for 20% MW	MW	% of Peak	Shortfall for 7% MW
2012	4,292	617	4,909	3,763	4,008	1,146	30.5%	N/A	901	23.9%	N/A
2013	4,312	421	4,733	3,784	4,023	949	25.1%	N/A	710	18.8%	N/A
2014	4,312	421	4,733	3,823	4,049	910	23.8%	N/A	684	17.9%	N/A
2015	4,312	421	4,733	3,859	4,082	874	22.7%	N/A	651	16.9%	N/A
2016	4,312	398	4,710	3,900	4,125	810	20.8%	N/A	585	15.0%	N/A
2017	4,771	121	4,892	3,940	4,165	952	24.2%	N/A	727	18.5%	N/A
2018	4,771	121	4,892	3,980	4,207	912	22.9%	N/A	685	17.2%	N/A
2019	4,920	0	4,920	4,022	4,250	898	22.3%	N/A	670	16.7%	N/A
2020	4,920	0	4,920	4,064	4,292	856	21.1%	N/A	628	15.5%	N/A
2021	4,920	0	4,920	4,103	4,331	817	19.9%	4	589	14.4%	N/A

Appendix M: FRCC Reliability Analysis

Forecast of Capacity and Demand at Time of Summer Peak with Planned Additions									
Year	Total Installed Capacity	Net Firm Capacity Purchases	Total Capacity Available	System Firm Peak Demand	System Total Peak Demand	Firm Reserve Margin With Exercising Load Mgmt & Int.		Reserve Margin w/o Exercising Load Mgmt & Int.	
	MW	MW	MW	MW	MW	MW	% of Peak	MW	% of Peak
2012	47,747	6,486	54,233	42,430	45,613	11,803	27.8%	8,620	18.9%
2013	48,506	6,316	54,822	43,041	46,270	11,781	27.4%	8,552	18.5%
2014	49,730	5,613	55,343	43,618	46,857	11,725	26.9%	8,486	18.1%
2015	51,567	5,614	57,181	44,459	47,758	12,722	28.6%	9,423	19.7%
2016	52,118	4,473	56,591	45,242	48,594	11,349	25.1%	7,997	16.5%
2017	52,553	4,296	56,849	45,802	49,244	11,047	24.1%	7,605	15.4%
2018	52,539	4,382	56,921	46,152	49,643	10,769	23.3%	7,278	14.7%
2019	53,585	4,263	57,848	46,803	50,356	11,045	23.6%	7,492	14.9%
2020	53,667	4,180	57,847	47,581	51,191	10,266	21.6%	6,656	13.0%
2021	55,968	3,973	59,941	48,273	51,933	11,668	24.2%	8,008	15.4%

Appendix N: FRCC Reliability Sensitivity Analysis



Appendix O: Technology Assumptions

Screening Data

NAME	Solar		Wind	Wind	Aero CT	7FA CT
	Solar PV	Thermal	Onshore	Offshore		
CAPACITY (MW)	10	100	50	300	61	177
BASE YEAR CAPITAL COST (\$000)	62,200	668,200	119,177	1,620,000	40,624	119,498
BASE YEAR CAPITAL RATE (\$/kW)	6,220	6,682	2,384	5,400	666	675
BASE YEAR FIXED O&M (\$000/Year)	311	0	0	6,900	1,265	1,359
BASE YEAR FIXED O&M (\$/kW-yr)	31.09	0.00	0.00	23.00	20.73	7.68
USE FIXED O&M STREAM BELOW? (Y/N)						
[If No, rate will be escalated on next page]	N	N	N	N	N	N
BASE YEAR VARIABLE O&M (\$/MWh)	0.00	23.32	23.63	29.02	3.87	3.87
USE VARIABLE O&M STREAM BELOW? (Y/N)						
[If No, rate will be escalated on next page]	N	N	N	N	N	N
BASE YEAR FUEL RATE (\$/MWH)	-	-	-	-	-	-
USE FUEL STREAM BELOW? (Y/N)						
[If No, rate will be escalated on next page]	Y	Y	Y	Y	Y	Y
K-FACTOR	1.5937	1.5937	1.5937	1.5937	1.5937	1.5937
REMAINING LIFE (Years)	25	25	25	25	25	25
Levlized Fixed Charge Rate (FCR)	0.1382	0.1382	0.1382	0.1382	0.1382	0.1382

NAME	Nuclear	IGCC	CFB	SCPC	NGCC	Biomass
	CAPACITY (MW)	1,140	623	295	785	530
BASE YEAR CAPITAL COST (\$000)	5,799,264	3,055,080	1,185,554	2,593,916	680,470	173,195
BASE YEAR CAPITAL RATE (\$/kW)	5,087	4,904	4,019	3,304	1,283	4,948
BASE YEAR FIXED O&M (\$000/Year)	15,358	20,198	11,411	21,907	3,333	3,990
BASE YEAR FIXED O&M (\$/kW-yr)	13.47	32.42	38.68	27.91	6.28	114.00
USE FIXED O&M STREAM BELOW? (Y/N)						
[If No, rate will be escalated on next page]	N	N	N	N	N	N
BASE YEAR VARIABLE O&M (\$/MWh)	3.86	6.63	1.97	1.55	4.27	15.65
USE VARIABLE O&M STREAM BELOW? (Y/N)						
[If No, rate will be escalated on next page]	N	N	N	N	N	N
BASE YEAR FUEL RATE (\$/MWH)	-	-	-	-	-	-
USE FUEL STREAM BELOW? (Y/N)						
[If No, rate will be escalated on next page]	Y	Y	Y	Y	Y	Y
K-FACTOR	1.6301	1.5937	1.5937	1.5937	1.5937	1.5937
REMAINING LIFE (Years)	40	25	25	25	25	25
Levlized Fixed Charge Rate (FCR)	0.1265	0.1382	0.1382	0.1382	0.1382	0.1382

Appendix P : RFP Qualitative Factors

	PK 2-5	Proposal A	Proposal B	Proposal C	Proposal D
Technology Type	Combined Cycle	Combined Cycle	Peakers	Peaker	Peaker
Transmission Reliability, Voltage Support, Reserves	High High	High High	Medium Low	Medium Low	Medium Low
Water Availability	Municipal Source	Municipal Source	Limited, water use caution area	Unknown	Unknown
Dual Fuel Capability	2 CTs - Yes, 2 CTs - Capable	No	2 CTs - Yes	1 CT - Yes	1 CT - Yes
Project Execution	Low risk	Existing Unit	Existing Unit	Low risk	Low risk
Project Operation	TEC	Owner	ST – contractors LT – TEC employees	Contractor	Contractor
Project Maintenance	CSA	Self-managed, as needed	CSA and CT spares modeled	Self-managed, as needed	Self-managed, as needed
Project Security	Investment Grade	Low – offered lien or step in rights	Investment Grade	Investment Grade	Investment Grade
Environmental Emission Rates	Lower	Lower	Higher	Higher	Higher
Renewable Option	30 MW Solar	None	None	None	None
Simple Cycle Capability	Yes	No	Yes	Yes	Yes
Job Creation and Tax Base	Construction labor	No: existing unit	No: existing unit TEC may increase O&M	Construction, O&M labor	Construction, O&M labor

Appendix Q: Polk 2-5 Preliminary Project Schedule

**POLK 2-5 COMBINED CYCLE PROJECT
MAJOR MILESTONE SCHEDULE**

Award Contract for Steam Turbine Generator Supply	January 4, 2013
Award Contract for Heat Recovery Steam Generator Supply	April 12, 2013
Award Contract for Preliminary Construction	November 22, 2013
Receive Permits and Modified Site Certification	January 31, 2014
Begin Construction (Plant and Transmission)	February 3, 2014
Award Contract for Construction	March 21, 2014
Begin Tie-in Outages on Existing Units	September 1, 2014
Begin Combined Cycle Startup and Testing	May 2, 2016
Transmission System Upgrades Complete	November 4, 2016
Commercial Operation	January 2, 2017

Appendix R: Polk 2-5 Environmental Permit Requirements

Permit	Review/ Approval Agencies	Status/Comments
• Florida Electrical Power Plant Siting Act (PPSA)	FDEP/Affected Agencies/Siting Board	
○ PSD air construction permit	FDEP	
○ NPDES industrial wastewater treatment permit	FDEP	
• Ground water discharge permit	FDEP	
• Consumptive water use permit	SWFWMD	
○ Section 404 dredge-and-fill permit	USACE/ FDEP	
○ Section 10 permit	USACE	
○ Endangered/threatened species review	USFWS/ FFWCC	
• Section 401 water quality certification	FDEP	
• Environmental resource permit/storm water management	FDEP	
• Water well construction permit	FDEP	
• Non-transient, non-community water system permit	FDEP	
• Domestic septic system permit	Polk County	
• NPDES storm water permit NOI associated with industrial activity	FDEP	
• Solid waste management facilities permit	FDEP	
Determination of need	FPSC	
○ NPDES general permit NOI for storm water for construction sites	EPA	
✦ Phase II Title IV acid rain permit	FDEP/EPA	

Permit	Review/ Approval Agencies	Status/Comments
✦ Title V air emissions operation permit	FDEP	
• Construction dewatering permit	SWFWMD	
✦ Hazardous waste generator registration	EPA/ FDEP	
Notice of construction in navigable aerospace	FAA	
✦ Aboveground storage tank (AST) registration	FDEP	
✦ Spill prevention, control, and countermeasure plan	EPA	
✦ Facility response plan	EPA/FDEP	
• Zoning/local comprehensive plan	Polk County	Already consistent with zoning for Power Plant use.

- Reviewed and approved as part of the PPSA process; required prior to start of construction.
- Reviewed concurrently with the PPSA process with separate permit issued 30 to 45 days after issuance of certification by Siting Board; required prior to start of construction.
- ✦ Not required prior to start of construction.

Note: EPA = U.S. Environmental Protection Agency.
 FAA = Federal Aviation Administration.
 FDEP = Florida Department of Environmental Protection.
 FFWCC = Florida Fish and Wildlife Conservation Commission.
 FPSC = Florida Public Service Commission.
 USACE = U.S. Army Corps of Engineers
 SWFWMD = Southwest Florida Water Management District.

Appendix S: Transmission Interconnection and Integration Diagrams

The content of pages 84-85 has been redacted and filed separately with a request for confidential classification.

The content of pages 84-85 has been redacted and filed separately with a request for confidential classification.

The content of pages 84-85 has been redacted and filed separately with a request for confidential classification.



BEFORE THE
FLORIDA PUBLIC SERVICE COMMISSION

DOCKET NO. 120234-EI
IN RE: TAMPA ELECTRIC COMPANY'S
PETITION TO DETERMINE NEED FOR
POLK 2-5 COMBINED CYCLE CONVERSION

DIRECT TESTIMONY AND EXHIBIT
OF
MARK J. HORNICK

1 **BEFORE THE FLORIDA PUBLIC SERVICE COMMISSION**

2 **PREPARED DIRECT TESTIMONY**

3 **OF**

4 **MARK J. HORNICK**

5
6 **Q.** Please state your name, business address, occupation and
7 employer.

8
9 **A.** My name is Mark J. Hornick. My business address is 702
10 North Franklin Street, Tampa, Florida 33602. I am
11 employed by Tampa Electric Company ("Tampa Electric" or
12 "company") in the position of Director of Engineering
13 and Project Management.

14
15 **Q.** Please provide a brief outline of your educational
16 background and business experience.

17
18 **A.** I received a Bachelor of Science Degree in Mechanical
19 Engineering in 1981 from the University of South
20 Florida. I am a registered professional engineer in the
21 state of Florida. I began my career with Tampa Electric
22 in 1981 as an Engineer Associate in the Production
23 Department. I have held a number of engineering and
24 management positions at Tampa Electric's power
25 generating stations. From 1991 to 1998, I was a manager

1 at Big Bend Power Station with various responsibilities
2 including serving as Manager of Operations from 1995 to
3 1998. In July 1998, I was promoted to Director - Fuels
4 where I was responsible for managing Tampa Electric's
5 fuel procurement and transportation activities.

6
7 In March 2000, I transferred to General Manager - Polk
8 and Phillips Power Stations, where I was responsible for
9 the overall operation of these two generating
10 facilities. I have broad experience in the engineering
11 and operation of power generation equipment using oil,
12 natural gas, coal and other solid fuels and technologies
13 including conventional steam cycle, combustion turbine
14 in simple cycle and combined cycle as well as Integrated
15 Gasification Combined Cycle ("IGCC"). I am a past
16 Chairman of the Gasifier Users Association, an
17 international group of users and potential users of
18 gasification technology.

19
20 In my current role as Director of Engineering and
21 Project Management I am responsible for centralized
22 engineering support for all operating power stations and
23 for the management of large capital projects including
24 new generating units.

25

1 Q. What is the purpose of your direct testimony?

2

3 A. The purpose of my direct testimony is to describe the
4 engineering and construction of the proposed Polk 2-5
5 Combined Cycle Conversion ("Polk 2-5"). I will describe
6 the proposed facilities and their operating
7 characteristics. Additionally, I will discuss the
8 schedule for completing construction of Polk 2-5 and
9 Tampa Electric's project execution plan. Finally, I
10 will describe the development of the reasonable and
11 prudent project cost estimates.

12

13 Q. Have you prepared an exhibit to support your direct
14 testimony?

15

16 A. Yes, Exhibit No. ____ (MJH-1) was prepared under my
17 direction and supervision. It consists of the following
18 documents:

19 Document No. 1 Polk site aerial photograph

20 Document No. 2 Process Diagram - 4 x 1 Combined
21 Cycle Configuration

22 Document No. 3 Project Schedule

23 Document No. 4 Cost Estimate

24

25 Q. Are you sponsoring any sections of Tampa Electric's

1 Determination of Need Study for Electrical Power: Polk
2 2-5 Combined Cycle Conversion ("Need Study")?
3

4 **A.** Yes. I sponsor the section of the Need Study regarding
5 Tampa Electric's Proposed Unit. Specifically, I sponsor
6 sections IX.A "Overview," IX.B "Description," IX.E
7 "Cost" and IX.F "Schedule."
8

9 **Q.** Did you participate in Tampa Electric's evaluation of
10 supply alternatives?
11

12 **A.** Yes. In addition to natural gas combined cycle ("NGCC")
13 technology, Tampa Electric considered other technologies
14 including conventional steam cycle, simple cycle
15 combustion turbines, IGCC, solar and other renewables.
16 My team provided capital costs and construction
17 schedules for these alternatives. Tampa Electric
18 witness R. James Rocha describes the company's
19 evaluation of alternative generating technologies, which
20 demonstrates that the proposed NGCC unit is the most
21 cost-effective, reliable option for Tampa Electric.
22

23 **Q.** What considerations were used in determining that the
24 conversion of the four existing simple cycle combustion
25 turbines ("CTs") at Polk Power Station was the best

1 option for generation expansion?
2

3 **A.** Tampa Electric considered a number of factors in the
4 evaluation of the best technology choice for generation
5 expansion. The primary consideration is the capability
6 to reliably serve the peak demand needs of our customers
7 in the future. Any new generating unit will have to
8 comply with all environmental laws regarding regulated
9 emissions. The overall life cycle cost of the unit,
10 including installed cost and ongoing operation and
11 maintenance expenses should be as low as practicable.
12 In addition to unit reliability and environmental
13 performance, other operating factors such as efficiency,
14 fuel diversity, "dispatchability" (flexibility to start-
15 up, shut-down and rapidly change output) are strong
16 considerations.

17
18 **PROJECT DESCRIPTION**

19 **Q.** Please describe the planned project.
20

21 **A.** Tampa Electric plans to make use of its experience with
22 NGCC technology to construct Polk 2-5, an NGCC power
23 plant at Polk Power Station, the site of Tampa
24 Electric's existing IGCC facility. Polk Power Station
25 occupies over 2,800 acres on State Road 37 in Polk

1 County, Florida, approximately 40 miles southeast of
2 Tampa and about 60 miles southwest of Orlando. An
3 aerial diagram of the Polk site is provided as Document
4 No. 1 of my exhibit.

5
6 The existing Units 2-5 were constructed over the past
7 twelve years to meet incremental demand growth in a
8 manner which was very cost effective to our customers.
9 To further reduce the costs to our customers, the
10 company relocated Units 4 and 5 from a cancelled project
11 instead of purchasing new equipment. The units were
12 arranged with the future plan of converting them into a
13 highly efficient combined cycle ("CC") plant.

14
15 After conversion, with no additional fuel consumption,
16 Polk 2-5 will generate an incremental net 352 MW of
17 electricity in winter at 32 degrees Fahrenheit and 339
18 MW in the summer at 92 degrees Fahrenheit. In addition,
19 Polk 2-5 will utilize supplemental firing, also known as
20 duct burners, to provide additional cost effective
21 peaking capacity that will offset the need for future
22 peaking unit construction. With supplement firing, the
23 additional net electrical output of Polk 2-5 will
24 increase to 463 MW in the winter and 459 MW in the
25 summer.

1 The average annual net heat rate, higher heating value,
2 is expected to be about 7,064 Btu/kWh (48 percent
3 efficiency), and the instantaneous heat rate is expected
4 to be 6,803 (50 percent efficiency) Btu/kWh at an
5 average temperature of 73 degrees Fahrenheit without
6 supplemental firing. Two of the combustion turbines
7 will have the capability of firing distillate oil as a
8 backup fuel.

9
10 The supplemental firing will provide peaking capacity at
11 an incremental heat rate of 8,240 Btu/kWh, which
12 compares very favorably to a simple cycle CT with a heat
13 rate of over 10,000 Btu/kWh.

14
15 **Q.** Please briefly describe the power generation technology
16 that Polk 2-5 will utilize.

17
18 **A.** Polk 2-5 will be a NGCC facility consisting of four CTs,
19 four heat recovery steam generators ("HRSGs") and a
20 single steam turbine ("ST") arranged in a 4x4x1
21 configuration. The technology is a combination of a
22 combustion turbine (Brayton) cycle and a traditional
23 steam (Rankine) cycle. The combination of the two
24 technologies allows for thermal efficiencies of 50
25 percent and higher.

1 This is a proven technology with which Tampa Electric
2 and the industry in general have significant experience
3 designing, constructing and operating.
4

5 **Q.** Please describe the various components and systems that
6 will make up Polk 2-5.
7

8 The project will utilize the four existing General
9 Electric 7FA combustion turbines on site. We will add
10 triple pressure HRSGs to each of these CTs to capture
11 the waste heat in the exhaust. The HRSGs will also have
12 supplemental firing capability to add approximately 120
13 MW of peaking capacity.
14

15 The steam generated in the four HRSGs will be used in a
16 new ST generator. The ST generator will exhaust into a
17 water cooled condenser which will utilize the existing
18 cooling reservoir at the Polk Power Station for heat
19 rejection. Use of the existing cooling reservoir
20 infrastructure will allow Polk 2-5 to operate with lower
21 water consumption and lower parasitic load than if a
22 cooling tower were used for the ST heat rejection
23 system.
24

25 A new cooling tower will also be constructed to provide

1 equipment cooling for Polk 2-5 as well as Polk Unit 1.
2 This is necessary to optimize the heat loading on the
3 existing cooling reservoir and mitigate operational
4 impacts that could occur due to increased water
5 temperature in the cooling reservoir.
6

7 **KEY PROJECT ATTRIBUTES**

8 **Q.** Please describe the beneficial aspects of utilizing the
9 "waste heat" from the four existing CTs to produce
10 additional electricity from the Polk site.
11

12 **A.** Polk 2-5 are currently configured as simple cycle
13 combustion turbines with a summer capability of 151 MW
14 each. Simple cycle CTs are relatively low in cost and
15 have the ability to rapidly startup, shutdown and change
16 power output. These machines are good choices for
17 meeting peak power demands.
18

19 The exhaust gases leaving CTs are over 1,000 degrees
20 Fahrenheit and contain a substantial amount of energy.
21 By recovering this heat energy, which otherwise would be
22 wasted, up to 352 MW in the winter and 339 MW in the
23 summer of net electric power can be generated without
24 any additional fuel input. Through the addition of heat
25 recovery the efficiency of these generating units will

1 be increased by approximately 37 percent.

2

3 **Q.** How will the Polk 2-5 project impact the environmental
4 profile of the generating units?

5

6 **A.** This project will provide significant environmental
7 benefits. The improvement in power generating
8 efficiency results in a direct reduction in emission
9 rate for all pollutants on a pound per MWH basis. The
10 project will therefore reduce CO₂ emission rates by
11 approximately 37 percent.

12

13 The project will also include the installation of
14 Selective Catalytic Reduction equipment ("SCRs") in each
15 HRSG to reduce NO_x emissions. The SCRs in combination
16 with cycle efficiency improvements will provide an
17 approximately 86 percent reduction in the NO_x emission
18 rate.

19

20 **Q.** Does the Polk 2-5 project allow for inclusion of
21 renewable energy in the future?

22

23 **A.** Yes. The project is being designed with the ability to
24 incorporate approximately 30 MW of solar energy in the
25 form of steam from solar thermal collectors located at

1 the Polk site. Integration of steam produced via solar
2 collectors into a CC plant is known as a solar hybrid
3 system as it uses the existing combined cycle steam
4 turbine rather than a separate turbine dedicated to
5 solar use.

6
7 Renewable energy from solar thermal hybrid systems is
8 more reliable than other solar technologies because it
9 has the capability to replace solar MWS with capacity
10 from duct firing in the HRSGs. This mitigates the
11 intermittent nature of solar energy due to cloud cover
12 or darkness.

13
14 **Q.** Please discuss the operating flexibility of the proposed
15 project and how system reliability will be impacted.

16
17 **A.** The project is being designed to allow operation of each
18 CT in either simple cycle or CC mode by use of diverter
19 dampers which allow hot exhaust gases to bypass the
20 HRSG. This gives system operators the ability to use
21 the rapid response of CTs when needed for peaking
22 service and the ability to achieve high efficiency in CC
23 mode to serve intermediate and base load needs. In
24 addition, this allows the existing simple cycle capacity
25 to be available for dispatch during times when the steam

1 turbine is unavailable.

2

3 **Q.** What benefit does the inclusion of supplemental firing
4 of the four HRSGs provide?

5

6 **A.** Supplemental firing (or duct firing) provides additional
7 peaking power capability at low cost. The project will
8 incorporate approximately 30 MW of supplemental firing
9 into each HRSG for a total of approximately 120 MW. The
10 steam turbine will be sized to accommodate this
11 additional steam input. Supplemental firing has a very
12 rapid response rate and can be used to supply spinning
13 reserve capacity on the system. The heat rate and
14 installed cost of supplemental firing is lower than
15 other rapid response peaking options such as aero-
16 derivative CTs. In addition, supplemental firing
17 capability must be included in the original design and
18 equipment sizing and will not be able to be added at a
19 later date.

20

21 **Q.** Why is dual fuel capability important and how will this
22 project benefit?

23

24 **A.** The capability to utilize either natural gas or
25 distillate oil as a fuel improves the reliability of the

1 power generating units. In circumstances when the
2 natural gas supply to the facility is curtailed or
3 unavailable, dual fuel units can be operated on
4 distillate oil. This capability is becoming more
5 important as a larger percentage of the generating units
6 in Florida rely on natural gas as a fuel.

7
8 Dual fuel capability can also serve to reduce the cost
9 of supplying natural gas to the generating unit(s) via
10 pipeline. Pipeline transportation services can be
11 purchased on a firm basis with known quantities and a
12 fixed price. These are generally "take or pay"
13 agreements. Alternately, pipeline capacity can obtained
14 each day on an "as available" basis. The reliability of
15 supply is greater with firm transportation than with as
16 available transportation, however, the total cost is
17 generally higher with firm agreements. With dual fuel
18 capability, a larger percentage of pipeline capacity can
19 be obtained "as available" since the unit can be
20 operated on distillate oil in the event gas
21 transportation cannot be secured.

22
23 **Q.** Please describe the location of the Polk site and any
24 reliability benefits that may be associated with
25 expanding generating capacity at this location.

1 **A.** The Polk Power Station is located approximately 40 miles
2 inland from the Gulf of Mexico at an elevation of
3 approximately 100 feet. This inland location makes it
4 much less likely to suffer damage in the event of a
5 hurricane than coastal facilities.

6
7 **Q.** How will the electric transmission upgrades associated
8 with this project benefit ratepayers?

9
10 **A.** The Polk 2-5 project will provide the interconnection
11 from the new steam turbine generator to the grid and
12 will also include upgrades to the transmission system to
13 allow for the delivery of this energy to customers
14 located west of the facility. These upgrades will
15 relieve transmission congestion in the region and
16 improve both the reliability of the grid and reduce the
17 cost to customers from the ability to economically
18 optimize generating unit operation. This is described
19 in the direct testimony of Tampa Electric witness S.
20 Beth Young.

21
22 **Q.** What source of water will be used to supply the proposed
23 project?

24
25 **A.** The project will utilize reclaimed water from the City

1 of Lakeland to meet the majority of makeup water needs.
2 The use of reclaimed water will be maximized, however
3 ground water can be used to supplement the supply if
4 needed. In addition, by using the existing cooling
5 water reservoir at the site for the majority of the new
6 cooling duty, water use from evaporative losses will be
7 reduced relative to using a cooling tower for this
8 service.

9
10 **OPERATING PERFORMANCE**

11 **Q.** What is the expected heat rate for Polk 2-5?
12

13 **A.** Polk 2-5 is expected to have an average annual net heat
14 rate of 7,064 Btu/kWh, and an instantaneous net heat
15 rate of 6,803 Btu/kWh at an average temperature of 73
16 degrees Fahrenheit without supplemental firing.
17

18 **Q.** Please describe the expected availability for Polk 2-5.
19

20 **A.** The expected Equivalent Availability Factor ("EAF") for
21 Polk 2-5 is 96.2 percent averaged over the life of the
22 unit, based on a Planned Outage Rate of 3.2 percent and
23 a Forced Outage Rate of 0.7 percent.
24

25 **Q.** What is your conclusion regarding the reasonableness of

1 these heat rate and availability expectations?

2
3 **A.** The efficiency and availability estimates for the Polk
4 2-5 facility have been developed by the engineering firm
5 of Black and Veatch along with Tampa Electric. Black
6 and Veatch has engineered a number of CC units in
7 Florida and around the world. Based on my experience
8 with engineering and operating power plants, I believe
9 the estimated heat rate and availability factors are
10 reasonable.

11

12 **PROJECT MANAGEMENT AND CONSTRUCTION**

13 **Q.** What is the expected construction schedule for Polk 2-5?

14

15 **A.** If approved, construction will begin in 2014, and Polk
16 2-5 is expected to enter commercial operation in January
17 2017.

18

19 **Q.** Please describe Tampa Electric's efforts to obtain the
20 required certifications and permits to begin
21 construction of Polk 2-5.

22

23 **A.** Tampa Electric began developing design information to
24 support permit application preparation in February 2012.
25 The company entered into a contract with Environmental

1 Consulting & Technology Inc. The permit activities are
2 described in the direct testimony of Tampa Electric
3 witness David M. Lukcic.
4

5 **Q.** What is the current schedule for the project?
6

7 **A.** Document No. 3 of my exhibit outlines the project
8 schedule. Conceptual design began in late 2011, and the
9 preliminary engineering package development began in
10 February 2012 and was completed in May 2012. The Site
11 Certification Application will be filed with the Florida
12 Department of Environmental Protection in September
13 2012. The detailed design and procurement will begin in
14 January 2013. Detailed design and procurement
15 activities are expected to continue through November
16 2014. Construction activities are expected to begin in
17 the first quarter 2014 with general site work.
18 Commissioning of the equipment is expected to begin in
19 February 2016. Finally, the unit is expected to begin
20 commercial operation in January 2017.
21

22 **Q.** What is Tampa Electric doing to mitigate the effects of
23 potential construction schedule uncertainty?
24

25 **A.** The construction effort will be managed by a Tampa

1 Electric construction management group which is
2 experienced in managing large complex construction
3 projects. In addition, the project schedule is being
4 developed to allow for approximately one month of float
5 per year of construction to provide a schedule
6 contingency for unplanned events.
7

8 **Q.** Does Tampa Electric have experience in building and
9 operating combined cycle power plants similar to the
10 proposed Polk 2-5 facility?
11

12 **A.** Yes. Tampa Electric constructed and has operated since
13 2003 the H. L. Culbreath Bayside Power Station ("Bayside
14 Power Station") which consists of 4x4x1 and 3x3x1 NGCC
15 units. This \$700 million project was constructed on
16 schedule and under budget.
17

18 **Q.** Is NGCC technology used successfully at Tampa Electric's
19 Bayside Power Station?
20

21 **A.** Yes. By a number of measures, NGCC technology has been
22 successfully implemented by Tampa Electric. The company
23 has used NGCC technology to generate more than 66
24 million MWH of electricity. These units have met
25 efficiency and availability expectations and are a vital

1 part of Tampa Electric's generating unit portfolio.
2

3 **PROJECT COST**

4 **Q.** What is Tampa Electric's estimate of the overnight
5 construction costs for Polk 2-5?
6

7 **A.** The overnight construction cost estimate is \$424.4
8 million in 2012 dollars.
9

10 **Q.** Please explain what is included in the cost estimate.
11

12 **A.** Document No. 4 of my exhibit provides the details of the
13 cost estimate. The \$424.4 million cost estimate
14 represents overnight construction costs for conversion
15 work on Polk 2-5. This includes all engineering,
16 procurement, construction, commissioning, owner's costs
17 and an allowance for indeterminates. The project
18 estimate does not include related transmission additions
19 or modifications or escalation.
20

21 **Q.** What is Tampa Electric's estimate of the total in-
22 service costs for Polk 2-5?
23

24 **A.** The total in-service cost estimate for Polk 2-5 is
25 \$610.4 million, which includes the aforementioned

1 overnight construction costs as well as escalation and
2 transmission upgrades. Owner's costs include project
3 development costs such as technology development and
4 environmental permitting; project management and
5 operational support and training; legal and other
6 professional services costs; and insurance. Tampa
7 Electric estimated the owner's costs for Polk 2-5 based
8 on its experience developing and constructing generating
9 units in Florida.

10
11 The \$147.2 million costs of required transmission
12 facilities to integrate and interconnect Polk 2-5 with
13 Tampa Electric's system are separately identified and
14 are described in the direct testimony of witness Young.

15
16 **Q.** Did Tampa Electric conduct sensitivity analysis with
17 regards to project construction costs?

18
19 **A.** Yes. The base case is considered the most likely cost
20 based on current equipment market conditions, labor costs
21 and escalation rates. Tampa Electric also applied
22 sensitivities to the base case by utilizing high and low
23 construction cost bands to consider the effect of higher
24 and lower demand for equipment as well as materials and
25 labor costs. Compared to the base case, the low band

1 construction cost is 7 percent lower and the high band
2 construction cost is 6 percent higher.

3
4 **Q.** Will subsequent engineering work result in changes to
5 the installed cost estimate for Polk 2-5?

6
7 **A.** Perhaps. The cost estimate represents the best estimate
8 Tampa Electric has to date for the planned project
9 configuration. The estimate does not include costs for
10 changes in the scope of the project or significant
11 modifications of the planned configuration. During
12 subsequent engineering work, our intent is to optimize
13 the design of the project to minimize the lifetime cost
14 to our customers. Such changes will be evaluated and
15 justified based on the impact to the cost and
16 performance of the project. Approved changes could
17 result in increases or decreases to the cost estimate.

18
19 **Q.** What contracting strategy and competitive pricing
20 options will Tampa Electric pursue to manage the cost
21 and schedule of Polk 2-5?

22
23 **A.** Tampa Electric is planning to competitively bid all the
24 major equipment required for Polk 2-5. The precise
25 contracting strategy has not yet been finalized, but we

1 envision using multiple prime contractors to construct
2 Polk 2-5. These contracts will be fixed price or cost-
3 reimbursable depending on the contract. We plan to use
4 an appropriate mix of incentives and penalties to align
5 the various contractors with the project goals.
6

7 **Q.** What scope of services will Black and Veatch be
8 providing?
9

10 **A.** Currently Black and Veatch has been contracted to
11 perform the preliminary engineering work for both the
12 generating plant and the associated transmission
13 facilities. It is anticipated that, going forward,
14 Black and Veatch will perform the detailed engineering,
15 procurement services and support Tampa Electric's
16 Construction Management team.
17

18 **Q.** What is the current status of Polk 2-5?
19

20 **A.** Tampa Electric is currently engaged in preliminary
21 engineering to develop the project permit applications.
22 Additional engineering efforts are also ongoing to
23 better define the major aspects of the plant design.
24 This information will be used to manage the detailed
25 engineering effort and refine cost estimates and the

1 project schedule.

2

3 **Q.** What is the basis for Tampa Electric's cost estimate for
4 the Polk 2-5 project?

5

6 **A.** Cost estimates are based on a preliminary design
7 completed by Black and Veatch. This design includes the
8 identification and sizing of all major plant components
9 as well as the integration of the unit to existing plant
10 systems. Black and Veatch has obtained multiple
11 quotations for major equipment and has validated current
12 pricing for commodities and labor in the central Florida
13 area.

14

15 **Q.** Please summarize Tampa Electric's efforts to ensure the
16 reasonableness of the Polk 2-5 total estimated installed
17 cost.

18

19 **A.** Tampa Electric has constructed many large capital
20 projects using a similar approach to the Polk 2-5
21 approach. Tampa Electric employs several strategies to
22 monitor and manage all phases of these projects
23 including: (1) establishing project contracts that will
24 provide the best value; (2) monitoring the work of the
25 engineering company to ensure that work is done in an

1 efficient manner; and (3) assigning full time project
2 controls personnel to manage the costs and the schedule
3 throughout the project execution. Dedicated Tampa
4 Electric personnel lead the project management
5 throughout construction and are integrally involved in
6 each phase of its development. The company's track
7 record using this approach is excellent.

8
9 In addition, the overnight construction cost estimate
10 was developed with support from Black & Veatch, which
11 has engineered and constructed numerous similar
12 facilities with a significant amount being in Florida.

13
14 **Q.** Is the total installed cost estimate reasonable?

15
16 **A.** Yes. The total estimated cost represents the best
17 efforts of both Tampa Electric and Black and Veatch. In
18 addition, if the book value of the existing combustion
19 turbines are taken into account, the estimated cost
20 compares favorably to similar projects recently
21 completed.

22
23 **Q.** Are there circumstances that may result in rapidly
24 increasing demand for combined cycle power generating
25 equipment?

1 **A.** Yes. There are several factors that are indicating that
2 the demand for natural gas fired generating equipment
3 will significantly increase in the next few years. The
4 economic downturn beginning in 2008 has reduced the
5 growth rate of electricity demand nationwide. A recovery
6 of the economy will reverse this effect and may increase
7 the demand for energy at a rapid rate.

8
9 Natural gas prices are at relatively low levels and are
10 forecasted to remain low for several years. This makes
11 gas fired generation a more attractive option versus
12 coal fired units. Natural gas fired technology is
13 typically less expensive to build than other options
14 including nuclear, coal, and renewable generating
15 options such as wind and solar. The combination of low
16 capital cost and forecasted low fuel prices currently
17 make natural gas fired units the most economical choice.

18
19 Recent environmental regulations have focused largely on
20 coal fired units. New or tightened regulations on
21 mercury and other metals, small particulates, coal
22 combustion by products and CO₂ have all put pressure on
23 coal fired generation. As a result, many utilities
24 across the nation have announced that they will shut
25 down older, less efficient coal fired units rather than

1 retrofit them with expensive emission controls.

2

3 The combination of coal unit retirements (reduced
4 supply) and economic recovery (increased demand) is
5 indication the likelihood of a large number of gas fired
6 units being constructed in the next few years.

7

8 In the late 1990's and early 2000's there was a large
9 spike in demand for gas fired units. This resulted in
10 what was termed a "gas bubble" situation where
11 manufacturers had difficulty meeting demand. The lead
12 time for equipment manufacture increased significantly
13 and prices escalated dramatically. The current
14 circumstances indicate that the industry may be on the
15 verge of a similar situation.

16

17 **Q.** How does the timing for the Polk 2-5 CC conversion
18 relate to the potential for an equipment demand spike?

19

20 **A.** The company has surveyed the industry suppliers of major
21 equipment needed for the projects. Currently the lead
22 times and pricing for HRSGs steam turbines, condensers
23 and cooling towers are reasonable. Several
24 manufacturers have indicated that they anticipate lead
25 times will extend and prices will go up in the near

1 future. Tampa Electric is working to issue proposals
2 and lock in prices for major equipment for Polk 2-5
3 early in 2013. A delay in the project could result in
4 cost increases if there is a market price spike.

5
6 **Q.** Please summarize your direct testimony.

7
8 **A.** If approved, Polk 2-5 will be converted to a highly
9 efficient NGCC facility which will offer numerous
10 benefits to Tampa Electric's customers. With no
11 additional fuel consumption, Polk 2-5 will generate up
12 to an additional 352 MW of electricity resulting in a 37
13 percent improvement in efficiency over the existing
14 units. The efficiency improvement will also provide an
15 equivalent reduction in air emission rates. Polk 2-5
16 will also include use of SCR technology, which combined
17 with the efficiency gains, will reduce NO_x emissions by
18 86 percent.

19
20 Polk 2-5 will have additional environmental benefits
21 such as being capable of future renewable integration,
22 use of reclaimed water, no additional land use and
23 permanent deferral of two future peaking units.

24
25 In summary, Polk 2-5 will be designed and constructed

1 for \$610.4 million in accordance with the project
2 schedule to provide cost effective, clean power for
3 Tampa Electric's customers.

4
5 **Q.** Does this conclude your direct testimony?

6
7 **A.** Yes, it does.

8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25

EXHIBIT

OF

MARK J. HORNICK


Table of Contents

DOCUMENT NO.	TITLE	PAGE
1	Polk Site Aerial Photograph	31
2	Process Diagram - 4 x 1 Combined Cycle Configuration	33
3	Project Schedule	35
4	Cost Estimate	37

TAMPA ELECTRIC COMPANY
DOCKET NO. 12 _____-EI
EXHIBIT NO. _____ (MJH-1)
DOCUMENT NO. 1
FILED: 09/12/2012

DOCUMENT NO. 1

POLK SITE AERIAL PHOTOGRAPH




TAMPA ELECTRIC COMPANY
DOCKET NO. 12 _____-EI
EXHIBIT NO. _____ (MJH-1)
DOCUMENT NO. 2
FILED: 09/12/2012

DOCUMENT NO. 2

PROCESS DIAGRAM - 4 X 1 COMBINED CYCLE

CONFIGURATION



34

POLK 2 COMBINED CYCLE PROJECT
 COMBINED CYCLE COMBUSTION TURBINE
 PROCESS FLOW DIAGRAM

TAMPA ELECTRIC COMPANY
 DOCKET NO. 12
 EXHIBIT NO. _____
 DOCUMENT NO. 2
 FILED: 09/12/2012
 (MJH-1)

TAMPA ELECTRIC COMPANY
DOCKET NO. 12 _____-EI
EXHIBIT NO. _____ (MJH-1)
DOCUMENT NO. 3
FILED: 09/12/2012

DOCUMENT NO. 3

PROJECT SCHEDULE

**POLK 2-5 COMBINED CYCLE PROJECT
MAJOR MILESTONE SCHEDULE**

Award Contract for Steam Turbine Generator Supply	January 4, 2013
Award Contract for Heat Recovery Steam Generator Supply	April 12, 2013
Award Contract for Preliminary Construction	November 22, 2013
Receive Permits and Modified Site Certification	January 31, 2014
Begin Construction (Plant and Transmission)	February 3, 2014
Award Contract for Construction	March 21, 2014
Begin Tie-in Outages on Existing Units	September 1, 2014
Begin Combined Cycle Startup and Testing	May 2, 2016
Transmission System Upgrades Complete	November 4, 2016
Commercial Operation	January 2, 2017

TAMPA ELECTRIC COMPANY
DOCKET NO. 12 _____-EI
EXHIBIT NO. _____ (MJH-1)
DOCUMENT NO. 4
FILED: 09/12/2012

DOCUMENT NO. 4

COST ESTIMATE

**POLK 2-5 CONVERSION PROJECT
PROJECT COST ESTIMATE**

	(\$000)
Direct Construction Costs	352,610
Indirect Construction Costs	71,813
Total Generating Plant Cost	424,422
Transmission Upgrade Cost	147,193
Escalation	38,825
Total Project Before AFUDC	610,440
AFUDC	96,179
<hr/> Total Expected Project Cost	<hr/> 706,619



BEFORE THE
FLORIDA PUBLIC SERVICE COMMISSION

DOCKET NO. 120234 -EI
IN RE: TAMPA ELECTRIC COMPANY'S
PETITION TO DETERMINE NEED FOR
POLK 2-5 COMBINED CYCLE CONVERSION

DIRECT TESTIMONY AND EXHIBIT
OF
LORRAINE L. CIFUENTES

1 **BEFORE THE FLORIDA PUBLIC SERVICE COMMISSION**

2 **PREPARED DIRECT TESTIMONY**

3 **OF**

4 **LORRAINE L. CIFUENTES**

5
6 **Q.** Please state your name, business address, occupation and
7 employer.

8
9 **A.** My name is Lorraine L. Cifuentes. My business address is
10 702 North Franklin Street, Tampa, Florida 33602. I am
11 employed by Tampa Electric Company ("Tampa Electric" or
12 "company") as Manager, Load Research and Forecasting in
13 the Regulatory Affairs Department.

14
15 **Q.** Please provide a brief outline of your educational
16 background and business experience.

17
18 **A.** In 1986, I received a Bachelor of Science degree in
19 Management Information Systems from the University of
20 South Florida. In 1992, I received a Masters of Business
21 Administration degree from the University of Tampa. In
22 October 1987, I joined Tampa Electric as a Generation
23 Planning Technician, and I have held various positions
24 within the areas of Generation Planning, Load Forecasting
25 and Load Research. In October 2002, I was promoted to

1 Manager, Load Research and Forecasting. My present
2 responsibilities include the management of Tampa
3 Electric's customer, peak demand and energy sales
4 forecasts as well as management of Tampa Electric's load
5 research program and other related activities.

6

7 **Q.** What is the purpose of your direct testimony?

8

9 **A.** The purpose of my direct testimony is to describe Tampa
10 Electric's load forecasting process, describe the
11 methodologies and assumptions, and present the load
12 forecast used in Tampa Electric's Determination of Need
13 Study for Electrical Power: Polk 2-5 Combined Cycle
14 Conversion ("Need Study"). Additionally, I will
15 demonstrate how the forecast is appropriate and
16 reasonable based on the assumptions provided.

17

18 **Q.** Have you prepared an exhibit to support your testimony?

19

20 **A.** Yes, I am sponsoring Exhibit No. ____ (LLC-1) consisting
21 of 10 documents, prepared under my direction and
22 supervision. These consist of:

23 Document No. 1 Economic Assumptions

24 Document No. 2 Billing Cycle Degree Days

25 Document No. 3 Customer Forecast

1	Document No. 4	Per Customer Energy Consumption
2	Document No. 5	Retail Energy Sales
3	Document No. 6	Per Customer Peak Demand
4	Document No. 7	Peak Demand
5	Document No. 8	Firm Peak Demand
6	Document No. 9	Firm Peak Load Factor
7	Document No. 10	Updated Firm Peak Demand

8

9 **Q.** Are you sponsoring any sections of Tampa Electric's Need
10 Study?

11

12 **A.** Yes. I sponsor section III.B. "Demand and Energy
13 Forecasts" of the Need Study.

14

15 **TAMPA ELECTRIC'S FORECASTING PROCESS**

16 **Q.** Please describe Tampa Electric's load forecasting
17 process.

18

19 **A.** Tampa Electric uses econometric models and statistically
20 adjusted engineering ("SAE") models, which are integrated
21 to develop projections of customer growth, energy
22 consumption and peak demands. The econometric models
23 measure past relationships between economic variables,
24 such as population, employment and customer growth. The
25 SAE models, which incorporate end-use structure into an

1 econometric model, are used for projecting average per-
2 customer consumption. These models have consistently
3 been used by Tampa Electric for generation planning
4 purposes and the modeling results have been submitted to
5 the Commission for review and approval in past regulatory
6 proceedings.

7
8 **Q.** Which assumptions were used in the base case analysis of
9 customer growth?

10
11 **A.** The primary economic drivers for the customer forecast
12 are Hillsborough County population estimates, service
13 area households and Hillsborough County employment. The
14 population forecast is the starting point for developing
15 the customer and energy projections. Both the University
16 of Florida's Bureau of Economic and Business Research
17 ("BEBR") and Moody's Economy.com provide population
18 projections. The population forecast is based upon the
19 projections of BEBR in the short-term and is a blend of
20 BEBR and Economy.com for the long-term forecast.
21 Economy.com provides projections of Hillsborough County
22 households and employment by major sectors. Service area
23 households and Hillsborough County employment assumptions
24 are utilized in estimating non-residential customer
25 growth. For example, an increase in the number of

1 households results in a need for additional services,
2 restaurants, and retail establishments. Additionally,
3 projections of employment in the construction sector are
4 a good indicator of expected increases and decreases in
5 local construction activity. Similarly, commercial and
6 industrial employment growth is a good indicator of
7 expected activity in their respective sectors. The ten-
8 year historical and forecasted average annual growth
9 rates for these economic indicators are shown in Document
10 No. 1 of my exhibit.

11
12 **Q.** Which assumptions were used in the base case analysis of
13 energy sales growth?

14
15 **A.** Customer growth and per-customer consumption growth are
16 the primary drivers for growth in energy sales. The
17 average per-customer consumption for each revenue class
18 is based on the SAE modeling approach. The SAE models
19 have three components. The first component includes
20 assumptions of the long-term saturation and efficiency
21 trends in end-use equipment. The second component
22 captures changes in economic conditions, such as
23 increases in real household income, changes in number of
24 persons per household, the price of electricity and how
25 these factors affect a residential customer's consumption

1 level. A complete list of the critical economic
2 assumptions used in developing these forecasts is shown
3 in Document No. 1 of my exhibit. The third component
4 captures the seasonality of energy consumption. Heating
5 and cooling degree day assumptions allocate the
6 appropriate monthly weather impacts and are based on
7 weather patterns over the past 20 years. Historical and
8 projected degree days are shown in Document No. 2 of my
9 exhibit.

10
11 **Q.** Which assumptions were used in the base case analysis of
12 peak demand growth?

13
14 **A.** Peak demand growth is affected by long-term appliance
15 trends, economic conditions and weather conditions. The
16 end-use and economic conditions are integrated into the
17 peak demand model from the energy sales forecast. The
18 weather variables are heating and cooling degree days at
19 the time of the peak and for the 24-hour period of the
20 peak day. Weather variables provide the seasonality to
21 the monthly peaks. By incorporating both temperature
22 variables, the model accounts for cold or heat buildup
23 that contributes to determining the peak day. The
24 temperature assumptions used are based on an analysis of
25 20 years of peak day temperatures. For the peak demand

1 forecast, the design temperature at the time of winter
2 and summer peak is 31 and 92 degrees Fahrenheit,
3 respectively.
4

5 **Q.** Is 31 degrees Fahrenheit the 20-year average temperature
6 at the time of the winter peak?
7

8 **A.** No. The 20-year average temperature at the time of the
9 winter peak is 35 degrees Fahrenheit. Although 31
10 degrees is not the 20-year average, it is representative
11 of the average temperature for the top ten coldest peak
12 days in the past 20 years and also the top five coldest
13 peak days in the past ten years. The 31 degrees
14 Fahrenheit assumption has consistently been used by Tampa
15 Electric for generation planning purposes and in peak
16 demand projections submitted to the Commission for review
17 and approval in prior regulatory proceedings.
18

19 **Q.** Is 92 degrees Fahrenheit the 20-year average temperature
20 at the time of the summer peak?
21

22 **A.** Yes, 92 degrees Fahrenheit has consistently been the 20-
23 year average temperature at the time of the peak. It is
24 the summer peak demand projection that has been submitted
25 to the Commission in prior regulatory proceedings.

1 **Q.** Does Tampa Electric assess the reasonableness of these
2 base assumptions?

3
4 **A.** Yes. The base case economic assumptions have been
5 evaluated based on a comparison of the data series'
6 historical average annual growth rates to the projected
7 average annual growth rates for the forecast period. In
8 addition, each economic data series is compared to an
9 alternate source and evaluated for consistency.
10 Economy.com's projections for Florida employment by major
11 sectors and Florida real household income are compared to
12 the projections from the Office of Economic and
13 Demographic Research which is part of the Florida
14 Legislature. The projections for Florida employment
15 growth were consistent between the two sources;
16 therefore, it is reasonable to conclude that
17 Economy.com's Hillsborough County employment growth was
18 also reasonable.

19
20 **Q.** Were the forecasts for population growth also evaluated
21 for reasonableness?

22
23 **A.** Yes. Economy.com and BEBR's population forecasts were
24 also compared and evaluated for consistency. A blend of
25 the two sources was used and provides a reasonable

1 population projection.

2

3 **TAMPA ELECTRIC'S FORECASTED GROWTH**

4 **Q.** What is Tampa Electric's forecasted customer base?

5

6 **A.** Tampa Electric's current customer base is shown in
7 Document No. 3 of my exhibit. As of December 2011, Tampa
8 Electric's customer base was 675,799 retail accounts.

9

10 **Q.** What is Tampa Electric's projected customer growth?

11

12 **A.** Tampa Electric is projecting an average annual increase
13 of 9,597 new customers over the next ten years (2012-
14 2021). This average annual increase of 1.3 percent is
15 slightly lower than the average annual growth rate of 1.5
16 percent during the past ten years (2002-2011). Despite
17 the slightly lower customer growth rate, an increase of
18 over 86,000 customers is anticipated over the forecast
19 period as reflected in Document No. 3 of my exhibit.

20

21 **Q.** How does Tampa Electric's projected customer growth rates
22 compare with the growth rates experienced historically?

23

24 **A.** Customer growth rates are lower than those experienced
25 prior to the recent recession; however, customer growth

1 is considerably higher than it was in the recession
2 period between 2007 and 2009. Customer growth was flat
3 to declining during the recession period. Customer growth
4 rates are currently back up to 1.0 percent and are
5 expected to increase over the forecast horizon.
6

7 **Q.** What is Tampa Electric's energy sales forecast?
8

9 **A.** The primary driver behind the increase in the energy
10 sales forecast is customer growth. Additionally, per-
11 customer consumption is expected to decrease at an
12 average annual rate of 0.5 percent, as shown in Document
13 No. 4 of my exhibit. Combining the customer growth and
14 per-customer consumption, retail energy sales are
15 expected to increase at an average annual rate of 0.8
16 percent. Excluding the phosphate sector which has been
17 declining, retail energy sales are expected to increase
18 at an average annual rate of 1.0 percent. Historical and
19 forecasted energy sales are shown in Document No. 5 of my
20 exhibit.
21

22 **Q.** How does Tampa Electric's projected energy sales compare
23 with the 2011 Ten Year Site Plan ("TYSP")?
24

25 **A.** When compared to the 2011 TYSP (prior year's forecast),

1 both customer growth and per-customer energy consumption
2 were adjusted downward to capture the slower than
3 expected economic recovery. Additionally, energy sales
4 are growing at slower rates in the current TYSP. The
5 result is an average annual increase of 0.8 percent in
6 total retail sales compared to an increase of 1.1 percent
7 in the 2011 TYSP.

8
9 **Q.** What is Tampa Electric's peak demand forecast?

10
11 **A.** Summer and winter peak usage per-customer are both
12 projected to decrease at an average annual rate of 0.4
13 percent, which is consistent with historical per-customer
14 peak demand. Document No. 6 of my exhibit shows
15 historical and forecasted peak usage per-customer for
16 summer and winter peaks. The increase in customers and
17 the decrease in per-customer demand results in an average
18 annual growth rate of 1.0 percent for the winter peak and
19 a 0.9 percent growth rate for the summer peak. As shown
20 in Document No. 7 of my exhibit, peak demand for the
21 summer of 2012 is forecasted to be 3,993 MW, increasing
22 to 4,331 MW in 2021, an average increase of 38 MW per
23 year. The 2012 winter peak is forecasted to be 4,081 MW,
24 increasing to 4,453 MW in 2021, an average increase of 41
25 MW per year. Summer and winter firm peak demands, which

1 have been reduced by curtailable load such as load
2 management and interruptible loads, are shown in Document
3 No. 8 of my exhibit.
4

5 **Q.** How does Tampa Electric's projected peak demands compare
6 with the 2011 TYSP?
7

8 **A.** Similar to energy consumption, peak demands have been
9 adjusted downward and are growing at slower rates. The
10 result is an average annual increase of 0.9 percent in
11 summer peak demand compared to an increase of 1.3 percent
12 in the 2011 TYSP. Winter peak demands are increasing at
13 an average annual rate of 1.0 percent compared to an
14 increase of 1.3 percent in the 2011 TYSP.
15

16 **SENSITIVITY ANALYSIS**

17 **Q.** Has the company performed any sensitivity analyses on its
18 load forecast?
19

20 **A.** Yes. The base case scenario was tested for sensitivity
21 to varying economic conditions and customer growth rates.
22 The high and low peak demand and energy scenarios
23 represent an alternative to the company's base case
24 outlook. The high scenario represents more optimistic
25 economic conditions in the areas of customers, employment

1 and income. The low band represents less optimistic
2 scenarios in the same areas. Compared to the base case,
3 the expected customer and economic growth rates are 0.5
4 percent higher in the high scenario and 0.5 percent lower
5 in the low scenario.

6
7 **Q.** Were conservation and demand side management ("DSM")
8 impacts accounted for in the energy sales and peak demand
9 forecasts?

10
11 **A.** Yes. Tampa Electric forecasts demand and energy
12 reductions for each conservation and DSM program, which
13 are aggregated to represent the total cumulative savings.
14 The energy sales and peak demand forecasts were adjusted
15 by the total incremental savings each year.

16
17 **Q.** Are the forecasts described in your testimony and filed
18 in the 2012 TYSP the company's most recent customer,
19 demand and energy projections?

20
21 **A.** No. Those forecasts were based on the company's 2011
22 annual forecast process. The 2012 annual forecast
23 process was completed in June 2012.

24
25 **Q.** How do the more recent 2012 projections of customers,

1 demand and energy consumption compare to the forecasts
2 used in the need study?

3
4 **A.** The most current forecast of customers is higher than the
5 forecast presented in the need study. However, the
6 current energy sales and peak demand forecasts are lower
7 than the forecasts presented in the need study. The
8 primary factor that is driving the changes in the load
9 forecasts is the slower than expected economic recovery
10 and continued reduction in per-customer consumption.

11
12 **Q.** How much lower are the current demand and energy
13 forecasts compared to the forecasts used in the need
14 study?

15
16 **A.** Over the 10-year forecast horizon, the energy sales
17 forecast is an average of 3.5 percent lower than the
18 previous projections. The average firm peak demand
19 reductions in winter and summer are 2.9 percent and 2.7
20 percent respectively. The most current firm peak
21 projections are shown in Document No. 10 of my exhibit.

22
23 **Q.** Are the most current load forecasts still above the low
24 scenario in the sensitivity analysis?

25

1 **A.** Yes. In 2017, summer firm peak demand projections are
2 above the low scenario by 26 MW.

3
4 **Q.** Does Tampa Electric conclude that the forecasts of
5 customers, energy sales and demand are appropriate and
6 reasonable?

7
8 **A.** Yes. The results have been reviewed by Itron Corporation,
9 a leader in the load forecast consulting industry. The
10 average annual growth rates for per-customer demand and
11 energy usage are compared with each other for consistency
12 and compared to historical growth rates. Summer and
13 winter load factors are reviewed to ensure proper
14 integration of the peak and energy models. The results
15 show that the load factors are reasonable when compared
16 to historical years. Load factors have dropped slightly
17 due to the loss of phosphate load. The load factors are
18 shown in Document No. 9 of my exhibit.

19
20 **Q.** Please summarize your direct testimony.

21
22 **A.** Tampa Electric's service area will continue to grow at a
23 steady pace over the forecast horizon. Based on the most
24 current forecasts, we expect an average increase in
25 customers of 1.5 percent a year which is an increase of

1 almost 60,000 by 2017. As a result, winter and summer
2 firm peak demand is projected to increase by 162 MW and
3 136 MW, respectively, by 2017. The methods used for
4 developing the customer, demand and energy forecasts
5 presented in my direct testimony, as well as the
6 forecasts updated as part of the company's 2012 annual
7 business plan process, represent best industry practice.

8
9 **Q.** Does this conclude your direct testimony?

10
11 **A.** Yes, it does.
12
13
14
15
16
17
18
19
20
21
22
23
24
25

EXHIBIT

OF

LORRAINE L. CIFUENTES

Table of Contents

DOCUMENT NO.	TITLE	PAGE
1	Economic Assumptions	19
2	Billing Cycle Degree Days	21
3	Customer Forecast	23
4	Per Customer Energy Consumption	25
5	Retail Energy Sales	27
6	Per Customer Peak Demand	29
7	Peak Demand	31
8	Firm Peak Demand	33
9	Firm Peak Load Factor	35
10	June 2012 Update Firm Peak Demand	37

TAMPA ELECTRIC COMPANY
DOCKET NO. 12 _____-EI
EXHIBIT NO. _____ (LLC-1)
DOCUMENT NO. 1
FILED: 09/12/2012

DOCUMENT NO. 1

ECONOMIC ASSUMPTIONS

	Population (Millions)	Residential Price of Electricity (\$/MWH)	Real Household Income	Persons Per Household	Per Capita Commercial Real Gross Output (Millions)	Per Capita Government Real Gross Output (Millions)	Construction Employment (Thousands)	Commercial Employment (Thousands)	Industrial Employment (Thousands)
2002	1,060	\$64.75	\$82,367	2.6	647.5	74.7	35.3	453.6	34.0
2003	1,086	\$65.00	\$84,255	2.6	653.4	75.7	37.0	448.7	31.7
2004	1,113	\$65.95	\$86,610	2.6	668.4	77.4	41.0	465.5	32.7
2005	1,139	\$65.66	\$88,639	2.6	704.9	72.1	45.5	480.8	33.5
2006	1,170	\$66.43	\$91,584	2.6	714.4	71.9	47.2	490.6	33.8
2007	1,194	\$70.16	\$91,789	2.6	709.6	76.0	44.9	500.6	32.1
2008	1,200	\$69.38	\$90,562	2.6	680.0	76.9	39.2	479.9	29.5
2009	1,199	\$71.91	\$89,183	2.6	666.9	90.2	30.6	453.3	25.7
2010	1,203	\$71.55	\$88,502	2.6	685.8	77.4	27.0	452.0	24.2
2011	1,211	\$66.85	\$91,166	2.6	715.0	77.1	29.0	456.7	24.5
2012	1,221	\$64.68	\$95,661	2.56	748.1	77.7	34.0	472.0	25.2
2013	1,235	\$63.21	\$99,245	2.56	777.9	77.4	35.5	486.7	25.4
2014	1,252	\$61.40	\$101,779	2.56	797.8	76.3	36.4	502.0	25.3
2015	1,269	\$60.49	\$104,180	2.56	814.5	75.6	37.4	514.1	25.1
2016	1,288	\$59.65	\$106,693	2.56	830.9	75.7	38.1	523.8	24.6
2017	1,307	\$58.81	\$109,611	2.56	850.9	76.3	38.7	534.0	24.2
2018	1,325	\$57.99	\$112,938	2.56	871.9	77.1	39.4	544.5	23.8
2019	1,344	\$57.19	\$116,465	2.56	892.5	78.0	40.3	555.2	23.5
2020	1,361	\$56.43	\$120,064	2.56	911.8	78.8	41.3	566.1	23.1
2021	1,378	\$55.71	\$123,867	2.56	929.8	79.7	42.4	576.9	22.7

Average Annual Growth Rates

2002-2011	1.5%	0.4%	1.1%	0.0%	1.1%	0.4%	-2.2%	0.1%	-3.6%
2012-2021	1.4%	-1.6%	2.9%	0.0%	2.4%	0.3%	2.5%	2.3%	-1.2%

Average Absolute Growth

2002-2011	17	\$0.23	\$978	0.00	7.5	0.3	(0.7)	0.3	(1.1)
2012-2021	18	(\$1.00)	\$3,134	0.00	20.2	0.2	0.9	11.7	(0.3)

TAMPA ELECTRIC COMPANY
DOCKET NO. 12 _____-EI
EXHIBIT NO. _____ (LLC-1)
DOCUMENT NO. 2
FILED: 09/12/2012

DOCUMENT NO. 2

BILLING CYCLE DEGREE DAYS

**Tampa Electric Company
Billing Cycle Based Degree Days**

	Heating Degree Days	Cooling Degree Days
1992	540	3,302
1993	441	3,453
1994	430	3,762
1995	547	3,689
1996	792	3,479
1997	343	3,754
1998	406	4,011
1999	342	3,719
2000	417	3,689
2001	572	3,613
2002	447	3,982
2003	605	3,736
2004	547	3,490
2005	534	3,469
2006	499	3,513
2007	381	3,849
2008	420	3,523
2009	457	3,823
2010	1000	3,642
2011	575	3,844
2012	494	3,661
2013	492	3,665
2014	492	3,665
2015	492	3,665
2016	492	3,665
2017	492	3,665
2018	492	3,665
2019	492	3,665
2020	492	3,665
2021	492	3,665

Average Annual Degree Days

1992-2011	515	3,667
2012-2021	494	3,661

TAMPA ELECTRIC COMPANY
DOCKET NO. 12 _____-EI
EXHIBIT NO. _____ (LLC-1)
DOCUMENT NO. 3
FILED: 09/12/2012

DOCUMENT NO. 3

CUSTOMER FORECAST

Tampa Electric Company Customer Forecast	
	Number of Customers
2002	590,199
2003	604,900
2004	619,535
2005	635,621
2006	653,706
2007	666,354
2008	667,266
2009	666,750
2010	670,991
2011	675,799
2012	680,316
2013	688,083
2014	696,913
2015	706,481
2016	717,032
2017	727,330
2018	737,398
2019	747,441
2020	757,343
2021	766,690

Average Annual Growth Rates	
2002-2011	1.5%
2012-2021	1.3%

Average Absolute Growth	
2002-2011	9,511
2012-2021	9,597

TAMPA ELECTRIC COMPANY
DOCKET NO. 12_____-EI
EXHIBIT NO. ____ (LLC-1)
DOCUMENT NO. 4
FILED: 09/12/2012

DOCUMENT NO. 4

PER-CUSTOMER ENERGY CONSUMPTION
(KWH/CUSTOMER)

**Tampa Electric Company
Per Customer Energy Consumption
(kWh/Customer)**

	Total Retail	Total Excluding Phosphate
2002	30,371	28,039
2003	30,131	28,021
2004	29,759	27,777
2005	29,752	27,954
2006	29,103	27,673
2007	29,313	27,739
2008	28,459	27,008
2009	28,158	26,800
2010	28,634	27,216
2011	27,469	26,388
2012	27,993	26,853
2013	27,843	26,818
2014	27,551	26,737
2015	27,355	26,606
2016	27,234	26,482
2017	27,111	26,385
2018	27,023	26,307
2019	26,946	26,239
2020	26,873	26,175
2021	26,804	26,115

Average Annual Growth Rates

2002-2011	-1.1%	-0.7%
2012-2021	-0.5%	-0.3%

Average Absolute Growth

2002-2011	-322	-183
2012-2021	-132	-82

TAMPA ELECTRIC COMPANY
DOCKET NO. 12 _____-EI
EXHIBIT NO. _____ (LLC-1)
DOCUMENT NO. 5
FILED: 09/12/2012

DOCUMENT NO. 5

RETAIL ENERGY SALES

(GWH)

Tampa Electric Company Retail Energy Sales (GWH)		
	Total Retail	Total Excluding Phosphate
2002	17,925	16,547
2003	18,226	16,948
2004	18,437	17,208
2005	18,911	17,767
2006	19,025	18,089
2007	19,533	18,483
2008	18,990	18,020
2009	18,774	17,868
2010	19,213	18,261
2011	18,564	17,832
2012	19,044	18,268
2013	19,158	18,452
2014	19,201	18,633
2015	19,326	18,796
2016	19,528	18,988
2017	19,719	19,190
2018	19,927	19,398
2019	20,141	19,612
2020	20,352	19,823
2021	20,550	20,021

Average Annual Growth Rates		
2002-2011	0.4%	0.8%
2012-2021	0.8%	1.0%

Average Absolute Growth		
2002-2011	71	143
2012-2021	167	195

TAMPA ELECTRIC COMPANY
DOCKET NO. 12 _____-EI
EXHIBIT NO. _____ (LLC-1)
DOCUMENT NO. 6
FILED: 09/12/2012

DOCUMENT NO. 6

PER-CUSTOMER PEAK DEMAND

(kW/Customer)

Tampa Electric Company Per Customer Peak Demand (kW/Customer)		
	Winter	Summer
2002	6.12	6.16
2003	6.42	5.99
2004	5.40	6.03
2005	5.80	6.24
2006	5.72	6.13
2007	5.10	6.19
2008	5.56	5.92
2009	6.12	6.02
2010	6.72	5.84
2011	5.97	5.88
2012	6.00	5.87
2013	5.98	5.85
2014	5.94	5.81
2015	5.92	5.78
2016	5.89	5.75
2017	5.87	5.73
2018	5.85	5.71
2019	5.83	5.69
2020	5.82	5.67
2021	5.81	5.65

Average Annual Growth Rates		
2002-2011	-0.3%	-0.5%
2012-2021	-0.4%	-0.4%

Average Absolute Growth		
2002-2011	-0.02	-0.03
2012-2021	-0.02	-0.02

TAMPA ELECTRIC COMPANY
DOCKET NO. 12 _____-EI
EXHIBIT NO. _____ (LLC-1)
DOCUMENT NO. 7
FILED: 09/12/2012

DOCUMENT NO. 7

PEAK DEMAND

(MW)

Tampa Electric Company Peak Demand (MW)		
	Winter	Summer
2002	3612	3634
2003	3881	3623
2004	3344	3737
2005	3686	3968
2006	3736	4010
2007	3398	4123
2008	3709	3952
2009	4080	4015
2010	4512	3917
2011	4037	3976
2012	4081	3993
2013	4112	4023
2014	4141	4049
2015	4180	4082
2016	4224	4125
2017	4269	4165
2018	4315	4207
2019	4361	4250
2020	4408	4292
2021	4453	4331

Average Annual Growth Rates		
2002-2011	1.2%	1.0%
2012-2021	1.0%	0.9%

Average Absolute Growth		
2002-2011	47	38
2012-2021	41	38

TAMPA ELECTRIC COMPANY
DOCKET NO. 12 _____-EI
EXHIBIT NO. _____ (LLC-1)
DOCUMENT NO. 8
FILED: 09/12/2012

DOCUMENT NO. 8

FIRM PEAK DEMAND

(MW)

Tampa Electric Company		
Firm Peak Demand		
(MW)		
	Winter	Summer
2002	3259	3318
2003	3455	3351
2004	2936	3445
2005	3287	3725
2006	3523	3769
2007	3127	3876
2008	3443	3723
2009	3754	3799
2010	4246	3710
2011	3735	3699
2012	3777	3748
2013	3819	3784
2014	3864	3823
2015	3910	3859
2016	3955	3900
2017	4003	3940
2018	4050	3980
2019	4097	4022
2020	4146	4064
2021	4194	4103

Average Annual Growth Rates		
2002-2011	1.5%	1.2%
2012-2021	1.2%	1.0%

Average Absolute Growth		
2002-2011	53	42
2012-2021	46	39

DOCUMENT NO. 9

FIRM PEAK LOAD FACTOR

(%)

Tampa Electric Company		
Firm Peak Load Factor		
(%)		
	Winter	Summer
2002	62.8%	61.7%
2003	60.2%	62.1%
2004	71.5%	60.9%
2005	65.7%	57.9%
2006	61.6%	57.6%
2007	71.3%	57.5%
2008	62.8%	58.1%
2009	57.1%	56.4%
2010	51.7%	59.1%
2011	56.7%	57.3%
2012	57.4%	57.9%
2013	57.3%	57.8%
2014	56.7%	57.3%
2015	56.4%	57.2%
2016	56.2%	57.0%
2017	56.2%	57.1%
2018	56.2%	57.2%
2019	56.1%	57.2%
2020	55.9%	57.0%
2021	55.9%	57.2%

Average Annual Growth Rates		
2002-2011	-1.1%	-0.8%
2012-2021	-0.3%	-0.1%

TAMPA ELECTRIC COMPANY
DOCKET NO. 12_____-EI
EXHIBIT NO. ____ (LLC-1)
DOCUMENT NO. 10
FILED: 09/12/2012

DOCUMENT NO. 10

JUNE 2012 UPDATE
FIRM PEAK DEMAND
(MW)

**Tampa Electric Company
June 2012 Update
Firm Peak Demand
(MW)**

	Winter	Summer
2002	3259	3318
2003	3455	3351
2004	2936	3445
2005	3287	3725
2006	3523	3769
2007	3127	3876
2008	3443	3723
2009	3754	3799
2010	4246	3710
2011	3725	3699
2012	3237	3677
2013	3699	3667
2014	3731	3701
2015	3778	3741
2016	3832	3788
2017	3887	3835
2018	3941	3881
2019	3993	3927
2020	4045	3971
2021	4095	4012

Average Annual Growth Rates

2002-2011	1.5%	1.2%
2012-2021	1.3%	1.0%

Average Absolute Growth

2002-2011	52	42
2012-2021	50	37



BEFORE THE
FLORIDA PUBLIC SERVICE COMMISSION

DOCKET NO. 12 0234 -EI
IN RE: TAMPA ELECTRIC COMPANY'S
PETITION TO DETERMINE NEED FOR
POLK 2-5 COMBINED CYCLE CONVERSION

DIRECT TESTIMONY AND EXHIBIT
OF
HOWARD T. BRYANT

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25

BEFORE THE FLORIDA PUBLIC SERVICE COMMISSION

PREPARED DIRECT TESTIMONY

OF

HOWARD T. BRYANT

Q. Please state your name, business address, occupation and employer.

A. My name is Howard T. Bryant. My business address is 702 North Franklin Street, Tampa, Florida 33602. I am employed by Tampa Electric Company ("Tampa Electric" or "company") as Manager, Rates in the Regulatory Affairs Department.

Q. Please provide a brief outline of your educational background and business experience.

A. I graduated from the University of Florida in June 1973 with a Bachelor of Science degree in Business Administration. I have been employed at Tampa Electric since 1981. My work has included various positions in Customer Service, Energy Conservation Services, Demand Side Management ("DSM") Planning, Energy Management and Forecasting, and Regulatory Affairs. In my current position I am responsible for the company's Energy

1 Conservation Cost Recovery ("ECCR") clause, the
2 Environmental Cost Recovery Clause ("ECRC"), and their
3 retail rate designs.
4

5 **Q.** What is the purpose of your direct testimony?
6

7 **A.** The purpose of my direct testimony is to describe Tampa
8 Electric's DSM programs and initiatives. I will provide
9 an overview of the company's historical and current DSM
10 programs. I will also discuss the process used by Tampa
11 Electric in setting its DSM goals. Additionally, I will
12 address Tampa Electric's DSM renewable energy
13 initiatives. Finally, I will discuss why the company's
14 comprehensive DSM program offerings cannot be utilized to
15 eliminate the 2017 capacity need.
16

17 **Q.** Have you prepared an exhibit to support your direct
18 testimony?
19

20 **A.** Yes, Exhibit No. _____ (HTB-1) was prepared under my
21 direction and supervision. It consists of the following
22 three documents:

23 Document No. 1 Tampa Electric DSM Programs

24 Document No. 2 Tampa Electric DSM Goals

25 Document No. 3 Tampa Electric 2010-2019 DSM Goals

Accomplishments

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25

Q. Are you sponsoring any sections of Tampa Electric's Determination of Need Study for Electrical Power: Polk Combined Cycle Conversion ("Need Study")?

A. Yes. I sponsor sections of the Need Study pertaining to DSM. Specifically I sponsor sections III.A.3 "Demand Side Management", III.F.1 "Demand Side Programs", and IV.A.1 "Demand Side Management".

HISTORICAL OVERVIEW OF TAMPA ELECTRIC'S DSM PROGRAMS

Q. Please describe the phrase "demand side management programs" as used by Tampa Electric?

A. Tampa Electric utilizes the term demand side management to describe the planning, development, implementation, monitoring and evaluation of conservation and load management programs designed to cost-effectively reduce weather sensitive peak demand and overall energy consumption on the company's system.

Q. How does Tampa Electric measure the cost-effectiveness of DSM programs?

1 **A.** Tampa Electric measures the cost-effectiveness of DSM
2 programs by using the Commission-approved methodology,
3 which consists of three specific tests: the Rate Impact
4 Measure ("RIM") Test, the Participants' Test and the
5 Total Resource Cost ("TRC") Test. Programs that have a
6 cost-benefit-ratio ("CBR") greater than 1.0 under the RIM
7 Test provide benefits to all customers by the deferral or
8 avoidance of new capacity which thereby results in lower
9 rates for all customers than would otherwise occur in the
10 absence of the programs. Similarly, programs that have a
11 CBR greater than 1.0 under the Participants' Test ensure
12 that the programs are economical for customers who choose
13 to participate in the programs. Finally, programs that
14 have a CBR greater than 1.0 under the TRC Test ensure
15 that society, as a whole, is not harmed when comparing
16 specifically defined costs and benefits regardless of who
17 is responsible for those costs and benefits. However, a
18 program with a TRC Test CBR greater than 1.0 in
19 conjunction with its RIM Test CBR of less than 1.0 will
20 result in a cross subsidization occurring between those
21 customers who cannot participate in programs, yet must
22 pay the program costs associated with those who can
23 participate.

24
25 **Q.** When did Tampa Electric begin offering DSM programs to

1 its customers?

2

3 **A.** Tampa Electric has long been a leader in offering its
4 customers cost-effective DSM programs coupled with a
5 comprehensive educational emphasis on the efficient use
6 of energy. This effort began in the mid-1970s when Tampa
7 Electric offered its first DSM program, the Energy Answer
8 Home, to curb heating and air-conditioning requirements
9 in new homes by encouraging the use of high-efficiency
10 heat pumps instead of conventional air-conditioning with
11 resistance heating. Within two years, the company
12 introduced a computer-based home energy audit well in
13 advance of the legislation that ultimately required this
14 level of home energy analysis.

15

16 **Q.** Please describe Tampa Electric's DSM efforts over time.

17

18 **A.** In 1980, the Florida Energy Efficiency and Conservation
19 Act ("FEECA") was passed by the Florida Legislature. In
20 response to that legislation, Tampa Electric filed its
21 DSM plans with the Commission and became the first
22 Florida utility to have its DSM programs for both
23 residential and commercial customers approved.
24 Subsequent to that first DSM plan, Tampa Electric has
25 filed and gained Commission approval for numerous DSM

1 programs designed to promote new energy efficient
2 technologies and to change customer behavioral patterns
3 such that energy savings occur with minimal effect on
4 customer comfort. Additionally, the company has modified
5 existing DSM programs over time to promote evolving
6 technologies and to maintain program cost-effectiveness.
7 Document No. 1 of my exhibit identifies Tampa Electric's
8 current DSM programs.

9
10 **Q.** Has Tampa Electric been successful implementing its DSM
11 initiatives over time?

12
13 **A.** Yes. Tampa Electric has experienced great success with
14 its DSM initiatives. From the inception of its programs
15 in 1980 through the end of 2011, Tampa Electric has
16 achieved 719 MW of winter peak demand reduction, 306 MW
17 of summer peak demand reduction and 770 GWH of annual
18 energy savings.

19
20 This amount of peak load reduction has eliminated the
21 need for the equivalent of four 180 MW power plants of
22 winter capacity.

23
24 Furthermore, the company's DSM program results compare
25 quite favorably to other utilities across the nation.

1 The Energy Information Administration of the United
2 States Department of Energy reports annually on the
3 effectiveness of utility DSM initiatives. Based on
4 available data reported for the 2001 through 2010 period,
5 Tampa Electric's national average ranking for cumulative
6 conservation is at the 89th percentile and is at the 85th
7 percentile for load management achievement.

8
9 **OVERVIEW OF TAMPA ELECTRIC'S DSM PROGRAMS**

10 **Q.** What are Tampa Electric's current Commission-approved
11 residential DSM programs?

12
13 **A.** Tampa Electric's current DSM plan consists of 11
14 comprehensive residential programs several of which
15 provide customers with a multitude of program offerings
16 to better manage their energy consumption. A description
17 of these various programs is provided below.

18
19 **Energy Audit:** A comprehensive program offered to all
20 residential customers designed to save demand and energy
21 by increasing customer awareness of energy use in
22 personal residences. The types of audits available
23 include a free walk-through, computer assisted and
24 telephone audits as well as a paid comprehensive audit.
25 Savings are dependent on the customer implementing energy

1 saving recommendations. Recommendations are the same
2 across the four types of audits offered and include an
3 estimated range of savings.
4

5 **Building Envelope:** A conservation incentive program that
6 encourages customers to make cost-effective improvements
7 to existing residences in the areas of ceiling
8 insulation, wall insulation and window improvements. The
9 goal is to offer customer incentives for making these
10 improvements while helping them reduce energy consumption
11 and weather sensitive peak demand.
12

13 **Energy Planner:** A conservation and load management
14 program that relies on a multi-tiered rate structure
15 combined with price signals conveyed to participating
16 customers during the day. This price information is
17 designed to encourage customers to make behavioral or
18 equipment usage changes to their energy consumption
19 thereby achieving the desired high cost period load
20 reduction to assist in meeting system peak. Price
21 information from the utility is used by the customer to
22 program a smart thermostat into preset actions based on
23 the level of pricing. Equipment may be turned on, turned
24 off or changed to a different temperature setting
25 automatically by the smart thermostat or manually by the

1 customer through the smart thermostat in response to
2 either the multi-tiered rates or critical price signals.
3

4 **Duct Repair:** A conservation incentive program designed to
5 reduce demand and energy by decreasing the load on
6 residential air conditioning and heating ("HVAC")
7 equipment. This program eliminates or reduces areas of
8 HVAC air distribution losses by sealing and repairing the
9 air distribution system ("ADS"). The ADS is defined as
10 the air handler, air ducts, return plenums, supply
11 plenums and any connecting structure.
12

13 **New Construction Program:** A conservation program designed
14 to reduce the growth of peak demand and energy
15 consumption in the residential new construction market
16 through the installation of high efficiency equipment and
17 building envelope options. The program utilizes
18 incentives to encourage the construction of new homes
19 that exceed the minimum energy efficiency levels required
20 in the State of Florida Energy Efficiency Code for New
21 Construction.
22

23 **Heating and Cooling:** A conservation program that uses a
24 rebate to encourage the installation of high efficiency
25 heating and cooling systems in existing residential

1 dwellings. The program is aimed at reducing the growth
2 of weather sensitive peak demand and energy through two
3 types of equipment replacement. Both types of equipment
4 replacement have a minimum threshold for qualification of
5 15.0 Seasonal Energy Efficiency Ratio ("SEER").

6
7 **Low Income Weatherization/Agency Outreach:** A conservation
8 program designed to reduce weather sensitive peak demand
9 and energy. The goal of the program is to establish a
10 package of conservation measures at no cost for the
11 customer. In addition to providing and/or installing the
12 necessary materials for the various conservation
13 measures, a key component will be educating families on
14 energy conservation techniques to promote behavioral
15 changes to help customers control their energy usage.
16 Customer eligibility is determined by utilization of
17 census data to identify eligible customer geographic
18 regions or referral through local community agencies
19 which serve low-income households.

20
21 **Public Education Outreach:** A conservation program
22 designed to save energy and demand by establishing
23 informative presentations to help educate customers on
24 no-cost practices they can implement to reduce energy
25 consumption, low-cost improvements to increase the

1 efficiency of their homes, and incentives available for
2 making larger, long-term investments. This program is
3 designed to establish opportunities for engaging groups
4 of customers and students in energy-efficiency related
5 discussions in an organized setting. In addition,
6 participants will be provided with energy saving devices
7 such as compact fluorescent lamps, low-flow faucet
8 aerators, HVAC filter whistles and energy saving tips and
9 recommendations.

10
11 **HVAC Maintenance:** A conservation incentive program
12 designed to help customers ensure HVAC equipment is
13 operating at optimal efficiency through maintenance and
14 equipment tune-up. This will in turn help participating
15 customers reduce demand and energy usage and help promote
16 positive long-term maintenance habits.

17
18 **Electronically Commutated Motors:** A conservation
19 incentive program designed to reduce demand and energy by
20 decreasing the load on HVAC equipment. Customers will
21 improve the overall efficiency by replacing the existing
22 motor in the air-handler with an electronically
23 commutated motor.

24
25 **Prime Time:** A residential load management program

1 designed to alter Tampa Electric's system load curve by
2 reducing summer and winter demand peaks. Residential
3 loads such as heating, air conditioning, water heaters
4 and pool pumps are controlled from a radio signal
5 initiated by Tampa Electric's Energy Control Center.
6 This signal operates switches located on individual
7 customer homes that are wired directly to the controlled
8 appliances. Customers participating in Prime Time
9 receive monthly credits on their electric bill.
10 Appliances are interrupted on a prescribed schedule
11 unless a system emergency occurs. Currently, Prime Time
12 is closed and not accepting new customers.

13
14 **Q.** What are Tampa Electric's current Commission-approved
15 commercial/industrial DSM programs?

16
17 **A.** Tampa Electric's current DSM plan consists of 19
18 comprehensive commercial/industrial programs which
19 provide customers with a multitude of offerings to better
20 manage their energy consumption. A description of these
21 various programs is provided below.

22
23 **Energy Audit:** A conservation program designed to reduce
24 demand and energy consumption by increasing customer
25 awareness of energy use in their facilities. The savings

1 are dependent upon customer implementation of audit
2 recommendations. Recommendations are based on the
3 replacement of less efficient equipment and systems or
4 modifications to operations to enhance the customer's
5 overall efficiency. Recommendations are primarily
6 standardized and encourage the customer to implement
7 measures that, if cost-effective, move the customer
8 beyond the efficiency level typically installed in the
9 marketplace.

10
11 **Cool Roof:** A conservation program that uses incentives to
12 encourage the installation of cool roof systems above
13 conditioned spaces. The program is aimed at reducing
14 heat transfer through reflectance which in turn, reduces
15 HVAC loads and improves comfort.

16
17 **Energy Recovery Ventilation:** A conservation program that
18 uses incentives to encourage the installation of
19 ventilation systems that reduce humidity and HVAC loads
20 in buildings. This program is intended to reduce demand
21 and energy while improving comfort in commercial
22 buildings.

23
24 **Chiller Replacement:** A conservation program that uses
25 incentives to encourage the installation of high

1 efficiency electric water-cooled and air-cooled chillers.
2 This program is intended to reduce demand and energy by
3 encouraging customers to replace worn out, inefficient
4 cooling equipment with systems that exceed minimum
5 product standards.

6
7 **Commercial Lighting:** An incentive program for existing
8 commercial facilities to encourage investment in more
9 efficient lighting technologies. Specifically, this
10 program is designed to: 1) affect a significant number of
11 eligible customers; 2) recognize the most probable
12 lighting investment opportunities; and 3) contribute
13 toward weather-sensitive peak demand reduction.

14
15 **Building Envelope:** A conservation program that encourages
16 customers to make cost-effective improvements to existing
17 commercial facilities in the areas of ceiling and roof
18 insulation, wall insulation and window improvements. The
19 goal is to offer customer incentives for making these
20 improvements while helping them reduce energy consumption
21 and weather sensitive peak demand.

22
23 **Commercial Cooling:** A commercial conservation program
24 that uses incentives for the installation of high
25 efficiency cooling systems in commercial buildings. The

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25

program is aimed at reducing the growth of peak demand and energy by encouraging customers to replace worn out, inefficient cooling equipment with high efficiency equipment that exceeds minimum product manufacturing standards.

Duct Repair: A conservation incentive program designed to reduce demand and energy by decreasing the load on commercial HVAC equipment. This program eliminates or reduces areas of HVAC air distribution losses by sealing and repairing the ADS. The ADS is defined as the air handler, air ducts, return plenums, supply plenums and any connecting structure.

Energy Efficient Motors: A conservation incentive program designed to reduce demand and energy by encouraging commercial/industrial customers to install premium-efficiency motors in new or existing facilities.

Lighting Occupancy Sensors: A conservation incentive program designed to reduce demand and energy by encouraging commercial/industrial customers to install occupancy sensors to efficiently control lighting systems.

1 **Refrigeration (Anti-Condensate):** A conservation incentive
2 program designed to reduce demand and energy by
3 encouraging commercial/industrial customers to install
4 efficient anti-condensate controls on refrigeration
5 equipment.

6
7 **Water Heating:** A conservation incentive program designed
8 to reduce demand and energy by encouraging
9 commercial/industrial customers to install high
10 efficiency water heating systems. Two technologies
11 covered under this program are heat recovery units and
12 heat pump water heaters.

13
14 **Conservation Value:** An incentive program available for
15 all commercial/industrial customers on firm rates to
16 recognize and encourage investments in demand shifting or
17 demand reduction measures. Measures funded in this
18 program are not covered under other Tampa Electric
19 commercial/industrial conservation programs. Candidates
20 are identified through the energy audit, or their
21 engineering consultants can submit proposals for funding
22 which offer energy reduction during weather sensitive
23 peak times.

24
25 **Commercial Load Management:** A load management program

1 intended to help alter the company's system load curve by
2 reducing summer and winter demand peaks. Large loads
3 such as walk-in freezers are interrupted for up to three
4 hours by radio controlled switches similar to those used
5 in the residential load management. Commercial air
6 conditioning equipment is cycled during summer control
7 periods. Monthly incentive credits are paid to customers
8 participating in this program.

9
10 **Industrial Load Management:** A load management program for
11 large industrial customers with interruptible loads of
12 500 kW or greater. In accordance with the Florida
13 Administrative Code, assessments for customer
14 participation are conducted every six months.

15
16 **Standby Generator:** A program designed to utilize the
17 emergency generation capacity of commercial/industrial
18 facilities in order to reduce weather sensitive peak
19 demand. Tampa Electric provides participating customers
20 a thirty minute notice that their generation will be
21 required. This allows customers time to start generators
22 and arrange for orderly transfer of load. Tampa Electric
23 meters and issues monthly credits for that portion of the
24 generator's output that could serve normal building load
25 after the notification time. Normal building load is

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25

defined as load (type, amount and duration) that would have been served by Tampa Electric if the emergency generator did not operate. Under no circumstances will the generator deliver power to Tampa Electric's grid.

Demand Response: A program intended to alter the company's system load curve by reducing summer and winter demand peaks. The company will contract through a vendor for a turn-key program that will induce commercial/industrial customer to reduce their demand for electricity in response to market signals. Reductions will be achieved through a mix of emergency backup generation, energy management systems, raising cooling set-points and turning off or dimming lights, signage, etc.

HVAC Maintenance: A conservation incentive program designed to help commercial/industrial customers ensure HVAC equipment is operating at optimal efficiency through maintenance and equipment tune-up. This will in turn help participating customers reduce demand and energy usage and help promote positive long-term maintenance habits.

Electronically Commutated Motors: A conservation

1 incentive program designed to reduce demand and energy by
2 decreasing the load on HVAC and refrigeration equipment.
3 Commercial/industrial customers will improve the overall
4 efficiency by replacing the existing motors in air-
5 handlers and refrigeration systems with electronically
6 commutated motors.

7
8 **Q.** Does Tampa Electric engage in other activities closely
9 associated with DSM programs?

10
11 **A.** Tampa Electric has a longstanding practice of engaging in
12 relevant commercial and residential research and
13 development ("R&D") to discover measures that would
14 return DSM savings for customers and the company and
15 therefore become integral to DSM programs. The company's
16 R&D projects have included renewable energy generating
17 technology investigations, renewable energy program
18 development, desiccant technologies for moisture removal
19 from buildings, ventilation designs for fresh air intake
20 on commercial buildings, chiller and motor efficiency
21 testing, anti-condensate controls for refrigerator and
22 freezer doors, thermal energy storage, commercial load
23 management experimentation, heat recovery technology for
24 ice makers and residential and commercial demand response
25 through time specific pricing tiers. From these R&D

1 efforts, Tampa Electric has developed or enhanced the
2 following programs: Renewable Energy Program, Energy
3 Planner, Conservation Value, Chiller Replacement,
4 Commercial Refrigeration and Commercial Load Management.

5
6 **TAMPA ELECTRIC'S DSM RENEWABLE ENERGY INITIATIVES**

7 **Q.** Has Tampa Electric engaged in DSM activities that support
8 renewables?

9
10 **A.** Yes, it has. Some of Tampa Electric's initial work in
11 the area of renewables has included photovoltaic ("PV")
12 arrays. Early work included utilizing PV arrays to
13 charge batteries that would power parking lot lighting.
14 An R&D effort was also undertaken to evaluate the use of
15 PV arrays to provide emergency lighting at a strategic
16 storm shelter.

17
18 Tampa Electric's commitment to a more formalized
19 renewable energy program began in 2001. The company
20 implemented a pilot renewable energy program with the
21 following goals: 1) determine the level of program
22 interest among customers and their willingness to pay a
23 higher cost for renewable energy; 2) examine marketing
24 methods to identify the most cost-effective manner to
25 secure residential and commercial program participants;

1 3) determine the longevity of customer participation; 4)
2 determine the functionality of certain renewable
3 generation; and 5) determine the sustainability of
4 renewable fuel resources.

5
6 Due to the R&D effort put forth on the pilot program,
7 Tampa Electric offers a permanent renewable energy
8 program for both residential and commercial customers.
9 The program continues to offer incremental renewable
10 energy that is produced locally and within the State and
11 as such, the environmental benefits accrue to the
12 citizens of Florida.

13
14 **Q.** What are Tampa Electric's other Commission-approved
15 renewable DSM programs?

16
17 **A.** Tampa Electric's current DSM plan consists of the
18 aforementioned permanent program and four pilot renewable
19 program offerings. A description of these various
20 programs is provided below.

21
22 **Renewable Energy Program:** A program designed to allow
23 residential and commercial/industrial customers the
24 option of paying an additional charge for incremental
25 renewable energy delivered to the company's grid system.

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25

The customer can elect to pay \$5.00 for a 200 kWh block of renewable energy generated from renewable resources on an on-going monthly or one-time basis.

Solar Photovoltaics (Pilot): A conservation incentive program designed to reduce demand and energy by encouraging residential and commercial/industrial customers to install PV systems. Participants must agree to have the system interconnected to the grid with an interconnection agreement in place once installation has occurred.

Residential Solar Water Heating (Pilot): A conservation incentive program designed to reduce demand and energy by encouraging residential customers to install solar water heating ("SWH") technologies on residential premises.

School PV (Pilot): A conservation program designed to reduce demand and energy by providing schools designated as emergency shelters with PV systems. In addition, Tampa Electric has partnered with the Florida Solar Energy Center to provide educational components for teachers and students to evaluate and understand the performance and benefits of PV.

1 **Low-income Solar Water Heating (Pilot):** A conservation
2 program designed to reduce demand and energy by providing
3 the installation of SWH systems on low-income housing
4 done in partnership with local non-profit building
5 organizations.

6
7 **DSM GOALS SETTING PROCESS**

8 **Q.** Why are DSM goals established for Tampa Electric?
9

10 **A.** Investor-owned utilities like Tampa Electric have DSM
11 goals established by the Commission as a requirement of
12 FEECA and the Florida Administrative Code. Furthermore,
13 DSM goals are established and utilized in the cost-
14 effective planning to meet future generating needs.
15

16 **Q.** How frequently are Tampa Electric's DSM goals
17 established?
18

19 **A.** Tampa Electric's DSM goals are established by the
20 Commission every five years for a 10-year period. Every
21 five years, the existing goals are re-examined for
22 appropriateness and often adjusted to reflect levels of
23 accomplishment as well as the changing potential of
24 customer participation based on DSM technology
25 development and customer willingness to participate.

1 Tampa Electric's current Commission-approved DSM goals
2 are shown in Document No. 2 of my exhibit.

3

4 **Q.** How has Tampa Electric performed relative to its DSM
5 goals?

6

7 **A.** Since 1980, Tampa Electric has met or exceeded its DSM
8 demand and energy goals in every period but one.
9 Document No. 3 of my exhibit clearly demonstrates that
10 Tampa Electric is exceeding its DSM goals for the current
11 period.

12

13 **Q.** How were Tampa Electric's current Commission-approved DSM
14 goals developed?

15

16 **A.** Tampa Electric's process to develop its DSM goals used
17 multiple steps. The first step was to identify the
18 measures to be evaluated for cost-effectiveness. Tampa
19 Electric identified 270 measures for evaluation. The
20 next step was to perform the cost-effectiveness
21 evaluation on each measure across the various market
22 segments where potential acceptance could occur. This
23 resulted in almost 2,300 individual measure cost-
24 effectiveness evaluations being performed. Next, Tampa
25 Electric examined those measures that were cost-effective

1 to determine their potential for program development.
2 Once the results from this step were identified, the
3 cost-effective measures were separated into residential
4 and commercial/industrial categories and became the
5 foundation for DSM goals proposed to the Commission. The
6 Commission approved the company's DSM goals in Docket No.
7 080409-EG, Order No. PSC-09-0855-FOF-EG, issued December
8 30, 2009.

9
10 **ABILITY TO SATISFY 2017 CAPACITY NEED THROUGH DSM**

11 **Q.** Has Tampa Electric identified all of the cost-effective
12 DSM program potential for the 2010 through 2019 period?

13
14 **A.** Yes. Through the exhaustive DSM goals setting process
15 that culminated in the demand and energy goals for the
16 2010 through 2019 period, Tampa Electric has identified
17 all the cost-effective DSM program potential for the
18 period.

19
20 **Q.** In 2007, a modification was made to subsection (4) of
21 Section 403.519, Florida Statutes, that requires the
22 Commission, in making its determination of need for a
23 requesting utility, to consider "...whether renewable
24 energy sources and technologies, as well as conservation
25 measures, are utilized to the extent reasonably

1 available." Has Tampa Electric met this requirement?

2

3 **A.** Yes. Tampa Electric has conducted an extensive
4 evaluation of all demand-side conservation and renewable
5 energy measures reasonably available. The company's
6 current 2010-2019 DSM goals were established utilizing a
7 comprehensive set of DSM measures. Through the company's
8 efforts, these goals are being exceeded.

9

10 **Q.** Will Tampa Electric's DSM efforts provide sufficient
11 potential such that the capacity identified in this
12 determination of need can be deferred?

13

14 **A.** No. Tampa Electric has identified all reasonably
15 achievable DSM demand and energy reductions and utilized
16 that potential in the assessment of this determination of
17 need. The company will not be able to meet the capacity
18 identified in this determination of need. Therefore,
19 Tampa Electric's evaluation of future generating capacity
20 has already captured all the cost-effective DSM potential
21 available on the company's system, and there are no DSM
22 alternatives that could defer the need for additional
23 generating capacity in 2017.

24

25 **Q.** Please summarize your direct testimony.

1 **A.** Tampa Electric has been successfully implementing cost-
2 effective DSM programs since the 1970s. During the last
3 decade, the company's average national ranking is at the
4 89th percentile for cumulative conservation and the 85th
5 percentile for load management achievements. Through
6 2011, Tampa Electric has implemented 719 MW of winter DSM
7 and 306 MW of summer DSM which equates to four 180 MW
8 power plants.

9
10 Tampa Electric has been very consistent at meeting or
11 exceeding its DSM goals set by the Commission.
12 Furthermore, Tampa Electric assesses its DSM potential on
13 an annual basis and seeks Commission approval of those
14 programs that will cost-effectively help the company
15 reach its DSM goals while providing customers with
16 opportunities to better manage their energy usage.

17
18 In spite of Tampa Electric's efforts and significant
19 accomplishments in the areas of DSM and renewables, the
20 company is not able to meet the 2017 capacity need
21 through additional conservation measures.

22
23 **Q.** Does this conclude your direct testimony?
24

25 **A.** Yes, it does.

EXHIBIT

OF

HOWARD T. BRYANT

Table of Contents

DOCUMENT NO.	TITLE	PAGE
1	Tampa Electric DSM Programs	30
2	Tampa Electric DSM Goals	33
3	Tampa Electric 2010-2019 DSM Goals Accomplishments	35

DOCUMENT NO. 1

TAMPA ELECTRIC DSM PROGRAMS

Tampa Electric DSM Programs

Residential

Energy Audits:

- Walk-Through
- Computer Assisted
- Phone
- Paid

Building Envelope:

- Ceiling Insulation
- Wall Insulation
- Window Replacement
- Window film

Energy Planner

- Duct Repair
- New Construction
- Heating and Cooling
- Low Income Weatherization/Agency Outreach
- Public Education Outreach
- HVAC Maintenance
- Electronically Commutated Motors (HVAC)
- Prime Time

Commercial/Industrial

Energy Audits:

- Free
- Paid

- Cool Roof
- Energy Recovery Ventilation
- Chiller Replacement

Lighting:

- Indoor
- Outdoor
- Exit Signs

- Air Conditioning Replacement
- Duct Repair

Building Envelope:

- Ceiling Insulation
- Roof Insulation
- Wall Insulation
- Window Film

- Energy Efficient Motors
- Lighting Occupancy Sensors
- Refrigeration (Anti-Condensate)
- Water Heating
- Conservation Value
- Industrial Load Management
- Standby Generator
- Demand Response
- Cogeneration
- HVAC Maintenance
- Electronically Commutated Motors (HVAC, Refrigeration)
- Commercial Load Management

Renewable Energy

- Renewable Energy Subscription
 - Solar PV Incentives
 - Solar Water Heating Incentives
 - Solar for Schools
 - Low-Income Solar Water Heating
-

DOCUMENT NO. 2

TAMPA ELECTRIC DSM GOALS

(2010 - 2019)

Tampa Electric DSM Goals
2010-2019

Residential

Year	Tampa Electric Projected Summer Demand Savings (MW)		Commission Approved Summer Goal (MW)		Tampa Electric Projected Winter Demand Savings (MW)		Commission Approved Winter Goal (MW)		Tampa Electric Projected Annual Energy Savings (GWH)		Commission Approved Annual Energy Goal (GWH)	
	Incr.	Cum.	Incr.	Cum.	Incr.	Cum.	Incr.	Cum.	Incr.	Cum.	Incr.	Cum.
2010	7.0	7.0	4.6	4.6	9.2	9.2	6.4	6.4	14.9	14.9	9.8	9.8
2011	8.8	15.9	6.6	11.2	11.1	20.3	8.5	14.9	19.9	34.8	14	23.8
2012	10.0	25.9	8.4	19.6	12.3	32.6	10.2	25.1	23.1	57.9	17.7	41.5
2013	11.5	37.4	9.9	29.5	13.8	46.4	11.5	36.6	20.6	78.5	20.6	62.1
2014	12.7	50.1	10.8	40.3	15.1	61.5	12.2	48.8	22.6	101.1	22.6	84.7
2015	13.3	63.5	10.9	51.2	16.0	77.6	11.6	60.4	23.0	124.1	23.0	107.7
2016	12.7	76.2	9.8	61.0	15.4	92.9	10.1	70.5	21.5	145.6	21.3	129.0
2017	11.7	87.9	9.0	70.0	14.1	107.0	8.8	79.3	20.2	165.7	19.4	148.4
2018	11.4	99.3	8.3	78.3	13.6	120.6	8.0	87.3	19.8	185.5	18.3	166.7
2019	11.0	110.3	7.8	86.1	12.9	133.6	7.4	94.7	19.2	204.7	17.3	184.0

Commercial / Industrial

Year	Tampa Electric Projected Summer Demand Savings (MW)		Commission Approved Summer Goal (MW)		Tampa Electric Projected Winter Demand Savings (MW)		Commission Approved Winter Goal (MW)		Tampa Electric Projected Annual Energy Savings (GWH)		Commission Approved Annual Energy Goal (GWH)	
	Incr.	Cum.	Incr.	Cum.	Incr.	Cum.	Incr.	Cum.	Incr.	Cum.	Incr.	Cum.
2010	3.7	3.7	2.5	2.5	2.1	2.1	0.9	0.9	12.2	12.2	6.5	6.5
2011	4.9	8.6	3.6	6.1	2.5	4.6	1.1	2.0	17.3	29.5	10.6	17.1
2012	5.7	14.3	4.3	10.4	3.0	7.6	1.4	3.4	18.4	48.0	15.4	32.5
2013	6.0	20.3	5.1	15.5	3.2	10.7	1.3	4.7	19.2	67.1	16.2	48.7
2014	6.8	27.0	5.4	20.9	3.7	14.4	1.5	6.2	20.4	87.5	19.5	68.2
2015	7.1	34.1	6.0	26.9	4.0	18.4	1.7	7.9	21.6	109.1	20.9	89.1
2016	7.4	41.5	6.2	33.1	4.1	22.5	1.6	9.5	22.7	131.8	21.6	110.7
2017	8.2	49.7	6.3	39.4	4.6	27.1	1.6	11.1	22.9	154.7	21.8	132.5
2018	7.6	57.2	6.4	45.8	4.2	31.2	1.7	12.8	22.1	176.8	22.1	154.6
2019	7.0	64.2	6.3	52.1	3.7	34.9	1.7	14.5	21.7	198.5	21.7	176.3

DOCUMENT NO. 3

Tampa Electric
2010-2019 DSM Goals Accomplishments

Tampa Electric Incremental 2010-2019 DSM Goals Accomplishments

Total Residential and Commercial/Industrial

Year	Winter Peak MW Reduction			Summer Peak MW Reduction			GWh Energy Reduction		
	Commission			Commission			Commission		
	Total Achieved	Approved Goal	% Variance	Total Achieved	Approved Goal	% Variance	Total Achieved	Approved Goal	% Variance
2010	18.5	7.3	253.4%	19.2	7.1	270.4%	35.6	16.3	218.4%
2011	22.0	9.6	229.2%	23.9	10.2	234.3%	52.2	24.6	212.2%

Residential

Year	Winter Peak MW Reduction			Summer Peak MW Reduction			GWh Energy Reduction		
	Commission			Commission			Commission		
	Total Achieved	Approved Goal	% Variance	Total Achieved	Approved Goal	% Variance	Total Achieved	Approved Goal	% Variance
2010	11.3	6.4	176.6%	8.1	4.6	176.1%	17.3	9.8	176.5%
2011	10.2	8.5	120.0%	8.6	6.6	130.3%	19.2	14.0	137.1%

Commercial/Industrial

Year	Winter Peak MW Reduction			Summer Peak MW Reduction			GWh Energy Reduction		
	Commission			Commission			Commission		
	Total Achieved	Approved Goal	% Variance	Total Achieved	Approved Goal	% Variance	Total Achieved	Approved Goal	% Variance
2010	7.2	0.9	800.0%	11.1	2.5	444.0%	18.3	6.5	281.5%
2011	11.8	1.1	1072.7%	15.3	3.6	425.0%	33.0	10.6	311.3%

Tampa Electric Cumulative 2010-2019 DSM Goals Accomplishments

Total Residential and Commercial/Industrial

Year	Winter Peak MW Reduction			Summer Peak MW Reduction			GWh Energy Reduction		
	Commission			Commission			Commission		
	Total Achieved	Approved Goal	% Variance	Total Achieved	Approved Goal	% Variance	Total Achieved	Approved Goal	% Variance
2010	18.5	7.3	253.4%	19.2	7.1	270.4%	35.6	16.3	218.4%
2011	40.5	16.9	239.6%	43.1	17.3	249.1%	87.8	40.9	214.7%

Residential

Year	Winter Peak MW Reduction			Summer Peak MW Reduction			GWh Energy Reduction		
	Commission			Commission			Commission		
	Total Achieved	Approved Goal	% Variance	Total Achieved	Approved Goal	% Variance	Total Achieved	Approved Goal	% Variance
2010	11.3	6.4	176.6%	8.1	4.6	176.1%	17.3	9.8	176.5%
2011	21.5	14.9	144.3%	16.7	11.2	149.1%	36.5	23.8	153.4%

Commercial/Industrial

Year	Winter Peak MW Reduction			Summer Peak MW Reduction			GWh Energy Reduction		
	Commission			Commission			Commission		
	Total Achieved	Approved Goal	% Variance	Total Achieved	Approved Goal	% Variance	Total Achieved	Approved Goal	% Variance
2010	7.2	0.9	800.0%	11.1	2.5	444.0%	18.3	6.5	281.5%
2011	19.0	2.0	950.0%	26.4	6.1	432.8%	51.3	17.1	300.0%



BEFORE THE
FLORIDA PUBLIC SERVICE COMMISSION

DOCKET NO. 120234-EI
IN RE: TAMPA ELECTRIC COMPANY'S
PETITION TO DETERMINE NEED FOR
POLK 2-5 COMBINED CYCLE CONVERSION

DIRECT TESTIMONY AND EXHIBIT
OF
J. BRENT CALDWELL

1 **BEFORE THE FLORIDA PUBLIC SERVICE COMMISSION**

2 **PREPARED DIRECT TESTIMONY**

3 **OF**

4 **J. BRENT CALDWELL**

5

6 **Q.** Please state your name, business address, occupation and
7 employer.

8

9 **A.** My name is J. Brent Caldwell. My business address is
10 702 N. Franklin Street, Tampa, Florida 33602. I am
11 employed by Tampa Electric Company ("Tampa Electric" or
12 "company") as Director of Origination & Market Services.

13

14 **Q.** Please provide a brief outline of your educational
15 background and business experience.

16

17 **A.** I received a Bachelor Degree in Electrical Engineering
18 from Georgia Institute of Technology in 1985 and a
19 Master of Science in Electrical Engineering from the
20 University of South Florida in 1988. I have over 15
21 years of utility experience with an emphasis in state
22 and federal regulatory matters, natural gas procurement
23 and transportation, fuel logistics and cost reporting,
24 and business systems analysis. In October 2010, I
25 assumed my current position where a portion of my

1 responsibilities include the long term fuel supply
2 planning and procurement for Tampa Electric's generation
3 plants.

4
5 **Q.** What is the purpose of your direct testimony?

6
7 **A.** The purpose of my direct testimony is to describe Tampa
8 Electric's fuel procurement and delivery strategy for
9 Polk 2-5 Combined Cycle Conversion ("Polk 2-5"). I
10 describe the pipeline infrastructure, contractual
11 portfolio, and company capabilities that will be used to
12 ensure reliable and cost-effective fuel supply for Polk
13 2-5.

14
15 I also sponsor the fuel price forecast that was used in
16 the Polk 2-5 analyses. I describe the development of
17 the fuel price forecast, including the sources of
18 projected future prices, the value of sensitivity around
19 those price projections, and the reasonableness of the
20 forecast for use in the Polk 2-5 analyses.

21
22 Finally, I briefly describe Tampa Electric's market
23 solicitation for reliable and cost-effective purchased
24 power alternatives in lieu of building Polk 2-5. This
25 description includes Tampa Electric's Request for

1 Proposals ("RFP") issued March 23, 2012 and the bids
2 received in response to the RFP.

3
4 **Q.** Have you prepared an exhibit to support your direct
5 testimony?

6
7 **A.** Yes, Exhibit No. _____ (JBC-1) was prepared under my
8 direction and supervision. It consists of the following
9 documents:

- 10 Document No. 1 Fuel Price Forecast
11 Document No. 2 Fuel Price Forecast Range Compared to
12 Independent Forecasts

13
14 **Q.** Are you sponsoring any sections of Tampa Electric's
15 Determination of Need Study for Electrical Power: Polk
16 2-5 Combined Cycle Conversion ("Need Study")?

17
18 **A.** Yes. I sponsor sections of the Need Study regarding the
19 fuel price forecasts. Specifically, I sponsor sections
20 III.C. "Fuel Forecast," IV.A.1., "Firm Purchased Power
21 Agreements," and VIII.B.1. "Fuel Sensitivity".

22
23 **FUEL SUPPLY FOR POLK UNITS 2-5 CC CONVERSION**

24 **Q.** Please describe the fuel supply needs for Polk 2-5?
25

1 **A.** When the conversion is complete, Polk 2-5 will be an
2 approximately 1,100 (1,063 summer, 1,195 winter) MW
3 natural gas fueled combined-cycle ("CC") unit. The
4 incremental capacity of the project, over and above the
5 current stand-alone combustion turbine ("CT") capacity
6 of Polk Units 2 through 5, will be approximately 459 MW
7 of summer capacity and 463 MW of winter capacity. With
8 an overall heat rate of approximately 7 MMBtu/MWH, Polk
9 2-5 requires approximately 7 MMBtu/MWH times 1,100 MW
10 which equals 7,700 MMBtus of natural gas fuel per hour
11 of generation at maximum generation. When the unit runs
12 for 16 hours, its total natural gas consumption will be
13 approximately 7,700 MMBtu/hour times 16 hours which
14 equals 123,200 mmBtu of total natural gas consumption.
15 These figures provide a sense of the amount of gas that
16 will need to be procured to run the plant.

17
18 In addition to the primary fuel of natural gas, half of
19 Polk 2-5 will be able to run on distillate oil. When
20 oil is used to fuel two of the four CTs in Polk 2-5, the
21 natural gas fuel requirements will be essentially
22 reduced by half. While natural gas supply disruptions
23 are rare, this dual fuel capability will provide for
24 added reliability from a fuel supply perspective.

25

1 **Q.** How does Polk 2-5 fit into Tampa Electric's overall fuel
2 supply strategy?

3
4 **A.** The Tampa Electric generation fleet consists of a
5 balanced portfolio of coal and natural gas fueled
6 generation assets. Because Polk 2-5 will utilize heat
7 recovery technology on existing units, the conversion
8 fits into the company's fuel supply strategy in many
9 ways. Polk 2-5 maintains the balance of coal and
10 natural gas fueled generation in the company's portfolio
11 while improving total system fuel efficiency. This
12 improved efficiency results in lower energy costs for
13 customers and maintains the price stability afforded by
14 a balance of coal and natural gas fueled generation.

15
16 **Q.** How will the fuel supply needs of Polk 2-5 be met?

17
18 **A.** The existing flexible and reliable natural gas and oil
19 supply infrastructure will continue to be used to supply
20 fuel to Polk 2-5. Polk 2-5 will utilize the existing
21 natural gas commodity portfolio, storage, pipeline
22 capacity and infrastructure along with backup oil
23 capability and storage in a more efficient manner. The
24 four existing CTs, Polk Units 2 through 5, are currently
25 in operation at Polk Power Station and are already using

1 those fuel supply assets. The steam turbine added to
2 convert the four CTs to a combined-cycle unit uses the
3 waste heat from the existing CTs to generate the
4 additional MW, without the need for additional fuel.
5 The four existing CTs generate approximately 160 MW each
6 and require approximately 11.0 MMBtu/MWh of natural gas
7 at maximum generation. Therefore, the four existing CTs
8 require four times 160 MW times 11.0 MMBtu/MWh, which
9 equals 7,000 MMBtus/hour, nearly the same amount of fuel
10 per hour for 640 MW as required by Polk 2-5 that will
11 deliver approximately 1,100 MW. Also, Polk CT Units 2
12 and 3 have distillate oil backup, including storage.
13 Those units will have the same oil backup capability and
14 utilize the same distillate oil supply and storage when
15 they become part of Polk 2-5.

16
17 **Q.** What other considerations make fuel supply for Polk 2-5
18 reliable and cost-effective?

19
20 **A.** Tampa Electric's portfolio of natural gas fuel supply
21 assets and generation units combined with Tampa
22 Electric's experience and capability in natural gas fuel
23 supply enhance the reliability and cost-effectiveness of
24 the fuel supply for Polk 2-5.

25

1 **Q.** Does Tampa Electric have experience supplying fuel for
2 natural gas fueled units?

3
4 **A.** Yes, Tampa Electric has been supplying natural gas to
5 Polk Units 2-5 since 2000, to the H. L. Culbreath
6 Bayside Power Station ("Bayside Power Station") since
7 2003, and to five aero-derivative peaking units located
8 at Bayside Power Station and Big Bend Power Station
9 since 2009.

10
11 Specifically, the company's Fuels Management department
12 provides procurement and fuel management services for
13 support of the Tampa Electric generation portfolio as
14 well as the Peoples Gas System distribution system.
15 Fuels Management has developed and manages a diverse
16 portfolio of natural gas supply assets that includes
17 commodity supply source from several regions, salt
18 cavern storage capacity, upstream pipeline capacity, and
19 market area delivery pipeline capacity on three
20 different interstate pipelines.

21
22 **Q.** Please describe Tampa Electric's current natural gas
23 delivery capability and flexibility to the Polk site and
24 the rest of its system?

25

1 **A.** Tampa Electric maintains a commodity supply portfolio
2 which includes base load, intermediate and daily swing
3 supply. This supply portfolio is coupled with a
4 significant portfolio of natural gas pipeline assets to
5 serve the company's fleet of natural gas fueled
6 generators. Bayside, Polk and Big Bend Power Stations
7 are physically connected to the Florida Gas Transmission
8 ("FGT") pipeline system. Bayside and Big Bend Power
9 Stations are physically connected to the Gulfstream
10 Pipeline, LLC ("Gulfstream") system. Thus, Tampa
11 Electric has redundant physical natural gas delivery to
12 two of its three natural gas fueled stations. In
13 addition to physical natural gas pipeline delivery
14 flexibility, Tampa Electric also has interstate pipeline
15 contractual delivery flexibility. The company has
16 multiple long-term firm pipeline capacity agreements
17 with FGT and Gulfstream. Tampa Electric's primary
18 service agreement with FGT lists Bayside and Polk Power
19 Stations as Primary Delivery Points allowing Tampa
20 Electric to deliver natural gas to either plant as a
21 Primary Delivery Point. Natural gas scheduled timely to
22 either station as a primary delivery point will have the
23 highest priority for delivery in the event of a pipeline
24 constraint.

25

1 With its physical delivery flexibility and contractual
2 delivery flexibility, the company's natural gas
3 portfolio contains significant reliability and
4 flexibility to direct gas supply deliveries to different
5 power plants using either FGT or Gulfstream. Each day,
6 Tampa Electric assesses the economic benefits and
7 operational reliability of its natural gas delivery
8 assets. The company chooses the most economic and
9 reliable dispatch of its pipeline portfolio for serving
10 Tampa Electric's natural gas generation needs, depending
11 on the current circumstances. Polk CT Units 2-5 already
12 benefit from this reliable and flexible portfolio, and
13 that benefit will continue for Polk 2-5 after the
14 conversion.

15
16 **Q.** Are there opportunities to further enhance the long-term
17 reliability and flexibility of the natural gas delivery
18 portfolio?

19
20 **A.** Yes. In addition to its access to FGT, the Gulfstream
21 pipeline is located relatively close to the Polk Power
22 Station property. While the connection is not needed
23 currently, Tampa Electric expects that when economics
24 and market operational issues indicate that it is
25 beneficial, the company will eventually connect Polk

1 Power Station to Gulfstream to further enhance the
2 reliability and optionality of natural gas supply and
3 delivery to Polk Power Station.
4

5 **Q.** Please describe the backup fuel source that could be
6 used for Polk 2-5 in the event of a natural gas supply
7 disruption?
8

9 **A.** Polk CTs 2 through 3 already have distillate oil backup
10 fuel capability and onsite storage. The existing
11 distillate tank provides enough storage to operate those
12 CT units for at least 72 hours of continuous operation.
13 Tampa Electric also has existing liquid fuel supply
14 contracts to replenish the diesel fuel as necessary.
15

16 **Q.** Do you believe sufficient fuel supply will be available
17 to support Polk 2-5 during the unit's expected life?
18

19 **A.** Yes. Natural gas supplies have surged in the U.S. due
20 to recent developments in the extraction of natural gas
21 trapped in shale formations. The Energy Information
22 Administration indicates natural gas supplies are
23 growing and there are enough proven reserves in the U.S.
24 to meet the country's natural gas supply needs for many
25 decades.

1 **FUEL PRICE FORECAST**

2 **Q.** Are you sponsoring fuel price forecasts that were used
3 in the Polk 2-5 analyses?
4

5 **A.** Yes. I am sponsoring fuel price forecasts prepared
6 under my direction and that were provided to the
7 company's Resource Planning group for use in the Polk 2-
8 5 economic analyses.
9

10 **Q.** Please describe the process of developing and applying
11 fuel forecasts at Tampa Electric?
12

13 **A.** Tampa Electric prepares an official, 30-year fuel price
14 forecast each summer, and this official forecast is used
15 by the Resource Planning group for long-term planning
16 analyses conducted during the subsequent twelve months.
17 This official forecast is prepared during the summer to
18 coincide with preparation of the Fuel and Purchased
19 Power Cost Recovery Clause filing typically filed with
20 the Florida Public Service Commission at the beginning
21 of August, for the actual/re-projection of the current
22 year, and the beginning of September, for the projected
23 year. This same official long-term forecast is also
24 used for the Ten Year Site Plan ("TYSP") filed the
25 following April. Consistent with Tampa Electric's

1 typical processes, the fuel price forecast used in the
2 Polk 2-5 economic analyses was the same official long-
3 term forecast prepared in the summer of 2011 for the
4 2012 Fuel and Purchased Power Cost Recovery Clause
5 Projection filing and the 2012 TYSP.

6
7 **Q.** Please describe how the fuel forecast was prepared for
8 each commodity.

9
10 **A.** The fuel price forecast contains projected pricing for
11 the commodity and delivery of the commodity for natural
12 gas, distillate oil (*i.e.*, No. 2 oil), residual oil
13 (*i.e.*, No. 6 oil), coal, and propane. The forecast is
14 produced annually and spans a projected 30-year time
15 period. The projected fuel commodity prices are derived
16 from a combination of published market indices,
17 independent fuel price forecasts, and escalators. Tampa
18 Electric utilizes the escalators to extend the forecasts
19 beyond the period of published values.

20
21 The foundation for the natural gas price forecast is the
22 10-year New York Mercantile Exchange ("NYMEX") natural
23 gas futures monthly contract closing prices for the five
24 consecutive business days between July 5, 2011 and July
25 11, 2011. Since the NYMEX natural gas futures contract

1 is based on physical delivery of natural gas to the
2 Henry Hub in southern Louisiana, Tampa Electric adds a
3 "basis" cost to account for the company receiving its
4 natural gas delivered into FGT Zone 3 instead of into
5 the Henry Hub. This establishes the first 10 years of
6 the forecast. To generate the full 30 year forecast
7 (i.e., the remaining 20 years), Tampa Electric escalates
8 the natural gas price by the projected escalation of the
9 Consumer Price Index Less Energy.

10
11 The foundation for the distillate oil forecast is the
12 NYMEX No. 2 Heating Oil futures contract monthly closing
13 prices for the five consecutive business days between
14 June 1, 2011 and June 7, 2011. At that time, the NYMEX
15 only published the No. 2 oil futures contracts through
16 December, 2012. To generate the full 30-year forecast,
17 Tampa Electric escalated the distillate oil price
18 consistent with the escalation used for natural gas.

19
20 The foundation for the residual oil forecast is the
21 distillate oil forecast. To produce the residual oil
22 forecast, Tampa Electric first calculated the
23 relationship between distillate and residual oil, i.e.,
24 the cost ratio of No. 6 to No. 2 oil. The company
25 applied this relationship to its distillate oil forecast

1 to derive the residual oil price. The result is a 30-
2 year forecast for residual oil.

3
4 When forecasting coal prices, Tampa Electric uses
5 published forecasts for "like-quality" coals (*i.e.*,
6 coals that are comparable to those burned in its
7 generating units). If necessary, the company makes
8 price adjustments to the published indices or published
9 forecast prices to account for quality and locational
10 differences. These price adjustments align the
11 published coal's heat content and sulfur content with
12 the coals burned at Tampa Electric's coal generating
13 stations.

14
15 The foundation of the coal forecast is a combination of
16 various published index prices for like-quality coal for
17 the first two to four years. The publications include
18 *Coal Daily* and ICAP, an online energy broker and
19 information service. For the subsequent years through
20 2018, a weighted average price is developed using *Argus*
21 *Coal Daily* and index prices, along with the coal prices
22 from an independent, published forecast from Wood
23 Mackenzie Energy Consultants ("Wood Mac"). The company
24 utilizes a weighted average method where Tampa
25 Electric's final coal forecast blends the published

1 market indices with the Wood Mac forecast. The market
2 indices are a high percentage of the blend in the near
3 term and Wood Mac is a low percent. Over time the
4 market indices percentage decreases until the Wood Mac
5 forecast is 100 percent of the forecasted price. Beyond
6 2018, the coal commodity price is escalated annually
7 consistent with the escalation of the other commodities.

8
9 **Q.** Are Tampa Electric's fuel price forecasts reasonable for
10 planning purposes and as a basis for committing to
11 proceed with Polk 2-5?

12
13 **A.** Yes. As previously described, Tampa Electric's fuel
14 price forecasts are based on sound, industry-respected
15 publications, indices, forecasts and escalators. Tampa
16 Electric's approach of using NYMEX as the basis of its
17 fuel price forecasts is a reasonable approach. The
18 NYMEX represents the balance point between buyers and
19 sellers and is a sound indicator of the market for a
20 fuel commodity, including fuels such as natural gas and
21 oil.

22
23 **Q.** Did Tampa Electric consider fuel price uncertainty in
24 its fuel price forecasts?

25

1 **A.** Yes. While Tampa Electric believes its base forecast is
2 appropriate for planning purposes, the company also
3 recognizes that uncertainty exists in any fuel price
4 forecast. To evaluate fuel price fluctuations, Tampa
5 Electric prepared high and low price forecasts for
6 natural gas, oil, and coal. For both oil and natural
7 gas, these alternative scenario price forecasts are
8 increased or decreased by 35 percent. For coal, the
9 commodity price is increased or decreased by 20 percent.
10 Document No. 2 of my exhibit shows a graphical
11 representation of the range of natural gas prices used
12 by Tampa Electric for analysis. Natural gas price
13 forecasts from the Energy Information Administration and
14 Wood Mac are also included on the graph. As shown on
15 the graph, Tampa Electric's base forecast is consistent
16 with other independent forecasts available at the time
17 and the sensitivity range is reasonable.

18

19 **Q.** Has Tampa Electric updated its annual fuel price
20 forecast?

21

22 **A.** Yes. Tampa Electric recently updated its fuel price
23 forecast for the 2013 fuel and purchased power cost
24 recovery clause projection filing. This forecast was
25 developed similarly to the 2012 fuel projection forecast

1 and fuel costs are generally lower in the 2013
2 projection than the 2012 projection. The 2013 fuel
3 projection fuel price was also used as a sensitivity in
4 the Polk 2-5 analysis.
5

6 **REQUEST FOR PROPOSALS**

7 **Q.** Did Tampa Electric test the power market for purchase
8 power opportunities that could substitute for Polk 2-5?
9

10 **A.** Yes. Tampa Electric published an RFP on March 23, 2012,
11 soliciting proposals for power to purchase. The company
12 also consulted with Mr. Alan S. Taylor of Sedway
13 Consulting to assist with drafting the RFP document and
14 evaluating subsequent proposals. Mr. Taylor's direct
15 testimony, filed on behalf of Tampa Electric in this
16 docket, describes his role in the RFP process. As
17 detailed in his direct testimony, Mr. Taylor has a vast
18 amount of experience with conducting power RFP and need
19 determinations in the U.S., including Florida. Mr.
20 Taylor provided guidance to Tampa Electric so that the
21 RFP was open and inviting to potential bidders.
22

23 **Q.** What information did the RFP include?
24

25 **A.** The RFP provided a detailed description of the Polk 2-5

1 project, fuel types and costs, estimated costs of the
2 proposed project and other major financial assumptions.
3 The RFP also contained minimum proposal requirements,
4 such as the requirement for firm capacity and firm
5 access to fuel, and a timeline of key RFP activities,
6 such as dates for the RFP Bid Workshop and the proposal
7 submission deadline. Lastly, the RFP contained a draft
8 proposed purchase power agreement, allowing potential
9 respondents to submit proposals based upon known and
10 consistent terms and conditions.

11
12 **Q.** How did Tampa Electric solicit responses to the RFP?

13
14 **A.** In order to alert the market to this RFP, the company
15 published notices in the *Wall Street Journal*, the *Tampa*
16 *Tribune* and other energy industry publications. Two
17 informational meetings were held at the company's
18 headquarters in Tampa to describe the RFP process and to
19 encourage offers and proposals in response to the RFP.
20 The first meeting was a pre-release meeting held on
21 March 21, 2012. This meeting was noticed to the public
22 on March 16, 2012 and was held prior to the official
23 release of the RFP. The purpose of the pre-release
24 meeting was to discuss the RFP process, including how to
25 obtain a copy of the RFP and its attachments and how to

1 formally submit questions to Tampa Electric. The second
2 meeting was the RFP Bid Workshop held on April 4, 2012.
3 The workshop provided a more in-depth review of the RFP
4 and provided participants the opportunity to ask in
5 depth questions after having reviewed the RFP. Both
6 meetings allowed potential bidders to participate either
7 in person or via telephone conference call. Lastly,
8 Tampa Electric established a publicly available web site
9 (www.tampaelectric.com/2017powerrfp) that granted access
10 to the RFP documents and contained a form whereby
11 potential respondents could submit RFP questions to
12 Tampa Electric. The company posted the questions
13 anonymously and the corresponding answers on the web
14 site for the benefit of all potential respondents.

15
16 **Q.** Was there robust participation in the RFP?

17
18 **A.** Yes. Both the pre-release conference and the post-
19 release workshop were attended by numerous individuals
20 representing several segments of the energy industry and
21 no objections to the process were expressed by the
22 participants. Also, over 70 questions were posted to
23 the website and answered by the company. Ultimately,
24 the company received four proposals. Each proposal was
25 opened by Mr. Taylor, the third party evaluator, and

1 accepted as a qualifying bid for evaluation. The
2 evaluation process is described in the direct
3 testimonies of Mr. Taylor and Tampa Electric witness R.
4 James Rocha.

5
6 **Q.** Please summarize your direct testimony.

7
8 **A.** Tampa Electric seeks to maintain a balance of fuel types
9 with flexible supply and delivery options for the
10 generating sources on its system as a way to provide
11 lower cost, to manage fuel price stability and maintain
12 fuel supply reliability. The company determined that
13 additional natural gas fueled generation is needed and
14 will accomplish these goals. Tampa Electric's proposed
15 Polk 2-5 project will convert four existing natural gas
16 fueled CTs into a more efficient combined cycle
17 operating unit. Since the steam turbine is powered by
18 waste heat from the existing CTs, the pipeline
19 infrastructure, including primary firm delivery point
20 designation, already exist at the site. Thus, Polk 2-5
21 will benefit from using the existing expertise and
22 flexible and reliable fuel supply infrastructure already
23 being utilized to fuel all of the company's generation
24 fleet.

25

1 The company has utilized independent, industry-
2 recognized fuel price forecasts and market information
3 as the basis of the fuel price forecast used in the Polk
4 2-5 need determination analyses. The forecasted fuel
5 prices are based on NYMEX futures markets, published
6 market indices, and independent energy consultant
7 forecasts. The forecast used for the need determination
8 is the same forecast Tampa Electric produced for its
9 2012 Fuel and Purchased Power Cost Recovery Clause
10 filings and its 2012 Ten Year Site Plan, and the
11 issuance and analysis of the RFP responses.
12 Additionally, the company utilized fuel price
13 sensitivities to evaluate price uncertainty with respect
14 to forecasted natural gas, oil, and coal commodity
15 prices. Polk 2-5 will allow Tampa Electric to maintain
16 system fuel diversity that results in reliability and
17 cost advantages that benefit customers.

18
19 **Q.** Does this conclude your direct testimony?
20

21 **A.** Yes, it does.
22
23
24
25

EXHIBIT

OF

J. BRENT CALDWELL

Table of Contents

DOCUMENT NO.	TITLE	PAGE
1	Fuel Price Forecast	24
2	Fuel Price Forecast Range Compared to Independent Forecasts	26

TAMPA ELECTRIC COMPANY
DOCKET NO. 12 _____-EI
EXHIBIT NO. _____ (JBC-1)
DOCUMENT NO. 1
FILED: 09/12/2012

DOCUMENT NO. 1

FUEL PRICE FORECAST

Table of Forecasted Fuel Prices


Tampa Electric Fuel Prices Forecast 2013 - 2040			
Year	Natural Gas \$/MMBtu	No. 2 Oil \$/Gallon	Illinois Basin Coal \$/ton
2013	\$5.12	\$3.33	\$55.57
2014	\$5.39	\$3.51	\$56.45
2015	\$5.67	\$3.69	\$58.88
2016	\$5.95	\$3.88	\$55.48
2017	\$6.23	\$4.06	\$55.24
2018	\$6.51	\$4.24	\$52.26
2019	\$6.79	\$4.42	\$55.94
2020	\$7.07	\$4.60	\$59.64
2021	\$7.34	\$4.78	\$63.20
2022	\$7.63	\$4.97	\$66.81
2023	\$7.80	\$5.08	\$69.16
2024	\$7.97	\$5.19	\$71.55
2025	\$8.14	\$5.30	\$73.96
2026	\$8.31	\$5.41	\$76.40
2027	\$8.49	\$5.53	\$78.85
2028	\$8.67	\$5.64	\$81.35
2029	\$8.85	\$5.76	\$83.89
2030	\$9.03	\$5.88	\$86.48
2031	\$9.22	\$6.00	\$89.11
2032	\$9.41	\$6.13	\$91.79
2033	\$9.61	\$6.26	\$94.52
2034	\$9.80	\$6.38	\$97.31
2035	\$10.01	\$6.52	\$100.14
2036	\$10.21	\$6.65	\$103.03
2037	\$10.42	\$6.79	\$105.97
2038	\$10.64	\$6.93	\$108.97
2039	\$10.85	\$7.07	\$112.03
2040	\$11.08	\$7.21	\$115.15

TAMPA ELECTRIC COMPANY
DOCKET NO. 12 _____-EI
EXHIBIT NO. _____ (JBC-1)
DOCUMENT NO. 2
FILED: 09/12/2012

DOCUMENT NO. 2

FUEL PRICE FORECAST RANGE
COMPARED TO INDEPENDENT FORECASTS

Graph of Natural Gas Price Forecast with Range and Compared to Independent Forecasts





BEFORE THE
FLORIDA PUBLIC SERVICE COMMISSION

DOCKET NO. 120234-EI
IN RE: TAMPA ELECTRIC COMPANY'S
PETITION TO DETERMINE NEED FOR
POLK 2-5 COMBINED CYCLE CONVERSION

DIRECT TESTIMONY
OF
DAVID M. LUKCIC

1 **BEFORE THE FLORIDA PUBLIC SERVICE COMMISSION**

2 **PREPARED DIRECT TESTIMONY**

3 **OF**

4 **DAVID M. LUKCIC**

5
6 **Q.** Please state your name, business address, occupation and
7 employer.

8
9 **A.** My name is David M. Lukcic. My business address is 702
10 North Franklin Street, Tampa, Florida 33602. I am
11 employed by Tampa Electric Company ("Tampa Electric" or
12 "company") as Manager Environmental Capital Projects in
13 the Environmental Health and Safety Department.

14
15 **Q.** Please provide a brief outline of your educational
16 background and business experience.

17
18 **A.** I received a Bachelor's of Science degree in Electrical
19 Engineering from University of South Florida, and a
20 Masters of Business Administration from University of
21 South Florida. I am also a registered Professional
22 Engineer in the State of Florida. I worked in Energy
23 Delivery in Distribution Engineering and Standards for
24 two years overseeing the design and implementation of
25 our company's distribution design standards. In 2000, I

1 was promoted to Manager of Land and Water Programs in
2 Environmental Affairs. In 2003, I became Manager
3 Environmental Capital Projects in Environmental Health
4 and Safety. I have overseen the development, submittal,
5 and permitting of Transmission Line Siting Act ("TSLA")
6 and Power Plan Siting Act ("PPSA") projects over the
7 last 12 years. This includes the Willow Oak - Wheeler -
8 Davis and the Lake Angus - Gifford transmission siting's
9 as well as the development and submittal of both
10 integrated coal gasification combined cycle ("IGCC") and
11 natural gas combined cycle ("NGCC") units.

12
13 **Q.** What is the purpose of your direct testimony?
14

15 **A.** The purpose of my direct testimony is to demonstrate,
16 from an environmental perspective, the benefits of the
17 proposed Polk 2-5 Combined Cycle Conversion over other
18 alternatives Tampa Electric considered. I will describe
19 the environmental requirements and permits necessary to
20 comply with existing regulation. Finally, I will explain
21 why the selection of NGCC technology is the best
22 alternative to ensure the company meets or surpasses
23 environmental requirements on emissions over other
24 technologies.
25

1 Q. Are you sponsoring any sections of Tampa Electric's
2 Determination of Need Study for Electrical Power: Polk 2-
3 5 Combined Cycle Conversion ("Need Study")?
4

5 A. Yes. I sponsor sections of the Need Study entitled
6 "Environmental". Specifically, I sponsor sections III.D
7 "Environmental" and IX.C. "Environmental."
8

9 **ENVIRONMENTAL BENEFITS OF POLK 2-5**

10 Q. What are the environmental benefits of NGCC generation
11 versus simple cycle combustion turbine ("CT") generation?
12

13 A. The conversion of the existing CTs to an NGCC unit is
14 designed to take advantage of the waste heat from
15 operation of the CTs that would otherwise be vented into
16 the atmosphere. This waste heat is a valuable resource
17 that can be used to generate up to 352 MW of electric
18 power without any additional fuel input. The addition of
19 heat recovery will make the efficiency of these
20 generating units to increase by approximately 37 percent.
21 The improvement in power generating efficiency results in
22 a direct reduction in the emission rate for all
23 pollutants on a pound per MWH basis and will also reduce
24 CO₂, NO_x, and SO_x emission rates by approximately 37
25 percent.

1 The project will also include the installation of
2 Selective Catalytic Reduction ("SCRs") equipment in each
3 heat recovery steam generator ("HRSG") to reduce NO_x
4 emissions. The SCRs in combination with cycle
5 efficiency improvements will provide an 86 percent
6 reduction in the NO_x emission rate.
7

8 **Q.** Are there any other environmental benefits specific to
9 the Polk 2-5 conversion project?
10

11 **A.** Yes, the Polk Power Station site is already sited and
12 zoned for power generation. This project takes advantage
13 of significant existing infrastructure. The Polk Power
14 Station site will also take advantage of an existing
15 Reclaimed Water Supply Agreement with the City of
16 Lakeland and Polk County that will provide for a majority
17 of the water needed for the expansion. The project will
18 utilize reclaimed water for the makeup to the cooling
19 reservoir. Lakeland's Water Treatment Facility currently
20 discharges its reclaimed water into the Alafia River
21 which flows into Tampa Bay. Polk Power Station is taking
22 this water from Lakeland and treating it removing any
23 nutrients before discharging into Little Pane Creek which
24 aids in improving the water quality in Tampa Bay. Using
25 the treated water will minimize additional consumptive

1 use withdrawals to the greatest extent possible and will
2 assist in lessening the amount of nutrients flowing into
3 Tampa Bay.
4

5 **ENVIRONMENTAL APPROVALS AND REQUIREMENTS**

6 **Q.** What type of permits will be required for Polk 2-5?
7

8 **A.** Polk 2-5 will require federal, state, and regional
9 environmental approvals and permits. The principal
10 approval is Certification under Florida's Electrical
11 PPSA. This will include a comprehensive review of all
12 environmental aspects of Polk 2-5, coordinated through
13 the Florida Department of Environmental Protection
14 ("FDEP") and will involve all state and regional agencies
15 with environmental responsibility and those potentially
16 affected by Polk 2-5.
17

18 **Q.** Please summarize the major requirements for the
19 environmental approvals for Polk 2-5.
20

21 **A.** The environmental approvals required for the Polk 2-5
22 conversion will require the assembly of technical
23 information on the physical equipment and operational
24 parameters in addition to the environmental aspects of
25 the future operations. The environmental regulatory

1 agencies will evaluate the environmental impacts and/or
2 improvements of the project against historical operations
3 of the plant and alternate generation technologies.
4 Based on this evaluation they will make a determination
5 whether any operational restrictions are needed or if any
6 additional pollution control equipment is needed for the
7 Polk 2-5 conversion.
8

9 **Q.** What is the schedule for filing the required
10 environmental permits?
11

12 **A.** We expect to file the Site Certification Application with
13 the FDEP in September 2012.
14

15 **Q.** What general features of the Polk Power Station site
16 serve to meet existing or potential environmental
17 requirements?
18

19 **A.** The Polk Power Station site was selected because of the
20 advantages of using the existing site and infrastructure
21 which helps minimize environmental impacts. The Polk
22 Power Station site includes sufficient land area, which
23 has been previously certified in accordance with the
24 PPSA. In addition, Polk Power Station has secured
25 additional consumptive water from Reclaimed Water Use

1 Agreements with both the City of Lakeland and Polk
2 County. These agreements will not only minimize
3 additional groundwater withdrawals but will also remove
4 nutrients from the reclaimed water before it is used for
5 cooling water purposes and then returned to the
6 environment.

7

8 **Q.** Will the proposed project comply with all local, state
9 and federal environmental standards and requirements?

10

11 **A.** Yes, it will.

12

13 **COMPLIANCE STRATEGY**

14 **Q.** Will the emission rates of mercury from Polk 2-5 meet or
15 be lower than regulatory standards?

16

17 **A.** The recently promulgated Mercury and Air Toxics Standards
18 for mercury and other hazardous air pollutants do not
19 apply to natural gas-fired units and there are no other
20 mercury emission rate standards applicable to Polk 2-5.
21 Mercury emissions from natural gas units are de minimis.

22

23 **Q.** What are the Mercury and Air Toxics ("MACT") standards
24 for Electric Generating Units and how will they influence
25 or impact Polk 2-5?

1 **A.** The MACT standards for Electric Generating Units are not
2 applicable to natural gas units including Polk 2-5.

3
4 **Q.** How do the emissions of Polk 2-5 compare to those from
5 units using coal generation technologies?

6
7 **A.** The emissions from Polk 2-5 are substantially lower than
8 units using coal generation technologies. In fact,
9 compared to super critical coal technology, NO_x SO₂, CO₂,
10 emissions are lower by 90, 99, and 42 percent
11 respectively, and Mercury levels are 99.9 percent lower
12 utilizing the proposed combined cycle technology.

13
14 **Q.** How do the air emission rates for Polk 2-5 compare with
15 recently proposed NGCC generation projects such as
16 Florida Power & Light's ("FP&L") modernization of Port
17 Everglades Plant?

18
19 **A.** Polk 2-5 will have similar emission rates to recently
20 proposed NGCC projects such as FP&L's modernization of
21 Port Everglades. This is demonstrated by a comparison of
22 the most recently proposed projects in the state of
23 Florida based on permit applications and proposed data.

24
25 **Q.** How will the emission rates proposed for Polk 2-5 affect

1 air quality?

2

3 **A.** The emission rates will only minimally affect Florida's
4 air quality. This owes largely to the fact that the bulk
5 of the incremental generation will come from waste heat
6 from natural gas combustion that is already occurring.
7 Polk County and the entire air shed or geographical area
8 associated with Polk 2-5 are classified as in attainment
9 with all National Ambient Air Quality Standards. The
10 emissions as a result of Polk 2-5 are not expected to
11 change the attainment status of the area.

12

13 **OTHER ENVIRONMENTAL CONSIDERATIONS**

14 **Q.** Are there any environmental or permitting requirements
15 associated with the proposed transmission line required
16 for the Polk 2-5 project?

17

18 **A.** Yes. The associated transmission facilities will be
19 permitted through the FDEP Site Certification process.
20 The company does not anticipate any problems obtaining
21 the necessary permitting as a majority of the route will
22 be in either Tampa Electric owned land/easements or in
23 road right-of-way. The preferred route also minimizes
24 any environmental impact and is further described in the
25 direct testimony of Tampa Electric witness S. Beth Young.

1 Q. Please summarize your direct testimony.

2

3 A. Polk 2-5 will utilize a proven technology that will not
4 only meet, but will likely surpass existing environmental
5 regulatory requirements. The selection of NGCC
6 technology over other alternatives will minimize
7 emissions while simultaneously providing cost-effective
8 and reliable energy. This project takes advantage of the
9 waste heat which will result in additional generation
10 with minimal fuel addition therefore reducing emissions
11 on a pound per MWH basis. The project will also take
12 advantage of the existing site infrastructure and the
13 water resources that exist at the current facility.

14

15 Q. Does this conclude your direct testimony?

16

17 A. Yes, it does.

18

19

20

21

22

23

24

25



BEFORE THE
FLORIDA PUBLIC SERVICE COMMISSION

DOCKET NO. 12 0234-EI

IN RE: TAMPA ELECTRIC COMPANY'S
PETITION TO DETERMINE NEED FOR
POLK 2-5 COMBINED CYCLE CONVERSION

DIRECT TESTIMONY AND EXHIBIT

OF

S. BETH YOUNG

1 **BEFORE THE FLORIDA PUBLIC SERVICE COMMISSION**

2 **PREPARED DIRECT TESTIMONY**

3 **OF**

4 **S. BETH YOUNG**

5
6 **Q.** Please state your name, business address, occupation and
7 employer.

8
9 **A.** My name is S. Beth Young. My business address is 702 N.
10 Franklin Street, Tampa, Florida 33602. I am employed by
11 Tampa Electric Company ("Tampa Electric" or "company") as
12 Director, Energy Control Center.

13
14 **Q.** Please provide a brief outline of your educational
15 background and business experience.

16
17 **A.** I received my Bachelor's of Science in Electrical
18 Engineering degree from the University of South Florida
19 in 1983. I am a registered professional engineer in the
20 state of Florida. I joined Tampa Electric as a co-
21 operative education student in 1980 and became a full
22 time employee as an associate engineer in 1983. From
23 1983 through 2007, I held various positions in Tampa
24 Electric's Electric Delivery Department including System
25 Operations, Substation Engineering, Lighting and

1 Standards. In 2007, I was promoted to Director,
2 Substation Services and Project Management. In this
3 position, I was responsible for the construction and
4 maintenance of the substation facilities of Tampa
5 Electric and the management of large Transmission and
6 Distribution ("T&D") projects within Tampa Electric. In
7 August 2009, I added Meter Services responsibilities
8 which included meter specifications, testing, meter
9 reading, and field credit. In February 2010, I was named
10 Director, Energy Control Center. My present
11 responsibilities include the areas of long-term
12 transmission and distribution infrastructure planning
13 day-to-day distribution outage restoration, transmission
14 and distribution system operations, system dispatch
15 operations, wholesale energy accounting and billing,
16 transmission billing, system reliability tracking and
17 reporting, construction and maintenance of Tampa
18 Electric's lighting facilities and Energy Delivery
19 emergency response and planning.
20

21 **Q.** What is the purpose of your direct testimony?
22

23 **A.** The purpose of my direct testimony is to describe how
24 Tampa Electric determined the most cost-effective
25 transmission plan for the interconnection and integration

1 of Tampa Electric's proposed Polk 2-5 Combined Cycle
2 ("Polk 2-5") Conversion project that meets both North
3 American Electric Reliability Council ("NERC") and
4 Florida Reliability Coordinating Council ("FRCC")
5 reliability standards. I will discuss the overall
6 transmission evaluation process Tampa Electric conducted
7 including the stability and steady state power flow study
8 results used in determining the most cost-effective
9 manner to interconnect and integrate Polk 2-5 into the
10 transmission system. Finally, I will discuss the
11 estimated costs and construction schedule of the
12 transmission system facilities required to interconnect
13 and integrate Polk 2-5 into Tampa Electric's system.

14
15 **Q.** Have you prepared an exhibit to support your direct
16 testimony?

17
18 **A.** Yes. I sponsor Exhibit No. ____ (SBY-1) that consists of
19 four documents:

20
21 Document No. 1 Polk 2-5 CC Interconnection Diagram

22 Document No. 2 Polk 2-5 Integration Diagram

23 Document No. 3 Summary of Required Facilities,
24 Ratings and Cost
25

1 Document No. 4 FRCC letter confirming the
2 reliability of the interconnection
3 and integration plan
4

5 **Q.** Are you sponsoring any sections of Tampa Electric's
6 Determination of Need Study for Electrical Power: Polk 2-
7 5 Combined Cycle Conversion ("Need Study")?
8

9 **A.** Yes. I sponsor section III.A.1. entitled "Transmission
10 and Distribution" and section IX.D. entitled
11 "Transmission Facilities".
12

13 **Q.** Please describe Tampa Electric's transmission system.
14

15 **A.** Tampa Electric's transmission system consists of
16 approximately 1,300 miles of transmission lines and is
17 operated at 3 different voltage levels; 69 kV, 138 kV,
18 and 230 kV. Tampa Electric is interconnected to four
19 other balancing areas through twenty-seven tie lines.
20

21 **Q.** Please describe Tampa Electric's evaluation process that
22 results in determining the most cost-effective
23 transmission system requirements for new generation
24 resources.
25

1 **A.** Tampa Electric's process begins with evaluating the
2 proposed generating plant site location to determine its
3 proximity to existing transmission facilities. To the
4 extent there are existing transmission facilities nearby,
5 the site is then assessed to determine its capability for
6 reliably interconnecting and integrating the proposed new
7 generation into the transmission system as a firm Tampa
8 Electric network resource.

9

10 **Q.** What factors are considered when integrating the proposed
11 new generation into the transmission system?

12

13 **A.** There are numerous factors that are considered prior to
14 integration of a new generating unit into the bulk
15 electric system ("BES"). They include:

16

- 17 • The megawatt ("MW") amount of generation being added
18 at the generation site and various dispatch profiles
19 of the new generation resource relative to existing
20 generation resources serving Tampa Electric and
21 others utilities' load in the region;
- 22 • Compliance with NERC and FRCC reliability standards;
- 23 • Stability and system protection impacts;
- 24 • Impact on existing Tampa Electric or third party
25 facilities;

- 1 • Capability to upgrade existing substation or
2 transmission facilities;
- 3 • Ability to site new substation or transmission line
4 facilities including right-of-way requirements,
5 existing right-of-way capabilities, permitting
6 requirements, and expected time frame to acquire
7 right-of-way and necessary permits;
- 8 • Ability to construct the required transmission
9 facilities without having to take outages on
10 existing operating facilities during periods that
11 would result in an adverse reliability impact;
- 12 • Operating considerations such as maintenance
13 requirements of the proposed interconnection and
14 integration facilities and impacts to the ongoing
15 operation of the system;
- 16 • The timing and amount of power needed for testing
17 equipment such as pumps and motors;
- 18 • Expected in-service testing and commercial operation
19 dates for new generation, which determines the date
20 transmission interconnection and integration
21 facilities must be completed for the unit's testing;
22 and
- 23 • The initial and ongoing costs of facilities and
24 operations.

25

1 Q. How did Tampa Electric evaluate the impact of the Polk 2-
2 5 generation addition on the Bulk Electric System?

3
4 A. A Network Resource Interconnect Study ("NRIS") was used
5 to evaluate the impact of the generation addition on
6 Florida's BES. The NRIS included a review of stability
7 requirements, short circuit impacts and steady state
8 requirements in compliance with NERC and FRCC reliability
9 standards. These power flow studies were used to
10 evaluate the performance of the transmission system and
11 to determine various project alternatives that would be
12 needed to interconnect and integrate the new generation
13 into the BES.

14
15 Q. How were project alternatives for adding or upgrading
16 transmission facilities developed?

17
18 A. A Tampa Electric core team developed and reviewed
19 potential alternatives and estimated costs. This core
20 team was comprised of engineers from System Planning,
21 Environmental, Health and Safety, Substation Engineering,
22 Transmission Engineering, Telecommunications, System
23 Security and staff from Line Clearance, Real Estate,
24 Project Management, and Community Relations. As part of
25 their analysis, this team considered the issues outlined

1 previously, including ability to construct, potential
2 upgrade of existing facilities, right-of-way
3 requirements, in-service dates and operating
4 considerations. When the core team was satisfied that
5 they had developed the most cost-effective transmission
6 interconnection and integration plan that complied with
7 NERC and FRCC reliability standards, the process was
8 deemed complete.

9

10 **Q.** How is the Polk Power Station connected to the BES?

11

12 **A.** The Polk Power Station is interconnected to the BES
13 through the Polk Power Substation.

14

15

16

17

18

19

20 **Q.** What were the results of the stability, short circuit and
21 power flow studies that Tampa Electric performed?

22

23 **A.** The stability studies did not show any adverse impacts to
24 the BES by the addition of the Polk 2-5. The Short
25 circuit study showed that 16-230 kV circuit breakers

1 located at Polk Power, Pebbledale, Mines and Big Bend
2 Power Substations did not meet the interrupting
3 capability required due to the addition of Polk 2-5.

4
5 The results of the power flow studies determined under
6 certain dispatches an overload might occur on the
7 following facilities:

- 8 1. The 230 kV transmission line from Polk Power
9 Substation to Mines Substation,
- 10 2. The 230 kV transmission line from Pebbledale
11 Substation to FishHawk Substation,
- 12 3. The two 230 kV transmission lines from Polk Power
13 Substation to Pebbledale Substation,
- 14 4. Some additional 3rd parties' transmission facilities.

15
16 These results indicated that, under extreme conditions,
17 there might not be enough transmission capability out of
18 Polk Power Substation to transmit the entire plant's
19 capacity. After considering these potential impacts, the
20 core team set about to consider various alternatives to
21 insure continuing BES reliability.

22
23 **Q.** What projects did the core team recommend after reviewing
24 the power flow study results?

- 1 **A.** The core team recommended the following projects in order
2 to maintain the BES reliability:
- 3 1. Build a new 230 kV transmission switching station
4 (Aspen Substation) west of Mines Substation.
 - 5 2. Build the following 230 kV transmission lines
6 • Polk Power Substation to Mines Substation,
7 • Mines Substation to Aspen Substation,
8 • Two lines from Aspen Substation to FishHawk
9 Substation.
 - 10 3. Upgrade segments of existing 230 kV transmission
11 lines to create a 230 kV transmission line from Polk
12 Power Substation to Aspen Substation.
 - 13 4. Interconnect and rerate existing 230 kV transmission
14 line from Big Bend Power Substation to Mines
15 Substation into Aspen Substation.
 - 16 5. Upgrade 16-230 kV circuit breakers at Polk Power
17 Substation, Pebbledale Substation, Mines Substation
18 and Big Bend Power Substation.
 - 19 6. Reroute and upgrade the first Polk Power Substation
20 to Pebbledale Substation 230 kV transmission line.
 - 21 7. Rerate the second Polk Power Substation to
22 Pebbledale Substation 230 kV transmission line.
 - 23 8. Install a switched reactor at Davis Substation.
 - 24 9. Upgrade the bus for the State Road 60 North 230/69
25 kV Transformer.

1 10. Upgrade the bus and low side circuit breaker for the
2 Dale Mabry West 230/69 kV Transformer.

3
4 **DESCRIPTION OF PLANNED PROJECT**

5 **Q.** Please provide a general description of the existing
6 transmission facilities at Polk Power Station.

7
8 **A.** As I previously stated, the Polk Power Substation is
9 connected to the BES by four 230 kV transmission lines.
10 Two of these lines run from Polk Power Substation to the
11 Tampa Electric Pebbledale Substation. The third line
12 runs from Polk Power Substation to Tampa Electric's Mines
13 Substation and the fourth from Polk Power Substation to
14 Invenergy's Hardee Station.

15
16 **Q.** Please provide a general description of the transmission
17 facilities required for interconnection and integration
18 of Polk 2-5 to Tampa Electric's system.

19
20 **A.** Two new 230 kV transmission circuits, three new 230 kV
21 circuit breakers and a generator step-up transformer will
22 be required to interconnect the new generation to the
23 Polk Power Substation. As previously stated, one new
24 switching substation, four new 230 kV transmission lines
25 and upgrades to four other 230 kV transmission lines will

1 be required to integrate Polk 2-5 into the BES. In
2 addition, sixteen circuit breakers will need to be
3 upgraded, some buswork and a 69 kV circuit breaker
4 upgraded and a switched reactor added.

5
6 **Q.** Has the route for the four new 230 kV transmission lines
7 been selected?

8
9 **A.** Yes. A route study was initiated in December 2011 and
10 completed on July 27 2012. The route study identified
11 the most cost-effective corridor Tampa Electric should
12 utilize for the four new 230 kV transmission lines
13 necessary as part of the Polk 2-5 project. Tampa
14 Electric expects approval from the Florida Department of
15 Environmental Protection of the corridor in the fourth
16 quarter of 2013.

17
18 **Q.** How did Tampa Electric evaluate the transmission related
19 costs associated with the planned Polk 2-5?

20
21 **A.** An estimating team made up of members from Substation
22 Engineering, Transmission Engineering, Real Estate,
23 System Security, Telecommunications, Line Clearance,
24 Community Relations, Project Management, and
25 Environmental Health and Safety reviewed the transmission

1 interconnection and integration requirements to develop a
2 scope of work. This included the review of existing
3 drawings and site visits. Each member, along with an
4 engineering consulting firm, then estimated the costs to
5 complete their scope of work. As stated previously, the
6 final corridor for the four new 230 kV transmission lines
7 was not selected until July 27, 2012; therefore, the
8 transmission line costs were based on one of the
9 potential routes. The potential route used in the
10 evaluation was approximately 4 miles longer than the
11 route determined to be the most cost-effective in the
12 completed route study.

13
14 **Q.** What is the total cost of the transmission
15 interconnection and integration costs for Polk 2-5?

16
17 **A.** The total estimated project cost is approximately \$147.2
18 million. A summary of the facilities required and
19 associated costs is provided in Document No. 3 of my
20 exhibit. Utilizing the updated information from the
21 aforementioned route study completed on July 27, 2012,
22 project costs would decrease as compared to those used in
23 the project estimate, but these costs have not been
24 finalized.

1 **Q.** What is the schedule for construction of the transmission
2 facilities needed for the interconnection and integration
3 of Polk 2-5?
4

5 **A.** The Polk 2-5 interconnection/integration work is
6 scheduled to begin January 2013 and is estimated to be
7 completed by November 2016. This will allow time for
8 testing of the unit and associated NGCC equipment prior
9 to its commercial in-service date. The Polk Power
10 Substation to Aspen Substation to FishHawk Substation
11 transmission line construction will begin by October 2014
12 with an in-service date of November 2016. The remainder
13 of the work will be completed prior to November 2016.
14 This ensures that all transmission facilities will be in-
15 service prior to any full power testing of Polk 2-5.
16

17 **Q.** Has this assessment, along with the Polk 2-5
18 interconnection and integration requirements discussed
19 above, been reviewed by the FRCC?
20

21 **A.** Yes. According to the FRCC's Regional Transmission
22 Planning Process, Tampa Electric's interconnection and
23 integration plan for Polk 2-5 as discussed above was
24 provided to the FRCC for review and affirmation was given
25 that no reliability issues exist. A letter from the

1 FRCC confirming the reliability of Tampa Electric's
2 interconnection and integration plan is provided in
3 Document No. 4 of my exhibit.
4

5 **Q.** What were the FRCC conclusions about Tampa Electric's
6 Polk 2-5 transmission plan?
7

8 **A.** Based on the review and analysis conducted by the
9 Transmission Working Group, the FRCC Planning Committee
10 has determined that the proposed interconnection and
11 integration plan will be reliable and will not adversely
12 impact the reliability of the FRCC transmission system.
13

14 **TRANSMISSION RELIABILITY BENEFITS OF POLK 2-5**

15 **Q.** How will Polk 2-5 and its associated transmission
16 facilities improve Tampa Electric's transmission
17 reliability to Tampa Electric customers?
18

19 **A.** In addition to integrating the Polk 2-5 generation
20 reliably into the BES, the new transmission facilities
21 will also increase the import and export capability of
22 the Tampa Electric transmission system. This provides
23 more source options during planned and unplanned
24 generation outages. The upgrades of the existing 230 kV
25 facilities will also reduce the existing exposure to

1 multi-circuit structure outages, increasing the
2 reliability of the transmission system.

3
4 The addition of the new transmission facilities in the
5 Central Florida region of the BES will also improve the
6 reliability of that region for Tampa Electric customers
7 as well as for those in the FRCC region.

8
9 **Q.** Please summarize your direct testimony.

10
11 **A.** Tampa Electric has completed stability, short circuit and
12 power flow studies to determine the impact of the
13 interconnection and integration of Polk 2-5 to the BES.
14 The studies indicate two new 230 kV transmission
15 circuits, three new 230 kV circuit breakers and a
16 generator step-up transformer will be required to
17 interconnect the new generation to the Polk Power
18 Substation. In addition one new switching substation,
19 four new 230 kV transmission lines and upgrades to other
20 230 kV transmission lines will be required to integrate
21 Polk 2-5 into the BES. Sixteen circuit breakers, some
22 buswork and a 69 kV circuit breaker will also need to be
23 upgraded as well as the addition of a switched reactor.

24
25 These additions will reliably interconnect and integrate

1 the Polk 2-5 into the BES. In addition, Tampa Electric
2 customers will benefit by the increased import and export
3 capability, reduced exposure to multi-circuit structure
4 outages and improved reliability for the Central Florida
5 region.

6
7 **Q.** Does this conclude your direct testimony?

8
9 **A.** Yes, it does.

10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25

EXHIBIT

OF

S. BETH YOUNG

Table of Contents

DOCUMENT NO.	TITLE	PAGE
1	Polk 2-5 CC Interconnection Diagram	20
2	Polk 2-5 Integration Diagram	23
3	Summary of Required Facilities, Ratings and Cost	25
4	FRCC Letter Confirming the Reliability of the Interconnection and Integration Plan	27

TAMPA ELECTRIC COMPANY
DOCKET NO. 12 _____-EI
EXHIBIT NO. _____ (SBY-1)
DOCUMENT NO. 1
FILED: 09/12/2012

DOCUMENT NO. 1

POLK 2-5 CC INTERCONNECTION DIAGRAM

REDACTED

TAMPA ELECTRIC COMPANY
DOCKET NO. 12 _____-EI
EXHIBIT NO. _____ (SBY-1)
DOCUMENT NO. 1
FILED: 09/12/2012

The content of this page has been redacted and filed separately with a request for confidential classification.

REDACTED

TAMPA ELECTRIC COMPANY
DOCKET NO. 12_____-EI
EXHIBIT NO. ____ (SBY-1)
DOCUMENT NO. 1
FILED: 09/12/2012

The content of this page has been redacted and filed separately with a request for confidential classification.

TAMPA ELECTRIC COMPANY
DOCKET NO. 12 _____-EI
EXHIBIT NO. _____ (SBY-1)
DOCUMENT NO. 2
FILED: 09/12/2012

DOCUMENT NO. 2

POLK 2-5 INTEGRATION DIAGRAM

REDACTED

TAMPA ELECTRIC COMPANY
DOCKET NO. 12 _____-EI
EXHIBIT NO. _____ (SBY-1)
DOCUMENT NO. 2
FILED: 09/12/2012

The content of this page has been redacted and filed separately with a request for confidential classification.

TAMPA ELECTRIC COMPANY
DOCKET NO. 12_____-EI
EXHIBIT NO. ____ (SBY-1)
DOCUMENT NO. 3
FILED: 09/12/2012

DOCUMENT NO. 3

SUMMARY OF REQUIRED FACILITIES, RATINGS AND COST

Summary of Required Facilities, Ratings and Cost

Circuit #	Point of Origin and Termination	Project Description	Revised Rating (MVA)	Anticipated Capital Investment (\$ million)
230007	Big Bend to Aspen 230 kV	This circuit will be rerated to a rating of 729.4 MVA.	729.4	\$125
230401	Polk to Aspen 230 kV	The existing circuits from Polk to Mines East and from Mines West to Big Bend will be disconnected from Mines substation and tied together to create the modified circuit 230401. This circuit will be rerated to a rating of 729.4 MVA.	729.4	
230402	Mines West to Aspen 230 kV	This is a new construction of approximately 15 miles circuit with a rating of 1,118.6 MVA.	1,118.6	
230426	Aspen to FishHawk 230 kV	This is a new construction of approximately 6 miles of two circuits with a rating of 1,195.1 MVA.	1,195.1	
230427	Aspen to FishHawk 230 kV	This is a new construction of approximately 6 miles of two circuits with a rating of 1,195.1 MVA.	1,195.1	
230606	Polk to Pebbledale Ckt 1 230 kV	This circuit will be rerouted for approximately 9.8 miles to eliminate a double circuit line with the existing Polk to Mines East line with a rerate of 729.4 MVA.	729.4	
230635	Polk to Mines East 230 kV	This is a new construction of approximately 12 miles circuit with a rating of 1,118.6 MVA.	1,118.6	
-	Aspen Switching Station	This is a new construction of the Aspen 230 kV Switching Station along the existing circuits between Mines West and Big Bend.	-	\$8
-	Davis Substation Switched Reactor	A new switchable series reactor will be installed on the Davis to Chapman circuit (230601).	-	\$2
-	FishHawk 230 kV Substation Upgrade	The FishHawk 230 kV Substation will be upgraded as a result of the additional capacity.	-	\$1
-	Mines 230 kV Substation Upgrade	The Mines 230 kV Substation will be upgraded as a result of the additional capacity.	-	\$2
-	Polk Steam Turbine Interconnect & Upgrade	The Polk 2-5 Steam Turbine will be interconnected to the existing station and required upgrades.	-	\$5


26

TAMPA ELECTRIC COMPANY
 DOCKET NO. 12 _____ -EI
 EXHIBIT NO. _____ (SBY-1)
 DOCUMENT NO. 3
 FILED: 09/12/2012

TAMPA ELECTRIC COMPANY
DOCKET NO. 12 _____-EI
EXHIBIT NO. _____ (SBY-1)
DOCUMENT NO. 4
FILED: 09/12/2012

DOCUMENT NO. 4

FRCC LETTER CONFIRMING THE RELIABILITY OF THE
INTERCONNECTION AND INTEGRATION PLAN



FLORIDA RELIABILITY COORDINATING COUNCIL, INC.
1408 N. WESTSHORE BLVD., SUITE 1002
TAMPA, FLORIDA 33607-4512
PHONE 813.289.5644 • FAX 813.289.5646
WWW.FRCC.COM

June 7, 2012

Beth Young
Director of Energy Control Center
Tampa Electric
P.O. Box 111
Tampa, FL 33601-0111

Re: FRCC Review of the Polk Power Station Combined Cycle Conversion interconnection

Dear Beth,

Florida Reliability Coordinating Council's (FRCC) Transmission Working Group (TWG) and Stability Working Group (SWG) have evaluated the proposed interconnection and integration of the Polk Power Station Units 2-5 Combined Cycle Conversion Project (PK CC Conv Project) to interconnect to the Tampa Electric (TEC) transmission system. Based upon the information provided by TEC to the FRCC, the TWG has determined that the proposed interconnection and integration of the PK CC Conv Project with the identified projects, protection upgrades and remedies, is reliable and does not adversely impact the transmission system within the FRCC Region.

The PK CC Conv Project will encompass converting the existing Polk Power Station simple cycle combustion turbines (Polk Units 2-5) into a natural gas fired, four-on-one, combined cycle unit with the addition of a new steam turbine. The new steam turbine will result in an incremental 500 MW net increase (summer and winter) to the existing capacity of the four simple cycle combustion turbines located in Polk County, Florida. The proposed total capability of the PK CC Conv Project will have a summer net output of 1,195 MW and a winter net output of 1,232 MW. The scheduled in-service date is January 1, 2017.

The TWG reviewed the results of the steady state single and multiple contingency analyses. The results did not identify any contingency event that caused limitations in the FRCC Region with PK CC Conv Project facility at maximum queued output. In addition to the steady state analysis, the SWG reviewed the dynamic simulations showing a stable response at peak load and light load levels for normally cleared and delayed cleared three-phase faults in the vicinity of PK CC Conv Project. The results indicate that there are no grid stability concerns with the addition of the PK CC Conv Project.

A review of the short circuit analysis has shown that there are no short circuit concerns with the addition of the PK CC Conv Project.

Based upon the above review and analysis conducted by the TWG, the FRCC Planning Committee has determined that the proposed interconnection and integration of the PK CC Conv Project to interconnect to the TEC system, does not adversely impact the reliability of FRCC transmission system.

Sincerely,

Vicente Ordax, Jr., P.E.
Manager of Planning



BEFORE THE
FLORIDA PUBLIC SERVICE COMMISSION

DOCKET NO. 120234-EI
IN RE: TAMPA ELECTRIC COMPANY'S
PETITION TO DETERMINE NEED FOR
POLK 2-5 COMBINED CYCLE CONVERSION

DIRECT TESTIMONY AND EXHIBIT
OF
R. JAMES ROCHA

1 **BEFORE THE FLORIDA PUBLIC SERVICE COMMISSION**

2 **PREPARED DIRECT TESTIMONY**

3 **OF**

4 **R. JAMES ROCHA**

5
6 **Q.** Please state your name, business address, occupation and
7 employer.

8
9 **A.** My name is R. James Rocha. My business address is 702 N.
10 Franklin Street, Tampa, Florida 33602. I am employed by
11 Tampa Electric Company ("Tampa Electric" or "company") as
12 Director of Planning, Strategy & Compliance. I direct the
13 resource planning group where my responsibilities include
14 identifying the need for future resource additions as well as
15 analyzing the economic and other operational impacts to Tampa
16 Electric's system associated with the addition of resource
17 options.

18
19 **Q.** Please provide a brief outline of your educational background
20 and business experience.

21
22 **A.** I graduated from the Georgia Institute of Technology with a
23 Bachelor of Nuclear Engineering degree in 1982 and a Master
24 of Science Degree in Nuclear Engineering in 1983. I earned a
25 Master's degree in Business Administration from the

1 University of Tampa in 1993 and I am a registered
2 Professional Engineer in the State of Florida. In 1984, I
3 was employed by Commonwealth Edison Company as a nuclear fuel
4 engineer, modeling unit operation. In 1987, I joined Florida
5 Power, and became a resource planning engineer in the
6 Generation Planning department. In 2000, I became Manager of
7 Financial Analysis at TECO Energy, responsible for business
8 development and asset management. Since 2006, I have held
9 several positions at Tampa Electric responsible for
10 budgeting, business strategies and North American Electric
11 Reliability Corporation ("NERC") Critical Infrastructure
12 Protection ("CIP") and non-CIP NERC compliance. I have 28
13 years of accumulated electric utility experience working in
14 the areas of resource planning, business and financial
15 analysis, and engineering. In December 2011, I was appointed
16 to my current position.

17
18 **Q.** What is the purpose of your direct testimony?
19

20 **A.** The purpose of my direct testimony is to describe Tampa
21 Electric's integrated resource planning ("IRP") process and
22 the resulting resource plan which supports the 2017 need for
23 the Polk 2-5 combined cycle conversion project ("Polk 2-5"),
24 a natural gas combined cycle ("NGCC") unit rated at 459 MW
25 summer and 463 MW winter net incremental capacity,

1 respectively. My direct testimony will (1) describe Tampa
2 Electric's existing system and resource mix, (2) describe
3 Tampa Electric's IRP process for selection of future demand
4 and supply resource alternatives, (3) demonstrate that Polk
5 2-5 is the most cost-effective alternative to reliably meet
6 Tampa Electric's customer needs, (4) describe the need for
7 additional resources for the Florida Reliability Coordinating
8 Council ("FRCC") region, (5) describe the results of the RFP
9 analysis, and (6) explain the adverse consequences if Polk 2-
10 5 is deferred or denied.

11
12 **Q.** Have you prepared an exhibit to support your direct
13 testimony?

14
15 **A.** Yes, Exhibit No. _____ (RJR-1) was prepared under my
16 direction and supervision. It consists of the following
17 thirteen documents:

- 18 Document No. 1 Energy Mix by Fuel Type
19 Document No. 2 Capacity Mix by Fuel Type
20 Document No. 3 Levelized Cost Screening Curves
21 Document No. 4 Tampa Electric Reliability Analysis
22 Document No. 5 FRCC Reliability Analysis
23 Document No. 6 FRCC Reliability Sensitivity Analysis
24 Document No. 7 Preliminary Resource Plans & Analysis
25 Document No. 8 IRP Resource Plans & Analysis

- 1 Document No. 9 IRP Sensitivity Analysis
- 2 Document No. 10 RFP Summary of Proposals
- 3 Document No. 11 RFP Resource Plans & Analysis
- 4 Document No. 12 RFP Qualitative Factors
- 5 Document No. 13 June 2012 Assumptions Update

6

7 **Q.** Are you sponsoring any sections of Tampa Electric's
8 Determination of Need Study for Electrical Power: Polk 2-5
9 Combined Cycle Conversion ("Need Study")?

10

11 **A.** Yes. I am sponsoring the following sections of the Need
12 Study: I. "Executive Summary", II. "Introduction and
13 Overview", III.A. "Description of Tampa Electric's System",
14 III.F.2. "Supply Technologies", IV. "Need for Capacity in
15 2017" (with the exception of IV.A.1.), V. "Screening of
16 Potential Technologies", VI. "Detailed Economic Analysis",
17 VII. "Sensitivity Analysis", X. "June 2012 Assumptions
18 Update", XI. "Adverse Consequences if Polk 2-5 is Delayed or
19 Denied" and XII. "Conclusion".

20

21 **DESCRIPTION OF EXISTING SYSTEM AND RESOURCE MIX**

22 **Q.** Please describe Tampa Electric's service area.

23

24 **A.** Tampa Electric, an investor-owned electric utility, is the
25 principal subsidiary of TECO Energy, Inc. The service area

1 for Tampa Electric spans approximately 2,000 square miles and
2 consists of Hillsborough County, western Polk County and
3 parts of Pasco and Pinellas counties. Tampa Electric served
4 approximately 676,000 customers in 2011.

5
6 **Q.** What types of units make up Tampa Electric's existing
7 generating system?

8
9 **A.** Tampa Electric has three large generating stations and one
10 peaking station including an integrated gasification combined
11 cycle ("IGCC") and steam coal base load units, NGCC
12 intermediate load units, natural gas and oil fueled
13 combustion turbine units, aero-derivative engine peaking
14 units, and oil fueled internal combustion peaking units. The
15 total net system generating capacity in winter 2011 was 4,684
16 MW and 4,292 MW in summer 2012. Tampa Electric operates 670
17 MW of winter net generating capacity that has dual fuel
18 capability which improves overall system reliability.

19
20 Big Bend Power Station includes four pulverized coal-fired
21 steam units and one aero-derivative peaking unit. Big Bend
22 Units 1 through 4 are coal units that were retrofitted
23 between 2007 and 2010 with additional environmental control
24 systems including selective catalytic reduction ("SCR") to
25 reduce nitrogen oxides ("NO_x") emissions to complete the

1 station's comprehensive air emissions reduction program. Big
2 Bend Combustion Turbine ("CT") 4 is a dual fuel (natural gas
3 or oil) unit that is quick-start (full load in less than 15
4 minutes) and could provide black-start capability (a
5 generating unit capable of starting from a shutdown condition
6 without assistance from the electric system) for the station
7 and the system.

8
9 H. L. Culbreath Bayside Power Station ("Bayside Power
10 Station") includes two NGCC units and four aero-derivative
11 peaking units. Bayside Unit 1 utilizes three combustion
12 turbines, three heat recovery steam generators ("HRSG") and
13 one steam turbine. Bayside Unit 2 utilizes four combustion
14 turbines, four HRSGs and one steam turbine. Bayside Units 3
15 through 6 are natural gas-fired aero-derivative peaking units
16 that are quick-start and provide black start capability for
17 the station and the system.

18
19 Polk Power Station includes one base load and four peak load
20 generating units. Polk Unit 1 is a dual fuel IGCC unit
21 primarily fired with synthesis gas produced from a blend of
22 low-sulfur coal and petroleum coke ("petcoke"). Distillate
23 oil is a secondary fuel which is used for both start-up and
24 shut-down of the power block, and can be used to operate the
25 combined cycle at times when the gasification system is

1 unavailable. Polk Units 2 through 5 are simple cycle CTs
2 primarily fired by natural gas, and Units 2 and 3 are capable
3 of firing distillate oil as a secondary fuel.
4

5 J. H. Phillips Sebring Power Station includes two diesel oil-
6 fired peaking units located in Sebring, Florida. These two
7 units were placed on long-term reserve stand-by ("LTRS")
8 status on September 4, 2009 due to the relative higher cost
9 of heavy oil compared to natural gas and coal. These units
10 will remain on LTRS until the operating costs are competitive
11 with other supply resources. These units also have the
12 potential to utilize liquid biofuels and operate as a
13 renewable energy resource in the future.
14

15 **Q.** Does Tampa Electric include any purchased power in its total
16 supply resource mix?
17

18 **A.** Yes. Tampa Electric purchases power, both firm and non-firm,
19 from other utilities and independent power producers
20 operating in the Florida market. In 2011, Tampa Electric
21 solicited the market for firm peaking power through the end
22 of 2016 to replace the 20-year Hardee Power station purchase
23 power agreement ("PPA") expiring December 31, 2012. Two PPAs
24 were executed in fall 2011 for peaking capacity from the
25 Florida market. These agreements are described in more

1 detail in section III.A.2. of the Need Study. Only firm
2 purchased power capacity is included in the reliability
3 assessment process to determine the timing and minimum amount
4 of new resources required to maintain the firm reserve
5 planning criteria. However, both firm and non-firm purchased
6 power energy is included in the production cost analyses to
7 determine the most cost-effective mix of resources needed.
8

9 **Q.** What is the expected energy and capacity mix by fuel type for
10 Tampa Electric's total supply resources including purchases
11 in 2017?
12

13 **A.** The energy mix by fuel type for 2011 was 56 percent solid
14 fuel, 43 percent natural gas, a slight amount of oil and 1
15 percent net interchange purchases on an energy (MWH) basis.
16 In 2017, the energy mix is expected to be 59 percent solid
17 fuel, 39 percent natural gas, a slight amount of oil and 2
18 percent net interchange purchases on the same basis. This is
19 reflected in Document No. 1 of my exhibit. The capacity mix
20 by fuel type for 2011 was 36 percent solid fuel and 64
21 percent natural gas on a capacity (MW) basis. In 2017, the
22 capacity mix is expected to be 36 percent solid fuel and 64
23 percent natural gas on a capacity (MW) basis. This is
24 reflected in Document No. 2 of my exhibit.
25

1 Q. Has Tampa Electric developed and implemented demand and
2 energy reduction programs in its existing resource mix?

3
4 A. Yes. As described in Section III.A.3. of the Need Study,
5 Tampa Electric has successfully developed and implemented
6 numerous demand reduction and energy conservation programs
7 for over 30 years. The cumulative effect of these programs
8 as of the end of 2011 has eliminated the need for 719 MW in
9 the winter and 306 MW in the summer of net generating
10 capacity by slowing growth in both the company's peak demand
11 and energy requirements. This reduction is roughly
12 equivalent to the combined winter net capacity of Big Bend
13 Units 1 and 2, and by 2017 the cumulative effect of these
14 programs will eliminate the need for more than 376 MW of net
15 summer generating capacity. As a percentage of the Tampa
16 Electric total peak demand, this represents 9.0 percent of
17 the planned total summer peak of 4,165 MW in 2017, higher
18 than any NERC region average for demand reduction. Tampa
19 Electric witness Howard T. Bryant describes the company's
20 demand-side management ("DSM") achievements in his direct
21 testimony.

22
23 **INTEGRATED RESOURCE PLANNING PROCESS OVERVIEW**

24 Q. What are the objectives of Tampa Electric's IRP process?

25

1 **A.** Tampa Electric's IRP process determines the timing, amount
2 and type of additional demand reduction, energy conservation,
3 and supply resources required to maintain system reliability
4 in a cost-effective manner. The process considers the
5 existing customer demand and energy mix, expected growth and
6 changes in the customer demand and energy requirements,
7 existing and future DSM and energy conservation programs,
8 supply resources comprised of the Tampa Electric generating
9 units and purchased power, existing and future bulk
10 transmission system for Tampa Electric and the Florida grid,
11 and potential renewable energy resources appropriate for the
12 Florida energy market.

13

14 **Q.** Please describe Tampa Electric's IRP process.

15

16 **A.** The IRP process balances existing and future demand and
17 supply resources in a reliable and cost-effective manner
18 while considering strategic factors. Since cost-
19 effectiveness is a requirement for both demand and supply
20 resources, the process is an iterative cycle to capture the
21 value of deferring new generating units or PPAs resulting
22 from additional DSM programs. A reference resource plan that
23 includes both demand and supply resources is developed which
24 then becomes the basis for determining the new avoided costs
25 for deferral of supply resources. The additional cost-

1 effective DSM resources are then implemented to establish the
2 system demand and energy requirement, which is the new basis
3 for consideration of supply resource additions. The cycle is
4 repeated annually each business planning cycle, as all of the
5 operating and financial assumptions are updated.

6
7 The supply resources are initially screened on a levelized
8 cost basis with several criteria: construction costs,
9 operating and maintenance costs, technology viability or
10 applicability to the operating region, commercial
11 availability, and construction lead times. Multiple resource
12 plans are developed that consist of various combinations of
13 technologies and in-service dates to maintain system
14 reliability. The relative impacts of each resource expansion
15 plan are evaluated for total system annual operating and
16 maintenance costs and incremental capital costs. This
17 includes fuel, fixed and variable O&M, purchased power
18 capacity, energy and transmission wheeling and/or
19 transmission construction costs, and the incremental costs to
20 build all new generating units and associated transmission
21 capacity in each expansion plan. The plans are then
22 initially ranked based on the lowest cumulative present worth
23 revenue requirements ("CPWRR") of the system over a 30-year
24 operating period.

25

1 The highest ranked resource plan incorporates an initial
2 demand and energy forecast including DSM and supply
3 resources. The supply resources in the reference resource
4 plan are then used to determine the avoided cost for an
5 economic analysis of additional viable DSM and conservation
6 programs.

7
8 Next, the cost-effective DSM programs are included in a
9 revised demand and energy forecast which effectively reduces
10 system peaks and energy requirements. The revised system
11 demand and energy forecast is used in a final reliability
12 analysis to determine the new timing and magnitude of
13 additional supply resources needed to meet system reliability
14 criteria.

15
16 Final economic evaluations and sensitivities are performed to
17 determine the recommended resource plan. The highest ranked
18 plans are evaluated under various sensitivities to test key
19 planning assumptions and compare the relative cost impact on
20 a CPWRR basis. Strategic factors such as system and FRCC
21 region reliability, resource dispatchability, system and FRCC
22 deliverability, constructability (lead time, available
23 technology, etc.), fuel diversity and environmental impacts
24 are considered in determining the most cost-effective and
25 viable resource mix for both Tampa Electric's customers and

1 Florida. In addition, the existing generating system is
2 reviewed and includes planned unit retirements, expected
3 modifications to operating performance, capital, fixed O&M,
4 and variable O&M since the integration of new resources has
5 the potential to impact the utilization of existing
6 generating assets.

7
8 **SYSTEM RELIABILITY PROCESS**

9 **Q.** Please describe the criteria that Tampa Electric utilizes in
10 its IRP process to determine both the minimum amount and
11 timing of additional resources required to maintain system
12 reliability.

13
14 **A.** Tampa Electric utilizes a 20 percent firm reserve margin
15 reliability criteria above the system firm peak, as required
16 by the Florida Public Service Commission ("Commission") in
17 Order No. PSC-99-2507-S-EU issued on December 22, 1999, and a
18 minimum 7 percent supply reserve margin. The firm reserve
19 margin consists of both supply and non-firm demand resources
20 to maintain an allowance for unexpected variances in system
21 demand, generating unit availability, and purchased power
22 availability and deliverability. The minimum supply reserve
23 margin criterion maintains an important qualitative component
24 of firm reserves for reliability purposes to minimize the
25 impact of the loss of a supply resource at the time of peak.

1 If the firm reserve margin consisted of only non-firm demand
2 reserves (whereby total firm supply equals total load), then
3 the frequency of use of demand resources in a given year
4 would increase significantly. The firm system peak is
5 determined by including all firm wholesale agreements and
6 excluding non-firm customer demand from the total system
7 demand. Non-firm demand includes all interruptible service
8 customers and customer load reduction programs. Customers
9 who continue to participate in these voluntary programs help
10 defer the need for additional supply resources by reducing
11 firm peak demands. These customers may request to become a
12 firm customer or be excluded from a DSM program with
13 appropriate notification.

14
15 As reflected in its 2011 Ten Year Site Plan ("TYSP") and then
16 updated in its 2012 TYSP analyses, Tampa Electric is
17 expecting to incrementally reduce demand through 2017 by 70.4
18 MW and 33.1 MW in summer and winter, respectively, and reduce
19 the system energy requirement by 230.7 GWH, but will still
20 require 294 MW of capacity additions in 2017 to its existing
21 supply resource mix to meet the 20 percent reserve margin
22 criteria.

23
24 **Q.** Please describe the FRCC Minimum Reserve Margin Planning
25 criterion.

1 **A.** The FRCC has established a minimum firm reserve margin
2 planning criterion of 15 percent, taking into account the
3 three investor owned utilities' requirement of twenty
4 percent. The 15 percent margin is calculated using the
5 aggregate planned firm peaks of all FRCC member utilities in
6 addition to the aggregate generating units and firm PPAs; it
7 also includes all net firm interchange via the bulk
8 transmission ties to the SERC region. This margin assumes
9 that all available capacity is deliverable to all load
10 centers. During the FRCC presentation to the Commission at
11 the TYSP workshop on August 13, 2012 ("TYSP workshop"), the
12 FRCC presented analysis of the degree to which the peninsular
13 Florida system is becoming increasingly dependent upon demand
14 side management to meet its reserve margin criterion. In
15 order to ensure the peninsular Florida system remains
16 reliable in the future, the FRCC has developed and will
17 monitor a metric for DSM as a percentage of regional peak.

18
19 **SUPPLY RESOURCE ANALYSIS**

20 **Q.** What supply alternatives were considered in the analysis that
21 resulted in the selection of converting Polk 2-5 from simple
22 cycle to CC as the company's next planned generating unit
23 addition?

24
25 **A.** Tampa Electric considered a variety of options prior to

1 identifying NGCC technology as the best option for Tampa
2 Electric and its customers. Tampa Electric's screening
3 process included natural gas, solid fuel and renewable
4 technologies. General characteristics of natural gas
5 technologies include lower emissions, lower heat rate,
6 configured as either simple cycle or CC, wide range of
7 capacity sizes, and competitive cost per unit output.
8 Characteristics of solid fuel technologies include lower
9 variable fuel costs and higher fixed costs, such as capital
10 construction and fixed operating and maintenance costs, and
11 somewhat higher emissions depending on environmental control
12 technologies. Solid fuel technologies are typically better
13 suited for large capacity and high utilization applications
14 because these assets will dispatch for longer continuous
15 periods of time. Their lower variable operating costs,
16 longer ramp rates, and longer minimum down times make cycling
17 off the units more difficult than natural gas based
18 technology.

19
20 Renewable technologies tend to have lower or no fuel costs
21 but have significant fixed costs. In addition, technologies
22 such as geothermal and hydroelectric have limited practical
23 application in Florida. Similarly, wind and solar have
24 limited and unpredictable operating hours due to the
25 intermittent nature of their energy source. In the absence

1 of stored energy capability, intermittent renewables are best
2 considered as energy resources and not as firm capacity for
3 planning purposes. However, some renewable energy such as
4 biomass can be considered as a firm resource if sufficient
5 biomass material is stored and available.

6
7 **Q.** Which options were determined to be appropriate for Tampa
8 Electric's needs and system characteristics and analyzed in
9 greater detail?

10
11 **A.** The TYSP process included strategic considerations such as
12 fuel price stability, fuel diversity, environmental impacts,
13 technology viability, construction lead times, site
14 availability, and FRCC regional supply needs in the 2012-2021
15 period. Tampa Electric's screening analysis narrowed the
16 focus to natural gas-fired combined cycle or simple cycle
17 technologies for further analysis in the IRP process.

18
19 **Q.** Please describe the natural gas-fired generation alternatives
20 considered.

21
22 **A.** Tampa Electric considered in its screening simple cycle aero-
23 derivative engines similar to Bayside Unit 3 and simple cycle
24 combustion turbines similar to Polk Unit 5. The company also
25 screened a stand-alone 2x1 combined cycle unit in addition to

1 the integration of the existing Polk Units 2 through 5
2 peaking units into a combined cycle unit.

3
4 **Q.** Please describe the results of Tampa Electric's screening
5 analysis used to select the best supply alternatives for the
6 detailed economic analyses.

7
8 **A.** Tampa Electric's screening analysis of the various
9 alternatives compared the levelized annual cost (\$/kW-yr) of
10 each technology at various capacity factors. The levelized
11 cost includes the cost to construct, operate and maintain
12 each technology. The slope of each cost curve is a function
13 of the heat rate and variable O&M which increases linearly
14 with the increasing capacity factor. For all technologies,
15 the cost at zero capacity factor is simply the levelized
16 construction cost and fixed O&M. Tampa Electric selected the
17 following viable options: natural gas combined cycle
18 technology as intermediate options and simple cycle
19 combustion turbines as peaking options. The graphical
20 results of the levelized cost screening curves are presented
21 in Document No. 3 of my exhibit.

22
23 **DEMAND RESOURCE ANALYSIS**

24 **Q.** How were demand resources factored into the IRP process?
25

1 **A.** Tampa Electric included all DSM programs described by witness
2 Bryant in its preliminary demand and energy forecast, which
3 effectively reduced system peaks and energy requirements. By
4 2017, Tampa Electric's existing and incremental DSM programs
5 are projected to contribute summer and winter demand
6 reductions of 376.4 MW and 752.1 MW, respectively and energy
7 conservation of 1,000.7 GWH is expected and is reflected in
8 the projected firm peak and system energy requirements.

9
10 **Q.** Is it possible for Tampa Electric to meet its expected
11 resource needs through additional DSM and renewable energy
12 resources?

13
14 **A.** No. As previously stated, Tampa Electric identified all
15 cost-effective DSM reductions and utilized that potential in
16 the assessment of this determination of need. There are no
17 additional cost-effective DSM alternatives (above the
18 currently forecasted demand reductions and energy
19 conservation) or viable cost-effective renewable energy
20 resources that would defer the need for additional generating
21 capacity in 2017.

22
23 **RELIABILITY ANALYSIS AND RESOURCE PLAN**

24 **Q.** Please describe the results of the reliability analysis.
25

1 **A.** The reliability analysis was based on existing generating
2 unit operating data and projected system firm peak and energy
3 requirements which were developed in summer 2011. This data
4 supported the development of Tampa Electric's 2012 TYSP filed
5 with the Commission in April 2012. This analysis indicated
6 incremental supply resources are needed in 2017 to meet the
7 20 percent reserve margin criteria and 7 percent minimum
8 supply criteria, as shown on Document No. 4 of my exhibit.
9 Without additional firm supply resources the summer firm
10 reserve margin is 12.5 percent and the supply component would
11 fall to 6.8 percent in summer 2017.

12
13 **Q.** Please describe the results of the FRCC region reliability
14 analysis.

15
16 **A.** Tampa Electric's 2012 TYSP data was included in the aggregate
17 2012 FRCC TYSP workshop presentation to the Commission on
18 August 13, 2012. The FRCC reserve margin table in Document
19 No. 5 of my exhibit shows that the existing planned demand
20 and supply resource additions by Florida utilities will meet
21 the minimum reliability of 15 percent through 2021. However,
22 the initial reliability assessment should remove all planned
23 and proposed unit additions and review potential
24 modifications to existing generating capacity.

25

1 In addition, the FRCC has analyzed the increasing dependency
2 on DSM programs to provide these reserves. Beginning with
3 the 2012 Load & Resource Plan, the FRCC developed a metric
4 for DSM as a percentage of regional peak. During the FRCC
5 workshop, it was reported that of the eight NERC reliability
6 regions, the FRCC is among the highest in DSM as a percentage
7 of regional peak.

8
9 This increased dependency on DSM programs combined with the
10 uncertainty of planned yet uncommitted supply additions as
11 well as existing resources at risk of retirement due to
12 emerging environmental regulations or other factors raise
13 questions regarding future reserve margin calculations. If
14 future additions do not materialize and some existing
15 resources in the region are retired in response to costly
16 mandatory retrofits, the FRCC reserve margin could drop below
17 the minimum required from 2016 through 2019. This
18 sensitivity analysis is reflected in Document No. 6 of my
19 exhibit.

20
21 **Q.** Please describe the results of the preliminary IRP analysis.

22
23 **A.** The IRP included an additional 70.4 MW and 33.1 MW of summer
24 and winter demand reductions and incremental energy
25 conservation of 230.7 GWH compared to the cumulative

1 reductions to date. The IRP also confirmed the need for firm
2 purchases through 2016, and confirmed the need for the
3 conversion of the existing Polk 2-5 peaking units to combined
4 cycle in 2017 together with an additional simple cycle
5 combustion turbine in 2019. The preliminary resource plan is
6 shown in Document No. 7 of my exhibit. This shows that
7 accelerating the Polk 2-5 in-service date from 2019 as shown
8 in the 2011 TYSP to 2017 resulted in \$65.4 million in
9 savings.

10

11 The IRP screening process identified numerous resource plans
12 and two alternate plans were selected for further comparative
13 analysis to the Polk 2-5 plan. The first alternate plan
14 utilized only simple-cycle peaking unit additions throughout
15 the planning horizon, and the second alternate plan utilized
16 simple-cycle peaking units in the near term with the
17 conversion of the Polk CTs to a NGCC in 2025. The final IRP
18 resource plans that Tampa Electric considered are shown in
19 Document No. 8 of my exhibit.

20

21 **Q.** Please describe the results of the final IRP analysis.

22

23 **A.** Tampa Electric's economic evaluation process and
24 consideration of qualitative factors determined that
25 constructing NGCC technology at Polk Power Station

1 represented the most cost-effective option for Tampa Electric
2 and its customers. The expansion plan was then used to
3 develop avoided cost parameters to evaluate new and modified
4 DSM programs. The final Polk 2-5 plan demonstrated a CPWRR
5 savings of \$231.1 million when compared to the next best
6 alternative. The two alternate plans are higher total cost
7 utilizing the base assumptions due to higher operating costs.
8 This base economic analysis is shown in Document No. 8 of my
9 exhibit.

10
11 **Q.** Did Tampa Electric conduct sensitivity analyses related to
12 the selection of Polk 2-5 in the IRP process?

13
14 **A.** Yes. Tampa Electric conducted sensitivity analyses to
15 compare the Polk 2-5 plan with the two alternate expansion
16 plans. The analyses tested the sensitivity of the
17 recommended plan to independent variances in fuel prices,
18 customer demand and energy forecasts, and expansion plan
19 construction costs. High and low fuel forecast bands are
20 discussed in the direct testimony of Tampa Electric witness
21 J. Brent Caldwell. High and low customer demand forecast
22 bands are discussed in the direct testimony of Tampa Electric
23 witness Lorraine L. Cifuentes. High and low construction
24 cost bands are discussed in the direct testimony of Tampa
25 Electric witness Mark J. Hornick. The analysis held all

1 other factors constant while applying the targeted
2 sensitivities to the recommended plan and alternate plans to
3 determine the total systems costs and compare the 30-year
4 CPWRR.

5
6 **Q.** Please describe the results of the IRP sensitivity analyses.

7
8 **A.** After completion of the six sensitivity cases mentioned
9 above, Polk 2-5 was found to be the most economical choice in
10 all cases. When comparing Polk 2-5 to the two alternate
11 plans in the capital cost sensitivities, Polk 2-5 showed
12 savings of \$278.4 million (low cost) and \$289.9 million (high
13 cost) in CPWRR compared to the next most cost-effective
14 option. When comparing Polk 2-5 to the two alternate plans
15 in the customer demand and energy sensitivities, Polk 2-5
16 showed savings of \$283.9 million (low demand) and \$75.6
17 million (high demand) in CPWRR compared to the next most
18 cost-effective option. When comparing Polk 2-5 to the two
19 alternate plans in the fuel price sensitivities, Polk 2-5
20 showed savings of \$106.2 million (low fuel cost) and \$302.1
21 million (high fuel cost) in CPWRR compared to the next most
22 cost-effective option. A summary of the economic sensitivity
23 analysis is shown in Document No. 9 of my exhibit.

24
25 **RESOURCE REQUEST FOR PROPOSALS**

1 **Q.** Did Tampa Electric conduct an RFP to solicit proposals to
2 meet its peaking needs from 2013 through 2016 to replace the
3 expiration of the 20-year Hardee Power agreement that expires
4 on December 31, 2012?

5
6 **A.** Yes. In 2011, Tampa Electric issued a Request for Proposals
7 ("RFP") to solicit market proposals for capacity needs from
8 known participants in the market and conducted bilateral
9 negotiations with the top proposals. This resulted in
10 selecting two competitive agreements to purchase 117 MW
11 peaking power through the end of 2016 and 160 MW peaking
12 power through the end of 2015.

13
14 **Q.** Did Tampa Electric conduct an RFP to solicit alternatives to
15 meet its need for intermediate power beginning in 2017?

16
17 **A.** Yes. Tampa Electric conducted an RFP which solicited
18 proposals from all market participants. In March 2012, Tampa
19 Electric issued an RFP soliciting firm offers for cost-
20 effective alternatives to Polk 2-5. The RFP development and
21 evaluation process are discussed here and in the direct
22 testimony of witness Alan S. Taylor on behalf of Tampa
23 Electric.

24
25 **Q.** Please describe the development process of the RFP.

1 **A.** Various subject matter experts from across the company, along
2 with witness Taylor as the independent evaluator, crafted,
3 reviewed and edited the RFP document. It incorporated
4 sufficient schedule, scope and basis detail for all
5 respondents in the preparation of their bid, specifying how
6 their bid would be evaluated. As an attachment to the RFP,
7 Tampa Electric included a draft PPA that provided respondents
8 with a clear understanding of the general terms and
9 conditions.

10
11 **Q.** Please describe the evaluation process of the RFP?
12

13 **A.** The evaluation process included: initial screening for
14 minimum requirements, high level economic evaluation of
15 individual proposals, present value economic screen of
16 proposals, and a final evaluation of total system costs and
17 non-economic factors. Short-listed bidders were invited to
18 make a best and final offer. The final present value
19 evaluation included a relative evaluation of non-economic
20 factors.

21
22 In addition to evaluating individual proposals, Tampa
23 Electric evaluated combinations of proposals into portfolios
24 of generating alternatives in order to solicit a robust range
25 of individual proposals. Eligible proposals that passed

1 initial screening and individual economic ranking, but did
2 not individually meet the capacity requirement for a given
3 year, were evaluated in portfolios that matched them with
4 other resources to meet the capacity need and the sequence of
5 annual need identified in the solicitation.

6
7 **Q.** What was the result of the RFP for 2017 capacity?

8
9 **A.** Document No. 10 of my exhibit contains a summary of the
10 short-listed bidders. After comparing the results of Tampa
11 Electric's analysis and those performed by the independent
12 evaluator, Polk 2-5 NGCC was selected as the most cost-
13 effective alternative. This resulted in a CPWRR savings of
14 \$132.4 million relative to the next higher cost bidder. A
15 summary of the RFP resource plans and economic analysis is
16 shown in Document No. 11 of my exhibit.

17
18 **Q.** Please describe Tampa Electric's proposed Polk 2-5 NGCC unit.

19
20 **A.** The existing Polk 2 through 5 combustion turbines will be
21 converted to a NGCC facility located at Polk Power Station by
22 integrating a new steam turbine with an additional capacity
23 of 459 MW summer and 463 MW winter, incrementally. This
24 incremental capacity is derived from waste heat from the four
25 existing combustion turbines of 339 MW summer and 352 MW

1 winter, as well as 120 MW summer and 111 MW winter from
2 supplemental natural gas duct-firing in the four HRSGs. This
3 supplemental firing eliminates the need for two future aero-
4 derivative peaking units due to the expiration of a 121 MW
5 PPA on December 31, 2018. In addition, after the Polk 2-5
6 conversion to NGCC, the HRSGs are designed to allow the
7 existing combustion turbines to operate independently in
8 simple cycle mode in the event the steam turbine is
9 unavailable, providing significant system reliability and
10 operating flexibility. The NGCC configuration also enables
11 the potential integration of solar thermal renewable capacity
12 and energy in the future.

13
14 **Q.** Does Polk 2-5 have dual fuel capability?

15
16 **A.** The existing Polk Units 2 and 3 have dual fuel capability;
17 the existing Polk Units 4 and 5 are currently natural gas
18 fuel only, but will be permitted for future dual fuel
19 capability. The cost for converting Units 4 and 5 are not
20 included in the construction and operating plan.

21
22 **Q.** Please describe the consideration of the qualitative factors
23 in the selection of Polk 2-5.

24
25 **A.** Tampa Electric considered 13 unique non-economic, qualitative

1 factors in its selection. The proposals were evaluated
2 individually and in the relative context of the other
3 proposals. Document No. 12 of my exhibit contains a summary
4 of the evaluation of the relative qualitative factors. Polk
5 2-5 NGCC was favored due to its overall reliability, system
6 emissions rate, and dispatchability.

7
8 **FINAL RECOMMENDED RESOURCE PLAN**

9 **Q.** Were any resource plan assumptions updated prior to
10 developing the final recommended resource plan and after the
11 implementation of the RFP?

12
13 **A.** Yes. As part of the business planning cycle for Tampa
14 Electric, the fuel forecast, the customer demand forecast,
15 and other operating and financial forecasts are updated in
16 June 2012 of each year. These updated forecasts are the
17 basis for the next business planning cycle and activities,
18 including: studies which support all of the cost recovery
19 clause filings in August for reforecasting end of current
20 year and following year projections. These updated
21 assumptions are also used to develop the company's following
22 year TYSP filed in April. As a result, Tampa Electric
23 updated its fuel price and customer demand forecast in June
24 2012 as part of its normal business cycle and in preparation
25 for the 2013 fuel adjustment filed in August 2012 and the

1 2013 TYSP filing due in April 2013. This analysis included
2 the impacts of new and modified DSM programs. An assessment
3 of the June 2012 updated fuel price forecast and customer
4 demand and energy forecast confirm the forecasts are within
5 the bands of the sensitivities used in the original IRP
6 process. The updated fuel price forecast reflects lower
7 natural gas prices overall; the updated solid fuel price
8 forecast are somewhat lower as well.

9
10 The updated demand and energy forecast reflects lower growth
11 in customer demand and energy requirements which reduces the
12 amount of capacity needed in 2017 from 294 MW to 205 MW; this
13 affirms Tampa Electric's stated need for additional resources
14 in 2017. The updated forecasts were used to test the IRP and
15 RFP recommended plan to construct Polk 2-5 NGCC as the most
16 cost-effective alternative. For the IRP alternate expansion
17 plan cases using updated forecasts, the Polk 2-5 plan
18 resulted in CPWRR savings of \$266.7 million relative to the
19 closest IRP alternate expansion plan. For the RFP proposals
20 using updated forecasts, the resulting CPWRR savings is \$97.4
21 million relative to the most competitive bidder. Both of
22 these updated forecast results support Tampa Electric's final
23 recommended resource plan. Document No. 13 of my exhibit
24 contains a summary of the analysis utilizing updated
25 assumptions. Finally, considering the comprehensive

1 analyses, the qualitative factors, and the benefit to state-
2 wide reliability Polk 2-5 is the most cost effective
3 alternative for customers.
4

5 **Q.** What is the expected relative average retail customer cost
6 impact of Polk 2-5 compared to the reference case
7 alternative?
8

9 **A.** The relative retail customer cost impact was calculated on an
10 energy (MWH) basis. In 2017, the projected average retail
11 customer cost impact for the Polk 2-5 NGCC plan is \$6.09 per
12 MWH; however, the customer cost recovery clause impact for
13 Polk 2-5 NGCC is projected to be lower by \$1.32 per MWH due
14 to lower fuel and purchased power and capacity costs for a
15 net customer cost impact of \$4.76 per MWH compared to
16 projected costs in 2016. The incremental supplemental duct-
17 firing capacity of Polk 2-5 replaces the purchased power
18 capacity that retires at end of 2018. This cost-effective
19 incremental capacity eliminates the need for additional
20 supply resources and the associated costs to construct and
21 operate those avoided units. Finally, the PPA expiration
22 incrementally lowers the customer cost recovery clause impact
23 by an additional \$0.50 per MWH that would otherwise occur in
24 2019.
25

1 **BASIS FOR DETERMINATION OF NEED**

2 **Q.** Has Tampa Electric adequately established that there is a
3 need for Polk 2-5?
4

5 **A.** Yes. Tampa Electric will require an additional 294 MW of
6 firm supply resources in 2017 based upon the reliability
7 analysis. The most recent June 2012 forecast update for
8 customer demand described in the testimony of witness
9 Cifuentes reaffirms this need; based on this update, there is
10 a need for 205 MW of firm supply resources in 2017.
11

12 **Q.** Is the addition of Polk 2-5 consistent with the needs of
13 peninsular Florida?
14

15 **A.** Yes. Polk 2-5 does not significantly increase Tampa
16 Electric's reliance on natural gas on an energy basis and is
17 therefore consistent with state policy actions that encourage
18 fuel diversity. The Polk 2-5 conversion significantly
19 improves the efficiency of the four existing combustion
20 turbines units and Tampa Electric's system overall by
21 lowering the heat rate and dispatching ahead of other less
22 efficient units. It should also be noted that load
23 management and interruptible customer DSM programs are
24 voluntary, so customers have a choice to withdraw from
25 programs at any time with proper notification. During the

1 2012 TYSP Workshop on August 13, the FRCC presented a chart
2 to the FPSC which showed the summer reserve margin without
3 exercising load management or interruptibles would only be
4 about 15 percent, which includes all planned additions,
5 including Polk 2-5 in 2017.

6
7 Tampa Electric's need for additional natural gas-fired
8 combined cycle capacity in January 2017 is consistent with
9 the Peninsular Florida capacity needs in this same period, as
10 identified by the FRCC and reported in the FRCC 2012 Regional
11 Load and Resource Plan. The FRCC 2012 plan uses Tampa
12 Electric specific data in conjunction with similar
13 information from other Florida electric utilities. In
14 addition, there are concerns regarding continued operation of
15 existing solid fuel assets due to emerging environmental
16 regulations and the costs to comply. Tampa Electric has
17 completed all the required environmental controls for all of
18 its solid fuel units. If future additions do not materialize
19 and some existing resources in the region are retired in
20 response to costly mandatory retrofits, the FRCC reserve
21 margin could drop below the minimum required from 2016
22 through 2019.

23
24 **ADVERSE CONSEQUENCES**

25 **Q.** What would be the adverse consequences if the Polk 2-5 in-

1 service date were delayed from 2017 to 2019?
2

3 **A.** In the event that Polk 2-5 is delayed by two years, project
4 costs would increase, and customer fuel savings for 2017 and
5 2018 would not be realized. Tampa Electric would construct
6 simple cycle peaking units in 2017 to cover the reserve
7 margin requirement in 2017 and 2018. System energy
8 requirements would be served by peaking capacity resulting in
9 higher fuel costs. This would result in higher costs for
10 customers of \$65.4 million on a CPWRR basis. Witness Hornick
11 describes the potential for an equipment demand spike
12 scenario if there is a delay. If this equipment demand spike
13 scenario materializes, this would result in higher costs for
14 customers of \$100.0 million on a CPWRR basis.

15
16 **Q.** What would be the adverse consequences if the proposed Polk
17 2-5 is denied?
18

19 **A.** If Polk 2-5 is denied, Tampa Electric would not be able to
20 satisfy its minimum 20 percent Reserve Margin and minimum 7
21 percent supply planning criteria by the summer of 2017 in the
22 most reliable and cost-effective manner. This would expose
23 Tampa Electric's customers to a greater risk of interruption
24 of service in the event of unanticipated forced outages or
25 other contingencies for which Tampa Electric maintains

1 reserves. Even without an interruption in service, without
2 Polk 2-5 the company's customers would be subject to higher
3 fuel costs as the company would have to rely on less
4 efficient simple cycle generation to meet its need.

5
6 **Q.** Should Tampa Electric's petition for determination of need
7 for Polk 2-5 be approved?

8
9 **A.** Yes. For the reasons I have described, Polk 2-5 is the most
10 cost effective option for Tampa Electric's customers to
11 maintain system reliability, environmental emission rates and
12 fuel diversity. Tampa Electric requests that the Commission
13 issue an affirmative determination of need for Polk 2-5 in
14 this proceeding.

15
16 **Q.** Please summarize your direct testimony.

17
18 **A.** Tampa Electric's IRP process incorporated an on-going
19 evaluation of demand and supply resources and conservation
20 measures to maintain system reliability. By 2017, Tampa
21 Electric's DSM programs will have produced summer and winter
22 customer demand and energy reductions of 376.4 MW and 752.1
23 MW, respectively and energy conservation of 1,000.7 GWH. The
24 reliability analysis determined that Tampa Electric will have
25 capacity needs by 2017 of 294 MW. Alternate plans,

1 technologies, sensitivities, timing, and a market
2 solicitation were evaluated and the selection of Polk 2-5 was
3 supported by subsequent economic analyses of viable supply
4 alternatives, demonstrating that Polk 2-5 is the most cost-
5 effective option compared to other technologies and available
6 supply capacity from the Florida market.

7

8 After consideration of all existing, new and modified DSM
9 programs and renewable energy initiatives, the construction
10 of Polk 2-5 with a January 2017 in-service date should not be
11 deferred. A two-year deferral of the recommended plan could
12 increase costs to customers by \$100.0 million. Tampa
13 Electric also determined that fuel diversity is a key
14 objective and the addition of natural gas combined cycle
15 technology in 2017 still maintains a prudent balance in Tampa
16 Electric's capacity and energy mix. When considering the
17 viability of uncommitted resources, the risk of emerging
18 environmental regulations, and the uncertainty of voluntary
19 DSM programs, Polk 2-5 is needed as a firm resource within
20 the FRCC region.

21

22 Polk 2-5 provides significant savings of \$132.4 million to
23 Tampa Electric's customers when compared to the most cost-
24 effective alternative while providing additional benefits in
25 the areas of reliability, fuel diversity, environmental

1 impacts, and generating system efficiency. The results of
2 these scenarios reinforce Tampa Electric's selection of Polk
3 2-5 as the best alternative for Tampa Electric and its
4 customers.

5

6 **Q.** Does this conclude your direct testimony?

7

8 **A.** Yes, it does.

9

10

11

12

13

14

15

16

17

18

19

20

21

22

23

24

25

EXHIBIT

OF

R. JAMES ROCHA

Table of Contents

DOCUMENT NO.	TITLE	PAGE
1	Energy Mix by Fuel Type	40
2	Capacity Mix by Fuel Type	42
3	Levelized Cost Screening Curves	44
4	Tampa Electric Reliability Analysis	46
5	FRCC Reliability Analysis	48
6	FRCC Reliability Sensitivity Analysis	50
7	Preliminary Resource Plans & Analysis	52
8	IRP Resource Plans & Analysis	54
9	IRP Sensitivity Analysis	56
10	RFP Summary of Proposals	58
11	RFP Resource Plans & Analysis	60
12	RFP Qualitative Factors	62
13	June 2012 Assumptions Update	64


TAMPA ELECTRIC COMPANY
DOCKET NO. 12 _____-EI
EXHIBIT NO. _____ (RJR-1)
DOCUMENT NO. 1
FILED: 09/12/2012

DOCUMENT NO. 1

ENERGY MIX BY FUEL TYPE


Energy Mix By Fuel Type

2011 Actual Energy Percentage By Fuel Type
 Total Energy - 19,325 GWh



□ Coal ▨ Petcoke ■ Net Interchange ▩ Gas - TEC Owned □ Gas - Purchased ■ Oil

2017 Projected Energy Percentage By Fuel Type
 Total Energy - 20,773 GWh



□ Coal ▨ Petcoke ■ Net Interchange ▩ Gas - TEC Owned □ Gas - Purchased ■ Oil


TAMPA ELECTRIC COMPANY
DOCKET NO. 12_____-EI
EXHIBIT NO. ____ (RJR-1)
DOCUMENT NO. 2
FILED: 09/12/2012

DOCUMENT NO. 2


CAPACITY MIX BY FUEL TYPE

Capacity Mix By Fuel Type

2011 Actual Capacity Percentage By Fuel Type
Total Capacity - 4,909 MW



2017 Projected Capacity Percentage By Fuel Type
Total Capacity - 4,856 MW





TAMPA ELECTRIC COMPANY
DOCKET NO. 12 _____-EI
EXHIBIT NO. _____ (RJR-1)
DOCUMENT NO. 3
FILED: 09/12/2012

DOCUMENT NO. 3

LEVELIZED COST SCREENING CURVES

Levelized Cost Screening Curves



TAMPA ELECTRIC COMPANY
DOCKET NO. 12 _____-EI
EXHIBIT NO. _____ (RJR-1)
DOCUMENT NO. 4
FILED: 09/12/2012

DOCUMENT NO. 4

TAMPA ELECTRIC RELIABILITY ANALYSIS

Tampa Electric Reliability Analysis

Forecast of Capacity and Demand at Time of Summer Peak

Year	Total Installed Capacity	Net Firm Capacity Purchases	Total Capacity Available	System Firm Peak Demand	System Total Peak Demand	Firm Reserve Margin w/o Planned Additions			Supply-Side Reserve Margin w/o Planned Additions		
	MW	MW	MW	MW	MW	MW	% of Peak	Shortfall for 20% MW	MW	% of Peak	Shortfall for 7% MW
2012	4,292	617	4,909	3,763	4,008	1,146	30.5%	N/A	901	23.9%	N/A
2013	4,312	421	4,733	3,784	4,023	949	25.1%	N/A	710	18.8%	N/A
2014	4,312	421	4,733	3,823	4,049	910	23.8%	N/A	684	17.9%	N/A
2015	4,312	421	4,733	3,859	4,082	874	22.7%	N/A	651	16.9%	N/A
2016	4,312	398	4,710	3,900	4,125	810	20.8%	N/A	585	15.0%	N/A
2017	4,312	121	4,433	3,940	4,165	493	12.5%	294	268	6.8%	8
2018	4,312	121	4,433	3,980	4,207	453	11.4%	343	226	5.7%	53
2019	4,312	0	4,312	4,022	4,250	290	7.2%	515	62	1.5%	220
2020	4,312	0	4,312	4,064	4,292	248	6.1%	565	20	0.5%	264
2021	4,312	0	4,312	4,103	4,331	209	5.1%	612	(19)	-0.5%	306

47

TAMPA ELECTRIC COMPANY
DOCKET NO. 12_____-EI
EXHIBIT NO. _____ (RJR-1)
DOCUMENT NO. 5
FILED: 09/12/2012

DOCUMENT NO. 5

FRCC RELIABILITY ANALYSIS

FRCC Reliability Analysis

Forecast of Capacity and Demand at Time of Summer Peak with Planned Additions


Year	Total Installed Capacity	Net Firm Capacity Purchases	Total Capacity Available	System Firm Peak Demand	System Total Peak Demand	Firm Reserve Margin With Exercising Load Mgmt & Int.		Reserve Margin w/o Exercising Load Mgmt & Int.	
	MW	MW	MW	MW	MW	MW	% of Peak	MW	% of Peak
2012	47,747	6,486	54,233	42,430	45,613	11,803	27.8%	8,620	18.9%
2013	48,506	6,316	54,822	43,041	46,270	11,781	27.4%	8,552	18.5%
2014	49,730	5,613	55,343	43,618	46,857	11,725	26.9%	8,486	18.1%
2015	51,567	5,614	57,181	44,459	47,758	12,722	28.6%	9,423	19.7%
2016	52,118	4,473	56,591	45,242	48,594	11,349	25.1%	7,997	16.5%
2017	52,553	4,296	56,849	45,802	49,244	11,047	24.1%	7,605	15.4%
2018	52,539	4,382	56,921	46,152	49,643	10,769	23.3%	7,278	14.7%
2019	53,585	4,263	57,848	46,803	50,356	11,045	23.6%	7,492	14.9%
2020	53,667	4,180	57,847	47,581	51,191	10,266	21.6%	6,656	13.0%
2021	55,968	3,973	59,941	48,273	51,933	11,668	24.2%	8,008	15.4%

TAMPA ELECTRIC COMPANY
DOCKET NO. 12 _____-EI
EXHIBIT NO. _____ (RJR-1)
DOCUMENT NO. 6
FILED: 09/12/2012

DOCUMENT NO. 6

FRCC RELIABILITY SENSITIVITY ANALYSIS

FRCC Reliability Sensitivity Analysis



TAMPA ELECTRIC COMPANY
DOCKET NO. 12 _____-EI
EXHIBIT NO. _____ (RJR-1)
DOCUMENT NO. 7
FILED: 09/12/2012

DOCUMENT NO. 7

PRELIMINARY RESOURCE PLANS & ANALYSIS

Preliminary Resource Plans & Analysis

Resource Plans

2019 Polk 2-5

Year	Portfolio Additions
2012	Peaker PPA 117 MW
2013	Peaker PPA 117 MW Peaker PPA 160 MW
2014	Peaker PPA 117 MW Peaker PPA 160 MW
2015	Peaker PPA 117 MW Peaker PPA 160 MW
2016	Peaker PPA 117 MW Peaker PPA 160 MW
2017	(2) 7FA CT 354/298 MW
2018	(1) 7FA CT 177/149 MW
2019	(1) Polk 2-5 NGCC 463/459 MW
2020	
2021	

2017 Polk 2-5

Year	Portfolio Additions
2012	Peaker PPA 117 MW
2013	Peaker PPA 117 MW Peaker PPA 160 MW
2014	Peaker PPA 117 MW Peaker PPA 160 MW
2015	Peaker PPA 117 MW Peaker PPA 160 MW
2016	Peaker PPA 117 MW Peaker PPA 160 MW
2017	(1) Polk 2-5 NGCC 463/459 MW
2018	
2019	(1) 7FA CT 177/149 MW
2020	
2021	

CPWRR (\$M)

	2019 Polk 2-5	2017 Polk 2-5
Capital	\$1,584.2	\$1,566.4
O&M	\$1,113.6	\$1,099.7
Fuel & Purchased Power	\$15,599.8	\$15,566.1
Total	\$18,300.3	\$18,232.2
Delta		\$65.4

TAMPA ELECTRIC COMPANY
DOCKET NO. 12_____-EI
EXHIBIT NO. ____ (RJR-1)
DOCUMENT NO. 8
FILED: 09/12/2012

DOCUMENT NO. 8

IRP RESOURCE PLANS & ANALYSIS

IRP Resource Plans & Analysis

Resource Plans Alternative 1

Polk 2-5	
Year	Portfolio Additions
2012	Peaker PPA 117 MW
2013	Peaker PPA 117 MW Peaker PPA 160 MW
2014	Peaker PPA 117 MW Peaker PPA 160 MW
2015	Peaker PPA 117 MW Peaker PPA 160 MW
2016	Peaker PPA 117 MW Peaker PPA 160 MW
2017	(1) Polk 2-5 NGCC 463/459 MW
2018	
2019	(1) 7FA CT 177/149 MW
2020	
2021	
2022	(1) 7FA CT 177/149 MW
2023	
2024	
2025	(1) 7FA CT 177/149 MW
2026	
2027	-
2028	-
2029	(1) 7FA CT 177/149 MW
2030	-
2031	-
2032	-

Year	Portfolio Additions
2012	Peaker PPA 117 MW
2013	Peaker PPA 117 MW Peaker PPA 160 MW
2014	Peaker PPA 117 MW Peaker PPA 160 MW
2015	Peaker PPA 117 MW Peaker PPA 160 MW
2016	Peaker PPA 117 MW Peaker PPA 160 MW
2017	(2) 7FA CT 354/298 MW
2018	(1) 7FA CT 177/149 MW
2019	(1) 7FA CT 177/149 MW
2020	
2021	
2022	(1) 7FA CT 177/149 MW
2023	
2024	
2025	(1) 7FA CT 177/149 MW
2026	
2027	-
2028	-
2029	(1) 7FA CT 177/149 MW
2030	-
2031	-
2032	-

Alternative 2	
Year	Portfolio Additions
2012	Peaker PPA 117 MW
2013	Peaker PPA 117 MW Peaker PPA 160 MW
2014	Peaker PPA 117 MW Peaker PPA 160 MW
2015	Peaker PPA 117 MW Peaker PPA 160 MW
2016	Peaker PPA 117 MW Peaker PPA 160 MW
2017	(2) 7FA CT 354/298 MW
2018	(1) 7FA CT 177/149 MW
2019	(1) 7FA CT 177/149 MW
2020	
2021	
2022	(1) 7FA CT 177/149 MW
2023	
2024	
2025	(1) Polk 2-5 NGCC 463/459 MW
2026	
2027	-
2028	-
2029	-
2030	-
2031	-
2032	-

CPWRR (\$M)

	Polk 2-5	Alternative 1	Alternative 2
Capital	\$1,566.4	\$1,281.1	\$1,576.9
O&M	\$1,099.7	\$1,172.5	\$1,139.5
Fuel & Purchased Power	<u>\$15,566.1</u>	<u>\$16,062.6</u>	<u>\$15,746.9</u>
Total	<u>\$18,232.2</u>	<u>\$18,516.2</u>	<u>\$18,463.3</u>
Delta		\$284.0	\$231.1

TAMPA ELECTRIC COMPANY
DOCKET NO. 12 _____-EI
EXHIBIT NO. _____ (RJR-1)
DOCUMENT NO. 9
FILED: 09/12/2012

DOCUMENT NO. 9

IRP SENSITIVITY ANALYSIS

IRP Sensitivity Analysis

CPWRR (\$M)

	Polk 2-5	Alternative 1	Alternative 2
Capital Costs Sensitivities:			
Low	\$17,950.5	\$18,416.9	\$18,228.9
Delta		\$466.4	\$278.4
High	\$18,135.3	\$18,592.1	\$18,425.2
Delta		\$456.8	\$289.9

Customer Demand Sensitivities			
Low	\$16,857.1	\$17,141.0	\$17,168.7
Delta		\$283.9	\$311.6
High	\$19,791.6	\$20,356.6	\$19,867.2
Delta		\$565.0	\$75.6

Fuel Costs Sensitivities			
Low	\$15,549.6	\$15,655.8	\$15,715.5
Delta		\$106.2	\$165.8
High	\$21,971.5	\$22,453.5	\$22,273.5
Delta		\$482.1	\$302.1

TAMPA ELECTRIC COMPANY
DOCKET NO. 12 _____-EI
EXHIBIT NO. _____ (RJR-1)
DOCUMENT NO. 10
FILED: 09/12/2012

DOCUMENT NO. 10

RFP SUMMARY OF PROPOSALS

RFP Summary of Proposals

	PK 2-5	Proposal A	Proposal B	Proposal C	Proposal D
Company	TEC				
Type	Intermediate	Intermediate PPA	Sale of peaking facility	Peaking PPA	Peaking PPA
Technology	4x1 CC Conversion	2x1 CC	(2) 7FA CTs	New Build 7FA.05 CT	New Build 7FA.05 CT
Plant Name	Polk Power Station				
Capacity (MW)	459(S)/463(W)				
Start Year	2017	2017	2013	2017	2017
Term (years)	N/A	10	N/A	10	15
HR (Btu/kWh)	7,062				

TAMPA ELECTRIC COMPANY
 DOCKET NO. 12 _____ -EI
 EXHIBIT NO. _____ (RJR-1)
 DOCUMENT NO. 10
 FILED: 09/12/2012

TAMPA ELECTRIC COMPANY
DOCKET NO. 12 _____-EI
EXHIBIT NO. _____ (RJR-1)
DOCUMENT NO. 11
FILED: 09/12/2012

DOCUMENT NO. 11

RFP RESOURCE PLANS & ANALYSIS

RFP Resource Plans & Analysis

Resource Plans

Year	Polk 2-5	Proposal A	Proposal B	Proposal C	Proposal D
2012					
2013			Proposal B		
2014					
2015					
2016					
2017	(1) Polk 2-5 NGCC 463/459 MW	Proposal A		Proposal C (1) 7FA CT 177/149 MW	Proposal D (1) 7FA CT 177/149 MW
2018			(1) Polk 2-5 NGCC 463/459 MW		
2019	(1) 7FA CT 177/149 MW	(1) 7FA CT 177/149 MW		(2) 7FA CT 354/298 MW	(2) 7FA CT 354/298 MW
2020					
2021					
2022	(1) 7FA CT 177/149 MW	(1) 7FA CT 177/149 MW			
2023				(1) Polk 2-5 NGCC 463/459 MW	(1) Polk 2-5 NGCC 463/459 MW
2024					
2025	(1) 7FA CT 177/149 MW	(1) 7FA CT 177/149 MW			
2026			(1) 7FA CT 177/149 MW		
2027		(1) Polk 2-5 NGCC 463/459 MW			
2028					
2029	(1) 7FA CT 177/149 MW	(1) 7FA CT 177/149 MW	(1) 7FA CT 177/149 MW	(1) 7FA CT 177/149 MW	
2030					
2031					
2032					(1) 7FA CT 177/149 MW

CPWRR (\$ million)

	Polk 2-5	Proposal A	Proposal B	Proposal C	Proposal D
Capital	\$1,575.2	\$1,253.3	\$1,400.1	\$1,430.9	\$1,416.6
O&M	\$1,099.7	\$1,064.6	\$1,068.7	\$1,111.2	\$1,109.2
Fuel & Purchased Power	\$15,566.1	\$16,143.0	\$15,904.5	\$15,909.9	\$15,954.9
Total	\$18,241.0	\$18,460.9	\$18,373.4	\$18,452.0	\$18,480.8
Delta		\$219.9	\$132.4	\$210.9	\$239.7

TAMPA ELECTRIC COMPANY
DOCKET NO. 12_____-EI
EXHIBIT NO. ____ (RJR-1)
DOCUMENT NO. 12
FILED: 09/12/2012

DOCUMENT NO.12

RFP QUALITATIVE FACTORS

RFP Qualitative Factors

	PK 2-5	Proposal A	Proposal B	Proposal C	Proposal D
Technology Type	Combined Cycle	Combined Cycle	Peakers	Peaker	Peaker
Transmission Reliability, Voltage Support, Reserves	High High	High High	Medium Low	Medium Low	Medium Low
Water Availability	Municipal Source	Municipal Source	Limited, water use caution area	Unknown	Unknown
Dual Fuel Capability	2 CTs - Yes, 2 CTs - Capable	No	2 CTs - Yes	1 CT - Yes	1 CT - Yes
Project Execution	Low risk	Existing Unit	Existing Unit	Low risk	Low risk
Project Operation	TEC	Owner	ST – contractors LT – TEC employees	Contractor	Contractor
Project Maintenance	CSA	Self-managed, as needed	CSA and CT spares modeled	Self-managed, as needed	Self-managed, as needed
Project Security	Investment Grade	Low – offered lien or step in rights	Investment Grade	Investment Grade	Investment Grade
Environmental Emission Rates	Lower	Lower	Higher	Higher	Higher
Renewable Option	30 MW Solar	None	None	None	None
Simple Cycle Capability	Yes	No	Yes	Yes	Yes
Job Creation and Tax Base	Construction labor	No: existing unit	No: existing unit TEC may increase O&M	Construction, O&M labor	Construction, O&M labor

63

TAMPA ELECTRIC COMPANY
 DOCKET NO. 12 _____
 EXHIBIT NO. _____ (RJR-1)
 DOCUMENT NO. 12
 FILED: 09/12/2012

TAMPA ELECTRIC COMPANY
DOCKET NO. 12 _____-EI
EXHIBIT NO. _____ (RJR-1)
DOCUMENT NO. 13
FILED: 09/12/2012

DOCUMENT NO. 13

JUNE 2012 ASSUMPTIONS UPDATE

June 2012 Assumptions Update

Polk 2-5		Resource Plans Alternative 2		Proposal B	
Year	Assumptions	Year	Assumptions	Year	Assumptions
2012		2012		2012	
2013		2013		2013	Proposal B
2014		2014		2014	
2015		2015		2015	
2016		2016		2016	
2017	(1) Polk 2-5 NGCC 463/459 MW	2017	(2) 7FA CT 354/298 MW	2017	
2018		2018		2018	
2019		2019	(1) 7FA CT 177/149 MW	2019	(1) Polk 2-5 NGCC 463/459 MW
2020	(1) 7FA CT 177/149 MW	2020	(1) 7FA CT 177/149 MW	2020	
2021		2021		2021	
2022		2022		2022	
2023	(1) 7FA CT 177/149 MW	2023	(1) 7FA CT 177/149 MW	2023	
2024		2024		2024	
2025		2025		2025	
2026	(1) 7FA CT 177/149 MW	2026	(1) Polk 2-5 NGCC 463/459 MW	2026	
2027		2027		2027	(1) 7FA CT 177/149 MW
2028		2028		2028	
2029	(1) 7FA CT 177/149 MW	2029		2029	(1) 7FA CT 177/149 MW
2030		2030		2030	
2031		2031		2031	
2032		2032		2032	

CPWRR (\$ million)

	Polk 2-5	Alternative 2	Proposal B
Capital	\$1,557.2	\$1,520.4	\$1,357.5
O&M	\$845.2	\$897.5	\$815.1
Fuel & Purchased Power	\$13,631.7	\$13,882.9	\$13,623.5
Total	\$16,034.1	\$16,300.8	\$16,131.5
Delta		\$266.7	\$97.4

BEFORE THE
FLORIDA PUBLIC SERVICE COMMISSION

DOCKET NO. 12 0234 -EI

IN RE: TAMPA ELECTRIC COMPANY'S
PETITION TO DETERMINE NEED FOR
POLK 2-5 COMBINED CYCLE CONVERSION

DIRECT TESTIMONY AND EXHIBIT

OF

ALAN S. TAYLOR
ON BEHALF OF TAMPA ELECTRIC COMPANY

1 **BEFORE THE FLORIDA PUBLIC SERVICE COMMISSION**

2 **PREPARED DIRECT TESTIMONY**

3 **OF**

4 **ALAN S. TAYLOR**

5 **ON BEHALF OF TAMPA ELECTRIC COMPANY**

6
7 **Q.** Please state your name and business address.

8
9 **A.** My name is Alan S. Taylor, and my business address is
10 821 15th Street, Boulder, Colorado, 80302.

11
12 **Q.** By whom are you employed and what position do you hold?

13
14 **A.** I am President of Sedway Consulting, Inc. ("Sedway
15 Consulting").

16
17 **Q.** Please describe your duties and responsibilities in that
18 position.

19
20 **A.** I perform consulting engagements in which I assist
21 utilities, regulators, and customers with the challenges
22 that they may face in today's dynamic electricity
23 marketplace. My area of specialization is in the
24 provision of independent evaluation services in power
25 supply solicitations and in the associated economic and

1 financial analysis of power supply options.

2
3 **Q.** Please describe your education and professional
4 experience.

5
6 **A.** I earned a Bachelor of Science Degree in energy
7 engineering from the Massachusetts Institute of
8 Technology and a Masters of Business Administration from
9 the Haas School of Business at the University of
10 California, Berkeley, where I specialized in finance and
11 graduated valedictorian.

12
13 I have worked in the utility planning and operations area
14 for 25 years, predominantly as a consultant specializing
15 in integrated resource planning, competitive bidding
16 analysis, utility industry restructuring, market price
17 forecasting, and asset valuation. I have testified
18 before state commissions in proceedings involving
19 resource solicitations, environmental surcharges, and
20 fuel adjustment clauses.

21
22 I began my career at Baltimore Gas & Electric Company
23 (BG&E), where I performed efficiency and environmental
24 compliance testing on the utility system's power plants.
25 I subsequently worked for five years as a senior

1 consultant at Energy Management Associates ("EMA", now
2 New Energy Associates), training and assisting over two
3 dozen utilities in their use of EMA's operational and
4 strategic planning models, PROMOD III and PROSCREEN II.
5 During my graduate studies, I was employed by Pacific Gas
6 & Electric Company ("PG&E"), where I analyzed the
7 utility's proposed demand side management ("DSM")
8 incentive ratemaking mechanism, and by Lawrence Berkeley
9 Laboratory ("LBL"), where I evaluated utility regulatory
10 policies surrounding the development of brownfield
11 generation sites.

12
13 Subsequently, I worked at PHB Hagler Bailly (and its
14 predecessor firms) for ten years, serving as a vice
15 president in the firm's Global Economic Business Services
16 practice and as a senior member of the Wholesale Energy
17 Markets practice of PA Consulting Group, when that firm
18 acquired PHB Hagler Bailly in 2000. In 2001, I founded
19 Sedway Consulting, Inc. and have continued to specialize
20 in economic analyses associated with electricity
21 wholesale markets. Since the founding of Sedway
22 Consulting, I have provided independent evaluation
23 services in over two dozen electric utility conventional
24 and renewable resource solicitations.

1 **Q.** What is the purpose of your direct testimony?
2

3 **A.** Sedway Consulting was retained by Tampa Electric Company
4 (Tampa Electric) to provide independent evaluation
5 services in the utility's 2012 solicitation for
6 competitive power supplies. As the principal consultant
7 on the project, I helped with the development of the
8 Request for Proposals ("RFP"), reviewed Tampa Electric's
9 solicitation process, and performed a parallel and
10 independent economic evaluation of both Tampa Electric's
11 Next Planned Generating Unit ("NPGU") and the proposals
12 that were received by Tampa Electric in response to the
13 utility's solicitation. Ultimately, I concluded that
14 Tampa Electric's Repowering of Polk 2-5 into a combined-
15 cycle ("CC") facility described in Tampa Electric's RFP,
16 with an in-service date of January, 2017, represented the
17 most cost-effective resource for meeting Tampa Electric's
18 resource needs for 2017.

19
20 The purpose of my direct testimony is to describe my role
21 as an independent evaluator and present my findings. I
22 will discuss the process and tools that I used to conduct
23 Sedway Consulting's independent economic evaluation.
24 Based on the results of my independent evaluation, I
25 concluded that Tampa Electric's Polk Power Station

1 Repowering option is more cost-effective than the
2 proposed power purchase agreement ("PPA") and asset sale
3 alternatives that were submitted in Tampa Electric's
4 resource solicitation.

5
6 **Q.** Are you sponsoring any exhibits in this case?

7
8 **A.** Yes. I am sponsoring Exhibit No. AST-1 consisting of two
9 documents, which are attached to my direct testimony:

10 Document No. 1 Resume of Alan S. Taylor

11 Document No. 2 Sedway Consulting's Independent
12 Evaluation Report

13
14 **Q.** Please describe the role you performed as an independent
15 evaluator in Tampa Electric's 2012 RFP project.

16
17 **A.** As the independent evaluator in Tampa Electric's 2012
18 power supply solicitation, I reviewed Tampa Electric's
19 2012 Ten-Year Site Plan and the utility's modeling
20 processes pertaining to its use of Planning and Risk,
21 Tampa Electric's detailed production costing model. I
22 participated in the March 21, 2012 Pre-Issuance
23 Conference Call and attended the April 4, 2012 Bidders
24 Conference in Tampa. Before receiving the proposals, I
25 requested that Tampa Electric run its Planning and Risk

1 model and provide production costing results that I could
2 use to calibrate Sedway Consulting's resource evaluation
3 model. I participated in the opening of proposal
4 packages in Tampa on the Proposal Due Date (May 22,
5 2012), retained an electronic copy of each submitted
6 proposal, and evaluated the economic/pricing information
7 from each proposal. Tampa Electric conferred with me on
8 a number of issues relating to proposal RFP-noncompliance
9 decisions, interpretation of proposal information,
10 clarification requests, and economic evaluation
11 assumptions. As the evaluation progressed, Tampa
12 Electric and I discussed appropriate courses of action
13 and modeling assumptions. Using Sedway Consulting's
14 Response Surface Model ("RSM"), I evaluated Tampa
15 Electric's NPGU and each submitted proposal and assessed
16 their overall costs. I compared Sedway Consulting's
17 ranking and results with those of Tampa Electric to
18 confirm consistency of assumptions and concurrence of
19 conclusions, and I documented the entire process in an
20 independent evaluation report.

21
22 **Q.** You stated that you were involved in the development of
23 the RFP. What did your involvement entail?
24

25 **A.** As the independent evaluator, I reviewed draft versions

1 of the RFP document, participated in several discussions
2 by phone, and was given the opportunity to provide my
3 input and suggestions for improving the RFP.
4

5 **Q.** Do you believe that Tampa Electric's RFP was a reasonable
6 document for soliciting proposals?
7

8 **A.** Yes. As one who has developed over a dozen such utility
9 resource RFPs, I believe that Tampa Electric's RFP struck
10 a good balance between being sufficiently detailed
11 without being burdensome on the respondent. With its
12 RFP, Tampa Electric released a draft PPA that provided
13 bidders with a clear understanding of the general
14 business arrangement that Tampa Electric contemplated.
15

16 **Q.** Do you believe that Tampa Electric's evaluation process
17 was conducted fairly?
18

19 **A.** Yes. The proposals and Tampa Electric's NPGU were
20 evaluated on an equal footing, with consistent
21 assumptions applied to all resource options.
22

23 **Q.** Please describe Sedway Consulting's RSM model and its use
24 in Tampa Electric's resource solicitation.
25

1 **A.** The RSM is a spreadsheet model that I have used in dozens
2 of solicitations around the country. It is a relatively
3 straightforward tool that allows one to independently
4 assess the cost impacts of different generating or
5 purchase resources for a utility's supply portfolio.
6 Most of the evaluation analytics in the RSM involve
7 calculations that are based entirely on my input of
8 proposal costs and characteristics. A small part of the
9 model examines system production cost impacts and needs
10 to be calibrated to simulate a specific utility's system.
11 In the case of the Tampa Electric solicitation, in the
12 weeks prior to the proposal opening, I requested that
13 Tampa Electric execute specific sets of runs with its
14 detailed production cost model. With the results of
15 these runs, I was able to calibrate the RSM to
16 approximate the production cost results Tampa Electric's
17 Planning and Risk model would produce in a subsequent
18 evaluation of any proposals or self-build options that
19 Tampa Electric might receive. Thus, I would not have to
20 rely on Tampa Electric's modeling of a proposal or self-
21 build option; instead, I would be able to insert my own
22 inputs into my own model and independently evaluate the
23 economic impact of any particular resource. In short,
24 the RSM provides an independent assessment to help ensure
25 against the inadvertent introduction of significant

1 mistakes that could cause the evaluation team to reach
2 the wrong conclusions.

3
4 **Q.** How is the RSM an independent analytical tool if it is
5 based on initial Planning and Risk results?

6
7 **A.** As I noted above, most of the calculations performed by
8 the RSM are not based on Planning and Risk results in any
9 way. There are two main categories of costs that are
10 evaluated in a resource solicitation: fixed costs and
11 variable costs. The costs in the first category - the
12 fixed costs of a proposal - are calculated entirely
13 separately in the RSM, with no reliance on the Planning
14 and Risk model for these calculations. The second
15 category - variable costs - has two parts: (1) the
16 calculation of a resource's variable dispatch rates and,
17 (2) the impact that a resource with such variable rates
18 is likely to have on Tampa Electric's total system
19 production costs. As with the fixed costs, a proposal's
20 variable dispatch rates are calculated entirely
21 separately in the RSM, with no basis or reliance on the
22 Planning and Risk model. It is only in the final
23 subcategory - the impact that a resource is likely to
24 have on system production costs - that the RSM has any
25 reliance on calibrated results from Planning and Risk.

1 **Q.** Please elaborate on that area of calculations where the
2 RSM is affected by the Planning and Risk calibration
3 runs.

4
5 **A.** This is the area of system production costs. These costs
6 represent the total fuel, variable operation and
7 maintenance (O&M), emission, and purchased power energy
8 costs that Tampa Electric incurs in serving its
9 customers' load. Given Tampa Electric's load forecast,
10 the existing Tampa Electric supply portfolio (i.e., all
11 current generating facilities and purchase power
12 contracts), and many specific assumptions about future
13 resources and fuel costs, Planning and Risk simulates the
14 dispatch of Tampa Electric's system and forecasts total
15 production costs for each month of each year of the study
16 period. At the outset of the solicitation project, the
17 RSM was populated with monthly system production cost
18 results that were created by the Planning and Risk
19 calibration runs.

20
21 **Q.** What did the RSM do with this production cost
22 information?

23
24 **A.** Once incorporated into the RSM, the production cost
25 information allowed the RSM to answer the question: How

1 much money (in monthly total production costs) is Tampa
2 Electric likely to save if it acquires a proposed
3 resource, relative to a reference resource? The use of a
4 reference resource simply allowed a consistent point of
5 comparison for evaluating all proposals and Tampa
6 Electric's self-build options. As a reference resource,
7 I used a hypothetical gas-fired resource with a very high
8 variable dispatch rate associated with a heat rate of
9 25,000 Btu/kWh. In fact, I could have picked any
10 variable dispatch or heat rate for the reference resource
11 and obtained the same relative ranking of proposals out
12 of the RSM. The cost of the reference resource has no
13 impact on the relative results - it is merely a
14 consistent reference point.

15
16 **Q.** Can you provide a numerical example that shows how the
17 RSM works?

18
19 **A.** Certainly. Assume that a utility has a one-year resource
20 need of 500 MW and must select one of the two following
21 proposals:

	<u>Proposal A</u>	<u>Proposal B</u>
22		
23	Capacity: 500 MW	500 MW
24	Capacity Price: \$9.00/kW-month	\$5.50/kW-month
25	Energy Price: \$40/MWh	\$60/MWh

1 For both proposals, the RSM has already calculated the
2 fixed costs (and represented them in the capacity price)
3 and the variable costs (and represented them in the
4 energy price). Proposal A is more expensive in terms of
5 fixed costs, but Proposal B is more expensive on an
6 energy cost basis. The RSM calculates the final piece of
7 the economic analysis - the different impacts on system
8 production costs - to determine which proposal is less
9 expensive in a total sense for the utility system as a
10 whole.

11
12 Assume that the 25,000 Btu/kWh reference unit has a
13 variable cost of \$150/MWh and that the RSM has been
14 calibrated and populated with the following production
15 cost information:

16
17 For a 500 MW proxy resource, the utility's one-year total
18 system production costs are:

19
20 \$900 million for a \$150/MWh energy price reference
21 resource

22 \$894 million for a \$60/MWh energy price resource
23 (Proposal B)

24 \$876 million for a \$40/MWh energy price resource
25 (Proposal A)

1 Thus, the energy savings (relative to the selection of a
 2 \$150/MWh reference resource) are \$24 million for Proposal
 3 A with its \$40/MWh energy price and \$6 million for
 4 Proposal B with its \$60/MWh energy price. In its
 5 proposal ranking process, the RSM converts all production
 6 cost savings into a \$/kW-month equivalent value so that
 7 the savings can be deducted from the capacity price to
 8 yield a final net cost (in \$/kW-month) for each proposal.
 9 Converting the energy savings in this numerical example
 10 into \$/kW-month equivalent values yields the following:

11

12 $\$24 \text{ million} / (500 \text{ MW} * 12 \text{ months}) = \$4.00/\text{kW-month}$
 13 $\$6 \text{ million} / (500 \text{ MW} * 12 \text{ months}) = \$1.00/\text{kW-month}$

14

15 The RSM calculates the net cost of both proposals by
 16 subtracting the energy cost savings from the fixed costs:

17

	<u>Proposal A</u>	<u>Proposal B</u>
18 Capacity Price:	\$9.00/kW-month	\$5.50/kW-month
19 Energy Cost Savings:	\$4.00/kW-month	\$1.00/kW-month
20 Net Cost:	\$5.00/kW-month	\$4.50/kW-month

21

22

23 Proposal B is less expensive. This can be confirmed
 24 through a total cost analysis as well:

25

1 Proposal A will require total capacity payments of \$54
2 million (= 500 MW x \$9.00/kW-month x 12 months), and
3 Proposal B will require \$33 million (= 500 MW x \$5.50/kW-
4 month x 12 months). Thus, Proposal A has fixed costs
5 that are \$21 million more than Proposal B.

6
7 Proposal A will provide \$18 million more in energy cost
8 savings (= \$24 million - \$6 million); however, this is
9 not enough to warrant paying \$21 million more in fixed
10 costs. Therefore, Proposal B is the less expensive
11 alternative.

12
13 Note that the RSM is described in more detail in the
14 independent evaluation report that is attached to my
15 direct testimony as Document No. 2 of my exhibit.

16
17 **Q.** With that understanding of the RSM process, what did you
18 do to calibrate the RSM to Planning and Risk?

19
20 **A.** I reviewed the production cost information that Tampa
21 Electric provided at the start of the project and
22 confirmed that the production costs were, for the most
23 part, exhibiting smooth, correct trends (i.e., they were
24 increasing where they should be increasing and declining
25 where they should be declining). Having verified that

1 the RSM production cost values were "smooth," I was
2 confident that inputting variable cost parameters into
3 the models for similar proposals would yield similar
4 production cost results. Although the RSM is not a
5 detailed model and could not simulate Tampa Electric's
6 production costs with Planning and Risk's accuracy, in
7 the end (after accounting for future portfolio
8 composition and future unit revenue requirement
9 methodology differences), the independent RSM evaluation
10 results tracked Planning and Risk's results reasonably
11 well.

12
13 **Q.** Once the RSM was calibrated, what was the next step?
14

15 **A.** I flew to Tampa for the Proposal Due Date, opened all
16 proposal packages, and retained an electronic copy of
17 each proposal. I read each proposal and participated in
18 discussions with Tampa Electric about interpreting the
19 proposals, identifying areas requiring clarification, and
20 assessing each proposal's compliance with the RFP's
21 Minimum Requirements. Tampa Electric communicated with
22 proposers to seek clarification and corrections to
23 uncertain areas of the proposals, copying me on all email
24 correspondence and encouraging bidders to do the same.
25

1 I incorporated pricing and operational information from
2 each proposal into the RSM. Such information included
3 contract commencement and expiration dates, summer and
4 winter capacity, capacity pricing, heat rates, fuel
5 supply assumptions, variable O&M charges, start-up costs,
6 expected forced outage hours, and expected planned outage
7 hours. Most of this information was directly inputted
8 into the RSM. After the initial part of the evaluation,
9 Tampa Electric provided Sedway Consulting with its own
10 modeling results so that Sedway Consulting could cross-
11 check all key modeling assumptions and outputs and ensure
12 consistency with the information in the RSM.

13
14 On June 21, 2012, Tampa Electric and Sedway Consulting
15 discussed the evaluation results of the original
16 proposals and agreed that several offers should be
17 shortlisted. The bidders of these offers were engaged in
18 conference calls (which Sedway Consulting monitored) to
19 discuss their bids and respond to questions. These
20 bidders were provided an opportunity to provide best-and-
21 final offers on July 13, 2012.

22
23 **Q.** What were the results of Sedway Consulting's RSM
24 analysis?
25

1 **A.** Using the RSM, Sedway Consulting was able to compare the
2 economics of Tampa Electric's NPGU and each of the
3 proposed resource options (both the original bids and the
4 best-and-final offers). That comparison entailed a
5 calculation of the net present value of each option from
6 2013 through 2046 and accounted for 1) resources that
7 would need to "fill in" behind options that expired
8 before 2046 and 2) differences in the capacity of each
9 option proposed. The evaluation was performed for a base
10 case set of fuel price and load forecast assumptions, as
11 well as a low fuel price/low load scenario and a high
12 fuel price/high load scenario. Tampa Electric's NPGU was
13 found to be \$69 million (cumulative present value of
14 revenue requirements - "CPVRR") less expensive than the
15 next best resource's best-and-final offer under base case
16 assumptions. The results, ranking of resources and
17 additional scenarios are described in detail in Sedway
18 Consulting's independent evaluation report that is
19 attached as Document No. 2 of my exhibit.

20
21 **Q.** What do you conclude about Tampa Electric's solicitation?
22

23 **A.** I conclude that Tampa Electric's NPGU is the most cost-
24 effective resource for meeting Tampa Electric's 2017
25 capacity needs and concur with Tampa Electric's decision

1 to move forward with that project. The solicitation
2 process yielded the best results for Tampa Electric's
3 customers while treating proposers fairly. The RFP was
4 sufficiently detailed to provide necessary information to
5 proposers. The economic evaluation methodology and
6 assumptions were appropriate and unbiased, and the
7 independent evaluation procedures provided a cross-check
8 of Tampa Electric's proposal representation in Planning
9 and Risk and confirmed Tampa Electric's conclusions.
10 Finally, I conclude that Tampa Electric's NPGU is \$69
11 million CPVRR less expensive than the next best offered
12 resource under base case assumptions.

13
14 **Q.** Does this conclude your direct testimony?

15
16 **A.** Yes, it does.
17
18
19
20
21
22
23
24
25

EXHIBIT

OF

ALAN S. TAYLOR

ON BEHALF OF TAMPA ELECTRIC COMPANY

Table of Contents

DOCUMENT NO.	TITLE	PAGE
1	Resume Of Alan S. Taylor	21
2	Sedway Consulting's Independent Evaluation Report	31

DOCUMENT NO. 1

RESUME OF ALAN S. TAYLOR

RESUME OF ALAN S. TAYLOR

AREAS OF QUALIFICATION

Independent evaluation services for competitive bidding resource selection, integrated resource planning, market analysis, risk assessment, and strategic planning

EMPLOYMENT HISTORY

- ◆ President, Sedway Consulting, Inc., Boulder, CO, 2001-present
- ◆ Senior Member of PA Consulting, Inc., Boulder, CO, 2001
- ◆ Vice President, Global Energy Business Sector, PHB Hagler Bailly, Inc., Boulder, CO, 2000
- ◆ From Senior Associate to Principal, Utility Services Group, Hagler Bailly Consulting, Inc., Boulder, CO, 1991-1999
- ◆ Senior Consultant, Energy Management Associates, Atlanta, GA, 1983-1988
- ◆ Internships at: Pacific Gas & Electric Company, San Francisco, CA (1990)
Lawrence Berkeley National Laboratory, Berkeley, CA (1989-1991)
MIT Resource Extraction Laboratory, Cambridge, MA (1982)
Baltimore Gas and Electric Company, Baltimore, MD (1980)

EDUCATION

- ◆ Walter A. Haas School of Business, University of California at Berkeley, MBA, Valedictorian, Corporate Finance, 1991
- ◆ Massachusetts Institute of Technology, BS, Energy Engineering, 1983

PROFESSIONAL EXPERIENCE

- ◆ Developed and/or reviewed dozens of requests for proposals for utility resource solicitations.
- ◆ Conducted numerous competitive bidding project evaluations for conventional generating resources, renewable facilities, and off-system power purchases; analyzed thousands of power supply proposals.
- ◆ Assisted in or monitored contract negotiations with hundreds of shortlisted bidders in utility resource solicitations.
- ◆ Testified on utility competitive bidding solicitation results, affiliate transactions, cost recovery procedures, rate case calculations, and incentive ratemaking proposals.
- ◆ Managed the development of market price forecasts of North American and European electricity markets under deregulation.
- ◆ Performed financial modeling of electric utility bankruptcy workout plans.
- ◆ Trained and assisted many of the nation's largest electric and gas utilities in their use of operational and strategic planning computer models.

SELECTED PROJECTS

2006- California Solicitations for Conventional and Renewable Resources

2012 Client: Southern California Edison

Currently serving or has served as the Independent Evaluator (IE) in 18 solicitations for power or gas supplies in southern California – one for over 2,500 MW of new conventional resources, four for renewable energy purchases to help Southern California Edison meet its state Renewables Portfolio Standard (RPS) requirements, five for near-term capacity resources, four for reverse energy auctions of the dispatch rights to facilities under new power purchase agreements, and four for gas financial hedging products. Mr. Taylor managed or is managing a Sedway Consulting team to perform a parallel evaluation of all proposals, monitor communications and negotiations with power suppliers, and support the review of the final selected proposals by the Procurement Review Group – a collection of non-market-participant stakeholders and regulators who are/were provided confidential access to the evaluation results at intermediate stages. He has filed IE reports and sponsored testimony before the California Public Utilities Commission concerning the results of most of these solicitations.

2011 Minnesota Solicitation for Wind Resources

Client: Minnesota Power

Provided independent evaluation services in a solicitation for 100 MW of wind generation in Minnesota. Proposals competed with a utility proposal to develop its own wind farm. Mr. Taylor assisted with the development of the RFP and performed a parallel economic evaluation of the utility's facility and all competing proposals.

2005- California Solicitations for Conventional and Renewable Resources

2010 Client: Pacific Gas & Electric

Served as the Independent Evaluator in four solicitations for new power supplies in northern California – one for 2,200 MW of new conventional resources, another for up to 1,200 MW of new generating resources from any source, and two others for between 1,400 and 2,800 GWh/year of renewable energy purchases. Mr. Taylor managed a Sedway Consulting team to perform a parallel evaluation of all proposals, monitor communications and negotiations with power suppliers, and support the review of the final selected proposals by the Procurement Review Group – a collection of non-market-participant stakeholders and regulators who were provided confidential access to the evaluation results at intermediate stages. He has filed IE reports and sponsored testimony before the California Public Utilities Commission concerning the results of most of these solicitations.

2007- **Florida Solicitation for New Resources**

2008 Client: Florida Power & Light

Provided independent evaluation services in Florida Power & Light's solicitation for 1,250 MW of new power supplies for 2011. Mr. Taylor performed a parallel economic evaluation to that which was undertaken by the utility. His work efforts allowed all proposal parameters to be cross-checked and corrected where necessary. He sponsored testimony before the Florida Public Service Commission concerning the results of the solicitation evaluation.

2007- **Avoided Cost Analysis for Interruptible Loads**

2008 Client: Public Service Company of Colorado

Provided an independent assessment of Public Service Company of Colorado's peaking resource avoided costs for use in the utility's development of customer credits for its interruptible service tariff.

2007- **Florida Solicitations for New Resources**

2008 Client: Tampa Electric Company

Provided independent evaluation services in two separate Tampa Electric Company solicitations for 600 MW of new power supplies for 2013, as a market test for the utility's proposals to develop initially an integrated gasification combined cycle (IGCC) facility and later a gas-fired combined cycle facility.

2004- **Regulatory Support of Commission Staff**

2005 Client: Utah Division of Public Utilities

Assisted staff for the Utah Division of Public Utilities in the division's efforts to analyze PacifiCorp's 2005 rate case. Mr. Taylor reviewed production cost modeling results and forecasts of system-wide fuel and purchase power costs.

2004- **Minnesota Solicitation for New Resources**

2005 Client: Minnesota Power

Provided independent evaluation services in a solicitation for 200 MW of firm power supplies. Mr. Taylor reviewed all proposals and performed a parallel economic evaluation among proposed turnkey facilities and power purchases.

2004 Canadian Solicitations for Conventional and Renewable Resources

Client: Ontario Energy Ministry

Participated in a broader consulting team and provided assistance in the development of RFPs for 2,500 MW of conventional resources and 300 MW of renewable resources. New long-term sources of power were sought to replace regional coal-fired generation.

2003- Florida Solicitation for New Resources

2004 Client: Florida Power & Light

Provided independent evaluation services in Florida Power & Light's solicitation for 1,100 MW of new power supplies for 2007. Mr. Taylor performed a parallel economic evaluation of all proposals and reviewed, cross-checked, and corrected (where necessary) the utility's analyses. He sponsored testimony before the Florida Public Service Commission concerning the results of the solicitation evaluation.

2002- Minnesota Solicitation for New Resources

2003 Client: Northern States Power

Assisted in the evaluation of a large number of multi-option proposals for new power supplies in the 2005-2009 time frame. Mr. Taylor was the independent evaluator in two separate solicitations. He managed a team of individuals in the evaluation of responses for both Requests for Proposals (RFPs). In the first solicitation, contingent proposals were received that could serve as replacement contracts for 1,100 MW of nuclear capacity if NSP were forced to decommission its Prairie Island power plant in 2007. In the second solicitation, NSP sought approximately 1,000 MW of new supplies to supplement its existing supply portfolio. The evaluation included the review of over a dozen proposed wind projects.

2002 Florida Revisions to Bidding Rule

Client: Consortium of utilities

Provided the Florida Public Service Commission with recommendations concerning appropriate revisions to the state's bidding rule. Mr. Taylor participated in public workshops to provide the benefits of his extensive experience in performing competitive bidding solicitations and to convey what changes should or should not be made to Florida's existing bid rule to ensure the selection of the best resources for the state's electricity customers.

2002 Arizona Testimony Concerning Competitive Bidding Solicitations

Client: Harquahala Generating Company, LLC

Filed testimony before the Arizona Corporation Commission in the Generic Proceedings Concerning Electric Restructuring Issues and Associated Proceedings. Mr. Taylor's testimony provided the Commission with information about competitive bidding processes that he had seen

work in other states. Also, his testimony addressed various concerns that were raised by Arizona Public Service as to the feasibility of implementing competitive bidding in Arizona.

2002 Florida Solicitation for New Resources

Client: Florida Power & Light

Provided independent evaluation services in Florida Power & Light's solicitation for 1,750 MW of new power supplies in the 2005-2006 time frame. Mr. Taylor performed a parallel economic evaluation to that which was undertaken by the utility. His work efforts allowed all proposal parameters to be cross-checked and corrected where necessary. Also, he provided suggestions on resource optimization modeling approaches that ensured the most comprehensive examination of thousands of potential combinations of proposals.

2001 Wisconsin Testimony Concerning Competitive Bidding Solicitations

Client: MidWest Independent Power Suppliers

Provided testimony in a proceeding before the Wisconsin Public Service Commission on behalf of a consortium of independent power producers. Mr. Taylor testified on the benefits and timing of a competitive bidding solicitation that Wisconsin Electric Power Company (WEPCO) should be ordered to conduct prior to the utility's development of \$2.8 billion in self-build generation facilities (embodied in a WEPCO proposal called Power the Future – 2). Without the benefits of a competitive solicitation, there would be no defensible means of ensuring that the utility's customers were being offered the best, most cost-effective resources.

2001 Negotiation of Full-Requirements Purchase Contract

Client: Georgia cooperative utility

Assisted in negotiation of a \$2 billion power purchase contract. Mr. Taylor worked with a team of legal experts and other consultants to assist the client in negotiating a 15-year full-requirements contract with a large, national power supplier. Detailed modeling simulations were performed to compare the complex transaction to the utility's own self-build alternatives. Mr. Taylor helped investigate and negotiate detailed provisions in the power supply contract concerning ancillary services and other operational parameters.

2001 Evaluation of Resource Proposals

Client: North Carolina municipal utility

Reviewed responses to a utility resource solicitation and assisted the client in developing a short list of the best bidders. Mr. Taylor reviewed the results of the client's economic analysis of the proposals and provided insights on various nonprice factors related to each of the top-ranked proposals. Mr. Taylor helped the client in structuring and strategizing for the negotiation process.

2000- Solicitation for New Resources

2001 Client: Public Service of Colorado

Assisted in the evaluation of a large number of multi-option proposals for new power supplies in the 2002-2005 time frame. Mr. Taylor managed a team of a dozen individuals who performed economic and nonprice evaluations of conventional and renewable proposals. Mr. Taylor developed recommendations for a short list of the best resources and managed a supplemental evaluation of second-tier bidders when the client's capacity needs subsequently increased. Ultimately, over \$2 billion of contracts were negotiated for over 1,700 MW of new power supplies under terms of up to 10 years. Mr. Taylor testified before the Colorado Public Utilities Commission on the processes and results of both the primary and supplemental evaluations.

1999- Solicitation for New Resources

2000 Client: MidAmerican Energy

Reviewed MidAmerican's solicitation for new power supplies for the 2000-2005 resource planning period. Mr. Taylor managed a team of individuals who performed an independent parallel evaluation of MidAmerican's analysis of responses to the utility's request for proposals (RFP). Mr. Taylor reviewed MidAmerican's evaluation and negotiation process and testified to the fairness and appropriateness of MidAmerican's actions. He filed testimony before the utility regulatory commissions in Iowa, Illinois, and South Dakota.

2000 Electricity Market Assessments

Client: various American and European clients

Helped develop electricity market prices for regional electricity markets in North America (California, New England, Arizona/New Mexico, Louisiana) and Europe (Austria, Belgium, France, Germany, and the Netherlands). Mr. Taylor worked with project teams in the U.S. and Europe to develop simulation models and databases to forecast energy and capacity prices in the deregulating power markets.

1999 Evaluation of New Resources

Client: Florida Power Corporation

Helped prepare the FPC's RFP for long-term supply-side resources and assisted in the independent evaluation of responses. Mr. Taylor oversaw the review of FPC's computer simulations (in PROVIEW and PROSYM) of the proposals that were received. The project team also evaluated the proposals by using a response surface model to approximate the results that might be produced in the more detailed simulations. Mr. Taylor testified before the Florida Public Service Commission concerning his assessment of FPC's solicitation and the results of the analysis.

1998 **Evaluation of New Resources**

Client: Public Service of Colorado

Assisted the evaluation of proposals for PSCo's near-term 1999 resource additions and managed the complete third party evaluation of proposals for resources in the 2000-2007 time frame. Such resources included third-party facilities and power purchases, as well as company-sponsored interruptible tariffs. Mr. Taylor assisted with the development of the request for proposals and oversaw the evaluation of all responses. He and his team monitored subsequent negotiations with shortlisted bidders. Mr. Taylor testified before the Colorado Public Utilities Commission on the fairness of the solicitation and the results of the evaluation.

1997- **Evaluation/Negotiation of Transmission Interconnection Solicitation**

1999 Client: New Century Energies

Managed a solicitation for participation in a major transmission project interconnecting Southwestern Public Service (a Texas member of the Southwest Power Pool) and Public Service of Colorado (a member of the Western Systems Coordinating Council). As the first major inter-reliability-council transmission project in the era of open access, FERC required that SPS and PSCo solicit third-party interest in participation. This project required the development of an RFP and evaluation of responses for both equity participation and long-term transmission service for over 21 alternative high-voltage AC/DC/AC transmission projects. The evaluation focused on the costs and intangible risks of different transmission alternatives relative to the benefits and savings associated with increased economy interchange, avoided future generating capacity, and reductions in single-system spinning reserve and reliability requirements.

1996- **Evaluation/Negotiation of All-Source Solicitation**

1997 Client: Southwestern Public Service

Managed the evaluation of a broad array of responses to an all-source solicitation that was issued by Southwestern Public Service (SPS). Resources in the areas of conventional supply-side generation, renewable resources, off-system transactions, DSM, and interruptible loads were proposed. The evaluation entailed scoring the proposals for a variety of price and nonprice attributes. Mr. Taylor assisted Southwestern in its negotiations with the bidders and performed the detailed evaluation of the best and final offers.

1996- **Risk Assessment for 1,000-MW Solicitation**

1997 Client: Seminole Electric Cooperative

Managed the review and assessment of risks associated with responses to a 1,000-MW solicitation that was issued by Seminole Electric Cooperative. The evaluation entailed reviewing selected proposals' financial feasibility, performance guarantees, fuel supply plans, O&M plans, project siting, dispatching flexibility, and bidder qualifications.

1997 Analysis/Testimony Concerning Louisville Gas & Electric's Fuel Adjustment Clause
Client: Kentucky Industrial Utility Customers

Performed a detailed examination of Louisville Gas & Electric's (LG&E) fuel adjustment clause and identified misallocated costs in the areas of transmission line losses and purchased power fuel costs. Mr. Taylor also critiqued LG&E's rate adjustment methodology and recommended closer scrutiny of costs associated with jurisdictional and non-jurisdictional sales. Mr. Taylor testified before the Kentucky Public Service Commission and presented the findings of his analysis.

1995 Development of All-Source Solicitation RFPs
Client: Southwestern Public Service

Managed the development of five RFPs that solicited resources in the areas of conventional supply-side generation, renewable resources, off-system transactions, DSM, and interruptible loads. The RFPs were issued by SPS as part of an all-source solicitation to identify resources that may be competitive with two generation facilities that SPS intended to develop.

1994 Development of Competitive Bidding RFP
Client: Empire District Electric Company

Based on knowledge gained from the review of dozens of other utility RFPs, developed a combined-cycle resource RFP for Empire District Electric Company. The project team was responsible for the RFP's entire development, including the development of scoring provisions for price and nonprice project attributes.

1993 Selection of Developer for 25 MW Wind Facility
Client: Northern States Power

Evaluated ten bids that were received by NSP in a solicitation for the development of a 25 MW wind facility in Minnesota. The proposals were scored and ranked through a point-based evaluation system that was developed prior to the solicitation. The scoring involved an assessment of operational and financial feasibility, power purchase pricing terms, construction schedules, and community acceptance issues.

1993 Competitive Bidding Design
Client: Northern States Power

Assisted NSP in the utility's effort to design a generic competitive bidding RFP that could be issued for a variety of generation resources. Two dozen RFPs from other utilities were reviewed to determine the appropriate weights and mechanisms that should be used to score various project attributes.

1993 **Evaluation of 500 MW Supply-Side Solicitation**

Client: San Diego Gas & Electric

Assisted in the evaluation of 15 bids that were received from a 500 MW solicitation for power by SDG&E. The utility wanted to determine whether or not there were less expensive alternatives to the implementation of its plan to repower one of its own units. The 15 projects represented over 4,000 MW. The bids were evaluated using extensive production costing modeling, in which over 1,000 model runs were performed to evaluate each bid under a variety of scenarios.

DOCUMENT NO. 2

SEDWAY CONSULTING'S
INDEPENDENT EVALUATION REPORT

Docket No. _____
Sedway Consulting's
Independent Evaluation Report
Document 2, Page 1 of 15

Sedway Consulting, Inc.

INDEPENDENT EVALUATION REPORT
FOR TAMPA ELECTRIC COMPANY'S
2012 POWER SUPPLY SOLICITATION

Submitted by:

*Alan S. Taylor
Sedway Consulting, Inc.
Boulder, Colorado*

September 10, 2012

Sedway Consulting, Inc.

Introduction and Background

On March 23, 2012, Tampa Electric Company (Tampa Electric) issued a Request for Proposals (RFP) for capacity and energy to satisfy the utility’s projected incremental resource need for 2017. In April, 2012, Tampa Electric released its 2012 Ten-Year Site Plan with three load forecasts (a low-load scenario, a base case, and a high-load scenario) that translated into the cumulative 2017-2019 capacity needs depicted in Table A-1.

Table A-1 Tampa Electric Cumulative Capacity Needs (All Values in MWs)			
Year	Low Load Forecast	Base Case Forecast	High Load Forecast
2017	139	295	463
2018	159	343	540
2019	304	515	739

Tampa Electric’s RFP indicated that power supply proposals would be competing against a utility self-build option – namely, a conversion of four existing simple-cycle combustion turbines (CTs) at Tampa Electric’s Polk power plant¹ into a 4-on-1 combined-cycle (CC) facility. The addition of the CC steam cycle is projected to provide Tampa Electric with incremental summer capacity of 459 MW by January, 2017; this conversion project was referred to as the Next Planned Generating Unit (NPGU).

Sedway Consulting, Inc. (Sedway Consulting) was retained to provide independent evaluation services to Tampa Electric and provide a parallel economic evaluation of responses to the RFP. This independent evaluation report documents Sedway Consulting’s evaluation process and presents the results of Sedway Consulting’s economic analysis. It describes Sedway Consulting’s proprietary Response Surface Model (RSM) which was used to conduct the parallel economic evaluation, fundamental assumptions that were applied, and additional economic factors that affected the final cost of each resource.

Receipt of Proposals

On May 22, 2012, Tampa Electric received five proposals from four power suppliers. One proposal – from [REDACTED] – was a follow-up offer regarding a biomass retrofit project of some of TECO’s existing Bayside units. Because the proposal involved a developer’s use of a Tampa Electric-owned power plant, it did not comply with the RFP. Indeed, the bidder confirmed that the proposal was never meant to be considered as part of the 2012 RFP and was merely a continuation of negotiations that had been underway with Tampa Electric for several years. Thus, the [REDACTED] proposal was set aside, and four

¹ Specifically Polk Units 2-5.

Docket No. _____
 Sedway Consulting's
 Independent Evaluation Report
 Document 2, Page 3 of 15

remaining proposals that involved three power projects from three bidders were ultimately compared with Tampa Electric's NPGU. All of these projects were natural gas-fired technologies. The four proposals/three projects entailed the following:

1. [REDACTED] a [REDACTED] power purchase agreement (PPA) for capacity and energy deliveries commencing January 1, 2017 [REDACTED] Hereafter, this proposal will be referred to as Proposal A in the unredacted portions of this report.
2. [REDACTED] a sale [REDACTED] proposed that the asset sale and transfer conclude on June 1, 2013. Hereafter, this proposal will be referred to as Proposal B in the unredacted portions of this report.
3. [REDACTED] PPA for capacity and energy deliveries commencing January 1, 2017 [REDACTED] The bidder provided alternative proposals for two PPAs of different durations – one of approximately [REDACTED] with an expiration date of [REDACTED] and a second of approximately [REDACTED] with an expiration date of [REDACTED].² Hereafter, these two proposals will be referred to as Proposal C (for the shorter PPA) and Proposal D (for the longer PPA) in the unredacted portions of this report.


Table A-2 depicts key information for Tampa Electric's NPGU and each of the proposals. Specifically, the table includes each resource's summer capacity, type (combined cycle or combustion turbine), the year that the PPA or asset transaction is expected to commence deliveries, the PPA term (or economic life in the case of asset transaction), levelized capacity price or capital-related revenue requirement (over the PPA term or asset life), full load heat rate, and variable operation and maintenance (O&M) charge.

Table A-2 Summary of Tampa Electric's NPGU and Initial Proposals							
Resource	Sum. Cap. (MW)	Type	Start Year	Term/Econ. Life (yrs)	Cap. Price (\$/kW-mo)	Full Load Heat Rate (Btu/kWh)	Var. O&M (\$/MWh)
Proposal A	[REDACTED]	[REDACTED]	2017	[REDACTED]	[REDACTED]	[REDACTED]	[REDACTED]
Proposal B	[REDACTED]	[REDACTED]	2013	[REDACTED]	[REDACTED]	[REDACTED]	[REDACTED]
Proposal C	[REDACTED]	[REDACTED]	2017	[REDACTED]	[REDACTED]	[REDACTED]	[REDACTED]
Proposal D	[REDACTED]	[REDACTED]	2017	[REDACTED]	[REDACTED]	[REDACTED]	[REDACTED]
Polk NPGU	459	CC	2017	30	16.94	7,062	2.98

² For ease of reference, these PPA alternatives will simply be referred to as [REDACTED]-year and [REDACTED]-year proposals in the remainder of this report.

Docket No. _____
Sedway Consulting's
Independent Evaluation Report
Document 2, Page 4 of 15

It is important to note that the statistics for Tampa Electric's NPGU in Table A-2 are based on the conversion project's *incremental* capacity. On a total capacity basis, the project will entail adding 459 MW of summer capacity to four existing CTs that have a combined summer capacity of 604 MW. Thus, the complete combined cycle plant will have a summer capacity of 1,063 MW. The levelized capacity price includes all capital costs (for generation and transmission investments) and fixed O&M costs and is converted into an equivalent levelized capacity price by dividing these costs by the incremental 459 MW. The Proposal B levelized capacity price also includes an estimate for fixed O&M costs. Unlike the NPGU, none of the bid information in Table A-2 includes transmission costs or firm gas transportation costs – all of which were calculated as described later in this report and subsequently added to the bid costs. In some cases (specifically, Proposal B), such additional costs amounted to more than \$ [REDACTED]/kW-month in levelized terms.



Although Sedway Consulting's (and Tampa Electric's) base case evaluation results of the initial proposals yielded total costs that were higher than the costs of Tampa Electric's NPGU, the results were deemed to be close enough³ to warrant shortlisting all four proposals on June 22, 2012. Conference calls were scheduled with each of the bidders on July 2-3, 2012 to allow for further clarification of each bid. Sedway Consulting monitored all of those conference calls. Each bidder was offered the opportunity to provide a best-and-final offer by July 13, 2012.



³ Also, sufficient uncertainty existed in key evaluation areas to warrant further review of each bid.



All

subsequent information and results in this report pertain to the best-and-final offers.

Evaluation Process

Through its review of the proposals that Sedway Consulting retrieved at the bid opening (and the subsequent submission of best-and-final offers), Sedway Consulting extracted the following economic information for each proposal:

- Capacity (winter and summer; base and duct-fired, where applicable)
- Commencement and expiration dates of contract
- Capacity pricing (or asset sales price, if applicable)
- Fixed operation and maintenance (O&M) charges (where applicable)
- Firm fuel transportation assumptions
- Fuel pricing or indexing
- Heat rate (base and duct-fired, where applicable)
- Variable O&M pricing
- Start-up costs and fuel requirements
- Expected forced outage and planned outage hours
- Tampa Electric and third-party transmission costs.

The same or analogous information was received for Tampa Electric's NPGU.

The remainder of this report section addresses the following topics:

- a description of the RSM,
- the use of a "filler" resource in evaluating proposed transactions that expired before the end of the study period, and
- the process of developing final cost estimates for all resources.

RSM Evaluation Process

The economic information for all outside proposals and Tampa Electric's NPGU was input into Sedway Consulting's RSM – a power supply evaluation tool that was calibrated to approximate the impact of each proposal on Tampa Electric's system production costs. The RSM calculated each option's annual fixed costs and variable dispatch costs, estimated the production cost impacts of each option, and accounted for capacity replacement costs for all proposed contracts that expired before the end of the study period. In addition, Sedway Consulting's analysis accounted for the different sizes of resources by calculating additional costs or benefits associated with meeting Tampa

Electric's resource needs from 2017-2019. For those resources and scenarios where a resource would not fully meet Tampa Electric's resource needs through 2019, a per-MW cost of a new generic CT was added to the resource's costs to cover the deficiency. In instances where a resource provided more than the required capacity, a credit was calculated – thereby recognizing the value of surplus capacity in deferring the need for Tampa Electric to develop or procure future generating capacity in 2019 and beyond.

An option's net cost was a combination of fixed and variable cost factors. On the fixed side, the RSM calculated annual fixed costs associated with capacity payments (or generation and transmission revenue requirements), fixed O&M costs, incremental capital charges, and firm gas transportation costs. These annual total fixed costs were discounted to mid-2012 dollars.

On the variable cost side, the RSM first developed a variable dispatch charge (in \$/MWh) for each option for each month. This charge was calculated by multiplying the option's heat rate by the specified monthly fuel index price and adding the variable O&M charge.

The RSM then estimated Tampa Electric's system production costs for each month and each option by interpolating between production costs estimates that were extracted from a set of Planning and Risk runs. These runs were performed at the start of the project and were used to calibrate the RSM by varying the monthly variable dispatch charge for a proxy proposal and recording the resulting Tampa Electric system production cost.

For the same capacity as the proposal under consideration, the RSM also estimated Tampa Electric's system production costs for a natural-gas-fired reference unit that had a high variable dispatch charge based on a heat rate of 25,000 Btu/kWh. Thus, for each option, the RSM yielded estimates of the annual production cost savings that Tampa Electric would be projected to experience if the utility selected the resource option, relative to acquiring the same sized transaction but at the high reference resource dispatch rate. The lower an option's variable dispatch charge, the greater the production cost savings.

Filler Resource

As was mentioned earlier, the RSM accounted for the costs of replacing capacity for all proposed contracts that expired before the end of the study period (2046). This was done by "filling in" for the lost capacity at the end of each proposal's term of service. This allowed for a side-by-side comparison of the value of proposals that had varying contract durations. Also, the RSM had been calibrated with Planning and Risk runs that assumed that a proxy proposed resource would provide its capacity for the entire duration of the study period. Thus, it was necessary to continue a proposal's capacity throughout the entire period so as to maintain consistent and sufficient reserve margins. In effect, by supplementing each short-term proposal with a filler resource for the later years, the RSM was simulating what Tampa Electric would have to do when a proposed transaction expired – acquire or develop an amount of replacement capacity equal to that expired resource.

As the basis for cost assumptions for the filler resource, Sedway Consulting (and Tampa Electric) used the Polk NPGU CC resource. The same \$/kW fixed cost assumptions (e.g., capital-related revenue requirements, fixed O&M costs) and variable cost assumptions (e.g., heat rates, variable O&M costs, fuel supply issues) were used, although all capital-related costs were escalated by 3%/year and variable O&M costs were escalated by 2.4%/year to account for later in-service dates than the NPGU's 2017 expected commercial operation date. The only difference involved a methodological variation, whereby the RSM scaled the replacement capacity to exactly equal the size of the expiring proposal resource. Thus, all PPA proposals enjoyed the benefit of being replaced at the end of their terms with a resource that exhibited the operating efficiencies and economy-of-scale benefits of the NPGU combined-cycle plant. In other words, if a 200 MW proposal ended in 2027, the RSM assumed that a 200 MW combined-cycle facility replaced it in 2028; however, the construction costs for the replacement facility were not those that would typically be associated with a 200 MW combined-cycle plant, but rather, they were a prorated portion of the construction costs of the larger NPGU combined-cycle facility.

As noted above, depending on the "in-service date" for the filler resource, the filler's capital costs were escalated from a 2012 base-year value by 3%/year. This escalation assumption represented Tampa Electric's estimate of how construction costs were likely to increase for its generation alternatives. Sedway Consulting decided to use this escalation value to trend the filler's annual capacity charges over time. Thus, instead of using Tampa Electric's declining revenue requirements profile for the recovery of capacity costs, Sedway Consulting used an escalating pattern that yielded the same long-term present value of revenue requirements. A traditional revenue requirements profile results in the highest capital charges in a project's early years. Thereafter, the capital-related charges decline. This is the opposite from what is usually seen in most power purchase proposals in power supply solicitations. Most power purchase proposals tend to have flat or escalating capacity charges, presumably reflecting expectations that general inflation will increase the costs of constructing new facilities in the future. Sedway Consulting therefore restructured the filler's profile of capacity costs to match what is generally seen in the marketplace. This meant that the filler's first year's capacity costs were the lowest, with each year thereafter escalating at 3%. Figure A-1 displays the escalating capacity price profile used by Sedway Consulting as well as the traditional declining revenue requirements profile. Both profiles have the same present value.

Over the full 30 years, the restructuring of the filler's capacity costs made no difference to the present value of the facility's revenue requirements. However, in the evaluation of outside proposals that did not extend through 2046 (the end of the study period), it provided the most favorable basis for such proposals' evaluation. In effect, it assumed that, following the expiration of an outside proposal's term, Tampa Electric would procure replacement power supplies at a trended price based its NPGU. In reality, if the NPGU was determined to be most cost-effective at this future decision point, the declining revenue requirements profile would present the actual annual costs that Tampa Electric's customers would likely pay.





Figure A-2 depicts a comparison of the two approaches for replacing a hypothetical 15-year proposed power supply contract. The proposed contract is assumed to have a capacity charge that begins at \$8/kW-month and escalates at 2.5%/year.

Relative to the declining revenue requirements methodology, the escalating filler capacity price methodology favors the 10-year proposed power supply because it defers the most expensive years of capacity costs until beyond the end of the study period. Thus, the present value of total study-period capacity costs (i.e., power supply proposal plus filler resource) is lower under the escalating filler methodology than under the declining revenue requirements methodology. Ultimately, the use of different filler methodologies by Sedway Consulting and Tampa Electric provided added value in looking at the evaluation results from two different perspectives and ensuring that the conclusions were supported from either perspective. However, because Sedway Consulting and Tampa Electric used these different methodologies, the total net present value differences depicted in the final results were understandably different.



Proposal Cost Computation

Most of the input assumptions for the proposals and Tampa Electric's NPGU were directly input into the RSM in a straightforward fashion. There were some key additional external cost estimates that were developed outside of the proposal and input into the RSM or calculated within the model. They entailed the following:

- Firm gas transportation
- Tampa Electric transmission costs
- Third-party transmission costs
- Net equity adjustment
- Surplus/deficient capacity valuation.

Docket No. _____
 Sedway Consulting's
 Independent Evaluation Report
 Document 2, Page 10 of 15

Firm gas transportation. Tampa Electric's RFP required that bidders of gas-fired projects ensure that firm gas transportation would be available for their facilities. In the RFP bid forms/spreadsheets, bidders were asked to provide information that would allow Tampa Electric to estimate the expected annual firm gas transportation charges for each project. Sedway Consulting reviewed Tampa Electric's calculations – which included two different estimates for each project. Sedway Consulting used the lower estimate for each project. In the case of the Proposal A, the bidder had provided its own estimate (which Sedway Consulting used) that was essentially identical to the value developed by Tampa Electric. Table A-3 shows the annual firm gas transportation charges that were assigned to each resource/proposal, as well as the net present value impact on each proposal's economic evaluation.

Table A-3 Firm Gas Transportation Cost Assumptions and NPV Impact		
Resource/Proposal	Annual Charges (\$M/year)	NPV Impact (\$M)
Proposal A	13.7	68
Proposal B	17.4	196
Proposal C	10.6	54
Proposal D	10.6	68
Polk NPGU	0	0

Tampa Electric's Polk NPGU was assumed to have no incremental firm gas transportation charges associated with it. Sedway Consulting had several discussions with Tampa Electric regarding this assumption. Tampa Electric explained that existing firm gas transportation contracts were already in place to provide a firm gas supply to the existing Polk 2-5 CTs. During full load operations of the base combined-cycle capacity of the new project, the gas consumption would not increase because the new project would simply be using the waste heat from the CTs for the incremental generation. During hours when the 120 MW of duct-firing is called on, however, gas consumption would increase. Tampa Electric maintained that it might supplement its firm gas supply with interruptible gas (i.e., higher-commodity-priced gas that did not have firm gas reservation charges associated with it). Sedway Consulting reviewed Tampa Electric's modeling results that indicated that the NPGU could be expected to consume an annual average of 6% of its gas supply in the form of interruptible gas. Sedway Consulting incorporated the annual percentage assumptions into its modeling of the NPGU, thereby increasing the effective commodity price of gas for the NPGU. All of the proposals were modeled as consuming fully firm gas (at a lower commodity price).

Tampa Electric transmission costs. With addition of new generation to a utility system, portions of the utility's transmission grid may need to be reinforced. This can entail the construction of new circuits or the reconductoring and upgrading of existing transmission lines. For proposals that were outside of Tampa Electric's transmission system, bidders were responsible for including the costs of such network upgrades to the

other transmission provider's system in their bid pricing. However, with regard to Tampa Electric's transmission system, any proposal for generation supplies – whether located within or outside of Tampa Electric's system – might trigger the need for Tampa Electric network upgrades. Estimates of such investments were calculated by Tampa Electric's transmission department and were not verifiable by Sedway Consulting. Table A-4 provides those estimates, as well as the net present value impact on each proposal's economic evaluation.

Table A-4 Tampa Electric Network Upgrade Assumptions and NPV Impact		
Resource/Proposal	Network Upgrades (\$M)	NPV Impact (\$M)
Proposal A	100	62
Proposal B	17	23
Proposal C	1	1
Proposal D	1	1
Polk NPGU	147	N/A ¹
¹ Included in base revenue requirements for NPGU.		

Sedway Consulting and Tampa Electric had several discussions particularly about the Proposal A transmission cost estimate. Given that [REDACTED], Sedway Consulting thought that it would likely have no network upgrades. However, Tampa Electric's transmission department maintains that [REDACTED], thereby necessitating Tampa Electric transmission system reinforcements.

Sedway Consulting employed a different methodology for developing the cost impacts of network upgrades than Tampa Electric. Sedway Consulting calculated levelized annual transmission revenue requirements⁴ for the applicable investment and applied those annual costs only during the term of the PPA (or economic life of the asset in the case of owned generation options). Tampa Electric developed revenue requirements from the transmission investment estimates and applied them for all years of the study period for all bids. Neither approach is right or wrong. Sedway Consulting's approach simply assumes that a transaction's transmission investments may benefit Tampa Electric's customers after the expiration of the current PPA or be associated with other power purchase transactions in the future and thus only attributes annual transmission charges to the current PPA during the years that the PPA is active. Tampa Electric's approach assumes that no future benefits will exist and the full study period revenue requirements of the transmission investment must be associated with the PPA regardless of the PPA's duration. The only proposal where this resulted in any significant net present value difference was the [REDACTED]. Tampa Electric's approach yielded an NPV

⁴ Assuming a 30-year asset life.

cost impact for this project of \$130 million, approximately \$68 million more than Sedway Consulting's approach.

Third-party transmission costs. As noted above, bidders were required to include network upgrade investments on other transmission owners' systems in their bid pricing. In addition, bidders had to identify in their proposals any firm transmission wheeling charges (e.g., for point-to-point transmission service) that would be incurred and passed on to Tampa Electric. Table A-5 depicts the assumptions that were provided by the bidders and verified by the evaluation team. Wheeling charges were assumed to remain flat over the duration of the transaction – likely a conservative assumption.

Table A-5 Transmission Wheeling Cost Assumptions and NPV Impact			
Resource/Proposal	Annual	Wheeling Charges (\$M/year)	NPV Impact (\$M)
Proposal A		0	0
Proposal B		6.8	77
Proposal C		5.3	27
Proposal D		5.3	34
Polk NPGU		0	0

Net Equity Adjustment. Rating agencies view some portion of a utility's capacity payment obligations to a power provider as the equivalent of debt on the utility's balance sheet. If a utility does not rebalance its capital structure by issuing stock, this debt equivalent can negatively impact a utility's financial ratios and cause rating agencies to downgrade their opinion of the utility's creditworthiness. This can increase the utility's cost of borrowing.

Sedway Consulting estimated for each PPA proposal (i.e., Proposals A, C and D) the costs for Tampa Electric to rebalance its capital structure if it were to enter into the PPA. This estimate was referred to as an "equity adjustment" because it reflected the present value of the incremental cost of the additional equity that Tampa Electric would need to raise to preserve the integrity of its balance sheet. The net present value of the equity adjustment for the Proposal A was in the range of \$16-\$17 million; it was \$8 million and \$13 million for Proposal C and Proposal D, respectively.

Surplus/Deficient Capacity Valuation. In Sedway Consulting's analysis, projects were evaluated on a stand-alone basis rather than in the context of a 30-year generation expansion plan, as was the case with Tampa Electric's detailed model. Sedway Consulting therefore accounted for the different capacity of each resource by recognizing to what extent it either exceeded or failed to meet Tampa Electric's capacity need in 2017-2019 and valuing the surplus or deficient capacity based on Tampa Electric's generic Frame 7FA CT costs. Specifically, if a resource provided more than Tampa Electric's cumulative capacity need in 2017-2019, then the resource was deemed to

provide surplus capacity. This capacity had value because it would reduce Tampa Electric's capacity needs in 2019 and beyond and reduce the need in future power supply solicitations.⁵ Using the costs and expected energy benefits of a generic Frame 7FA CT, Sedway Consulting derived a 2017 value of \$8.90/kW-month, escalating thereafter at 3% per year. This stream represented trended values for the net cost of the surplus/deficient capacity.

The same arithmetic applied to those resources that were too small to meet Tampa Electric's 2017-2019 capacity needs, although in the other direction. In those cases, the deficient capacity in each year (2017-2019 and beyond) was assigned a cost that was based on the same trended net cost of Tampa Electric's generic Frame 7FA CT. In essence, such offers were being packaged with a CT to create a compliant portfolio, much the same way that Tampa Electric's generation expansion plan model did.

The inclusion of a surplus/deficient capacity benefit/cost in the RSM results placed those results on a more comparable footing with the Tampa Electric detailed production costing and generation expansion results. While no explicit surplus/deficient capacity benefit/cost was calculated to supplement the model results in Tampa Electric's analysis, this cost or benefit was captured in the long-range expansion plans that were developed around each resource.

RSM Evaluation Results

As noted in the Introduction and Background section and Table A-1 of this report, Tampa Electric's 2012 Ten-Year Site Plan included three load forecasts (a low-load scenario, a base case, and a high-load scenario). Sedway Consulting and Tampa Electric decided to conduct the evaluation of all resources under each of those load forecasts. In addition, each load scenario would be coupled with a fuel price scenario. Thus, the base load scenario would be run with the base fuel price forecast, and the high and low load forecasts would be paired with fuel prices that were approximately 35% higher or lower, respectively, than the base forecast. All such assumption details were anchored before proposals were received.

Under all scenarios, Sedway Consulting found that Tampa Electric's NPGU was the least-cost option. Table A-6 depicts the cost differences that Sedway Consulting's analysis determined for each proposal under each of the three fuel price/load scenarios.

⁵ Sedway Consulting assumed that little opportunity for short-term capacity sales in the Tampa Electric area would exist in 2017 and 2018 and therefore assigned no surplus capacity value in those years; surplus capacity was only valued for 2019 and beyond.

Table A-6
Cost Differences Relative to Tampa Electric's NPGU
(\$M, NPV₂₀₁₂)

Proposal	Low Case	Base Case	High Case
Proposal A [REDACTED]	62	148	242
Proposal A [REDACTED]	52	131	210
Proposal A [REDACTED]	15	69	120
Proposal B	291	592	947
Proposal C	240	508	802
Proposal D	260	553	876

On a net present value basis, the NPGU was found to be \$69 million less expensive than the lowest-cost proposal under base case assumptions. However, it is important to note that this cost differential was associated with Proposal A's [REDACTED]. It is Sedway Consulting's understanding that Tampa Electric did not initially evaluate this or the [REDACTED] offer because they were not compliant with the RFP [REDACTED]. Sedway Consulting's results for the [REDACTED] offer are fairly close to Tampa Electric's results, after accounting for the transmission revenue requirement methodology differences described above.

Sedway Consulting's evaluation of all of the Proposal A offers is predicated on the assumption that Tampa Electric's Polk NPGU could be deferred until the end of the PPAs ([REDACTED]). However, at that time, the existing Polk 2-5 CTs will be approaching an age where it may not make economic sense to invest in their conversion. Sedway Consulting followed the same process with Proposal C and Proposal D (replacing them with Tampa Electric's NPGU at the expiration of the PPAs in [REDACTED] and [REDACTED]) and thus the same or stronger caveat applies. Proposal B did not entail an expiration of the resources (i.e., the resources were assumed to continue operating through the end of the study period, 2046) and therefore they were never "replaced" with the NPGU. This is consistent with Sedway Consulting's stand-alone bid evaluation process. However, in reviewing the details behind Tampa Electric's results, Sedway Consulting noted that Tampa Electric optimized the bid-specific generation expansion plans. This optimization resulted in the NPGU resource being included in the bid plans, commencing operations in 2018 in the Proposal B base case analysis and 2023 in the Proposal C and Proposal D base case analyses. Tampa Electric's NPGU is a very cost-effective resource; its expected system production cost savings more than offset the project's investment costs in Sedway Consulting's base and high gas price results. Thus, its inclusion in the Proposal B analysis and its earlier inclusion in the Proposal C and Proposal D analyses significantly improved the economics of those resources' analyses. In essence, Tampa Electric's Proposal B base case evaluation is largely an analysis of a one-year deferral of the NPGU. Sedway Consulting's analysis was based more on a stand-alone bid evaluation process.

Docket No. _____
Sedway Consulting's
Independent Evaluation Report
Document 2, Page 15 of 15

Conclusions

Sedway Consulting performed an independent evaluation of Tampa Electric's Polk NPGU relative to the responses to Tampa Electric's 2012 resource RFP and concluded that the NPGU represents the lowest-cost resource for meeting Tampa Electric's 2017 resource need. The NPGU was found to be \$69 million on a cumulative present value of revenue requirements basis (CPVRR) less expensive than the next cheapest option under base case assumptions.