



RECEIVED-FPSC

13 OCT 29 AM 10:18

COMMISSION
CLERK

October 28, 2013

Ms. Ann Cole, Clerk
Florida Public Service Commission
2540 Shumard Oak Boulevard
Tallahassee, Florida 32399-0850

Re: Docket No.: 130001
Performance Data Report for September, 2013

Dear Ms. Cole:

Enclosed for filing in the above docket are the original and ten (10) copies of Duke Energy Florida's Performance Data Report for September, 2013.

If you have any questions, please do not hesitate to contact me at 727-820-4692.

Sincerely,

Dianne Triplett
Associate General Counsel

DT/emc
Enclosure

cc: Tom Ballinger
Director of Engineering
FPSC
Parties of Record

COM	
AFD	5
APA	1
ECO	1
ENG	1
GCL	1
IDM	1
TEL	1
CLK	1

Duke Energy Florida

ACTUAL UNIT PERFORMANCE DATA -- YEAR 2013

Bartow CC	Jan-13	Feb-13	Mar-13	Apr-13	May-13	Jun-13	Jul-13	Aug-13	Sep-13	Oct-13	Nov-13	Dec-13	Jan - Sep Period
1. EAF	97.92	84.48	56.60	93.13	95.12	99.03	95.48	99.91	97.59				91.04
2. PH	744	672	743	720	744	720	744	744	720				6,551
3. SH	612.5	539.2	406.6	632.5	653.5	690.7	696.7	744.0	670.1				5,645.6
4. RSH	117.6	28.8	18.6	70.7	60.5	23.5	14.4	0.0	36.9				371.0
5. UH	13.9	104.0	317.8	16.8	30.1	5.9	33.0	0.0	13.0				534.4
6. POH	0.0	87.0	317.4	0.0	0.0	0.0	0.0	0.0	0.0				404.4
7. FOH	7.6	16.9	0.4	0.6	3.9	4.1	4.3	0.0	6.2				43.8
8. MOH	6.3	0.2	0.0	16.2	26.2	1.8	28.7	0.0	6.8				86.2
9. PPOH	0.0	168.8	58.5	0.0	0.0	0.0	0.0	0.0	0.0				227.3
10. LR PP (MW)	0.0	156.5	156.5	0.0	0.0	0.0	0.0	0.0	0.0				156.5
11. PFOH	8.0	1.7	32.3	223.6	8.9	9.0	10.5	45.8	60.3				399.9
12. LR PF (MW)	214.6	156.3	156.5	157.0	90.2	99.5	69.3	16.2	77.8				125.0
13. PMOH	0.0	0.0	0.0	0.0	57.8	4.0	0.0	0.0	0.0				61.8
14. LR PM (MW)	0.0	0.0	0.0	0.0	101.8	67.5	0.0	0.0	0.0				99.6
15. NSC (MW)	1074	1074	1074	1074	1074	1074	1074	1074	1074				1074
16. OPER MBTU	4,127,193	3,712,463	3,068,324	4,104,517	4,284,649	4,783,269	4,989,524	5,260,497	4,439,902				38,770,338
17. NET GEN (MWH)	563,341	502,626	366,800	560,403	588,872	654,808	664,060	724,554	602,661				5,228,125
18. ANOHR (BTU/KWH)	7,326.3	7,386.1	8,365.1	7,324.2	7,276.0	7,304.8	7,513.7	7,260.3	7,367.2				7,415.7
19. NOF (%)	85.64	86.80	84.00	82.50	83.91	88.28	88.75	90.68	83.74				86.22
20. NPC (MW)	1074	1074	1074	1074	1074	1074	1074	1074	1074				1074

Duke Energy Florida

ACTUAL UNIT PERFORMANCE DATA -- YEAR 2013

CRYSTAL RIVER 4	Jan-13	Feb-13	Mar-13	Apr-13	May-13	Jun-13	Jul-13	Aug-13	Sep-13	Oct-13	Nov-13	Dec-13	Jan - Sep Period
1. EAF	100.00	99.40	30.07	99.40	73.17	69.97	80.26	96.83	99.27				82.91
2. PH	744	672	743	720	744	720	744	744	720				6,551
3. SH	744.0	669.8	225.5	720.0	545.0	503.8	597.3	744.0	720.0				5,469.4
4. RSH	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0				0.0
5. UH	0.0	2.2	517.5	0.0	199.0	216.2	146.7	0.0	0.0				1,061.6
6. POH	0.0	0.0	516.8	0.0	0.0	0.0	0.0	0.0	0.0				516.8
7. FOH	0.0	2.2	0.7	0.0	38.3	0.0	0.0	0.0	0.0				41.2
8. MOH	0.0	0.0	0.0	0.0	160.8	216.2	146.7	0.0	0.0				523.7
9. PPOH	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0				0.0
10. LR PP (MW)	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0				0.0
11. PFOH	0.0	0.0	16.0	10.8	8.7	0.0	1.5	135.5	4.8				177.3
12. LR PF (MW)	0.0	0.0	93.0	5.0	44.2	0.0	93.2	84.0	96.7				78.5
13. PMOH	0.0	30.0	0.0	12.5	0.0	0.0	0.0	35.4	15.1				92.9
14. LR PM (MW)	0.0	42.8	0.0	241.7	0.0	0.0	0.0	153.6	217.1				140.0
15. NSC (MW)	712	712	712	712	712	712	712	712	712				712
16. OPER MBTU	3,665,173	3,389,230	1,043,604	4,691,727	3,416,885	3,079,048	3,314,511	4,042,517	3,803,752				30,446,447
17. NET GEN (MWH)	351,098	326,307	98,909	441,792	312,393	290,324	301,999	386,618	365,924				2,875,364
18. ANOHR (BTU/KWH)	10,439.2	10,386.6	10,551.2	10,619.8	10,937.8	10,605.6	10,975.2	10,456.1	10,394.9				10,588.7
19. NOF (%)	66.28	68.43	61.60	86.18	80.51	80.94	71.01	72.98	71.38				73.84
20. NPC (MW)	712	712	712	712	712	712	712	712	712				712

Duke Energy Florida

ACTUAL UNIT PERFORMANCE DATA -- YEAR 2013

CRYSTAL RIVER 5	Jan-13	Feb-13	Mar-13	Apr-13	May-13	Jun-13	Jul-13	Aug-13	Sep-13	Oct-13	Nov-13	Dec-13	Jan - Sep Period
1. EAF	75.56	90.09	86.71	99.73	99.00	92.32	99.77	97.95	93.32				92.72
2. PH	744	672	743	720	744	720	744	744	720				6,551
3. SH	597.6	635.0	645.0	720.0	736.8	666.3	744.0	733.6	678.3				6,156.6
4. RSH	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0				0.0
5. UH	146.4	37.0	98.0	0.0	7.2	53.7	0.0	10.5	41.7				394.5
6. POH	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0				0.0
7. FOH	146.4	0.0	98.0	0.0	7.2	53.7	0.0	6.7	41.7				353.7
8. MOH	0.0	37.0	0.0	0.0	0.0	0.0	0.0	3.8	0.0				40.8
9. PPOH	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0				0.0
10. LR PP (MW)	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0				0.0
11. PFOH	48.1	49.9	0.6	19.4	5.5	4.5	9.2	18.0	0.0				155.1
12. LR PF (MW)	523.9	286.4	79.0	45.7	28.8	91.0	63.4	99.3	0.0				279.5
13. PMOH	0.0	43.3	2.0	5.5	0.0	8.0	7.0	3.4	30.1				99.3
14. LR PM (MW)	0.0	155.1	234.0	91.0	0.0	91.0	91.0	472.5	151.6				153.3
15. NSC (MW)	710	710	710	710	710	710	710	710	710				710
16. OPER MBTU	2,595,380	3,126,153	3,988,380	4,364,618	4,373,920	3,818,889	3,798,563	3,817,476	3,363,239				33,246,618
17. NET GEN (MWH)	242,344	300,323	390,822	414,469	415,235	363,532	353,702	364,433	320,502				3,165,362
18. ANOHR (BTU/KWH)	10,709.5	10,409.3	10,205.1	10,530.6	10,533.6	10,505.0	10,739.4	10,475.1	10,493.7				10,503.3
19. NOF (%)	57.12	66.61	85.34	81.08	79.38	76.84	66.96	69.97	66.55				72.41
20. NPC (MW)	710	710	710	710	710	710	710	710	710				710

Duke Energy Florida

ACTUAL UNIT PERFORMANCE DATA -- YEAR 2013

HINES 1	Jan-13	Feb-13	Mar-13	Apr-13	May-13	Jun-13	Jul-13	Aug-13	Sep-13	Oct-13	Nov-13	Dec-13	Jan - Sep Period
1. EAF	100.00	100.00	100.00	40.53	76.25	95.02	97.27	96.65	95.13				88.99
2. PH	744	672	743	720	744	720	744	744	720				6,551
3. SH	744.0	672.0	743.0	291.8	567.3	699.0	744.0	744.0	720.0				5,925.1
4. RSH	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0				0.0
5. UH	0.0	0.0	0.0	428.2	176.7	21.0	0.0	0.0	0.0				625.9
6. POH	0.0	0.0	0.0	428.2	170.7	0.0	0.0	0.0	0.0				598.9
7. FOH	0.0	0.0	0.0	0.0	6.1	21.0	0.0	0.0	0.0				27.1
8. MOH	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0				0.0
9. PPOH	0.0	0.0	216.0	291.8	383.4	0.0	0.0	0.0	0.0				891.2
10. LR PP (MW)	0.0	0.0	207.0	207.0	207.0	0.0	0.0	0.0	0.0				207.0
11. PFOH	0.0	0.0	0.0	0.0	0.0	28.6	55.3	45.5	0.0				129.4
12. LR PF (MW)	0.0	0.0	0.0	0.0	0.0	229.0	169.6	247.0	0.0				209.9
13. PMOH	0.0	0.0	0.0	0.0	0.0	1.6	0.0	1.4	71.2				74.2
14. LR PM (MW)	0.0	0.0	0.0	0.0	0.0	198.6	0.0	199.5	227.5				226.3
15. NSC (MW)	462	462	462	462	462	462	462	462	462				462
16. OPER MBTU	2,402,918	2,210,653	2,097,737	429,245	970,603	1,985,653	2,144,916	2,381,294	2,239,789				16,862,808
17. NET GEN (MWH)	333,404	312,259	266,812	53,909	123,979	255,827	292,937	319,038	306,641				2,264,806
18. ANOHR (BTU/KWH)	7,207.2	7,079.6	7,862.2	7,962.4	7,828.8	7,761.7	7,322.1	7,464.0	7,304.3				7,445.6
19. NOF (%)	97.00	100.58	77.73	39.99	47.31	79.22	85.22	92.82	92.18				82.74
20. NPC (MW)	462	462	462	462	462	462	462	462	462				462

Duke Energy Florida

ACTUAL UNIT PERFORMANCE DATA -- YEAR 2013

HINES 2	Jan-13	Feb-13	Mar-13	Apr-13	May-13	Jun-13	Jul-13	Aug-13	Sep-13	Oct-13	Nov-13	Dec-13	Jan - Sep Period
1. EAF	100.00	11.25	96.56	100.00	96.39	96.68	98.57	100.00	99.84				89.55
2. PH	744	672	743	720	744	720	744	744	720				6,551
3. SH	335.8	51.6	717.4	720.0	717.2	696.5	744.0	744.0	720.0				5,446.5
4. RSH	408.2	24.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0				432.2
5. UH	0.0	596.4	25.6	0.0	26.8	23.6	0.0	0.0	0.0				672.4
6. POH	0.0	495.6	0.0	0.0	0.0	0.0	0.0	0.0	0.0				495.6
7. FOH	0.0	100.8	25.6	0.0	26.8	23.6	0.0	0.0	0.0				176.8
8. MOH	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0				0.0
9. PPOH	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0				0.0
10. LR PP (MW)	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0				0.0
11. PFOH	0.0	0.0	0.0	0.0	0.0	0.0	22.7	0.0	1.1				23.8
12. LR PF (MW)	0.0	0.0	0.0	0.0	0.0	0.0	230.3	0.0	313.1				234.2
13. PMOH	0.0	0.0	0.0	0.0	0.0	1.5	0.0	0.0	1.5				3.0
14. LR PM (MW)	0.0	0.0	0.0	0.0	0.0	127.0	0.0	0.0	136.0				131.5
15. NSC (MW)	490	490	490	490	490	490	490	490	490				490
16. OPER MBTU	573,429	172,528	1,727,376	2,023,581	2,120,946	2,330,984	2,274,828	2,371,095	2,409,757				16,004,523
17. NET GEN (MWH)	76,912	10,384	251,308	279,001	283,907	303,656	310,483	335,282	331,030				2,181,963
18. ANOHR (BTU/KWH)	7,455.6	16,614.8	6,873.5	7,253.0	7,470.6	7,676.4	7,326.7	7,071.9	7,279.6				7,334.9
19. NOF (%)	46.74	41.05	71.49	79.08	80.79	88.98	85.17	91.97	93.83				81.76
20. NPC (MW)	490	490	490	490	490	490	490	490	490				490

Duke Energy Florida

ACTUAL UNIT PERFORMANCE DATA -- YEAR 2013

HINES 3	Jan-13	Feb-13	Mar-13	Apr-13	May-13	Jun-13	Jul-13	Aug-13	Sep-13	Oct-13	Nov-13	Dec-13	Jan - Sep Period
1. EAF	100.00	100.00	76.90	100.00	100.00	100.00	93.52	100.00	99.90				96.63
2. PH	744	672	743	720	744	720	744	744	720				6,551
3. SH	744.0	672.0	571.4	720.0	744.0	720.0	700.4	744.0	720.0				6,335.8
4. RSH	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0				0.0
5. UH	0.0	0.0	171.7	0.0	0.0	0.0	43.6	0.0	0.0				215.2
6. POH	0.0	0.0	171.7	0.0	0.0	0.0	0.0	0.0	0.0				171.7
7. FOH	0.0	0.0	0.0	0.0	0.0	0.0	43.6	0.0	0.0				43.6
8. MOH	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0				0.0
9. PPOH	0.0	0.0	571.4	176.5	8.9	0.0	0.0	0.0	0.0				756.7
10. LR PP (MW)	0.0	0.0	228.0	228.0	125.0	0.0	0.0	0.0	0.0				226.8
11. PFOH	0.0	0.0	0.0	0.0	0.0	0.0	17.1	0.0	0.0				17.1
12. LR PF (MW)	0.0	0.0	0.0	0.0	0.0	0.0	132.2	0.0	0.0				132.2
13. PMOH	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	2.2				2.2
14. LR PM (MW)	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	156.2				156.2
15. NSC (MW)	488	488	488	488	488	488	488	488	488				488
16. OPER MBTU	1,400,404	1,320,380	1,005,540	1,778,298	2,300,689	2,158,319	2,125,122	2,338,002	2,315,333				16,742,087
17. NET GEN (MWH)	187,931	174,079	129,263	243,767	309,630	297,713	294,815	329,808	325,268				2,292,274
18. ANOHR (BTU/KWH)	7,451.7	7,584.9	7,779.0	7,295.1	7,430.4	7,249.7	7,208.3	7,089.0	7,118.2				7,303.7
19. NOF (%)	51.76	53.08	46.36	69.38	85.28	84.73	86.25	90.84	92.57				74.14
20. NPC (MW)	488	488	488	488	488	488	488	488	488				488

Duke Energy Florida

ACTUAL UNIT PERFORMANCE DATA -- YEAR 2013

HINES 4	Jan-13	Feb-13	Mar-13	Apr-13	May-13	Jun-13	Jul-13	Aug-13	Sep-13	Oct-13	Nov-13	Dec-13	Jan - Sep Period
1. EAF	100.00	100.00	98.78	100.00	98.25	99.91	100.00	99.93	99.50				99.59
2. PH	744	672	743	720	744	720	744	744	720				6,551
3. SH	744.0	672.0	733.9	720.0	731.0	720.0	744.0	744.0	716.9				6,525.7
4. RSH	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0				0.0
5. UH	0.0	0.0	9.1	0.0	13.0	0.0	0.0	0.0	3.2				25.3
6. POH	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0				0.0
7. FOH	0.0	0.0	0.0	0.0	13.0	0.0	0.0	0.0	3.2				16.2
8. MOH	0.0	0.0	9.1	0.0	0.0	0.0	0.0	0.0	0.0				9.1
9. PPOH	0.0	0.0	0.0	0.0	6.6	0.0	0.0	0.0	0.0				6.6
10. LR PP (MW)	0.0	0.0	0.0	0.0	140.0	0.0	0.0	0.0	0.0				140.0
11. PFOH	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0				0.0
12. LR PF (MW)	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0				0.0
13. PMOH	0.0	0.0	0.0	0.0	0.0	2.2	0.0	2.4	1.8				6.4
14. LR PM (MW)	0.0	0.0	0.0	0.0	0.0	139.8	0.0	100.1	119.8				119.4
15. NSC (MW)	472	472	472	472	472	472	472	472	472				472
16. OPER MBTU	1,589,486	1,692,970	2,231,910	1,839,618	1,797,414	2,158,318	2,439,978	2,490,011	2,263,525				18,503,230
17. NET GEN (MWH)	229,724	249,046	334,726	255,052	252,425	333,089	346,547	342,271	319,809				2,662,689
18. ANOHR (BTU/KWH)	6,919.1	6,797.8	6,667.9	7,212.7	7,120.6	6,479.7	7,040.8	7,275.0	7,077.7				6,949.1
19. NOF (%)	65.42	78.52	96.63	75.05	73.16	98.01	98.68	97.47	94.52				86.45
20. NPC (MW)	472	472	472	472	472	472	472	472	472				472

Duke Energy Florida

ACTUAL UNIT EVENT DATA -- January - September 2013

Bartow CC

Unit	Date	Outage Type	Hours	MW Affected	Description
BCC 4A	1/3/2013	FFO	0.68	176.0	OPERATOR ERROR
BCC 4A	2/8/2013	PO	572.02	176.0	GAS TURBINE - HOT END INSPECTION
BCC 4A	3/4/2013	PO	190.05	176.0	GAS TURBINE CONTROL SYSTEM - UPGRADES
BCC 4A	6/18/2013	FFO	25.17	176.0	GAS TURBINE - COMBUSTOR CASING
BCC 4A	9/23/2013	FFO	25.32	176.0	GAS TURBINE - COMBUSTOR CASING
BCC 4A	9/24/2013	FMO	2.07	176.0	LP DRUM
BCC 4B	1/30/2013	FFO	47.28	176.0	HP STARTUP BYPASS SYSTEM VALVES
BCC 4B	2/1/2013	FMO	1.33	176.0	POWER AUGMENTATION SYSTEM EQUIPMENT
BCC 4B	3/4/2013	PO	479.65	176.0	GAS TURBINE - HOT END INSPECTION
BCC 4B	4/26/2013	FMO	100.48	176.0	IP SUPERHEATER
BCC 4B	5/15/2013	FFO	23.90	176.0	GAS TURBINE - FIRE DETECTION AND EXTINGUISHING SYS
BCC 4B	6/2/2013	FMO	11.17	176.0	OTHER HP STEAM SYSTEM PROBLEMS
BCC 4C	3/5/2013	PO	174.35	176.0	GAS TURBINE CONTROL SYSTEM - UPGRADES
BCC 4C	5/17/2013	FMO	162.57	176.0	OTHER EXCITER PROBLEMS
BCC 4C	8/13/2013	PFO	14.83	15.5	GAS TURBINE - FUEL PIPING AND VALVES
BCC 4C	8/14/2013	PFO	18.22	15.5	GAS TURBINE - FUEL PIPING AND VALVES
BCC 4C	8/15/2013	PFO	22.58	15.5	GAS TURBINE - FUEL PIPING AND VALVES
BCC 4C	8/16/2013	PFO	16.62	15.5	GAS TURBINE - FUEL PIPING AND VALVES
BCC 4C	8/17/2013	PFO	15.62	15.5	GAS TURBINE - FUEL PIPING AND VALVES
BCC 4C	8/18/2013	PFO	14.12	15.5	GAS TURBINE - FUEL PIPING AND VALVES
BCC 4C	8/19/2013	PFO	17.37	15.5	GAS TURBINE - FUEL PIPING AND VALVES
BCC 4C	8/20/2013	PFO	16.45	15.5	GAS TURBINE - FUEL PIPING AND VALVES
BCC 4C	8/21/2013	PFO	15.40	15.5	GAS TURBINE - FUEL PIPING AND VALVES
BCC 4C	8/22/2013	PFO	16.80	15.5	GAS TURBINE - FUEL PIPING AND VALVES
BCC 4C	8/23/2013	PFO	16.28	15.5	GAS TURBINE - FUEL PIPING AND VALVES
BCC 4C	8/24/2013	PFO	16.15	15.5	GAS TURBINE - FUEL PIPING AND VALVES
BCC 4C	8/25/2013	PFO	13.50	15.5	GAS TURBINE - FUEL PIPING AND VALVES

Duke Energy Florida

ACTUAL UNIT EVENT DATA -- January - September 2013

Bartow CC

Unit	Date	Outage Type	Hours	MW Affected	Description
BCC 4C	8/26/2013	PFO	12.23	15.5	GAS TURBINE - FUEL PIPING AND VALVES
BCC 4C	8/27/2013	PFO	13.47	15.5	GAS TURBINE - FUEL PIPING AND VALVES
BCC 4C	8/28/2013	PFO	12.07	20.5	GAS TURBINE - FUEL PIPING AND VALVES
BCC 4C	8/29/2013	PFO	15.33	20.5	GAS TURBINE - FUEL PIPING AND VALVES
BCC 4C	8/30/2013	PFO	1.58	0.0	GAS TURBINE - FUEL PIPING AND VALVES
BCC 4C	8/31/2013	PFO	2.57	20.5	GAS TURBINE - FUEL PIPING AND VALVES
BCC 4C	8/31/2013	PFO	14.48	20.5	GAS TURBINE - FUEL PIPING AND VALVES
BCC 4C	9/1/2013	PFO	15.82	20.5	GAS TURBINE - FUEL PIPING AND VALVES
BCC 4C	9/2/2013	PFO	1.25	25.5	GAS TURBINE - FUEL PIPING AND VALVES
BCC 4C	9/2/2013	PFO	15.02	25.5	GAS TURBINE - FUEL PIPING AND VALVES
BCC 4C	9/3/2013	PFO	17.60	24.5	GAS TURBINE - FUEL PIPING AND VALVES
BCC 4C	9/4/2013	PFO	16.03	24.5	GAS TURBINE - FUEL PIPING AND VALVES
BCC 4C	9/5/2013	PFO	15.58	29.5	GAS TURBINE - FUEL PIPING AND VALVES
BCC 4C	9/6/2013	PFO	9.17	29.5	GAS TURBINE - FUEL PIPING AND VALVES
BCC 4C	9/6/2013	FMO	22.60	176.0	GAS TURBINE - FUEL PIPING AND VALVES
BCC 4D	1/2/2013	FFO	0.53	176.0	OPERATOR ERROR
BCC 4D	1/31/2013	FFO	1.53	176.0	IP STARTUP BYPASS SYSTEM VALVES
BCC 4D	3/1/2013	FFO	2.38	176.0	GAS FUEL SYSTEM WITH CONTROLS AND INSTRUMENTS
BCC 4D	3/5/2013	PO	161.35	176.0	GAS TURBINE CONTROL SYSTEM - UPGRADES
BCC 4D	4/3/2013	FFO	3.65	176.0	GAS TURBINE - LUBE OIL VALVES/PIPING
BCC 4D	7/22/2013	FFO	26.80	176.0	GAS TURBINE - FUEL PIPING AND VALVES
BCC 4D	9/11/2013	FFO	9.27	176.0	OTHER CIRCULATING WATER SYSTEM PROBLEMS
BCC 4D	9/12/2013	FMO	18.05	176.0	OTHER CIRCULATING WATER SYSTEM PROBLEMS
BCC 4S	1/2/2013	FMO	17.62	429.0	STEAM TURBINE CONTROL SYSTEM - HARDWARE PROBLEMS
BCC 4S	1/30/2013	PFO	22.50	214.5	HP STARTUP BYPASS SYSTEM VALVES
BCC 4S	2/1/2013	PFO	3.22	156.4	HP STARTUP BYPASS SYSTEM VALVES
BCC 4S	2/1/2013	PFO	1.42	156.5	POWER AUGMENTATION SYSTEM EQUIPMENT

Duke Energy Florida

ACTUAL UNIT EVENT DATA -- January - September 2013

Bartow CC

Unit	Date	Outage Type	Hours	MW Affected	Description
BCC 4S	2/3/2013	FFO	45.90	429.0	TURBINE - OTHER LUBE OIL SYSTEM PROBLEMS
BCC 4S	2/8/2013	PPO	474.67	156.5	GAS TURBINE - HOT END INSPECTION
BCC 4S	2/28/2013	PO	420.83	429.0	OTHER LOW PRESSURE TURBINE PROBLEMS
BCC 4S	3/17/2013	PPO	164.48	156.5	GAS TURBINE - HOT END INSPECTION
BCC 4S	3/28/2013	PFO	155.02	156.5	REHEAT STEAM PIPING UP TO TURBINE STOP VALVES
BCC 4S	4/3/2013	PFO	3.65	245.5	GAS TURBINE - LUBE OIL VALVES/PIPING
BCC 4S	4/3/2013	PFO	450.90	156.5	REHEAT STEAM PIPING UP TO TURBINE STOP VALVES
BCC 4S	4/26/2013	PFO	110.80	156.5	IP SUPERHEATER
BCC 4S	5/15/2013	PFO	23.90	87.5	GAS TURBINE - FIRE DETECTION AND EXTINGUISHING SYS
BCC 4S	5/17/2013	PMO	70.72	69.5	OTHER EXCITER PROBLEMS
BCC 4S	5/20/2013	PMO	60.28	156.5	FEEDWATER CONTROLS
BCC 4S	5/23/2013	PMO	31.57	69.5	OTHER EXCITER PROBLEMS
BCC 4S	6/2/2013	PMO	11.17	67.5	OTHER HP STEAM SYSTEM PROBLEMS
BCC 4S	6/18/2013	PFO	25.17	99.5	GAS TURBINE - COMBUSTOR CASING
BCC 4S	7/12/2013	FMO	80.57	429.0	MAIN TRANSFORMER
BCC 4S	7/22/2013	PFO	26.80	69.5	GAS TURBINE - FUEL PIPING AND VALVES
BCC 4S	7/29/2013	PFO	2.63	67.5	TRAVELING SCREENS
BCC 4S	9/6/2013	PFO	36.25	156.5	GAS TURBINE - FUEL PIPING AND VALVES
BCC 4S	9/11/2013	PFO	61.92	69.5	OTHER CIRCULATING WATER SYSTEM PROBLEMS
BCC 4S	9/14/2013	PFO	3.28	86.5	TRAVELING SCREENS
BCC 4S	9/23/2013	PFO	27.38	69.5	GAS TURBINE - COMBUSTOR CASING
BCC 4S	9/25/2013	FFO	1.65	429.0	BURNER INSTRUMENTS AND CONTROLS (EXCEPT LIGHT-OFF)

Duke Energy Florida

ACTUAL UNIT EVENT DATA -- January - September 2013

Crystal River 4

Date	Outage Type	Hours	MW Affected	Description
2/2/2013	PMO	8.25	65.0	CONTROLS AND INSTRUMENTATION
2/24/2013	FFO	2.23	712.0	CONTROLS AND INSTRUMENTATION
2/26/2013	PMO	15.00	8.0	BOILER SAFETY VALVE TEST
2/27/2013	PMO	6.73	93.0	BOILER SAFETY VALVE TEST
3/2/2013	PO	516.80	712.0	BOILER INSPECTIONS
3/25/2013	FFO	0.67	712.0	START-UP FEEDWATER PUMP
3/27/2013	PFO	16.00	93.0	PRIMARY AIR DUCTS AND DAMPERS
4/3/2013	PMO	6.50	379.0	COAL CONVEYERS AND FEEDERS
4/18/2013	PMO	6.00	93.0	PULVERIZER LUBE OIL SYSTEM
4/19/2013	PFO	10.08	1.0	WET COAL (OMC)
4/27/2013	PFO	0.67	65.1	CONTROLS AND INSTRUMENTATION
5/3/2013	FMO	160.77	712.0	MAIN TRANSFORMER
5/11/2013	FFO	1.82	712.0	WET SCRUBBER/ABSORBER TOWER OR MODULE
5/17/2013	PFO	0.50	159.5	WET COAL (OMC)
5/17/2013	PFO	0.52	140.5	WET COAL (OMC)
5/17/2013	PFO	1.28	141.0	WET COAL (OMC)
5/28/2013	FFO	36.45	712.0	OTHER EXCITER PROBLEMS
5/31/2013	PFO	6.42	8.0	MAIN STEAM RELIEF/SAFETY VALVES
6/21/2013	FMO	362.90	712.0	OTHER HYDROGEN SYSTEM PROBLEMS
7/7/2013	PFO	1.53	92.9	PULVERIZER SYSTEM COAL LEAKS (NOT PULVERIZERS)
8/5/2013	PFO	135.50	84.0	PULVERIZER MOTORS AND DRIVES
8/12/2013	PMO	9.08	84.0	PULVERIZER MOTORS AND DRIVES
8/19/2013	PMO	3.80	92.9	INDUCED DRAFT FANS
8/21/2013	PMO	2.07	93.0	INDUCED DRAFT FANS
8/22/2013	PMO	4.50	93.0	INDUCED DRAFT FANS
8/23/2013	PMO	6.07	92.9	INDUCED DRAFT FANS
8/27/2013	PMO	3.43	474.1	OTHER STACK OR EXHAUST EMISSIONS TESTING - FOSSIL

Duke Energy Florida

ACTUAL UNIT EVENT DATA -- January - September 2013

Crystal River 4

Date	Outage Type	Hours	MW Affected	Description
8/27/2013	PMO	3.80	236.1	OTHER STACK OR EXHAUST EMISSIONS TESTING - FOSSIL
8/30/2013	PMO	2.60	236.1	OTHER STACK OR EXHAUST EMISSIONS TESTING - FOSSIL
9/4/2013	PFO	2.95	92.9	PULVERIZER LUBE OIL SYSTEM
9/4/2013	PMO	5.25	236.0	FORCED DRAFT FAN LUBRICATION SYSTEM
9/5/2013	PMO	7.83	236.0	FORCED DRAFT FAN LUBRICATION SYSTEM
9/14/2013	PFO	1.82	103.1	OTHER FUEL QUALITY PROBLEMS (OMC)
9/18/2013	PMO	2.00	92.9	PRIMARY AIR FAN DRIVES

Duke Energy Florida

ACTUAL UNIT EVENT DATA -- January - September 2013

Crystal River 5

Date	Outage Type	Hours	MW Affected	Description
1/1/2013	PFO	23.00	520.0	CONTROLS AND INSTRUMENTATION
1/2/2013	PFO	3.87	699.9	HEATER LEVEL CONTROL
1/2/2013	FFO	3.50	710.0	HEATER LEVEL CONTROL
1/2/2013	PFO	21.20	496.0	CONTROLS AND INSTRUMENTATION
1/16/2013	FFO	55.68	710.0	FURNACE WALL LEAKS
1/21/2013	FFO	87.22	710.0	CONTROLS AND INSTRUMENTATION
2/4/2013	PFO	8.80	63.0	AIR SUPPLY DAMPERS
2/5/2013	PMO	9.22	63.0	CONTROLS AND INSTRUMENTATION
2/6/2013	PMO	9.80	63.0	CONTROLS AND INSTRUMENTATION
2/7/2013	PFO	9.25	63.0	PULVERIZER FIRES
2/7/2013	PFO	0.83	91.2	PULVERIZER SYSTEM COAL LEAKS (NOT PULVERIZERS)
2/12/2013	PMO	7.92	305.0	CONTROLS AND INSTRUMENTATION
2/13/2013	PMO	7.53	305.0	CONTROLS AND INSTRUMENTATION
2/14/2013	PMO	8.82	91.0	CONTROLS AND INSTRUMENTATION
2/17/2013	PFO	3.77	58.1	PULVERIZER FEEDER MOTOR
2/19/2013	FMO	37.00	710.0	OTHER MAIN STEAM VALVES
2/24/2013	PFO	27.25	472.0	CONTROLS AND INSTRUMENTATION
3/10/2013	PFO	0.60	79.3	CONTROLS AND INSTRUMENTATION
3/12/2013	PMO	2.00	233.9	INVERTERS
3/16/2013	FFO	98.00	710.0	GEN. STATOR WINDINGS; BUSHINGS; AND TERMINALS
4/8/2013	PFO	1.00	90.9	PULVERIZER MILLS
4/9/2013	PFO	1.48	91.0	CONTROLS AND INSTRUMENTATION
4/9/2013	PFO	0.15	89.9	CONTROLS AND INSTRUMENTATION
4/9/2013	PFO	0.25	42.6	CONTROLS AND INSTRUMENTATION
4/18/2013	PMO	5.50	91.0	PULVERIZER FEEDER MOTOR
4/19/2013	PFO	0.50	48.3	PULVERIZER FEEDERS
4/19/2013	PFO	9.87	1.0	WET COAL (OMC)

Duke Energy Florida

ACTUAL UNIT EVENT DATA -- January - September 2013

Crystal River 5

Date	Outage Type	Hours	MW Affected	Description
4/20/2013	PFO	1.58	91.0	CONTROLS AND INSTRUMENTATION
4/28/2013	PFO	4.52	101.1	CONTROLS AND INSTRUMENTATION
5/5/2013	PFO	1.00	90.9	CONTROLS AND INSTRUMENTATION
5/15/2013	FFO	7.22	710.0	SWITCHYARD SYSTEM PROTECTION DEVICES
5/17/2013	PFO	4.50	15.0	WET COAL (OMC)
6/7/2013	FFO	53.70	710.0	OTHER MISCELLANEOUS GENERATOR PROBLEMS
6/19/2013	PMO	8.00	91.0	PULVERIZER FEEDERS
6/24/2013	PFO	4.50	91.0	PULVERIZER FEEDER MOTOR
7/2/2013	PFO	3.98	15.0	WET COAL (OMC)
7/2/2013	PFO	2.58	109.9	FOREIGN OBJECT IN MILL
7/10/2013	PFO	2.62	90.9	CONTROLS AND INSTRUMENTATION
7/29/2013	PMO	7.00	91.0	FOREIGN OBJECT IN MILL
8/2/2013	PFO	13.00	91.0	PULVERIZER INSPECTION
8/2/2013	PFO	5.00	120.8	CIRCULATING WATER PUMPS
8/14/2013	FFO	6.65	710.0	TURBINE SUPERVISORY SYSTEM
8/27/2013	PMO	3.43	472.0	OTHER STACK OR EXHAUST EMISSIONS TESTING - FOSSIL
8/27/2013	FMO	3.80	710.0	OTHER STACK OR EXHAUST EMISSIONS TESTING - FOSSIL
9/3/2013	PMO	8.60	91.0	FOREIGN OBJECT IN MILL
9/10/2013	PMO	7.00	234.0	FORCED DRAFT FANS
9/11/2013	PMO	7.17	234.0	FORCED DRAFT FANS
9/19/2013	PMO	7.30	63.0	INDUCED DRAFT FANS
9/24/2013	FFO	41.68	710.0	OTHER MISCELLANEOUS GENERATOR PROBLEMS

Duke Energy Florida

ACTUAL UNIT EVENT DATA -- January - September 2013

Hines 1

Date	Outage Type	Hours	MW Affected	Description
3/23/2013	PPO	507.80	207.0	MAJOR GAS TURBINE OVERHAUL
4/13/2013	PO	598.88	462.0	MAJOR GAS TURBINE OVERHAUL
5/8/2013	PPO	13.57	207.0	MAJOR GAS TURBINE OVERHAUL
5/8/2013	FFO	6.05	462.0	GAS TURBINE - INLET AIR VANES
5/8/2013	PPO	369.80	207.0	MAJOR GAS TURBINE OVERHAUL
6/4/2013	PFO	2.95	229.0	OTHER EXCITER PROBLEMS
6/22/2013	FFO	4.00	462.0	STEAM TURBINE CONTROL SYSTEM - HARDWARE PROBLEMS
6/25/2013	PMO	1.62	198.9	INTAKE GRATING FOULING
6/28/2013	FFO	17.00	462.0	4000-7000-VOLT CONDUCTORS AND BUSES
6/29/2013	PFO	25.63	229.0	4000-7000-VOLT CONDUCTORS AND BUSES
7/11/2013	PFO	19.00	58.0	MAIN TRANSFORMER
7/27/2013	PFO	30.30	228.0	GAS TURBINE - FIRE DETECTION AND EXTINGUISHING SYS
7/31/2013	PFO	6.00	228.0	GAS TURBINE - FIRE DETECTION AND EXTINGUISHING SYS
8/3/2013	PFO	10.98	228.0	GAS TURBINE - FIRE DETECTION AND EXTINGUISHING SYS
8/4/2013	PFO	4.90	228.0	GAS TURBINE - FIRE DETECTION AND EXTINGUISHING SYS
8/4/2013	PFO	0.83	227.9	OTHER EXCITER PROBLEMS
8/4/2013	PFO	20.10	228.0	GAS TURBINE - FIRE DETECTION AND EXTINGUISHING SYS
8/22/2013	PFO	8.70	327.0	FEEDWATER PUMP
8/25/2013	PMO	1.38	199.1	INTAKE GRATING FOULING
9/22/2013	PMO	69.97	228.0	ECONOMIZER LEAKS
9/25/2013	PMO	1.22	198.9	INTAKE GRATING FOULING

Duke Energy Florida

ACTUAL UNIT EVENT DATA -- January - September 2013

Hines 2

Date	Outage Type	Hours	MW Affected	Description
2/2/2013	PO	495.57	490.0	GAS TURBINE - BOROSCOPE INSPECTION
2/24/2013	FFO	5.07	490.0	GAS TURBINE - FIRE DETECTION AND EXTINGUISHING SYS
2/25/2013	FFO	121.33	490.0	GAS TURBINE - FIRE DETECTION AND EXTINGUISHING SYS
5/3/2013	FFO	18.40	490.0	UNIT AUXILIARIES TRANSFORMER
5/27/2013	FFO	8.43	490.0	CIRCULATING WATER PUMP MOTORS
6/1/2013	PMO	1.50	127.1	INTAKE GRATING FOULING
6/28/2013	FFO	23.55	490.0	4000-7000-VOLT CONDUCTORS AND BUSES
7/5/2013	PFO	1.00	336.1	CONDENSER LOSS OF VACUUM
7/6/2013	PFO	13.48	225.0	MAIN TRANSFORMER
7/18/2013	PFO	8.18	226.0	MAIN TRANSFORMER
9/5/2013	PFO	1.12	314.1	TURBINE HYDRAULIC SYSTEM PUMPS
9/7/2013	PMO	1.50	135.9	INTAKE GRATING FOULING

Duke Energy Florida

ACTUAL UNIT EVENT DATA -- January - September 2013

Hines 3

Date	Outage Type	Hours	MW Affected	Description
3/1/2013	PPO	112.93	228.0	MAJOR GAS TURBINE OVERHAUL
3/5/2013	PO	171.65	488.0	GAS TURBINE - BOROSCOPE INSPECTION
3/12/2013	PPO	634.87	228.0	MAJOR GAS TURBINE OVERHAUL
5/14/2013	PPO	8.87	125.0	CONDENSER TUBE AND WATER BOX CLEANING
7/16/2013	PFO	13.63	68.0	CIRCULATING WATER PUMP MOTORS
7/20/2013	FFO	40.45	488.0	TURBINE HYDRAULIC SYSTEM PUMPS
7/22/2013	PFO	3.43	387.1	TURBINE HYDRAULIC SYSTEM PUMPS
7/23/2013	FFO	3.13	488.0	STEAM TURBINE CONTROL SYSTEM - LOGIC PROBLEMS
9/16/2013	PMO	2.23	156.0	INTAKE GRATING FOULING

Duke Energy Florida

ACTUAL UNIT EVENT DATA -- January - September 2013

Hines 4

Date	Outage Type	Hours	MW Affected	Description
3/26/2013	FMO	9.10	472.0	INVERTERS
5/13/2013	FFO	13.02	472.0	CONDENSATE/HOTWELL PUMPS
5/23/2013	PPO	6.55	140.0	CONDENSER TUBE AND WATER BOX CLEANING
6/3/2013	PMO	1.22	140.0	INTAKE GRATING FOULING
6/25/2013	PMO	1.00	140.2	INTAKE GRATING FOULING
8/6/2013	PMO	2.38	100.0	INTAKE GRATING FOULING
9/16/2013	PMO	1.77	119.9	INTAKE GRATING FOULING
9/27/2013	FFO	3.15	472.0	GAS TURBINE CONTROL SYSTEM - HARDWARE PROBLEM