



Matthew R. Bernier
SENIOR COUNSEL

May 27, 2015

VIA ELECTRONIC FILING

Ms. Carlotta Stauffer, Commission Clerk
Florida Public Service Commission
2540 Shumard Oak Boulevard
Tallahassee, Florida 32399-0850

Re: Summary of Mulberry Cogen Event on May 14, 2015; Undocketed

Dear Ms. Stauffer:

Pursuant to FPSC Rule 25-17.086, "Periods During Which Purchases are Not Required," Duke Energy Florida (DEF) is providing notice to the Florida Public Service Commission that a DEF outage affected the Mulberry Cogen facility on May 14, 2015. The Mulberry Cogen facility is interconnected to the DEF transmission system at DEF's Mulberry substation. At approximately 1343 hours on May 14, 2015, an A-phase lightning arrester failed on the Mulberry substation bus #1 damaging two 69 kV potential transformers. The repair work at the Mulberry Substation was completed at approximately 2247 hours on May 14, 2015, when the event ended. Mulberry Cogen was notified when the repairs were complete and the unit resumed normal operation.

Thank you for your assistance in this matter. Should you have any questions, please feel free to call me at (850) 521-1428.

Sincerely,

/s/ Matthew R. Bernier

Matthew R. Bernier

MRB/db