

Review of Electric Utility Hurricane Preparedness and Restoration Actions

Docket No : 20170215-EU

Name : Michael Nichols

Electric Utility Provider : EI802 - Florida Power & Light Company

Zip Code : 34102

Category : Power restoration time

Comments : Repsonses to the Dec. 19, 2017 Memo from Wesley Taylor

Undergrounding of Electric Facilities questions 1 through 3:

1: The City of Naples Building Department has a policy which requires electrical service upgrades to be installed with underground feeders to the utility (FPL) point of connection.

Additionally, the City of Naples is assisting neighborhoods that are interested in creating special assessment districts to create funding for undergrounding their overhead electrical facilities.

2: The City of Naples Building Department has a policy which requires all electrical services for new construction, both residential and commercial, to be installed with underground feeders to the utility (FPL) point of connection.

3: The City of Naples Building Department has improved our method of communication with FPL for service connects, reconnects and overhead line issues from Fax Messages to Direct E-mail or Phone Contact with our FPL representatives for quicker response tim