

#### COVER LETTER FOR:

Re: Docket No. 20170215-EU - Review of electric utility hurricane preparedness and restoration actions.

# Third Data Request

## LAKELAND ELECTRIC (LE) RESPONSES **ARE IN RED**

Suzanne McCarthy, Planning Specialist 863-834-6321



501 E. Lemon St. + Lakeland, Florida 33801 Phone: 863.834.6300 + Fax: 863.834.6344

PSC Website: http://www.floridapsc.com

## STATE OF FLORIDA

COMMISSIONERS: ART GRAHAM, CHAIRMAN JULIE I. BROWN DONALD J. POLMANN GARY F. CLARK



Office of the General Counsel Keith C. Hetrick General Counsel (850)413-6199

# **Public Service Commission**

January 19, 2018

### STAFF'S THIRD DATA REQUEST

Via E-mail

To:

Municipal Group (<u>AZubaly@publicpower.com</u>)
Lee County (<u>dennie.hamilton@lcec.net</u>)
Cooperative Group (<u>mhershel@feca.com</u>)

Re: Docket No. 20170215-EU - Review of electric utility hurricane preparedness and restoration actions.

To Whom It May Concern:

By this letter, the Commission staff requests that each utility provide responses to the following data requests.

- 1. Please provide the following information for a specific example where storm hardened structures incurred damage and required repair or replacement due to Hurricane Irma.
  - a. A description of the damage incurred (i.e. broken pole, displaced underground vault, etc.).
    - No damaged to hardened facilities
  - b. A description of the repair process, including a description of any temporary repairs that required a follow-up trip.
    - No damaged to hardened facilities
  - c. A description of the repair process if the facilities had not been hardened.
    - There were 3 areas that impacted the sub-transmission system (69KV) each had a double circuit distribution systems attached that had not been hardened, but was slated to be in the near future. They were:
      - Polk City Rd. (24 poles total, 17 transmission poles and 6 mid-span lift distribution poles or adjacent poles)
      - o Gib-Galloway Rd. (4 poles)

o S98 at Winter Lake Rd. (2 pole).

Due to Hurricane Irma all 3 projects required a large scale effort to return power. The new standard to harden the system for these locations required steel poles. This would have taken a substantially longer time and required more equipment, so it was decided to wave the requirement in this emergency, due to the urgency of returning power to many customers affected as-soon-as possible.

It is the utility's goal to bring the 3 locations up to the new hardening standard as soon as possible.

Please file all responses electronically no later than February 19, 2018 from the Commission's website at <a href="www.floridapsc.com">www.floridapsc.com</a>, by selecting the Clerk's Office tab and Electronic Filing Web Form. Please contact me at <a href="wtaylor@psc.state.fl.us">wtaylor@psc.state.fl.us</a> or at 850.413.6175 if you have any legal questions, or contact Emily Knoblauch for technical questions at <a href="eknoblau@psc.state.fl.us">eknoblau@psc.state.fl.us</a> or at 850.413.6632.

Sincerely,

/s/Wesley Taylor

Wesley Taylor Attorney

WDT/as

cc: Office of Commission Clerk

Office of Public Counsel (kelly.jr@leg.state.fl.us, sayler.erik@leg.state.fl.us)