

21 West Church Street
Jacksonville, Florida 32202-3139

February 20, 2018



E L E C T R I C

W A T E R

S E W E R

Ms. Carlotta S. Stauffer
Commission Clerk
Florida Public Service Commission
2540 Shumard Oak Boulevard
Tallahassee, Florida 32399-0850

Docket No. 20170215-EU - Review of electric utility hurricane preparedness and restoration actions

Dear Ms. Stauffer:

Please find attached JEA's response to the FPSC Staff's Third Data Request for the referenced docket.

Please contact me at 904/509-0521 or via email kilgna@jea.com if you have further questions or need clarification.

We appreciate the opportunity to provide the information to the Commission.

Sincerely,

A handwritten signature in blue ink, appearing to read 'Nancy K. Veasey', is written over a circular stamp or seal.

Nancy K. Veasey
Director, Government Relations

cc: Wesley Taylor, Esq., FPSC, via email
Amy Zubaly, FMEA, via email

COMMISSIONERS:
ART GRAHAM, CHAIRMAN
JULIE I. BROWN
DONALD J. POLMANN
GARY F. CLARK

STATE OF FLORIDA



OFFICE OF THE GENERAL COUNSEL
KEITH C. HETRICK
GENERAL COUNSEL
(850) 413-6199

Public Service Commission

January 19, 2018

STAFF'S THIRD DATA REQUEST
Via E-mail

To:

Municipal Group (AZubaly@publicpower.com)
Lee County (dennie.hamilton@lcec.net)
Cooperative Group (mhershel@feca.com)

Re: Docket No. 20170215-EU - Review of electric utility hurricane preparedness and restoration actions.

To Whom It May Concern:

[JEA Response:](#)

By this letter, the Commission staff requests that each utility provide responses to the following data requests.

1. Please provide the following information for a specific example where storm hardened structures incurred damage and required repair or replacement due to Hurricane Irma.
 - a. A description of the damage incurred (i.e. broken pole, displaced underground vault, etc.). *Broken Pole due to a tree falling on the pole.*
 - b. A description of the repair process, including a description of any temporary repairs that required a follow-up trip. *When broken poles occur, very few can be repaired. JEA replaces broken poles with new poles. To replace the broken pole in Irma, the facilities (electric lines, transformers, switches, etc.) were removed from the broken pole and the pole was cut to insure there is no conflict with the new pole. A new pole was installed and the electric lines were re-attached to the new pole. A follow-up trip by JEA is needed to pull the old pole that was cut.*
 - c. A description of the repair process if the facilities had not been hardened. *Same process as above.*

Please file all responses electronically no later than February 19, 2018 from the Commission's website at www.floridapsc.com, by selecting the **Clerk's Office** tab and **Electronic Filing Web Form**. Please contact me at wtaylor@psc.state.fl.us or at 850.413.6175 if you have any legal questions, or contact Emily Knoblauch for technical questions at eknoblau@psc.state.fl.us or at 850.413.6632.

Sincerely,

/s/Wesley Taylor

Wesley Taylor
Attorney

WDT/as

cc: Office of Commission Clerk
Office of Public Counsel (kelly.jr@leg.state.fl.us, sayler.erik@leg.state.fl.us)