

State of Florida



Public Service Commission
CAPITAL CIRCLE OFFICE CENTER • 2540 SHUMARD OAK BOULEVARD
TALLAHASSEE, FLORIDA 32399-0850

-M-E-M-O-R-A-N-D-U-M-

DATE: June 14, 2018
TO: Carlotta S. Stauffer, Commission Clerk, Office of Commission Clerk
FROM: Art Graham, Chairman
RE: Docket 20170215-EU

Please place the attached document in docket file 20170215-EU, Review of Electric Utility Hurricane Preparedness and Restoration Actions. It contains proposed language that I will offer for the Commission's consideration at the June 19, 2018 Internal Affairs meeting, and I would like it to be available to the public now.

It modifies the staff's draft report by replacing the Executive Summary, moving hardening performance data to a new Section V created for that topic, along with additional data from the docket file, and makes other lesser revisions throughout the report.

It does not propose anything for the Conclusions section, which I anticipate the Commission will develop in the IA meeting.

Thank you.

RECEIVED-FPSC
2018 JUN 14 PM 4:59
COMMISSION
CLERK

Executive Summary

The Florida Public Service Commission (PSC or Commission) has broad authority over the adequacy and reliability of the state's electric transmission and distribution grids, as well as setting rates and all cost-recovery matters for investor-owned electric utilities (IOUs).

To promote strengthening of Florida's electric infrastructure following the intense 2004 and 2005 hurricane seasons, the Commission adopted extensive storm hardening initiatives, such as wooden pole inspection and replacement, to reduce the frequency and length of outages. The Commission ordered IOUs to file updated storm hardening plans for Commission review every three years. Those initiatives and the utilities' hardening plans have been the roadmap for aggressively improving resilience during the past 12 years.

There were no major storm landfalls in Florida until the four hurricanes of 2016-2017, making them the first opportunity to gather performance data from the programs.

On October 3, 2017, the Commission opened Docket No. 20170215-EU to review electric utility preparedness and restoration actions, and to identify potential areas where infrastructure damage, outages, and recovery time for customers could be minimized in the future. Commission staff issued several data requests to all utilities and sought input from non-utility stakeholders and customers, including a customer comments portal on the PSC website.

On May 2-3, 2018, the Commission held a workshop in which information was presented by utilities, customers and their representatives, and local governments.

Key findings

- Data collected during and after the storms show Florida's aggressive hardening programs work. The length of outages has been reduced markedly from the 2004-2005 storm seasons. (Page [_____](#))
- Hardened overhead facilities had substantially lower failure rates. (Page [_____](#))
- Underground facilities had minimal failure rates. (Page [_____](#))
- The three largest IOUs currently have 37.6% of distribution lines underground. Underground line is being added at an average rate of 440 miles per year. (Page [_____](#))
- Despite substantial, well documented improvement, customers were dissatisfied with the extent of outages and restoration times. The public's expectations are rising, indicating resilience and restoration will have to continually improve. (Page [_____](#))
- Years of trimming programs have controlled vegetation intruding into utilities' right of way, now the primary cause of outages is vegetation and other debris coming from outside the rights of way, where utilities typically don't have access to trim. (Page [_____](#))

- Restoration time estimates and customer communication issues caused significant additional dissatisfaction. (Page _____)
- Some local governments see a need for better coordination and communication with utilities during and after storms. (Page _____)

A more detailed description and analysis of the information collected are in the following pages. Consensus items describing the Commission's proposed actions and new policy initiatives can be found on page _____.

Section I: Background

In response to the intense impact that the 2004 and 2005 hurricanes had on the state, the 2006 Florida Legislature directed the Commission to “. . . conduct a review to determine what should be done to enhance the reliability of Florida’s transmission and distribution grids during extreme weather events, including the strengthening of distribution and transmission facilities.”

Based on its review of the 2004 and 2005 hurricane seasons, the Commission provided three recommendations in a 2007 report to the Legislature:¹ (1) maintain a high level of storm preparation; (2) strengthen the electric infrastructure to withstand severe weather events with the use of hardening activities; and (3) establish additional planning tools to identify and implement instances where undergrounding is appropriate as a means of storm hardening.

As discussed in the 2007 report to the Florida Legislature, “. . . the Commission has been careful to balance the need to strengthen the state’s electric infrastructure to minimize storm damage, reduce outages, and reduce restoration time while mitigating excessive cost increases to electric customers.

The 2006 Order

In 2006, after considering recommendations from the utilities on feasibility, the Commission ordered IOUs to inspect wooden poles every eight years to assure weakened ones are replaced, and to implement 10 storm preparedness initiatives:

- Three-year Vegetation Management Cycle for Distribution Circuits
- Audit of Joint-Use Attachment Agreements (shared use of poles with telecom)
- Six-year Transmission Structure Inspection Program
- Hardening of Existing Transmission Structures
- Development of Transmission and Distribution Geographic Information System
- Collection of Post-Storm Data and Forensic Analysis
- Collection of Detailed Outage Data Differentiating Between the Reliability Performance of Overhead and Underground Systems
- Increased Utility Coordination with Local Governments
- Collaborative Research on Effects of Hurricane Winds and Storm Surge
- Development of Natural Disaster Preparedness and Recovery Program Plans

¹ Report to the Legislature on Enhancing the Reliability of Florida’s Distribution and Transmission Grids During Extreme Weather, July 2007, <http://www.psc.state.fl.us/Files/PDF/Utilities/Electricgas/EnergyInfrastructure/UtilityFilings/docs/stormhardening2007.pdf>

The Commission also ordered electric utilities to file updated storm hardening plans every three years, and began annual Hurricane Season Preparation Workshops, which allow the IOUs, municipals, and cooperatives to share individual hurricane season preparation activities. These practices continue today.

Also in 2006, the Commission required Florida's local exchange telecommunications companies to implement inspections of their wooden poles.² The Commission's authority to impose that requirement was subsequently repealed in 2011 as part of a number of deregulatory changes made to Chapter 364, F.S.

2016-2017 Hurricanes

During September and October 2016, Florida was impacted by two hurricanes: Hermine and Matthew. In 2017, Hurricanes Irma and Nate impacted Florida. Hurricane Irma made landfall in Florida on September 10, 2017, as a Category 4 hurricane in Monroe County, followed by a second landfall as a Category 3 hurricane in Collier County, providing the first major test to the system since 2005.

On October 3, 2017, the PSC opened Docket No. 20170215-EU to identify potential areas where infrastructure damage, outages, and recovery time for customers could be minimized in the future. In order to identify these areas, Commission staff issued several data requests to all utilities in the areas of preparation, restoration practices, customer communication, outage causes, facility performance, meteorological data, and suggested improvements.

Commission staff also sought comments from non-utility stakeholders and customers. A summary of the non-utility stakeholders' comments are provided in Appendix A. On October 9, 2017, a customer portal was opened on the Commission's website, allowing customers to submit comments regarding their reaction to utility restoration/communication efforts. The portal was closed on May 1, 2018, with 701 customer comments and and 14 non-utility stakeholder comments received.

On May 2-3, 2018 the Commission held a workshop. Leading up to the workshop, staff provided topics for utilities to address, which included preparation and restoration processes, hardened vs. non-hardened facility performance, underground vs. overhead performance, impediments to restoration, customer/stakeholder communication, and suggested improvements based on lessons learned.

² Order No. PSC-06-0168-PAA-TL, issued March 1, 2006, in Docket No. 20060077-TL, *In re: Proposal to require local exchange telecommunications companies to implement ten-year wood pole inspection program.*

At the workshop, the following provided input:

- FPL
- DEF
- TECO
- GPC
- FPUC
- Florida Electric Cooperatives Association, Inc. (FECA)
- Florida Municipal Electric Association (FMEA)
- OPC
- Florida Industrial Power Users Group (FIPUG)
- Florida Retail Federation (FRF)
- City of Dunedin
- St. Johns County
- City of Monticello

All of the IOUs provided data at the workshop that showed hardened facilities performed better than non-hardened facilities. There were clearly fewer outages for underground than overhead circuits.

The utilities suggested improvements such as targeted undergrounding projects for certain lateral circuits, possible legislation to require inspections and hardening of non-electric utility poles, and additional coordination and communication regarding vegetation outside of the utilities' rights of way.

Non-utility stakeholders, including local governments, suggested increased coordination and more utility staffing at local EOCs.

Section II: Hurricane Preparedness Practices

Commission Role

No amount of preparation can eliminate outages in extreme weather events, so all utility regulators work to reduce and shorten outages.

In support of sharing individual hurricane preparation activities among IOUs, Municipals, and Cooperatives, the Commission has held annual Hurricane Season Preparation Workshops since 2006. The workshops provide an opportunity for electric utilities to discuss their storm preparation and restoration processes, coordination with local governments, and public outreach.

The Commission's Division of Engineering is responsible for staffing the Emergency Support Function 12 (ESF-12) in the State's Emergency Operations Center. ESF-12 coordinates with the electric and natural gas utilities operating in Florida to ensure the integrity of their energy supply systems are maintained during emergency situations. In this role, Commission staff also participates in an annual hurricane preparedness drill and other EOC related exercises.

The Commission provides information to consumers regarding storm preparedness, such as hurricane survival kits, portable generator safety, and ways to prepare your home before a storm. In the event of a storm, links to current Florida Division of Emergency Management information are highlighted on the PSC website (www.floridapsc.com), as well as links to the Federal Emergency Management Agency (FEMA) and the National Hurricane Center. The PSC issues statewide news releases at the beginning of each storm season regarding hurricane workshops, or Commission decisions on utility storm preparedness plans. All of this information is distributed via the PSC Twitter account (<https://twitter.com/floridapsc>) at appropriate times throughout the year.

Utility Preparedness and Storm Hardening Activities

Throughout the year, utilities participate in hurricane exercises and drills in order to better prepare for a storm event. Prior to hurricane season, utilities ensure that they have the required internal materials on hand, as well as commitments for external resources which may be needed following a storm. Utilities also partake in hurricane preparedness exercises and meetings with local governments and the state Emergency Operations Center, and they ensure that the proper critical facilities (i.e., hospitals, water and wastewater treatment plants, and fire stations) are identified.

The activities outlined in each IOUs' storm hardening plan vary to a degree; however, all are grounded in substantive strengthening and protection of the utility's electric facilities. Programs include tree trimming, pole inspections, hardening of feeders and laterals, and undergrounding.

Utilities typically focus hardening efforts on transmission facilities, as these can impact large numbers of customers. Hardening efforts are also prioritized for facilities that serve critical infrastructure, such as hospitals, first responders, water and wastewater treatment plants, and local EOCs. Such facilities are generally restored first following a storm event.

IOUs complete tree trimming of their distribution circuits, composed of laterals and feeders, in three- to six-year cycles. Feeders run outward from substations and have the capability of serving thousands of customers. Laterals branch from the feeder circuits and are the final portion of the electric delivery system, serving a smaller portion of customers, and are typically associated with residential areas.

Each year, IOUs trim a certain percentage of their total lateral and feeder miles as part of their hardening plans; however, the trees trimmed only include those that are in the utilities' rights of way. Most IOUs trim overhead feeder circuits over a three-year trim cycle, excluding TECO which is currently on a four-year trim cycle.³ For overhead laterals, IOUs must complete all trimming during a maximum six-year cycle.⁴

Table 2-1 below lists the number of miles trimmed that each IOU has completed for its feeder and lateral circuits since 2006. The number of miles provided includes planned tree trimming and may not include hot-spot or mid-cycle trimming. Hot-spot tree trimming occurs when crews are sent to specific areas that require unscheduled trimming due to rapid growth.

**Table 2-1.
Vegetation Clearing from Feeder and Lateral Circuits (in Miles)**

	DEF		FPL		FPUC		GPC		TECO	
	Feeders	Laterals	Feeders	Laterals	Feeders	Laterals	Feeders	Laterals	Feeders	Laterals
2006	723	2,703	10,094	825	-	-	-	-	268	840
2007	2,112	2,203	4,454	2,215	-	-	1,878	675	363	945
2008	708	2,544	4,262	2,078	59	86	274	821	374	806
2009	467	3,178	4,151	2,768	63	96	274	821	374	806
2010	787	4,139	5,222	2,741	65	84	281	1,060	617	1,634
2011	2,370	1,132	4,337	3,367	68	205	259	1,530	606	1,514
2012	196	3,228	4,045	3,703	52	123	240	857	435	1,282
2013	476	3,810	4,637	4,124	67	129	240	1,293	374	1,098
2014	3,297	2,782	4,249	3,685	52	145	241	1,294	465	1,161
2015	1,024	3,579	4,209	3,817	51	134	241	913	454	1,146
2016	1,016	2,173	4,418	3,745	62	188	241	331	386	926
2017	2,106	1,909	4,381	3,560	29	86	241	446	199	627

Source: IOUs' 2006-2017 distribution reliability reports.

As part of each IOUs' storm hardening plan, the Wooden Pole Inspection Program requires each utility to inspect and assess the strength of all of its installed wooden poles over an eight-year

³ Order No. PSC-12-0303-PAA-EI, issued June 12, 2012, in Docket No. 20120038-EI, *In re: Petition to modify vegetation management plan by Tampa Electric Company.*

⁴ Order No. PSC-07-0468-FOF-EI, issued May 30, 2007, in Docket No. 20060198-EI, *In re: Requirement for investor-owned electric utilities to file ongoing storm preparedness plans and implementation cost estimates.*

period. IOUs also have wooden pole replacement programs in place where a select number of existing poles are replaced with hardened poles. The National Electric Safety Code Extreme Wind Loading standards are used in designing replacement poles. Table 2-2 shows the number of wooden poles replaced from 2006 to 2017.

**Table 2-2.
Wooden Pole Replacement**

	DEF		FPL		FPUC		GPC	TECO	
	Trans.	Distr.	Trans.	Distr.	Trans.	Distr.	Distr.	Trans.	Distr.
2006	-	-	307	2,334	-	-	-	-	-
2007	956	1,130	1,471	8,164	-	-	185	494	1,536
2008	866	1,903	1,966	7,533	47	-	736	781	2,056
2009	704	3,018	3,206	7,342	34	-	969	713	1,640
2010	-	-	1,409	10,639	215	-	418	900	2,815
2011	635	2,887	1,559	9,942	215	-	1,060	1,060	3,328
2012	803	4,670	816	10,454	242	-	1,032	683	4,957
2013	1,347	5,722	1,106	13,639	135	-	380	866	6,572
2014	2,028	5,597	2,070	12,777	536	-	790	720	6,038
2015	1,738	8,420	1,888	15,089	382	-	676	649	5,392
2016	698	4,429	1,737	12,067	254	-	693	940	6,701
2017	530	2,654	1,934	8,486	-	-	746	-	-
Total	10,305	40,430	19,469	118,466	2,060	-	6,939	7,806	41,035

Source: Document Nos. 01516-2018, 01517-2018, 01518-2018, 01519-2018, 01520-2018, DEF's 2006-2017 distribution reliability reports.

In response to staff's data requests, the IOUs stated that the majority of recent underground projects were for new construction, rather than the conversion of overhead to underground. Since 2006, the installed underground facilities have increased by approximately 5,300 miles for the IOUs. The total amount of installed underground facilities during the past five years was approximately 2,200 miles.

The construction of underground electrical distribution systems, when compared with overhead systems, is more expensive. For construction of underground, the customer is responsible for the difference in the costs between underground and overhead, which often results in an installation barrier. Pursuant to Rules 25-6.0342 and 25-6.064, F.A.C., the costs and benefits of storm hardening are factored into the cost difference calculation for new construction or conversion to underground facilities, as reflected on each IOUs' tariff.

Storm Hardening Cost Recovery

While an IOU's storm hardening plan must be approved by the Commission, this does not guarantee an IOU the recovery of all incurred costs for the implementation of the plan. Storm hardening costs are addressed during an IOU's general rate case proceeding, and those costs are covered in base rates since they are considered a part of providing electric service in Florida.


During a general rate case, the costs for storm hardening are taken into consideration and the Commission makes a ruling on whether the costs are prudent. However, recent rate case proceedings have resulted in settlement agreements between the parties, and figures for storm hardening costs are not specified in the agreements.

Section III: Summary of 2016 and 2017 Storms

Hurricane Hermine

Hurricane Hermine made landfall on September 2, 2016, near Wakulla and Jefferson counties. Hurricane Hermine was a Category 1 hurricane when it made landfall, primarily affecting the Big Bend area. Figure 3-1 illustrates the path of Hurricane Hermine, and the areas that experienced tropical storm and hurricane force winds. The National Hurricane Center defines tropical storm force winds as winds between 39 miles per hour (mph) to 73 mph. Winds that are equal to or exceeding 74 mph are defined as hurricane force winds.

Figure 3-1.
Hurricane Hermine – Tropical Storm and Hurricane Force Winds



Source: NOAA's National Hurricane Center

Wind, rainfall, and storm surge data was requested from IOUs, Municipals, and Cooperatives for each hurricane. A total of 36 utilities provided data and the maximum reported sustained winds, wind gusts, rainfall, and storm surge for Hurricane Hermine, summarized in Appendix C. The three counties that experienced some of the highest sustained winds and wind gusts from

Hermine were Jefferson, Madison, and Taylor. These counties also received high levels of rainfall; however, the two counties with the largest amounts of rainfall were Manatee and Sarasota. These two counties did not rank highest for any other category, and appear to be outliers in the reported weather data. The reason for the large amount of rain experienced in Manatee and Sarasota counties may have been due to strong storm bands that hit that part of the state. The three counties that had the largest storm surges were Dixie, Taylor, and Wakulla. All of these counties, with the exception of Manatee and Sarasota, were located in the area where Hurricane Hermine made landfall.

Table 3-1 provides the five counties with the highest number of outages for Hurricane Hermine. This outage data was reported to the state EOC by IOUs, Municipals, and Cooperatives at set intervals of reporting times. The percentages of accounts without power were calculated based on the peak number of customer accounts without power divided by the total number of customer accounts for that county, which includes IOUs, Municipals, and Cooperatives customers. The total peak percentage of accounts in the state without power was approximately 3 percent for Hurricane Hermine. Appendix B provides a comprehensive list of the peak number of customer accounts by county that were without power for each hurricane.

**Table 3-1.
Hurricane Hermine – Five Counties with Highest Maximum Outages**

	Max. Account Outages	Max. Percent of Account Outages
Hamilton	5,864	87.9%
Jefferson	5,762	71.5%
Lafayette	2,965	71.5%
Madison	7,278	69.0%
Wakulla	14,009	93.0%


Source: State EOC power outage reports.

The outages for Jefferson, Madison, and Wakulla counties correlate to the reported weather data as they were among the counties that experienced the highest winds, rainfall, and storm surges. Wind data was not reported for Hamilton and Lafayette counties, though they both received large amounts of rainfall.

Hurricane Matthew

While Hurricane Matthew never made landfall in Florida; it passed along Florida’s east coast shoreline, where some areas experienced sustained hurricane force winds. Hurricane Matthew began as a Category 4 hurricane on October 7, 2016, but weakened and later became a Category 2 hurricane northeast of Jacksonville Beach on October 8, 2016. Figure 3-2 illustrates the path of Hurricane Matthew, and the areas that experienced tropical storm and hurricane force winds.

**Figure 3-2.
Hurricane Matthew – Tropical Storm and Hurricane Force Winds**



Source: NOAA's National Hurricane Center

Wind speed, rainfall, and storm surge data for Hurricane Matthew is contained in Appendix D. The three counties that experienced some of the highest sustained winds and wind gusts for Hurricane Matthew were Brevard, St. Johns, and Volusia. From the reported rainfall data, the counties with the three highest amounts of rainfall were Brevard, Indian River, and St. Lucie. The three counties that had the largest storm surges were Flagler, Nassau, and St. Johns. All of these counties are located on Florida's east coast and correspond to the path of storm. Table 3-2 provides the five counties with the highest number of outages for Hurricane Matthew. The total peak percentage of customer accounts in the state without power was 11 percent.

**Table 3-2.
Hurricane Matthew – Five Counties with Highest Maximum Outages**

	Max. Account Outages	Max. Percent of Account Outages
Flagler	57,016	100.0%
Indian River	59,244	67.2%
Putnam	27,393	66.8%
St. Johns	78,610	89.6%
Volusia	257,718	92.0%


Source: State EOC power outage reports.

The outages for Flagler, Indian, St. Johns, and Volusia counties correlate to the reported weather data as they were among the counties that experienced the highest winds, rainfall, and storm surges. Rainfall data was not reported for Putnam County; however, it is located next to St. Johns County, which experienced severe weather conditions.

Hurricane Irma

Hurricane Irma was the first major hurricane to make landfall in Florida since the 2004 and 2005 hurricane seasons. On September 10, 2017, Hurricane Irma made landfall in the Florida Keys as a Category 4 hurricane and weakened to a Category 3 hurricane as it made a second landfall near Marco Island, Florida on the same day. The storm continued to weaken as it moved over Florida, affecting all 67 counties in the state and resulting in widespread power outages. Figure 3-3 illustrates the path of Hurricane Irma, and the areas that experienced tropical storm and hurricane force winds.

Figure 3-3.
Hurricane Irma – Tropical Storm and Hurricane Force Winds



Source: NOAA's National Hurricane Center

Wind speed, rainfall, and storm surge data for Hurricane Irma is contained in Appendix E. The three counties that experienced the highest maximum sustained winds for Hurricane Irma were Collier, Monroe, and Polk. The largest amount of rainfall was reported for Bradford, Hillsborough, and St. Lucie counties. The three counties that had the largest maximum storm surge were Collier, Monroe, and Nassau. Due to the path of Hurricane Irma, many of the southernmost counties, such as Monroe and Collier, experienced high winds and storm surges, while parts of central Florida had large amounts of rain. Additionally, parts of northeast Florida, such as Nassau County, experienced high winds and storm surges due to the outer bands and the path of the storm.

Table 3-3 provides the five counties with the highest number of outages for Hurricane Irma. The total peak percentage of customer accounts in the state without power was 62 percent.

**Table 3-3.
Hurricane Irma – Five Counties with Highest Maximum Outages**

	Max. Account Outages	Max. Percent of Account Outages
Hardee	11,976	97.4%
Hendry	18,750	100.0%
Highlands	62,010	99.3%
Nassau	43,740	97.6%
Okeechobee	21,990	96.5%


Source: State EOC power outage reports.

The outages for Nassau County correlate to the reported weather data as it was among the counties that experienced high storm surges. Okeechobee, Hardee, Henry, and Highlands counties are in close proximity to one another and are located in south Florida, near Hurricane Irma’s landfall. All of these counties experienced wind gusts over 100 mph and all but Okeechobee recorded over 10 inches of rainfall.

Hurricane Nate

On October 7, 2017, Florida was impacted by a second storm, Hurricane Nate, which made its first landfall at the mouth of the Mississippi River as a Category 1 hurricane, followed by a second landfall near Biloxi, Mississippi on the same day. While Hurricane Nate did not make landfall in Florida, parts of the panhandle were impacted by the hurricane. Figure 3-4 illustrates the path of Hurricane Nate, and the areas that experienced tropical storm and hurricane force winds.

**Figure 3-4.
Hurricane Nate – Tropical Storm and Hurricane Force Winds**



Source: NOAA's National Hurricane Center

Wind speed, rainfall, and storm surge data for Hurricane Nate is contained in Appendix F. The impact of Hurricane Nate was much smaller in scope compared to the previous three hurricanes. The three counties that experienced the highest sustained winds, wind gusts, and rainfall were Escambia, Okaloosa, and Santa Rosa. The three counties that had the highest storm surges were Escambia, Franklin, and Santa Rosa. All of these counties are located in Florida's panhandle, close to where Hurricane Nate made landfall. Table 3-4 provides the five counties with the highest number of outages for Hurricane Nate. The total peak percentage of accounts in the state without power was 0.1 percent.

**Table 3-4.
Hurricane Nate – Five Counties with Highest Maximum Outages**

	Max. Account Outages	Max. Percent of Account Outages
Escambia	5,384	3.4%
Holmes	77	0.7%
Okaloosa	6,382	5.9%
Santa Rosa	1,712	2.2%
Walton	613	1.0%

Source: State EOC power outage reports.

The outages for Escambia, Okaloosa, and Santa Rosa counties correlate to the reported weather data as they were among the counties that experienced some of the highest winds, rainfall, and storm surges. While Walton County did not have the highest reported winds and rainfall, it experienced high winds comparable to Okaloosa County, as well as receiving several inches of rain. Wind data was not reported for Holmes County; however, it is located in the panhandle area near Okaloosa and Walton counties.

Section IV: Review of Outage Restoration Activities

Restoration Process

The restoration process is a year-round activity. Many utilities across the state engage in exercises that simulate storms in order to better prepare for an actual hurricane or other significant weather event.

In an actual hurricane, utilities may initiate pre-staging meetings and activities as early as 240 hours before landfall, which may include requests for mutual aid. Utilities communicate with county EOCs to identify critical facilities (i.e., hospitals, water and wastewater treatment plants, and fire stations) and coordinate on other restoration activities.

Before a storm makes landfall, an assessment of potential damage is completed by utilities based on the forecasted path of the storm. This information can be used to determine if mutual aid and additional material resources should be requested.

As the storm approaches, repair activities will continue until winds reach 35-40 miles per hour, at which time crews will be called back for a stand-down period. Once winds drop below 35-40 miles per hour and weather conditions are considered to be safe following a storm, utility crews are re-deployed to continue the restoration process.

Once the storm has passed, a post-storm damage assessment is completed, where utilities can establish what facilities have been damaged, refine restoration time estimates, manage workloads, and allocate resources to where they are needed.

Restoration begins with repairs to generation plants and transmission facilities that sustained damage, followed by repairs to substations and feeders. Substations and feeders that power critical infrastructure are prioritized first in order to get those necessary facilities back in service.

Feeders that serve the largest number of customers are restored next, and finally laterals that serve neighborhoods with fewer customers are repaired and restored. Overall, utilities strive to restore as many customers as possible in the shortest amount of time.

Based on a review of the utility presented data for each hurricane, no abnormalities were identified between storms for the restoration process. Hurricane Irma affected the entire state and was the first significant test of Florida's electric infrastructure since the 2004 and 2005 hurricane season. For simplification purposes, and due to the size and scope of the storm, the following subsections on restoration, outage causes, mutual aid, and impediments are specific to Hurricane Irma only. Data from other storms was used for comparison purposes to determine if there were any anomalies or unique circumstances.


Hurricane Irma Restoration

Florida’s utilities managed more than 27,000 crews in the aftermath of Hurricane Irma. The rate of restoration was fairly rapid, 50 percent of customers restored in one day, with comparable results for all utilities.

Using outage data reported to the Florida Division of Emergency Management (DEM), Figure 4-1 provides the number of customer accounts without power in proportion to the total state caused by Hurricane Irma.

The peak outages occurred on September 11, 2017, with approximately 62 percent of all customers in the state without power. Five days following this peak, the number of outages dropped to approximately 11 percent. On September 20, 2017, 10 days following the outage peak, the percent of customer accounts without power dropped below 1 percent.

Figure 4-1.
Hurricane Irma – Daily Maximum Percent of Florida’s Customers without Power




Source: State EOC power outage reports.

Note: Individual utility outage maximums occurred at different times and do not add to the total.

Figure 4-2 provides the affected customers that were without power from Hurricane Irma. Following the peak outages on September 11, the proportion of affected customers without power was below 50 percent by September 14. By September 20 the number of customers without power dropped to 2 percent. For several utilities, once the number of customers without power dropped to 2 percent or less, the utility stopped reporting outages to the DEM as these outages could be unrelated to the storm event.

Figure 4-2.
Hurricane Irma – Daily Maximum Percent of Affected Customers without Power



Source: State EOC power outage reports.

Note: Individual utility outage maximums occurred at different times and do not add to the total.

Overall, Figures 4-1 and 4-2 illustrate that the graphs for IOUs are similar in shape to the Municipals and Cooperatives, demonstrating comparable power restoration achievements for the different utility groups. No irregularities were observed in the data.

During the May 2018 workshop, FPL provided a comparison of outage data and restoration times for Hurricanes Wilma and Irma. As seen in Table 4-1, it took one day to restore power to

50 percent of FPL’s customers for Hurricane Irma, while FPL reported it took five days for Hurricane Wilma. Restoring all customers took 10 days after Hurricane Irma, and it took 18 days after Hurricane Wilma.

Also at the workshop, TECO provided a comparison of time to complete restoration after Hurricanes Irma (7 days) and Jeanne (11 days).

No other utility provided a similar comparison. While each storm is different and presents its own set of difficulties, the data show restoration times have decreased markedly compared to previous storms.

**Table 4-1.
FPL – Outage and Restoration Data for Hurricanes Wilma and Irma**

	Wilma	Irma
Customer outages	3.2M	4.4M
Staging sites	20	29
% Restored / days	50% / 5	50% / 1
All restored (days)	18	10
Avg. days to restore	5.4	2.1

Source: FPL’s presentation at the May 2, 2018, Commission Workshop.

Outage Causes

Data collected from 39 utilities identified that the biggest source of outages was vegetation issues. Many utilities described that these issues were from fallen trees or branches that were outside of the utilities’ rights of way. Additional trimming by the utilities within their rights of way would not eliminate these vegetation related outages. It should also be noted that typical hardening projects are designed and constructed to withstand extreme wind loads, not fallen trees.

The second most prevalent outage cause was from embedded severe weather events, such as tornadoes, microbursts, and flooding.

Mutual Aid

Many mutual aid agreements among IOUs throughout the country are managed by seven Regional Mutual Assistance Groups (RMAGs). Florida’s IOUs are members of the Southeastern Electric Exchange RMAG. RMAGs facilitate the process of identifying available restoration workers and help coordinate the logistics to help with restoration efforts.

IOUs that are in RMAGs follow guidelines established by the Edison Electric Institute (EEI), and also establish additional guidelines that aid in the communication process and rapid mobilization and response efforts.

If needed, utilities in one RMAG will assist those in another region.⁵ EEI also communicates regularly with the associations that serve Municipals and Cooperatives during major outage incidents, providing a process for electric companies to request support from other electric companies that have not been affected by major outage events.⁶

Section 252.40, F.S., Mutual Aid Arrangements, authorizes the governing body of each political subdivision of the state, “to develop and enter into mutual aid agreements within the state for reciprocal emergency aid and assistance in case of emergencies too extensive to be dealt with unassisted.” It also provides that, “[s]uch agreements shall be consistent with the state comprehensive emergency management plan and program, and in time of emergency it shall be the duty of each local emergency management agency to render assistance in accordance with the provisions of such mutual aid agreements to the fullest possible extent.”

The American Public Power Association (APPA), together with state and regional public power utilities and organizations, coordinate the mutual aid network for the nation’s public power utilities. These utilities have local, state, and regional contracts and agreements for mutual aid, and there is a national mutual aid agreement with over 2,000 public power and rural electric cooperatives so they are able to assist one another when needed.

In addition to helping public power utilities in need, public power utilities also provide mutual aid to cooperatives and to IOUs when requested and have also received assistance from cooperatives and IOUs when needed. Mutual aid played a key role in restoring the power quickly after Hurricane Irma. Public power utilities and IOUs aided one another in the restoration efforts.⁷

Prior to Hurricane Irma making landfall, many utilities made requests for mutual aid. Based on information from the state EOC, a total of 49 utilities received mutual aid. Information on the number of crew managers and crews managed, which includes both utility and mutual aid crews, was requested from utilities.

Table 4-2 illustrates the large number of crews that were managed by a limited number of experienced managers. From the 47 utilities that responded to staff’s data request, the average experience level of the crew managers was 25 years. This demonstrates the level of expertise that is required to coordinate large recovery efforts, particularly in regard to mutual aid crews that are unfamiliar with local terrain, the transmission and distribution systems, and procedures specific to each utility.

Considering the large number of mutual aid crews that were brought in to assist with power restoration, the number of injuries was low and there were no fatalities. Of the total 103 injuries, 38 were reported for utility personnel and 65 were reported for mutual aid personnel.

⁵ Miles Keogh and Sharon Thomas, NARUC Grants and Research, *Regional Mutual Assistance Groups: A Primer* (November 2015).

⁶ Edison Electric Institute, *Understanding the Electric Power Industry’s Response and Restoration Process* (October 2016).

⁷ APPA letter to U.S. House Energy & Commerce Committee, Subcommittee on Energy (November 1, 2017).

**Table 4-2.
Hurricane Irma – Utility Coordination, Injuries, and Fatalities**

	Managers	Crews Managed	Meals	Injuries	Fatalities
IOU	48	22,398	1,409,352	76	0
Municipals	96	1,935	109,266	13	0
Cooperatives	104	3,295	171,803	14	0
Total	248	27,628	1,690,421	103	0

Impediments to Restoration

Data was collected from 39 utilities on the primary impediments that were identified for Hurricane Irma. Consistent with prior hurricanes, the biggest impediment to restoration was clearing vegetation, much of which was debris from fallen trees or branches that were outside of the utilities’ rights of way.

Other impediments to restoration unique to Hurricane Irma were roadway congestion and lack of motor fuel availability due to the size and scale of evacuations. Therefore, utility crews that were tasked to aid in power restoration for various areas were delayed by some fuel shortages and traffic congestion on the roadways.

Storm Restoration Cost Recovery

Storm hardening costs (Section II), incurred to generally make the system less vulnerable, are covered by the rates the utility is authorized to charge. Storm restoration costs, incurred in response to a specific storm, are addressed differently and are not covered by normal rates.

Following Hurricane Andrew in 1992, which radically changed the availability and cost of commercial insurance, IOUs requested that the Commission allow for alternative risk mitigation for storm damage. The Commission considered various forms of storm cost risk mitigation for the IOUs and settled on a three part approach:

- A storm damage reserve
- An annual storm accrual
- A provision to seek recovery of costs that exceed the storm damage reserve balance

Under the three-part system, cost recovery of storm related damage is typically addressed through a storm damage reserve, a surcharge, or a combination of the two.

The annual accrual spreads cost over a long period to build a reserve dedicated to storm expenses. Once the storm reserve reaches a target value, the accrual can be suspended. The reserve alleviates consumer rate shock, either by entirely absorbing the cost of lesser storm damage, or at least diminishing the cost impact of major storms that may exceed the reserve

balance. When the reserve is depleted, typically it is replenished through a small amount added to monthly bills.

In order to define what type of costs can be recovered, the Commission adopted Rule 25-6.0143, F.A.C., which specifies that only incremental costs – those above the normal costs that are covered by rates – can be charged to the storm reserve or recovered in a storm cost recovery proceeding. The largest incremental storm cost categories typically include repair materials, added payroll/overtime, contracted crews, travel, housing, and food.

As outlined in recent settlement agreements, in the event that the storm reserve is depleted from a major storm or multiple storms, or if a utility does not have a storm reserve, an IOU can request an interim storm surcharge, added to rates for a specific period based on an estimate, pending a thorough accounting.

The Commission docket the matter for a formal process to determine actual eligible costs when they are available.

Revenues collected with the interim storm charge are then compared to the total actual amount of storm restoration costs determined to be eligible. Expenses that exceed what the interim charge generated are recovered in rates, or excess interim charge revenues are flowed back to customers.

Section V: Storm Hardening Performance

Analyzing infrastructure performance is inherently problematic because conditions vary widely among storms, and among different times and locations within the same storm. However, Hurricane Irma's very large footprint, which spread extreme weather conditions across multiple IOUs' service territories throughout the Florida peninsula, provided a very large sample that tends to offset those variables. This section focuses on Hurricane Irma outcomes.

Although the sample was large, data collection was limited due to urgency and tumultuous conditions during storm restoration. With a decade having passed since the Commission's 2006 storm order, the IOUs report they were focused on restoring service as rapidly as possible and it was not feasible to collect data as called for in the order. In part, the performance data had to be reconstructed after the fact, not all the contemplated data is available, and much of it is based on differing methodologies and sometimes not comparable among utilities.

The 2016-2017 experience suggests the next step is more complete and standardized data collection in future storms, which will allow a deeper analysis of the circumstances under which hardening and undergrounding are most beneficial. However, the Hurricane Irma data provides a broad performance comparison of non-hardened overhead, hardened overhead, and underground facilities.

Outage Performance

FPL, the state's largest utility, was able to report outage rates of Irma-impacted facilities broken out by non-hardened, hardened, and underground facilities. The results showed across its system hardening overhead lines resulted in fewer outages, and underground lines suffered minimal outages.

Transmission

20% Overhead, non-hardened
16% Hardened overhead
0% Underground

Feeders

82% Overhead, non-hardened
69% Hardened overhead
18% Underground

Laterals

24% Overhead (not specified)
4% Underground

Source: Second Supplemental Amended Response, Staff First Data Request, No. 29, dated 4/25/18

Infrastructure performance

Hardening overhead facilities also resulted in lower rates of pole failure, and failure rates of underground facilities were even lower, across all three of Florida's largest IOUs. (Gulf Power Company's territory was not materially affected by Hurricane Irma, and FPUC's territory would provide a very small data sample.) Note that poles are the unit of measurement for non-hardened vs hardened overhead data, while overhead vs. underground figures are miles of circuit.

Florida Power & Light

Non-hardened vs hardened overhead

Transmission poles

	Poles total	Replaced/repared
Overhead, non-hardened	5,991	5
Hardened overhead	60,694	0

Non-hardened vs hardened overhead

Distribution poles

	Poles total	Replaced/repared
Overhead, non-hardened	1,063,684	2,834
Hardened overhead	124,518	26

Overhead vs underground

Transmission circuits in miles

	Total miles	Replaced/repared
Overhead	6,857	0.1
Underground	105	0

Overhead vs underground

Distribution circuits in miles

	Total miles	Replaced/repared
Overhead	42,301	443.0
Underground	25,818	12.5

Source: FPL worksheets dated 4/27/18

Duke Energy Florida

Non-hardened vs hardened overhead

Transmission poles

	Poles total	Replaced/repaired
Overhead, non-hardened	21,285	139
Hardened overhead	29,499	0

Non-hardened vs hardened overhead

Distribution poles

No data available.

Overhead vs underground

Transmission circuits in miles

	Total miles	Replaced/repaired
Overhead	5,139	0
Underground	69.83	0

Overhead vs underground

Distribution circuits in miles

	Total miles	Replaced/repaired
Overhead	17,993	324.0
Underground	14,140	4.3

Source: Duke worksheets filed 4/27/18

Tampa Electric

Non-hardened vs hardened overhead

Transmission poles

	Poles total	Replaced/repaired
Overhead, non-hardened	5,834	15
Hardened overhead	19,447	2

Non-hardened vs hardened overhead

Distribution poles

	Poles total	Replaced/repaired
Overhead, non-hardened	199,880	145
Hardened overhead	63,120	20

Overhead vs underground
Transmission circuits in miles

	Total miles	Replaced/repaired
Overhead	5,307	0
Underground	27	0

Overhead vs underground
Distribution circuits in miles

	Total miles	Replaced/repaired
Overhead	19,104	24.8
Underground	7,915	0.1

Source: TECO worksheets filed 4/25/18

It should be noted that while underground facilities fared particularly well during Hurricane Irma, they also are susceptible. The damage may be caused by uprooted trees and flooding, and the repairs to such facilities typically take longer to complete

Forensic Analysis

As part of their storm hardening plans, as required by the 2006 order, IOUs conduct post-storm forensic analyses which review storm-related data and assess damaged facilities that did not perform as designed. Following a review of the storm damage data, which typically takes several months, a report is issued outlining the findings of the review.

For Hurricane Irma, FPL, DEF, and TECO completed a forensic analysis to evaluate the performance of their facilities during the storm. GPC and FPUC indicated that forensic analyses were not completed due to a lack of significant damage or determined that all damage was caused by vegetation.

DEF provided five forensic analysis reports related to failures of wooden distribution poles, wooden transmission poles, and a transmission tower. In the forensic report on the steel transmission tower that fell during Hurricane Irma, the failure was identified as corrosion at the base of the tower. DEF's forensic reports also identified 27 wooden transmission pole failures due to high winds, with wood rot contributing to some of the failures.

FPL provided a post-storm forensic review for Hurricane Irma, which identified five wooden transmission pole failures caused by wind only.

TECO's forensic analysis identified three leaning structures following Hurricane Irma, and at the workshop, TECO reported that it had ten transmission structure failures.

Section VI: Customer Communication

Public preparedness is critical during natural disasters. The utilities and the Commission provide information to consumers regarding storm preparedness, such as hurricane survival kits, portable generator safety, and ways to prepare a home before a storm.

Following a storm, customers are provided various methods to communicate with utilities. Customers can report a power outage to the utility through various means such as interactive voice response systems, customer call centers, the utility’s website, mobile applications, and the PSC.

Communication issues were a notable source of customer dissatisfaction during Hurricane Irma. Customers particularly complained of inaccurate restoration projections and unavailability of overwhelmed utility websites and apps.

A total of 41 utilities provided data on the number of customer representatives that were utilized during Hurricanes Hermine, Matthew, Irma, and Nate. This information is summarized in Table 5-1, which includes third-party representatives.

Table 5-1.
Total Number of Utility and Third-Party Customer Contact Representatives

	Hermine	Matthew	Irma	Nate
IOUs	948	1,825	2,418	106
Municipals	300	571	1,059	48
Cooperatives	163	84	297	6
Total	1,411	2,480	3,774	160

Source: Utilities’ responses to staff’s first data request, No. 14.

Table 5-2 provides the number of customer contacts for Hurricanes Hermine, Matthew, Irma, and Nate. Customer contacts may include various forms of communication, including phone, email, mobile application, utility website, and social media.

Table 5-2.
Total Customer Contacts

	Hermine	Matthew	Irma	Nate
IOUs	395,358	3,605,174	11,424,246	30,545
Municipals	71,302	414,202	1,634,438	0
Cooperatives	53,804	12,053	207,488	343
Total	520,464	4,031,429	13,266,172	30,888

Source: Utilities’ responses to staff’s first data request, No. 15.

Table 5-3 provides the average number of customer contacts that were handled by each utility and third-party customer contact representatives. For Hurricane Irma, an average number of 2,513 customer contacts per representative, which demonstrates the large scale of communication that occurred between customers and the electric utilities.

**Table 5-3.
Average Number of Customer Contacts per Utility Representative⁸**

	Hermine	Matthew	Irma	Nate
IOUs	628	1,776	2,513	332
Municipals	138	774	1,061	0
Cooperatives	439	84	796	57

Source: Utilities' responses to staff's first data request, Nos. 14 and 15.

Public Comments to the PSC

Following the establishment of Docket No. 20170215-EU, a customer portal was opened on the Commission's website on October 9, 2017, allowing customers to submit comments regarding their reaction to utility restoration/communication efforts.


The portal provided consumers four categories to select from, as well as the option to submit written comments, where consumers could address any specific concerns. The four categories that consumers could select from were:

- Power restoration time.
- Information provided by electric utility provider prior to the storm.
- Information provided by electric utility provider after the storm.
- Other.

⁸ It should be noted that this average includes only utilities that were affected by a storm.

Figure 5-1 provides a timeline of the number of comments received through the PSC Consumer Comment Portal.

**Figure 5-1.
PSC Portal – Timeline of Consumer Comments Received**



Source: PSC Consumer Comment Portal

For the month of October the PSC received 319 comments, which mostly related to consumers' experiences and feedback during Hurricane Irma. Comments focused on frustration with timely communication, inaccurate estimated restoration times, and tree trimming.

Comments decreased after October, but there was a small swell of comments from December 28, 2017, to January 12, 2018, when consumers expressed concerns about the potential addition of a surcharge to customer bills as a result of the hurricane.

From February 16 to February 22, 2018, a total of 303 comments were received, which were predominantly focused on supporting and encouraging the use of distributed solar generation. The portal was closed on May 1, 2018, with a total of 701 public comments received.

Staff collected and sorted the comments by category and divided them into subcategories based on whether the comment was negative, positive, or neutral. Table 5-4 provides a summary of the comments that were received.

Table 5-4.
PSC Portal – Customer Comments

Category	Comments
Power Restoration Time	345
Information Provided Prior to the Storm	14
Information Provided After the Storm	69
Other	273
Total	701
Positive vs. Negative Comments	
Negative Comments on Electric Utility	346
Positive Comments on Electric Utility	74
Not Expressed	281
Total	701

Source: PSC Consumer Comments Portal

Table 5-5 provides the number of comments received for IOUs, Municipals and Cooperatives. Two of the customer comments did not provide the names of their electric utilities.

Table 5-5.
PSC Portal – Customer Comments by Utility Type

Utility Type	Comments
Investor Owned Electric Utility	616
Municipal Electric Utility	48
Cooperative Electric Utility	35
Not Specified	2
Total	701

Source: PSC Consumer Comments Portal

The most prevalent topics were related to supporting and encouraging the use of distributed solar generation, cost responsibility for restoration, frustration with communication, tree trimming, and effectiveness of storm hardening.

Table 5-6 provides the number of comments that were received for each of these topics.

Table 5-6.
PSC Portal – Most Prevalent Topics Discussed in Customer Comments

Subcategory	Comments	Percent of Total
Support and encouragement of solar	258	37%
Cost responsibility for restoration	105	15%
Frustration with timely communications	84	12%
Tree trimming	73	10%
Effectiveness of hardening	60	9%

Despite the wide-spread impact of Hurricane Irma on the state and the number of customers that were affected, the number of comments the Commission received was nominal.

Stakeholder Comments to the PSC

In addition to comments from utilities and customers, staff also solicited comments from non-utility stakeholders, which included Associated Industries of Florida, the Florida Chamber of Commerce, Florida Association of Counties, and Florida League of Cities. Appendix A provides a summary of the stakeholder comments that the Commission received.

A total of 14 stakeholders provided comments on the topics of vegetation management, undergrounding, and coordination and communications.

For vegetation management, the comments mainly focused on improving communication between stakeholders and utilities on where and when tree trimming occurs, as well as better educating the public on tree trimming.

While the comments on undergrounding varied, many voiced a positive position on undergrounding, though stakeholders expressed differences in opinion on cost responsibility.

Last, the comments on coordination and communication largely concentrated on more involvement from utilities at local EOCs, in addition to improving post-event information and power restoration time estimates.

Aside from the suggested areas of improvement mentioned, the overall comments that stakeholders provided were positive.