



Matthew R. Bernier  
Associate General Counsel

April 22, 2022

**VIA ELECTRONIC FILING**

Adam Teitzman, Commission Clerk  
Florida Public Service Commission  
2540 Shumard Oak Boulevard  
Tallahassee, Florida 32399-0850

Re: *Fuel and purchased power cost recovery clause with generating performance incentive factor;*  
*Docket No. 20220001-EI*

Dear Mr. Teitzman:

Please find enclosed for electronic filing on behalf of Duke Energy Florida, LLC ("DEF"), the Request for Confidential Classification regarding the Direct Testimony of Anthony Salvarezza and Exhibit No. \_\_\_ (AS-1), Exhibit No. \_\_\_ (AS-2), and Exhibit No. \_\_\_ (AS-3). The filing includes the following:

- DEF's Request for Confidential Classification
- Slip-sheet for confidential Exhibit A
- Redacted Exhibit B (two copies)
- Exhibit C (justification matrix), and
- Exhibit D (affidavit of Anthony Salvarezza)

DEF's confidential Exhibit A that accompanies the above-referenced was submitted with DEF's Notice of Intent to Request Confidential Classification on April 1, 2022, under separate cover.

Thank you for your assistance in this matter. Please feel free to call me at (850) 521-1428 should you have any questions concerning this filing.

Respectfully,

*s/Matthew R. Bernier*

---

Matthew R. Bernier

MRB/mw  
Enclosures

BEFORE THE FLORIDA PUBLIC SERVICE COMMISSION

---

In re: Fuel and purchased power cost  
recovery clause with generating performance  
incentive factor.

---

Docket No. 20220001-EI

Dated: April 22, 2022

**DUKE ENERGY FLORIDA LLC'S  
REQUEST FOR CONFIDENTIAL CLASSIFICATION**

Duke Energy Florida, LLC (“DEF” or “Company”), pursuant to Section 366.093, Florida Statutes (F.S.), and Rule 25-22.006, Florida Administrative Code (F.A.C.), submits this Request for Confidential Classification for certain information provided in the Direct Testimony of Anthony Salvarezza and Exhibit No. \_\_\_ (AS-1), Exhibit No. \_\_\_ (AS-2) and Exhibit No. \_\_\_ (AS-3), dated April 1, 2022, concurrently with DEF’s Notice of Intent to Request Confidential Classification. This Request is timely. *See* Rule 25-22.006(3)(a)1, F.A.C. In support of this Request, DEF states:

1. The Direct Testimony of Anthony Salvarezza and Exhibit No. \_\_\_ (AS-1), Exhibit No. \_\_\_ (AS-2) and Exhibit No. \_\_\_ (AS-3), contain information that is “confidential proprietary business information” under Section 366.093(3), Florida Statutes.

2. The following exhibits are included with this request:

(a) Sealed Composite Exhibit A is a package containing unredacted copies of all the documents for which DEF seeks confidential treatment. Composite Exhibit A was submitted separately in a sealed envelope labeled “CONFIDENTIAL” on April 1, 2022. In the unredacted versions, the information asserted to be confidential is highlighted in yellow.

(b) Composite Exhibit B is a package containing two copies of redacted versions of the documents for which the Company requests confidential classification. The specific

information for which confidential treatment is requested has been blocked out by opaque marker or other means.

(c) Exhibit C is a table which identifies by page and line the information for which DEF seeks confidential classification and the specific statutory bases for seeking confidential treatment.

(d) Exhibit D contains affidavits attesting to the confidential nature of information identified in this request.

3. As indicated in Exhibit C, the information for which DEF requests confidential classification is “proprietary confidential business information” within the meaning of Section 366.093(3), F.S. Specifically, the information at issue in the Direct Testimony of Anthony Salvarezza and Exhibit No. \_\_\_(AS-1), Exhibit No. \_\_\_(AS-2) and Exhibit No. \_\_\_(AS-3), relates to proprietary third-party drawings, evaluations, and information. Pursuant to contracts, DEF is obligated to maintain the confidentiality of this information, and therefore it qualifies for confidential classification. The disclosure of this information could adversely affect the Company’s ability to contract on favorable terms. *See* § 366.093(3)(d), F.S.; Affidavit of Anthony Salvarezza at ¶¶ 4 and 5. Furthermore, disclosure of the information could detrimentally impact DEF’s ability to negotiate favorable contracts, thereby harming its competitive interests, ultimately to its customers’ detriment. *See* § 366.093(3)(e), F.S.; Affidavit of Anthony Salvarezza at ¶¶ 4 and 5. Accordingly, such information constitutes “proprietary confidential business information” which is exempt from disclosure under the Public Records Act pursuant to Section 366.093(1), F.S.

4. The information identified as Exhibit “A” is intended to be and is treated as

confidential by the Company. *See* Affidavit of Anthony Salvarezza at ¶ 6. The information has not been disclosed to the public, and the Company has treated and continues to treat the information at issue as confidential. *See* Affidavit of Anthony Salvarezza at ¶ 6.

6. DEF requests that the information identified in Exhibit A be classified as “proprietary confidential business information” within the meaning of section 366.093(3), F.S., that the information remain confidential for a period of at least 18 months as provided in section 366.093(4) F.S., and that the information be returned as soon as it is no longer necessary for the Commission to conduct its business.

WHEREFORE, for the foregoing reasons, DEF respectfully requests that this Request for Confidential Classification be granted.

RESPECTFULLY SUBMITTED this 22<sup>nd</sup> day of April, 2022.

*s/Matthew R. Bernier*  
**DIANNE M. TRIPLETT**  
Deputy General Counsel  
299 1<sup>st</sup> Avenue North  
St. Petersburg, Florida 33701  
T: (727) 820-4692  
F: (727) 820-5041  
E: [dianne.triplett@duke-energy.com](mailto:dianne.triplett@duke-energy.com)

**MATTHEW R. BERNIER**  
Associate General Counsel  
T: (850) 521-1428  
E: [matthew.bernier@duke-energy.com](mailto:matthew.bernier@duke-energy.com)  
**STEPHANIE A. CUELLO**  
Senior Counsel  
106 East College Avenue, Suite 800  
Tallahassee, Florida 32301  
T: (850) 521-1425  
F: (727) 820-5041  
E: [Stephanie.Cuello@duke-energy.com](mailto:Stephanie.Cuello@duke-energy.com)  
[FLRegulatoryLegal@duke-energy.com](mailto:FLRegulatoryLegal@duke-energy.com)

Attorneys for Duke Energy Florida, LLC

## CERTIFICATE OF SERVICE

Docket No. 20220001-EI

I HEREBY CERTIFY that a true and correct copy of the foregoing has been furnished via email this 22<sup>nd</sup> day of April, 2022, to all parties of record as indicated below.

s/Matthew R. Bernier

Attorney

|  |   |
|--|---|
| <p>Suzanne Brownless<br/>Stefanie Jo Osborn<br/>Office of General Counsel<br/>FL Public Service Commission<br/>2540 Shumard Oak Blvd.<br/>Tallahassee, FL 32399-0850<br/><a href="mailto:sbrownle@psc.state.fl.us">sbrownle@psc.state.fl.us</a><br/><a href="mailto:sosborn@psc.state.fl.us">sosborn@psc.state.fl.us</a></p> <p>J. Wahlen / M. Means<br/>Ausley McMullen<br/>P.O. Box 391<br/>Tallahassee, FL 32302<br/><a href="mailto:jwahlen@ausley.com">jwahlen@ausley.com</a><br/><a href="mailto:mmeans@ausley.com">mmeans@ausley.com</a></p> <p>Kenneth A. Hoffman<br/>Florida Power &amp; Light Company<br/>134 W. Jefferson Street<br/>Tallahassee, FL 32301-1713<br/><a href="mailto:ken_hoffman@fpl.com">ken_hoffman@fpl.com</a></p> <p>Jon C. Moyle, Jr.<br/>Moyle Law Firm, P.A.<br/>FIPUG<br/>118 North Gadsden Street<br/>Tallahassee, FL 32301<br/><a href="mailto:jmoyle@moylelaw.com">jmoyle@moylelaw.com</a><br/><a href="mailto:mqualls@moylelaw.com">mqualls@moylelaw.com</a></p> <p>Peter J. Mattheis<br/>Michael K. Lavanga<br/>Joseph R. Briscar<br/>Stone, Mattheis, Xenopoulos, &amp; Brew P.C.<br/>Nucor<br/>1025 Thomas Jefferson Street, NW<br/>Eighth Floor, West Tower<br/>Washington, DC 20007<br/><a href="mailto:pjm@smxblaw.com">pjm@smxblaw.com</a><br/><a href="mailto:mkl@smxblaw.com">mkl@smxblaw.com</a><br/><a href="mailto:jrb@smxblaw.com">jrb@smxblaw.com</a></p> <p>Corey Allain<br/>Nucor Steel Florida, Inc.<br/>22 Nucor Drive<br/>Frostproof, FL 33843<br/><a href="mailto:corey.allain@nucor.com">corey.allain@nucor.com</a></p> | <p>Anastacia Pirrello / Richard Gentry<br/>Office of Public Counsel<br/>111 W. Madison St., Room 812<br/>Tallahassee, FL 32399-1400<br/><a href="mailto:pirrello.anastacia@leg.state.fl.us">pirrello.anastacia@leg.state.fl.us</a><br/><a href="mailto:gentry.richard@leg.state.fl.us">gentry.richard@leg.state.fl.us</a></p> <p>Paula K. Brown<br/>Regulatory Affairs<br/>Tampa Electric Company<br/>P.O. Box 111<br/>Tampa, FL 33601-0111<br/><a href="mailto:regdept@tecoenergy.com">regdept@tecoenergy.com</a></p> <p>Maria Moncada / David Lee<br/>Florida Power &amp; Light Company<br/>700 Universe Blvd. (LAW/JB)<br/>Juno Beach, FL 33408-0420<br/><a href="mailto:david.lee@fpl.com">david.lee@fpl.com</a><br/><a href="mailto:maria_moncada@fpl.com">maria_moncada@fpl.com</a></p> <p>James Brew / Laura W. Baker<br/>Stone Mattheis Xenopoulos &amp; Brew, P.C.<br/>White Springs/PCS Phosphate<br/>1025 Thomas Jefferson St., N.W.<br/>Eighth Floor, West Tower<br/>Washington, DC 20007<br/><a href="mailto:jbrew@smxblaw.com">jbrew@smxblaw.com</a><br/><a href="mailto:lwb@smxblaw.com">lwb@smxblaw.com</a></p> <p>Mike Cassel<br/>Florida Public Utilities Company<br/>208 Wildlight Avenue<br/>Yulee, FL 32097<br/><a href="mailto:mcassel@fpuc.com">mcassel@fpuc.com</a></p> <p>Michelle D. Napier<br/>Florida Public Utilities Company<br/>1635 Meathe Drive<br/>West Palm Beach, FL 33411<br/><a href="mailto:mnapier@fpuc.com">mnapier@fpuc.com</a></p> <p>Beth Keating<br/>Gunster, Yoakley &amp; Stewart, P.A.<br/>FPUC<br/>215 South Monroe Street, Suite 601<br/>Tallahassee, FL 32301<br/><a href="mailto:bkeating@gunster.com">bkeating@gunster.com</a></p> |
|--|---|

# **Exhibit A**

**“CONFIDENTIAL”**

**(filed under separate cover on April 1, 2022)**

# **Exhibit B**

**REDACTED**

**(two copies)**

# REDACTED

1 outages and steps to mitigate the risk of further outages, and ultimately to explain  
2 how the Company has at all times acted reasonably and prudently.

3  
4 **Q. Please provide a summary of your testimony.**

5 A. My testimony explains the reasonableness and prudence of DEF's decisions and  
6 actions in relation to discovery of latent damage to the Bartow Combined Cycle  
7 ("Bartow CC") Combustion Turbine Generators ("CTGs") and the resulting outages,  
8 given the information known or reasonably knowable by DEF at the time those  
9 decisions were made and those actions were taken. Moreover, I explain how DEF  
10 prudently operated the CTGs at all times, including during the period when DEF  
11 now believes the damage to the units was initiated, and therefore that DEF's  
12 operation of the units did not initiate the damage to the units – a conclusion fully  
13 supported by the Original Equipment Manufacturer's ("OEM") root cause analysis.  
14 Finally, I explain that the CTG damage and outages currently at issue are completely  
15 unrelated to the Commission's previous determination of imprudence related to the  
16 operation of the Bartow Steam Turbine.

17 As I explain in detail below, as a result of standard maintenance testing, DEF first  
18 learned in March 2020 that one of the Bartow CTGs (Unit 4B) was damaged by  
19 [REDACTED] years earlier. Because the temperature  
20 alarms were never triggered, DEF could not have known of the issue during this  
21 period of operation, which ended after the OEM replaced a degraded component  
22 within the CTGs. During this period, DEF followed the OEM-provided operation



# REDACTED

- 1 • Exhibit No. \_\_ (AS-1), Root Cause Analysis (Confidential);
- 2 • Exhibit No. \_\_ (AS-2), Siemens Product Bulletin PB-08-5038-GN-EN-01
- 3 [REDACTED] (Confidential); and
- 4 • Exhibit No. \_\_ (AS-3), Siemens Product Bulletin PB3-13-0008-GN-EN-01
- 5 [REDACTED]
- 6 [REDACTED] (Confidential).

7 These exhibits are the property of Siemens Energy, Inc., and are designated as  
8 proprietary and confidential by Siemens. Therefore, DEF is seeking confidentiality  
9 to protect the third-party's interest in these materials.

## 11 Background

12 **Q. Can you please provide a summary and timeline of events relating to the Bartow**  
13 **CTG outages?**

14 A. Yes. The Bartow CC came online in summer 2009. There are four (4) Combustion  
15 Turbines ("CT") attached to Siemens model SGen6-1000A Combustion Turbine  
16 Generators ("CTG"). During planned outages in fall 2012 and spring 2013, DEF  
17 performed an inspection of the [REDACTED] consistent with guidance provided  
18 by Siemens Product Bulletin PB-08-5038-GN-EN-01 (Exhibit No. \_\_ (AS-2)) and  
19 later updated by PB3-13-0008-GN-EN-01 (Exhibit No. \_\_ (AS-3)). DEF discovered  
20 the [REDACTED] were degraded and, consistent with the OEM's guidance, contracted  
21 with Siemens to install upgrades.

22 As I explain below, unbeknownst to DEF, operation of the CTGs with the degraded  
23 [REDACTED] ultimately led to a series of outages impacting each of the CTGs: Unit 4B

# REDACTED

1 separate RCA was unnecessary when similar damage led to forced outages of Units  
2 4A and 4C. That is, the same equipment and operating conditions were present in  
3 all four CTGs for the same duration, and therefore the resulting damage discovered  
4 on Unit 4B was considered likely to develop on the other units at some unknown  
5 point in the future. However, it was also clear that the damage DEF suspected had  
6 been initiated, if it existed at all, had not propagated to the same degree on Units 4A,  
7 4C, and 4D at that time.<sup>1</sup>

8  
9 **Q. Please provide an overview of the Root Cause Analysis for the outages.**

10 A. The outages were caused by stator bar failures. Despite the fact the temperatures of  
11 the stator core windings never triggered the OEM established RTD alarm, the stator  
12 bar failures were most likely initiated by [REDACTED]  
13 [REDACTED]  
14 [REDACTED]. The RCA determined the “main contributor” to the [REDACTED]  
15 [REDACTED] was [REDACTED]  
16 [REDACTED] which led to a period  
17 of operation at higher temperature levels than the [REDACTED]. The units’  
18 normal load cycling [REDACTED]  
19 [REDACTED]  
20 [REDACTED]

---

<sup>1</sup> The other units had each recently underwent the same maintenance hipot test at the same voltage levels and passed without any findings or engineering concerns (Unit 4A, 2019; Unit 4C, 2018; and Unit 4D, 2019).

# REDACTED

1  
2  
3  
4  
5  
6  
7  
8  
9  
10  
11  
12  
13  
14  
15  
16  
17  
18  
19  
20  
21  
22

[REDACTED]

[REDACTED].

**Q. Can you please elaborate on the RCA findings?**

A. Yes. As mentioned above, in the fall 2019, in advance of return to service from a planned outage, maintenance high potential (hi-pot) testing on Unit 4B indicated stator winding faults on the CTG. Further investigation revealed two stator winding bars of two different phases had faulted to ground [REDACTED]

[REDACTED]

Forensic analysis determined the [REDACTED]

[REDACTED]

[REDACTED]

[REDACTED] Finally, the OEM established the “main contributor” to the [REDACTED] as [REDACTED]

[REDACTED]

[REDACTED] Exhibit No. \_\_ (AS-1), p. 1.

What all this means is that the faulted stator bars resulted from [REDACTED]

[REDACTED]

[REDACTED]. This failure mode naturally led to the question of what led to the relatively [REDACTED].

The OEM analyzed the operational life of the unit to confirm or refute as many as eleven (11) secondary level elements. Its review of data noted that the stator slot

# REDACTED

1 temperatures dropped in early 2013, while the generator output (MW and MVAR)  
2 remained stable. It further found:

3 [REDACTED]  
4 [REDACTED]  
5 [REDACTED]  
6 [REDACTED]  
7 [REDACTED]  
8 [REDACTED]  
9 [REDACTED]  
10 [REDACTED]  
11 [REDACTED]

12 *Id.* at p. 20.

13 Thus, the OEM recognized that the [REDACTED] were a  
14 symptom of the degraded [REDACTED]. When the [REDACTED] were replaced with  
15 an upgrade, the operating temperature was reduced to the lower operating range  
16 while generator output remained consistent (i.e., the [REDACTED]  
17 were not a symptom of the units being run outside of the OEM's established  
18 operating parameters). However, unbeknownst to DEF at the time, the [REDACTED]

19 [REDACTED]

20 [REDACTED]. *See id.*  
21 at p. 24.

22  
23 **Q. Why did the Company conclude that similar damage was likely to have**  
24 **occurred at the other Bartow CTGs?**

25 A. The Company reasoned that, because the other three (3) CTGs operated at similar  
26 temperatures for a similar period of time (prior to receiving the same upgrades), it

# REDACTED

1 was likely that they had also suffered damage to the stator bars that would eventually  
2 require remediation – though it was unknown when that time would be.

3  
4 **Q. Did the stator winding temperatures observed during the 2009-2013 timeframe**  
5 **provide any basis for concern?**

6 A. No. The stator winding temperature is monitored by an RTD alarm that alerts the  
7 Company if the stator winding temperature exceeds the OEM recommended  
8 threshold. The OEM alarm is based on [REDACTED]  
9 [REDACTED], giving an alarm around [REDACTED] and unload at  
10 approximately [REDACTED], depending on specific ambient conditions on a particular day.  
11 It is important to note the alarm set-points allow for engineered operating margins  
12 built into generator design; for example, the alarm set-point of [REDACTED] is more than  
13 [REDACTED] below the IEEE-established failure point for Class F Insulation (the type of  
14 insulation at issue) of 311°F (155°C). The point being, given the information  
15 reasonably available to DEF during the 2009-2013 timeframe, according to the  
16 indicated stator RTD temperatures the insulation remained well below its  
17 temperature rating at all times. In fact, in 2013 when Siemens performed the [REDACTED]  
18 [REDACTED] replacement discussed above, it inspected the end windings and main leads  
19 and found no signs of over-heating.

20  
21 **Q. Has DEF's and the OEM's understanding of the actual operating temperatures**  
22 **experienced during the 2009-2013 timeframe changed?**

1 A. Yes, based on the findings of the RCA, the OEM and DEF now believe that the [REDACTED]  
2 [REDACTED]  
3 [REDACTED]  
4 [REDACTED]  
5 [REDACTED]

6 [REDACTED]. *See id.* at pp. 19-21, 23. However, as discussed above, because  
7 the Bartow CTGs never triggered the RTD alarms, and because those alarms were  
8 set at a point that provided approximately [REDACTED] of margin before reaching the  
9 insulation’s IEEE-established temperature rating, DEF had no way of knowing the  
10 temperature likely exceeded the rating limit and no reason for concern or to seek  
11 comparison with the remainder of Siemens’ fleet.

12  
13 **Q. Did DEF operate the Bartow CTGs within the operating parameters**  
14 **established by the OEM?**

15 A. Yes, at all times DEF operated the units consistent with the OEM’s instructions as  
16 provided in the operating manual. DEF reviewed the units’ operating history in Pi  
17 data from 2010 to the 2012/2013 outages when the [REDACTED] upgrade was performed.  
18 The data, which was sampled on an hourly basis, showed zero instances of operating  
19 the generators outside the OEM ratings as defined on the generator capability curve  
20 provided in that manual.

21 Specifically, the generators have a maximum capability of [REDACTED] MW and the  
22 operating history shows the maximum output of any of the four (4) generators was  
23 213 MW. At this output of 213 MW, the allowable reactive power (MVAR) rating

# REDACTED

1 is [REDACTED] MVAR - the maximum MVAR output actually generated across this time  
2 period was 83 MVAR (as MW load decreases, the MVAR allowable increases). The  
3 table below provides the maximum MW and both maximum and minimum MVAR  
4 output of the four (4) CTGs over the period in question.  
5

| <i>Unit</i> | <i>Max MW</i> | <i>Max MVAR</i> | <i>Min MVAR</i> |
|-------------|---------------|-----------------|-----------------|
| <i>4A</i>   | <i>211</i>    | <i>80</i>       | <i>-77</i>      |
| <i>4B</i>   | <i>209</i>    | <i>71</i>       | <i>-71</i>      |
| <i>4C</i>   | <i>210</i>    | <i>77</i>       | <i>-73</i>      |
| <i>4D</i>   | <i>213</i>    | <i>83</i>       | <i>-75</i>      |

6  
7 Furthermore, the RCA shows that the OEM did not identify operation of the CTGs  
8 outside of their preapproved operating parameters as the cause of the damage to Unit  
9 4B. The RCA determined that the main contributing cause of the stator bar damage  
10 was [REDACTED]  
11 [REDACTED] which led to increased [REDACTED]  
12 [REDACTED], but again, the OEM-established RTD temperature alarm was  
13 never triggered. The RCA also shows that after the degraded [REDACTED] were  
14 replaced in 2012 and 2013, the [REDACTED]  
15 [REDACTED] while the generator output (MW and MVAR) remained stable.  
16 *See id.* at p. 20 & Fig. 16.

17 In short, DEF operated the CTGs within the OEM's defined operating parameters;  
18 hence, DEF's operation was not the cause of [REDACTED] and

1 therefore not the cause of the damage to the units. Instead, the degraded [REDACTED],  
2 which DEF replaced in accordance with OEM recommendations once it discovered  
3 the issue, [REDACTED] and caused the [REDACTED].  
4

5 **DEF's Actions to Prudently Mitigate the Risk of Failure**

6 **Q. What steps did DEF take to prudently manage the likelihood of damage at the**  
7 **remaining units?**

8 A. Once DEF learned the cause of Unit 4B's damage and the likelihood that the  
9 remaining units may have experienced similar damage, the Company took several  
10 proactive steps to evaluate the remaining units, monitor unit operations to detect  
11 damage propagation (to the extent possible), and ultimately remediate the likelihood  
12 of damage to the remaining units. First, DEF reconfigured the Electromagnetic  
13 Signature Analysis ("EMSA") collars on Units 4A and 4C<sup>2</sup> to potentially identify  
14 insulation degradation during continued operation.<sup>3</sup> Second, DEF scheduled  
15 borescope inspections on Units 4A and 4C to look for any visual indications of  
16 buckled insulation.<sup>4</sup> Third, DEF issued procurement specifications in anticipation  
17 of a bid event for a spare set of stator bars to have on hand in case of an in-service  
18 failure or failed indicative testing of one of the remaining CTGs. Finally, DEF  
19 scheduled generator rewinds for the remaining units, notwithstanding that a rewind  
20 would not typically be required for thousands of equivalent operating hours.

---

<sup>2</sup> As noted above, Units 4A and 4D underwent hipot testing in spring and fall 2019, respectively, resulting in no negative findings or engineering concerns.

<sup>3</sup> DEF previously relocated the EMSA collars on Units 4B and 4D in fall 2019.

<sup>4</sup> Unit 4D was thoroughly inspected in fall 2019 (when the Unit 4B damage was discovered), so a borescope inspection was unnecessary.



# REDACTED

1 stator rewind for Unit 4A was scheduled for the fall 2023 planned major outage, and  
2 the stator rewind for Unit 4C was scheduled for the fall 2024 planned major outage.  
3 This schedule was intended to allow DEF to take advantage of previously scheduled  
4 outages in a measured cadence to avoid concurrent CTG outages (maximizing output  
5 from the remainder of the plant by allowing for operation in 3 on 1 configuration),  
6 to minimize the number of planned outages by performing multiple maintenance  
7 tasks during the same outages, and to provide time for the OEM to manufacture the  
8 stator bars and support the outages.

9 In an effort to prudently address and mitigate the risks to the other units suggested  
10 by the Unit 4B RCA, while also attempting to retain the benefits of Bartow's low-  
11 cost generation for customers by spacing the scheduling of planned major outages,  
12 DEF scheduled these stator rewinds to occur much earlier in the units' operating life  
13 than the Duke Energy fleet standard recommendation of [REDACTED] equivalent hours  
14 for this type of air-cooled unit. Specifically, Unit 4D was planned for a rewind at  
15 ~103,000 equivalent hours, Unit 4A at ~109,000 equivalent hours, and Unit 4C at  
16 ~116,000 equivalent hours.

17  
18 **Q. Was DEF able to maintain the schedule of proactive outages discussed above?**

19 A. No, Unit 4A experienced an unexpected in-service failure in January 2021 that  
20 required a forced outage lasting into April 2021; as discussed above, due to the  
21 nature of the suspected damage and the limitations on available testing, DEF could  
22 not have anticipated when such a failure may occur (if at all). As a result of this  
23 outage, DEF accelerated the scheduled Unit 4C planned outage up to fall 2023.

# REDACTED

1 However, shortly after Unit 4A's return to service, Unit 4C also experienced an in-  
2 service failure in May 2021.

3  
4 **Q. Did these unexpected occurrences further alter DEF's plan?**

5 A. Yes. Given the two in-service failures in a short period of time, DEF determined  
6 that this new information required a strategy shift. Therefore, the Company  
7 accelerated the planned outage of Unit 4D from spring 2022 to June 2021. DEF  
8 completed the stator rewinds and returned Units 4C and 4D to service in November  
9 and October 2021, respectively.

10  
11 **Q. You indicated that the two forced outages in a short period of time was "new  
12 information" that led to DEF's strategy change. Given that DEF determined  
13 in March 2020 that there was a likelihood of latent damage to the remaining  
14 units, how did the in-service failures constitute "new information"?**

15 A. The new information I was referring to is the speed at which the [REDACTED],  
16 which was thought but not definitively known to exist, was propagating on the  
17 remaining units notwithstanding operation within the OEM-provided parameters and  
18 the normal fleet operating temperatures. Recall that DEF became aware of the main  
19 contributing cause of the damage to Unit 4B in March 2020. At that time, the units  
20 had been operating for approximately seven (7) years after the [REDACTED] is  
21 believed to have occurred without an in-service failure known to have resulted from  
22 the damage identified in the RCA; that is, DEF had only its experience and did not  
23 have any means to formulate a trend or projection for when subsequent failures may

1 plant). Said differently, the prior order concerned operation of the Bartow Steam  
2 Turbine and contained no discussion regarding the operation of the CTGs. In fact,  
3 the Commission specifically noted “that this case is highly fact specific and for that  
4 reason will have limited precedential value.”<sup>5</sup>

## 6 Conclusion

### 7 **Q. In your opinion, has DEF acted prudently?**

8 A. Yes. First, as I have explained above, the Company’s operation of the units did not  
9 initiate the damage to the units, rather it was a function of [REDACTED] that  
10 the Company simply could not have contemporaneously known about. When DEF  
11 later determined the damage was likely present on the other units, it was confronted  
12 with a lack of information about: a) whether the other units (or some subset of those  
13 units) were actually damaged, and if so to what degree; and b) if the units were  
14 damaged, at what point the damage would be identifiable via available testing or  
15 when the units may experience a failure. Given this dearth of information, DEF  
16 made the reasonable decision to continue operating the units (benefitting customers  
17 by the continued generation of low-cost energy) and prudently took steps intended  
18 to mitigate the risk of future in-service failure. What we now know, but could not  
19 have known at the time, was the relatively short period in which the hypothesized  
20 damage would manifest. As I have explained above, as the Company learned  
21 additional facts, it prudently incorporated the new information into its analysis and  
22 made reasonable adjustments where possible. When making operations decisions in

---

<sup>5</sup> Order No. PSC-2020-0368A-FOF-EI, at p. 22.

Duke Energy Florida, LLC  
Docket No. 20220001  
Witness: Salvarezza  
Exhibit No. \_\_\_\_ (AS-1)

**REDACTED**  
Pages 1 through 26  
are confidential in their entirety.

Duke Energy Florida, LLC  
Docket No. 20220001  
Witness: Salvarezza  
Exhibit No. \_\_\_\_ (AS-2)

REDACTED  
Pages 1 through 6  
are confidential in their entirety.

Duke Energy Florida, LLC  
Docket No. 20220001  
Witness: Salvarezza  
Exhibit No. \_\_\_\_ (AS-3)

REDACTED  
Pages 1 through 6  
are confidential in their entirety.

# REDACTED

1 outages and steps to mitigate the risk of further outages, and ultimately to explain  
2 how the Company has at all times acted reasonably and prudently.

3  
4 **Q. Please provide a summary of your testimony.**

5 A. My testimony explains the reasonableness and prudence of DEF's decisions and  
6 actions in relation to discovery of latent damage to the Bartow Combined Cycle  
7 ("Bartow CC") Combustion Turbine Generators ("CTGs") and the resulting outages,  
8 given the information known or reasonably knowable by DEF at the time those  
9 decisions were made and those actions were taken. Moreover, I explain how DEF  
10 prudently operated the CTGs at all times, including during the period when DEF  
11 now believes the damage to the units was initiated, and therefore that DEF's  
12 operation of the units did not initiate the damage to the units – a conclusion fully  
13 supported by the Original Equipment Manufacturer's ("OEM") root cause analysis.  
14 Finally, I explain that the CTG damage and outages currently at issue are completely  
15 unrelated to the Commission's previous determination of imprudence related to the  
16 operation of the Bartow Steam Turbine.

17 As I explain in detail below, as a result of standard maintenance testing, DEF first  
18 learned in March 2020 that one of the Bartow CTGs (Unit 4B) was damaged by  
19 [REDACTED] years earlier. Because the temperature  
20 alarms were never triggered, DEF could not have known of the issue during this  
21 period of operation, which ended after the OEM replaced a degraded component  
22 within the CTGs. During this period, DEF followed the OEM-provided operation

# REDACTED

- 1 • Exhibit No. \_\_ (AS-1), Root Cause Analysis (Confidential);
- 2 • Exhibit No. \_\_ (AS-2), Siemens Product Bulletin PB-08-5038-GN-EN-01
- 3 [REDACTED] (Confidential); and
- 4 • Exhibit No. \_\_ (AS-3), Siemens Product Bulletin PB3-13-0008-GN-EN-01
- 5 [REDACTED]
- 6 [REDACTED] (Confidential).

7 These exhibits are the property of Siemens Energy, Inc., and are designated as  
8 proprietary and confidential by Siemens. Therefore, DEF is seeking confidentiality  
9 to protect the third-party's interest in these materials.

## 11 Background

12 **Q. Can you please provide a summary and timeline of events relating to the Bartow**  
13 **CTG outages?**

14 A. Yes. The Bartow CC came online in summer 2009. There are four (4) Combustion  
15 Turbines ("CT") attached to Siemens model SGen6-1000A Combustion Turbine  
16 Generators ("CTG"). During planned outages in fall 2012 and spring 2013, DEF  
17 performed an inspection of the [REDACTED] consistent with guidance provided  
18 by Siemens Product Bulletin PB-08-5038-GN-EN-01 (Exhibit No. \_\_ (AS-2)) and  
19 later updated by PB3-13-0008-GN-EN-01 (Exhibit No. \_\_ (AS-3)). DEF discovered  
20 the [REDACTED] were degraded and, consistent with the OEM's guidance, contracted  
21 with Siemens to install upgrades.

22 As I explain below, unbeknownst to DEF, operation of the CTGs with the degraded  
23 [REDACTED] ultimately led to a series of outages impacting each of the CTGs: Unit 4B



# REDACTED

1 separate RCA was unnecessary when similar damage led to forced outages of Units  
2 4A and 4C. That is, the same equipment and operating conditions were present in  
3 all four CTGs for the same duration, and therefore the resulting damage discovered  
4 on Unit 4B was considered likely to develop on the other units at some unknown  
5 point in the future. However, it was also clear that the damage DEF suspected had  
6 been initiated, if it existed at all, had not propagated to the same degree on Units 4A,  
7 4C, and 4D at that time.<sup>1</sup>

8  
9 **Q. Please provide an overview of the Root Cause Analysis for the outages.**

10 A. The outages were caused by stator bar failures. Despite the fact the temperatures of  
11 the stator core windings never triggered the OEM established RTD alarm, the stator  
12 bar failures were most likely initiated by [REDACTED]  
13 [REDACTED]  
14 [REDACTED]. The RCA determined the “main contributor” to the [REDACTED]  
15 [REDACTED] was [REDACTED]  
16 [REDACTED] which led to a period  
17 of operation at higher temperature levels than the [REDACTED]. The units’  
18 normal load cycling [REDACTED]  
19 [REDACTED]  
20 [REDACTED]

---

<sup>1</sup> The other units had each recently underwent the same maintenance hipot test at the same voltage levels and passed without any findings or engineering concerns (Unit 4A, 2019; Unit 4C, 2018; and Unit 4D, 2019).

# REDACTED

1  
2  
3  
4  
5  
6  
7  
8  
9  
10  
11  
12  
13  
14  
15  
16  
17  
18  
19  
20  
21  
22

[REDACTED]

[REDACTED].

**Q. Can you please elaborate on the RCA findings?**

A. Yes. As mentioned above, in the fall 2019, in advance of return to service from a planned outage, maintenance high potential (hi-pot) testing on Unit 4B indicated stator winding faults on the CTG. Further investigation revealed two stator winding bars of two different phases had faulted to ground [REDACTED]

[REDACTED]

Forensic analysis determined the [REDACTED]

[REDACTED]

[REDACTED]

[REDACTED] Finally, the OEM established the “main contributor” to the [REDACTED] as [REDACTED]

[REDACTED]

[REDACTED] Exhibit No. \_\_ (AS-1), p. 1.

What all this means is that the faulted stator bars resulted from [REDACTED]

[REDACTED]

[REDACTED]. This failure mode naturally led to the question of what led to the relatively [REDACTED].

The OEM analyzed the operational life of the unit to confirm or refute as many as eleven (11) secondary level elements. Its review of data noted that the stator slot

# REDACTED

1 temperatures dropped in early 2013, while the generator output (MW and MVAR)  
2 remained stable. It further found:

3 [REDACTED]  
4 [REDACTED]  
5 [REDACTED]  
6 [REDACTED]  
7 [REDACTED]  
8 [REDACTED]  
9 [REDACTED]  
10 [REDACTED]  
11 [REDACTED]

12 *Id.* at p. 20.

13 Thus, the OEM recognized that the [REDACTED] were a  
14 symptom of the degraded [REDACTED]. When the [REDACTED] were replaced with  
15 an upgrade, the operating temperature was reduced to the lower operating range  
16 while generator output remained consistent (i.e., the [REDACTED]  
17 were not a symptom of the units being run outside of the OEM's established  
18 operating parameters). However, unbeknownst to DEF at the time, the [REDACTED]

19 [REDACTED]

20 [REDACTED]. *See id.*  
21 at p. 24.

22  
23 **Q. Why did the Company conclude that similar damage was likely to have**  
24 **occurred at the other Bartow CTGs?**

25 A. The Company reasoned that, because the other three (3) CTGs operated at similar  
26 temperatures for a similar period of time (prior to receiving the same upgrades), it

# REDACTED

1 was likely that they had also suffered damage to the stator bars that would eventually  
2 require remediation – though it was unknown when that time would be.

3  
4 **Q. Did the stator winding temperatures observed during the 2009-2013 timeframe**  
5 **provide any basis for concern?**

6 A. No. The stator winding temperature is monitored by an RTD alarm that alerts the  
7 Company if the stator winding temperature exceeds the OEM recommended  
8 threshold. The OEM alarm is based on [REDACTED]  
9 [REDACTED], giving an alarm around [REDACTED] and unload at  
10 approximately [REDACTED], depending on specific ambient conditions on a particular day.  
11 It is important to note the alarm set-points allow for engineered operating margins  
12 built into generator design; for example, the alarm set-point of [REDACTED] is more than  
13 [REDACTED] below the IEEE-established failure point for Class F Insulation (the type of  
14 insulation at issue) of 311°F (155°C). The point being, given the information  
15 reasonably available to DEF during the 2009-2013 timeframe, according to the  
16 indicated stator RTD temperatures the insulation remained well below its  
17 temperature rating at all times. In fact, in 2013 when Siemens performed the [REDACTED]  
18 [REDACTED] replacement discussed above, it inspected the end windings and main leads  
19 and found no signs of over-heating.

20  
21 **Q. Has DEF's and the OEM's understanding of the actual operating temperatures**  
22 **experienced during the 2009-2013 timeframe changed?**

1 A. Yes, based on the findings of the RCA, the OEM and DEF now believe that the [REDACTED]  
2 [REDACTED]  
3 [REDACTED]  
4 [REDACTED]  
5 [REDACTED]

6 [REDACTED]. *See id.* at pp. 19-21, 23. However, as discussed above, because  
7 the Bartow CTGs never triggered the RTD alarms, and because those alarms were  
8 set at a point that provided approximately [REDACTED] of margin before reaching the  
9 insulation’s IEEE-established temperature rating, DEF had no way of knowing the  
10 temperature likely exceeded the rating limit and no reason for concern or to seek  
11 comparison with the remainder of Siemens’ fleet.

12  
13 **Q. Did DEF operate the Bartow CTGs within the operating parameters**  
14 **established by the OEM?**

15 A. Yes, at all times DEF operated the units consistent with the OEM’s instructions as  
16 provided in the operating manual. DEF reviewed the units’ operating history in Pi  
17 data from 2010 to the 2012/2013 outages when the [REDACTED] upgrade was performed.  
18 The data, which was sampled on an hourly basis, showed zero instances of operating  
19 the generators outside the OEM ratings as defined on the generator capability curve  
20 provided in that manual.

21 Specifically, the generators have a maximum capability of [REDACTED] MW and the  
22 operating history shows the maximum output of any of the four (4) generators was  
23 213 MW. At this output of 213 MW, the allowable reactive power (MVAR) rating

# REDACTED

1 is [REDACTED] MVAR - the maximum MVAR output actually generated across this time  
2 period was 83 MVAR (as MW load decreases, the MVAR allowable increases). The  
3 table below provides the maximum MW and both maximum and minimum MVAR  
4 output of the four (4) CTGs over the period in question.  
5

| <i>Unit</i> | <i>Max MW</i> | <i>Max MVAR</i> | <i>Min MVAR</i> |
|-------------|---------------|-----------------|-----------------|
| <i>4A</i>   | <i>211</i>    | <i>80</i>       | <i>-77</i>      |
| <i>4B</i>   | <i>209</i>    | <i>71</i>       | <i>-71</i>      |
| <i>4C</i>   | <i>210</i>    | <i>77</i>       | <i>-73</i>      |
| <i>4D</i>   | <i>213</i>    | <i>83</i>       | <i>-75</i>      |

6  
7 Furthermore, the RCA shows that the OEM did not identify operation of the CTGs  
8 outside of their preapproved operating parameters as the cause of the damage to Unit  
9 4B. The RCA determined that the main contributing cause of the stator bar damage  
10 was [REDACTED]  
11 [REDACTED] which led to increased [REDACTED]  
12 [REDACTED], but again, the OEM-established RTD temperature alarm was  
13 never triggered. The RCA also shows that after the degraded [REDACTED] were  
14 replaced in 2012 and 2013, the [REDACTED]  
15 [REDACTED] while the generator output (MW and MVAR) remained stable.  
16 *See id.* at p. 20 & Fig. 16.

17 In short, DEF operated the CTGs within the OEM's defined operating parameters;  
18 hence, DEF's operation was not the cause of [REDACTED] and

1           therefore not the cause of the damage to the units. Instead, the degraded [REDACTED],  
2           which DEF replaced in accordance with OEM recommendations once it discovered  
3           the issue, [REDACTED] and caused the [REDACTED].  
4

5           **DEF's Actions to Prudently Mitigate the Risk of Failure**

6           **Q.   What steps did DEF take to prudently manage the likelihood of damage at the**  
7           **remaining units?**

8           A.   Once DEF learned the cause of Unit 4B's damage and the likelihood that the  
9           remaining units may have experienced similar damage, the Company took several  
10          proactive steps to evaluate the remaining units, monitor unit operations to detect  
11          damage propagation (to the extent possible), and ultimately remediate the likelihood  
12          of damage to the remaining units. First, DEF reconfigured the Electromagnetic  
13          Signature Analysis ("EMSA") collars on Units 4A and 4C<sup>2</sup> to potentially identify  
14          insulation degradation during continued operation.<sup>3</sup> Second, DEF scheduled  
15          borescope inspections on Units 4A and 4C to look for any visual indications of  
16          buckled insulation.<sup>4</sup> Third, DEF issued procurement specifications in anticipation  
17          of a bid event for a spare set of stator bars to have on hand in case of an in-service  
18          failure or failed indicative testing of one of the remaining CTGs. Finally, DEF  
19          scheduled generator rewinds for the remaining units, notwithstanding that a rewind  
20          would not typically be required for thousands of equivalent operating hours.

---

<sup>2</sup> As noted above, Units 4A and 4D underwent hipot testing in spring and fall 2019, respectively, resulting in no negative findings or engineering concerns.

<sup>3</sup> DEF previously relocated the EMSA collars on Units 4B and 4D in fall 2019.

<sup>4</sup> Unit 4D was thoroughly inspected in fall 2019 (when the Unit 4B damage was discovered), so a borescope inspection was unnecessary.

# REDACTED

1 stator rewind for Unit 4A was scheduled for the fall 2023 planned major outage, and  
2 the stator rewind for Unit 4C was scheduled for the fall 2024 planned major outage.  
3 This schedule was intended to allow DEF to take advantage of previously scheduled  
4 outages in a measured cadence to avoid concurrent CTG outages (maximizing output  
5 from the remainder of the plant by allowing for operation in 3 on 1 configuration),  
6 to minimize the number of planned outages by performing multiple maintenance  
7 tasks during the same outages, and to provide time for the OEM to manufacture the  
8 stator bars and support the outages.

9 In an effort to prudently address and mitigate the risks to the other units suggested  
10 by the Unit 4B RCA, while also attempting to retain the benefits of Bartow's low-  
11 cost generation for customers by spacing the scheduling of planned major outages,  
12 DEF scheduled these stator rewinds to occur much earlier in the units' operating life  
13 than the Duke Energy fleet standard recommendation of [REDACTED] equivalent hours  
14 for this type of air-cooled unit. Specifically, Unit 4D was planned for a rewind at  
15 ~103,000 equivalent hours, Unit 4A at ~109,000 equivalent hours, and Unit 4C at  
16 ~116,000 equivalent hours.

17  
18 **Q. Was DEF able to maintain the schedule of proactive outages discussed above?**

19 **A.** No, Unit 4A experienced an unexpected in-service failure in January 2021 that  
20 required a forced outage lasting into April 2021; as discussed above, due to the  
21 nature of the suspected damage and the limitations on available testing, DEF could  
22 not have anticipated when such a failure may occur (if at all). As a result of this  
23 outage, DEF accelerated the scheduled Unit 4C planned outage up to fall 2023.



# REDACTED

1 However, shortly after Unit 4A's return to service, Unit 4C also experienced an in-  
2 service failure in May 2021.

3  
4 **Q. Did these unexpected occurrences further alter DEF's plan?**

5 A. Yes. Given the two in-service failures in a short period of time, DEF determined  
6 that this new information required a strategy shift. Therefore, the Company  
7 accelerated the planned outage of Unit 4D from spring 2022 to June 2021. DEF  
8 completed the stator rewinds and returned Units 4C and 4D to service in November  
9 and October 2021, respectively.

10  
11 **Q. You indicated that the two forced outages in a short period of time was "new  
12 information" that led to DEF's strategy change. Given that DEF determined  
13 in March 2020 that there was a likelihood of latent damage to the remaining  
14 units, how did the in-service failures constitute "new information"?**

15 A. The new information I was referring to is the speed at which the [REDACTED],  
16 which was thought but not definitively known to exist, was propagating on the  
17 remaining units notwithstanding operation within the OEM-provided parameters and  
18 the normal fleet operating temperatures. Recall that DEF became aware of the main  
19 contributing cause of the damage to Unit 4B in March 2020. At that time, the units  
20 had been operating for approximately seven (7) years after the [REDACTED] is  
21 believed to have occurred without an in-service failure known to have resulted from  
22 the damage identified in the RCA; that is, DEF had only its experience and did not  
23 have any means to formulate a trend or projection for when subsequent failures may

1 plant). Said differently, the prior order concerned operation of the Bartow Steam  
2 Turbine and contained no discussion regarding the operation of the CTGs. In fact,  
3 the Commission specifically noted “that this case is highly fact specific and for that  
4 reason will have limited precedential value.”<sup>5</sup>

## 6 Conclusion

### 7 **Q. In your opinion, has DEF acted prudently?**

8 A. Yes. First, as I have explained above, the Company’s operation of the units did not  
9 initiate the damage to the units, rather it was a function of [REDACTED] that  
10 the Company simply could not have contemporaneously known about. When DEF  
11 later determined the damage was likely present on the other units, it was confronted  
12 with a lack of information about: a) whether the other units (or some subset of those  
13 units) were actually damaged, and if so to what degree; and b) if the units were  
14 damaged, at what point the damage would be identifiable via available testing or  
15 when the units may experience a failure. Given this dearth of information, DEF  
16 made the reasonable decision to continue operating the units (benefitting customers  
17 by the continued generation of low-cost energy) and prudently took steps intended  
18 to mitigate the risk of future in-service failure. What we now know, but could not  
19 have known at the time, was the relatively short period in which the hypothesized  
20 damage would manifest. As I have explained above, as the Company learned  
21 additional facts, it prudently incorporated the new information into its analysis and  
22 made reasonable adjustments where possible. When making operations decisions in

---

<sup>5</sup> Order No. PSC-2020-0368A-FOF-EI, at p. 22.

Duke Energy Florida, LLC  
Docket No. 20220001  
Witness: Salvarezza  
Exhibit No. \_\_\_\_ (AS-1)

**REDACTED**  
Pages 1 through 26  
are confidential in their entirety.

Duke Energy Florida, LLC  
Docket No. 20220001  
Witness: Salvarezza  
Exhibit No. \_\_\_\_ (AS-2)

REDACTED  
Pages 1 through 6  
are confidential in their entirety.

Duke Energy Florida, LLC  
Docket No. 20220001  
Witness: Salvarezza  
Exhibit No. \_\_\_\_ (AS-3)

REDACTED  
Pages 1 through 6  
are confidential in their entirety.

## Exhibit C

### DUKE ENERGY FLORIDA Confidentiality Justification Matrix

| DOCUMENT/RESPONSES  | PAGE/LINE   | JUSTIFICATION   |
|---|---|---|
| <p>Direct Testimony of Anthony Salvarezza dated April 1, 2022</p> | <p><b>Page 3</b><br/> <b>Line 19:</b> All information before “years earlier” is confidential.</p> <p><b>Page 5</b><br/> <b>Line 3:</b> All information before “(Confidential)”<br/> <b>Line 6:</b> all information on before “(Confidential)”<br/> <b>Line 17:</b> all information after “of the” and before “consistent”<br/> <b>Line 20:</b> All information after “the” and before “were degraded”<br/> <b>Line 23:</b> All Information before “ultimately”.</p> <p><b>Page 7</b><br/> <b>Lines 12-</b>The remaining information after “initiated by”.<br/> <b>Line 13:</b> All information in its entirety.<br/> <b>Line 14:</b> The information before “The RCA”, after “to the”.<br/> <b>Line 15:</b> The information before “was”, and the remainder of the sentence after “was”.<br/> <b>Line 16:</b> The information before which led<br/> <b>Line 17:</b> The information after “than the” and before “The units”.<br/> <b>Line 18:</b> The remaining information after “cycling”<br/> <b>Lines 19 and 20:</b> in their</p> | <p>§366.093(3)(d), F.S.<br/> The document in question contains confidential information, the disclosure of which would impair DEF’s efforts to contract for goods or services on favorable terms.</p> <p>§366.093(3)(e), F.S.<br/> The document in question contains confidential information relating to competitive business interests, the disclosure of which would impair the competitive business of the provider/owner of the information.</p> |

entirety.

**Page 8**

**Lines 1 and 2:** All information in their entirety.

**Line 8:** the information after “ground”

**Line 9:** The information in its entirety

**Line 10:** the information after “determined the”

**Lines 11 and 12:** the information in its entirety

**Line 13:** The information before

**Line 14:** The information after “to the”, before “as” after “as”

**Line 15:** The information in its entirety.

**Line 16:** The information before “Exhibit” after “from” and before “This”, after “relatively” and before “The OEM”.

**Page 9**

**Lines 3-10,** all information in its entirety

**Lines 13:**The information after “that the” and before “were”

**Line 14:** The information after “degraded” and before “When”, after “the” and before “were replaced”

**Line 16:**The remaining information after “the”

**Line 18:** the remaining information after “the”

Line 19: all information in its entirety

Line 20:All information before “See”

**Page 10**

**Line 8:** The remaining information after “based on”  
**Line 9;** The information before “giving”, after “around”, and before “and”  
**Line 10:** The information after “approximately” and before “depending”  
**Line 12:** The information after “set-point of” and before “is more”  
**Line 13:** The information before “below”  
**Line 17:** The information after “the”  
**Line 18:** The information before “replacement”

**Page 11**

**Line 1:** The information after “that the”.  
**Lines 2-5:** All information in its entirety.  
**Line 6:** All information before “See”.  
**Line 8:** The information after “approximately” and before “of margin”.  
**Line 17: The information** after “when the” and before “upgrade”.  
**Line 21:** The information after “capability of” and before MW”

**Page 12**

**Line 1:** the information after “is” and before “MVAR”  
**Line 10:** The remaining information after “was”  
**Line 11:** The information before “which led”, and after “increased”.  
**Line 13:** The information after “degraded” and before “were”



|   |   |   |
|---|---|---|
|   | <p><b>Line 14:</b> The remaining information after “the”</p> <p><b>Line 15:</b> The information before “while”</p> <p><b>Line 18:</b> The information after “cause of” and before “and”.</p> <p><b>Page 13</b></p> <p><b>Line 1:</b> the information after “degraded”</p> <p><b>Line 3:</b> The information after “issue” and before “and caused” and the remaining sentence after “the”.</p> <p><b>Page 16</b></p> <p><b>Line 13:</b> The information after “of” and before “equivalent”</p> <p><b>Page 17</b></p> <p><b>Line 15:</b> The remaining information after “which the”.</p> <p><b>Line 20:</b> The information after “after the” and before “is”.</p> <p><b>Page 21</b></p> <p><b>Line 9:</b> The information after “function of” and before “that”</p> |   |
| <b>DOCUMENT/RESPONSES</b>   | <b>PAGE/LINE</b>  | <b>JUSTIFICATION</b>  |
| Exhibit No. ____ (AS-1) to the Direct Testimony of Anthony Salvarezza | Pages 1 through 26 are confidential in their entirety.  | <p>§366.093(3)(d), F.S.<br/>The document in question contains confidential information, the disclosure of which would impair DEF’s efforts to contract for goods or services on favorable terms.</p> <p>§366.093(3)(e), F.S.<br/>The document in question contains confidential</p> |

|   |   |   |
|---|---|---|
|   |   | information relating to competitive business interests, the disclosure of which would impair the competitive business of the provider/owner of the information.   |
| <b>DOCUMENT/RESPONSES</b>   | <b>PAGE/LINE</b>                                      | <b>JUSTIFICATION</b>  |
| Exhibit No. ____ (AS-2) to the Direct Testimony of Anthony Salvarezza | Pages 1 through 6 are confidential in their entirety. | <p>§366.093(3)(d), F.S.<br/>The document in question contains confidential information, the disclosure of which would impair DEF's efforts to contract for goods or services on favorable terms.</p> <p>§366.093(3)(e), F.S.<br/>The document in question contains confidential information relating to competitive business interests, the disclosure of which would impair the competitive business of the provider/owner of the information.</p> |
| <b>DOCUMENT/RESPONSES</b>   | <b>PAGE/LINE</b>                                      | <b>JUSTIFICATION</b>  |
| Exhibit No. ____ (AS-3) to the Direct Testimony of Anthony Salvarezza | Pages 1 through 6 are confidential in their entirety. | <p>§366.093(3)(d), F.S.<br/>The document in question contains confidential information, the disclosure of which would impair DEF's efforts to contract for goods or services on favorable terms.</p> <p>§366.093(3)(e), F.S.<br/>The document in question contains confidential information relating to competitive business interests, the disclosure of which would impair the competitive business of the provider/owner of the information.</p> |

# **Exhibit D**

## **AFFIDAVIT OF ANTHONY SALVAREZZA**

**BEFORE THE FLORIDA PUBLIC SERVICE COMMISSION**

---

In re: Fuel and purchased power cost recovery  
Clause with generating performance incentive  
Factor

---

Docket No. 20220001-EI

Dated: April 22, 2022

**AFFIDAVIT OF ANTHONY SALVAREZZA IN SUPPORT OF  
DUKE ENERGY FLORIDA'S  
REQUEST FOR CONFIDENTIAL CLASSIFICATION**

STATE OF FLORIDA

COUNTY OF PINELLAS

BEFORE ME, the undersigned authority duly authorized to administer oaths, personally appeared Anthony Salvarezza, who being first duly sworn, on oath deposes and says that:

1. My name is Anthony Salvarezza. I am over the age of 18 years old, and I have been authorized by Duke Energy Florida (hereinafter "DEF" or the "Company") to give this affidavit in the above-styled proceeding on DEF's behalf and in support of DEF's Request for Confidential Classification (the "Request"). The facts attested to in my affidavit are based upon my personal knowledge.

2. I am the General Manager of Regional Services. I am responsible for leading and directing project engineering, project management, outage management, business planning and specialized maintenance in Regulated and Renewable Energy. My major duties and responsibilities include providing safe, reliable, efficient, economic, environmental, and regulatory compliant maintenance activities through the development and implementation of processes and programs.

3. DEF is seeking confidential classification for certain information contained in my direct testimony and Exhibit No. \_\_\_(AS-1), Exhibit No.\_\_(AS-2), and Exhibit No.\_\_(AS-3). The confidential information at issue is contained in confidential Exhibit A to DEF's Request and is outlined in DEF's Justification Matrix that is attached to DEF's Request as Exhibit C. DEF is requesting confidential classification of this information because it contains sensitive business information, the disclosure of which would impair the Company's competitive business interests and ability to contract for goods and services on favorable terms.

4. The confidential information at issue relates to proprietary third-party and technical information regarding the third-party's proprietary component design and operation parameters, the disclosure of which would impair the third-party's competitive business interests, and if disclosed, the Company's competitive business interests and efforts to contract for goods or services on favorable terms. In order to contract with third-party vendors on favorable terms, DEF must keep third-party proprietary information confidential.

5. Further, if DEF cannot demonstrate to its third-party vendors and others that may enter contracts with DEF in the future, that DEF has the ability to protect those third parties' confidential and proprietary business information, third parties will be less likely to provide that information to DEF – harming DEF's ability to prudently operate its business. DEF has not publicly disclosed the information. Without DEF's measures to maintain the confidentiality of this sensitive business information, DEF's ability to contract with third parties could detrimentally impact DEF's ability to negotiate favorable contracts, as third parties may begin to demand a "premium" to do business with DEF to account for the risk that its proprietary information will become a matter of public record, thereby harming DEF's competitive interests and ultimately its customers' financial interests.

6. Upon receipt of its own confidential information, strict procedures are established and followed to maintain the confidentiality of the terms of the documents and information provided, including restricting access to those persons who need the information to assist the Company, and restricting the number of, and access to the information and contracts. At no time since receiving the information in question has the Company publicly disclosed that information. The Company has treated and continues to treat the information at issue as confidential.

7. This concludes my affidavit.


Further affiant sayeth not.

Dated the 19<sup>th</sup> day of April, 2022.




(Signature)  
Anthony Salvarezza  
General Manager – Regional Services

THE FOREGOING INSTRUMENT was sworn to and subscribed before me this 19<sup>th</sup> day of April, 2022 by Anthony Salvarezza. He is personally known to me or has produced his \_\_\_\_\_ driver's license, or his \_\_\_\_\_ as identification.



(AFFIX NOTARIAL SEAL)



(Signature)  
Deanna Lee Carver

(Printed Name)  
NOTARY PUBLIC, STATE OF FL

July 18, 2022  
(Commission Expiration Date)

(Serial Number, If Any)