



Maria Jose Moncada
Managing Attorney
Florida Power & Light Company
700 Universe Boulevard
Juno Beach, FL 33408-0420
(561) 304-5795
(561) 691-7135 (Facsimile)
E-mail: maria.moncada@fpl.com

December 20, 2022

-VIA ELECTRONIC FILING-

Adam Teitzman
Commission Clerk
Florida Public Service Commission
2540 Shumard Oak Blvd.
Tallahassee, FL 32399-0850

Re: Docket No. 20220001-EI

Dear Mr. Teitzman:

Attached for electronic filing in the above docket are Florida Power & Light Company's GPIF Actual Unit Performance Data Schedules covering the month of November 2022. These schedules are being filed at the same time but separately from the monthly A Schedules.

If there are any questions regarding this transmittal, please contact me at (561) 304-5795.

Sincerely,

s/ Maria Jose Moncada
Maria Jose Moncada

Attachments

cc: Counsel for Parties of Record (w/ attachments)

CERTIFICATE OF SERVICE
Docket 20220001-EI

I **HEREBY CERTIFY** that a true and correct copy of the foregoing has been furnished
by electronic delivery on this 20th day of December 2022 to the following:

Suzanne Brownless
Ryan Sandy
Division of Legal Services
Florida Public Service Commission
2540 Shumard Oak Blvd.
Tallahassee, Florida 32399-0850
sbrownle@psc.state.fl.us
rsandy@psc.state.fl.us

Paula K. Brown, Manager
Tampa Electric Company
Regulatory Coordinator
Post Office Box 111
Tampa, Florida 33601-0111
regdept@tecoenergy.com

J. Jeffrey Wahlen
Malcolm N. Means
Virginia Ponder
Ausley & McMullen
P.O. Box 391
Tallahassee, Florida 32302
jwahlen@ausley.com
mmeans@ausley.com
vponder@ausley.com
Attorneys for Tampa Electric Company

Michelle D. Napier
Director, Regulatory Affairs Distribution
Florida Public Utilities Company
1635 Meathe Drive
West Palm Beach, FL33411
mnapier@fpuc.com

Richard Gentry
Patricia A. Christensen
Charles J. Rehwinkel
Mary Wessling
Office of Public Counsel
c/o The Florida Legislature
111 West Madison St., Room 812
Tallahassee, Florida 32399-1400
gentry.richard@leg.state.fl.us
christensen.patty@leg.state.fl.us
rehwinkel.charles@leg.state.fl.us
wessling.mary@leg.state.fl.us

Robert L. Pickels
Duke Energy Florida
106 East College Avenue, Suite 800
Tallahassee, Florida 32301
robert.pickels@duke-energy.com
FLRegulatoryLegal@duke-energy.com

Dianne M. Triplett
299 First Avenue North
St. Petersburg, Florida 33701
dianne.triplett@duke-energy.com

Matthew R. Bernier
Stephanie A. Cuello
Duke Energy Florida
106 East College Avenue, Suite 800
Tallahassee, Florida 32301
matthew.bernier@duke-energy.com
stephanie.cuello@duke-energy.com
Attorneys for Duke Energy Florida

Mike Cassel
Vice President/Government and
Regulatory Affairs
Florida Public Utilities Company
208 Wildlight Ave.
Yulee, Florida 32097
mcassel@fpuc.com

Beth Keating
Gunster Law Firm
215 South Monroe St., Suite 601
Tallahassee, Florida 32301-1804
bkeating@gunster.com
**Attorneys for Florida Public Utilities
Company**

Jon C. Moyle, Jr.
Moyle Law Firm, P.A.
118 North Gadsden Street
Tallahassee, FL 32301
jmoyle@moylelaw.com
mqualls@moylelaw.com
**Attorneys for Florida Industrial Power
Users Group**

Peter J. Mattheis
Michael K. Lavanga
Joseph R. Briscar
Stone Mattheis Xenopoulos & Brew, PC
1025 Thomas Jefferson Street, NW
Eighth Floor, West Tower
Washington, DC 20007-5201
pjm@smxblaw.com
mkl@smxblaw.com
jrb@smxblaw.com
Attorneys for Nucor Steel Florida, Inc.

James W. Brew
Laura Wynn Baker
Stone Mattheis Xenopoulos & Brew, P.C.
1025 Thomas Jefferson Street, NW
Eighth Floor, West Tower
Washington, DC 20007
jbrew@smxblaw.com
lwb@smxblaw.com
**Attorneys for PCS Phosphate-White
Springs**

Robert Scheffel Wright
John T. LaVia, III
Gardner, Bist, Bowden, Dee
LaVia, Wright, Perry & Harper, P.A.
1300 Thomaswood Drive
Tallahassee, FL 32308
schef@gbwlegal.com
jlavia@gbwlegal.com
**Attorneys for The Florida Retail
Federation**

By: s/ Maria Jose Moncada

Maria Jose Moncada
Florida Bar No. 0773301

ACTUAL PERFORMANCE DATA
 COMPANY: FLORIDA POWER AND LIGHT
 FROM: Jan-2022 TO: Dec-2022

		PLANT/UNIT: Cape Canaveral - PCC											PCC-03	
		Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	Ytd
1	EAF (%)	87.50	78.00	64.70	63.70	90.70	97.00	95.10	97.00	97.60	15.40	18.20	0.00	73.20
2	PH	744.00	672.00	743.00	720.00	744.00	720.00	744.00	744.00	720.00	744.00	721.00	0.0	8016.00
3	SH	744.00	666.02	731.48	720.00	744.00	720.00	744.00	744.00	720.00	95.83	218.87	0.0	6848.20
4	RSH	0.00	5.98	11.52	0.00	0.00	0.00	0.00	0.00	0.00	24.17	0.00	0.0	41.67
5	UH	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	624.00	502.13	0.0	1126.13
6	POH	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	624.00	502.13	0.0	1126.13
7	FOH	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.0	0.00
8	MOH	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.0	0.00
9	PPOH	0.00	416.00	667.63	343.90	0.00	0.00	0.00	0.00	0.00	0.00	216.78	0.0	1644.32
10	LRPP (MW)	0.00	438.00	434.76	438.00	0.00	0.00	0.00	0.00	0.00	0.00	529.36	0.0	448.73
11	PFOH	0.00	7.92	44.80	2.72	50.73	64.65	56.75	0.87	19.15	17.42	0.00	0.0	265.00
12	LRPF (MW)	0.00	694.84	324.52	275.00	484.63	438.00	437.06	197.00	454.86	437.30	0.00	0.0	433.93
13	PMOH	228.87	17.50	126.75	411.33	148.85	0.00	52.07	61.83	31.20	0.00	0.00	0.0	1078.40
14	LRPM (MW)	535.22	364.26	312.19	464.92	441.76	0.00	442.25	473.59	437.30	0.00	0.00	0.0	455.66
15	NSC	1312	1312	1312	1312	1312	1312	1312	1312	1312	1312	1312	0.0	1312
16	OPERBTU (MBTU)	2197358	1887569	2198988	2671849	3898131	4165955	4717519	4753529	4217200	443707	654893	0.0	31806699
17	NET GEN	326716.0	280921.0	323669.0	390412.0	572958.0	622083.0	704337.0	704367.0	620649.0	65028.0	90084.0	0.0	4701224.0
18	ANOHR (BTU/KWH)	6726.0	6719.0	6794.0	6844.0	6804.0	6697.0	6698.0	6749.0	6795.0	6823.0	7270.0	0.0	6766.0
19	NOF (%)	33.50	32.10	33.70	41.30	58.70	65.90	72.20	72.20	65.70	51.00	31.00	0.00	52.30
20	NPC	1312	1312	1312	1312	1312	1312	1312	1312	1312	1312	1312	0.0	1312

21	ANOHR EQUATION	$ANOHR = A+B(N.O.F)$ A=0 B=0
----	----------------	---------------------------------

NOTE : LINE 17 IS DATA WHEN THE UNIT IS SYNCHRONIZED TO THIS SYSTEM

ISSUED BY: FLORIDA POWER AND LIGHT CO.

FILED:
 SUSPENDED:
 EFFECTIVE:
 DOCKET NO:
 ORDER NO:

ACTUAL PERFORMANCE DATA
 COMPANY: FLORIDA POWER AND LIGHT
 FROM: Jan-2022 TO: Dec-2022

		PLANT/UNIT: Fort Myers - PFM											PFM-02	
		Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	Ytd
1	EAF (%)	97.70	97.60	97.50	98.10	97.80	98.40	99.90	95.80	92.50	88.20	84.30	0.00	95.30
2	PH	744.00	672.00	743.00	720.00	744.00	720.00	744.00	744.00	720.00	744.00	721.00	0.0	8016.00
3	SH	744.00	672.00	743.00	720.00	744.00	720.00	744.00	744.00	689.07	744.00	721.00	0.0	7985.07
4	RSH	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	30.93	0.00	0.00	0.0	30.93
5	UH	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.0	0.00
6	POH	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.0	0.00
7	FOH	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.0	0.00
8	MOH	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.0	0.00
9	PPOH	0.00	0.00	0.00	72.27	28.00	0.00	0.00	0.00	0.00	0.00	624.40	0.0	724.67
10	LRPP (MW)	0.00	0.00	0.00	195.00	195.00	0.00	0.00	0.00	0.00	0.00	292.94	0.0	279.39
11	PFOH	57.53	62.28	13.95	4.42	70.67	3.47	4.43	148.97	53.05	138.92	35.93	0.0	593.62
12	LRPF (MW)	287.96	223.98	306.34	207.55	328.38	195.00	212.41	72.77	292.91	240.30	211.16	0.0	215.42
13	PMOH	69.28	78.40	147.42	47.77	1.35	96.00	0.00	166.53	270.67	307.12	50.38	0.0	1234.92
14	LRPM (MW)	195.00	195.00	195.00	195.00	195.00	211.38	0.00	268.20	295.60	398.78	195.00	0.0	278.87
15	NSC	1774	1774	1774	1774	1774	1774	1774	1774	1774	1774	1774	0.0	1774
16	OPERBTU (MBTU)	5696315	5353982	6730429	6616650	6565605	6177617	7050150	6633583	5942143	6094287	5920270	0.0	68781031
17	NET GEN	797036.0	751897.0	953196.0	932761.0	916500.0	866839.0	991263.0	931600.0	837541.0	859367.0	833598.0	0.0	9671598.0
18	ANOHR (BTU/KWH)	7147.0	7121.0	7061.0	7094.0	7164.0	7127.0	7112.0	7121.0	7095.0	7092.0	7102.0	0.0	7112.0
19	NOF (%)	60.40	63.10	72.30	73.00	69.40	67.90	75.10	70.60	68.50	65.10	65.20	0.00	68.30
20	NPC	1774	1774	1774	1774	1774	1774	1774	1774	1774	1774	1774	0.0	1774

21	ANOHR EQUATION	ANOHR = A+B(N.O.F) A=0 B=0
----	----------------	-------------------------------

NOTE : LINE 17 IS DATA WHEN THE UNIT IS SYNCHRONIZED TO THIS SYSTEM

FILED:
 SUSPENDED:
 EFFECTIVE:
 DOCKET NO:
 ORDER NO:

ISSUED BY: FLORIDA POWER AND LIGHT CO.

ACTUAL PERFORMANCE DATA
COMPANY: FLORIDA POWER AND LIGHT
FROM: Jan-2022 TO: Dec-2022

		PLANT/UNIT: Manatee - PM3											PM3-03	
		Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	Ytd
1	EAF (%)	99.10	98.50	85.90	56.40	88.20	98.10	99.90	99.80	97.70	81.10	63.90	0.00	88.10
2	PH	744.00	672.00	743.00	720.00	744.00	720.00	744.00	744.00	720.00	744.00	721.00	0.0	8016.00
3	SH	744.00	670.30	743.00	632.32	744.00	720.00	744.00	744.00	720.00	744.00	642.48	0.0	7848.10
4	RSH	0.00	1.70	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	1.70
5	UH	0.00	0.00	0.00	87.68	0.00	0.00	0.00	0.00	0.00	0.00	78.52	0.0	166.20
6	POH	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.0	0.00
7	FOH	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.0	0.00
8	MOH	0.00	0.00	0.00	87.68	0.00	0.00	0.00	0.00	0.00	0.00	78.52	0.0	166.20
9	PPOH	0.00	0.00	399.23	626.60	309.27	0.00	0.00	0.00	0.00	0.00	0.00	0.0	1335.10
10	LRPP (MW)	0.00	0.00	314.75	416.28	314.27	0.00	0.00	0.00	0.00	0.00	0.00	0.0	358.40
11	PFOH	30.28	0.00	13.03	54.38	7.42	36.42	3.37	5.17	1.22	16.33	15.98	0.0	183.60
12	LRPF (MW)	280.55	0.00	281.98	178.33	195.00	309.50	309.50	309.50	309.50	195.00	230.63	0.0	243.00
13	PMOH	0.00	65.75	0.00	29.92	32.67	19.00	0.00	0.00	105.23	403.00	642.48	0.0	1298.05
14	LRPM (MW)	0.00	195.00	0.00	329.71	314.75	309.50	0.00	0.00	195.00	423.94	344.85	0.0	348.04
15	NSC	1238	1238	1238	1238	1238	1238	1238	1238	1238	1238	1238	0.0	1238
16	OPERBTU (MBTU)	3514859	3293903	4132741	2498852	4014816	4060474	4515764	4496568	4056057	4104095	3452542	0.0	42140671
17	NET GEN	509047.0	476175.0	605531.0	365554.0	594513.0	597229.0	658249.0	663669.0	596364.0	598887.0	493317.0	0.0	6158535.0
18	ANOHR (BTU/KWH)	6905.0	6917.0	6825.0	6836.0	6753.0	6799.0	6860.0	6775.0	6801.0	6853.0	6999.0	0.0	6843.0
19	NOF (%)	55.30	57.40	65.80	46.60	64.60	67.00	71.50	72.00	66.90	65.00	62.00	0.00	63.40
20	NPC	1238	1238	1238	1238	1238	1238	1238	1238	1238	1238	1238	0.0	1238

21	ANOHR EQUATION	ANOHR = A+B(N.O.F) A=0 B=0
----	----------------	-------------------------------

NOTE : LINE 17 IS DATA WHEN THE UNIT IS SYNCHRONIZED TO THIS SYSTEM

FILED:
 SUSPENDED:
 EFFECTIVE:
 DOCKET NO:
 ORDER NO:

ISSUED BY: FLORIDA POWER AND LIGHT CO.

ACTUAL PERFORMANCE DATA
 COMPANY: FLORIDA POWER AND LIGHT
 FROM: Jan-2022 TO: Dec-2022

		PLANT/UNIT: Martin - PM8						PM8-08						
		Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	Ytd
1	EAF (%)	98.70	87.50	81.30	98.60	100.00	76.40	96.40	93.10	93.20	98.50	71.90	0.00	90.60
2	PH	744.00	672.00	743.00	720.00	744.00	720.00	744.00	744.00	720.00	744.00	721.00	0.0	8016.00
3	SH	724.68	636.37	700.92	720.00	735.68	720.00	744.00	744.00	720.00	744.00	598.00	0.0	7787.65
4	RSH	19.32	9.32	16.53	0.00	8.32	0.00	0.00	0.00	0.00	0.00	0.00	0.0	53.48
5	UH	0.00	26.31	25.55	0.00	0.00	0.00	0.00	0.00	0.00	0.00	123.00	0.0	174.87
6	POH	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.0	0.00
7	FOH	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.0	0.00
8	MOH	0.00	26.32	25.55	0.00	0.00	0.00	0.00	0.00	0.00	0.00	123.00	0.0	174.87
9	PPOH	0.00	76.95	334.57	0.00	0.00	681.50	82.95	0.00	0.00	0.00	0.00	0.0	1175.97
10	LRPP (MW)	0.00	305.50	305.19	0.00	0.00	305.50	305.50	0.00	0.00	0.00	0.00	0.0	305.41
11	PFOH	11.60	20.03	12.38	1.50	0.00	5.58	2.05	2.27	154.97	0.00	0.00	0.0	210.38
12	LRPF (MW)	305.51	199.27	195.00	505.50	0.00	195.00	128.75	355.50	390.00	0.00	0.00	0.0	348.43
13	PMOH	27.38	138.87	114.45	37.17	0.00	0.00	23.98	159.78	0.00	60.45	335.67	0.0	897.75
14	LRPM (MW)	305.52	310.90	309.09	324.33	0.00	0.00	310.00	390.00	0.00	221.61	292.11	0.0	312.08
15	NSC	1231	1231	1231	1231	1231	1231	1231	1231	1231	1231	1231	0.0	1231
16	OPERBTU (MBTU)	3805657	2968690	3381175	3938148	4072743	3047000	3948250	3968974	3924094	4477778	2856658	0.0	40389168
17	NET GEN	533006.0	430039.0	491749.0	582170.0	577132.0	436364.0	600646.0	584588.0	564954.0	639836.0	403848.0	0.0	5844332.0
18	ANOHR (BTU/KWH)	7140.0	6903.0	6876.0	6765.0	7057.0	6983.0	6573.0	6789.0	6946.0	6998.0	7074.0	0.0	6911.0
19	NOF (%)	59.80	54.90	57.00	65.70	63.70	49.20	65.60	63.80	63.70	69.80	54.70	0.00	60.90
20	NPC	1231	1231	1231	1231	1231	1231	1231	1231	1231	1231	1231	0.0	1231

21	ANOHR EQUATION	ANOHR = A+B(N.O.F) A=0 B=0
----	----------------	-------------------------------

NOTE : LINE 17 IS DATA WHEN THE UNIT IS SYNCHRONIZED TO THIS SYSTEM

ISSUED BY: FLORIDA POWER AND LIGHT CO.

FILED:
 SUSPENDED:
 EFFECTIVE:
 DOCKET NO:
 ORDER NO:

ACTUAL PERFORMANCE DATA
 COMPANY: FLORIDA POWER AND LIGHT
 FROM: Jan-2022 TO: Dec-2022

		PLANT/UNIT: Port Everglades - PPE											PPE-05	
		Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	Ytd
1	EAF (%)	100.00	99.40	67.80	92.90	92.70	100.00	99.20	98.50	97.20	90.80	90.90	0.00	93.50
2	PH	744.00	672.00	743.00	720.00	744.00	720.00	744.00	744.00	720.00	744.00	721.00	0.0	8016.00
3	SH	744.00	671.12	509.13	697.53	707.47	713.43	744.00	744.00	720.00	744.00	664.67	0.0	7659.35
4	RSH	0.00	0.00	0.00	0.00	0.00	6.57	0.00	0.00	0.00	0.00	0.00	0.0	6.57
5	UH	0.00	0.88	233.87	22.47	36.53	0.00	0.00	0.00	0.00	0.00	56.33	0.0	350.08
6	POH	0.00	0.88	233.87	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.0	234.75
7	FOH	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.0	0.00
8	MOH	0.00	0.00	0.00	22.47	36.53	0.00	0.00	0.00	0.00	0.00	56.33	0.0	115.33
9	PPOH	0.00	1.72	16.48	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.0	18.20
10	LRPP (MW)	0.00	421.14	415.61	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.0	416.13
11	PFOH	0.00	11.78	0.00	6.80	0.00	0.60	1.10	10.03	0.00	14.45	18.10	0.0	62.87
12	LRPF (MW)	0.00	275.00	0.00	431.00	0.00	275.00	421.40	421.55	0.00	480.84	452.75	0.0	416.31
13	PMOH	0.00	0.00	0.00	113.12	70.17	0.00	13.37	34.52	55.13	134.88	6.35	0.0	427.53
14	LRPM (MW)	0.00	0.00	0.00	291.15	316.73	0.00	552.52	275.00	465.29	593.20	583.57	0.0	424.31
15	NSC	1264	1264	1264	1264	1264	1264	1264	1264	1264	1264	1264	0.0	1264
16	OPERBTU (MBTU)	5671237	4942439	2882649	4208403	3889814	3858770	4409552	4315797	3963291	3682772	3735972	0.0	45560695
17	NET GEN	866926.0	753235.0	426319.0	625462.0	573302.0	564360.0	651121.0	638674.0	582221.0	513008.0	548445.0	0.0	6743073.0
18	ANOHR (BTU/KWH)	6542.0	6562.0	6762.0	6728.0	6785.0	6837.0	6772.0	6757.0	6807.0	7179.0	6812.0	0.0	6757.0
19	NOF (%)	92.20	88.80	66.10	70.90	64.10	62.60	69.20	67.90	64.00	54.60	65.20	0.00	69.60
20	NPC	1264	1264	1264	1264	1264	1264	1264	1264	1264	1264	1264	0.0	1264

21	ANOHR EQUATION	ANOHR = A+B(N.O.F) A=0 B=0
----	----------------	-------------------------------

NOTE : LINE 17 IS DATA WHEN THE UNIT IS SYNCHRONIZED TO THIS SYSTEM

FILED:
 SUSPENDED:
 EFFECTIVE:
 DOCKET NO:
 ORDER NO:

ISSUED BY: FLORIDA POWER AND LIGHT CO.

ACTUAL PERFORMANCE DATA
COMPANY: FLORIDA POWER AND LIGHT
FROM: Jan-2022 TO: Dec-2022

		PLANT/UNIT: Riviera - PRV PRV-05												
		Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	Ytd
1	EAF (%)	94.70	95.60	92.70	96.60	100.00	98.00	96.20	94.40	70.30	81.80	73.70	0.00	90.40
2	PH	744.00	672.00	743.00	720.00	744.00	720.00	744.00	744.00	720.00	744.00	721.00	0.0	8016.00
3	SH	744.00	672.00	743.00	720.00	736.52	720.00	744.00	744.00	720.00	678.93	721.00	0.0	7943.45
4	RSH	0.00	0.00	0.00	0.00	7.48	0.00	0.00	0.00	0.00	16.75	0.00	0.0	24.23
5	UH	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	48.32	0.00	0.0	48.32
6	POH	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.0	0.00
7	FOH	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.0	0.00
8	MOH	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	48.32	0.00	0.0	48.32
9	PPOH	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	597.98	136.43	569.00	0.0	1303.42
10	LRPP (MW)	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	437.00	437.00	437.00	0.0	437.00
11	PFOH	0.00	36.53	0.00	0.00	0.00	3.98	8.30	28.43	2.35	59.90	0.00	0.0	139.50
12	LRPF (MW)	0.00	438.00	0.00	0.00	0.00	437.00	452.46	437.00	438.00	437.00	0.00	0.0	438.20
13	PMOH	117.57	52.08	121.77	72.97	0.00	38.55	76.67	96.42	41.67	50.90	0.00	0.0	668.58
14	LRPM (MW)	438.00	438.00	583.31	438.00	0.00	437.00	440.66	437.08	437.00	567.77	0.00	0.0	474.40
15	NSC	1312	1312	1312	1312	1312	1312	1312	1312	1312	1312	1312	0.0	1312
16	OPERBTU (MBTU)	2780735	3120013	4424648	3946277	4279099	4209446	4554274	4607010	3138192	3465417	3340432	0.0	41865543
17	NET GEN	411337.0	466252.0	674119.0	594871.0	643907.0	632589.0	688562.0	693324.0	466341.0	517024.0	501501.0	0.0	6289827.0
18	ANOHR (BTU/KWH)	6760.0	6692.0	6564.0	6634.0	6646.0	6654.0	6614.0	6645.0	6729.0	6703.0	6661.0	0.0	6656.0
19	NOF (%)	42.10	52.90	69.20	63.00	66.60	67.00	70.50	71.00	49.40	58.00	53.00	0.00	60.30
20	NPC	1312	1312	1312	1312	1312	1312	1312	1312	1312	1312	1312	0.0	1312

21	ANOHR EQUATION	$ANOHR = A+B(N.O.F)$ A=0 B=0
----	----------------	---------------------------------

NOTE : LINE 17 IS DATA WHEN THE UNIT IS SYNCHRONIZED TO THIS SYSTEM

ISSUED BY: FLORIDA POWER AND LIGHT CO.

FILED:
 SUSPENDED:
 EFFECTIVE:
 DOCKET NO:
 ORDER NO:

ACTUAL PERFORMANCE DATA
 COMPANY: FLORIDA POWER AND LIGHT
 FROM: Jan-2022 TO: Dec-2022

		PLANT/UNIT: St. Lucie Nuclear - PSL											PSL-01	
		Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	Ytd
1	EAF (%)	98.00	99.40	99.30	100.00	99.40	99.40	99.40	99.40	4.80	73.30	47.40	0.00	83.70
2	PH	744.00	672.00	743.00	720.00	744.00	720.00	744.00	744.00	720.00	744.00	721.00	0.0	8016.00
3	SH	744.00	672.00	743.00	720.00	744.00	720.00	744.00	744.00	46.78	657.95	721.00	0.0	7256.73
4	RSH	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.0	0.00
5	UH	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	673.22	86.05	0.00	0.0	759.27
6	POH	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	672.00	86.05	0.00	0.0	758.05
7	FOH	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	1.22	0.00	0.00	0.0	1.22
8	MOH	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.0	0.00
9	PPOH	532.80	672.00	742.98	0.00	744.00	720.00	744.00	744.00	18.28	43.22	0.00	0.0	4961.28
10	LRPP (MW)	19.55	6.32	7.09	0.00	6.38	6.38	6.38	6.38	645.84	628.96	0.00	0.0	15.67
11	PFOH	211.18	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	85.75	435.98	0.0	732.92
12	LRPF (MW)	19.60	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	970.82	853.60	0.0	627.00
13	PMOH	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.0	0.00
14	LRPM (MW)	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.0	0.00
15	NSC	981	981	981	981	981	981	981	981	981	981	981	0.0	981
16	OPERBTU (MBTU)	7538977	6872799	7598187	7360621	7602107	7346792	7594439	7591173	402280	6613179	7105242	0.0	73625796
17	NET GEN	732926.0	669212.0	736952.0	712907.0	736962.0	702800.0	729478.0	730534.0	37408.0	631377.0	676064.0	0.0	7096620.0
18	ANOHR (BTU/KWH)	10286.0	10270.0	10310.0	10325.0	10315.0	10454.0	10411.0	10391.0	10754.0	10474.0	10510.0	0.0	10375.0
19	NOF (%)	100.40	101.50	101.10	100.90	101.00	99.50	100.00	100.10	70.60	97.50	95.60	0.00	99.60
20	NPC	981	981	981	981	981	981	981	981	981	981	981	0.0	981

21	ANOHR EQUATION	$ANOHR = A+B(N.O.F)$ A=0 B=0
----	----------------	---------------------------------

NOTE : LINE 17 IS DATA WHEN THE UNIT IS SYNCHRONIZED TO THIS SYSTEM

FILED:
 SUSPENDED:
 EFFECTIVE:
 DOCKET NO:
 ORDER NO:

ISSUED BY: FLORIDA POWER AND LIGHT CO.

ACTUAL PERFORMANCE DATA
 COMPANY: FLORIDA POWER AND LIGHT
 FROM: Jan-2022 TO: Dec-2022

		PLANT/UNIT: St. Lucie Nuclear - PSL											PSL-02	
		Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	Ytd
1	EAF (%)	53.80	100.00	100.00	100.00	100.00	99.20	100.00	100.00	100.00	100.00	100.00	0.00	95.60
2	PH	744.00	672.00	743.00	720.00	744.00	720.00	744.00	744.00	720.00	744.00	721.00	0.0	8016.00
3	SH	408.75	672.00	743.00	720.00	744.00	720.00	744.00	744.00	720.00	744.00	721.00	0.0	7680.75
4	RSH	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.0	0.00
5	UH	335.25	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.0	335.25
6	POH	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.0	0.00
7	FOH	335.25	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.0	335.25
8	MOH	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.0	0.00
9	PPOH	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.0	0.00
10	LRPP (MW)	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.0	0.00
11	PFOH	26.25	0.00	0.00	0.00	0.00	150.45	0.00	0.00	0.00	0.00	0.00	0.0	176.70
12	LRPF (MW)	332.66	0.00	0.00	0.00	0.00	38.36	0.00	0.00	0.00	0.00	0.00	0.0	82.08
13	PMOH	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.0	0.00
14	LRPM (MW)	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.0	0.00
15	NSC	986	986	986	986	986	986	986	986	986	986	986	0.0	986
16	OPERBTU (MBTU)	4121057	6916015	7650462	7414598	7660265	7349340	7661279	7661205	7414721	7661106	7424647	0.0	78934695
17	NET GEN	405132.0	682917.0	751846.0	727858.0	752368.0	707883.0	746323.0	747770.0	718376.0	746435.0	726436.0	0.0	7713344.0
18	ANOHR (BTU/KWH)	10172.0	10127.0	10176.0	10187.0	10182.0	10382.0	10265.0	10245.0	10322.0	10264.0	10221.0	0.0	10234.0
19	NOF (%)	99.00	103.10	102.60	102.50	102.60	99.70	101.70	101.90	101.20	101.80	102.20	0.00	101.80
20	NPC	986	986	986	986	986	986	986	986	986	986	986	0.0	986

21	ANOHR EQUATION	$ANOHR = A+B(N.O.F)$ A=0 B=0
----	----------------	---------------------------------

NOTE : LINE 17 IS DATA WHEN THE UNIT IS SYNCHRONIZED TO THIS SYSTEM

FILED:
 SUSPENDED:
 EFFECTIVE:
 DOCKET NO:
 ORDER NO:

ISSUED BY: FLORIDA POWER AND LIGHT CO.

ACTUAL PERFORMANCE DATA
 COMPANY: FLORIDA POWER AND LIGHT
 FROM: Jan-2022 TO: Dec-2022

		PLANT/UNIT: Sanford - PSR											PSR-05	
		Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	Ytd
1	EAF (%)	99.40	96.60	93.50	99.50	100.00	98.80	86.60	100.00	99.60	88.00	99.90	0.00	96.50
2	PH	744.00	672.00	743.00	720.00	744.00	720.00	744.00	744.00	720.00	744.00	721.00	0.0	8016.00
3	SH	464.82	390.13	672.18	621.05	744.00	720.00	711.87	722.38	720.00	719.00	614.00	0.0	7099.43
4	RSH	279.18	278.02	23.13	98.95	0.00	0.00	32.13	21.62	0.00	25.00	107.00	0.0	865.03
5	UH	0.00	3.85	47.69	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.0	51.54
6	POH	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.0	0.00
7	FOH	0.00	3.85	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.0	3.85
8	MOH	0.00	0.00	47.68	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.0	47.68
9	PPOH	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.0	0.00
10	LRPP (MW)	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.0	0.00
11	PFOH	10.13	9.92	1.60	0.00	0.00	0.00	2.35	1.35	12.42	22.85	4.22	0.0	64.83
12	LRPF (MW)	149.88	181.42	295.00	0.00	0.00	0.00	195.00	281.77	291.00	195.00	291.00	0.0	214.77
13	PMOH	12.92	69.95	0.00	14.42	0.00	34.35	396.35	0.00	0.00	342.68	0.00	0.0	870.67
14	LRPM (MW)	295.00	295.00	0.00	295.00	0.00	291.00	291.00	0.00	0.00	291.00	0.00	0.0	291.45
15	NSC	1164	1164	1164	1164	1164	1164	1164	1164	1164	1164	1164	0.0	1164
16	OPERBTU (MBTU)	1655861	1566883	3241344	2822069	3504540	3318382	3118184	3660135	3494074	2946624	2941212	0.0	32269308
17	NET GEN	223112.0	213433.0	454521.0	390283.0	491055.0	462639.0	433506.0	514872.0	487317.0	406500.0	409951.0	0.0	4487189.0
18	ANOHR (BTU/KWH)	7422.0	7341.0	7131.0	7231.0	7137.0	7173.0	7193.0	7109.0	7170.0	7249.0	7175.0	0.0	7191.0
19	NOF (%)	41.00	46.70	58.10	53.90	56.70	55.20	52.30	61.20	58.20	48.60	57.30	0.00	54.20
20	NPC	1164	1164	1164	1164	1164	1164	1164	1164	1164	1164	1164	0.0	1164

21	ANOHR EQUATION	$ANOHR = A+B(N.O.F)$ A=0 B=0
----	----------------	---------------------------------

NOTE : LINE 17 IS DATA WHEN THE UNIT IS SYNCHRONIZED TO THIS SYSTEM

FILED:
 SUSPENDED:
 EFFECTIVE:
 DOCKET NO:
 ORDER NO:

ISSUED BY: FLORIDA POWER AND LIGHT CO.

ACTUAL PERFORMANCE DATA
 COMPANY: FLORIDA POWER AND LIGHT
 FROM: Jan-2022 TO: Dec-2022

		PLANT/UNIT: Turkey Point Nuclear - PTN											PTN-03	
		Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	Ytd
1	EAF (%)	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00	0.00	100.00
2	PH	744.00	672.00	743.00	720.00	744.00	720.00	744.00	744.00	720.00	744.00	721.00	0.0	8016.00
3	SH	744.00	672.00	743.00	720.00	744.00	720.00	744.00	744.00	720.00	744.00	721.00	0.0	8016.00
4	RSH	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.0	0.00
5	UH	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.0	0.00
6	POH	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.0	0.00
7	FOH	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.0	0.00
8	MOH	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.0	0.00
9	PPOH	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.0	0.00
10	LRPP (MW)	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.0	0.00
11	PFOH	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.0	0.00
12	LRPF (MW)	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.0	0.00
13	PMOH	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.0	0.00
14	LRPM (MW)	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.0	0.00
15	NSC	837	837	837	837	837	837	837	837	837	837	837	0.0	837
16	OPERBTU (MBTU)	6698242	6057460	6698581	6490264	6705519	6489766	6707121	6706623	6490611	6707165	6498805	0.0	72250157
17	NET GEN	650567.0	587963.0	648244.0	625553.0	641643.0	616745.0	635802.0	635020.0	615725.0	643514.0	622784.0	0.0	6923559.0
18	ANOHR (BTU/KWH)	10296.0	10302.0	10333.0	10375.0	10451.0	10523.0	10549.0	10561.0	10541.0	10423.0	10435.0	0.0	10435.0
19	NOF (%)	104.50	104.50	104.20	103.80	103.00	102.30	102.10	102.00	102.20	103.30	103.20	0.00	103.20
20	NPC	837	837	837	837	837	837	837	837	837	837	837	0.0	837

21	ANOHR EQUATION	$ANOHR = A+B(N.O.F)$ A=0 B=0
----	----------------	---------------------------------

NOTE : LINE 17 IS DATA WHEN THE UNIT IS SYNCHRONIZED TO THIS SYSTEM

FILED:
 SUSPENDED:
 EFFECTIVE:
 DOCKET NO:
 ORDER NO:

ISSUED BY: FLORIDA POWER AND LIGHT CO.

ACTUAL PERFORMANCE DATA
COMPANY: FLORIDA POWER AND LIGHT
FROM: Jan-2022 TO: Dec-2022

		PLANT/UNIT: Turkey Point Nuclear - PTN											PTN-04	
		Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	Ytd
1	EAF (%)	100.00	100.00	33.10	58.10	100.00	100.00	100.00	100.00	100.00	100.00	100.00	0.00	90.00
2	PH	744.00	672.00	743.00	720.00	744.00	720.00	744.00	744.00	720.00	744.00	721.00	0.0	8016.00
3	SH	744.00	672.00	264.02	465.70	744.00	720.00	744.00	744.00	720.00	744.00	721.00	0.0	7282.72
4	RSH	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.0	0.00
5	UH	0.00	0.00	478.98	254.30	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.0	733.28
6	POH	0.00	0.00	478.98	254.30	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.0	733.28
7	FOH	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.0	0.00
8	MOH	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.0	0.00
9	PPOH	0.00	0.00	28.17	76.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.0	104.17
10	LRPP (MW)	0.00	0.00	539.20	491.71	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.0	504.55
11	PFOH	0.00	0.00	0.00	23.67	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.0	23.67
12	LRPF (MW)	0.00	0.00	0.00	118.75	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.0	118.75
13	PMOH	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.0	0.00
14	LRPM (MW)	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.0	0.00
15	NSC	844	844	844	844	844	844	844	844	844	844	844	0.0	844
16	OPERBTU (MBTU)	6707598	6058327	2252124	3818721	6705887	6490568	6706861	6707273	6490546	6707208	6500602	0.0	65145714
17	NET GEN	654745.0	590616.0	215892.0	367576.0	649093.0	626013.0	644865.0	644317.0	624671.0	651847.0	632163.0	0.0	6301797.0
18	ANOHR (BTU/KWH)	10245.0	10258.0	10432.0	10389.0	10331.0	10368.0	10400.0	10410.0	10390.0	10290.0	10283.0	0.0	10338.0
19	NOF (%)	104.30	104.10	96.30	92.90	103.40	103.00	102.70	102.60	102.80	103.80	103.90	0.00	102.50
20	NPC	844	844	844	844	844	844	844	844	844	844	844	0.0	844

21	ANOHR EQUATION	ANOHR = A+B(N.O.F) A=0 B=0
----	----------------	-------------------------------

NOTE : LINE 17 IS DATA WHEN THE UNIT IS SYNCHRONIZED TO THIS SYSTEM

ISSUED BY: FLORIDA POWER AND LIGHT CO.

FILED:
SUSPENDED:
EFFECTIVE:
DOCKET NO:
ORDER NO:

ACTUAL PERFORMANCE DATA
 COMPANY: FLORIDA POWER AND LIGHT
 FROM: Jan-2022 TO: Dec-2022

PLANT/UNIT: West County Energy Center - PWC														PWC-01
		Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	Ytd
1	EAF (%)	95.40	55.70	78.60	98.70	94.80	100.00	96.50	94.90	80.60	52.00	51.80	0.00	82.00
2	PH	744.00	672.00	743.00	720.00	744.00	720.00	744.00	744.00	720.00	744.00	721.00	0.0	8016.00
3	SH	744.00	672.00	743.00	720.00	744.00	720.00	744.00	744.00	720.00	657.60	693.63	0.0	7902.23
4	RSH	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	11.28	0.00	0.0	11.28
5	UH	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	75.12	27.37	0.0	102.49
6	POH	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.0	0.00
7	FOH	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.0	0.00
8	MOH	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	75.12	27.37	0.0	102.48
9	PPOH	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	384.00	668.88	693.63	0.0	1746.52
10	LRPP (MW)	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	421.00	477.02	465.65	0.0	460.19
11	PFOH	6.08	0.00	12.15	3.17	7.43	0.20	1.52	6.68	34.85	14.75	1.75	0.0	88.58
12	LRPF (MW)	427.00	0.00	427.00	490.00	421.00	262.93	421.00	421.00	421.06	481.70	258.00	0.0	431.25
13	PMOH	95.93	664.62	295.72	23.27	107.33	0.00	77.08	107.03	0.00	68.82	273.45	0.0	1713.25
14	LRPM (MW)	427.00	566.21	660.60	427.00	427.00	0.00	421.00	421.00	0.00	441.42	296.23	0.0	500.39
15	NSC	1264	1264	1264	1264	1264	1264	1264	1264	1264	1264	1264	0.0	1264
16	OPERBTU (MBTU)	3576705	2709144	4164742	4538185	4452987	4590422	4843780	4913601	3968298	2554611	2559483	0.0	42871957
17	NET GEN	507462.0	383946.0	606196.0	658921.0	637150.0	662902.0	700847.0	696696.0	567851.0	355458.0	355740.0	0.0	6133169.0
18	ANOHR (BTU/KWH)	7048.0	7056.0	6870.0	6887.0	6989.0	6925.0	6911.0	7053.0	6988.0	7187.0	7195.0	0.0	6990.0
19	NOF (%)	54.00	45.20	64.60	72.40	67.80	72.80	74.50	74.10	62.40	42.80	40.60	0.00	61.40
20	NPC	1264	1264	1264	1264	1264	1264	1264	1264	1264	1264	1264	0.0	1264

21	ANOHR EQUATION	$ANOHR = A+B(N.O.F)$ A=0 B=0
----	----------------	---------------------------------

NOTE : LINE 17 IS DATA WHEN THE UNIT IS SYNCHRONIZED TO THIS SYSTEM

FILED:
 SUSPENDED:
 EFFECTIVE:
 DOCKET NO:
 ORDER NO:

ISSUED BY: FLORIDA POWER AND LIGHT CO.

ACTUAL PERFORMANCE DATA
 COMPANY: FLORIDA POWER AND LIGHT
 FROM: Jan-2022 TO: Dec-2022

		PLANT/UNIT: West County Energy Center - PWC											PWC-02	
		Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	Ytd
1	EAF (%)	89.60	47.50	0.00	0.00	77.40	98.80	98.60	94.60	98.50	91.40	95.90	0.00	72.20
2	PH	744.00	672.00	743.00	720.00	744.00	720.00	744.00	744.00	720.00	744.00	721.00	0.0	8016.00
3	SH	744.00	336.00	0.00	0.00	647.65	720.00	744.00	744.00	720.00	744.00	721.00	0.0	6120.65
4	RSH	0.00	0.00	0.00	0.00	1.40	0.00	0.00	0.00	0.00	0.00	0.00	0.0	1.40
5	UH	0.00	336.00	743.00	720.00	94.95	0.00	0.00	0.00	0.00	0.00	0.00	0.0	1893.95
6	POH	0.00	336.00	743.00	720.00	34.60	0.00	0.00	0.00	0.00	0.00	0.00	0.0	1833.60
7	FOH	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.0	0.00
8	MOH	0.00	0.00	0.00	0.00	60.35	0.00	0.00	0.00	0.00	0.00	0.00	0.0	60.35
9	PPOH	0.00	45.90	0.00	0.00	150.18	0.00	0.00	0.00	0.00	0.00	0.00	0.0	196.08
10	LRPP (MW)	0.00	466.25	0.00	0.00	364.12	0.00	0.00	0.00	0.00	0.00	0.00	0.0	388.03
11	PFOH	3.58	0.00	0.00	0.00	5.23	26.75	0.00	0.00	0.00	0.02	2.37	0.0	37.95
12	LRPF (MW)	426.00	0.00	0.00	0.00	448.90	421.00	0.00	0.00	0.00	283.00	421.00	0.0	425.26
13	PMOH	226.68	0.00	0.00	0.00	80.90	0.00	32.43	121.02	33.33	192.62	87.25	0.0	774.23
14	LRPM (MW)	426.00	0.00	0.00	0.00	439.48	0.00	421.00	421.00	421.00	421.00	421.00	0.0	424.39
15	NSC	1264	1264	1264	1264	1264	1264	1264	1264	1264	1264	1264	0.0	1264
16	OPERBTU (MBTU)	3124528	1556660	15	80	3321403	4301599	4904091	4909158	4726574	4446094	4531085	0.0	35821286
17	NET GEN	435387.0	217135.0	-234.0	-2273.0	464009.0	610349.0	711382.0	703288.0	684105.0	640399.0	660300.0	0.0	5123847.0
18	ANOHR (BTU/KWH)	7176.0	7169.0	0.0	0.0	7158.0	7048.0	6894.0	6980.0	6909.0	6943.0	6862.0	0.0	6991.0
19	NOF (%)	46.30	51.10	0.00	0.00	56.70	67.10	75.70	74.80	75.20	68.10	72.50	0.00	66.20
20	NPC	1264	1264	1264	1264	1264	1264	1264	1264	1264	1264	1264	0.0	1264

21	ANOHR EQUATION	ANOHR = A+B(N.O.F) A=0 B=0												
----	----------------	-------------------------------	--	--	--	--	--	--	--	--	--	--	--	--

NOTE : LINE 17 IS DATA WHEN THE UNIT IS SYNCHRONIZED TO THIS SYSTEM

FILED:
 SUSPENDED:
 EFFECTIVE:
 DOCKET NO:
 ORDER NO:

ISSUED BY: FLORIDA POWER AND LIGHT CO.

ACTUAL PERFORMANCE DATA
 COMPANY: FLORIDA POWER AND LIGHT
 FROM: Jan-2022 TO: Dec-2022

		PLANT/UNIT: West County Energy Center - PWC											PWC-03	
		Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	Ytd
1	EAF (%)	91.00	85.70	98.50	94.10	96.50	95.50	100.00	100.00	98.60	88.60	100.00	0.00	95.40
2	PH	744.00	672.00	743.00	720.00	744.00	720.00	744.00	744.00	720.00	744.00	721.00	0.0	8016.00
3	SH	744.00	614.90	743.00	720.00	744.00	720.00	744.00	744.00	720.00	653.03	721.00	0.0	7867.93
4	RSH	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	25.43	0.00	0.0	25.43
5	UH	0.00	57.10	0.00	0.00	0.00	0.00	0.00	0.00	0.00	65.54	0.00	0.0	122.64
6	POH	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.0	0.00
7	FOH	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.0	0.00
8	MOH	0.00	57.10	0.00	0.00	0.00	0.00	0.00	0.00	0.00	65.53	0.00	0.0	122.63
9	PPOH	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.0	0.00
10	LRPP (MW)	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.0	0.00
11	PFOH	85.97	17.40	33.57	0.00	16.23	2.05	0.30	0.00	4.23	0.17	0.00	0.0	159.92
12	LRPF (MW)	432.42	427.00	416.58	0.00	193.88	490.00	490.00	0.00	421.00	490.00	0.00	0.0	404.90
13	PMOH	111.17	77.13	0.00	135.95	67.02	95.27	0.00	0.00	25.75	25.53	0.00	0.0	537.82
14	LRPM (MW)	427.87	542.36	0.00	392.30	446.49	417.49	0.00	0.00	421.00	965.22	0.00	0.0	460.96
15	NSC	1264	1264	1264	1264	1264	1264	1264	1264	1264	1264	1264	0.0	1264
16	OPERBTU (MBTU)	3202078	2953733	4747223	3977365	4303684	4592274	4999279	4905123	4696821	3901323	4625033	0.0	46903936
17	NET GEN	449976.0	414860.0	685536.0	568092.0	611312.0	660762.0	721848.0	711120.0	674373.0	551542.0	656128.0	0.0	6705549.0
18	ANOHR (BTU/KWH)	7116.0	7120.0	6925.0	7001.0	7040.0	6950.0	6926.0	6898.0	6965.0	7073.0	7049.0	0.0	6995.0
19	NOF (%)	47.90	53.40	73.00	62.40	65.00	72.60	76.80	75.60	74.10	66.80	72.00	0.00	67.40
20	NPC	1264	1264	1264	1264	1264	1264	1264	1264	1264	1264	1264	0.0	1264

21	ANOHR EQUATION	ANOHR = A+B(N.O.F) A=0 B=0
----	----------------	-------------------------------

NOTE : LINE 17 IS DATA WHEN THE UNIT IS SYNCHRONIZED TO THIS SYSTEM

FILED:
 SUSPENDED:
 EFFECTIVE:
 DOCKET NO:
 ORDER NO:

ISSUED BY: FLORIDA POWER AND LIGHT CO.

ACTUAL PERFORMANCE DATA
 COMPANY: FLORIDA POWER AND LIGHT
 FROM: Jan-2022 TO: Dec-2022

		PLANT/UNIT: Turkey Point - TP5											TP5-05	
		Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	Ytd
1	EAF (%)	91.90	82.90	98.50	99.90	96.80	97.10	93.90	96.00	93.90	85.50	63.60	0.00	91.00
2	PH	744.00	672.00	743.00	720.00	744.00	720.00	744.00	744.00	720.00	744.00	721.00	0.0	8016.00
3	SH	690.77	595.07	743.00	720.00	744.00	720.00	744.00	744.00	720.00	679.97	459.02	0.0	7559.82
4	RSH	53.23	2.57	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	64.08	0.0	119.88
5	UH	0.00	74.36	0.00	0.00	0.00	0.00	0.00	0.00	0.00	64.03	197.90	0.0	336.30
6	POH	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	64.03	197.90	0.0	261.93
7	FOH	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.0	0.00
8	MOH	0.00	74.37	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.0	74.37
9	PPOH	0.00	0.00	0.00	2.70	0.00	0.00	0.00	0.00	0.00	11.15	25.38	0.0	39.23
10	LRPP (MW)	0.00	0.00	0.00	485.00	0.00	0.00	0.00	0.00	0.00	949.91	891.77	0.0	880.30
11	PFOH	1.18	1.28	0.83	0.00	0.00	16.63	0.00	15.73	9.47	0.00	0.73	0.0	45.87
12	LRPF (MW)	195.00	485.00	218.19	0.00	0.00	372.94	0.00	316.00	437.75	0.00	195.00	0.0	359.67
13	PMOH	391.00	228.78	71.05	0.00	96.02	63.83	181.78	102.47	224.20	141.13	130.22	0.0	1630.48
14	LRPM (MW)	195.00	222.88	195.00	0.00	313.77	316.00	316.00	316.00	228.84	316.00	453.21	0.0	267.49
15	NSC	1265	1265	1265	1265	1265	1265	1265	1265	1265	1265	1265	0.0	1265
16	OPERBTU (MBTU)	2739812	2605604	4714767	4271314	4159094	3827604	4433094	4407437	4116951	3632412	2518371	0.0	41426462
17	NET GEN	370766.0	357278.0	676669.0	602020.0	591573.0	539731.0	634019.0	628945.0	585472.0	509823.0	346481.0	0.0	5842776.0
18	ANOHR (BTU/KWH)	7390.0	7293.0	6968.0	7095.0	7031.0	7092.0	6992.0	7008.0	7032.0	7125.0	7268.0	0.0	7090.0
19	NOF (%)	42.40	47.50	72.00	66.00	62.90	59.30	67.40	66.80	64.30	59.30	59.70	0.00	61.10
20	NPC	1265	1265	1265	1265	1265	1265	1265	1265	1265	1265	1265	0.0	1265

21	ANOHR EQUATION	ANOHR = A+B(N.O.F) A=0 B=0
----	----------------	-------------------------------

NOTE : LINE 17 IS DATA WHEN THE UNIT IS SYNCHRONIZED TO THIS SYSTEM

FILED:
 SUSPENDED:
 EFFECTIVE:
 DOCKET NO:
 ORDER NO:

ISSUED BY: FLORIDA POWER AND LIGHT CO.

ACTUAL PERFORMANCE DATA
 COMPANY: FLORIDA POWER AND LIGHT
 FROM: Jan-2022 TO: Dec-2022

PLANT/UNIT: Cape Canaveral - PCC		PCC-03		
DATE	OUTAGE TYPE(1)	HOURS	(MW) AFFECTED	DESCRIPTION
2022-01-10	PMO	118.3	244.00	PCC Block De-rate Had one loop of condenser out of service for cleaning
2022-01-10	PMO	45.9	205.25	PCC Block De-rate Had one loop of condenser out of service for cleaning
2022-01-10	PMO	118.3	104.37	PCC Block De-rate Had one loop of condenser out of service for cleaning
2022-01-10	PMO	60.2	104.37	PCC Block De-rate Had one loop of condenser out of service for cleaning
2022-01-12	PMO	62.1	275.00	PCC 31 Borescope Turbine
2022-01-12	PMO	62.1	205.25	PCC Block De-rate Had one loop of condenser out of service for cleaning
2022-01-13	PMO	168.6	275.00	PCC 3-3 Borescope Turbine
2022-01-13	PMO	58.0	104.37	PCC Block De-rate Had one loop of condenser out of service for cleaning
2022-01-15	PMO	10.2	205.25	PCC Block De-rate Had one loop of condenser out of service for cleaning
2022-01-15	PFO	0.5	96.77	PCC 3-1 Partial Forced CRH Valve Failed to open
2022-01-15	PFO	0.5	163.00	PCC 3-1 Partial Forced CRH Valve Failed to open
2022-02-03	PMO	17.5	275.00	PCC 3-3 SNOW HP FW Block Valve Repair
2022-02-03	PMO	1.4	163.00	PCC 3-3 SNOW HP FW Block Valve Repair
2022-02-03	PFO	7.9	487.00	PCC 3-0 EFOR Switchgear Transformer Breaker
2022-02-03	PMO	7.9	163.00	PCC 3-3 SNOW HP FW Block Valve Repair
2022-02-03	PFO	5.9	275.00	PCC 3-2 EFOR Switchgear Transformer Breaker
2022-02-03	PMO	8.1	163.00	PCC 3-3 SNOW HP FW Block Valve Repair
2022-02-11	PPO	768.5	275.00	PCC 31 HGP
2022-02-11	PPO	768.5	163.00	PCC 31 HGP
2022-03-18	PPO	659.0	275.00	PCC CT 33 HGP
2022-03-18	PPO	3.6	163.00	PCC CT 33 HGP
2022-03-19	PMO	9.1	275.00	PCC 3-2 Collector Brush System Installation
2022-03-19	PMO	10.3	487.00	PCC 3-0 Collector Brush System Installation
2022-03-19	PPO	10.3	163.00	PCC CT 33 HGP
2022-03-19	PPO	2.2	163.00	PCC CT 33 HGP
2022-03-19	PFO	2.9	487.00	PCC 3-0 Failed to sync due to relay protections
2022-03-19	PPO	2.9	163.00	PCC CT 33 HGP
2022-03-19	PFO	2.9	274.00	PCC 3-0 Failed to sync due to relay protections
2022-03-19	PFO	0.9	274.00	PCC 3-0 Failed to sync due to relay protections
2022-03-19	PFO	2.9	274.00	PCC 3-0 Failed to sync due to relay protections
2022-03-19	PFO	4.1	275.00	PCC 3-2 Missed RFC due to ST failure to sync
2022-03-19	PFO	2.0	274.00	PCC 3-0 Failed to sync due to relay protections
2022-03-19	PPO	639.9	163.00	PCC CT 33 HGP
2022-03-24	PMO	116.3	275.00	PCC 3-2 SNO Tube Leak Repair
2022-03-30	PFO	39.9	275.00	PCC 32 EFOR Turning Gear Anomaly and HRSG Tube Leak
2022-04-07	PMO	127.6	275.00	PCC 3-2 SNOW witch hat inspection
2022-04-13	PFO	1.8	275.00	EFOR - CT32 Trip Due to Fans Soft Tagged
2022-04-13	PFO	1.8	163.00	EFOR - CT32 Trip Due to Fans Soft Tagged
2022-04-17	PMO	70.8	275.00	Cape Canaveral Condenser Cleaning - PCC CT MOF
2022-04-17	PMO	70.8	163.00	Cape Canaveral Condenser Cleaning - PCC CT MOF
2022-04-17	PMO	14.1	275.00	Cape Canaveral Condenser Cleaning - PCC CT MOF
2022-04-17	PMO	14.1	163.00	Cape Canaveral Condenser Cleaning - PCC CT MOF
2022-04-19	PMO	14.5	275.00	Cape Canaveral Condenser Cleaning - PCC CT MOF
2022-04-19	PMO	14.5	163.00	Cape Canaveral Condenser Cleaning - PCC CT MOF
2022-04-19	PMO	41.5	275.00	Cape Canaveral Condenser Cleaning
2022-04-19	PMO	17.4	163.00	Cape Canaveral Condenser Cleaning
2022-04-20	PMO	24.0	163.00	Cape Canaveral Condenser Cleaning
2022-04-21	PMO	109.3	275.00	Cape Canaveral Condenser Cleaning - PCC CT-33 MOF

2022-04-21	PMO		13.4	163.00	Cape Canaveral Condenser Cleaning - PCC CT-33 MOF
2022-04-21	PMO		95.9	163.00	Cape Canaveral Condenser Cleaning - PCC CT-33 MOF
2022-04-22	PMO		15.9	275.00	Cape Canaveral Condenser Cleaning - PCC CT MOF
2022-04-22	PMO		15.9	163.00	Cape Canaveral Condenser Cleaning - PCC CT MOF
2022-04-25	PMO		17.4	275.00	Cape Canaveral Condenser Cleaning - PCC CT MOF
2022-04-25	PMO		17.4	163.00	Cape Canaveral Condenser Cleaning - PCC CT MOF
2022-04-26	PMO		16.6	275.00	Cape Canaveral Condenser Cleaning - PCC CT MOF
2022-04-26	PMO		16.6	163.00	Cape Canaveral Condenser Cleaning - PCC CT MOF
2022-04-26	PMO		14.3	275.00	Cape Canaveral Condenser Cleaning - PCC CT MOF
2022-04-26	PMO		14.3	163.00	Cape Canaveral Condenser Cleaning - PCC CT MOF
2022-04-27	PMO		14.9	275.00	Cape Canaveral Condenser Cleaning - PCC CT MOF
2022-04-27	PMO		14.9	163.00	Cape Canaveral Condenser Cleaning - PCC CT MOF
2022-04-27	PMO		15.0	275.00	Cape Canaveral Condenser Cleaning - PCC CT MOF
2022-04-27	PMO		13.6	163.00	Cape Canaveral Condenser Cleaning - PCC CT MOF
2022-04-28	PMO		1.3	163.00	Cape Canaveral Condenser Cleaning - PCC CT MOF
2022-04-28	PMO		14.4	275.00	Cape Canaveral Condenser Cleaning - PCC CT MOF
2022-04-28	PMO		14.4	163.00	Cape Canaveral Condenser Cleaning - PCC CT MOF
2022-04-28	PMO		14.2	275.00	Cape Canaveral Condenser Cleaning - PCC CT MOF
2022-04-28	PMO		12.4	163.00	Cape Canaveral Condenser Cleaning - PCC CT MOF
2022-04-29	PMO		1.7	163.00	Cape Canaveral Condenser Cleaning - PCC CT MOF
2022-04-29	PMO		61.0	275.00	Cape Canaveral Condenser Cleaning - PCC CT MOF
2022-04-29	PMO		61.0	163.00	Cape Canaveral Condenser Cleaning - PCC CT MOF
2022-04-30	PFO		0.7	275.00	PCC CT 33 failed to synchronize. Delayed RFC
2022-04-30	PFO		0.7	163.00	PCC CT 33 failed to synchronize. Delayed RFC
2022-05-01	PFO		0.5	275.00	Startup Failure: CT32 Inlet Damper Failed to Auto Open due to Logic
2022-05-01	PFO		0.5	163.00	Startup Failure: CT32 Inlet Damper Failed to Auto Open due to Logic
2022-05-10	PMO		35.3	275.00	Maintenance Outage: Liquid Fuel Testing
2022-05-10	PMO		35.3	163.00	Maintenance Outage: Liquid Fuel Testing
2022-05-12	PMO		4.7	275.00	Maintenance Outage: Liquid Fuel Testing
2022-05-12	PMO		4.7	163.00	Maintenance Outage: Liquid Fuel Testing
2022-05-12	PMO		21.4	275.00	Maintenance Outage: Liquid Fuel Testing
2022-05-12	PMO		21.4	163.00	Maintenance Outage: Liquid Fuel Testing
2022-05-13	PMO		1.6	275.00	Maintenance Outage: Liquid Fuel Testing
2022-05-13	PMO		1.6	163.00	Maintenance Outage: Liquid Fuel Testing
2022-05-13	PMO		16.6	275.00	Maintenance Outage: Liquid Fuel Testing
2022-05-13	PMO		16.6	163.00	Maintenance Outage: Liquid Fuel Testing
2022-05-14	PMO		4.5	275.00	Maintenance Outage: Liquid Fuel Testing
2022-05-14	PMO		4.5	163.00	Maintenance Outage: Liquid Fuel Testing
2022-05-14	PMO		3.2	275.00	Maintenance Outage: Liquid Fuel Testing
2022-05-14	PMO		3.2	163.00	Maintenance Outage: Liquid Fuel Testing
2022-05-14	PMO		2.5	275.00	Maintenance Outage: Liquid Fuel Testing
2022-05-14	PMO		2.5	163.00	Maintenance Outage: Liquid Fuel Testing
2022-05-14	PMO		12.3	275.00	Maintenance Outage: Liquid Fuel Testing
2022-05-14	PMO		12.3	163.00	Maintenance Outage: Liquid Fuel Testing
2022-05-20	PMO		11.4	487.00	Maintenance Outage: ST Brush Replacement
2022-05-21	PFO		1.1	487.00	Forced Outage: ST Tripped When Placing to SLIDING
2022-05-21	PFO		49.0	487.00	Forced Outage: ST Tripped When Placing To SLIDING and EHC Pump Issue

2022-06-06	PFO		2.5	275.00	Forced Outage CT31 SFC1 Breaker Failed To Close And BAB-40 86 Lockout
2022-06-06	PFO		2.5	163.00	Forced Outage CT31 SFC1 Breaker Failed To Close And BAB-40 86 Lockout
2022-06-07	PFO		0.7	275.00	Forced Outage CT31 HP Bypass Failed to Open
2022-06-07	PFO		0.7	163.00	Forced Outage CT31 HP Bypass Failed to Open
2022-06-08	PFO		61.3	275.00	Forced Outage CT33 High Exhaust Temp Spread Trip
2022-06-08	PFO		61.3	163.00	Forced Outage CT33 High Exhaust Temp Spread Trip
2022-07-02	PMO		5.4	487.00	Maintenance Outage: ST Collector Brush Replacement
2022-07-03	PFO		45.9	275.00	Force Outage: HRSG 31 IP Econ Leak
2022-07-03	PFO		45.9	162.00	Force Outage: HRSG 31 IP Econ Leak
2022-07-08	PMO		46.6	275.00	Maintenance Outage: CT33 Main Fuel Gas Filter Replacement
2022-07-08	PMO		46.6	162.00	Maintenance Outage: CT33 Main Fuel Gas Filter Replacement
2022-07-14	PFO		5.7	275.00	Startup Failure: CT33 High Temperature Spread Trip
2022-07-14	PFO		5.7	162.30	Startup Failure: CT33 High Temperature Spread Trip
2022-07-15	PFO		1.1	275.00	Startup Failure: CT33 High Temperature Spread Trip
2022-07-15	PFO		1.1	162.30	Startup Failure: CT33 High Temperature Spread Trip
2022-07-19	PFO		3.9	275.00	Force Outage: CT31 Temperature Spread Trip Thermocouple Failure
2022-07-19	PFO		3.9	162.30	Force Outage: CT31 Temperature Spread Trip Thermocouple Failure
2022-08-06	PMO		22.0	275.00	Maintenance Outage: Turning Gear Oil Leak Repair
2022-08-06	PMO		1.3	162.00	Maintenance Outage: Turning Gear Oil Leak Repair
2022-08-06	PMO		6.2	487.00	Maintenance Outage: Collector Brush Replacement
2022-08-06	PMO		6.2	162.00	Maintenance Outage: Turning Gear Oil Leak Repair
2022-08-07	PMO		14.5	162.00	Maintenance Outage: Turning Gear Oil Leak Repair
2022-08-18	PFO		0.8	66.00	Partial Forced Outage: CT33 Protective SD - GV2 Bad Quality
2022-08-18	PFO		0.8	131.00	Partial Forced Outage: CT33 Protective SD - GV2 Bad Quality
2022-08-18	PMO		20.2	275.00	Maintenance Outage: CT33 GV2 Repair and NG Tuning
2022-08-18	PMO		20.2	162.30	Maintenance Outage: CT33 GV2 Repair and NG Tuning
2022-08-19	PMO		15.0	275.00	Maintenance Outage: CT33 GV2 Repair and NG Tuning
2022-08-19	PMO		15.0	162.30	Maintenance Outage: CT33 GV2 Repair and NG Tuning
2022-08-27	PMO		4.5	487.00	Maintenance Outage: Collector Brush Replacement
2022-09-16	PMO		31.2	275.00	Maintenance Outage: HP FW Valve Packing Replacement
2022-09-16	PMO		31.2	162.30	Maintenance Outage: HP FW Valve Packing Replacement
2022-09-29	PFO		1.6	487.00	Forced Outage: ST Protective Shutdown due to CRH Non Return Valve
2022-09-29	PFO		5.1	487.00	Forced Outage: ST Shutdown - Load Limitation - Related To Prior Event
2022-09-30	PFO		29.8	275.00	Forced Outage: CT31 Exciter Breaker Failed to Close
2022-09-30	PFO		29.8	162.30	Forced Outage: CT31 Exciter Breaker Failed to Close
2022-10-06	PO		889.0	1312.00	Cape Canaveral CT33 Planned Outage
2022-11-12	PO		237.1	1312.00	PCC ST Planned Outage
2022-11-21	PPO		94.4	275.00	Cape Canaveral CT31 Planned Outage Extension
2022-11-21	PPO		21.4	275.00	PCC CT33 Planned Outage Extension
2022-11-21	PPO		8.6	487.00	PCC ST Planned Outage
2022-11-22	PPO		0.0	275.00	PCC 33 Tuning
2022-11-22	PPO		17.4	275.00	PCC 33 Tuning
2022-11-24	PPO		0.0	275.00	PCC 33 Tuning
2022-11-24	PPO		10.7	275.00	PCC 33 Tuning
2022-11-25	PPO		0.0	275.00	PCC 33 Tuning
2022-11-25	PPO		24.4	275.00	PCC 33 Tuning
2022-11-26	PPO		0.0	275.00	PCC 31 Tuning
2022-11-26	PPO		14.3	275.00	PCC 31 Tuning
2022-11-26	PPO		0.0	275.00	PCC 33 Tuning
2022-11-26	PPO		0.7	275.00	PCC 33 Tuning

2022-11-26	PPO	0.0	275.00	PCC 33 Tuning
2022-11-26	PPO	0.6	275.00	PCC 33 Tuning
2022-11-26	PPO	0.0	275.00	PCC 31 Tuning
2022-11-26	PPO	3.6	275.00	PCC 31 Tuning
2022-11-26	PPO	0.0	275.00	PCC 32 Tuning
2022-11-26	PPO	19.4	275.00	PCC 32 Tuning
2022-11-26	PPO	19.4	160.00	PCC 32 Tuning
2022-11-27	PPO	0.0	275.00	PCC 32 Tuning
2022-11-27	PPO	24.9	275.00	PCC 32 Tuning
2022-11-27	PPO	24.9	160.00	PCC 32 Tuning
2022-11-27	PPO	0.0	275.00	PCC 31 Tuning
2022-11-27	PPO	0.7	275.00	PCC 31 Tuning
2022-11-27	PPO	0.0	275.00	PCC 31 Tuning
2022-11-27	PPO	0.6	275.00	PCC 31 Tuning
2022-11-27	PPO	0.0	275.00	PCC 31 Tuning
2022-11-27	PPO	17.3	275.00	PCC 31 Tuning
2022-11-27	PPO	16.4	160.00	PCC 31 Tuning
2022-11-28	PPO	0.9	160.00	PCC 31 Tuning
2022-11-28	PPO	0.0	275.00	PCC 32 Tuning
2022-11-28	PPO	4.7	275.00	PCC 32 Tuning
2022-11-28	PPO	0.4	160.00	PCC 32 Tuning
2022-11-28	PPO	4.2	160.00	PCC 32 Tuning
2022-11-28	PPO	0.0	275.00	PCC 31 Tuning
2022-11-28	PPO	0.6	275.00	PCC 3-1 Tuning
2022-11-28	PPO	0.0	275.00	PCC 32 Tuning
2022-11-28	PPO	0.0	160.00	PCC 32 Tuning
2022-11-28	PPO	42.8	275.00	PCC 32 Tuning
2022-11-28	PPO	42.8	160.00	PCC 32 Tuning
2022-11-28	PPO	0.0	275.00	PCC 31 Tuning
2022-11-28	PPO	21.3	275.00	PCC 3-1 Tuning
2022-11-29	PPO	0.0	275.00	PCC 3-1 Tuning
2022-11-29	PPO	0.6	275.00	PCC 3-1 Tuning
2022-11-29	PPO	0.0	275.00	PCC 3-1 Tuning
2022-11-29	PPO	25.4	275.00	PCC 3-1 Tuning
2022-11-30	PPO	0.0	275.00	PCC 32 Tuning
2022-11-30	PPO	0.0	162.00	PCC 32 Tuning
2022-11-30	PPO	0.7	275.00	PCC 32 Tuning
2022-11-30	PPO	0.7	162.00	PCC 32 Tuning

(1) FFO - FULL FORCED OUTAGE
PPO - PARTIAL PLANNED OUTAGE
PMO - PARTIAL MAINTENANCE OUTAGE
PO - PLANNED OUTAGE
PFO - PARTIAL FORCED OUTAGE
FMO - FULL MAINTENANCE OUTAGE

FILED:
SUSPENDED:
EFFECTIVE:
DOCKET NO:
ORDER NO:

ISSUED BY: FLORIDA POWER AND LIGHT CO.

ACTUAL PERFORMANCE DATA
 COMPANY: FLORIDA POWER AND LIGHT
 FROM: Jan-2022 TO: Dec-2022

PLANT/UNIT: Fort Myers - PFM		PFM-02		
DATE	OUTAGE TYPE(1)	HOURS	(MW) AFFECTED	DESCRIPTION
2022-01-10	PFO	13.0	195.00	PFM 2D EFOR - Flame scanners
2022-01-19	PFO	40.5	195.00	2B EFOR- Boiler Feed Pump Bearings
2022-01-19	PFO	40.5	27.00	2B EFOR- Boiler Feed Pump Bearings
2022-01-19	PFO	40.5	105.00	2B EFOR- Boiler Feed Pump Bearings
2022-01-25	PMO	69.2	195.00	2D Event MOF repair IP steam leak
2022-01-30	PFO	3.9	195.00	PFM 2D EFOR - 2D exhaust spread trip
2022-02-02	PFO	2.8	95.00	PFM 2A PARTIAL EFOR DERATED 1A LP FEED PUMP TRIP VALVE
2022-02-02	PFO	7.0	55.00	PFM 2B EFOR PARTIAL DERATE DUE TO 1A LP FEED PUMP TRIP VALVE
2022-02-02	PFO	7.0	55.00	PFM 2C EFOR PARTIAL DERATE DUE TO 1A LP FEED PUMP TRIP VALVE
2022-02-02	PFO	7.0	55.00	PFM 2D EFOR PARTIAL DERATE DUE TO 1A LP FEED PUMP TRIP VALVE
2022-02-02	PFO	7.0	55.00	PFM 2E EFOR PARTIAL DERATE DUE TO 1A LP FEED PUMP TRIP VALVE
2022-02-02	PFO	2.8	14.90	PFM 2A PARTIAL EFOR DERATED 1A LP FEED PUMP TRIP VALVE
2022-02-02	PFO	7.0	5.53	PFM 2C EFOR PARTIAL DERATE DUE TO 1A LP FEED PUMP TRIP VALVE
2022-02-02	PFO	7.0	0.25	PFM 2D EFOR PARTIAL DERATE DUE TO 1A LP FEED PUMP TRIP VALVE
2022-02-02	PFO	7.0	0.28	PFM 2E EFOR PARTIAL DERATE DUE TO 1A LP FEED PUMP TRIP VALVE
2022-02-02	PFO	7.0	30.03	PFM ST1 EFOR PARTIAL DERATE DUE TO 1A LP FEED PUMP TRIP VALVE
2022-02-02	PFO	2.8	67.50	PFM 2A PARTIAL EFOR DERATED 1A LP FEED PUMP TRIP VALVE
2022-02-02	PFO	7.0	17.00	PFM 2C EFOR PARTIAL DERATE DUE TO 1A LP FEED PUMP TRIP VALVE
2022-02-02	PFO	7.0	0.76	PFM 2D EFOR PARTIAL DERATE DUE TO 1A LP FEED PUMP TRIP VALVE
2022-02-02	PFO	7.0	0.84	PFM 2E EFOR PARTIAL DERATE DUE TO 1A LP FEED PUMP TRIP VALVE
2022-02-02	PFO	7.0	83.88	PFM ST2 EFOR PARTIAL DERATE DUE TO 1A LP FEED PUMP TRIP VALVE
2022-02-06	PFO	50.9	195.00	PFM 2F EFOR - HPIP BFP Outboard Motor Bearing Temp
2022-02-09	PFO	3.3	195.00	PFM 2B EFOR - 2B tripped on GCV4 OSCILL HIHI
2022-02-18	PMO	78.4	195.00	2F SNOW
2022-02-19	PFO	0.9	195.00	2D CT Trip
2022-02-19	PFO	0.9	32.00	2D CT Trip
2022-02-19	PFO	0.9	120.00	2D CT Trip
2022-03-15	PMO	48.7	195.00	2C TASK MOF - Replace Aux Stop Valve
2022-03-16	PFO	11.7	195.00	2F trip
2022-03-16	PFO	11.7	27.00	2F trip
2022-03-16	PFO	11.7	105.00	2F trip
2022-03-19	PMO	44.2	195.00	2F CT MOF
2022-03-22	PFO	2.1	195.00	2A EFOR HPIP BFP Trip
2022-03-24	PMO	54.4	195.00	2B Task MOF
2022-04-07	PFO	2.5	195.00	PFM 2A EFOR - 2A TRIP DUE TO VSV LVDT FAILURE.
2022-04-09	PFO	0.4	195.00	2F CT EFOR
2022-04-09	PFO	0.4	27.00	2F CT EFOR
2022-04-09	PFO	0.4	106.00	2F CT EFOR
2022-04-13	PFO	1.4	195.00	2F CTHRSV VSVs Trip
2022-04-14	PMO	47.7	195.00	2E CT MOF Various Repairs
2022-04-27	PFO	100.2	195.00	2F Task MOF
2022-05-09	PFO	24.5	143.00	PFM 1ST EFOR - Hydraulic oil leak
2022-05-09	PFO	23.2	461.00	PFM 2ST EFOR - Hydraulic oil leak
2022-05-27	PFO	46.1	195.00	2A EFOR NOT GO ON TURNING GEAR
2022-05-31	PMO	96.3	195.00	2E Task MOF
2022-06-02	PFO	3.4	195.00	2C EFOR due to IGV LVDT failure
2022-06-27	PMO	1.0	143.00	ST 1 Task MOF
2022-06-27	PMO	1.0	194.00	ST 1 Task MOF
2022-06-27	PMO	1.0	194.00	ST 1 Task MOF
2022-06-27	PMO	1.0	194.00	ST 1 Task MOF
2022-06-27	PMO	1.0	194.00	ST 1 Task MOF
2022-06-27	PMO	1.0	194.00	ST 1 Task MOF
2022-06-27	PMO	1.0	194.00	ST 1 Task MOF
2022-06-27	PMO	1.0	194.00	ST 1 Task MOF
2022-06-27	PMO	1.0	460.00	ST 1 Task MOF
2022-07-07	PFO	2.3	195.00	2C EFOR due to PM3 gas valve feedback differential
2022-07-18	PFO	0.7	195.00	PFM 2C EFOR - Trip on high drum level
2022-07-18	PFO	0.7	23.84	PFM 2C EFOR - Trip on high drum level

2022-07-18	PFO		0.7	76.83	PFM 2C EFOR - Trip on high drum level
2022-07-22	PFO		1.3	195.00	2B CT EFOR Unit Tripped Due To GCV3 Fault Error HI HI Alarm
2022-08-02	PFO		12.0	195.00	2C EFOR PM3 Feedback Error
2022-08-02	PFO		12.0	23.83	2C EFOR PM3 Feedback Error
2022-08-02	PFO		12.0	76.82	2C EFOR PM3 Feedback Error
2022-08-02	PFO		81.5	35.00	2C Partial EFOR - PM3 Valve Sticks at 68%
2022-08-02	PFO		126.9	4.00	2C Partial EFOR - PM3 Valve Sticks at 68%
2022-08-02	PFO		126.9	14.00	2C Partial EFOR - PM3 Valve Sticks at 68%
2022-08-05	PMO		45.3	195.00	2C Event MOF - SNOW taken to replace PM3 Gas Valve
2022-08-05	PFO		45.3	35.00	2C Partial EFOR - PM3 Valve Sticks at 68%
2022-08-16	PMO		74.9	195.00	2F EVENT MOF - repair IP riser leak and flame scanners
2022-08-16	PMO		74.9	23.79	2F EVENT MOF - repair IP riser leak and flame scanners
2022-08-16	PMO		74.9	76.80	2F EVENT MOF - repair IP riser leak and flame scanners
2022-08-18	PFO		8.1	195.00	PFM 2D EFOR - Failed PM1 Gas Control Valve Digital Motor Controller
2022-08-18	PFO		8.1	23.79	PFM 2D EFOR - Failed PM1 Gas Control Valve Digital Motor Controller
2022-08-18	PFO		8.1	76.80	PFM 2D EFOR - Failed PM1 Gas Control Valve Digital Motor Controller
2022-08-20	PMO		46.2	195.00	PFM 2B Event MOF - SNOW Taken To Repair Flange On HPIP Boiler Feed Pump
2022-08-20	PMO		46.2	23.79	PFM 2B Event MOF - SNOW Taken To Repair Flange On HPIP Boiler Feed Pump
2022-08-20	PMO		46.2	76.80	PFM 2B Event MOF - SNOW Taken To Repair Flange On HPIP Boiler Feed Pump
2022-08-25	PFO		0.8	195.00	2B EFOR HP feed water block valve closed causing BFP and unit to trip
2022-08-25	PFO		0.8	23.79	2B EFOR HP feed water block valve closed causing BFP and unit to trip
2022-08-25	PFO		0.8	76.80	2B EFOR HP feed water block valve closed causing BFP and unit to trip
2022-08-29	PFO		1.0	195.00	PFM 2A EFOR - Trip due to low HP drum level
2022-08-29	PFO		1.0	23.79	PFM 2A EFOR - Trip due to low HP drum level
2022-08-29	PFO		1.0	76.80	PFM 2A EFOR - Trip due to low HP drum level
2022-09-06	PFO		2.3	195.00	PFM 2C EFOR - Unit tripped on IGV feedback error
2022-09-06	PFO		2.3	23.79	PFM 2C EFOR - Unit tripped on IGV feedback error
2022-09-06	PFO		2.3	76.80	PFM 2C EFOR - Unit tripped on IGV feedback error
2022-09-12	PMO		49.9	195.00	PFM 2D Event MOF - SNOW taken to fix IP riser leak
2022-09-12	PMO		49.9	23.79	PFM 2D Event MOF - SNOW taken to fix IP riser leak
2022-09-12	PMO		49.9	76.80	PFM 2D Event MOF - SNOW taken to fix IP riser leak
2022-09-16	PMO		59.7	195.00	2A Event MOF - SNOW taken to fix HP feedwater valve
2022-09-16	PMO		59.7	23.79	2A Event MOF - SNOW taken to fix HP feedwater valve
2022-09-16	PMO		59.7	76.80	2A Event MOF - SNOW taken to fix HP feedwater valve
2022-09-19	PMO		131.9	195.00	2A Event MOF - SNOW taken to fix HP isolation valve and HP blowdown
2022-09-19	PMO		131.9	23.79	2A Event MOF - SNOW taken to fix HP isolation valve and HP blowdown
2022-09-19	PMO		131.9	76.80	2A Event MOF - SNOW taken to fix HP isolation valve and HP blowdown
2022-09-25	PFO		49.2	195.00	PFM 2F EFOR - IP riser leak
2022-09-25	PFO		49.2	23.79	PFM 2F EFOR - IP riser leak
2022-09-25	PFO		49.2	76.80	PFM 2F EFOR - IP riser leak
2022-09-29	PFO		1.4	195.00	PFM 2D EFOR - BFP Trip
2022-09-29	PMO		29.0	195.00	2E Event MOF - IP riser leak
2022-09-29	PMO		29.0	23.79	2E Event MOF - IP riser leak
2022-09-29	PMO		29.0	76.80	2E Event MOF - IP riser leak
2022-10-01	PMO		128.5	195.00	2E Event MOF - IP riser leak
2022-10-01	PMO		128.5	71.50	2E Event MOF - IP riser leak

2022-10-01	PMO	128.5	82.69	2E Event MOF - IP riser leak
2022-10-03	PFO	85.3	35.00	PFM 2 Partial EFOR - Circulating pump debris filter failure
2022-10-03	PFO	85.3	35.00	PFM 2 Partial EFOR - Circulating pump debris filter failure
2022-10-03	PFO	85.3	35.00	PFM 2 Partial EFOR - Circulating pump debris filter failure
2022-10-03	PFO	85.3	35.00	PFM 2 Partial EFOR - Circulating pump debris filter failure
2022-10-03	PFO	77.8	194.00	PFM 2 Partial EFOR - Circulating pump debris filter failure
2022-10-03	PFO	85.3	35.00	PFM 2 Partial EFOR - Circulating pump debris filter failure
2022-10-03	PFO	77.8	71.50	PFM 2 Partial EFOR - Circulating pump debris filter failure
2022-10-03	PFO	77.8	82.69	PFM 2 Partial EFOR - Circulating pump debris filter failure
2022-10-06	PFO	7.5	194.00	PFM 2 Partial EFOR - Circulating pump debris filter failure
2022-10-06	PFO	7.5	71.50	PFM 2 Partial EFOR - Circulating pump debris filter failure
2022-10-06	PFO	7.5	82.69	PFM 2 Partial EFOR - Circulating pump debris filter failure
2022-10-12	PFO	4.4	195.00	PFM 2B EFOR - Aux stop valve failed to open
2022-10-12	PFO	4.4	23.79	PFM 2B EFOR - Aux stop valve failed to open
2022-10-12	PFO	4.4	76.80	PFM 2B EFOR - Aux stop valve failed to open
2022-10-16	PFO	22.1	195.00	PFM 2F EFOR - Fuel Gas Valve PM2 Sticking Open
2022-10-16	PFO	22.1	23.79	PFM 2F EFOR - Fuel Gas Valve PM2 Sticking Open
2022-10-16	PFO	22.1	76.80	PFM 2F EFOR - Fuel Gas Valve PM2 Sticking Open
2022-10-18	PMO	133.8	195.00	2C Event MOF - PC Work And IP Risers
2022-10-18	PMO	133.8	23.79	2C Event MOF - PC Work And IP Risers
2022-10-18	PMO	133.8	76.80	2C Event MOF - PC Work And IP Risers
2022-10-19	PMO	54.1	195.00	2D Task MOF - Perform Offline Water Wash
2022-10-19	PMO	54.1	23.79	2D Task MOF - Perform Offline Water Wash
2022-10-19	PMO	54.1	76.80	2D Task MOF - Perform Offline Water Wash
2022-10-21	PMO	117.8	195.00	2A Task MOF - P and C Compliance Testing
2022-10-21	PMO	73.0	23.79	2A Task MOF - P and C Compliance Testing
2022-10-21	PMO	73.0	76.80	2A Task MOF - P and C Compliance Testing
2022-10-24	PMO	44.8	23.79	2A Task MOF - P and C Compliance Testing
2022-10-24	PMO	44.8	76.80	2A Task MOF - P and C Compliance Testing
2022-10-30	PFO	2.7	195.00	PFM 2A Startup Failure - PM2 gas valve issue
2022-10-30	PFO	2.7	23.79	PFM 2A Startup Failure - PM2 gas valve issue
2022-10-30	PFO	2.7	76.80	PFM 2A Startup Failure - PM2 gas valve issue
2022-10-30	PFO	24.3	195.00	PFM 2A EFOR - PM2 gas control valve acting erratically
2022-10-30	PFO	24.3	23.79	PFM 2A EFOR - PM2 gas control valve acting erratically
2022-10-30	PFO	24.3	76.80	PFM 2A EFOR - PM2 gas control valve acting erratically
2022-11-02	PPO	616.7	195.00	PFM 2D POF - HGP and Tech 2.0 upgrade
2022-11-02	PPO	616.7	23.79	PFM 2D POF - HGP and Tech 2.0 upgrade
2022-11-02	PPO	616.7	76.80	PFM 2D POF - HGP and Tech 2.0 upgrade
2022-11-11	PMO	50.3	195.00	PFM 2F Event MOF - Economizer drain valve packing leak and lift oil leak
2022-11-11	PMO	50.3	23.79	PFM 2F Event MOF - Economizer drain valve packing leak and lift oil leak
2022-11-11	PMO	50.3	76.80	PFM 2F Event MOF - Economizer drain valve packing leak and lift oil leak
2022-11-13	PFO	34.7	195.00	PFM 2E EFOR - Unit shutdown due to HP superheater steam leak
2022-11-13	PFO	34.7	23.79	PFM 2E EFOR - Unit shutdown due to HP superheater steam leak
2022-11-13	PFO	34.7	76.80	PFM 2E EFOR - Unit shutdown due to HP superheater steam leak
2022-11-29	PPO	1.3	195.00	PFM 2D POF - Software update necessary to complete tuning
2022-11-29	PPO	1.3	23.79	PFM 2D POF - Software update necessary to complete tuning
2022-11-29	PPO	1.3	76.80	PFM 2D POF - Software update necessary to complete tuning
2022-11-30	PFO	1.1	195.00	PFM 2A EFOR - 2A tripped on vital AC inverter failure

2022-11-30	PFO		1.1	195.00	PFM 2C EFOR - 2C unavailable on vital AC inverter failure
2022-11-30	PFO		1.1	195.00	PFM 2E EFOR - Unit tripped on vital AC inverter failure
2022-11-30	PFO		1.1	23.79	PFM 2A EFOR - 2A tripped on vital AC inverter failure
2022-11-30	PFO		1.1	23.79	PFM 2C EFOR - 2C unavailable on vital AC inverter failure
2022-11-30	PFO		1.1	23.79	PFM 2E EFOR - Unit tripped on vital AC inverter failure
2022-11-30	PFO		1.1	76.80	PFM 2A EFOR - 2A tripped on vital AC inverter failure
2022-11-30	PFO		1.1	76.80	PFM 2C EFOR - 2C unavailable on vital AC inverter failure
2022-11-30	PFO		1.1	76.80	PFM 2E EFOR - Unit tripped on vital AC inverter failure
2022-11-30	PPO		6.3	33.72	PFM 2D PD - Derating for tuning coming back from Tech 2.0 HGP upgrade

(1) FFO - FULL FORCED OUTAGE
PPO - PARTIAL PLANNED OUTAGE
PMO - PARTIAL MAINTENANCE OUTAGE
PO - PLANNED OUTAGE
PFO - PARTIAL FORCED OUTAGE
FMO - FULL MAINTENANCE OUTAGE

FILED:
SUSPENDED:
EFFECTIVE:
DOCKET NO:
ORDER NO:

ISSUED BY: FLORIDA POWER AND LIGHT CO.

ACTUAL PERFORMANCE DATA
 COMPANY: FLORIDA POWER AND LIGHT
 FROM: Jan-2022 TO: Dec-2022

PLANT/UNIT: Manatee - PM3		PM3-03		
DATE	OUTAGE TYPE(1)	HOURS	(MW) AFFECTED	DESCRIPTION
2022-01-04	PFO	1.8	195.00	PMT 3D EFOR - AUX STOP VALVE SOLENOID FAILURE
2022-01-04	PFO	1.8	119.75	PMT 3D EFOR - AUX STOP VALVE SOLENOID FAILURE
2022-01-09	PFO	19.7	195.00	PMT 3B EFOR - TRIPPED ON HIGH HIGH HAZ GAS GAS COMPARTMENT
2022-01-09	PFO	19.7	119.75	PMT 3B EFOR - TRIPPED ON HIGH HIGH HAZ GAS GAS COMPARTMENT
2022-01-23	PFO	8.6	195.00	3D Tripped on High Exhaust Spread
2022-02-06	PMO	65.7	195.00	3C Snow
2022-03-10	PFO	3.5	195.00	3A Failed startup
2022-03-13	PFO	4.7	195.00	3D Gas Vent failed during startup
2022-03-13	PFO	4.7	119.75	3D Gas Vent failed during startup
2022-03-14	PFO	4.7	195.00	3C TRIP During Startup
2022-03-14	PFO	4.7	119.75	3C TRIP During Startup
2022-03-15	PPO	336.0	195.00	3C POF HGP
2022-03-15	PPO	336.0	119.75	3C POF HGP
2022-03-29	PPO	105.6	195.00	3C POF Extension HGP
2022-03-29	PPO	105.6	119.75	3C POF Extension HGP
2022-04-03	PPO	0.0	195.00	3C POF HGP
2022-04-03	PPO	0.0	119.75	3C POF HGP
2022-04-03	PPO	13.2	195.00	3C POF Extension HGP
2022-04-03	PPO	13.2	119.75	3C POF Extension HGP
2022-04-03	PPO	113.3	195.00	3A POF
2022-04-03	PPO	6.4	119.25	3A POF
2022-04-03	PPO	106.5	119.25	3A POF
2022-04-05	PPO	64.0	195.00	3D POF - HGP
2022-04-05	PPO	63.6	18.87	3D POF - HGP
2022-04-07	PMO	0.4	458.00	Unit 3 Block Snow
2022-04-07	PPO	91.7	119.25	3A POF
2022-04-07	PPO	91.7	18.87	3D POF - HGP
2022-04-08	PMO	0.2	195.00	Unit 3 Block Snow
2022-04-08	FMO	87.6	1238.00	Unit 3 Block Snow
2022-04-11	PPO	211.6	195.00	3A POF
2022-04-11	PMO	3.6	458.00	Unit 3 Block Snow
2022-04-11	PPO	280.2	195.00	3D POF - HGP
2022-04-11	PMO	1.6	195.00	Unit 3 Block Snow
2022-04-11	PPO	208.0	119.25	3A POF
2022-04-11	PPO	276.6	18.87	3D POF - HGP
2022-04-16	PFO	34.9	195.00	PMT 3B EFOR Gen and Exciter Breaker Trip
2022-04-16	PFO	34.9	119.25	PMT 3B EFOR Gen and Exciter Breaker Trip
2022-04-20	PPO	0.9	195.00	3A POF
2022-04-20	PPO	0.9	100.38	3A POF
2022-04-21	PPO	10.5	195.00	3A POF
2022-04-21	PMO	25.9	195.00	PMT 3C Event MOF - SNOW taken to repair leak on fuel gas heat exchanger
2022-04-21	PMO	25.9	100.88	PMT 3C Event MOF - SNOW taken to repair leak on fuel gas heat exchanger
2022-04-23	PPO	465.9	195.00	3B Spring planned outage
2022-04-23	PPO	61.6	100.88	3B Spring planned outage
2022-04-23	PFO	10.6	45.00	PMT 3C Partial EFOR - IP Back Pressure Valve Positioner Failure
2022-04-23	PFO	10.6	18.37	PMT 3C Partial EFOR - IP Back Pressure Valve Positioner Failure
2022-04-23	PPO	51.3	195.00	PMT 3D POF Extension - Extension of HGP event 20220148
2022-04-23	PPO	51.3	0.50	PMT 3D POF Extension - Extension of HGP event 20220148
2022-04-25	PFO	7.8	195.00	PMT 3A EFOR - Unit tripped on high BFP Suction Strainer DP
2022-04-25	PFO	1.3	18.87	PMT 3A EFOR - Unit tripped on high BFP Suction Strainer DP
2022-04-25	PFO	0.7	458.00	PMT3 ST EFOR - Unit tripped due to operator forcing the wrong point
2022-04-25	PPO	0.7	100.88	3B Spring planned outage
2022-04-25	PFO	0.7	18.87	PMT 3A EFOR - Unit tripped on high BFP Suction Strainer DP
2022-04-25	PPO	403.6	100.88	3B Spring planned outage
2022-04-25	PFO	5.7	18.87	PMT 3A EFOR - Unit tripped on high BFP Suction Strainer DP
2022-04-26	PFO	0.9	195.00	PMT 3A EFOR - Unit tripped on low IP drum level
2022-04-26	PFO	0.9	18.87	PMT 3A EFOR - Unit tripped on low IP drum level
2022-05-03	PFO	7.4	195.00	3A EFOR BFP Trip on Runout
2022-05-03	PFO	7.4	18.87	3A EFOR BFP Trip on Runout
2022-05-12	PPO	0.4	195.00	3B Spring planned outage

2022-05-12	PPO		0.4	119.75	3B Spring planned outage
2022-05-12	PPO		1.2	195.00	3B Spring planned outage
2022-05-13	PPO		4.3	195.00	3B Spring planned outage
2022-05-13	PPO		4.3	119.75	3B Spring planned outage
2022-05-16	PPO		28.2	195.00	3B Spring planned outage
2022-05-16	PPO		28.2	119.75	3B Spring planned outage
2022-05-19	PMO		32.6	195.00	3B Task MOF
2022-05-19	PMO		32.6	119.75	3B Task MOF
2022-06-04	PMO		19.0	195.00	PMT 3A Event MOF - SNOW taken to replace fuel gas coalescing filter
2022-06-04	PMO		19.0	114.50	PMT 3A Event MOF - SNOW taken to replace fuel gas coalescing filter
2022-06-11	PFO		3.2	195.00	PMT 3C EFOR - Trip on compressor discharge pressure deviation
2022-06-11	PFO		3.2	114.50	PMT 3C EFOR - Trip on compressor discharge pressure deviation
2022-06-20	PFO		33.1	195.00	PMT3C EFOR - Trip during startup due to hi-haz gas in gas compartment
2022-06-20	PFO		33.1	114.50	PMT3C EFOR - Trip during startup due to hi-haz gas in gas compartment
2022-07-01	PFO		3.3	195.00	3C EFOR 3C-AH-1 Accumulator Pressure Low
2022-07-01	PFO		3.3	114.50	3C EFOR 3C-AH-1 Accumulator Pressure Low
2022-08-25	PFO		4.6	195.00	PMT 3D EFOR - Trip due to high exhaust duct pressure
2022-08-25	PFO		4.6	114.50	PMT 3D EFOR - Trip due to high exhaust duct pressure
2022-08-31	PFO		0.5	195.00	PMT 3A EFOR - A tripped on low HP drum level due to operator inadvertent
2022-08-31	PFO		0.5	114.50	PMT 3A EFOR - A tripped on low HP drum level due to operator inadvertent
2022-09-03	PFO		1.2	195.00	PMT 3B EFOR - Fuel gas diverter valve not working in auto
2022-09-03	PFO		1.2	114.50	PMT 3B EFOR - Fuel gas diverter valve not working in auto
2022-09-21	PMO		105.2	195.00	PMT U3D SNOW - A042 Expansion Joints
2022-10-08	PFO		1.2	195.00	PMT 3C EFOR - Trip Due to Low LP Drum Level
2022-10-09	PFO		2.4	195.00	PMT 3C EFOR - Low LP Drum Level
2022-10-10	PFO		12.6	195.00	PMT 3D EFOR - NOx Analyzer Failed Calibration
2022-10-15	PMO		67.0	51.00	PMT 3ST Derating - Travelling Screens damage
2022-10-15	PMO		67.0	51.00	PMT 3ST Derating - Travelling Screens damage
2022-10-15	PMO		67.0	51.00	PMT 3ST Derating - Travelling Screens damage
2022-10-15	PMO		67.0	127.00	PMT 3ST Derating - Travelling Screens damage
2022-10-15	PMO		67.0	51.00	PMT 3ST Derating - Travelling Screens damage
2022-10-18	PMO		759.4	51.00	PMT U3 ST Maintenance Derating Extension - Travelling Screen
2022-10-18	PMO		682.1	51.00	PMT U3 ST Maintenance Derating Extension - Travelling Screen
2022-10-18	PMO		704.8	51.00	PMT U3 ST Maintenance Derating Extension - Travelling Screen
2022-10-18	PMO		681.8	127.00	PMT U3 ST Maintenance Derating Extension - Travelling Screen
2022-10-18	PMO		42.1	51.00	PMT U3 ST Maintenance Derating Extension - Travelling Screen
2022-10-19	PMO		260.1	195.00	3A SNOW - BFP
2022-10-19	PMO		260.1	51.00	PMT U3 ST Maintenance Derating Extension - Travelling Screen
2022-10-30	PMO		85.0	51.00	PMT U3 ST Maintenance Derating Extension - Travelling Screen
2022-11-03	PFO		6.2	195.00	EFOR PMT 3A - IGV LVDT bad feedback signal
2022-11-03	PMO		6.2	51.00	PMT U3 ST Maintenance Derating Extension - Travelling Screen
2022-11-03	PMO		370.9	51.00	PMT U3 ST Maintenance Derating Extension - Travelling Screen
2022-11-15	PFO		1.3	458.00	PMT U3 ST EFOR - Trip inadvertent forced point
2022-11-15	PMO		1.3	127.00	PMT U3 ST Maintenance Derating Extension - Travelling Screen
2022-11-15	PFO		2.0	195.00	PMT 3C EFOR - ST Trip caused 3C Trip
2022-11-15	PMO		2.0	51.00	PMT U3 ST Maintenance Derating Extension - Travelling Screen

2022-11-15	PMO	82.5	127.00	PMT U3 ST Maintenance Derating Extension - Travelling Screen
2022-11-15	PMO	81.8	51.00	PMT U3 ST Maintenance Derating Extension - Travelling Screen
2022-11-16	PFO	7.5	195.00	PMT 3D EFOR - Tripped on high exhaust temp spread
2022-11-16	PMO	7.5	51.00	PMT U3 ST Maintenance Derating Extension - Travelling Screen
2022-11-16	PMO	54.7	51.00	PMT U3 ST Maintenance Derating Extension - Travelling Screen
2022-11-18	PMO	7.7	195.00	PMT 3B SNOW - turbine assembly vibration repair
2022-11-18	PMO	86.2	51.00	PMT U3 ST Maintenance Derating Extension - Travelling Screen
2022-11-18	PMO	2.7	195.00	PMT 3A SNOW - Block Snow Valve Leak
2022-11-18	PMO	87.9	51.00	PMT U3 ST Maintenance Derating Extension - Travelling Screen
2022-11-18	PMO	1.4	458.00	PMT U3ST SNOW - Valve replacement
2022-11-18	PMO	84.9	127.00	PMT U3 ST Maintenance Derating Extension - Travelling Screen
2022-11-18	PMO	1.2	195.00	PMT 3C SNOW - Block to repair broken valve
2022-11-18	PMO	81.3	51.00	PMT U3 ST Maintenance Derating Extension - Travelling Screen
2022-11-18	FMO	78.5	1238.00	PMT U3D SNOW - Block outage valve repair
2022-11-18	PMO	112.3	51.00	PMT U3 ST Maintenance Derating Extension - Travelling Screen
2022-11-22	PMO	6.6	195.00	PMT 3A SNOW - Block Snow Valve Leak
2022-11-22	PMO	1.6	195.00	PMT 3C SNOW - Block to repair broken valve
2022-11-22	PMO	33.7	195.00	PMT U3D SNOW - Block outage valve repair
2022-11-22	PMO	5.0	458.00	PMT U3ST SNOW - Valve replacement
2022-11-22	PMO	211.3	51.00	PMT U3 ST Maintenance Derating Extension - Travelling Screen
2022-11-22	PMO	209.6	51.00	PMT U3 ST Maintenance Derating Extension - Travelling Screen
2022-11-22	PMO	206.2	127.00	PMT U3 ST Maintenance Derating Extension - Travelling Screen
2022-11-22	PMO	204.6	51.00	PMT U3 ST Maintenance Derating Extension - Travelling Screen
2022-11-23	PMO	177.5	51.00	PMT U3 ST Maintenance Derating Extension - Travelling Screen

(1) FFO - FULL FORCED OUTAGE
PPO - PARTIAL PLANNED OUTAGE
PMO - PARTIAL MAINTENANCE OUTAGE
PO - PLANNED OUTAGE
PFO - PARTIAL FORCED OUTAGE
FMO - FULL MAINTENANCE OUTAGE

FILED:
SUSPENDED:
EFFECTIVE:
DOCKET NO:
ORDER NO:

ISSUED BY: FLORIDA POWER AND LIGHT CO.

ACTUAL PERFORMANCE DATA
 COMPANY: FLORIDA POWER AND LIGHT
 FROM: Jan-2022 TO: Dec-2022

PLANT/UNIT: Martin - PM8		PM8-08		
DATE	OUTAGE TYPE(1)	HOURS	(MW) AFFECTED	DESCRIPTION
2022-01-01	PFO	2.3	195.00	EFOR 8D 89-ND Switch Malfunction
2022-01-01	PFO	2.3	110.50	EFOR 8D 89-ND Switch Malfunction
2022-01-05	PFO	0.3	195.00	EFOR 8D Compressor Bleed Valve
2022-01-05	PFO	0.3	111.00	EFOR 8D Compressor Bleed Valve
2022-01-15	PFO	3.3	195.00	EFOR 8A Trip due to Recirculation Valve
2022-01-15	PFO	3.3	110.50	EFOR 8A Trip due to Recirculation Valve
2022-01-21	PFO	1.1	195.00	EFOR 8A Trip due to Low Min Flow
2022-01-21	PFO	1.1	110.50	EFOR 8A Trip due to Low Min Flow
2022-01-23	PFO	4.4	195.00	Unit 8A EFOR Recirc Valve
2022-01-23	PFO	4.4	110.50	Unit 8A EFOR Recirc Valve
2022-01-26	PMO	26.0	195.00	SNOW: 8A Atomizing Line Walkdown
2022-01-26	PMO	26.0	110.50	SNOW: 8A Atomizing Line Walkdown
2022-01-28	PMO	1.3	195.00	SNOW: 8D Switch Yard Relay
2022-01-28	PMO	1.3	111.00	SNOW: 8D Switch Yard Relay
2022-02-03	PFO	0.6	195.00	EFOR 8C HI Drum Level Trip
2022-02-03	PFO	0.6	110.50	EFOR 8C HI Drum Level Trip
2022-02-07	PMO	40.3	195.00	SNOW: 8D Generator Bearing Check
2022-02-07	PMO	40.3	110.50	SNOW: 8D Generator Bearing Check
2022-02-09	PFO	3.5	195.00	EFOR: 8D High Stack NOX
2022-02-09	PFO	3.5	110.50	EFOR: 8D High Stack NOX
2022-02-09	PMO	85.8	195.00	SNOW: 8D HRSG SCR Cleaning
2022-02-09	PMO	85.8	110.00	SNOW: 8D HRSG SCR Cleaning
2022-02-12	PFO	15.9	95.00	EFOR: 8B Blending Valve Failure
2022-02-12	PFO	15.9	76.79	EFOR: 8B Blending Valve Failure
2022-02-12	PMO	18.8	195.00	SNOW : 8B Blending Valve Repair
2022-02-13	PMO	1.9	195.00	SNOW: 8B Blending Valve
2022-02-13	PMO	1.0	451.00	SNOW: 8B Blending Valve Repair
2022-02-13	PMO	0.7	195.00	SNOW: 8B Blending Valve Repair
2022-02-13	FMO	26.3	1231.00	SNOW: 8B Blending Valve Repair
2022-02-25	PPO	358.4	195.00	8A Hot Gas Path Outage
2022-02-25	PPO	357.4	110.50	8A Hot Gas Path Outage
2022-03-04	PFO	11.7	195.00	8C EFOR Generator Breaker Failed to Close
2022-03-04	PFO	11.7	110.50	8C EFOR Generator Breaker Failed to Close
2022-03-12	PMO	1.5	195.00	SNOW: Block 8 -
2022-03-12	PMO	0.9	451.00	SNOW: Block 8 - 8ST Offline
2022-03-12	PPO	26.4	110.50	8A Hot Gas Path Outage
2022-03-12	PMO	0.8	195.00	SNOW: Unit 8 Block - 8C
2022-03-12	FMO	25.5	1231.00	SNOW: 8B
2022-03-13	PPO	23.0	195.00	8A Hot Gas Path Outage
2022-03-13	PPO	23.0	110.50	8A Hot Gas Path Outage
2022-03-14	PMO	112.9	195.00	SNOW: 8A Thrust Bearing Replacement
2022-03-14	PMO	112.9	110.50	SNOW: 8A Thrust Bearing Replacement
2022-03-19	PPO	0.0	195.00	8A : HGP
2022-03-19	PPO	0.0	110.50	8A : HGP
2022-03-19	PPO	23.3	195.00	Planned Outage Extension 8A HGP Tuning
2022-03-19	PPO	23.3	110.50	Planned Outage Extension 8A HGP Tuning
2022-03-20	PFO	0.6	195.00	EFOR: HP Drum Hi Level Trip
2022-03-20	PFO	0.6	110.50	EFOR: HP Drum Hi Level Trip
2022-03-20	PPO	0.0	195.00	Unit 8A Planned Outage
2022-03-20	PPO	0.0	110.50	Unit 8A Planned Outage
2022-03-20	PPO	2.0	195.00	8A HGP Planned Outage Extension
2022-03-20	PPO	2.0	110.50	8A HGP Planned Outage Extension
2022-03-20	PPO	0.0	195.00	8A HGP Planned Outage
2022-03-20	PPO	0.0	110.50	8A HGP Planned Outage
2022-03-20	PPO	4.6	195.00	8A HGP Planned Outage Extension
2022-03-20	PPO	4.6	110.50	8A HGP Planned Outage Extension
2022-04-20	PMO	33.6	195.00	SNOW: Unit 8B HRSG HP Superheat Tube Leak
2022-04-20	PMO	33.6	110.50	SNOW: Unit 8B HRSG HP Superheat Tube Leak
2022-04-28	PMO	3.5	195.00	SNOW: 8C CT Broken Water Wash Belly Drains
2022-04-28	PMO	3.5	310.50	SNOW: 8C CT Broken Water Wash Belly Drains

2022-04-30	PFO		1.5	195.00	EFOR: 8C LVDT Valve Fault
2022-04-30	PFO		1.5	310.50	EFOR: 8C LVDT Valve Fault
2022-06-02	PPO		702.3	195.00	8B Planned Outage: HGPI Tech 2.0
2022-06-02	PPO		702.3	110.50	8B Planned Outage: HGPI Tech 2.0
2022-06-28	PFO		3.2	195.00	EFOR 8C LVDT Deviation
2022-06-28	PFO		3.2	110.50	EFOR 8C LVDT Deviation
2022-06-29	PFO		2.3	195.00	EFOR: 8C BFP Transmitter Failure
2022-06-29	PFO		2.3	110.50	EFOR: 8C BFP Transmitter Failure
2022-07-01	PPO		16.6	195.00	Planned Outage 8B HGP Tuning
2022-07-01	PPO		16.6	110.50	Planned Outage 8B HGP Tuning
2022-07-02	PPO		2.0	195.00	Planned Outage 8B HGP
2022-07-02	PPO		2.0	110.50	Planned Outage 8B HGP
2022-07-02	PPO		14.7	195.00	8B HGP Planned Outage
2022-07-02	PPO		14.7	110.50	8B HGP Planned Outage
2022-07-06	PPO		0.0	195.00	8B Planned Outage HGP
2022-07-06	PPO		0.0	110.50	8B Planned Outage HGP
2022-07-06	PPO		0.0	195.00	8B HGP Planned Outage
2022-07-06	PPO		0.0	110.50	8B HGP Planned Outage
2022-07-06	PPO		8.6	195.00	Unit 8B HGP Planned Outage Extension
2022-07-06	PPO		8.6	110.50	Unit 8B HGP Planned Outage Extension
2022-07-07	PPO		0.0	195.00	Unit 8B HGP Planned Outage
2022-07-07	PPO		0.0	110.50	Unit 8B HGP Planned Outage
2022-07-07	PPO		3.5	195.00	Unit 8B HGP Planned Outage Extension
2022-07-07	PPO		3.5	110.50	Unit 8B HGP Planned Outage Extension
2022-07-07	PPO		0.0	195.00	Unit 8B HGP Planned Outage
2022-07-07	PPO		0.0	110.50	Unit 8B HGP Planned Outage
2022-07-07	PPO		4.5	195.00	Unit 8B HGP Planned Outage Extension
2022-07-07	PPO		4.5	110.50	Unit 8B HGP Planned Outage Extension
2022-07-07	PPO		0.0	195.00	Unit 8B HGP Planned Outage
2022-07-07	PPO		0.0	110.50	Unit 8B HGP Planned Outage
2022-07-07	PPO		0.9	195.00	Unit 8B HGP Planned Outage Extension
2022-07-07	PPO		0.9	110.50	Unit 8B HGP Planned Outage Extension
2022-07-07	PPO		0.0	195.00	Unit 8B HGP Planned Outage
2022-07-07	PPO		0.0	110.50	Unit 8B HGP Planned Outage
2022-07-07	PPO		10.8	195.00	Unit 8B HGP Planned Outage Extension
2022-07-07	PPO		10.8	110.50	Unit 8B HGP Planned Outage Extension
2022-07-12	PFO		0.0	180.00	EFOR Derate 8B
2022-07-12	PFO		0.0	104.07	EFOR Derate 8B
2022-07-14	PFO		0.4	38.80	Partial EFOR Derate 8B LP Drum Level
2022-07-14	PFO		0.4	22.43	Partial EFOR Derate 8B LP Drum Level
2022-07-15	PFO		1.5	18.59	Partial EFOR: Derate 8B LP Drum Issues
2022-07-15	PFO		1.5	123.00	Partial EFOR: Derate 8B LP Drum Issues
2022-07-15	PMO		23.9	195.00	SNOW: PMR 8A HRSG Tube Leak
2022-07-15	PMO		23.9	115.00	SNOW: PMR 8A HRSG Tube Leak
2022-08-12	PMO		60.4	195.00	SNOW: 8C LVDT- HRSG Leak
2022-08-12	PMO		60.4	195.00	SNOW: 8C LVDT- HRSG Leak
2022-08-19	PMO		50.6	195.00	SNOW: Unit 8 LP FW Valve and HRSG Inspection
2022-08-19	PMO		50.6	195.00	SNOW: Unit 8 LP FW Valve and HRSG Inspection
2022-08-22	PFO		0.2	14.00	EFOR: Derate due to Solar Excursion
2022-08-22	PFO		0.2	14.00	EFOR: Derate due to Solar Excursion
2022-08-22	PFO		0.2	14.00	EFOR: Derate due to Solar Excursion
2022-08-22	PFO		0.2	15.00	EFOR: Derate due to Solar Excursion
2022-08-22	PFO		0.2	57.00	EFOR: Derate due to Solar Excursion
2022-08-26	PMO		48.7	195.00	SNOW: 89-ND Switch Repairs
2022-08-26	PMO		48.7	195.00	SNOW: 89-ND Switch Repairs
2022-08-31	PFO		12.9	195.00	EFOR: 8A CT Water Injection Line Rupture
2022-08-31	PFO		12.9	195.00	EFOR: 8A CT Water Injection Line Rupture
2022-09-04	PFO		121.3	195.00	EFOR: 8D GSU Oil Transformer
2022-09-04	PFO		121.3	195.00	EFOR: 8D GSU Oil Transformer
2022-09-09	PFO		22.7	195.00	EFOR : 8D IGV Actuator Error
2022-09-09	PFO		22.7	195.00	EFOR : 8D IGV Actuator Error
2022-10-19	PMO		36.5	195.00	8B SNOW: Main Steam Isolation Valve Packing Leak

2022-10-20	PMO	32.1	195.00	8A SNOW: HRSG TUBE LEAK REPAIR
2022-11-11	PMO	4.2	195.00	SNOW: PMR 8C
2022-11-11	PMO	3.6	195.00	SNOW PMR 8D
2022-11-12	PMO	0.1	451.00	SNOW: Unit 8 Block Outage
2022-11-12	FMO	70.4	1231.00	SNOW: Unit 8 Block
2022-11-15	FMO	52.5	1231.00	SNOW: PMR 8D Outage: Crossfire Tube Leak Repair
2022-11-17	PMO	5.5	451.00	SNOW: Unit 8 Block Outage
2022-11-17	PMO	150.5	195.00	SNOW: PMR 8C Outage Crossfire Tube Leaks
2022-11-17	PMO	331.4	195.00	SNOW: PMR 8D Outage: Crossfire Tube Leak Repair

(1) FFO - FULL FORCED OUTAGE
PPO - PARTIAL PLANNED OUTAGE
PMO - PARTIAL MAINTENANCE OUTAGE
PO - PLANNED OUTAGE
PFO - PARTIAL FORCED OUTAGE
FMO - FULL MAINTENANCE OUTAGE

FILED:
SUSPENDED:
EFFECTIVE:
DOCKET NO:
ORDER NO:

ISSUED BY: FLORIDA POWER AND LIGHT CO.

ACTUAL PERFORMANCE DATA
 COMPANY: FLORIDA POWER AND LIGHT
 FROM: Jan-2022 TO: Dec-2022

PLANT/UNIT: Port Everglades - PPE		PPE-05		
DATE	OUTAGE TYPE(1)	HOURS	(MW) AFFECTED	DESCRIPTION
2022-02-23	PFO	11.7	275.00	51 Forced Outage Turbine Outlet Thermocouple 5 Failure
2022-02-28	PPO	1.7	275.00	52 Spring Outage
2022-02-28	PPO	0.4	275.00	53 Spring Outage
2022-02-28	PPO	0.3	439.00	50 ST Spring Outage
2022-02-28	PO	234.7	1264.00	51 Spring Outage
2022-03-10	PPO	16.4	275.00	53 Spring Outage
2022-03-10	PPO	5.0	439.00	50 ST Spring Outage
2022-03-10	PPO	0.3	275.00	51 Spring Outage
2022-04-09	PMO	107.9	275.00	51 MOF - HP FW Block Valve
2022-04-14	PMO	0.8	275.00	53 - Block SNOW
2022-04-14	PMO	0.8	439.00	50 ST - Block SNOW
2022-04-14	FMO	22.4	1264.00	52 - Block SNOW
2022-04-15	PMO	5.1	275.00	51 MOF - HP FW Block Valve
2022-04-15	PMO	0.4	275.00	53 - Block SNOW
2022-04-15	PMO	2.4	439.00	50 ST - Block SNOW
2022-04-22	PFO	2.8	275.00	Block 5 Derate - Seaweed in Outer Loop Debris Filter
2022-04-22	PFO	2.8	156.00	Block 5 Derate - Seaweed in Outer Loop Debris Filter
2022-04-23	PFO	3.9	275.00	52 EFOR Turbine Outlet Thermocouple 1 Fault
2022-04-23	PFO	3.9	156.00	52 EFOR Turbine Outlet Thermocouple 1 Fault
2022-05-16	PMO	4.3	275.00	U5 Block SNOW
2022-05-16	PMO	3.3	275.00	U5 Block SNOW
2022-05-16	PMO	1.9	439.00	U5 Block SNOW
2022-05-16	FMO	36.5	1264.00	U5 Block SNOW
2022-05-18	PMO	3.9	275.00	U5 Block SNOW
2022-05-18	PMO	0.3	275.00	U5 Block SNOW
2022-05-18	PMO	2.4	439.00	U5 Block SNOW
2022-05-27	PMO	61.9	275.00	53 MOF - Borescope Inspection
2022-06-08	PFO	0.6	275.00	51 - Blade Path Spread Start up Failure
2022-07-01	PFO	1.1	275.00	53 - Start Up Failure Due to Fuel Gas ESV Failure
2022-07-01	PFO	1.1	146.39	53 - Start Up Failure Due to Fuel Gas ESV Failure
2022-07-22	PMO	13.3	275.00	5ST MOF - Exciter Maintenance Mode Switch Install
2022-07-22	PMO	8.4	439.00	5ST MOF - Exciter Maintenance Mode Switch Install
2022-08-12	PMO	20.0	275.00	52 MOF - LF Tuning and Repairs
2022-08-13	PMO	14.5	275.00	52 MOF - LF Tuning and Repairs
2022-08-16	PFO	4.5	275.00	52 - CT Cooling Air Valve GV2 Actuator Positioner Failure
2022-08-16	PFO	4.5	146.00	52 - CT Cooling Air Valve GV2 Actuator Positioner Failure
2022-08-29	PFO	5.5	275.00	53 Start-up Failure due to BAB36 NOT OPEN feedback
2022-08-29	PFO	5.5	147.00	53 Start-up Failure due to BAB36 NOT OPEN feedback
2022-09-16	PMO	31.1	275.00	52 MOF - Purge and Cooling Air Valve Repair
2022-09-16	PMO	31.1	149.00	52 MOF - Purge and Cooling Air Valve Repair
2022-09-30	PMO	134.3	239.00	50 - ST Half Load Clearance
2022-09-30	PMO	134.3	75.00	50 - ST Half Load Clearance
2022-09-30	PMO	134.3	75.00	50 - ST Half Load Clearance
2022-09-30	PMO	146.2	275.00	53 - MOF Borescope Inspection
2022-10-06	PFO	0.7	275.00	51 Forced Outage HP Drum Low Level
2022-10-06	PFO	0.7	146.00	51 Forced Outage HP Drum Low Level
2022-10-06	PFO	5.1	275.00	51 Forced Outage Turbine Outlet Thermocouple Bad Quality
2022-10-06	PFO	5.1	146.00	51 Forced Outage Turbine Outlet Thermocouple Bad Quality
2022-10-23	PFO	4.1	275.00	51 - Forced Outage IP Drum Level High
2022-10-23	PFO	3.3	439.00	50 Forced Outage - High Exhaust Temp Unblended CRH HRH
2022-10-24	PFO	4.4	275.00	53 Forced Outage - HP Feedwater Block Valve Failed to Open
2022-10-24	PFO	4.4	146.00	53 Forced Outage - HP Feedwater Block Valve Failed to Open
2022-11-04	PMO	2.5	275.00	51 MOF - Pipe leaks
2022-11-04	PMO	1.6	275.00	53 MOF - Pipe Leaks
2022-11-04	PMO	0.2	439.00	50 MOF - Pipe Leaks
2022-11-04	FMO	56.3	1264.00	52 MOF - Pipe Leaks
2022-11-07	PMO	0.7	275.00	52 MOF - Pipe Leaks
2022-11-07	PMO	2.1	275.00	53 MOF - Pipe Leaks
2022-11-07	PMO	3.8	439.00	50 MOF - Pipe Leaks
2022-11-07	PFO	4.4	275.00	53 SUF - SFC Fault Trip

2022-11-07	PFO	2.8	439.00	50 SUF - LP Exhaust Hood High Temp
2022-11-07	PFO	8.3	275.00	53 SUF - TOT 10 Bad Quality
2022-11-07	PFO	0.1	145.00	53 SUF - TOT 10 Bad Quality
2022-11-07	PFO	8.2	145.00	53 SUF - TOT 10 Bad Quality
2022-11-12	PFO	1.5	275.00	53 SUF - FG ESV Failed to Open
2022-11-12	PFO	1.5	145.00	53 SUF - FG ESV Failed to Open
2022-11-27	PFO	3.7	275.00	52 Forced Outage - Turbine outlet temperature double fault
2022-11-27	PFO	3.7	146.00	52 Forced Outage - Turbine outlet temperature double fault

(1) FFO - FULL FORCED OUTAGE
PPO - PARTIAL PLANNED OUTAGE
PMO - PARTIAL MAINTENANCE OUTAGE
PO - PLANNED OUTAGE
PFO - PARTIAL FORCED OUTAGE
FMO - FULL MAINTENANCE OUTAGE

FILED:
SUSPENDED:
EFFECTIVE:
DOCKET NO:
ORDER NO:

ISSUED BY: FLORIDA POWER AND LIGHT CO.

ACTUAL PERFORMANCE DATA
 COMPANY: FLORIDA POWER AND LIGHT
 FROM: Jan-2022 TO: Dec-2022

PLANT/UNIT: Riviera - PRV		PRV-05		
DATE	OUTAGE TYPE(1)	HOURS	(MW) AFFECTED	DESCRIPTION
2022-01-15	PMO	117.5	275.00	PRV 51 - Event MOF - BFP Vibration
2022-01-15	PMO	117.5	163.00	PRV 51 - Event MOF - BFP Vibration
2022-02-03	PFO	3.7	275.00	PRV 51 - EFOR - GV2 Pressure Regulator
2022-02-03	PFO	3.7	163.00	PRV 51 - EFOR - GV2 Pressure Regulator
2022-02-04	PFO	8.8	275.00	PRV 51 - EFOR - Failed GV2 Positioner
2022-02-04	PFO	8.8	163.00	PRV 51 - EFOR - Failed GV2 Positioner
2022-02-06	PMO	24.5	275.00	PRV 53 - Event MOF - Replace Fuel Oil Pilot Valve
2022-02-06	PMO	24.5	163.00	PRV 53 - Event MOF - Replace Fuel Oil Pilot Valve
2022-02-08	PFO	2.6	275.00	PRV 52 - SF - FG Vent Valve Failure
2022-02-08	PFO	2.6	163.00	PRV 52 - SF - FG Vent Valve Failure
2022-02-17	PFO	6.3	275.00	PRV 53 - EFOR - Tripped on GT Fire Protection
2022-02-17	PFO	6.3	163.00	PRV 53 - EFOR - Tripped on GT Fire Protection
2022-02-19	PFO	11.6	275.00	PRV 53 - EFOR - GT Fire Protection Trip
2022-02-19	PFO	11.6	163.00	PRV 53 - EFOR - GT Fire Protection Trip
2022-02-20	PMO	27.5	275.00	PRV 51 - Event MOF - Repair HP drum level control valve
2022-02-20	PMO	27.5	163.00	PRV 51 - Event MOF - Repair HP drum level control valve
2022-02-23	PFO	3.3	275.00	PRV 53 - EFOR - GV2 Cooling Air Pressure Sensing Line
2022-02-23	PFO	3.3	163.00	PRV 53 - EFOR - GV2 Cooling Air Pressure Sensing Line
2022-03-24	PMO	88.3	275.00	PRV 53 - Event MOF - CT Borescope and Fire Panel Upgrade
2022-03-24	PMO	88.3	163.00	PRV 53 - Event MOF - CT Borescope and Fire Panel Upgrade
2022-03-26	PMO	73.9	275.00	PRV 51 - Event MOF - CO2 Fire Panel And Pull Station Upgrade and LF SU
2022-03-26	PMO	73.9	162.00	PRV 51 - Event MOF - CO2 Fire Panel And Pull Station Upgrade and LF SU
2022-04-08	PMO	72.9	275.00	PRV 52 - Event MOF - Fire Panel Upgrade and Feed Pump Alignment
2022-04-08	PMO	72.9	163.00	PRV 52 - Event MOF - Fire Panel Upgrade and Feed Pump Alignment
2022-06-03	PFO	0.9	275.00	PRV 52 - Start Up Failure - Compressor Blow-off Valve Fail to Close
2022-06-03	PFO	0.9	162.00	PRV 52 - Start Up Failure - Compressor Blow-off Valve Fail to Close
2022-06-07	PFO	1.9	275.00	PRV 52 - EFOR - CT 52 Shaft Position Reverse Trip
2022-06-07	PFO	1.9	162.00	PRV 52 - EFOR - CT 52 Shaft Position Reverse Trip
2022-06-10	PFO	1.1	275.00	PRV 52 - SF - Compressor Blow off valve fail to indicate close
2022-06-10	PFO	1.1	162.00	PRV 52 - SF - Compressor Blow off valve fail to indicate close
2022-06-10	PMO	38.5	275.00	PRV 52- Event MOF- Replace Shaft Position Sensor Troubleshoot Bleed Vlv
2022-06-10	PMO	38.5	162.00	PRV 52- Event MOF- Replace Shaft Position Sensor Troubleshoot Bleed Vlv
2022-07-01	PFO	4.6	275.00	PRV 53 - SF - BAB36 Breaker
2022-07-01	PFO	4.6	163.00	PRV 53 - SF - BAB36 Breaker
2022-07-08	PMO	4.1	487.00	PRV ST - Event MOF - Install Maintenance Mode Switch
2022-07-09	PFO	2.4	487.00	PRV ST - Sliding Pressure Control Trip
2022-07-27	PFO	1.1	275.00	PRV 51 - SF - Bleed Off Valve 1.1
2022-07-27	PFO	1.1	163.00	PRV 51 - SF - Bleed Off Valve 1.1
2022-07-28	PMO	80.1	275.00	PRV 53 - Event MOF - Borescope - BAB36 Repair - NH3 Blower Seal
2022-07-28	PMO	80.1	163.00	PRV 53 - Event MOF - Borescope - BAB36 Repair - NH3 Blower Seal
2022-08-18	PMO	88.8	275.00	PRV 52-Event MO- IP Economizer Tube Leak
2022-08-18	PMO	88.8	162.00	PRV 52-Event MO- IP Economizer Tube Leak
2022-08-22	PFO	28.4	275.00	PRV 52-EFOR - CT 52 Auxiliary Turning Gear Engaged

2022-08-22	PFO	28.4	162.00	PRV 52-EFOR - CT 52 Auxiliary Turning Gear Engaged
2022-09-02	PMO	41.6	275.00	PRV 53-Event MO- CT Borescope
2022-09-02	PMO	41.6	162.00	PRV 53-Event MO- CT Borescope
2022-09-06	PPO	734.4	275.00	PRV-PO-52-hot gas path outage
2022-09-06	PPO	734.4	162.00	PRV-PO-52-hot gas path outage
2022-09-09	PFO	1.3	275.00	PRV 53-EFOR Event-SFC fail to start
2022-09-09	PFO	1.3	163.00	PRV 53-EFOR Event-SFC fail to start
2022-09-12	PFO	0.9	275.00	PRV 51- EFOR bus breaker fail to close
2022-09-12	PFO	0.9	163.00	PRV 51- EFOR bus breaker fail to close
2022-10-12	PFO	59.9	275.00	PRV 52-EFOR - CT 52 Turning Gear came off
2022-10-12	PFO	59.9	162.00	PRV 52-EFOR - CT 52 Turning Gear came off
2022-10-19	PMO	40.8	275.00	PRV - 51-Event MOF - LP Economizer leak.
2022-10-19	PMO	33.6	162.00	PRV - 51-Event MOF - LP Economizer leak.
2022-10-20	PMO	7.1	487.00	PRV-50-MOF Event-Common and ST Repair
2022-10-20	PMO	7.1	162.00	PRV - 51-Event MOF - LP Economizer leak.
2022-10-20	PMO	6.8	275.00	PRV 53- Event MOF-Troubleshoot duct burner scanner
2022-10-21	FMO	48.3	1312.00	PRV - 51-Event MOF - LP Economizer leak-Block
2022-10-23	PMO	10.1	275.00	PRV - 51-Event MOF - LP Economizer leak-Block
2022-10-23	PMO	6.9	275.00	PRV 53- Event MOF-Troubleshoot duct burner scanner
2022-10-23	PMO	4.4	487.00	PRV-50-MOF Event-Common and ST Repair
2022-11-07	PPO	569.0	275.00	PRV-PO-53-Hot Gas Path Outage
2022-11-07	PPO	569.0	162.00	PRV-PO-53-Hot Gas Path Outage

(1) FFO - FULL FORCED OUTAGE
PPO - PARTIAL PLANNED OUTAGE
PMO - PARTIAL MAINTENANCE OUTAGE
PO - PLANNED OUTAGE
PFO - PARTIAL FORCED OUTAGE
FMO - FULL MAINTENANCE OUTAGE

FILED:
SUSPENDED:
EFFECTIVE:
DOCKET NO:
ORDER NO:

ISSUED BY: FLORIDA POWER AND LIGHT CO.

ACTUAL PERFORMANCE DATA
COMPANY: FLORIDA POWER AND LIGHT
FROM: Jan-2022 TO: Dec-2022

PLANT/UNIT: St. Lucie Nuclear - PSL		PSL-01		
DATE	OUTAGE TYPE(1)	HOURS	(MW) AFFECTED	DESCRIPTION
2022-01-01	PFO	211.1	19.60	U1 UEL Condensate Pump Degradation 01012022
2022-01-09	PPO	532.8	19.54	U1 PEL Condensate Pump Degradation 01092022
2022-02-01	PPO	672.0	6.32	U1 PEL Secondary Efficiency Loss 02012022
2022-03-01	PPO	742.9	7.09	U1 PEL Secondary Efficiency Loss 03012022
2022-05-01	PPO	744.0	6.37	U1 PEL Secondary Efficiency Loss
2022-06-01	PPO	720.0	6.37	Condensate Pump Efficiency Loss
2022-07-01	PPO	744.0	6.37	U1 PEL Secondary Efficiency Loss
2022-08-01	PPO	744.0	6.37	U1 PEL Secondary Efficiency Loss
2022-09-02	PPO	16.5	657.56	U1 PEL MSSV Tstng
2022-09-02	PPO	1.7	537.27	SL1-31 DN PWR To BO
2022-09-02	PPO	1.2	537.27	SL1-31 DN PWR To BO
2022-09-02	FFO	1.2	981.00	SL1-30 090222 Reactor Trip 1A MFP Unplanned Energy Loss
2022-09-03	PO	672.0	981.00	SL1-31 Refueling Outage September
2022-10-01	PO	48.0	981.00	U1 SL1-30 Outage Continued
2022-10-03	PO	38.0	981.00	U1 SL1-30 Outage Extension
2022-10-04	PPO	43.2	628.96	U1 PEL SL1-31 Up Pwr 100422
2022-10-28	PFO	85.7	970.82	SL1-31 UEL 1B Heater Drain Tube Leak
2022-11-01	PFO	321.6	880.45	UEL SL1-31 1B Drain Cooler November
2022-11-14	PFO	114.3	778.04	UEL SL1-31 1B Drain Cooler Repair

(1) FFO - FULL FORCED OUTAGE
PPO - PARTIAL PLANNED OUTAGE
PMO - PARTIAL MAINTENANCE OUTAGE
PO - PLANNED OUTAGE
PFO - PARTIAL FORCED OUTAGE
FMO - FULL MAINTENANCE OUTAGE

FILED:
SUSPENDED:
EFFECTIVE:
DOCKET NO:
ORDER NO:

ISSUED BY: FLORIDA POWER AND LIGHT CO.

ACTUAL PERFORMANCE DATA
COMPANY: FLORIDA POWER AND LIGHT
FROM: Jan-2022 TO: Dec-2022

PLANT/UNIT: St. Lucie Nuclear - PSL		PSL-02		
DATE	OUTAGE TYPE(1)	HOURS	(MW) AFFECTED	DESCRIPTION
2022-01-06	PFO	8.2	328.00	U2 UEL CEA 27 Down Power 01062022
2022-01-06	FFO	307.5	986.00	U2 UEL Shut Down For CEA 27 Repair 010622
2022-01-19	FFO	27.7	986.00	U2 UEL CEA 27 Shut Down Extension for MG Set Repair 01192022
2022-01-20	PFO	0.3	334.78	U2 UEL CEA 27 Power Ascension 01202022
2022-01-20	PFO	18.0	334.78	U2 UEL CEA 27 Power Ascension 01202022
2022-06-06	PFO	150.4	38.36	Heater Drain Pump 2A Motor Replacement

(1) FFO - FULL FORCED OUTAGE
PPO - PARTIAL PLANNED OUTAGE
PMO - PARTIAL MAINTENANCE OUTAGE
PO - PLANNED OUTAGE
PFO - PARTIAL FORCED OUTAGE
FMO - FULL MAINTENANCE OUTAGE

FILED:
SUSPENDED:
EFFECTIVE:
DOCKET NO:
ORDER NO:

ISSUED BY: FLORIDA POWER AND LIGHT CO.

ACTUAL PERFORMANCE DATA
 COMPANY: FLORIDA POWER AND LIGHT
 FROM: Jan-2022 TO: Dec-2022

PLANT/UNIT: Sanford - PSR		PSR-05		
DATE	OUTAGE TYPE(1)	HOURS	(MW) AFFECTED	DESCRIPTION
2022-01-01	PMO	12.9	195.00	PSR 5C EVENT MOF - TUBE LEAK
2022-01-01	PMO	12.9	100.00	PSR 5C EVENT MOF - TUBE LEAK
2022-01-31	PFO	18.8	98.00	PSR 5C Partial EFOR - CRH steam stop stuck
2022-01-31	PFO	18.8	51.87	PSR 5C Partial EFOR - CRH steam stop stuck
2022-02-11	PFO	0.8	195.00	PSR 5B EFOR - UNIT TRIP DUE TO IP DRUM LEVEL
2022-02-11	PFO	0.8	100.00	PSR 5B EFOR - UNIT TRIP DUE TO IP DRUM LEVEL
2022-02-13	PFO	0.3	384.00	PSR 5ST EFOR - LOSS DCS
2022-02-13	PFO	0.3	195.00	PSR 5A - LOSS OF DCS
2022-02-13	PFO	0.2	195.00	PSR 5B EFOR - LOSS OF DCS
2022-02-13	PFO	0.0	195.00	PSR 5D EFOR - LOSS OF DCS
2022-02-13	FFO	3.8	1164.00	PSR 5C EFOR- LOSS OF DCS
2022-02-20	PMO	69.9	195.00	PSR 5C EVENT MOF - REPAIR CRH STEAM STOP
2022-02-20	PMO	69.9	100.00	PSR 5C EVENT MOF - REPAIR CRH STEAM STOP
2022-03-03	PFO	0.8	195.00	PSR 5D EFOR - STARTUP FAILURE - LCI
2022-03-03	PFO	0.8	100.00	PSR 5D EFOR - STARTUP FAILURE - LCI
2022-03-25	FMO	47.6	1164.00	PSR 5D EVENT MOF - SUPPORT ST IV WORK
2022-03-25	PMO	47.6	4.00	PSR 5ST EVENT MOF - SUPPORT INTERCEPT VALVE WORK
2022-03-25	PMO	47.6	4.00	PSR 5ST EVENT MOF - SUPPORT INTERCEPT VALVE WORK
2022-03-25	PMO	47.6	4.00	PSR 5ST EVENT MOF - SUPPORT INTERCEPT VALVE WORK
2022-03-25	PMO	47.6	4.00	PSR 5ST EVENT MOF - SUPPORT INTERCEPT VALVE WORK
2022-03-25	PMO	47.6	100.00	PSR 5A EVENT MOF - SUPPORT INTERCEPT VALVE WORK
2022-03-25	PMO	47.6	100.00	PSR 5B EVENT MOF - SUPPORT INTERCEPT VALVE WORK
2022-03-25	PMO	47.6	100.00	PSR 5C EVENT MOF - SUPPORT INTERCEPT VALVE WORK
2022-03-25	PMO	47.6	100.00	PSR 5D EVENT MOF - SUPPORT ST IV WORK
2022-03-28	PFO	0.7	195.00	PSR 5B EFOR - STEAM STOP NOT OPEN
2022-03-28	PFO	0.7	100.00	PSR 5B EFOR - STEAM STOP NOT OPEN
2022-04-29	PMO	14.4	195.00	PSR 5D EVENT MOF - IP FW SAFETY OVERHAUL
2022-04-29	PMO	14.4	100.00	PSR 5D EVENT MOF - IP FW SAFETY OVERHAUL
2022-06-01	PMO	34.3	195.00	PSR 5C EVENT MOF - REPAIR BYPASS VALVE
2022-06-01	PMO	34.3	96.00	PSR 5C EVENT MOF - REPAIR BYPASS VALVE
2022-07-05	PMO	382.0	195.00	PSR 5A T FAIRING OUTAGE
2022-07-05	PMO	382.0	96.00	PSR 5A T FAIRING OUTAGE
2022-07-19	PFO	2.3	195.00	PSR 5C EFOR- AIR SYSTEM PROBLEM
2022-07-19	PFO	2.3	96.00	PSR 5C EFOR- AIR SYSTEM PROBLEM
2022-07-21	PMO	14.3	195.00	PSR 5A T FAIRING OUTAGE - CONTINUED
2022-07-21	PMO	14.3	96.00	PSR 5A T FAIRING OUTAGE - CONTINUED
2022-08-04	PFO	1.3	195.00	PSR 5A EFOR - RUNBACK DUE TO DCS CARD
2022-08-04	PFO	1.3	96.00	PSR 5A EFOR - RUNBACK DUE TO DCS CARD
2022-08-21	PFO	0.0	28.00	5A EFOR - RUNBACK DUE TO EXHAUST THERMOCOUPLE
2022-08-21	PFO	0.0	13.77	5A EFOR - RUNBACK DUE TO EXHAUST THERMOCOUPLE
2022-09-13	PFO	12.4	195.00	PSR 5C EFOR - UNIT UNAVAILABLE - FW BLOCK VALVE ISSUE
2022-09-13	PFO	12.4	96.00	PSR 5C EFOR - UNIT UNAVAILABLE - FW BLOCK VALVE ISSUE
2022-10-08	PMO	16.1	195.00	PSR 5D EVENT MOF - IP LEVEL CONTROL VALVE WORK
2022-10-08	PMO	16.1	96.00	PSR 5D EVENT MOF - IP LEVEL CONTROL VALVE WORK
2022-10-12	PMO	326.5	195.00	5B PLANNED OUTAGE - T FAIRING
2022-10-12	PMO	326.5	96.00	5B PLANNED OUTAGE - T FAIRING
2022-10-25	PFO	22.8	195.00	PSR 5C EFOR - HP FEED BLOCK VALVE ISSUE
2022-10-25	PFO	22.8	96.00	PSR 5C EFOR - HP FEED BLOCK VALVE ISSUE

2022-11-04	PFO	1.9	195.00	PSR 5B EFOR - UNIT OFF DUE TO COMPRESSOR BLEED VALVE ISSUE
2022-11-04	PFO	1.9	96.00	PSR 5B EFOR - UNIT OFF DUE TO COMPRESSOR BLEED VALVE ISSUE
2022-11-04	PFO	0.6	195.00	PSR 5B EFOR - UNIT TRIP DUE TO COMPRESSOR BLEED VALVE ISSUE
2022-11-04	PFO	0.6	96.00	PSR 5B EFOR - UNIT TRIP DUE TO COMPRESSOR BLEED VALVE ISSUE
2022-11-21	PFO	1.7	195.00	PSR 5B EFOR - STARTUP FAILURE - COMP BLEED VALVE
2022-11-21	PFO	1.7	96.00	PSR 5B EFOR - STARTUP FAILURE - COMP BLEED VALVE

(1) FFO - FULL FORCED OUTAGE
PPO - PARTIAL PLANNED OUTAGE
PMO - PARTIAL MAINTENANCE OUTAGE
PO - PLANNED OUTAGE
PFO - PARTIAL FORCED OUTAGE
FMO - FULL MAINTENANCE OUTAGE

FILED:
SUSPENDED:
EFFECTIVE:
DOCKET NO:
ORDER NO:

ISSUED BY: FLORIDA POWER AND LIGHT CO.

ACTUAL PERFORMANCE DATA
COMPANY: FLORIDA POWER AND LIGHT
FROM: Jan-2022 TO: Dec-2022

PLANT/UNIT: Turkey Point Nuclear - PTN		PTN-03		
DATE	OUTAGE TYPE(1)	HOURS	(MW) AFFECTED	DESCRIPTION

- (1) FFO - FULL FORCED OUTAGE
- PPO - PARTIAL PLANNED OUTAGE
- PMO - PARTIAL MAINTENANCE OUTAGE
- PO - PLANNED OUTAGE
- PFO - PARTIAL FORCED OUTAGE
- FMO - FULL MAINTENANCE OUTAGE

- FILED:
- SUSPENDED:
- EFFECTIVE:
- DOCKET NO:
- ORDER NO:

ISSUED BY: FLORIDA POWER AND LIGHT CO.

ACTUAL PERFORMANCE DATA
COMPANY: FLORIDA POWER AND LIGHT
FROM: Jan-2022 TO: Dec-2022

PLANT/UNIT: Turkey Point Nuclear - PTN		PTN-04		
DATE	OUTAGE TYPE(1)	HOURS	(MW) AFFECTED	DESCRIPTION
2022-03-10	PPO	28.1	539.20	Planned Power reduction to support Cycle 33 RFO
2022-03-12	PO	478.9	844.00	PTN Unit 4 planned Cycle 33 refueling outage
2022-04-01	PO	254.3	844.00	PTN Unit 4 planned Cycle 33 refueling outage
2022-04-11	PPO	76.0	491.71	PT4-33 RFO power ascension
2022-04-14	PFO	23.6	118.75	PT4-33 RFO Power Ascension Unplanned

(1) FFO - FULL FORCED OUTAGE
PPO - PARTIAL PLANNED OUTAGE
PMO - PARTIAL MAINTENANCE OUTAGE
PO - PLANNED OUTAGE
PFO - PARTIAL FORCED OUTAGE
FMO - FULL MAINTENANCE OUTAGE

FILED:
SUSPENDED:
EFFECTIVE:
DOCKET NO:
ORDER NO:

ISSUED BY: FLORIDA POWER AND LIGHT CO.

ACTUAL PERFORMANCE DATA
 COMPANY: FLORIDA POWER AND LIGHT
 FROM: Jan-2022 TO: Dec-2022

PLANT/UNIT: West County Energy Center - PWC				
				PWC-01
DATE	OUTAGE TYPE(1)	HOURS	(MW) AFFECTED	DESCRIPTION
2022-01-18	PFO	4.6	258.00	PWC 1A - SF - 41E Failed to Stay Closed
2022-01-18	PFO	4.6	169.00	PWC 1A - SF - 41E Failed to Stay Closed
2022-01-25	PMO	80.9	258.00	PWC 1B - Event MOF - HRSG Tube Leak and FO Valve Repair
2022-01-25	PMO	80.9	169.00	PWC 1B - Event MOF - HRSG Tube Leak and FO Valve Repair
2022-01-30	PFO	1.4	258.00	PWC 1B - SF - SW Loss of Flame
2022-01-30	PFO	1.4	169.00	PWC 1B - SF - SW Loss of Flame
2022-01-31	PMO	102.5	258.00	PWC 1A - Event MOF - IP Cooling Steam MOV repair
2022-01-31	PMO	102.5	169.00	PWC 1A - Event MOF - IP Cooling Steam MOV repair
2022-02-04	PMO	737.7	258.00	PWC 1C - Event MOF - Borescope CT and replace R1 blades
2022-02-04	PMO	737.7	329.33	PWC 1C - Event MOF - Borescope CT and replace R1 blades
2022-03-12	PFO	1.5	258.00	PWC 1A -SF - LB Bleed Valve
2022-03-12	PFO	1.5	169.00	PWC 1A -SF - LB Bleed Valve
2022-03-13	PFO	10.6	258.00	PWC 1A - SF - 41E Breaker
2022-03-13	PFO	10.6	169.00	PWC 1A - SF - 41E Breaker
2022-03-24	PMO	135.0	258.00	PWC 1A - Event MOF - Repair CT Expansion Joint
2022-03-24	PMO	135.0	329.00	PWC 1A - Event MOF - Repair CT Expansion Joint
2022-03-26	PMO	84.1	258.00	PWC 1B - Event MOF - HP Drum Inspection HRSG Tube Leak Leaks On Preheat
2022-03-26	PMO	84.1	329.00	PWC 1B - Event MOF - HP Drum Inspection HRSG Tube Leak Leaks On Preheat
2022-04-09	PFO	3.1	490.00	PWC 1ST - EFOR - GSU HIGH GAS ACCUMULATION
2022-04-09	PMO	23.0	258.00	PWC 1C - Event MOF - REPAIR LP PREHEATER VENT
2022-04-09	PMO	23.0	169.00	PWC 1C - Event MOF - REPAIR LP PREHEATER VENT
2022-04-30	PMO	107.6	258.00	PWC 1A - Event MOF - CT Borescope
2022-04-30	PMO	107.6	169.00	PWC 1A - Event MOF - CT Borescope
2022-05-18	PFO	5.2	258.00	PWC 1C - Start Up Failure - Failed DCS card
2022-05-18	PFO	5.2	163.00	PWC 1C - Start Up Failure - Failed DCS card
2022-05-25	PFO	2.1	258.00	PWC 1A - Startup Failure - LP Bleed Valve
2022-05-25	PFO	2.1	163.00	PWC 1A - Startup Failure - LP Bleed Valve
2022-06-03	PFO	0.2	161.00	PWC 1A - Runback - HP to Clg Stm Leakby
2022-06-03	PFO	0.2	101.93	PWC 1A - Runback - HP to Clg Stm Leakby
2022-07-09	PMO	18.6	258.00	PWC 1B - Event MOF - Replace fuel flow divider
2022-07-09	PMO	18.6	163.00	PWC 1B - Event MOF - Replace fuel flow divider
2022-07-13	PFO	1.5	258.00	PWC 1C - Blade Path Trip TC9
2022-07-13	PFO	1.5	163.00	PWC 1C - Blade Path Trip TC9
2022-07-22	PMO	58.4	258.00	PWC 1A - Event MOF - Cooling Steam Repair
2022-07-22	PMO	58.4	163.00	PWC 1A - Event MOF - Cooling Steam Repair
2022-08-11	PMO	25.6	258.00	PWC 1C-Event MOF-Repair Steam Leak of Cooling Steam Control Valve
2022-08-11	PMO	25.6	163.00	PWC 1C-Event MOF-Repair Steam Leak of Cooling Steam Control Valve
2022-08-13	PMO	81.4	258.00	PWC 1B-Event MOF-Replace Fuel Oil Flow Divider
2022-08-13	PMO	81.4	163.00	PWC 1B-Event MOF-Replace Fuel Oil Flow Divider
2022-08-17	PFO	6.6	258.00	PWC 1B START UP FAILURE Igniter Failure
2022-08-17	PFO	6.6	163.00	PWC 1B START UP FAILURE Igniter Failure
2022-09-09	PFO	32.8	258.00	PWC 1C-Fource Outage-HRSG Tube Leak
2022-09-09	PFO	32.8	163.00	PWC 1C-Fource Outage-HRSG Tube Leak
2022-09-15	PPO	887.8	258.00	PWC 1C Planned Outage
2022-09-15	PPO	887.5	163.00	PWC 1C Planned Outage
2022-09-15	PFO	1.9	258.00	PWC- 1A Low Boiler Feed Pump Trip on Low Lube Oil Pressure
2022-09-15	PFO	1.9	164.00	PWC- 1A Low Boiler Feed Pump Trip on Low Lube Oil Pressure

2022-10-10	PFO		1.8	258.00	PWC-1B-START UP FAILURE MP BLEED VALVE FAILED
2022-10-10	PFO		1.8	164.00	PWC-1B-START UP FAILURE MP BLEED VALVE FAILED
2022-10-14	PMO		58.5	258.00	PWC 1B - Event MOF - Repair HP Drum Level Control Valve
2022-10-14	PMO		58.5	164.00	PWC 1B - Event MOF - Repair HP Drum Level Control Valve
2022-10-21	PMO		1.1	258.00	PWC-1A- Event MOF-Condensate-Auxiliary Steam Leak
2022-10-21	PMO		0.9	164.00	PWC-1A- Event MOF-Condensate-Auxiliary Steam Leak
2022-10-21	PMO		0.2	490.00	PWC-1ST- Event MOF-Condensate-Auxiliary Steam Leak
2022-10-21	PPO		79.2	163.00	PWC 1C Planned Outage
2022-10-21	PMO		79.2	164.00	PWC-1A- Event MOF-Condensate-Auxiliary Steam Leak
2022-10-21	FMO		75.1	1264.00	PWC-1B- Event MOF-Condensate-Auxiliary Steam Leak
2022-10-25	PPO		286.4	258.00	PWC 1C Planned Outage
2022-10-25	PMO		9.0	258.00	PWC-1A- Event MOF-Condensate-Auxiliary Steam Leak
2022-10-25	PMO		3.8	490.00	PWC-1ST- Event MOF-Condensate-Auxiliary Steam Leak
2022-10-25	PPO		44.4	163.00	PWC 1C Planned Outage
2022-10-25	PMO		5.2	164.00	PWC-1A- Event MOF-Condensate-Auxiliary Steam Leak
2022-10-25	PPO		324.2	258.00	PWC-1A-CT-Planned Outage
2022-10-25	PPO		277.3	163.00	PWC-1A-CT-Planned Outage
2022-10-27	PFO		12.9	490.00	PWC -1ST-EFOR OMC line fault between the switchyard and the substation
2022-10-27	PPO		12.9	163.00	PWC 1C Planned Outage
2022-10-27	PPO		225.1	163.00	PWC 1C Planned Outage
2022-11-06	PPO		46.4	163.00	PWC-1A-CT-Planned Outage
2022-11-07	PMO		1.1	258.00	PWC 1C - Event MOF - Replace SJAE Hogger Valve
2022-11-07	PMO		0.7	164.00	PWC 1C - Event MOF - Replace SJAE Hogger Valve
2022-11-07	PMO		0.4	490.00	PWC 1ST - Event MOF - Replace SJAE Hogger Valve
2022-11-07	PPO		29.4	163.00	PWC-1A-CT-Planned Outage
2022-11-07	PMO		29.4	164.00	PWC 1C - Event MOF - Replace SJAE Hogger Valve
2022-11-07	FMO		27.3	1264.00	PWC 1B - Event MOF - Replace SJAE Hogger Valve
2022-11-09	PPO		525.4	258.00	PWC-1A-CT-Planned Outage
2022-11-09	PMO		9.7	258.00	PWC 1C - Event MOF - Replace SJAE Hogger Valve
2022-11-09	PMO		1.6	490.00	PWC 1ST - Event MOF - Replace SJAE Hogger Valve
2022-11-09	PPO		523.7	163.00	PWC-1A-CT-Planned Outage
2022-11-09	PMO		8.0	164.00	PWC 1C - Event MOF - Replace SJAE Hogger Valve
2022-11-17	PMO		160.6	258.00	PWC-1C-Event MOF-Efficiency Loss
2022-11-17	PMO		160.6	164.00	PWC-1C-Event MOF-Efficiency Loss
2022-11-24	PMO		101.9	78.00	PWC-1C-Event Maintenance Derating-Efficiency Loss
2022-11-24	PMO		101.9	146.70	PWC-1C-Event Maintenance Derating-Efficiency Loss
2022-11-30	PFO		1.7	258.00	PWC-1B-START UP FAILURE MP BLEED VALVE FAILED
2022-11-30	PFO		1.7	163.00	PWC-1B-START UP FAILURE MP BLEED VALVE FAILED

(1) FFO - FULL FORCED OUTAGE
PPO - PARTIAL PLANNED OUTAGE
PMO - PARTIAL MAINTENANCE OUTAGE
PO - PLANNED OUTAGE
PFO - PARTIAL FORCED OUTAGE
FMO - FULL MAINTENANCE OUTAGE

FILED:
SUSPENDED:
EFFECTIVE:
DOCKET NO:
ORDER NO:

ISSUED BY: FLORIDA POWER AND LIGHT CO.

ACTUAL PERFORMANCE DATA
 COMPANY: FLORIDA POWER AND LIGHT
 FROM: Jan-2022 TO: Dec-2022

PLANT/UNIT: West County Energy Center - PWC		PWC-02		
DATE	OUTAGE TYPE(1)	HOURS	(MW) AFFECTED	DESCRIPTION
2022-01-02	PFO	3.5	258.00	PWC 2C - EFOR - Blade Path Damaged R1 Vanes
2022-01-02	PFO	3.5	168.00	PWC 2C - EFOR - Blade Path Damaged R1 Vanes
2022-01-04	PMO	226.6	258.00	PWC 2C - Event MOF - Damaged R1 Vanes
2022-01-04	PMO	226.6	168.00	PWC 2C - Event MOF - Damaged R1 Vanes
2022-02-13	PPO	45.9	258.00	PWC 2B Planned Outage
2022-02-14	PPO	22.6	258.00	PWC 2C Planned Outage
2022-02-14	PPO	14.3	258.00	PWC 2A Planned Outage
2022-02-15	PO	1665.6	1264.00	PWC 2ST Planned Outage
2022-04-25	PO	14.3	1264.00	PWC 2A - Planned Outage Extension - Annual Maintenance
2022-04-26	PO	50.1	1264.00	PWC 2 ST - Planned Outage Extension - Major Outage HP IP Generator Major
2022-04-28	PO	23.2	1264.00	PWC 2B - Planned Outage Extension - CT Major
2022-04-29	PO	56.7	1264.00	PWC 2C - Planned Outage Extension
2022-05-01	PPO	3.7	490.00	PWC 2 ST - Planned Outage Extension - Major Outage HP IP Generator Major
2022-05-01	PPO	3.7	258.00	PWC 2B - Planned Outage Extension - CT Major
2022-05-01	PPO	3.7	258.00	PWC 2C - Planned Outage Extension
2022-05-01	PO	0.0	1264.00	PWC 2A - POF - Annual Maintenance Overhaul
2022-05-01	PO	13.8	1264.00	PWC 2A - PO Extension - Annual Maintenance Overhaul
2022-05-02	PPO	3.0	490.00	PWC 2 ST - Planned Outage Extension - Major Outage HP IP Generator Major
2022-05-02	PPO	3.1	258.00	PWC 2B - Planned Outage Extension - CT Major
2022-05-02	PPO	3.1	258.00	PWC 2C - Planned Outage Extension
2022-05-02	PO	0.0	1264.00	PWC 2A - Planned Outage
2022-05-02	PO	9.5	1264.00	PWC 2A - PO Extension
2022-05-02	PPO	143.3	258.00	PWC 2B - Planned Outage Extension - CT Major
2022-05-02	PPO	12.8	258.00	PWC 2C - Planned Outage Extension
2022-05-02	PPO	2.1	490.00	PWC 2 ST - Planned Outage Extension
2022-05-03	PPO	0.0	258.00	PWC 2C - Planned Outage
2022-05-03	PPO	0.0	329.00	PWC 2C - Planned Outage
2022-05-03	PPO	3.3	258.00	PWC 2C - Planned Outage Extension
2022-05-03	PPO	3.3	329.00	PWC 2C - Planned Outage Extension
2022-05-03	PPO	0.0	258.00	PWC 2C - Planned Outage
2022-05-03	PPO	0.0	329.00	PWC 2C - Planned Outage
2022-05-03	PPO	7.7	258.00	PWC 2C - Planned Outage Extension
2022-05-03	PPO	7.7	329.00	PWC 2C - Planned Outage Extension
2022-05-08	PFO	0.9	258.00	PWC 2C - Start Up Failure - Low Low HP drum level trip
2022-05-08	PFO	0.9	169.00	PWC 2C - Start Up Failure - Low Low HP drum level trip
2022-05-11	PMO	37.1	258.00	PWC 2A - Event MOF - Clean and inspect fuel gas strainers
2022-05-11	PMO	37.1	163.00	PWC 2A - Event MOF - Clean and inspect fuel gas strainers
2022-05-17	PFO	2.2	258.00	PWC 2B - EFOR - Drum Level Control valve stuck in the close position
2022-05-17	PFO	2.2	163.00	PWC 2B - EFOR - Drum Level Control valve stuck in the close position
2022-05-25	PMO	36.1	258.00	PWC 2B - Event MOF - Bearing 2 Oil Leak
2022-05-25	PMO	36.1	163.00	PWC 2B - Event MOF - Bearing 2 Oil Leak
2022-05-27	PMO	2.5	258.00	PWC 2B - Event MOF - Post Outage Repairs
2022-05-27	PMO	2.5	327.00	PWC 2B - Event MOF - Post Outage Repairs
2022-05-27	PMO	1.4	258.00	PWC 2A - Event MOF - Post Outage Repairs
2022-05-27	PMO	61.7	163.00	PWC 2A - Event MOF - Post Outage Repairs
2022-05-27	PMO	0.0	258.00	PWC 2C - Event MOF - Post Outage Repairs
2022-05-27	PMO	0.0	162.00	PWC 2C - Event MOF - Post Outage Repairs
2022-05-27	FMO	60.3	1264.00	PWC 2ST - Event MOF - Post Outage Repairs
2022-05-27	PMO	60.3	327.00	PWC 2B - Event MOF - Post Outage Repairs
2022-05-27	PMO	61.7	162.00	PWC 2C - Event MOF - Post Outage Repairs

2022-05-30	PMO		1.4	258.00	PWC 2C - Event MOF - Post Outage Repairs
2022-05-30	PMO		5.0	490.00	PWC 2ST - Event MOF - Post Outage Repairs
2022-05-30	PFO		2.0	490.00	PWC 2ST - SF - High Vibration Trip
2022-06-01	PFO		25.2	258.00	PWC 2C - EFOR - Generator Lock Out Relay
2022-06-01	PFO		25.2	163.00	PWC 2C - EFOR - Generator Lock Out Relay
2022-06-24	PFO		1.5	258.00	PWC 2A - EFOR - HP feedwater drum level control valve human performance
2022-06-24	PFO		1.5	163.00	PWC 2A - EFOR - HP feedwater drum level control valve human performance
2022-07-01	PMO		32.4	258.00	PWC 2B - Event MOF - Repair HRH steam leak
2022-07-01	PMO		32.4	163.00	PWC 2B - Event MOF - Repair HRH steam leak
2022-08-26	PMO		121.0	258.00	PWC 2B-Event MOF-Troubleshoot and inspect source of the high CO
2022-08-26	PMO		121.0	163.00	PWC 2B-Event MOF-Troubleshoot and inspect source of the high CO
2022-09-23	PMO		21.9	258.00	PWC 2B- Event MOF- Repair HRSG leaks
2022-09-23	PMO		21.9	163.00	PWC 2B- Event MOF- Repair HRSG leaks
2022-09-30	PMO		83.1	258.00	PWC-2C-Event MOF- Repair HRH Bypass crack
2022-09-30	PMO		83.1	163.00	PWC-2C-Event MOF- Repair HRH Bypass crack
2022-10-04	PMO		38.8	258.00	PWC-2A-Event MOF- Repair LP feedwater leak at the top of HRSG
2022-10-04	PMO		38.8	163.00	PWC-2A-Event MOF- Repair LP feedwater leak at the top of HRSG
2022-10-10	PMO		82.0	258.00	PWC-2B-Event MOF-Find and repair HRSG Tube Leak
2022-10-10	PMO		82.0	163.00	PWC-2B-Event MOF-Find and repair HRSG Tube Leak
2022-10-13	PFO		0.0	283.00	PWC-2ST-Runback-Main Steam Valve closed inadvertently
2022-11-11	PMO		87.2	258.00	PWC-2A-Event MOF-CT Borescope and repair HRH bypass line crack
2022-11-11	PMO		87.2	163.00	PWC-2A-Event MOF-CT Borescope and repair HRH bypass line crack
2022-11-15	PFO		2.3	258.00	PWC-Unit 2A CT -10 exceeded Blade Path Auto Stop Setpoint
2022-11-15	PFO		2.3	163.00	PWC-Unit 2A CT -10 exceeded Blade Path Auto Stop Setpoint

(1) FFO - FULL FORCED OUTAGE
PPO - PARTIAL PLANNED OUTAGE
PMO - PARTIAL MAINTENANCE OUTAGE
PO - PLANNED OUTAGE
PFO - PARTIAL FORCED OUTAGE
FMO - FULL MAINTENANCE OUTAGE

FILED:
SUSPENDED:
EFFECTIVE:
DOCKET NO:
ORDER NO:

ISSUED BY: FLORIDA POWER AND LIGHT CO.

ACTUAL PERFORMANCE DATA
COMPANY: FLORIDA POWER AND LIGHT
FROM: Jan-2022 TO: Dec-2022

PLANT/UNIT: West County Energy Center - PWC		PWC-03		
DATE	OUTAGE TYPE(1)	HOURS	(MW) AFFECTED	DESCRIPTION
2022-01-02	PFO	1.5	258.00	PWC 3A - EFOR - Reverse Power Trip
2022-01-02	PFO	1.5	169.00	PWC 3A - EFOR - Reverse Power Trip
2022-01-18	PFO	6.2	258.00	PWC 3C - SF - CT Trip Flame Out
2022-01-18	PFO	6.2	169.00	PWC 3C - SF - CT Trip Flame Out
2022-01-19	PFO	68.6	258.00	PWC 3C - SF - CT Compressor LP Bleed Valve
2022-01-19	PFO	68.6	169.00	PWC 3C - SF - CT Compressor LP Bleed Valve
2022-01-24	PFO	8.5	258.00	PWC 3A - SF - Flame Out Trip
2022-01-24	PFO	8.5	169.00	PWC 3A - SF - Flame Out Trip
2022-01-24	PFO	2.5	258.00	PWC 3C - SF - Blade Path Spread
2022-01-24	PFO	2.5	169.00	PWC 3C - SF - Blade Path Spread
2022-01-24	PMO	96.5	258.00	PWC 3A - Event MOF - Cooling Steam Valve
2022-01-24	PMO	96.5	170.00	PWC 3A - Event MOF - Cooling Steam Valve
2022-01-27	PFO	1.0	258.00	PWC 3C - SF - Blade Path Trip
2022-01-27	PFO	1.0	170.00	PWC 3C - SF - Blade Path Trip
2022-01-31	PMO	61.9	258.00	PWC 3C - Event MOF - Inspect FG Manifold
2022-01-31	PMO	61.7	169.00	PWC 3C - Event MOF - Inspect FG Manifold
2022-02-02	PMO	2.8	258.00	PWC 3B - Event MOF - Clean SCR
2022-02-02	PMO	2.6	160.67	PWC 3B - Event MOF - Clean SCR
2022-02-02	PMO	0.2	490.00	PWC 3ST - Event MOF - CTs in MOF
2022-02-02	PMO	59.8	169.00	PWC 3C - Event MOF - Inspect FG Manifold
2022-02-02	PMO	59.8	160.67	PWC 3B - Event MOF - Clean SCR
2022-02-02	FMO	57.1	1264.00	PWC 3A - Event MOF - PC Work On 3AS Line
2022-02-02	PMO	57.1	329.66	PWC 3A - Event MOF - PC Work On 3AS Line
2022-02-05	PMO	29.7	258.00	PWC 3C - Event MOF - Inspect FG Manifold
2022-02-05	PMO	2.5	490.00	PWC 3ST - Event MOF - CTs in MOF
2022-02-05	PMO	17.3	258.00	PWC 3B - Event MOF - Clean SCR
2022-02-05	PMO	27.2	169.00	PWC 3C - Event MOF - Inspect FG Manifold
2022-02-05	PMO	14.8	160.67	PWC 3B - Event MOF - Clean SCR
2022-02-27	PFO	2.4	258.00	PWC 3B - EFOR - BFP NPSH
2022-02-27	PFO	2.4	169.00	PWC 3B - EFOR - BFP NPSH
2022-02-28	PFO	30.6	258.00	PWC 3B - EFOR - HP Drum Manway Gasket
2022-02-28	PFO	30.6	169.00	PWC 3B - EFOR - HP Drum Manway Gasket
2022-03-03	PFO	15.7	258.00	PWC 3C - EFOR - Control Oil Leak
2022-03-03	PFO	15.7	169.00	PWC 3C - EFOR - Control Oil Leak
2022-03-07	PFO	1.2	258.00	PWC 3B - SF- Gen Bkr Loss of Power due to HVAC trip
2022-03-07	PFO	1.2	169.00	PWC 3B - SF- Gen Bkr Loss of Power due to HVAC trip
2022-03-21	PFO	0.9	18.00	PWC 3C - Runback - CPFM Alarm
2022-03-21	PFO	0.9	20.52	PWC 3C - Runback - CPFM Alarm
2022-04-03	PMO	42.2	258.00	PWC 3A - Event MOF - Condenser Tube Leak Repairs
2022-04-03	PMO	42.2	169.00	PWC 3A - Event MOF - Condenser Tube Leak Repairs
2022-04-05	PMO	18.2	169.00	PWC 3ST - Maintenance Derate - Condenser tube leak
2022-04-26	PMO	75.4	258.00	PWC 3B - Event MOF - HP to cooling steam line leaks
2022-04-26	PMO	75.4	169.00	PWC 3B - Event MOF - HP to cooling steam line leaks
2022-05-02	PMO	67.0	92.83	PWC 3 ST - Maintenance Derate - Condenser Tube Leak
2022-05-02	PMO	67.0	91.83	PWC 3 ST - Maintenance Derate - Condenser Tube Leak
2022-05-02	PMO	67.0	92.83	PWC 3 ST - Maintenance Derate - Condenser Tube Leak
2022-05-02	PMO	67.0	169.00	PWC 3 ST - Maintenance Derate - Condenser Tube Leak
2022-05-11	PFO	12.2	74.00	PWC 3B - Forced Derating - HRH blending valve motor
2022-05-11	PFO	12.2	46.85	PWC 3B - Forced Derating - HRH blending valve motor

2022-05-22	PFO		3.9	258.00	PWC 3C - EFOR - 3C did not meet 0800 RFC due to failed IP Transition
2022-05-22	PFO		3.9	163.00	PWC 3C - EFOR - 3C did not meet 0800 RFC due to failed IP Transition
2022-06-02	PMO		60.1	258.00	PWC 3C - Event MOF - Repair Generator Breaker
2022-06-02	PMO		60.1	163.00	PWC 3C - Event MOF - Repair Generator Breaker
2022-06-21	PMO		35.1	258.00	PWC 3C - Event MOF - Condenser Tube Leak
2022-06-21	PMO		11.0	163.00	PWC 3C - Event MOF - Condenser Tube Leak
2022-06-22	PFO		2.0	490.00	PWC 3ST - EFOR - Low Condenser Vacuum
2022-06-22	PMO		2.0	163.00	PWC 3C - Event MOF - Condenser Tube Leak
2022-06-22	PMO		22.0	163.00	PWC 3C - Event MOF - Condenser Tube Leak
2022-07-09	PFO		0.3	490.00	PWC 3ST - High Vacuum Trip
2022-09-02	PFO		4.2	258.00	PWC-3A - SF-LP Preheater Bypass ACV fail to operate
2022-09-02	PFO		4.2	163.00	PWC-3A - SF-LP Preheater Bypass ACV fail to operate
2022-09-19	PMO		25.7	258.00	PWC 3C - Event MOF - HRH Bypass Relief Valve Replacement
2022-09-19	PMO		25.7	163.00	PWC 3C - Event MOF - HRH Bypass Relief Valve Replacement
2022-10-03	PMO		14.4	258.00	PWC-3A-Event MOF- Repair main steam to auxiliary letdowns leaks
2022-10-03	PMO		2.1	489.90	PWC-3A-Event MOF- Repair main steam to auxiliary letdowns leaks
2022-10-03	PMO		13.6	258.00	PWC-3C-Event MOF- Repair main steam to auxiliary letdowns leaks
2022-10-03	PMO		87.3	489.90	PWC-3C-Event MOF- Repair main steam to auxiliary letdowns leaks
2022-10-03	PMO		12.3	490.00	PWC-3ST-Event MOF- Repair main steam to auxiliary letdowns leaks
2022-10-03	PMO		83.0	489.90	PWC-3A-Event MOF- Repair main steam to auxiliary letdowns leaks
2022-10-04	FMO		65.5	1264.00	PWC-3B-Event MOF- Repair main steam to auxiliary letdowns leaks
2022-10-04	PMO		65.5	489.90	PWC-3B-Event MOF- Repair main steam to auxiliary letdowns leaks
2022-10-07	PMO		11.1	258.00	PWC-3A-Event MOF- Repair main steam to auxiliary letdowns leaks
2022-10-07	PMO		8.1	258.00	PWC-3C-Event MOF- Repair main steam to auxiliary letdowns leaks
2022-10-07	PMO		5.1	490.00	PWC-3ST-Event MOF- Repair main steam to auxiliary letdowns leaks
2022-10-07	PMO		0.7	489.90	PWC-3A-Event MOF- Repair main steam to auxiliary letdowns leaks
2022-10-07	PFO		0.1	490.00	PWC-3ST-FORCED OUTAGE EVENT- MULTIPLE ISSUES
2022-10-07	PMO		0.1	489.90	PWC-3A-Event MOF- Repair main steam to auxiliary letdowns leaks
2022-10-07	PMO		5.0	489.90	PWC-3A-Event MOF- Repair main steam to auxiliary letdowns leaks

(1) FFO - FULL FORCED OUTAGE
PPO - PARTIAL PLANNED OUTAGE
PMO - PARTIAL MAINTENANCE OUTAGE
PO - PLANNED OUTAGE
PFO - PARTIAL FORCED OUTAGE
FMO - FULL MAINTENANCE OUTAGE

FILED:
SUSPENDED:
EFFECTIVE:
DOCKET NO:
ORDER NO:

ISSUED BY: FLORIDA POWER AND LIGHT CO.

ACTUAL PERFORMANCE DATA
 COMPANY: FLORIDA POWER AND LIGHT
 FROM: Jan-2022 TO: Dec-2022

PLANT/UNIT: Turkey Point - TP5		TP5-05		
DATE	OUTAGE TYPE(1)	HOURS	(MW) AFFECTED	DESCRIPTION
2022-01-01	PFO	1.1	195.00	PTF CT 5A FORCED OUTAGE VENT VALVE LEAK REPAIR
2022-01-13	PMO	376.7	195.00	PTF CT 5B MOF - LF Upgrades
2022-01-31	PMO	119.2	195.00	PTF CT 5B MOF - LF Upgrade Post Testing
2022-02-04	PMO	57.7	195.00	PTF CT 5D MOF - Inlet Filter Remove and Replace PM
2022-02-08	PMO	63.3	195.00	PTF CT 5C MOF Event-HRSG HP to CRH BYP Valve Leak Repair
2022-02-11	PFO	1.2	485.00	PTF 5ST Forced Outage - Loss of Vacuum
2022-02-18	PMO	3.3	195.00	PTF CT 5D Event MOF - GSU Maintenance
2022-02-18	PMO	2.7	195.00	PTF CT 5C Event MOF - GSU Maintenance
2022-02-18	PMO	0.4	195.00	PTF CT 5B Event MOF - GSU Maintenance
2022-02-18	PMO	0.4	485.00	PTF 5ST Event MOF - GSU Maintenance
2022-02-18	FMO	74.3	1265.00	PTF CT 5A Event MOF - GSU Maintenance
2022-02-22	PMO	10.5	195.00	PTF CT 5D Event MOF - GSU Maintenance
2022-02-22	PMO	0.5	195.00	PTF CT 5C Event MOF - GSU Maintenance
2022-02-22	PMO	8.7	195.00	PTF CT 5B Event MOF - GSU Maintenance
2022-02-22	PMO	3.1	485.00	PTF 5ST Event MOF - GSU Maintenance
2022-03-12	PMO	34.5	195.00	PTF CT 5D MOF - Main Steam Drain Line Repairs
2022-03-25	PMO	36.5	195.00	PTF CT 5A MOF - BFP Recirc Valve Packing Repair
2022-03-30	PFO	0.8	195.00	PTF EFOR 5A - Startup Failure - CT Vent Fan Damper Failure
2022-03-30	PFO	0.8	23.18	PTF EFOR 5A - Startup Failure - CT Vent Fan Damper Failure
2022-04-17	PPO	2.7	485.00	PTF 5ST Forced Outage - 86LOR - Low Stator Cooling Water Pressure Trip
2022-05-12	PMO	34.4	195.00	5B MOF - CT Inlet Bleed Heat Manual Isolation Valve Repairs
2022-05-20	PMO	59.5	195.00	5A MOF - CT Vent Fan12 Assembly R and R
2022-05-20	PMO	60.5	195.00	5D MOF - Support Circ Motor WDG High Temp Remove and Replace
2022-06-04	PFO	4.8	195.00	5A Forced Outage - LCI
2022-06-04	PFO	5.7	195.00	5D Forced Outage - LCI
2022-06-04	PFO	4.8	121.25	5A Forced Outage - LCI
2022-06-04	PFO	4.8	121.25	5D Forced Outage - LCI
2022-06-04	PFO	0.8	121.25	5D Forced Outage - LCI
2022-06-21	PFO	4.8	195.00	5A- EFOR Hydraulic Oil Pump 2 Failure
2022-06-21	PFO	4.8	121.00	5A- EFOR Hydraulic Oil Pump 2 Failure
2022-06-22	PFO	6.0	195.00	5A Tripfaulty IGVSV Actuators Hydraulic
2022-06-22	PFO	6.0	121.00	5A Tripfaulty IGVSV Actuators Hydraulic
2022-06-25	PMO	63.8	195.00	PTF 5A Event MOF - Low Hydraulic Pressure
2022-06-25	PMO	63.8	121.00	PTF 5A Event MOF - Low Hydraulic Pressure
2022-07-15	PMO	181.7	195.00	PTF 5D MOF Event CT A042 Transition Diffuser Duct Repairs
2022-07-15	PMO	181.7	121.00	PTF 5D MOF Event CT A042 Transition Diffuser Duct Repairs
2022-08-05	PMO	33.1	195.00	PTF MOF Event 5A CT Lube Oil filter replacement
2022-08-05	PMO	33.1	121.00	PTF MOF Event 5A CT Lube Oil filter replacement
2022-08-12	PMO	20.9	195.00	PTF MOF Event 5C Main steam packing leak
2022-08-12	PMO	20.9	121.00	PTF MOF Event 5C Main steam packing leak
2022-08-13	PMO	29.7	195.00	PTF MOF Event 5B HP spray control valve packing leak
2022-08-13	PMO	29.7	121.00	PTF MOF Event 5B HP spray control valve packing leak
2022-08-24	PFO	11.3	195.00	PTF EFOR 5C High Spread Temp
2022-08-24	PFO	11.3	121.00	PTF EFOR 5C High Spread Temp
2022-08-24	PFO	4.4	195.00	PTF EFOR 5C PM3 Gas Control Valve failed to respond the demand
2022-08-24	PFO	4.4	121.00	PTF EFOR 5C PM3 Gas Control Valve failed to respond the demand
2022-08-25	PMO	18.6	195.00	PTF MOF Event 5C PM3 gas control valve replacement
2022-08-25	PMO	18.6	121.00	PTF MOF Event 5C PM3 gas control valve replacement
2022-09-15	PMO	161.5	195.00	PTF MO Event - Exhaust Duct A042 Repairs

2022-09-19	PFO		9.3	195.00	PTF EFOR 5D PM4 DMC failure
2022-09-19	PFO		9.3	242.50	PTF EFOR 5D PM4 DMC failure
2022-09-23	PMO		48.1	195.00	PTF MO Event - 5A CT Hydraulic Pump 1 replacement
2022-09-23	PMO		48.1	121.00	PTF MO Event - 5A CT Hydraulic Pump 1 replacement
2022-09-27	PFO		0.1	455.00	PTF Partial EFOR - 5ST Automatic Control System
2022-09-30	PMO		74.3	195.00	PTF MO Event - 5D LF Check Valves replacement
2022-09-30	PMO		74.3	121.00	PTF MO Event - 5D LF Check Valves replacement
2022-10-14	PMO		81.4	195.00	PTF MO Event - 5D Igniters replacement
2022-10-14	PMO		81.4	121.00	PTF MO Event - 5D Igniters replacement
2022-10-28	PPO		8.5	195.00	FGT Outage
2022-10-28	PPO		8.0	195.00	FGT Outage
2022-10-28	PPO		7.2	485.00	FGT Outage
2022-10-28	PPO		7.0	195.00	FGT Outage
2022-10-29	PO		59.9	1265.00	FGT Outage
2022-10-31	PPO		2.5	195.00	FGT Outage
2022-10-31	PPO		2.5	195.00	FGT Outage
2022-10-31	PPO		2.5	485.00	FGT Outage
2022-10-31	PPO		0.6	195.00	FGT Outage
2022-10-31	PPO		0.3	195.00	FGT Outage
2022-10-31	PO		17.0	1265.00	FGT Outage
2022-11-01	PPO		1.4	195.00	FGT Outage
2022-11-01	PPO		6.9	195.00	FGT Outage
2022-11-01	PPO		6.9	485.00	FGT Outage
2022-11-01	PPO		6.9	195.00	FGT Outage
2022-11-01	PFO		0.7	195.00	5C EFOR Event - CRH Inlet Press Transmitters failed
2022-11-01	PFO		0.7	484.00	5C EFOR Event - CRH Inlet Press Transmitters failed
2022-11-01	PPO		0.4	195.00	FGT Outage
2022-11-01	PO		19.0	1265.00	FGT Outage
2022-11-02	PPO		4.4	195.00	FGT Outage
2022-11-02	PPO		4.4	485.00	FGT Outage
2022-11-02	PPO		4.4	195.00	FGT Outage
2022-11-02	PPO		4.4	195.00	FGT Outage
2022-11-02	PO		166.0	1265.00	FGT Outage
2022-11-09	PPO		3.4	195.00	FGT Outage
2022-11-09	PPO		14.0	485.00	FGT Outage
2022-11-09	PPO		11.0	195.00	FGT Outage
2022-11-09	PPO		9.2	195.00	FGT Outage
2022-11-15	PMO		78.2	195.00	5C MO Task - Generator Protection Maintenance
2022-11-15	PMO		78.2	122.00	5C MO Task - Generator Protection Maintenance
2022-11-28	PMO		51.9	195.00	5A MO Task - Generator Protection Maintenance
2022-11-28	PMO		49.6	485.00	5ST MO Task - Generator Protection Maintenance

(1) FFO - FULL FORCED OUTAGE
PPO - PARTIAL PLANNED OUTAGE
PMO - PARTIAL MAINTENANCE OUTAGE
PO - PLANNED OUTAGE
PFO - PARTIAL FORCED OUTAGE
FMO - FULL MAINTENANCE OUTAGE

FILED:
SUSPENDED:
EFFECTIVE:
DOCKET NO:
ORDER NO:

ISSUED BY: FLORIDA POWER AND LIGHT CO.