

State of Florida



Public Service Commission

CAPITAL CIRCLE OFFICE CENTER • 2540 SHUMARD OAK BOULEVARD
TALLAHASSEE, FLORIDA 32399-0850

-M-E-M-O-R-A-N-D-U-M-

DATE: December 29, 2022

TO: Adam J. Teitzman, Commission Clerk, Office of Commission Clerk

FROM: Kerri Maloy, Engineering Specialist II, Division of Engineering *KM LK*

RE: Docket No. 20220099-WS - Application for staff-assisted rate case in Highlands County by LP Waterworks, Inc.

Please file the attached email "pro forma update" in the above mentioned docket file.

KM/jp

From: [Joann Parsons](#)
To: [Joann Parsons](#)
Subject: FW: LP Waterworks - Pro Forma
Date: Thursday, December 29, 2022 8:27:19 AM

From: Troy Rendell <trendell@uswatercorp.net>
Sent: Wednesday, December 28, 2022 8:40 AM
To: Kerri Maloy
Subject: LP Waterworks - Pro Forma

Good morning Kerri,

As a follow up to our telephone conversation, I'm providing additional information on the requested pro forma plant items.

1. The first was a Stenner Pump replacement. This is actually used at the wastewater plant and was booked to Account 380. Therefore, this should not be considered in this SARC.
2. The second was a replacement of the generator controller at the water treatment plant. A new G series conversion on the transfer switch was replaced due to a high voltage issue. This work was actually performed by Mid Florida Diesel, Inc.

The invoice was paid by U.S. Water and then U.S. Water invoiced LP Waterworks for the work performed. This was necessary to ensure the generator remained functional in the event of power loss.

Troy Rendell
Vice President - Investor Owned Utilities



4939 Cross Bayou Boulevard
New Port Richey, FL 34652
(Office) 727-848-8292 x245
(Fax) 727-848-7701
(E-Mail) trendell@uswatercorp.net