



Maria Jose Moncada
Managing Attorney
Florida Power & Light Company
700 Universe Boulevard
Juno Beach, FL 33408
(561) 304-5795
(561) 691-7135 (facsimile)
maria.moncada@fpl.com

February 20, 2023

-VIA ELECTRONIC FILING-

Adam Teitzman
Division of Commission Clerk
Florida Public Service Commission
2540 Shumard Oak Blvd.
Tallahassee, FL 32399-0850

Re: Docket No. 20230001-EI

Dear Mr. Teitzman:

Attached for electronic filing in the above docket are Florida Power & Light Company's GPIF Actual Unit Performance Data Schedules covering the month of January 2023. These schedules are being filed at the same time but separately from the monthly A Schedules.

If there are any questions regarding this transmittal, please contact me at (561) 304-5795.

Sincerely,

s/ Maria Jose Moncada

Maria Jose Moncada

Attachments

cc: Counsel for Parties of Record (w/ attachments)

CERTIFICATE OF SERVICE
Docket No. 20230001-EI

I **HEREBY CERTIFY** that a true and correct copy of the foregoing has been furnished
by electronic service on this 20th day of February 2023 to the following:

Suzanne Brownless
Ryan Sandy
Office of General Counsel
Florida Public Service Commission
2540 Shumard Oak Boulevard
Tallahassee, Florida 32399-0850
sbrownle@psc.state.fl.us
rsandy@psc.state.fl.us

Dianne M. Triplett
299 First Avenue North
St. Petersburg, Florida 33701
Dianne.triplett@duke-energy.com

Matthew R. Bernier
Stephanie A. Cuello
106 East College Avenue, Suite 800
Tallahassee, Florida 32301
matthew.bernier@duke-energy.com
stephanie.cuello@duke-energy.com
Attorneys for Duke Energy Florida

Robert L. Pickels
Duke Energy Florida
106 East College Avenue, Suite 800
Tallahassee, Florida 32301
robert.pickels@duke-energy.com
FLRegulatoryLegal@duke-energy.com

Robert Scheffel Wright
John Thomas LaVia, III
Gardner, Bist, Bowden, Dee, LaVia,
Wright, Perry & Harper, P.A.
1300 Thomaswood Drive
Tallahassee, FL 32308
schef@gbwlegal.com
jlavia@gbwlegal.com
Attorneys for Florida Retail Federation

Mary A. Wessling
Associate Public Counsel
Patricia A. Christensen
Associate Public Counsel
Charles J. Rehwinkel
Deputy Public Counsel
Office of Public Counsel
The Florida Legislature
111 W. Madison Street, Room 812
Tallahassee, Florida 32399
wessling.mary@leg.state.fl.us
christensen.patty@leg.state.fl.us
rehwinkel.charles@leg.state.fl.us

J. Jeffry Wahlen
Malcolm N. Means
Virginia Ponder
Ausley McMullen
123 S. Calhoun Street (32301)
Post Office Box 391
Tallahassee, Florida 32302
jwahlen@ausley.com
mmeans@ausley.com
vponder@ausley.com
Attorneys for Tampa Electric Company

Paula K. Brown
Tampa Electric Company
P.O. Box 111
Tampa, Florida 33601-0111
regdept@tecoenergy.com

Jon C. Moyle, Jr.
Moyle Law Firm, P.A.
118 North Gadsden Street
Tallahassee, Florida 32301
jmoyle@moylelaw.com
mqualls@moylelaw.com
**Attorneys for Florida Industrial Power
Users Group**

Mike Cassel
Vice President, Governmental
and Regulatory Affairs
Florida Public Utilities Company
208 Wildlight Avenue
Yulee, Florida 32097
mcassel@fpuc.com

Michelle D. Napier
Director, Regulatory Affairs
Florida Public Utilities Company
1635 Meathe Drive
West Palm Beach, Florida 33411
mnapier@fpuc.com

Peter J. Mattheis
Michael K. Lavanga
Joseph R. Briscar
Stone Mattheis Xenopoulos & Brew, PC
1025 Thomas Jefferson Street, NW
Eighth Floor, West Tower
Washington, DC 20007
pjm@smxblaw.com
mkl@smxblaw.com
jrb@smxblaw.com
Attorneys for Nucor Steel Florida, Inc.

Beth Keating
Gunster Law Firm
215 South Monroe Street, Suite 601
Tallahassee, Florida 32301-1804
bkeating@gunster.com
**Attorneys for Florida Public Utilities
Company**

James W. Brew
Laura Wynn Baker
Stone Mattheis Xenopoulos & Brew, P.C.
1025 Thomas Jefferson Street, NW
Eighth Floor, West Tower
Washington, D.C. 20007
jbrew@smxblaw.com
lwb@smxblaw.com
**Attorneys for White Springs
Agricultural Chemicals, Inc. d/b/a PCS
Phosphate – White Springs**

By: s/ Maria Jose Moncada
Maria Jose Moncada
Florida Bar No. 0773301

ACTUAL PERFORMANCE DATA
 COMPANY: FLORIDA POWER AND LIGHT
 FROM: Jan-2022 TO: Dec-2022

		PLANT/UNIT: Cape Canaveral - PCC											PCC-03	
		Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	Ytd
1	EAF (%)	87.50	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	87.50
2	PH	744.00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	744.00
3	SH	744.00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	744.00
4	RSH	0.00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.00
5	UH	0.00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.00
6	POH	0.00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.00
7	FOH	0.00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.00
8	MOH	0.00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.00
9	PPOH	0.00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.00
10	LRPP (MW)	0.00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.00
11	PFOH	0.00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.00
12	LRPF (MW)	0.00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.00
13	PMOH	228.87	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	228.87
14	LRPM (MW)	532.67	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	532.67
15	NSC	1308	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	1308
16	OPERBTU (MBTU)	2197358	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	2197358
17	NET GEN	326716.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	326716.0
18	ANOHR (BTU/KWH)	6726.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	6726.0
19	NOF (%)	33.60	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	33.60
20	NPC	1308	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	1308

21	ANOHR EQUATION	$ANOHR = A+B(N.O.F)$ A=0 B=0
----	----------------	---------------------------------

NOTE : LINE 17 IS DATA WHEN THE UNIT IS SYNCHRONIZED TO THIS SYSTEM

FILED:
 SUSPENDED:
 EFFECTIVE:
 DOCKET NO:
 ORDER NO:

ISSUED BY: FLORIDA POWER AND LIGHT CO.

ACTUAL PERFORMANCE DATA
 COMPANY: FLORIDA POWER AND LIGHT
 FROM: Jan-2022 TO: Dec-2022

		PLANT/UNIT: Fort Myers - PFM											PFM-02	
		Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	Ytd
1	EAF (%)	97.80	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	97.80
2	PH	744.00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	744.00
3	SH	744.00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	744.00
4	RSH	0.00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.00
5	UH	0.00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.00
6	POH	0.00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.00
7	FOH	0.00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.00
8	MOH	0.00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.00
9	PPOH	0.00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.00
10	LRPP (MW)	0.00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.00
11	PFOH	57.53	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	57.53
12	LRPF (MW)	255.20	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	255.20
13	PMOH	69.28	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	69.28
14	LRPM (MW)	189.00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	189.00
15	NSC	1700	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	1700
16	OPERBTU (MBTU)	5537134	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	5537134
17	NET GEN	797036.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	797036.0
18	ANOHR (BTU/KWH)	6947.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	6947.0
19	NOF (%)	63.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	63.00
20	NPC	1700	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	1700

21	ANOHR EQUATION	$ANOHR = A+B(N.O.F)$ A=0 B=0
----	----------------	---------------------------------

NOTE : LINE 17 IS DATA WHEN THE UNIT IS SYNCHRONIZED TO THIS SYSTEM

FILED:
 SUSPENDED:
 EFFECTIVE:
 DOCKET NO:
 ORDER NO:

ISSUED BY: FLORIDA POWER AND LIGHT CO.

ACTUAL PERFORMANCE DATA
 COMPANY: FLORIDA POWER AND LIGHT
 FROM: Jan-2022 TO: Dec-2022

		PLANT/UNIT: Manatee - PM3											PM3-03	
		Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	Ytd
1	EAF (%)	99.10	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	99.10
2	PH	744.00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	744.00
3	SH	744.00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	744.00
4	RSH	0.00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.00
5	UH	0.00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.00
6	POH	0.00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.00
7	FOH	0.00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.00
8	MOH	0.00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.00
9	PPOH	0.00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.00
10	LRPP (MW)	0.00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.00
11	PFOH	30.28	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	30.28
12	LRPF (MW)	273.54	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	273.54
13	PMOH	0.00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.00
14	LRPM (MW)	0.00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.00
15	NSC	1223	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	1223
16	OPERBTU (MBTU)	3092717	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	3092717
17	NET GEN	509047.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	509047.0
18	ANOHR (BTU/KWH)	6076.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	6076.0
19	NOF (%)	55.90	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	55.90
20	NPC	1223	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	1223

21	ANOHR EQUATION	$ANOHR = A+B(N.O.F)$ A=0 B=0
----	----------------	---------------------------------

NOTE : LINE 17 IS DATA WHEN THE UNIT IS SYNCHRONIZED TO THIS SYSTEM

FILED:
 SUSPENDED:
 EFFECTIVE:
 DOCKET NO:
 ORDER NO:

ISSUED BY: FLORIDA POWER AND LIGHT CO.

ACTUAL PERFORMANCE DATA
 COMPANY: FLORIDA POWER AND LIGHT
 FROM: Jan-2022 TO: Dec-2022

		PLANT/UNIT: Martin - PM8						PM8-08						
		Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	Ytd
1	EAF (%)	98.70	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	98.70
2	PH	744.00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	744.00
3	SH	724.68	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	724.68
4	RSH	19.32	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	19.32
5	UH	0.00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.00
6	POH	0.00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.00
7	FOH	0.00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.00
8	MOH	0.00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.00
9	PPOH	0.00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.00
10	LRPP (MW)	0.00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.00
11	PFOH	11.60	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	11.60
12	LRPF (MW)	304.51	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	304.51
13	PMOH	27.38	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	27.38
14	LRPM (MW)	304.52	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	304.52
15	NSC	1218	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	1218
16	OPERBTU (MBTU)	3747493	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	3747493
17	NET GEN	533006.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	533006.0
18	ANOHR (BTU/KWH)	7031.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	7031.0
19	NOF (%)	60.40	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	60.40
20	NPC	1218	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	1218

21	ANOHR EQUATION	$ANOHR = A+B(N.O.F)$ A=0 B=0
----	----------------	---------------------------------

NOTE : LINE 17 IS DATA WHEN THE UNIT IS SYNCHRONIZED TO THIS SYSTEM

ISSUED BY: FLORIDA POWER AND LIGHT CO.

FILED:
 SUSPENDED:
 EFFECTIVE:
 DOCKET NO:
 ORDER NO:

ACTUAL PERFORMANCE DATA
 COMPANY: FLORIDA POWER AND LIGHT
 FROM: Jan-2022 TO: Dec-2022

		PLANT/UNIT: Port Everglades - PPE											PPE-05	
		Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	Ytd
1	EAF (%)	100.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	100.00
2	PH	744.00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	744.00
3	SH	744.00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	744.00
4	RSH	0.00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.00
5	UH	0.00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.00
6	POH	0.00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.00
7	FOH	0.00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.00
8	MOH	0.00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.00
9	PPOH	0.00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.00
10	LRPP (MW)	0.00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.00
11	PFOH	0.00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.00
12	LRPF (MW)	0.00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.00
13	PMOH	0.00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.00
14	LRPM (MW)	0.00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.00
15	NSC	1254	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	1254
16	OPERBTU (MBTU)	5671237	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	5671237
17	NET GEN	866926.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	866926.0
18	ANOHR (BTU/KWH)	6542.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	6542.0
19	NOF (%)	92.90	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	92.90
20	NPC	1254	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	1254

21	ANOHR EQUATION	$ANOHR = A+B(N.O.F)$ A=0 B=0
----	----------------	---------------------------------

NOTE : LINE 17 IS DATA WHEN THE UNIT IS SYNCHRONIZED TO THIS SYSTEM

FILED:
 SUSPENDED:
 EFFECTIVE:
 DOCKET NO:
 ORDER NO:

ISSUED BY: FLORIDA POWER AND LIGHT CO.

ACTUAL PERFORMANCE DATA
 COMPANY: FLORIDA POWER AND LIGHT
 FROM: Jan-2022 TO: Dec-2022

		PLANT/UNIT: Riviera - PRV PRV-05												
		Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	Ytd
1	EAF (%)	94.70	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	94.70
2	PH	744.00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	744.00
3	SH	744.00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	744.00
4	RSH	0.00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.00
5	UH	0.00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.00
6	POH	0.00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.00
7	FOH	0.00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.00
8	MOH	0.00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.00
9	PPOH	0.00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.00
10	LRPP (MW)	0.00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.00
11	PFOH	0.00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.00
12	LRPF (MW)	0.00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.00
13	PMOH	117.57	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	117.57
14	LRPM (MW)	436.00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	436.00
15	NSC	1308	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	1308
16	OPERBTU (MBTU)	2780735	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	2780735
17	NET GEN	411337.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	411337.0
18	ANOHR (BTU/KWH)	6760.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	6760.0
19	NOF (%)	42.30	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	42.30
20	NPC	1308	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	1308

21	ANOHR EQUATION	$ANOHR = A+B(N.O.F)$ A=0 B=0
----	----------------	---------------------------------

NOTE : LINE 17 IS DATA WHEN THE UNIT IS SYNCHRONIZED TO THIS SYSTEM

FILED:
 SUSPENDED:
 EFFECTIVE:
 DOCKET NO:
 ORDER NO:

ISSUED BY: FLORIDA POWER AND LIGHT CO.

ACTUAL PERFORMANCE DATA
 COMPANY: FLORIDA POWER AND LIGHT
 FROM: Jan-2022 TO: Dec-2022

		PLANT/UNIT: St. Lucie Nuclear - PSL											PSL-01	
		Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	Ytd
1	EAF (%)	98.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	98.00
2	PH	744.00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	744.00
3	SH	744.00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	744.00
4	RSH	0.00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.00
5	UH	0.00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.00
6	POH	0.00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.00
7	FOH	0.00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.00
8	MOH	0.00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.00
9	PPOH	532.82	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	532.82
10	LRPP (MW)	19.55	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	19.55
11	PFOH	211.18	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	211.18
12	LRPF (MW)	19.60	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	19.60
13	PMOH	0.00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.00
14	LRPM (MW)	0.00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.00
15	NSC	981	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	981
16	OPERBTU (MBTU)	7538977	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	7538977
17	NET GEN	732926.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	732926.0
18	ANOHR (BTU/KWH)	10286.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	10286.0
19	NOF (%)	100.40	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	100.40
20	NPC	981	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	981

21	ANOHR EQUATION	$ANOHR = A+B(N.O.F)$ A=0 B=0
----	----------------	---------------------------------

NOTE : LINE 17 IS DATA WHEN THE UNIT IS SYNCHRONIZED TO THIS SYSTEM

FILED:
 SUSPENDED:
 EFFECTIVE:
 DOCKET NO:
 ORDER NO:

ISSUED BY: FLORIDA POWER AND LIGHT CO.

ACTUAL PERFORMANCE DATA
 COMPANY: FLORIDA POWER AND LIGHT
 FROM: Jan-2022 TO: Dec-2022

		PLANT/UNIT: St. Lucie Nuclear - PSL											PSL-02	
		Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	Ytd
1	EAF (%)	53.80	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	53.80
2	PH	744.00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	744.00
3	SH	408.75	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	408.75
4	RSH	0.00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.00
5	UH	335.25	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	335.25
6	POH	0.00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.00
7	FOH	335.25	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	335.25
8	MOH	0.00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.00
9	PPOH	0.00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.00
10	LRPP (MW)	0.00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.00
11	PFOH	26.25	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	26.25
12	LRPF (MW)	333.66	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	333.66
13	PMOH	0.00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.00
14	LRPM (MW)	0.00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.00
15	NSC	987	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	987
16	OPERBTU (MBTU)	4121057	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	4121057
17	NET GEN	405132.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	405132.0
18	ANOHR (BTU/KWH)	10172.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	10172.0
19	NOF (%)	100.40	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	100.40
20	NPC	987	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	987

21	ANOHR EQUATION	$ANOHR = A+B(N.O.F)$ A=0 B=0
----	----------------	---------------------------------

NOTE : LINE 17 IS DATA WHEN THE UNIT IS SYNCHRONIZED TO THIS SYSTEM

FILED:
 SUSPENDED:
 EFFECTIVE:
 DOCKET NO:
 ORDER NO:

ISSUED BY: FLORIDA POWER AND LIGHT CO.

ACTUAL PERFORMANCE DATA
 COMPANY: FLORIDA POWER AND LIGHT
 FROM: Jan-2022 TO: Dec-2022

		PLANT/UNIT: Sanford - PSR											PSR-05	
		Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	Ytd
1	EAF (%)	99.40	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	99.40
2	PH	744.00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	744.00
3	SH	464.82	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	464.82
4	RSH	279.18	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	279.18
5	UH	0.00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.00
6	POH	0.00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.00
7	FOH	0.00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.00
8	MOH	0.00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.00
9	PPOH	0.00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.00
10	LRPP (MW)	0.00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.00
11	PFOH	10.13	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	10.13
12	LRPF (MW)	141.88	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	141.88
13	PMOH	12.92	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	12.92
14	LRPM (MW)	287.00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	287.00
15	NSC	1147	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	1147
16	OPERBTU (MBTU)	1596140	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	1596140
17	NET GEN	223112.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	223112.0
18	ANOHR (BTU/KWH)	7154.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	7154.0
19	NOF (%)	41.90	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	41.90
20	NPC	1147	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	1147

21	ANOHR EQUATION	$ANOHR = A+B(N.O.F)$ A=0 B=0
----	----------------	---------------------------------

NOTE : LINE 17 IS DATA WHEN THE UNIT IS SYNCHRONIZED TO THIS SYSTEM

FILED:
 SUSPENDED:
 EFFECTIVE:
 DOCKET NO:
 ORDER NO:

ISSUED BY: FLORIDA POWER AND LIGHT CO.

ACTUAL PERFORMANCE DATA
 COMPANY: FLORIDA POWER AND LIGHT
 FROM: Jan-2022 TO: Dec-2022

		PLANT/UNIT: Turkey Point Nuclear - PTN											PTN-03	
		Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	Ytd
1	EAF (%)	100.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	100.00
2	PH	744.00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	744.00
3	SH	744.00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	744.00
4	RSH	0.00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.00
5	UH	0.00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.00
6	POH	0.00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.00
7	FOH	0.00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.00
8	MOH	0.00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.00
9	PPOH	0.00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.00
10	LRPP (MW)	0.00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.00
11	PFOH	0.00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.00
12	LRPF (MW)	0.00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.00
13	PMOH	0.00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.00
14	LRPM (MW)	0.00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.00
15	NSC	837	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	837
16	OPERBTU (MBTU)	6698242	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	6698242
17	NET GEN	650567.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	650567.0
18	ANOHR (BTU/KWH)	10296.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	10296.0
19	NOF (%)	104.50	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	104.50
20	NPC	837	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	837

21	ANOHR EQUATION	$ANOHR = A+B(N.O.F)$ A=0 B=0
----	----------------	---------------------------------

NOTE : LINE 17 IS DATA WHEN THE UNIT IS SYNCHRONIZED TO THIS SYSTEM

FILED:
 SUSPENDED:
 EFFECTIVE:
 DOCKET NO:
 ORDER NO:

ISSUED BY: FLORIDA POWER AND LIGHT CO.

ACTUAL PERFORMANCE DATA
 COMPANY: FLORIDA POWER AND LIGHT
 FROM: Jan-2022 TO: Dec-2022

		PLANT/UNIT: Turkey Point Nuclear - PTN											PTN-04	
		Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	Ytd
1	EAF (%)	100.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	100.00
2	PH	744.00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	744.00
3	SH	744.00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	744.00
4	RSH	0.00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.00
5	UH	0.00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.00
6	POH	0.00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.00
7	FOH	0.00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.00
8	MOH	0.00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.00
9	PPOH	0.00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.00
10	LRPP (MW)	0.00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.00
11	PFOH	0.00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.00
12	LRPF (MW)	0.00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.00
13	PMOH	0.00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.00
14	LRPM (MW)	0.00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.00
15	NSC	844	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	844
16	OPERBTU (MBTU)	6707598	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	6707598
17	NET GEN	654745.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	654745.0
18	ANOHR (BTU/KWH)	10245.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	10245.0
19	NOF (%)	104.30	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	104.30
20	NPC	844	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	844

21	ANOHR EQUATION	$ANOHR = A+B(N.O.F)$ A=0 B=0
----	----------------	---------------------------------

NOTE : LINE 17 IS DATA WHEN THE UNIT IS SYNCHRONIZED TO THIS SYSTEM

FILED:
 SUSPENDED:
 EFFECTIVE:
 DOCKET NO:
 ORDER NO:

ISSUED BY: FLORIDA POWER AND LIGHT CO.

ACTUAL PERFORMANCE DATA
 COMPANY: FLORIDA POWER AND LIGHT
 FROM: Jan-2022 TO: Dec-2022

		PLANT/UNIT: West County Energy Center - PWC											PWC-01	
		Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	Ytd
1	EAF (%)	95.40	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	95.40
2	PH	744.00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	744.00
3	SH	744.00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	744.00
4	RSH	0.00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.00
5	UH	0.00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.00
6	POH	0.00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.00
7	FOH	0.00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.00
8	MOH	0.00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.00
9	PPOH	0.00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.00
10	LRPP (MW)	0.00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.00
11	PFOH	6.08	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	6.08
12	LRPF (MW)	408.00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	408.00
13	PMOH	95.93	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	95.93
14	LRPM (MW)	408.00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	408.00
15	NSC	1223	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	1223
16	OPERBTU (MBTU)	3477043	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	3477043
17	NET GEN	507462.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	507462.0
18	ANOHR (BTU/KWH)	6852.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	6852.0
19	NOF (%)	55.80	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	55.80
20	NPC	1223	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	1223

21	ANOHR EQUATION	$ANOHR = A+B(N.O.F)$ A=0 B=0
----	----------------	---------------------------------

NOTE : LINE 17 IS DATA WHEN THE UNIT IS SYNCHRONIZED TO THIS SYSTEM

FILED:
 SUSPENDED:
 EFFECTIVE:
 DOCKET NO:
 ORDER NO:

ISSUED BY: FLORIDA POWER AND LIGHT CO.

ACTUAL PERFORMANCE DATA
 COMPANY: FLORIDA POWER AND LIGHT
 FROM: Jan-2022 TO: Dec-2022

		PLANT/UNIT: West County Energy Center - PWC											PWC-02	
		Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	Ytd
1	EAF (%)	89.70	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	89.70
2	PH	744.00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	744.00
3	SH	744.00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	744.00
4	RSH	0.00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.00
5	UH	0.00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.00
6	POH	0.00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.00
7	FOH	0.00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.00
8	MOH	0.00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.00
9	PPOH	0.00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.00
10	LRPP (MW)	0.00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.00
11	PFOH	3.58	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	3.58
12	LRPF (MW)	407.00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	407.00
13	PMOH	226.68	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	226.68
14	LRPM (MW)	407.00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	407.00
15	NSC	1223	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	1223
16	OPERBTU (MBTU)	3023968	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	3023968
17	NET GEN	435387.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	435387.0
18	ANOHR (BTU/KWH)	6946.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	6946.0
19	NOF (%)	47.90	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	47.90
20	NPC	1223	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	1223

21	ANOHR EQUATION	$ANOHR = A+B(N.O.F)$ A=0 B=0
----	----------------	---------------------------------

NOTE : LINE 17 IS DATA WHEN THE UNIT IS SYNCHRONIZED TO THIS SYSTEM

FILED:
 SUSPENDED:
 EFFECTIVE:
 DOCKET NO:
 ORDER NO:

ISSUED BY: FLORIDA POWER AND LIGHT CO.

ACTUAL PERFORMANCE DATA
 COMPANY: FLORIDA POWER AND LIGHT
 FROM: Jan-2022 TO: Dec-2022

		PLANT/UNIT: West County Energy Center - PWC											PWC-03	
		Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	Ytd
1	EAF (%)	91.40	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	91.40
2	PH	744.00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	744.00
3	SH	744.00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	744.00
4	RSH	0.00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.00
5	UH	0.00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.00
6	POH	0.00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.00
7	FOH	0.00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.00
8	MOH	0.00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.00
9	PPOH	0.00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.00
10	LRPP (MW)	0.00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.00
11	PFOH	85.97	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	85.97
12	LRPF (MW)	414.27	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	414.27
13	PMOH	111.17	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	111.17
14	LRPM (MW)	388.88	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	388.88
15	NSC	1228	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	1228
16	OPERBTU (MBTU)	3127193	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	3127193
17	NET GEN	449976.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	449976.0
18	ANOHR (BTU/KWH)	6950.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	6950.0
19	NOF (%)	49.30	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	49.30
20	NPC	1228	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	1228

21	ANOHR EQUATION	$ANOHR = A+B(N.O.F)$ A=0 B=0
----	----------------	---------------------------------

NOTE : LINE 17 IS DATA WHEN THE UNIT IS SYNCHRONIZED TO THIS SYSTEM

FILED:
 SUSPENDED:
 EFFECTIVE:
 DOCKET NO:
 ORDER NO:

ISSUED BY: FLORIDA POWER AND LIGHT CO.

ACTUAL PERFORMANCE DATA
 COMPANY: FLORIDA POWER AND LIGHT
 FROM: Jan-2022 TO: Dec-2022

		PLANT/UNIT: Turkey Point - TP5											TP5-05	
		Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	Ytd
1	EAF (%)	92.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	92.00
2	PH	744.00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	744.00
3	SH	690.77	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	690.77
4	RSH	53.23	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	53.23
5	UH	0.00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.00
6	POH	0.00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.00
7	FOH	0.00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.00
8	MOH	0.00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.00
9	PPOH	0.00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.00
10	LRPP (MW)	0.00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.00
11	PFOH	1.18	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	1.18
12	LRPF (MW)	191.00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	191.00
13	PMOH	391.00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	391.00
14	LRPM (MW)	191.00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	191.00
15	NSC	1252	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	1252
16	OPERBTU (MBTU)	2739803	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	2739803
17	NET GEN	370766.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	370766.0
18	ANOHR (BTU/KWH)	7390.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	7390.0
19	NOF (%)	42.90	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	42.90
20	NPC	1252	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	1252

21	ANOHR EQUATION	$ANOHR = A+B(N.O.F)$ A=0 B=0
----	----------------	---------------------------------

NOTE : LINE 17 IS DATA WHEN THE UNIT IS SYNCHRONIZED TO THIS SYSTEM

FILED:
 SUSPENDED:
 EFFECTIVE:
 DOCKET NO:
 ORDER NO:

ISSUED BY: FLORIDA POWER AND LIGHT CO.

ACTUAL PERFORMANCE DATA
 COMPANY: FLORIDA POWER AND LIGHT
 FROM: Jan-2022 TO: Dec-2022

PLANT/UNIT: Cape Canaveral - PCC		PCC-03		
DATE	OUTAGE TYPE(1)	HOURS	(MW) AFFECTED	DESCRIPTION
2022-01-10	PMO	118.3	243.00	PCC Block De-rate Had one loop of condenser out of service for cleaning
2022-01-10	PMO	45.9	204.25	PCC Block De-rate Had one loop of condenser out of service for cleaning
2022-01-10	PMO	118.3	103.37	PCC Block De-rate Had one loop of condenser out of service for cleaning
2022-01-10	PMO	60.2	103.37	PCC Block De-rate Had one loop of condenser out of service for cleaning
2022-01-12	PMO	62.1	274.00	PCC 31 Borescope Turbine
2022-01-12	PMO	62.1	204.25	PCC Block De-rate Had one loop of condenser out of service for cleaning
2022-01-13	PMO	168.6	274.00	PCC 3-3 Borescope Turbine
2022-01-13	PMO	58.0	103.37	PCC Block De-rate Had one loop of condenser out of service for cleaning
2022-01-15	PMO	10.2	204.25	PCC Block De-rate Had one loop of condenser out of service for cleaning
2022-01-15	PFO	0.5	95.77	PCC 3-1 Partial Forced CRH Valve Failed to open
2022-01-15	PFO	0.5	162.00	PCC 3-1 Partial Forced CRH Valve Failed to open

(1) FFO - FULL FORCED OUTAGE
 PPO - PARTIAL PLANNED OUTAGE
 PMO - PARTIAL MAINTENANCE OUTAGE
 PO - PLANNED OUTAGE
 PFO - PARTIAL FORCED OUTAGE
 FMO - FULL MAINTENANCE OUTAGE

FILED:
 SUSPENDED:
 EFFECTIVE:
 DOCKET NO:
 ORDER NO:

ISSUED BY: FLORIDA POWER AND LIGHT CO.

ACTUAL PERFORMANCE DATA
COMPANY: FLORIDA POWER AND LIGHT
FROM: Jan-2022 TO: Dec-2022

PLANT/UNIT: Fort Myers - PFM		PFM-02		
DATE	OUTAGE TYPE(1)	HOURS	(MW) AFFECTED	DESCRIPTION
2022-01-10	PFO	13.0	189.00	PFM 2D EFOR - Flame scanners
2022-01-19	PFO	40.5	189.00	2B EFOR- Boiler Feed Pump Bearings
2022-01-19	PFO	40.5	23.00	2B EFOR- Boiler Feed Pump Bearings
2022-01-19	PFO	40.5	71.00	2B EFOR- Boiler Feed Pump Bearings
2022-01-25	PMO	69.2	189.00	2D Event MOF repair IP steam leak
2022-01-30	PFO	3.9	189.00	PFM 2D EFOR - 2D exhaust spread trip

(1) FFO - FULL FORCED OUTAGE
PPO - PARTIAL PLANNED OUTAGE
PMO - PARTIAL MAINTENANCE OUTAGE
PO - PLANNED OUTAGE
PFO - PARTIAL FORCED OUTAGE
FMO - FULL MAINTENANCE OUTAGE

FILED:
SUSPENDED:
EFFECTIVE:
DOCKET NO:
ORDER NO:

ISSUED BY: FLORIDA POWER AND LIGHT CO.

ACTUAL PERFORMANCE DATA
COMPANY: FLORIDA POWER AND LIGHT
FROM: Jan-2022 TO: Dec-2022

PLANT/UNIT: Manatee - PM3		PM3-03		
DATE	OUTAGE TYPE(1)	HOURS	(MW) AFFECTED	DESCRIPTION
2022-01-04	PFO	1.8	193.00	PMT 3D EFOR - AUX STOP VALVE SOLENOID FAILURE
2022-01-04	PFO	1.8	112.75	PMT 3D EFOR - AUX STOP VALVE SOLENOID FAILURE
2022-01-09	PFO	19.7	193.00	PMT 3B EFOR - TRIPPED ON HIGH HIGH HAZ GAS GAS COMPARTMENT
2022-01-09	PFO	19.7	112.75	PMT 3B EFOR - TRIPPED ON HIGH HIGH HAZ GAS GAS COMPARTMENT
2022-01-23	PFO	8.6	193.00	3D Tripped on High Exhaust Spread

(1) FFO - FULL FORCED OUTAGE
PPO - PARTIAL PLANNED OUTAGE
PMO - PARTIAL MAINTENANCE OUTAGE
PO - PLANNED OUTAGE
PFO - PARTIAL FORCED OUTAGE
FMO - FULL MAINTENANCE OUTAGE

FILED:
SUSPENDED:
EFFECTIVE:
DOCKET NO:
ORDER NO:

ISSUED BY: FLORIDA POWER AND LIGHT CO.

ACTUAL PERFORMANCE DATA
 COMPANY: FLORIDA POWER AND LIGHT
 FROM: Jan-2022 TO: Dec-2022

PLANT/UNIT: Martin - PM8		PM8-08		
DATE	OUTAGE TYPE(1)	HOURS	(MW) AFFECTED	DESCRIPTION
2022-01-01	PFO	2.3	191.00	EFOR 8D 89-ND Switch Malfunction
2022-01-01	PFO	2.3	113.50	EFOR 8D 89-ND Switch Malfunction
2022-01-05	PFO	0.3	191.00	EFOR 8D Compressor Bleed Valve
2022-01-05	PFO	0.3	114.00	EFOR 8D Compressor Bleed Valve
2022-01-15	PFO	3.3	191.00	EFOR 8A Trip due to Recirculation Valve
2022-01-15	PFO	3.3	113.50	EFOR 8A Trip due to Recirculation Valve
2022-01-21	PFO	1.1	191.00	EFOR 8A Trip due to Low Min Flow
2022-01-21	PFO	1.1	113.50	EFOR 8A Trip due to Low Min Flow
2022-01-23	PFO	4.4	191.00	Unit 8A EFOR Recirc Valve
2022-01-23	PFO	4.4	113.50	Unit 8A EFOR Recirc Valve
2022-01-26	PMO	26.0	191.00	SNOW: 8A Atomizing Line Walkdown
2022-01-26	PMO	26.0	113.50	SNOW: 8A Atomizing Line Walkdown
2022-01-28	PMO	1.3	191.00	SNOW: 8D Switch Yard Relay
2022-01-28	PMO	1.3	114.00	SNOW: 8D Switch Yard Relay

(1) FFO - FULL FORCED OUTAGE
 PPO - PARTIAL PLANNED OUTAGE
 PMO - PARTIAL MAINTENANCE OUTAGE
 PO - PLANNED OUTAGE
 PFO - PARTIAL FORCED OUTAGE
 FMO - FULL MAINTENANCE OUTAGE

FILED:
 SUSPENDED:
 EFFECTIVE:
 DOCKET NO:
 ORDER NO:

ISSUED BY: FLORIDA POWER AND LIGHT CO.

ACTUAL PERFORMANCE DATA
COMPANY: FLORIDA POWER AND LIGHT
FROM: Jan-2022 TO: Dec-2022

PLANT/UNIT: Port Everglades - PPE		PPE-05		
DATE	OUTAGE TYPE(1)	HOURS	(MW) AFFECTED	DESCRIPTION

- (1) FFO - FULL FORCED OUTAGE
- PPO - PARTIAL PLANNED OUTAGE
- PMO - PARTIAL MAINTENANCE OUTAGE
- PO - PLANNED OUTAGE
- PFO - PARTIAL FORCED OUTAGE
- FMO - FULL MAINTENANCE OUTAGE

- FILED:
- SUSPENDED:
- EFFECTIVE:
- DOCKET NO:
- ORDER NO:

ISSUED BY: FLORIDA POWER AND LIGHT CO.

ACTUAL PERFORMANCE DATA
COMPANY: FLORIDA POWER AND LIGHT
FROM: Jan-2022 TO: Dec-2022

PLANT/UNIT: Riviera - PRV		PRV-05		
DATE	OUTAGE TYPE(1)	HOURS	(MW) AFFECTED	DESCRIPTION
2022-01-15	PMO	117.5	274.00	PRV 51 - Event MOF - BFP Vibration
2022-01-15	PMO	117.5	162.00	PRV 51 - Event MOF - BFP Vibration

(1) FFO - FULL FORCED OUTAGE
PPO - PARTIAL PLANNED OUTAGE
PMO - PARTIAL MAINTENANCE OUTAGE
PO - PLANNED OUTAGE
PFO - PARTIAL FORCED OUTAGE
FMO - FULL MAINTENANCE OUTAGE

FILED:
SUSPENDED:
EFFECTIVE:
DOCKET NO:
ORDER NO:

ISSUED BY: FLORIDA POWER AND LIGHT CO.

ACTUAL PERFORMANCE DATA
 COMPANY: FLORIDA POWER AND LIGHT
 FROM: Jan-2022 TO: Dec-2022

PLANT/UNIT: St. Lucie Nuclear - PSL		PSL-01		
DATE	OUTAGE TYPE(1)	HOURS	(MW) AFFECTED	DESCRIPTION
2022-01-01	PFO	211.1	19.60	U1 UEL Condensate Pump Degradation 01012022
2022-01-09	PPO	532.8	19.54	U1 PEL Condensate Pump Degradation 01092022

(1) FFO - FULL FORCED OUTAGE
 PPO - PARTIAL PLANNED OUTAGE
 PMO - PARTIAL MAINTENANCE OUTAGE
 PO - PLANNED OUTAGE
 PFO - PARTIAL FORCED OUTAGE
 FMO - FULL MAINTENANCE OUTAGE

FILED:
 SUSPENDED:
 EFFECTIVE:
 DOCKET NO:
 ORDER NO:

ISSUED BY: FLORIDA POWER AND LIGHT CO.

ACTUAL PERFORMANCE DATA
COMPANY: FLORIDA POWER AND LIGHT
FROM: Jan-2022 TO: Dec-2022

PLANT/UNIT: St. Lucie Nuclear - PSL		PSL-02		
DATE	OUTAGE TYPE(1)	HOURS	(MW) AFFECTED	DESCRIPTION
2022-01-06	PFO	8.2	329.00	U2 UEL CEA 27 Down Power 01062022
2022-01-06	FFO	307.5	987.00	U2 UEL Shut Down For CEA 27 Repair 010622
2022-01-19	FFO	27.7	987.00	U2 UEL CEA 27 Shut Down Extension for MG Set Repair 01192022
2022-01-20	PFO	0.3	335.78	U2 UEL CEA 27 Power Ascension 01202022
2022-01-20	PFO	18.0	335.78	U2 UEL CEA 27 Power Ascension 01202022

(1) FFO - FULL FORCED OUTAGE
PPO - PARTIAL PLANNED OUTAGE
PMO - PARTIAL MAINTENANCE OUTAGE
PO - PLANNED OUTAGE
PFO - PARTIAL FORCED OUTAGE
FMO - FULL MAINTENANCE OUTAGE

FILED:
SUSPENDED:
EFFECTIVE:
DOCKET NO:
ORDER NO:

ISSUED BY: FLORIDA POWER AND LIGHT CO.

ACTUAL PERFORMANCE DATA
 COMPANY: FLORIDA POWER AND LIGHT
 FROM: Jan-2022 TO: Dec-2022

PLANT/UNIT: Sanford - PSR		PSR-05		
DATE	OUTAGE TYPE(1)	HOURS	(MW) AFFECTED	DESCRIPTION
2022-01-01	PMO	12.9	192.00	PSR 5C EVENT MOF - TUBE LEAK
2022-01-01	PMO	12.9	95.00	PSR 5C EVENT MOF - TUBE LEAK
2022-01-31	PFO	10.1	95.00	PSR 5C Partial EFOR - CRH steam stop stuck
2022-01-31	PFO	10.1	46.87	PSR 5C Partial EFOR - CRH steam stop stuck

(1) FFO - FULL FORCED OUTAGE
 PPO - PARTIAL PLANNED OUTAGE
 PMO - PARTIAL MAINTENANCE OUTAGE
 PO - PLANNED OUTAGE
 PFO - PARTIAL FORCED OUTAGE
 FMO - FULL MAINTENANCE OUTAGE

FILED:
 SUSPENDED:
 EFFECTIVE:
 DOCKET NO:
 ORDER NO:

ISSUED BY: FLORIDA POWER AND LIGHT CO.

ACTUAL PERFORMANCE DATA
COMPANY: FLORIDA POWER AND LIGHT
FROM: Jan-2022 TO: Dec-2022

PLANT/UNIT: Turkey Point Nuclear - PTN		PTN-03		
DATE	OUTAGE TYPE(1)	HOURS	(MW) AFFECTED	DESCRIPTION

- (1) FFO - FULL FORCED OUTAGE
- PPO - PARTIAL PLANNED OUTAGE
- PMO - PARTIAL MAINTENANCE OUTAGE
- PO - PLANNED OUTAGE
- PFO - PARTIAL FORCED OUTAGE
- FMO - FULL MAINTENANCE OUTAGE

- FILED:
- SUSPENDED:
- EFFECTIVE:
- DOCKET NO:
- ORDER NO:

ISSUED BY: FLORIDA POWER AND LIGHT CO.

ACTUAL PERFORMANCE DATA
COMPANY: FLORIDA POWER AND LIGHT
FROM: Jan-2022 TO: Dec-2022

PLANT/UNIT: Turkey Point Nuclear - PTN		PTN-04		
DATE	OUTAGE TYPE(1)	HOURS	(MW) AFFECTED	DESCRIPTION

- (1) FFO - FULL FORCED OUTAGE
- PPO - PARTIAL PLANNED OUTAGE
- PMO - PARTIAL MAINTENANCE OUTAGE
- PO - PLANNED OUTAGE
- PFO - PARTIAL FORCED OUTAGE
- FMO - FULL MAINTENANCE OUTAGE

- FILED:
- SUSPENDED:
- EFFECTIVE:
- DOCKET NO:
- ORDER NO:

ISSUED BY: FLORIDA POWER AND LIGHT CO.

ACTUAL PERFORMANCE DATA
COMPANY: FLORIDA POWER AND LIGHT
FROM: Jan-2022 TO: Dec-2022

PLANT/UNIT: West County Energy Center - PWC		PWC-01		
DATE	OUTAGE TYPE(1)	HOURS	(MW) AFFECTED	DESCRIPTION
2022-01-18	PFO	4.6	247.00	PWC 1A - SF - 41E Failed to Stay Closed
2022-01-18	PFO	4.6	161.00	PWC 1A - SF - 41E Failed to Stay Closed
2022-01-25	PMO	80.9	247.00	PWC 1B - Event MOF - HRSG Tube Leak and FO Valve Repair
2022-01-25	PMO	80.9	161.00	PWC 1B - Event MOF - HRSG Tube Leak and FO Valve Repair
2022-01-30	PFO	1.4	247.00	PWC 1B - SF - SW Loss of Flame
2022-01-30	PFO	1.4	161.00	PWC 1B - SF - SW Loss of Flame
2022-01-31	PMO	14.9	247.00	PWC 1A - Event MOF - IP Cooling Steam MOV repair
2022-01-31	PMO	14.9	161.00	PWC 1A - Event MOF - IP Cooling Steam MOV repair

(1) FFO - FULL FORCED OUTAGE
 PPO - PARTIAL PLANNED OUTAGE
 PMO - PARTIAL MAINTENANCE OUTAGE
 PO - PLANNED OUTAGE
 PFO - PARTIAL FORCED OUTAGE
 FMO - FULL MAINTENANCE OUTAGE

FILED:
 SUSPENDED:
 EFFECTIVE:
 DOCKET NO:
 ORDER NO:

ISSUED BY: FLORIDA POWER AND LIGHT CO.

ACTUAL PERFORMANCE DATA
 COMPANY: FLORIDA POWER AND LIGHT
 FROM: Jan-2022 TO: Dec-2022

PLANT/UNIT: West County Energy Center - PWC			PWC-02	
DATE	OUTAGE TYPE(1)	HOURS	(MW) AFFECTED	DESCRIPTION
2022-01-02	PFO	3.5	247.00	PWC 2C - EFOR - Blade Path Damaged R1 Vanes
2022-01-02	PFO	3.5	160.00	PWC 2C - EFOR - Blade Path Damaged R1 Vanes
2022-01-04	PMO	226.6	247.00	PWC 2C - Event MOF - Damaged R1 Vanes
2022-01-04	PMO	226.6	160.00	PWC 2C - Event MOF - Damaged R1 Vanes

(1) FFO - FULL FORCED OUTAGE
 PPO - PARTIAL PLANNED OUTAGE
 PMO - PARTIAL MAINTENANCE OUTAGE
 PO - PLANNED OUTAGE
 PFO - PARTIAL FORCED OUTAGE
 FMO - FULL MAINTENANCE OUTAGE

FILED:
 SUSPENDED:
 EFFECTIVE:
 DOCKET NO:
 ORDER NO:

ISSUED BY: FLORIDA POWER AND LIGHT CO.

ACTUAL PERFORMANCE DATA
 COMPANY: FLORIDA POWER AND LIGHT
 FROM: Jan-2022 TO: Dec-2022

PLANT/UNIT: West County Energy Center - PWC		PWC-03		
DATE	OUTAGE TYPE(1)	HOURS	(MW) AFFECTED	DESCRIPTION
2022-01-02	PFO	1.5	249.00	PWC 3A - EFOR - Reverse Power Trip
2022-01-02	PFO	1.5	160.00	PWC 3A - EFOR - Reverse Power Trip
2022-01-18	PFO	6.2	249.00	PWC 3C - SF - CT Trip Flame Out
2022-01-18	PFO	6.2	160.00	PWC 3C - SF - CT Trip Flame Out
2022-01-19	PFO	68.6	249.00	PWC 3C - SF - FG Main FCV Pilot FCV DP High
2022-01-19	PFO	68.6	160.00	PWC 3C - SF - FG Main FCV Pilot FCV DP High
2022-01-24	PFO	8.5	249.00	PWC 3A - SF - Flame Out Trip
2022-01-24	PFO	8.5	160.00	PWC 3A - SF - Flame Out Trip
2022-01-24	PFO	2.5	249.00	PWC 3C - SF - Blade Path Spread
2022-01-24	PFO	2.5	160.00	PWC 3C - SF - Blade Path Spread
2022-01-24	PMO	96.5	249.00	PWC 3A - Event MOF - Cooling Steam Valve
2022-01-24	PMO	96.5	161.00	PWC 3A - Event MOF - Cooling Steam Valve
2022-01-27	PFO	1.0	249.00	PWC 3C - SF - Blade Path Trip
2022-01-27	PFO	1.0	161.00	PWC 3C - SF - Blade Path Trip
2022-01-31	PMO	14.5	249.00	PWC 3C - Event MOF - Inspect FG Manifold

(1) FFO - FULL FORCED OUTAGE
 PPO - PARTIAL PLANNED OUTAGE
 PMO - PARTIAL MAINTENANCE OUTAGE
 PO - PLANNED OUTAGE
 PFO - PARTIAL FORCED OUTAGE
 FMO - FULL MAINTENANCE OUTAGE

FILED:
 SUSPENDED:
 EFFECTIVE:
 DOCKET NO:
 ORDER NO:

ISSUED BY: FLORIDA POWER AND LIGHT CO.

ACTUAL PERFORMANCE DATA
 COMPANY: FLORIDA POWER AND LIGHT
 FROM: Jan-2022 TO: Dec-2022

PLANT/UNIT: Turkey Point - TP5		TP5-05		
DATE	OUTAGE TYPE(1)	HOURS	(MW) AFFECTED	DESCRIPTION
2022-01-01	PFO	1.1	191.00	PTF CT 5A FORCED OUTAGE VENT VALVE LEAK REPAIR
2022-01-13	PMO	376.7	191.00	PTF CT 5B MOF - LF Upgrades
2022-01-31	PMO	14.2	191.00	PTF CT 5B MOF - LF Upgrade Post Testing

(1) FFO - FULL FORCED OUTAGE
 PPO - PARTIAL PLANNED OUTAGE
 PMO - PARTIAL MAINTENANCE OUTAGE
 PO - PLANNED OUTAGE
 PFO - PARTIAL FORCED OUTAGE
 FMO - FULL MAINTENANCE OUTAGE

FILED:
 SUSPENDED:
 EFFECTIVE:
 DOCKET NO:
 ORDER NO:

ISSUED BY: FLORIDA POWER AND LIGHT CO.