

# AUSLEY & McMULLEN

ATTORNEYS AND COUNSELORS AT LAW

227 SOUTH CALHOUN STREET  
P.O. BOX 391 (ZIP 32302)  
TALLAHASSEE, FLORIDA 32301  
(850) 224-9115 FAX (850) 222-7560

April 3, 2006

HAND DELIVERED

Ms. Blanca S. Bayo, Director  
Division of Commission Clerk  
and Administrative Services  
Florida Public Service Commission  
2540 Shumard Oak Boulevard  
Tallahassee, FL 32399-0850

060000-07

Re: Tampa Electric Company's Ten-Year Site Plan

Dear Ms. Bayo:

Enclosed for filing on behalf of Tampa Electric Company are twenty-five (25) copies of the company's January 2006 to December 2015 Ten-Year Site Plan.

Please acknowledge receipt and filing of the above by stamping the duplicate copy of this letter and returning same to this writer.

Thank you for your assistance in connection with this matter.

Sincerely,



James D. Beasley


JDB/pp  
Enclosures

cc: Michael Haff (w/enc.)


DOCUMENT NUMBER-DATE

02969 APR-3 06

FPSC-COMMISSION CLERK



H.L. Culbreath Bayside Power Station



TAMPA ELECTRIC

---

# TEN-YEAR SITE PLAN FOR ELECTRICAL GENERATING FACILITIES AND ASSOCIATED TRANSMISSION LINES

JANUARY 2006 TO DECEMBER 2015 DOCUMENT NUMBER-DATE

02969 APR-3 8

**TEN-YEAR SITE PLAN FOR  
ELECTRICAL GENERATING FACILITIES AND  
ASSOCIATED TRANSMISSION LINES**

**January 2006 to December 2015**

**TAMPA ELECTRIC COMPANY  
Tampa, Florida**

**April 1, 2006**

## TABLE OF CONTENTS

---

	<u>PAGE</u>
<b>CHAPTER I: DESCRIPTION OF EXISTING FACILITIES</b>	I-1
<b>CHAPTER II: FORECAST OF ELECTRIC POWER, DEMAND, AND ENERGY CONSUMPTION</b>	II-1
<b>CHAPTER III: FORECASTING OF ELECTRIC POWER DEMAND</b>	
Tampa Electric Company Forecasting Methodology	III-1
Retail Load	III-1
1. Economic Analysis	III-2
2. Customer Multiregression Model	III-2
3. Energy Multiregression Model	III-3
4. Demand Multiregression Models	III-7
5. Phosphate Demand and Energy Analysis	III-8
6. Conservation, Load Management and Cogeneration Programs	III-8
Wholesale Load	III-10
Base Case Forecast Assumptions	III-12
Retail Load	III-12
1. Population and Households	III-12
2. Commercial, Industrial and Governmental Employment	III-12
3. Commercial, Industrial and Governmental Output	III-12
4. Per Capita Income	III-12

## TABLE OF CONTENTS

---

	<u>PAGE</u>
<b>CHAPTER III (continued)</b>	
5. Price of Elasticity	III-13
6. Appliance Efficiency Standards	III-13
7. Weather	III-13
High and Low Scenario Forecast Assumptions	III-14
History and Forecast of Energy Use	III-14
Retail Energy	III-14
Wholesale Energy	III-14
History and Forecast of Peak Loads	III-14
<b>CHAPTER IV:    FORECAST OF FACILITIES REQUIREMENTS</b>	<b>IV-1</b>
Cogeneration	IV-1
Fuel Requirements	IV-2
Environmental Considerations	IV-2
Interchange Sales and Purchases	IV-3
<b>CHAPTER V:    OTHER PLANNING ASSUMPTIONS AND INFORMATION</b>	
Transmission Constraints and Impacts	V-1
Expansion Plan Economics and Fuel Forecast	V-1
Generating Unit Performance Assumptions	V-2
Financial Assumptions	V-2
Integrated Resource Planning Process	V-3
Strategic Concerns	V-5

## TABLE OF CONTENTS

---

<b>CHAPTER V (continued)</b>	<b><u>PAGE</u></b>
Generation and Transmission Reliability Criteria	V-6
Generation	V-6
Transmission	V-6
Generation Dispatch Modeled	V-7
Transmission System Planning Loading Limits Criteria	V-7
Available Transmission Transfer Capability (ATC) Criteria	V-8
Transmission Planning Assessment Practices	V-8
Base Case Operating Conditions	V-8
Single Contingency Planning Criteria	V-8
Multiple Contingency Planning Criteria	V-9
First Contingency Total Transfer Capability Considerations	V-9
Transmission Construction and Upgrade Plans	V-9
Supply Side Resources Procurement Process	V-9
DSM Energy Savings Durability	V-10
Tampa Electric's Renewable Energy Program	V-10
 <b>CHAPTER VI: ENVIRONMENTAL AND LAND USE INFORMATION</b>	 <b>VI-1</b>

## LIST OF SCHEDULES

---

<u>SCHEDULES</u>	<u>PAGE</u>
 <u>CHAPTER I</u>	
1 Existing Generating Facilities	I-2
 <u>CHAPTER II</u>	
2.1 History and Forecast of Energy Consumption and Number of Customers by Customer Class	II-2
2.2 History and Forecast of Energy Consumption and Number of Customers by Customer Class	II-3
2.3 History and Forecast of Energy Consumption and Number of Customers by Customer Class	II-4
3.1 History and Forecast of Summer Peak Demand	II-5
3.2 History and Forecast of Winter Peak Demand	II-6
3.3 History and Forecast of Annual Net Energy for Load	II-7
4 Previous Year and 2-Year Forecast of Peak Demand and Net Energy for Load by Month	II-8
5 History and Forecast of Fuel Requirements	II-9
6.1 History and Forecast of Net Energy for Load by Fuel Source in GWH	II-10
6.2 History and Forecast of Net Energy for Load by Fuel Source as a percentage	II-11

## LIST OF SCHEDULES

---

<u>SCHEDULES</u> (continued)	<u>PAGE</u>
 <u>CHAPTER IV</u>	
7.1 Forecast of Capacity, Demand, and Scheduled Maintenance at Time of Summer Peak	IV-5
7.2 Forecast of Capacity, Demand, and Scheduled Maintenance at Time of Winter Peak	IV-6
8 Planned and Prospective Generating Facility Additions	IV-7
9 Status Report and Specifications of Proposed Generating Facilities	IV-8
10 Status Report and Specifications of Proposed Directly Associated Transmission Lines	IV-23



## LIST OF FIGURES

---

<u>FIGURES</u>	<u>PAGE</u>
 <u>CHAPTER I</u>	
I-1 Tampa Electric Service Area Map	I-4
 <u>CHAPTER VI</u>	
VI-1 Site Location of Gannon/Bayside Power Station	VI-2
VI-2 Site Location of Polk Power Station	VI-3
VI-3 Site Location of Big Bend Power Station	VI-4

## TAMPA ELECTRIC COMPANY CODE IDENTIFICATION SHEET

---

<u>Unit Type:</u>	CT	=	Combustion Turbine
	CC	=	Combined Cycle
	CG	=	Coal Gasifier
	D	=	Diesel
	FS	=	Fossil Steam
	HRSG	=	Heat Recovery Steam Generator
	IGCC	=	Integrated Gasification Combined Cycle
	ST	=	Steam Turbine
<u>Unit Status:</u>	P	=	Planned
	T	=	Regulatory Approval Received
	LTRS	=	Long Term Reserve Stand-by
	UC	=	Under Construction
<u>Fuel Type:</u>	BIT	=	Bituminous Coal
	C	=	Coal
	PC	=	Petroleum Coke
	HO	=	Heavy Oil (#6 Oil)
	LO	=	Light Oil (#2 Oil)
	NG	=	Natural Gas
	WH	=	Waste Heat
<u>Environmental:</u>	CL	=	Closed Loop Water Cooled
	CLT	=	Cooling Tower
	EP	=	Electrostatic Precipitator
	FQ	=	Fuel Quality
	LS	=	Low Sulfur
	FGD	=	Flue Gas Desulfurization
	OLS	=	Open Loop Cooling Water System
	OTS	=	Once-Through System
	NR	=	Not Required
<u>Transportation:</u>	PL	=	Pipeline
	TK	=	Truck
	RR	=	Railroad
	WA	=	Water
<u>Other:</u>	N	=	None

**THIS PAGE LEFT INTENTIONALLY BLANK.**

## CHAPTER I

### DESCRIPTION OF EXISTING FACILITIES

#### Description of Electric Generating Facilities

Tampa Electric has five (5) generating stations that include fossil steam units, combined cycle units, combustion turbine peaking units, an integrated coal gasification combined cycle unit, and internal combustion diesel units.

**Big Bend:** The station contains four (4) pulverized coal fired steam units equipped with desulfurization scrubbers, electrostatic precipitators and three distillate fueled combustion turbines.

**H.L. Culbreath Bayside:** The station contains two (2) natural gas fired combined cycle units. Bayside Unit 1 utilizes three (3) combustion turbines, three (3) heat recovery steam generators (HRSGs) and one (1) steam turbine. Bayside Unit 2 utilizes four (4) combustion turbines, four (4) HRSGs and one (1) steam turbine.

**Polk:** The station is presently comprised of three (3) generating units. Polk Unit 1 is fired with synthetic gas produced from gasified coal and other carbonaceous fuels and is an integrated gasification combined cycle unit (IGCC). This technology integrates state-of-the-art environmental processes to create a clean fuel gas from a variety of feedstock with the efficiency benefits of combined cycle generation equipment. Polk Units 2 and 3 are combustion turbines, fueled primarily with natural gas with distillate backup.

**Phillips:** The station is comprised of two (2) residual or distillate oil fired diesel engines and one heat recovery steam generator with a steam turbine. The heat recover steam generator was placed on long term reserve standby in February 1991 and was retired in March of 2006.

**Partnership:** The station is comprised of two (2) natural gas fired diesel engines.

**Schedule 1**

**Existing Generating Facilities  
As of December 31, 2005**

(1) Plant Name	(2) Unit No.	(3) Location	(4) Unit Type	(5) Fuel		(7) Fuel Transport		(9) Alt Days	(10) Commercial In-Service Mo/Yr	(11) Expected Retirement Mo/Yr	(12) Gen. Max. Nameplate KW	(13) Net Capability		(14)
				Pri	Alt	Pri	Alt					Summer MW	Winter MW	
Big Bend		Hillsborough Co. 14/31S/19E									<b>1,998,000</b>	<b>1,819</b>	<b>1,877</b>	
	1		FS	C	N	WA	N	0	10/70	Unknown	445,500	411	411	
	2		FS	C	N	WA	N	0	04/73	"	445,500	391	391	
	3		FS	C	N	WA	N	0	05/76	"	445,500	414	433	
	4		FS	C	N	WA	N	0	02/85	"	486,000	457	462	
	CT 1		CT	LO	N	WA	TK	0	02/69	01/15	18,000	14	14	
	CT 2		CT	LO	N	WA	TK	0	11/74	01/15	78,750	66	80	
	CT 3		CT	LO	N	WA	TK	0	11/74	01/15	78,750	66	80	
Bayside		Hillsborough Co. 4/30S/19E									<b>2,014,160</b>	<b>1,632</b>	<b>1,847</b>	
	1		CC	NG	N	PL	N	0	4/03	Unknown	809,060	702	790	
	2		CC	NG	N	PL	N	0	1/04	Unknown	1,205,100	930	1,047	
Phillips		Highland Co. 12-055									<b>42,030</b>	<b>37</b>	<b>37</b>	
	1		D	HO	N	TK	N	0	06/83	Unknown	19,215	17	17	
	2		D	HO	N	TK	N	0	06/83	Unknown	19,215	17	17	
	3 (a)		HRSG	WH	N	N	N	0	06/83	03/06	3,600	3	3	
Polk		Polk Co. 2,3/32S/23E									<b>677,839</b>	<b>580</b>	<b>620</b>	
	1		IGCC	C	LO	WA/TK	TK	0	09/96	Unknown	326,299	255	260	
	2 (b)		CT	NG	LO	PL	TK	0	07/00	Unknown	175,770	160	180	
	3 (b)		CT	NG	LO	PL	TK	0	5/02	Unknown	175,770	165	180	
Partnership		Hillsborough Co. W30/29/19									<b>5,800</b>	<b>6</b>	<b>6</b>	
	1		D	NG	N	PL	N	0	04/01	Unknown	2,900	3	3	
	2		D	NG	N	PL	N	0	04/01	Unknown	2,900	3	3	
											<b>TOTAL</b>	<b>4,074</b>	<b>4,380</b>	

**Notes:** (a) Phillips Unit 3 was placed on long term reserve standby in February 1991 and will be retired in March 2006.  
(b) Polk Units 2 & 3 turbine name plate rating are based on 59 deg. F. The net capacity of these units vary with ambient air temperature.

**THIS PAGE LEFT INTENTIONALLY BLANK.**



SERVICE AREA  
TAMPA ELECTRIC COMPANY



69 KV \_\_\_\_\_  
138 KV \_\_\_\_\_  
230 KV \_\_\_\_\_

■ SUBSTATION  
○ FACILITY


REVISED FEB. 1996  
FILE NAME 445006.DGN  
REVISED 6/03



— 69 KV LINES  
— 138 KV LINES  
— 230 KV LINES

T245  
T255  
T265  
T275  
T285  
T295  
T305  
T315  
T325

R16E | R17E | R18E | R19E | R20E | R21E | R22E | R23E



TAMPA ELECTRIC COMPANY  
 TEN YEAR SITE PLAN  
 FOR ELECTRICAL GENERATING FACILITIES  
 AND ASSOCIATED TRANSMISSION LINES

FIGURE I-1  
 TAMPA ELECTRIC RETAIL CUSTOMER SERVICE AREA

SOURCE: TAMPA ELECTRIC.

FILE NAME: 445006.DGN  
 REVISED: 3/05



**THIS PAGE LEFT INTENTIONALLY BLANK.**

## CHAPTER II

### FORECAST OF ELECTRIC POWER, DEMAND, AND ENERGY CONSUMPTION

- Schedule 2.1: History and Forecast of Energy Consumption and Number of Customers by Customer Class
- Schedule 2.2: History and Forecast of Energy Consumption and Number of Customers by Customer Class
- Schedule 2.3: History and Forecast of Energy Consumption and Number of Customers by Customer Class
- Schedule 3.1: History and Forecast of Summer Peak Demand
- Schedule 3.2: History and Forecast of Winter Peak Demand
- Schedule 3.3: History and Forecast of Annual Net Energy for Load
- Schedule 4: Previous Year and 2-Year Forecast of Peak Demand and Net Energy for Load by Month
- Schedule 5: History and Forecast of Fuel Requirements
- Schedule 6.1: History and Forecast of Net Energy for Load by Fuel Source in GWH
- Schedule 6.2: History and Forecast of Net Energy for Load by Fuel Source as a Percentage

Schedule 2.1

History and Forecast of Energy Consumption and Number of Customers by Customer Class

(1)	(2)	(3)	(4)	(5)	(6)	(7)	(8)	(9)
Year	Rural and Residential					Commercial		
	Hillsborough County Population	Members Per Household	GWH	Customers*	Average kWh Consumption Per Customer	GWH	Customers*	Average kWh Consumption Per Customer
1996	910,855	2.5	6,607	445,664	14,825	4,815	55,479	86,790
1997	928,731	2.4	6,500	456,175	14,249	4,902	56,981	86,029
1998	942,322	2.4	7,050	466,189	15,123	5,173	58,542	88,364
1999	962,153	2.4	6,967	477,533	14,590	5,337	60,089	88,818
2000	1,006,400	2.6	7,369	491,925	14,980	5,541	61,902	89,512
2001	1,030,900	2.6	7,594	505,964	15,009	5,685	63,316	89,788
2002	1,053,900	2.6	8,046	518,554	15,516	5,832	64,665	90,188
2003	1,084,198	2.5	8,265	531,257	15,557	5,843	66,041	88,475
2004	1,106,487	2.5	8,293	544,313	15,236	5,988	67,488	88,727
2005	1,127,449	2.5	8,558	558,601	15,320	6,233	69,027	90,298
2006	1,158,825	2.5	9,173	570,999	16,064	6,455	70,207	91,945
2007	1,181,836	2.5	9,518	584,637	16,280	6,661	71,611	93,022
2008	1,205,303	2.5	9,856	597,663	16,491	6,896	72,965	94,510
2009	1,229,236	2.5	10,181	610,495	16,676	7,084	74,321	95,313
2010	1,252,614	2.5	10,510	623,180	16,865	7,287	75,686	96,282
2011	1,273,481	2.5	10,844	635,816	17,055	7,494	77,042	97,267
2012	1,294,521	2.5	11,189	648,654	17,249	7,715	78,402	98,408
2013	1,316,805	2.5	11,539	661,632	17,441	7,911	79,763	99,184
2014	1,337,649	2.5	11,894	674,590	17,631	8,125	81,118	100,167
2015	1,359,260	2.4	12,247	687,764	17,808	8,356	82,481	101,310

December 31, 2005 Status

\* Average of end-of-month customers for the calendar year.

## Schedule 2.2

History and Forecast of Energy Consumption and  
Number of Customers by Customer Class

(1)	(2)	(3)	(4)	(5)	(6)	(7)	(8)
Year	Industrial			Railroads and Railways GWH	Street & Highway Lighting GWH	Other Sales to Public Authorities GWH	Total Sales to Ultimate Consumers GWH
	GWH	Customers*	Average kWh Consumption Per Customer				
1996	2,305	504	4,573,413	0	53	1,150	14,930
1997	2,465	629	3,918,919	0	53	1,170	15,090
1998	2,520	682	3,695,015	0	54	1,231	16,028
1999	2,223	740	3,004,054	0	52	1,226	15,805
2000	2,390	776	3,079,897	0	53	1,285	16,638
2001	2,329	851	2,736,780	0	54	1,314	16,976
2002	2,612	948	2,755,274	0	55	1,380	17,925
2003	2,580	1,203	2,144,638	0	57	1,481	18,226
2004	2,556	1,299	1,967,667	0	58	1,542	18,437
2005	2,478	1,337	1,853,403	0	60	1,582	18,911
2006	2,390	1,392	1,716,740	0	62	1,600	19,680
2007	2,469	1,433	1,723,287	0	64	1,649	20,361
2008	2,508	1,475	1,699,690	0	67	1,697	21,023
2009	2,552	1,522	1,676,130	0	68	1,742	21,626
2010	2,359	1,567	1,505,547	0	70	1,788	22,014
2011	2,400	1,612	1,489,221	0	72	1,835	22,644
2012	2,437	1,658	1,469,893	0	74	1,883	23,298
2013	2,480	1,706	1,453,395	0	75	1,929	23,935
2014	2,519	1,757	1,433,766	0	77	1,977	24,592
2015	2,563	1,809	1,417,175	0	79	2,028	25,273

December 31, 2005 Status

\* Average of end-of-month customers for the calendar year.

## Schedule 2.3

History and Forecast of Energy Consumption and  
Number of Customers by Customer Class

(1)	(2)	(3)	(4)	(5)	(6)
<u>Year</u>	<u>Sales for * Resale GWH</u>	<u>Utility Use ** &amp; Losses GWH</u>	<u>Net Energy *** for Load GWH</u>	<u>Other **** Customers</u>	<u>Total **** Customers</u>
1996	399	760	16,089	4,391	506,038
1997	507	731	16,328	4,583	518,368
1998	431	783	17,242	4,839	530,252
1999	533	900	17,238	5,299	543,661
2000	763	972	18,373	5,497	560,100
2001	684	794	18,454	5,649	575,780
2002	502	935	19,362	6,032	590,199
2003	587	985	19,798	6,399	604,900
2004	589	945	19,971	6,435	619,535
2005	712	952	20,575	6,656	635,621
2006	522	1,000	21,203	6,715	649,313
2007	521	1,034	21,916	6,874	664,555
2008	522	1,069	22,614	7,024	679,128
2009	522	1,097	23,245	7,169	693,508
2010	522	1,116	23,653	7,313	707,746
2011	250	1,148	24,042	7,455	721,925
2012	227	1,183	24,708	7,599	736,313
2013	163	1,213	25,311	7,743	750,844
2014	59	1,246	25,897	7,887	765,352
2015	59	1,280	26,612	8,034	780,088

December 31, 2005 Status

\* Includes sales to Progress Energy Florida, Wauchula, Ft. Meade, St. Cloud and Reedy Creek.

\*\* Utility Use and Losses include accrued sales.

\*\*\* Net Energy for Load includes output to line including energy supplied by purchased cogeneration.

\*\*\*\* Average of end-of-month customers for the calendar year.

## Schedule 3.1

History and Forecast of Summer Peak Demand  
Base Case

(1)	(2)	(3)	(4)	(5)	(6)	(7)	(8)	(9)	(10)
<u>Year</u>	<u>Total *</u>	<u>Wholesale**</u>	<u>Retail *</u>	<u>Interruptible</u>	<u>Residential Load Management</u>	<u>Residential Conservation</u>	<u>Comm./Ind. Load Management</u>	<u>Comm./Ind. Conservation</u>	<u>Net Firm Demand</u>
1996	3,144	92	3,052	234	104	35	13	19	2,647
1997	3,187	106	3,081	225	95	39	21	24	2,677
1998	3,458	111	3,347	204	107	43	21	27	2,945
1999	3,648	190	3,458	193	98	48	19	31	3,069
2000	3,568	171	3,397	182	78	52	21	36	3,028
2001	3,730	178	3,552	181	90	55	21	40	3,165
2002	3,869	122	3,747	206	99	60	21	43	3,318
2003	3,854	122	3,732	188	63	65	21	44	3,351
2004	3,974	120	3,854	177	95	70	20	47	3,445
2005	4,218	128	4,090	144	79	73	19	49	3,725
2006	4,309	185	4,124	165	93	76	19	51	3,720
2007	4,438	185	4,253	168	91	78	20	53	3,843
2008	4,565	185	4,380	168	85	80	20	54	3,973
2009	4,686	185	4,501	168	84	82	20	55	4,091
2010	4,789	185	4,604	146	83	83	21	56	4,214
2011	4,845	115	4,730	146	82	85	21	57	4,338
2012	4,977	115	4,862	146	82	86	22	58	4,468
2013	5,089	100	4,989	146	81	87	23	59	4,593
2014	5,202	77	5,125	146	80	88	23	59	4,729
2015	5,341	77	5,264	146	79	89	24	59	4,867

December 31, 2005 Status

\* Includes residential and commercial/industrial conservation.

\*\* Includes sales to Progress Energy Florida, Wauchula, Ft. Meade, St. Cloud and Reedy Creek.

 Net Firm Demand is not coincident with system peak.

Note: Values shown may be affected due to rounding.

## Schedule 3.2

History and Forecast of Winter Peak Demand  
Base Case

(1)	(2)	(3)	(4)	(5)	(6)	(7)	(8)	(9)	(10)
<u>Year</u>	<u>Total *</u>	<u>Wholesale **</u>	<u>Retail *</u>	<u>Interruptible</u>	<u>Residential Load Management</u>	<u>Residential Conservation</u>	<u>Comm./Ind. Load Management</u>	<u>Comm./Ind. Conservation</u>	<u>Net Firm Demand</u>
1995/96	3,833	98	3,735	152	260	331	10	36	2,946
1996/97	3,632	109	3,523	228	164	353	21	38	2,719
1997/98	3,231	99	3,132	210	160	370	21	39	2,332
1998/99	3,985	131	3,854	152	266	388	18	40	2,990
1999/00	4,019	125	3,894	212	209	402	19	43	3,009
2000/01	4,405	136	4,269	191	196	410	21	44	3,407
2001/02	4,217	127	4,090	168	176	419	22	46	3,259
2002/03	4,484	129	4,355	195	210	428	21	46	3,455
2003/04	3,949	120	3,829	254	136	437	18	48	2,936
2004/05	4,308	129	4,179	194	189	444	16	49	3,287
2005/06	4,946	187	4,759	168	204	449	19	50	3,869
2006/07	5,093	188	4,905	171	201	452	19	50	4,012
2007/08	5,229	188	5,041	171	194	455	18	51	4,152
2008/09	5,358	188	5,170	171	191	457	18	51	4,282
2009/10	5,470	188	5,282	150	189	460	18	52	4,413
2010/11	5,601	188	5,413	150	187	461	19	52	4,544
2011/12	5,665	117	5,548	150	185	463	19	52	4,679
2012/13	5,786	102	5,684	149	183	464	20	53	4,815
2013/14	5,903	77	5,826	150	182	465	20	53	4,956
2014/15	6,047	77	5,970	150	180	466	21	53	5,100

December 31, 2005 Status

\* Includes cumulative conservation.

\*\* Includes sales to Progress Energy Florida, Wauchula, Fort Meade, St. Cloud and Reedy Creek.

Note: Values shown may be affected due to rounding.

## Schedule 3.3

History and Forecast of Annual Net Energy for Load - GWH  
Base Case

(1)	(2)	(3)	(4)	(5)	(6)	(7)	(8)	(9)
<u>Year</u>	<u>Total</u>	<u>Residential Conservation</u>	<u>Comm./Ind. Conservation</u>	<u>Retail</u>	<u>Wholesale *</u>	<u>Utility Use &amp; Losses</u>	<u>Net Energy for Load</u>	<u>Load ** Factor %</u>
1996	15,233	262	41	14,930	399	760	16,089	52.8
1997	15,429	279	61	15,089	507	731	16,327	57.5
1998	16,401	297	76	16,028	431	783	17,242	58.1
1999	16,212	315	92	15,805	533	900	17,238	55.1
2000	17,083	333	112	16,638	763	972	18,373	58.5
2001	17,444	346	122	16,976	684	794	18,454	53.3
2002	18,423	361	137	17,925	502	935	19,363	58.7
2003	18,756	378	152	18,226	587	985	19,798	56.4
2004	18,999	394	168	18,437	589	945	19,971	58.9
2005	19,491	404	176	18,911	712	952	20,575	57.3
2006	20,277	412	184	19,680	522	1000	21,203	54.4
2007	20,970	418	191	20,361	521	1034	21,916	54.5
2008	21,644	424	197	21,023	522	1069	22,614	54.5
2009	22,258	429	203	21,626	522	1097	23,245	54.7
2010	22,655	434	207	22,014	522	1116	23,653	54.5
2011	23,293	438	211	22,644	250	1148	24,042	53.9
2012	23,953	441	214	23,298	227	1183	24,708	54.6
2013	24,596	444	217	23,935	163	1213	25,311	54.8
2014	25,258	447	219	24,592	59	1246	25,897	54.9
2015	25,942	449	220	25,273	59	1280	26,612	55.0

December 31, 2005 Status

\* Includes sales to Progress Energy Florida, Wauchula, Ft. Meade, St. Cloud and Reedy Creek.

\*\* Load Factor is the ratio of total system average load to peak demand.



## Schedule 4

## Previous Year and 2-Year Forecast of Peak Demand and Net Energy for Load (NEL) by Month

(1)	(2)	(3)	(4)	(5)	(6)	(7)
Month	2005 Actual		2006 Forecast		2007 Forecast	
	Peak Demand *	NEL **	Peak Demand *	NEL **	Peak Demand *	NEL **
	MW	GWH	MW	GWH	MW	GWH
January	3,814	1,537	4,447	1,586	4,591	1,646
February	2,938	1,341	3,657	1,407	3,779	1,456
March	3,077	1,521	3,444	1,558	3,560	1,618
April	3,064	1,472	3,458	1,553	3,568	1,605
May	3,607	1,781	3,890	1,873	4,009	1,932
June	3,883	1,887	4,071	1,970	4,193	2,034
July	4,054	2,137	4,185	2,107	4,310	2,172
August	4,096	2,186	4,181	2,116	4,306	2,184
September	3,816	1,961	4,045	1,983	4,167	2,047
October	3,610	1,797	3,795	1,830	3,913	1,890
November	2,975	1,448	3,443	1,547	3,554	1,603
December	3,081	1,507	3,680	1,672	3,795	1,729
<b>TOTAL</b>		<b>20,574</b>		<b>21,203</b>		<b>21,916</b>

December 31, 2005 Status

- \* Peak demand represents total retail and wholesale demand, excluding conservation impacts.
- \*\* Values shown may be affected due to rounding.

Schedule 5

History and Forecast of Fuel Requirements

(1)	(2)	(3)	(4)	(5)	(6)	(7)	(8)	(9)	(10)	(11)	(12)	(13)	(14)	(15)	(16)
				Actual	Actual										
			Units	2004	2005	2006	2007	2008	2009	2010	2011	2012	2013	2014	2015
<u>Fuel Requirements</u>															
(1)	Nuclear		Trillion BTU	0	0	0	0	0	0	0	0	0	0	0	0
(2)	Coal		1000 Ton	4,456	4,072	4,493	4,438	4,763	4,545	4,563	4,567	4,630	4,864	5,000	4,940
(3)	Residual	Total	1000 BBL	102	110	54	49	132	143	114	132	133	114	162	197
(4)		Steam	1000 BBL	0	0	0	0	0	0	0	0	0	0	0	0
(5)		CC	1000 BBL	0	0	0	0	0	0	0	0	0	0	0	0
(6)		CT	1000 BBL	0	0	0	0	0	0	0	0	0	0	0	0
(7)		Diesel (1)	1000 BBL	102	110	54	49	132	143	114	132	133	114	162	197
(8)	Distillate	Total	1000 BBL	123	116	111	107	107	107	105	108	106	105	108	97
(9)		Steam	1000 BBL	0	0	0	0	0	0	0	0	0	0	0	0
(10)		CC	1000 BBL	110	75	87	93	92	93	95	94	93	94	95	89
(11)		CT	1000 BBL	14	42	24	14	15	14	10	14	13	10	13	7
(12)		Diesel	1000 BBL	0	0	0	0	0	0	0	0	0	0	0	0
(13)	Natural Gas	Total	1000 MCF	48,077	54,391	54,443	62,830	63,265	72,806	70,931	72,279	74,770	59,927	63,460	67,295
(14)		Steam	1000 MCF	0	0	0	0	0	0	0	0	0	0	0	0
(15)		CC	1000 MCF	46,535	53,166	52,389	59,569	58,737	65,985	62,976	61,365	62,918	52,542	55,075	57,323
(16)		CT	1000 MCF	1,542	1,225	2,055	3,261	4,529	6,821	7,955	10,914	11,852	7,385	8,385	9,972
(17)	Other (Specify)														
(18)	Petroleum Coke		1000 Ton	417	362	408	453	450	398	418	413	410	1708	1607	1586

\* Values shown may be affected due to rounding.

\*\* All values exclude ignition.

(1) Phillips 3 retired March 2006, data reported as diesel for Phillips 1 & 2.

## Schedule 6.1

## History and Forecast of Net Energy for Load by Fuel Source in GWH

(1)	(2)	(3)	(4)	(5)	(6)	(7)	(8)	(9)	(10)	(11)	(12)	(13)	(14)	(15)	(16)
				Actual	Actual										
			Units	2004	2005	2006	2007	2008	2009	2010	2011	2012	2013	2014	2015
(1)	Annual Firm Interchange		GWH	208	209	566	296	269	247	222	149	151	0	0	0
(2)	Nuclear		GWH	0	0	0	0	0	0	0	0	0	0	0	0
(3)	Coal		GWH	9,554	8,705	9,814	9,687	10,406	9,756	9,816	9,824	9,958	10,579	10,866	10,744
(4)	Residual	Total	GWH	65	71	36	32	87	92	73	86	94	80	111	131
(5)		Steam	GWH	0	0	0	0	0	0	0	0	0	0	0	0
(6)		CC	GWH	0	0	0	0	0	0	0	0	0	0	0	0
(7)		CT	GWH	0	0	0	0	0	0	0	0	0	0	0	0
(8)		Diesel (1)	GWH	65	71	36	32	87	92	73	86	94	80	111	131
(9)	Distillate	Total	GWH	75	64	58	57	57	57	57	58	57	56	58	53
(10)		Steam	GWH	0	0	0	0	0	0	0	0	0	0	0	0
(11)		CC	GWH	69	47	48	51	51	51	52	52	51	52	52	49
(12)		CT	GWH	6	18	10	6	7	6	5	6	6	4	5	4
(13)		Diesel	GWH	0	0	0	0	0	0	0	0	0	0	0	0
(14)	Natural Gas	Total	GWH	6,652	7,567	7,392	8,494	8,486	9,777	9,493	9,555	9,907	8,006	8,445	8,951
(15)		Steam	GWH	0	0	0	0	0	0	0	0	0	0	0	0
(16)		CC	GWH	6,518	7,461	7,225	8,229	8,119	9,122	8,707	8,484	8,703	7,247	7,598	7,916
(17)		CT	GWH	134	106	168	265	367	654	787	1,070	1,203	759	847	1,035
(18)	Other (Specify)														
(19)	Petroleum Coke Generation		GWH	1,155	955	1,079	1,196	1,188	1,056	1,107	1,095	1,085	4,994	4,683	4,628
(20)	Net Interchange		GWH	1,751	2,470	1,823	1,716	1,686	1,825	2,629	3,033	3,234	1,373	1,514	1,883
(21)	Purchased Energy from														
(22)	Non-Utility Generators		GWH	510	534	435	435	435	435	254	239	221	221	221	221
(23)	Net Energy for Load*		GWH	19,970	20,575	21,203	21,915	22,615	23,246	23,652	24,040	24,707	25,309	25,898	26,611

\* Values shown may be affected due to rounding.

(1) Phillips 3 retired March 2006, data reported as diesel for Phillips 1 & 2.

## Schedule 6.2

## History and Forecast of Net Energy for Load by Fuel Source as Percentage

(1)	(2)	(3)	(4)	(5)	(6)	(7)	(8)	(9)	(10)	(11)	(12)	(13)	(14)	(15)	(16)
				Actual	Actual										
			Units	2004	2005	2006	2007	2008	2009	2010	2011	2012	2013	2014	2015
(1)	Annual Firm Interchange		%	1	1	3	1	1	1	1	1	1	0	0	0
(2)	Nuclear		%	0	0	0	0	0	0	0	0	0	0	0	0
(3)	Coal		%	48	42	46	44	46	42	42	41	40	42	42	40
(4)	Residual	Total	%	0	0	0	0	0	0	0	0	0	0	0	0
(5)		Steam	%	0	0	0	0	0	0	0	0	0	0	0	0
(6)		CC (1)	%	0	0	0	0	0	0	0	0	0	0	0	0
(7)		CT	%	0	0	0	0	0	0	0	0	0	0	0	0
(8)		Diesel	%	0	0	0	0	0	0	0	0	0	0	0	0
(9)	Distillate	Total	%	0	0	0	0	0	0	0	0	0	0	0	0
(10)		Steam	%	0	0	0	0	0	0	0	0	0	0	0	0
(11)		CC	%	0	0	0	0	0	0	0	0	0	0	0	0
(12)		CT	%	0	0	0	0	0	0	0	0	0	0	0	0
(13)		Diesel	%	0	0	0	0	0	0	0	0	0	0	0	0
(14)	Natural Gas	Total	%	33	37	35	39	38	42	40	40	40	32	33	34
(15)		Steam	%	0	0	0	0	0	0	0	0	0	0	0	0
(16)		CC	%	33	36	34	38	36	39	37	35	35	29	29	30
(17)		CT	%	1	1	1	1	2	3	3	4	5	3	3	4
(18)	Other (Specify)														
(19)	Petroleum Coke Generation		%	6	5	5	5	5	5	5	5	4	20	18	17
(20)	Net Interchange		%	9	12	9	8	7	8	11	13	13	5	6	7
(21)	Purchased Energy from														
(22)	Non-Utility Generators		%	3	3	2	2	2	2	1	1	1	1	1	1
(23)	Net Energy for Load*		%	100	100	100	100	100	100	100	100	100	100	100	100

\* Values shown may be affected due to rounding.

(1) Phillips 3 retired March 2006, data reported as diesel for Phillips 1 & 2.

**THIS PAGE LEFT INTENTIONALLY BLANK.**

## CHAPTER III

### FORECAST OF ELECTRIC POWER DEMAND

#### Tampa Electric Company Forecasting Methodology

The Customer, Demand and Energy Forecast is the foundation for development of the integrated resource plan. Recognizing its importance, Tampa Electric utilizes the necessary methodologies for carrying out this function. The primary objective of this procedure is to blend proven statistical techniques with practical forecasting experience to provide a projection, which represents the highest probability of occurrence.

This chapter is devoted to describing Tampa Electric's forecasting methods and the major assumptions utilized in developing the 2006-2015 forecasts. The data tables in Chapter II outline the expected customer, demand, and energy values for the 2006-2015 time period.

#### Retail Load

MetrixND, an advanced statistics program for analysis and forecasting, was used to develop the 2006-2015 Customer, Demand and Energy forecasts. This software allows a platform for the development of more dynamic and fully integrated models.

In addition, Tampa Electric uses MetrixLT, which integrates with MetrixND to develop multiple-year forecasts of energy usage at the hourly level. This tool allows the annual or monthly forecasts in MetrixND to be combined with hourly load shape data to develop a long-term "bottom-up" forecast, which is consistent with short-term statistical forecasts.

Tampa Electric's retail customer, demand and energy forecasts are the result of six separate forecasting analyses:

1. economic analysis;
2. customer analysis;
3. energy analysis;
4. peak demand analysis;
5. phosphate analysis; and
6. conservation programs analysis

The MetrixND models are the company's most sophisticated and primary load forecasting models. The phosphate demand and energy is forecasted separately and

then combined in the final forecast. Likewise, the effect of Tampa Electric's conservation, load management, and cogeneration programs is incorporated into the process by subtracting the expected reduction in demand and energy from the forecast.

## 1. Economic Analysis

The economic assumptions used in the forecast models are derived from forecasts from Economy.com and the University of Florida's Bureau of Economic and Business Research (BEBR).

See the "Base Case Forecast Assumptions" section of this chapter for an explanation of the most significant economic inputs to the MetrixND models.

## 2. Customer Multiregression Model

The customer multiregression forecasting model is an eight-equation model. The equations forecast the number of customers by eight major categories. The primary economic drivers in the customer forecast models are state population estimates, service area households and Hillsborough County employment growth.

1. **Residential Customer Model**: Customer projections are a function of Florida's population. Since a strong correlation exists between historical changes in service area customers and historical changes in Florida's population, Florida population estimates for 2005-2025 were used to forecast the future growth patterns in residential customers.
2. **Commercial Customer Model**: Total commercial customers include commercial customers plus temporary service customers (temporary poles on construction sites); therefore, two models are used to forecast total commercial customers:
  - a. The **Commercial Customer Model** is a function of residential customers. An increase in the number of households provides the need for additional services, restaurants, and retail establishments. The amount of residential activity also plays a part in the attractiveness of the Tampa Bay area as a place to relocate or start a new business.
  - b. Projections of employment in the construction sector are a good indicator of expected increases and decreases in local construction activity. Therefore, the **Temporary Service model** projects the number of customers as a function of construction employment.

3. **Industrial Customer Model (Non-Phosphate):** Non-phosphate industrial customers include three rate classes that have been modeled individually: General Service, General Service Demand and General Service Large Demand.
  - a. The General Service Customer Model is a function of Hillsborough County commercial employment.
  - b. The General Service Demand Customer Model is a function of Hillsborough County commercial and industrial employment. Since the structure of our local industrial sector has been shifting from an energy-intense manufacturing sector to a non-energy intense manufacturing sector, the type of customers in this sector have qualities of both large scaled commercial customers and smaller scaled industrial customers.
  - c. The General Service Large Demand Customer Model is simply based on a time trend variable.
4. **Public Authority Customer Model:** Customer projections are a function of Florida's population. The need for public services will depend on the number of people in the region; therefore, consistent with the residential customer model, Florida's population projections are used to determine future growth in the public authorities sector.
5. **Street & Highway Lighting Customer Model:** As the number of commercial customers increases so does the need for infrastructure expansion, such as street and highway lighting. Therefore, the commercial customer forecast is the basis for the Street & Highway Lighting customer model.

### 3. **Energy Multiregression Model**

There are a total of eight energy models. All of these models represent average usage per customer (kWh/customer), except for the temporary services model which represents total kWh sales. The average usage models interact with the customer models to arrive at total sales for each class.



The energy models are based on an approach known as Statistically Adjusted Engineering (SAE). SAE entails specifying end-use variables, such as heating, cooling and base use appliance/equipment, and incorporating these variables into regression models. This approach allows the models to capture long-term structural changes that end-use models are known for, while also performing well in the short-term time frame, as do econometric regression models.

1. **Residential Energy Model:** The residential forecast model is made up of three major components: (1) The end-use equipment index variables, which capture the long-term net effect of equipment saturation and equipment efficiency improvements; (2) The second component serves to capture changes in the economy such as household income, household size, and the price of electricity; and, (3) The third component is made up of weather variables, which serve to allocate the seasonal impacts of weather throughout the year. The SAE model framework begins by defining energy use for an average customer in year (y) and month (m) as the sum of energy used by heating equipment (XHeat<sub>y,m</sub>), cooling equipment (XCool<sub>y,m</sub>), and other equipment (XOther<sub>y,m</sub>). The XHeat, XCool, and XOther variables are defined as a product of an **annual equipment index** and a **monthly usage multiplier**.

$$\text{Average Usage}_{y,m} = (\text{XHeat}_{y,m} + \text{XCool}_{y,m} + \text{XOther}_{y,m})$$

Where:

$$\text{XHeat}_{y,m} = \text{HeatEquipIndex}_y \times \text{HeatUse}_{y,m}$$

$$\text{XCool}_{y,m} = \text{CoolEquipIndex}_y \times \text{CoolUse}_{y,m}$$

$$\text{XOtherUse}_{y,m} = \text{OtherEquipIndex}_y \times \text{OtherUse}_{y,m}$$

The **annual equipment variables** (*HeatEquipIndex*, *CoolEquipIndex*, *OtherEquipIndex*) are defined as a weighted average across equipment types multiplied by equipment saturation levels normalized by operating efficiency levels. Given a set of fixed weights, the index will change over time with changes in equipment saturations and operating efficiencies. The weights are defined by the estimated energy use per household for each equipment type in the base year.

Where:

$$\text{HeatEquipIndex} = \sum_{\text{Tech.}} \text{Weight} \times \left( \frac{\text{Saturation}_y / \text{Efficiency}_y}{\text{Saturation}_{\text{base } y} / \text{Efficiency}_{\text{base } y}} \right)$$

$$\text{CoolEquipIndex} = \sum_{\text{Tech.}} \text{Weight} \times \left( \frac{\text{Saturation}_y / \text{Efficiency}_y}{\text{Saturation}_{\text{base } y} / \text{Efficiency}_{\text{base } y}} \right)$$

$$\text{OtherEquipIndex} = \sum_{\text{Tech.}} \text{Weight} \times \left( \frac{\text{Saturation}_y / \text{Efficiency}_y}{\text{Saturation}_{\text{base } y} / \text{Efficiency}_{\text{base } y}} \right)$$

Next, the **monthly usage multiplier or utilization variable** (*HeatUse*, *CoolUse*, *OtherUse*) are defined using economic and weather variables. A customer's monthly usage level is impacted by several factors, including weather, household size, income levels, electricity prices and the number of days in the billing cycle. The degree day variables serve to allocate the seasonal impacts of weather throughout the year, while the remaining variables serve to capture changes in the economy.

Where:

$$\text{HeatUse}_{y,m} = \left( \frac{\text{Price}_{y,m}}{\text{Price}_{\text{base } y,m}} \right)^{-0.20} \times \left( \frac{\text{HH Income}_{y,m}}{\text{HH Income}_{\text{base } y,m}} \right)^{0.30} \times \left( \frac{\text{HH Size}_{y,m}}{\text{HH Size}_{\text{base } y,m}} \right)^{0.30} \times \left( \frac{\text{HDD}_{y,m}}{\text{Normal HDD}} \right)$$

$$\text{CoolUse}_{y,m} = \left( \frac{\text{Price}_{y,m}}{\text{Price}_{\text{base } y,m}} \right)^{-0.20} \times \left( \frac{\text{HH Income}_{y,m}}{\text{HH Income}_{\text{base } y,m}} \right)^{0.30} \times \left( \frac{\text{HH Size}_{y,m}}{\text{HH Size}_{\text{base } y,m}} \right)^{0.30} \times \left( \frac{\text{CDD}_{y,m}}{\text{Normal CDD}} \right)$$

$$\text{OtherUse}_{y,m} = \left( \frac{\text{Price}_{y,m}}{\text{Price}_{\text{base } y,m}} \right)^{-0.20} \times \left( \frac{\text{HH Income}_{y,m}}{\text{HH Income}_{\text{base } y,m}} \right)^{0.30} \times \left( \frac{\text{HH Size}_{y,m}}{\text{HH Size}_{\text{base } y,m}} \right)^{0.25} \times \left( \frac{\text{Billing Days}_{y,m}}{\text{Billing Days}_{\text{base } y,m}} \right)$$

The SAE approach to modeling provides a powerful framework for developing short-term and long-term energy forecasts. This approach reflects changes in equipment saturation and efficiency levels and gives estimates of weather sensitivity that varies over time as well as estimate trend adjustments.

2. Commercial Energy Models: Total Commercial energy sales include commercial sales plus temporary service sales (temporary poles on construction sites); therefore, two models are used to forecast total commercial energy sales.
  - a. Commercial Energy Model: The model framework for the commercial sector is the same as the residential model; it also has three major components and utilizes the SAE model framework. The differences lie in the type of end-use equipment and in the economic variables used. The end-use equipment variables are based on commercial appliance/equipment saturation and efficiency assumptions. The economic drivers in the commercial model are commercial productivity measured in terms of dollar output and the price of electricity for the commercial sector. The third component, weather variables, is the same as in the residential model.
  - b. Temporary Service Energy Model: The model is a subset of the total commercial sector and is a rather small percentage of the total commercial sector. Although small in nature, it is still a component that needs to be included. A simple regression model is used with the primary drivers being the construction sector's productivity and heating and cooling degree-days.
3. Industrial Energy Model (Non-Phosphate): Non-phosphate industrial energy includes three rate classes that have been modeled individually: General Service, General Service Demand and General Service Large Demand.
  - a. The General Service Energy Model has two major components. Utilizing the SAE model framework, the first component, economic index variables, includes estimates for manufacturing output and the price of electricity in the industrial sector. The second component is a cooling degree-day variable. Unlike the previous models discussed, heating load does not impact the industrial sector.
  - b. The General Service Demand Energy Model is modeled like the General Service Energy Model.
  - c. The General Service Large Demand Customer Model is based on a time trend variable and a cooling degree day variable.
4. Public Authority Sector Model: Within this model, the equipment index is based on the same commercial equipment saturation and efficiency assumptions used in the commercial model. The economic component is based on government sector productivity and the price of electricity in this sector. Weather variables are consistent with the residential and commercial models.

5. Street & Highway Lighting Sector Model: The street and highway lighting sector is not impacted by weather; therefore; it is a rather simple model and the SAE modeling approach does not apply. The model is a linear regression model where street & highway lighting energy consumption is a function of the number of billing days in the cycle, and the number of daylight hours in a day for each month.

The eight energy models described above plus an exogenous interruptible and phosphate forecast are added together to arrive at the total retail energy sales forecast.

In summary, the SAE approach to modeling provides a powerful framework for developing short-term and long-term energy forecasts. This approach reflects changes in equipment saturation and efficiency levels, gives estimates of weather sensitivity that varies over time, as well as estimates trend adjustments.

#### **4. Demand Multiregression Models**

After the total retail energy sales forecast is complete, it is integrated into the peak demand model as an independent variable along with weather variables. The energy variable represents the long-term economic and appliance trend impacts. To stabilize the peak demand data series and improve model accuracy, the volatility of the phosphate load is removed. To further stabilize the data, the peak demand models project on a per customer basis.

The weather variables provide the monthly seasonality to the peaks. The weather variables used are heating and cooling degree-days for both the temperature at the time of the peak and the 24-hour average on the day of the peak. By incorporating both temperatures, the model is accounting for the fact that cold/heat buildup contributes to determining the peak day.

The non-phosphate per customer kW forecast is multiplied by the final customer forecast. This result is then aggregated with a phosphate coincident peak forecast to arrive at the final projected peak demand.

## **5. Phosphate Demand and Energy Analysis**

Because Tampa Electric's phosphate customers are relatively few in number, the company's Commercial/Industrial Customer Service Department has obtained detailed knowledge of industry developments including:

1. knowledge of expansion and close-out plans;
2. familiarity with historical and projected trends;
3. personal contact with industry personnel;
4. governmental legislation;
5. familiarity with worldwide demand for phosphate products.

This department's familiarity with industry dynamics and their close working relationship with phosphate company representatives were used to form the basis for a survey of the phosphate customers to determine their future energy and demand requirements. This survey is the foundation upon which the phosphate forecast is based. Further inputs are provided by the multiregression model's phosphate demand equations and discussions with industry experts.

## **6. Conservation, Load Management and Cogeneration Programs**

Tampa Electric has developed conservation, load management and cogeneration programs to achieve five major objectives:

1. Defer expansion, particularly production plant construction.
2. Reduce marginal fuel cost by managing energy usage during higher fuel cost periods
3. Provide customers with some ability to control energy usage and decrease energy costs.
4. Pursue the cost-effective accomplishment of the Florida Public Service Commission (FPSC) ten-year demand and energy goals for the residential and commercial/industrial sectors.
5. Achieve the comprehensive energy policy objectives as required by the Florida Energy Efficiency Conservation Act.

The company's current Demand Side Management (DSM) plan contains a mix of proven, mature programs that focus on the market place demand for their specific offerings. The following is a list that briefly describes the company's programs:

1. Heating and Cooling - Encourages the installation of high-efficiency residential heating and cooling equipment.
2. Load Management - Reduces weather-sensitive heating, cooling, water heating and pool pump loads through a radio signal control mechanism. Commercial and industrial programs are offered.

3. Energy Audits - The program is a "how to" information and analysis guide for customers. Five types of audits are available to Tampa Electric customers; three types are for residential class customers and two types for commercial/industrial customers.
4. Ceiling Insulation - An incentive program for existing residential structures which will help to supplement the cost of adding additional insulation.
5. Commercial Indoor Lighting - Encourages investment in more efficient lighting technologies within existing commercial facilities.
6. Standby Generator - A program designed to utilize the emergency generation capacity of commercial/industrial facilities in order to reduce weather sensitive peak demand.
7. Conservation Value - Encourages investments in measures that are not sanctioned by other commercial programs.
8. Duct Repair - An incentive program for existing homeowners which will help to supplement the cost of repairing leaky ductwork of central air-conditioning systems.
9. Cogeneration - A program whereby large industrial customers with waste heat or fuel resources may install electric generating equipment, meet their own electrical requirements and/or sell their surplus to the company.
10. Commercial Cooling - Encourages the installation of high efficiency direct expansion commercial cooling equipment.
11. Energy Plus Homes - Encourages the construction of residential dwellings at efficiency levels greater than current Florida building code baseline practices.

The programs listed above were developed to meet the FPSC demand and energy goals established in Docket No. 040033-EG, approved on August 9, 2004. The 2005 demand and energy savings achieved by conservation and load management programs are listed in Table III-1.

Tampa Electric developed a Monitoring and Evaluation (M&E) plan in response to requirements filed in Docket No. 941173-EG. The M&E plan was designed to effectively accomplish the required objective with prudent application of resources.

The M&E plan has as its focus two distinct areas: process evaluation and impact evaluation. Process evaluation examines how well a program has been implemented including the efficiency of delivery and customer satisfaction regarding the usefulness and quality of the services delivered. Impact evaluation is an evaluation of the change in demand and energy consumption achieved through program participation. The results of these evaluations give Tampa Electric insight into the direction that should be taken to refine delivery processes, program standards, and overall program cost-effectiveness.

### **Wholesale Load**

Tampa Electric's firm long-term wholesale sales consist of sales contracts with the Cities of Wauchula, Fort Meade, St. Cloud, Progress Energy Florida and Reedy Creek Improvement District.

Since Tampa Electric's sales to Wauchula and Fort Meade will vary over time based on the strength of the local economies, a multiple regression approach similar to that used for forecasting Tampa Electric's retail load has been utilized. Under this methodology, two equations have been developed for each municipality for forecasting energy: 1) customer forecast; 2) average usage forecast. The peak models for these two cities use sales forecast trend variables and heating and cooling degree variables as inputs.

For the remaining wholesale customers, future sales for a given year are based on the specific terms of their contracts with Tampa Electric.

**TABLE III-1**

**Comparison of Achieved MW and GWh Reductions With Florida Public Service Commission Goals**

Tampa Electric Company Ten Year Site Plan 2006 III-11

**Residential**

Year	<u>Winter Peak MW Reduction</u>			<u>Summer Peak MW Reduction</u>			<u>GWH Energy Reduction</u>		
	Total	Commission Approved	%	Total	Commission Approved	%	Total	Commission Approved	%
	<u>Achieved</u>	<u>Goal</u>	<u>Variance</u>	<u>Achieved</u>	<u>Goal</u>	<u>Variance</u>	<u>Achieved</u>	<u>Goal</u>	<u>Variance</u>
2005	4.2	4.0	105.0%	2.8	2.4	116.7%	7.7	7.0	110.0%

**Commercial/Industrial**

Year	<u>Winter Peak MW Reduction</u>			<u>Summer Peak MW Reduction</u>			<u>GWH Energy Reduction</u>		
	Total	Commission Approved	%	Total	Commission Approved	%	Total	Commission Approved	%
	<u>Achieved</u>	<u>Goal</u>	<u>Variance</u>	<u>Achieved</u>	<u>Goal</u>	<u>Variance</u>	<u>Achieved</u>	<u>Goal</u>	<u>Variance</u>
2005	3.4	1.0	340.0%	4.3	2.1	204.8%	7.9	6.7	117.9%

**Combined Total**

Year	<u>Winter Peak MW Reduction</u>			<u>Summer Peak MW Reduction</u>			<u>GWH Energy Reduction</u>		
	Total	Commission Approved	%	Total	Commission Approved	%	Total	Commission Approved	%
	<u>Achieved</u>	<u>Goal</u>	<u>Variance</u>	<u>Achieved</u>	<u>Goal</u>	<u>Variance</u>	<u>Achieved</u>	<u>Goal</u>	<u>Variance</u>
2005	7.6	5.0	152.0%	7.1	4.5	157.8%	15.6	13.7	113.9%



## Base Case Forecast Assumptions

### Retail Load

Numerous assumptions are inputs to the MetrixND models of which the more significant ones are listed below.

1. Population and Households;
2. Commercial, Industrial and Governmental Employment;
3. Commercial, Industrial and Governmental Output;
4. Per Capita Income;
5. Price of Electricity;
6. Appliance Efficiency Standards; and
7. Weather.

#### **1. Population and Households**

The state population forecast is the starting point for developing the customer and energy projections. Both the University of Florida's Bureau of Economic and Business Research (BEBR) and Economy.com supply population projections for Hillsborough County and Florida. The population forecast is a blend of long term and short term annual growth rates based upon the projections of BEBR and Economy.com. Over the next ten years (2006-2015) the average annual population growth rate in both Hillsborough County and Florida is expected to be 1.9%. In addition, Economy.com provides household data as an input to the residential average use model.

#### **2. Commercial, Industrial and Governmental Employment**

Commercial and industrial employment assumptions are utilized in computing the number of customers in their respective sectors. It is imperative that employment growth be consistent with the expected population expansion and unemployment levels. Over the next ten years, employment is assumed to rise at a 2.3% average annual rate. Economy.com supplies employment projections.

#### **3. Commercial, Industrial and Governmental Output**

In addition to employment, output in terms of real gross domestic product by employment sector is utilized in computing energy in their respective sectors. Over the next ten years, output for the entire employment sector is assumed to rise at a 4.0% average annual rate. Economy.com supplies output projections.

#### **4. Per Capita Income**

Economy.com supplies the assumptions for Hillsborough County's per capita income growth. During 2006-2015, real personal income per capita for Hillsborough County is expected to increase at a 3.7% average annual rate.

5. **Price of Electricity**

Forecasts for the price of electricity by customer class are supplied by Tampa Electric's Regulatory Department.

6. **Appliance Efficiency Standards**

Another factor influencing energy consumption is the movement toward more efficient appliances. The forces behind this development include market pressures for more energy-saving devices and the appliance efficiency standards enacted by the state and federal governments.

Also influencing energy consumption is the saturation levels of appliances. The saturation trend for heating appliances is increasing through time; however, overall electricity consumption actually declines over time as less efficient heating technologies (room heating and furnaces) are replaced with more efficient technologies (heat pumps). Similarly, cooling equipment saturation will continue to increase, but be offset by heat pump and central air conditioning efficiency gains.

Improvements in the efficiency of other non-weather related appliances also helps to lower electricity growth; however, any efficiency gains are offset by the increasing saturation trend of electronic equipment and appliances in households throughout the forecast period.

7. **Weather**

Since weather is the most difficult input to project, historical data is the major determinant in developing temperature profiles. For example, monthly profiles used in calculating energy consumption are based on twenty years of historical data. In addition, the temperature profiles used in projecting the winter and summer system peak are based on an examination of the minimum and maximum temperatures for the past twenty years plus the temperatures on peak days for the past twenty years.

In summary, despite the high saturation of electric appliances, increased appliance and equipment efficiencies will slow residential usage making them less sensitive to changes in temperature through time. However, economic conditions such as the decreasing real price of electricity and the increasing household income will mitigate any decline in consumption and actually increase overall energy consumption.

### **High and Low Scenario Forecast Assumptions**

The base case scenario is tested for sensitivity to varying economic conditions and customer growth rates. The high and low peak demand and energy scenarios represent alternatives to the company's base case outlook. The high scenario represents more optimistic economic conditions in the areas of customers, employment, and income. The low band represents a less optimistic scenario in the same areas. Compared to the base case, the expected customer and economic growth rates are 0.5% higher in the high scenario and 0.5% lower in the low scenario.

### **History and Forecast of Energy Use**

A history and forecast of energy consumption by customer classification are shown in Schedules 2.1 - 2.3.

#### **Retail Energy**

For 2006-2015, retail energy sales are projected to rise at a 2.8% annual rate. The major contributor to growth is the residential category, increasing at an annual rate of 3.3%.

#### **Wholesale Energy**

Wholesale energy sales to Progress Energy Florida, Wauchula, Ft. Meade, St. Cloud, and Reedy Creek of 522 GWH are expected in 2006. In 2011, sales drop substantially to 250 GWH and continue to decline to 227 GWH in 2012, 163 in 2013, and fall below 60 in 2014.

### **History and Forecast of Peak Loads**

Historical and base scenario forecasts of peak loads for the summer and winter seasons are presented in Schedules 3.1 and 3.2, respectively. For the 2006-2015 period, Tampa Electric's base case retail firm peak demand for both winter and summer are expected to advance at annual rates of 2.8%.

## CHAPTER IV

### FORECAST OF FACILITIES REQUIREMENTS

The proposed generating facility additions and changes shown in Schedule 8 integrate DSM programs and generating resources to provide economical, reliable service to Tampa Electric's customers. Various energy resource plan alternatives comprised of a mixture of generating technologies, purchased power, and cost-effective DSM programs are developed to determine this plan. These alternatives are combined with existing supply resources and analyzed to determine the energy resource option which best meets Tampa Electric's future system demand and energy requirements. A detailed discussion of Tampa Electric's integrated resource planning process is included in Chapter V.

The results of the integrated resource planning process provide Tampa Electric with a plan that is cost-effective while maintaining system reliability, balancing engineering concerns and other issues. The new capacity additions resulting from the analysis are shown in Schedule 8. To meet the expected system demand and energy requirements over the next ten years, combustion turbine additions are planned for 2007, 2009, 2010, 2011, 2012 and 2015, and one integrated coal gasification combined cycle (IGCC) unit is planned for 2013. The current Ten Year Site Plan identifies one IGCC unit as the most economic base load alternative for system expansion late in the ten-year planning horizon. The timing of the IGCC unit may vary due to uncertainties associated with fuel price forecasts and the long lead time requirements associated with siting, permitting, designing, and constructing this type of capacity.

As the construction start dates for each scheduled unit approaches, TEC will continue to look for competitive purchase power agreements that may replace or delay the scheduled units. Such alternatives will be considered, if they are better suited to achieving the overall objective of providing reliable power in the most cost-effective manner. Assumptions and information that impact the plan are discussed in the following sections. Additional assumptions and information are discussed in Chapter V.

#### **Cogeneration**

Tampa Electric plans for 455 MW of cogeneration capacity operating in its service area in 2006. Self-service capacity of 231 MW is used by cogenerators to serve internal load requirements, 62 MW are purchased by Tampa Electric on a firm contract basis, and 8 MW are purchased on a non-firm, as-available basis. The remaining 154 MW of cogeneration capacity is contracted to other utilities and is exported out of Tampa Electric's system.

## **Fuel Requirements**

A forecast of fuel requirements and energy sources is shown in Schedule 5, Schedule 6.1 and Schedule 6.2. Tampa Electric currently uses a balanced generation portfolio of coal and natural gas for its generating requirements. Tampa Electric has firm transportation contracts with the Florida Gas Transmission Company (FGT) and Gulfstream Natural Gas System LLC for delivery of natural gas to the Bayside Units. As shown in Schedule 6.2, in 2006 coal and pet coke will fuel 51% of net energy for load and natural gas will fuel 35%. Less than one percent of net energy for load will be fueled by oil at the Phillips plant and other combustion turbines. The remaining net energy for load is served by non-utility generators and net interchange.

## **Environmental Considerations**

An agreement between the Florida Department of Environmental Protection (DEP) and Tampa Electric produced a comprehensive emissions reduction plan delineated in a Consent Final Judgment (CFJ), which was finalized with the DEP on December 6, 1999. Approximately one year later, on February 29, 2000, Tampa Electric reached a similar agreement with the U.S. Environmental Protection Agency (EPA) in a Consent Decree (CD). Collectively, the CFJ and CD are referred to as the "Agreements". The efforts to reduce emissions from the company's facilities began long before the agreements. Tampa Electric has reduced annual sulfur dioxides (SO<sub>2</sub>), nitrogen oxides (NO<sub>x</sub>), and particulate matter (PM) emissions from our facilities by 162,000 tons, 44,000 tons, and 4,300 tons, respectively.

Reductions in SO<sub>2</sub> emissions were primarily accomplished through the installation of flue gas desulfurization (scrubber) systems on Big Bend Units 1 and 2 in 1999. Big Bend Unit 3 was integrated with Big Bend Unit 4's existing scrubber in 1995. Currently, the scrubbers at Big Bend station remove between 93% and 95% of the SO<sub>2</sub> emissions from the flue gas streams. In addition, reductions in NO<sub>x</sub> have been accomplished through combustion tuning and optimization projects at Big Bend Station and the repowering of Gannon Station to H.L. Culbreath Bayside Power Station.

Particulate matter is controlled at Big Bend station through the use of electrostatic precipitators, which removes more than 99.9% of the PM generated during the combustion process.

The repowering of Gannon Station to H.L. Culbreath Bayside Power Station resulted in significant reduction in emissions of all pollutant types. Tampa Electric's decision to install additional NO<sub>x</sub> emissions controls on all Big Bend Station Units by May of 2010 will result in the further reduction of emissions. Selective Catalytic Reduction (SCR) will be the control technology used to reduce Big Bend Station NO<sub>x</sub> emissions. The first unit scheduled to have an SCR installed by June 1, 2007 is Unit 4. Subsequently, the other units will be compliant by May 1 of 2008, 2009 and 2010. By 2010, these projects are expected to result in 61,840 tons per year of additional NO<sub>x</sub> reduction. In total, Tampa Electric's emission reduction initiatives will result in the reduction of SO<sub>2</sub>, NO<sub>x</sub> and PM emissions by 89%, 89%, and 72%, respectively, below 1998 levels. With these improvements in place, Tampa Electric's facilities will meet the same standards required of newer power generating facilities and significantly enhance the quality of the air in the community.

In addition, Tampa Electric is undertaking a number of environmental projects at Big Bend Station that were identified to enhance environmental operations at the site, including upgrades to the recycle/settling ponds, new slag de-watering bins that will replace the existing Industrial Waste Water (IWW) permitted slag pond system, a new gypsum storage area, and upgrades to the storm water system. Also, the company will remove the vast majority of coal combustion by-products from the existing land management systems in conjunction with construction of the new/replacement systems.

### **Interchange Sales and Purchases**

Tampa Electric's long-term interchange sales include Schedule D, Partial Requirements service agreements with Progress Energy Florida for 70 MW, Reedy Creek Improvement District for 75 MW, as well as the cities of Ft. Meade for 12 MW, St. Cloud for 15 MW, and Wauchula for 12 MW. Tampa Electric also has a firm sales agreement to New Smyrna Beach of 10 MW for January 2006 through December 31, 2007.

Tampa Electric has a long-term purchase power contract for capacity and energy from the Hardee Power Station owned by Invenergy. The contract term is January 1, 1993 through December 31, 2012. The contract involves a shared-capacity agreement with Seminole Electric Cooperative (SEC), whereby Tampa Electric plans for the full net capability (353 MW winter and 287 MW summer) of the Hardee Power Station during those times when SEC plans for the Seminole Units 1 and 2 and the SEC Crystal River Unit 3 allocation to be available for operation, and reduced availability during times when Seminole Units 1 and 2 are derated or unavailable due to planned maintenance. Tampa Electric has an additional long-term purchase power contract with Invenergy for 88 MW winter and 69 MW summer of firm non-shared capacity from the Hardee Power Station. This contract began in May 2000 and expires on December 31, 2012. Tampa Electric has also entered into a firm purchase power agreement with Progress Energy Florida for 50 MW from January 1, 2006 to March 31, 2007 and with Calpine Energy Services for 170 MW from May 1, 2006 to April 30, 2011.

In the 2006 planning process, Tampa Electric determined that it has a 230 MW capacity need in the winter of 2008. This capacity need is for the completion of the Selective Catalytic Reduction (SCR) system installations by the required Consent Decree (CD) date. Big Bend units 1, 2, and 3 will be down in consecutive years for the scheduled work from January through mid-April in 2008, 2009, and 2010. Tampa Electric will seek to satisfy this 2008 capacity need by contracting power from one or more entities. Informal inquiries have begun to locate potential sources of capacity. Tampa Electric will look to sign agreement(s) that provide cost-effective alternative(s) to satisfy the projected requirements.

The wholesale power sales and purchases are included in Schedules 3.1, 3.2, 3.3, 4, 5, 6.1, 7.1, and 7.2.

## Schedule 7.1

## Forecast of Capacity, Demand, and Scheduled Maintenance at Time of Summer Peak

(1)	(2)	(3)	(4)	(5)	(6)	(7)	(8)	(9)	(10)	(11)	(12)
Year	Total Installed Capacity MW	Firm Capacity Import MW	Firm Capacity Export MW	QF MW	Total Capacity Available MW	System Firm Summer Peak Demand MW	Reserve Margin Before Maintenance		Scheduled Maintenance MW	Reserve Margin After Maintenance	
							MW	% of Peak		MW	% of Peak
2006	4,071	576	10	62	4,699	3,905	794	20%	0	794	20%
2007	4,391	526	10	62	4,969	4,029	940	23%	0	940	23%
2008	4,391	526	0	62	4,979	4,159	820	20%	0	820	20%
2009	4,743	526	0	62	5,331	4,277	1,054	25%	0	1,054	25%
2010	4,919	526	0	39	5,484	4,400	1,084	25%	0	1,084	25%
2011	5,007	356	0	39	5,402	4,453	949	21%	0	949	21%
2012	5,183	356	0	23	5,562	4,583	979	21%	0	979	21%
2013	5,788	0	0	23	5,811	4,693	1,118	24%	0	1,118	24%
2014	5,788	0	0	23	5,811	4,805	1,006	21%	0	1,006	21%
2015	5,906	0	0	23	5,929	4,943	986	20%	0	986	20%

NOTE: 1. Capacity import includes firm purchase power agreements with Invenergy of 356 MW from 2006 through 2012, 50 MW from Progress Energy Florida in 2006 and 170 MW from Calpine from May 2006 through April 2011.

2. The QF column accounts for cogeneration that will be purchased under firm contracts.

3. Big Bend CT 1, 2, and 3 will be retired January 1, 2015.

\* Values may be affected due to rounding.



## Schedule 7.2

## Forecast of Capacity, Demand, and Scheduled Maintenance at Time of Winter Peak

(1)	(2)	(3)	(4)	(5)	(6)	(7)	(8)	(9)	(10)	(11)	(12)
Year	Total Installed Capacity MW	Firm Capacity Import MW	Firm Capacity Export MW	QF MW	Total Capacity Available MW	System Firm Winter Peak Demand MW	Reserve Margin Before Maintenance		Scheduled Maintenance MW	Reserve Margin After Maintenance	
							MW	% of Peak		MW	% of Peak
2005-06	4,383	491	10	62	4,926	4,056	870	21%	0	870	21%
2006-07	4,383	661	10	62	5,096	4,199	897	21%	0	897	21%
2007-08	4,743	841	0	62	5,646	4,340	1,306	30%	433	873	20%
2008-09	5,131	611	0	62	5,804	4,470	1,334	30%	391	943	21%
2009-10	5,325	611	0	62	5,998	4,601	1,397	30%	411	986	21%
2010-11	5,325	611	0	39	5,975	4,732	1,243	26%	0	1,243	26%
2011-12	5,422	441	0	23	5,886	4,796	1,090	23%	0	1,090	23%
2012-13	6,246	0	0	23	6,269	4,917	1,352	27%	0	1,352	27%
2013-14	6,246	0	0	23	6,269	5,032	1,237	25%	0	1,237	25%
2014-15	6,168	0	0	23	6,191	5,176	1,015	20%	0	1,015	20%

- NOTE:
1. Capacity import includes firm purchase power agreements with Invenergy of 441 MW from 2006 through 2012, Progress Energy Florida of 50 MW from 2006 through 2007, and Calpine of 170 MW from May 2006 through April 2011. Unspecified purchased power is expected to be needed for the installation of the Selective Catalytic Reduction (SCR) equipment on Big Bend unit 3, of 230 MW in 2008. The SCR installations are due to the Consent Decree between Tampa Electric Co. and the U.S. Environmental Protection Agency. Discussed in section IV-2, Enterchange Sales and Purchases.
  2. The QF column accounts for cogeneration that will be purchased under firm contracts.
  3. Big Bend CT 1, 2, and 3 will be retired January 1, 2015.

Schedule 8

Planned and Prospective Generating Facility Additions

(1)	(2)	(3)	(4)	(5)	(6)	(7)	(8)	(9)	(10)	(11)	(12)	(13)	(14)	(15)
Plant Name	Unit No.	Location	Unit Type	Fuel		Fuel Trans.		Const. Start Mo/Yr	Commercial In-Service Mo/Yr	Expected Retirement Mo/Yr	Gen. Max. Nameplate kW	Net Capability		Status
				Primary	Alternate	Primary	Alternate					Summer MW	Winter MW	
Polk	4	Polk	GT	NG	NA	PL	NA	5/06	5/07	unknown	unknown	160	180	T
Polk	5	Polk	GT	NG	NA	PL	NA	5/06	7/07	unknown	unknown	160	180	T
Future CT	1	unknown	GT	NG	NA	PL	NA	5/07	1/09	unknown	unknown	88	97	P
Future CT	2	unknown	GT	NG	NA	PL	NA	5/07	1/09	unknown	unknown	88	97	P
Future CT	3	unknown	GT	NG	NA	PL	NA	5/07	1/09	unknown	unknown	88	97	P
Future CT	4	unknown	GT	NG	NA	PL	NA	5/07	1/09	unknown	unknown	88	97	P
Future CT	5	unknown	GT	NG	NA	PL	NA	5/08	1/10	unknown	unknown	88	97	P
Future CT	6	unknown	GT	NG	NA	PL	NA	5/08	1/10	unknown	unknown	88	97	P
Future CT	7	unknown	GT	NG	NA	PL	NA	1/10	5/11	unknown	unknown	88	97	P
Future CT	8	unknown	GT	NG	NA	PL	NA	1/11	5/12	unknown	unknown	88	97	P
Future CT	9	unknown	GT	NG	NA	PL	NA	1/11	5/12	unknown	unknown	88	97	P
Future IGCC	1	unknown	CC	BIT	NG	WA	PL	1/09	1/13	unknown	unknown	605	630	P
Future CT	10	unknown	GT	NG	NA	PL	NA	5/13	1/15	unknown	unknown	88	97	P
Future CT	11	unknown	GT	NG	NA	PL	NA	1/14	5/15	unknown	unknown	88	97	P
Future CT	12	unknown	GT	NG	NA	PL	NA	1/14	5/15	unknown	unknown	88	97	P

## SCHEDULE 9

(Page 1 of 15)

### STATUS REPORT AND SPECIFICATIONS OF PROPOSED GENERATING FACILITIES UTILITY: TAMPA ELECTRIC COMPANY

(1)	PLANT NAME AND UNIT NUMBER	POLK 4
(2)	CAPACITY	
	A. SUMMER	160
	B. WINTER	180
(3)	TECHNOLOGY TYPE	COMBUSTION TURBINE
(4)	ANTICIPATED CONSTRUCTION TIMING	
	A. FIELD CONSTRUCTION START DATE	MAY 2006
	B. COMMERCIAL IN-SERVICE DATE	MAY 2007
(5)	FUEL	
	A. PRIMARY FUEL	NATURAL GAS
	B. ALTERNATE FUEL	N/A
(6)	AIR POLLUTION CONTROL STRATEGY	DRY LOW NO <sub>x</sub> BURNER
(7)	COOLING METHOD	N/A
(8)	TOTAL SITE AREA <sup>1</sup>	APPROXIMATELY 4,347 ACRES
(9)	CONSTRUCTION STATUS	REGULATORY APPROVAL
(10)	CERTIFICATION STATUS <sup>3</sup>	N/A
(11)	STATUS WITH FEDERAL AGENCIES	N/A
(12)	PROJECTED UNIT PERFORMANCE DATA	
	PLANNED OUTAGE FACTOR (POF)	1.9
	FORCED OUTAGE RATE (FOR)	4.8
	EQUIVALENT AVAILABILITY FACTOR (EAF)	93
	RESULTING CAPACITY FACTOR (2007)	8.3%
	AVERAGE NET OPERATING HEAT RATE (ANOHR) <sup>2</sup>	12,918 Btu/kWh
(13)	PROJECTED UNIT FINANCIAL DATA	
	BOOK LIFE (YEARS)	26
	TOTAL INSTALLED COST (IN-SERVICE YEAR \$/kW)	290.73
	DIRECT CONSTRUCTION COST (\$/kW)	274.03
	AFUDC AMOUNT (\$/kW)	15.63
	ESCALATION (\$/kW)	1.07
	FIXED O&M (\$/kW - Yr)	2.62
	VARIABLE O&M (\$/MWH)	9.44
	K FACTOR	1.6926

<sup>1</sup> REPRESENTS TOTAL POKL SITE.

<sup>2</sup> BASED ON IN-SERVICE YEAR.

<sup>3</sup> CERTIFICATION NOT REQUIRED.

**SCHEDULE 9**

(Page 2 of 15)

**STATUS REPORT AND SPECIFICATIONS OF PROPOSED GENERATING FACILITIES  
UTILITY: TAMPA ELECTRIC COMPANY**

(1)	PLANT NAME AND UNIT NUMBER	POLK 5
(2)	CAPACITY	
	A. SUMMER	160
	B. WINTER	180
(3)	TECHNOLOGY TYPE	COMBUSTION TURBINE
(4)	ANTICIPATED CONSTRUCTION TIMING	
	A. FIELD CONSTRUCTION START DATE	MAY 2006
	B. COMMERCIAL IN-SERVICE DATE	JUL 2007
(5)	FUEL	
	A. PRIMARY FUEL	NATURAL GAS
	B. ALTERNATE FUEL	N/A
(6)	AIR POLLUTION CONTROL STRATEGY	DRY LOW NO <sub>x</sub> BURNER
(7)	COOLING METHOD	N/A
(8)	TOTAL SITE AREA <sup>1</sup>	APPROXIMATELY 4,347 ACRES
(9)	CONSTRUCTION STATUS	REGULATORY APPROVAL
(10)	CERTIFICATION STATUS <sup>3</sup>	N/A
(11)	STATUS WITH FEDERAL AGENCIES	N/A
(12)	PROJECTED UNIT PERFORMANCE DATA	
	PLANNED OUTAGE FACTOR (POF)	1.9
	FORCED OUTAGE RATE (FOR)	4.8
	EQUIVALENT AVAILABILITY FACTOR (EAF)	93
	RESULTING CAPACITY FACTOR (2007)	4.6%
	AVERAGE NET OPERATING HEAT RATE (ANOHR) <sup>2</sup>	12,626 Btu/kWh
(13)	PROJECTED UNIT FINANCIAL DATA	
	BOOK LIFE (YEARS)	26
	TOTAL INSTALLED COST (IN-SERVICE YEAR \$/kW)	251.84
	DIRECT CONSTRUCTION COST (\$/kW)	233.55
	AFUDC AMOUNT (\$/kW)	17.22
	ESCALATION (\$/kW)	1.06
	FIXED O&M (\$/kW - Yr)	2.62
	VARIABLE O&M (\$/MWH)	9.44
	K FACTOR	1.6926

<sup>1</sup> REPRESENTS TOTAL POLK SITE.

<sup>2</sup> BASED ON IN-SERVICE YEAR.

<sup>3</sup> CERTIFICATION NOT REQUIRED.

## SCHEDULE 9

(Page 3 of 15)

### STATUS REPORT AND SPECIFICATIONS OF PROPOSED GENERATING FACILITIES UTILITY: TAMPA ELECTRIC COMPANY

(1)	PLANT NAME AND UNIT NUMBER	FUTURE CT 1
(2)	CAPACITY	
	A. SUMMER	88
	B. WINTER	97
(3)	TECHNOLOGY TYPE	COMBUSTION TURBINE
(4)	ANTICIPATED CONSTRUCTION TIMING	
	A. FIELD CONSTRUCTION START-DATE	MAY 2007
	B. COMMERCIAL IN-SERVICE DATE	JAN 2009
(5)	FUEL	
	A. PRIMARY FUEL	NATURAL GAS
	B. ALTERNATE FUEL	UNDETERMINED
(6)	AIR POLLUTION CONTROL STRATEGY	DRY LOW NO <sub>x</sub> BURNER
(7)	COOLING METHOD	N/A
(8)	TOTAL SITE AREA	UNDETERMINED
(9)	CONSTRUCTION STATUS	PROPOSED
(10)	CERTIFICATION STATUS	UNDETERMINED
(11)	STATUS WITH FEDERAL AGENCIES	N/A
(12)	PROJECTED UNIT PERFORMANCE DATA	
	PLANNED OUTAGE FACTOR (POF)	1.1
	FORCED OUTAGE RATE (FOR)	1.0
	EQUIVALENT AVAILABILITY FACTOR (EAF)	96.9
	RESULTING CAPACITY FACTOR (2009)	11.3%
	AVERAGE NET OPERATING HEAT RATE (ANOHR) <sup>1</sup>	8,200 Btu/kWh
(13)	PROJECTED UNIT FINANCIAL DATA	
	BOOK LIFE (YEARS)	26
	TOTAL INSTALLED COST (IN-SERVICE YEAR \$/kW)	510.09
	DIRECT CONSTRUCTION COST (\$/kW)	471.68
	AFUDC AMOUNT (\$/kW)	12.49
	ESCALATION (\$/kW)	25.92
	FIXED O&M (\$/kW - Yr)	3.96
	VARIABLE O&M (\$/MWH)	2.91
	K FACTOR	1.6926

<sup>1</sup> BASED ON IN-SERVICE YEAR.

**SCHEDULE 9**

(Page 4 of 15)

**STATUS REPORT AND SPECIFICATIONS OF PROPOSED GENERATING FACILITIES  
UTILITY: TAMPA ELECTRIC COMPANY**

(1)	PLANT NAME AND UNIT NUMBER	FUTURE CT 2
(2)	CAPACITY	
	A. SUMMER	88
	B. WINTER	97
(3)	TECHNOLOGY TYPE	COMBUSTION TURBINE
(4)	ANTICIPATED CONSTRUCTION TIMING	
	A. FIELD CONSTRUCTION START DATE	MAY 2007
	B. COMMERCIAL IN-SERVICE DATE	JAN 2009
(5)	FUEL	
	A. PRIMARY FUEL	NATURAL GAS
	B. ALTERNATE FUEL	UNDETERMINED
(6)	AIR POLLUTION CONTROL STRATEGY	DRY LOW NO <sub>x</sub> BURNER
(7)	COOLING METHOD	N/A
(8)	TOTAL SITE AREA	UNDETERMINED
(9)	CONSTRUCTION STATUS	PROPOSED
(10)	CERTIFICATION STATUS	UNDETERMINED
(11)	STATUS WITH FEDERAL AGENCIES	N/A
(12)	PROJECTED UNIT PERFORMANCE DATA	
	PLANNED OUTAGE FACTOR (POF)	1.1
	FORCED OUTAGE RATE (FOR)	1.0
	EQUIVALENT AVAILABILITY FACTOR (EAF)	96.9
	RESULTING CAPACITY FACTOR (2009)	9.4%
	AVERAGE NET OPERATING HEAT RATE (ANOHR) <sup>1</sup>	8,200 Btu/kWh
(13)	PROJECTED UNIT FINANCIAL DATA	
	BOOK LIFE (YEARS)	26
	TOTAL INSTALLED COST (IN-SERVICE YEAR \$/kW)	510.09
	DIRECT CONSTRUCTION COST (\$/kW)	471.68
	AFUDC AMOUNT (\$/kW)	12.49
	ESCALATION (\$/kW)	25.92
	FIXED O&M (\$/kW - Yr)	3.96
	VARIABLE O&M (\$/MWH)	2.91
	K FACTOR	1.6926

<sup>1</sup> BASED ON IN-SERVICE YEAR.

## SCHEDULE 9

(Page 5 of 15)

### STATUS REPORT AND SPECIFICATIONS OF PROPOSED GENERATING FACILITIES UTILITY: TAMPA ELECTRIC COMPANY

(1)	PLANT NAME AND UNIT NUMBER	FUTURE CT 3
(2)	CAPACITY	
	A. SUMMER	88
	B. WINTER	97
(3)	TECHNOLOGY TYPE	COMBUSTION TURBINE
(4)	ANTICIPATED CONSTRUCTION TIMING	
	A. FIELD CONSTRUCTION START DATE	MAY 2007
	B. COMMERCIAL IN-SERVICE DATE	JAN 2009
(5)	FUEL	
	A. PRIMARY FUEL	NATURAL GAS
	B. ALTERNATE FUEL	UNDETERMINED
(6)	AIR POLLUTION CONTROL STRATEGY	DRY LOW NO <sub>x</sub> BURNER
(7)	COOLING METHOD	N/A
(8)	TOTAL SITE AREA	UNDETERMINED
(9)	CONSTRUCTION STATUS	PROPOSED
(10)	CERTIFICATION STATUS	UNDETERMINED
(11)	STATUS WITH FEDERAL AGENCIES	N/A
(12)	PROJECTED UNIT PERFORMANCE DATA	
	PLANNED OUTAGE FACTOR (POF)	1.1
	FORCED OUTAGE RATE (FOR)	1.0
	EQUIVALENT AVAILABILITY FACTOR (EAF)	96.9
	RESULTING CAPACITY FACTOR (2009)	7.7%
	AVERAGE NET OPERATING HEAT RATE (ANOHR) <sup>1</sup>	8,200 Btu/kWh
(13)	PROJECTED UNIT FINANCIAL DATA	
	BOOK LIFE (YEARS)	26
	TOTAL INSTALLED COST (IN-SERVICE YEAR \$/kW)	510.09
	DIRECT CONSTRUCTION COST (\$/kW)	471.68
	AFUDC AMOUNT (\$/kW)	12.49
	ESCALATION (\$/kW)	25.92
	FIXED O&M (\$/kW - Yr)	3.96
	VARIABLE O&M (\$/MWH)	2.91
	K FACTOR	1.6926

<sup>1</sup> BASED ON IN-SERVICE YEAR.

## SCHEDULE 9

(Page 6 of 15)

### STATUS REPORT AND SPECIFICATIONS OF PROPOSED GENERATING FACILITIES UTILITY: TAMPA ELECTRIC COMPANY

(1)	PLANT NAME AND UNIT NUMBER	FUTURE CT 4
(2)	CAPACITY	
	A. SUMMER	88
	B. WINTER	97
(3)	TECHNOLOGY TYPE	COMBUSTION TURBINE
(4)	ANTICIPATED CONSTRUCTION TIMING	
	A. FIELD CONSTRUCTION START DATE	MAY 2007
	B. COMMERCIAL IN-SERVICE DATE	JAN 2009
(5)	FUEL	
	A. PRIMARY FUEL	NATURAL GAS
	B. ALTERNATE FUEL	UNDETERMINED
(6)	AIR POLLUTION CONTROL STRATEGY	DRY LOW NO <sub>x</sub> BURNER
(7)	COOLING METHOD	N/A
(8)	TOTAL SITE AREA	UNDETERMINED
(9)	CONSTRUCTION STATUS	PROPOSED
(10)	CERTIFICATION STATUS	UNDETERMINED
(11)	STATUS WITH FEDERAL AGENCIES	N/A
(12)	PROJECTED UNIT PERFORMANCE DATA	
	PLANNED OUTAGE FACTOR (POF)	1.1
	FORCED OUTAGE RATE (FOR)	1.0
	EQUIVALENT AVAILABILITY FACTOR (EAF)	96.9
	RESULTING CAPACITY FACTOR (2009)	6.6%
	AVERAGE NET OPERATING HEAT RATE (ANOHR) <sup>1</sup>	8,200 Btu/kWh
(13)	PROJECTED UNIT FINANCIAL DATA	
	BOOK LIFE (YEARS)	26
	TOTAL INSTALLED COST (IN-SERVICE YEAR \$/kW)	510.09
	DIRECT CONSTRUCTION COST (\$/kW)	471.68
	AFUDC AMOUNT (\$/kW)	12.49
	ESCALATION (\$/kW)	25.92
	FIXED O&M (\$/kW – Yr)	3.96
	VARIABLE O&M (\$/MWH)	2.91
	K FACTOR	1.6926

<sup>1</sup> BASED ON IN-SERVICE YEAR.



## SCHEDULE 9

(Page 7 of 15)

### STATUS REPORT AND SPECIFICATIONS OF PROPOSED GENERATING FACILITIES UTILITY: TAMPA ELECTRIC COMPANY

(1)	PLANT NAME AND UNIT NUMBER	FUTURE CT 5
(2)	CAPACITY	
	A. SUMMER	88
	B. WINTER	97
(3)	TECHNOLOGY TYPE	COMBUSTION TURBINE
(4)	ANTICIPATED CONSTRUCTION TIMING	
	A. FIELD CONSTRUCTION START DATE	MAY 2008
	B. COMMERCIAL IN-SERVICE DATE	JAN 2010
(5)	FUEL	
	A. PRIMARY FUEL	NATURAL GAS
	B. ALTERNATE FUEL	UNDETERMINED
(6)	AIR POLLUTION CONTROL STRATEGY	SCR, DLN BURNERS
(7)	COOLING METHOD	N/A
(8)	TOTAL SITE AREA	UNDETERMINED
(9)	CONSTRUCTION STATUS	PROPOSED
(10)	CERTIFICATION STATUS	UNDETERMINED
(11)	STATUS WITH FEDERAL AGENCIES	N/A
(12)	PROJECTED UNIT PERFORMANCE DATA	
	PLANNED OUTAGE FACTOR (POF)	1.1
	FORCED OUTAGE RATE (FOR)	1.0
	EQUIVALENT AVAILABILITY FACTOR (EAF)	96.9
	RESULTING CAPACITY FACTOR (2010)	6.3%
	AVERAGE NET OPERATING HEAT RATE (ANOHR) <sup>1</sup>	8,200 Btu/kWh
(13)	PROJECTED UNIT FINANCIAL DATA	
	BOOK LIFE (YEARS)	26
	TOTAL INSTALLED COST (IN-SERVICE YEAR \$/kW)	521.82
	DIRECT CONSTRUCTION COST (\$/kW)	471.68
	AFUDC AMOUNT (\$/kW)	12.78
	ESCALATION (\$/kW)	37.36
	FIXED O&M (\$/kW - Yr)	4.05
	VARIABLE O&M (\$/MWH)	2.97
	K FACTOR	1.6926

<sup>1</sup> BASED ON IN-SERVICE YEAR.

## SCHEDULE 9

(Page 8 of 15)

### STATUS REPORT AND SPECIFICATIONS OF PROPOSED GENERATING FACILITIES UTILITY: TAMPA ELECTRIC COMPANY

(1)	PLANT NAME AND UNIT NUMBER	FUTURE CT 6
(2)	CAPACITY	
	A. SUMMER	88
	B. WINTER	97
(3)	TECHNOLOGY TYPE	COMBUSTION TURBINE
(4)	ANTICIPATED CONSTRUCTION TIMING	
	A. FIELD CONSTRUCTION START DATE	MAY 2008
	B. COMMERCIAL IN-SERVICE DATE	JAN 2010
(5)	FUEL	
	A. PRIMARY FUEL	NATURAL GAS
	B. ALTERNATE FUEL	UNDETERMINED
(6)	AIR POLLUTION CONTROL STRATEGY	DRY LOW NO <sub>x</sub> BURNER
(7)	COOLING METHOD	N/A
(8)	TOTAL SITE AREA	UNDETERMINED
(9)	CONSTRUCTION STATUS	PROPOSED
(10)	CERTIFICATION STATUS	UNDETERMINED
(11)	STATUS WITH FEDERAL AGENCIES	N/A
(12)	PROJECTED UNIT PERFORMANCE DATA	
	PLANNED OUTAGE FACTOR (POF)	1.1
	FORCED OUTAGE RATE (FOR)	1.0
	EQUIVALENT AVAILABILITY FACTOR (EAF)	96.9
	RESULTING CAPACITY FACTOR (2010)	5.5%
	AVERAGE NET OPERATING HEAT RATE (ANOHR) <sup>1</sup>	8,200 Btu/kWh
(13)	PROJECTED UNIT FINANCIAL DATA	
	BOOK LIFE (YEARS)	26
	TOTAL INSTALLED COST (IN-SERVICE YEAR \$/kW)	521.82
	DIRECT CONSTRUCTION COST (\$/kW)	471.68
	AFUDC AMOUNT (\$/kW)	12.78
	ESCALATION (\$/kW)	37.36
	FIXED O&M (\$/kW - Yr)	4.05
	VARIABLE O&M (\$/MWH)	2.97
	K FACTOR	1.6926

<sup>1</sup> BASED ON IN-SERVICE YEAR.

## SCHEDULE 9

(Page 9 of 15)

### STATUS REPORT AND SPECIFICATIONS OF PROPOSED GENERATING FACILITIES UTILITY: TAMPA ELECTRIC COMPANY

(1)	PLANT NAME AND UNIT NUMBER	FUTURE CT 7
(2)	CAPACITY	
	A. SUMMER	88
	B. WINTER	97
(3)	TECHNOLOGY TYPE	COMBUSTION TURBINE
(4)	ANTICIPATED CONSTRUCTION TIMING	
	A. FIELD CONSTRUCTION START DATE	JAN 2010
	B. COMMERCIAL IN-SERVICE DATE	MAY 2011
(5)	FUEL	
	A. PRIMARY FUEL	NATURAL GAS
	B. ALTERNATE FUEL	UNDETERMINED
(6)	AIR POLLUTION CONTROL STRATEGY	DRY LOW NO <sub>x</sub> BURNER
(7)	COOLING METHOD	N/A
(8)	TOTAL SITE AREA	UNDETERMINED
(9)	CONSTRUCTION STATUS	PROPOSED
(10)	CERTIFICATION STATUS	UNDETERMINED
(11)	STATUS WITH FEDERAL AGENCIES	N/A
(12)	PROJECTED UNIT PERFORMANCE DATA	
	PLANNED OUTAGE FACTOR (POF)	1.1
	FORCED OUTAGE RATE (FOR)	1.0
	EQUIVALENT AVAILABILITY FACTOR (EAF)	96.9
	RESULTING CAPACITY FACTOR (2011)	6.6%
	AVERAGE NET OPERATING HEAT RATE (ANOHR) <sup>1</sup>	8,200 Btu/kWh
(13)	PROJECTED UNIT FINANCIAL DATA	
	BOOK LIFE (YEARS)	26
	TOTAL INSTALLED COST (IN-SERVICE YEAR \$/kW)	545.29
	DIRECT CONSTRUCTION COST (\$/kW)	471.68
	AFUDC AMOUNT (\$/kW)	24.54
	ESCALATION (\$/kW)	49.07
	FIXED O&M (\$/kW - Yr)	4.14
	VARIABLE O&M (\$/MWH)	3.04
	K FACTOR	1.6926

<sup>1</sup> BASED ON IN-SERVICE YEAR.

**SCHEDULE 9**

(Page 10 of 15)

**STATUS REPORT AND SPECIFICATIONS OF PROPOSED GENERATING FACILITIES  
UTILITY: TAMPA ELECTRIC COMPANY**

(1)	PLANT NAME AND UNIT NUMBER	FUTURE CT 8
(2)	CAPACITY	
	A. SUMMER	88
	B. WINTER	97
(3)	TECHNOLOGY TYPE	COMBUSTION TURBINE
(4)	ANTICIPATED CONSTRUCTION TIMING	
	A. FIELD CONSTRUCTION START DATE	JAN 2011
	B. COMMERCIAL IN-SERVICE DATE	MAY 2012
(5)	FUEL	
	A. PRIMARY FUEL	NATURAL GAS
	B. ALTERNATE FUEL	UNDETERMINED
(6)	AIR POLLUTION CONTROL STRATEGY	DRY LOW NO <sub>x</sub> BURNER
(7)	COOLING METHOD	N/A
(8)	TOTAL SITE AREA	UNDETERMINED
(9)	CONSTRUCTION STATUS	PROPOSED
(10)	CERTIFICATION STATUS	UNDETERMINED
(11)	STATUS WITH FEDERAL AGENCIES	N/A
(12)	PROJECTED UNIT PERFORMANCE DATA	
	PLANNED OUTAGE FACTOR (POF)	1.1
	FORCED OUTAGE RATE (FOR)	1.0
	EQUIVALENT AVAILABILITY FACTOR (EAF)	96.9
	RESULTING CAPACITY FACTOR (2012)	8.7%
	AVERAGE NET OPERATING HEAT RATE (ANOHR) <sup>1</sup>	8,200 Btu/kWh
(13)	PROJECTED UNIT FINANCIAL DATA	
	BOOK LIFE (YEARS)	26
	TOTAL INSTALLED COST (IN-SERVICE YEAR \$/kW)	557.84
	DIRECT CONSTRUCTION COST (\$/kW)	471.68
	AFUDC AMOUNT (\$/kW)	25.10
	ESCALATION (\$/kW)	61.05
	FIXED O&M (\$/kW - Yr)	4.24
	VARIABLE O&M (\$/MWH)	3.11
	K FACTOR	1.6926

<sup>1</sup> BASED ON IN-SERVICE YEAR.

**SCHEDULE 9**

(Page 11 of 15)

**STATUS REPORT AND SPECIFICATIONS OF PROPOSED GENERATING FACILITIES  
UTILITY: TAMPA ELECTRIC COMPANY**

(1)	PLANT NAME AND UNIT NUMBER	FUTURE CT 9
(2)	CAPACITY	
	A. SUMMER	88
	B. WINTER	97
(3)	TECHNOLOGY TYPE	COMBUSTION TURBINE
(4)	ANTICIPATED CONSTRUCTION TIMING	
	A. FIELD CONSTRUCTION START DATE	JAN 2011
	B. COMMERCIAL IN-SERVICE DATE	MAY 2012
(5)	FUEL	
	A. PRIMARY FUEL	NATURAL GAS
	B. ALTERNATE FUEL	UNDETERMINED
(6)	AIR POLLUTION CONTROL STRATEGY	DRY LOW NO <sub>x</sub> BURNER
(7)	COOLING METHOD	N/A
(8)	TOTAL SITE AREA	UNDETERMINED
(9)	CONSTRUCTION STATUS	PROPOSED
(10)	CERTIFICATION STATUS	UNDETERMINED
(11)	STATUS WITH FEDERAL AGENCIES	N/A
(12)	PROJECTED UNIT PERFORMANCE DATA	
	PLANNED OUTAGE FACTOR (POF)	1.1
	FORCED OUTAGE RATE (FOR)	1.0
	EQUIVALENT AVAILABILITY FACTOR (EAF)	96.9
	RESULTING CAPACITY FACTOR (2012)	7.7%
	AVERAGE NET OPERATING HEAT RATE (ANOHR) <sup>1</sup>	8,200 Btu/kWh
(13)	PROJECTED UNIT FINANCIAL DATA	
	BOOK LIFE (YEARS)	26
	TOTAL INSTALLED COST (IN-SERVICE YEAR \$/kW)	557.84
	DIRECT CONSTRUCTION COST (\$/kW)	471.68
	AFUDC AMOUNT (\$/kW)	25.10
	ESCALATION (\$/kW)	61.05
	FIXED O&M (\$/kW - Yr)	4.25
	VARIABLE O&M (\$/MWH)	3.11
	K FACTOR	1.6926

<sup>1</sup> BASED ON IN-SERVICE YEAR.

## SCHEDULE 9

(Page 12 of 15)

### STATUS REPORT AND SPECIFICATIONS OF PROPOSED GENERATING FACILITIES UTILITY: TAMPA ELECTRIC COMPANY

(1)	PLANT NAME AND UNIT NUMBER	FUTURE IGCC 1
(2)	CAPACITY	
	A. SUMMER	605
	B. WINTER	630
(3)	TECHNOLOGY TYPE	INTERGRATED COAL GASIFICATION COMBINED CYCLE
(4)	ANTICIPATED CONSTRUCTION TIMING	
	A. FIELD CONSTRUCTION START DATE	JAN 2009
	B. COMMERCIAL IN-SERVICE DATE	JAN 2013
(5)	FUEL	
	A. PRIMARY FUEL	COAL / PETCOKE
	B. ALTERNATE FUEL	NATURAL GAS
(6)	AIR POLLUTION CONTROL STRATEGY	DRY LOW NO <sub>x</sub> BURNER
(7)	COOLING METHOD	N/A
(8)	TOTAL SITE AREA	UNDETERMINED
(9)	CONSTRUCTION STATUS	PROPOSED
(10)	CERTIFICATION STATUS	UNDETERMINED
(11)	STATUS WITH FEDERAL AGENCIES	N/A
(12)	PROJECTED UNIT PERFORMANCE DATA	
	PLANNED OUTAGE FACTOR (POF)	7.4
	FORCED OUTAGE RATE (FOR)	5.0
	EQUIVALENT AVAILABILITY FACTOR (EAF)	85.07
	RESULTING CAPACITY FACTOR (2013)	87.0%
	AVERAGE NET OPERATING HEAT RATE (ANOHR) <sup>1</sup>	9,306 Btu/kWh
(13)	PROJECTED UNIT FINANCIAL DATA <sup>2</sup>	
	BOOK LIFE (YEARS)	26
	TOTAL INSTALLED COST (IN-SERVICE YEAR \$/kW)	2,626.70
	DIRECT CONSTRUCTION COST (\$/kW)	2,065.26
	AFUDC AMOUNT (\$/kW)	324.77
	ESCALATION (\$/kW)	236.67
	FIXED O&M (\$/kW - Yr)	38.54
	VARIABLE O&M (\$/MWH)	0.85
	K FACTOR	1.6926

<sup>1</sup> BASED ON IN-SERVICE YEAR.

<sup>2</sup> INCLUDES OWNER'S COST AND CONTINGENCY FUNDS

## SCHEDULE 9

(Page 13 of 15)

### STATUS REPORT AND SPECIFICATIONS OF PROPOSED GENERATING FACILITIES UTILITY: TAMPA ELECTRIC COMPANY

(1)	PLANT NAME AND UNIT NUMBER	FUTURE CT 10
(2)	CAPACITY A. SUMMER B. WINTER	88 97
(3)	TECHNOLOGY TYPE	COMBUSTION TURBINE
(4)	ANTICIPATED CONSTRUCTION TIMING A. FIELD CONSTRUCTION START DATE B. COMMERCIAL IN-SERVICE DATE	MAY 2013 JAN 2015
(5)	FUEL A. PRIMARY FUEL B. ALTERNATE FUEL	NATURAL GAS UNDETERMINED
(6)	AIR POLLUTION CONTROL STRATEGY	DRY LOW NO <sub>x</sub> BURNER
(7)	COOLING METHOD	N/A
(8)	TOTAL SITE AREA	UNDETERMINED
(9)	CONSTRUCTION STATUS	PROPOSED
(10)	CERTIFICATION STATUS	UNDETERMINED
(11)	STATUS WITH FEDERAL AGENCIES	N/A
(12)	PROJECTED UNIT PERFORMANCE DATA PLANNED OUTAGE FACTOR (POF) FORCED OUTAGE RATE (FOR) EQUIVALENT AVAILABILITY FACTOR (EAF) RESULTING CAPACITY FACTOR (2015) AVERAGE NET OPERATING HEAT RATE (ANOHR) <sup>1</sup>	1.1 1.0 96.9 3.6% 8,200 Btu/kWh
(13)	PROJECTED UNIT FINANCIAL DATA BOOK LIFE (YEARS) TOTAL INSTALLED COST (IN-SERVICE YEAR \$/kW) DIRECT CONSTRUCTION COST (\$/kW) AFUDC AMOUNT (\$/kW) ESCALATION (\$/kW) FIXED O&M (\$/kW - Yr) VARIABLE O&M (\$/MWH) K FACTOR	26 584.66 471.68 14.32 98.66 4.54 3.33 1.6926

<sup>1</sup> BASED ON IN-SERVICE YEAR.

## SCHEDULE 9

(Page 14 of 15)

### STATUS REPORT AND SPECIFICATIONS OF PROPOSED GENERATING FACILITIES UTILITY: TAMPA ELECTRIC COMPANY

(1)	PLANT NAME AND UNIT NUMBER	FUTURE CT 11
(2)	CAPACITY	
	A. SUMMER	88
	B. WINTER	97
(3)	TECHNOLOGY TYPE	COMBUSTION TURBINE
(4)	ANTICIPATED CONSTRUCTION TIMING	
	A. FIELD CONSTRUCTION START DATE	JAN 2014
	B. COMMERCIAL IN-SERVICE DATE	MAY 2015
(5)	FUEL	
	A. PRIMARY FUEL	NATURAL GAS
	B. ALTERNATE FUEL	UNDETERMINED
(6)	AIR POLLUTION CONTROL STRATEGY	DRY LOW NO <sub>x</sub> BURNER
(7)	COOLING METHOD	N/A
(8)	TOTAL SITE AREA	UNDETERMINED
(9)	CONSTRUCTION STATUS	PROPOSED
(10)	CERTIFICATION STATUS	UNDETERMINED
(11)	STATUS WITH FEDERAL AGENCIES	N/A
(12)	PROJECTED UNIT PERFORMANCE DATA	
	PLANNED OUTAGE FACTOR (POF)	1.1
	FORCED OUTAGE RATE (FOR)	1.0
	EQUIVALENT AVAILABILITY FACTOR (EAF)	96.9
	RESULTING CAPACITY FACTOR (2015)	4.6%
	AVERAGE NET OPERATING HEAT RATE (ANOHR) <sup>1</sup>	8,200 Btu/kWh
(13)	PROJECTED UNIT FINANCIAL DATA	
	BOOK LIFE (YEARS)	26
	TOTAL INSTALLED COST (IN-SERVICE YEAR \$/kW)	597.22
	DIRECT CONSTRUCTION COST (\$/kW)	471.68
	AFUDC AMOUNT (\$/kW)	26.88
	ESCALATION (\$/kW)	98.66
	FIXED O&M (\$/kW - Yr)	4.54
	VARIABLE O&M (\$/MWH)	3.33
	K FACTOR	1.6926

<sup>1</sup> BASED ON IN-SERVICE YEAR.



## SCHEDULE 9

(Page 15 of 15)

### STATUS REPORT AND SPECIFICATIONS OF PROPOSED GENERATING FACILITIES UTILITY: TAMPA ELECTRIC COMPANY

(1)	PLANT NAME AND UNIT NUMBER	FUTURE CT 12
(2)	CAPACITY	
	A. SUMMER	88
	B. WINTER	97
(3)	TECHNOLOGY TYPE	COMBUSTION TURBINE
(4)	ANTICIPATED CONSTRUCTION TIMING	
	A. FIELD CONSTRUCTION START DATE	JAN 2014
	B. COMMERCIAL IN-SERVICE DATE	MAY 2015
(5)	FUEL	
	A. PRIMARY FUEL	NATURAL GAS
	B. ALTERNATE FUEL	UNDETERMINED
(6)	AIR POLLUTION CONTROL STRATEGY	DRY LOW NO <sub>x</sub> BURNER
(7)	COOLING METHOD	N/A
(8)	TOTAL SITE AREA	UNDETERMINED
(9)	CONSTRUCTION STATUS	PROPOSED
(10)	CERTIFICATION STATUS	UNDETERMINED
(11)	STATUS WITH FEDERAL AGENCIES	N/A
(12)	PROJECTED UNIT PERFORMANCE DATA	
	PLANNED OUTAGE FACTOR (POF)	1.1
	FORCED OUTAGE RATE (FOR)	1.0
	EQUIVALENT AVAILABILITY FACTOR (EAF)	96.9
	RESULTING CAPACITY FACTOR (2015)	3.3%
	AVERAGE NET OPERATING HEAT RATE (ANOHR) <sup>1</sup>	8,200 Btu/kWh
(13)	PROJECTED UNIT FINANCIAL DATA	
	BOOK LIFE (YEARS)	26
	TOTAL INSTALLED COST (IN-SERVICE YEAR \$/kW)	597.22
	DIRECT CONSTRUCTION COST (\$/kW)	471.68
	AFUDC AMOUNT (\$/kW)	26.88
	ESCALATION (\$/kW)	98.66
	FIXED O&M (\$/kW - Yr)	4.54
	VARIABLE O&M (\$/MWH)	3.33
	K FACTOR	1.6926

<sup>1</sup> BASED ON IN-SERVICE YEAR.

## Schedule 10

### Status Report and Specifications of Proposed Directly Associated Transmission Lines

Point of Origin and Termination	Number of Circuits	Right-of-Way	Circuit Length	Voltage	Anticipated In-Service Date	Anticipated Capital Investment	Substations	Participation with Other Utilities
Gannon/SR 60	1	No new ROW required	2.3 mi	230 kV	Fall 2007	\$2.7 million	No new substations	None
Pebbledale to Willow Oak	1	Possible road ROW required	12.0 mi	230 kV	Summer 2009	\$16 million	New 230/69 kV Substation at Willow Oak	None
Wheeler/Davis	1	No new right of way required	13.0 mi	230 kV	Summer 2010	\$13 million	Davis - new 230 kV switching station & 230/69 kV transformer at Wheeler	None
Gannon/11 <sup>th</sup> Ave	1	No new right of way required	5.3 mi	230 kV	Fall 2010	\$6 million	11 <sup>th</sup> Avenue – complete 230 kV ring bus	None
Willow Oak to Wheeler Road	1	Possible road ROW required	20.0 mi	230 kV	Summer 2011	\$18 million	Wheeler Road – complete 230 kV Ring Bus	None
Davis to Chapman	1	No new right of way required	8.4 mi	230 kV	Summer 2011	\$1.0 million	No new substations	None
Polk to Hardee (2)	1	No new right of way required	9.4 mi	230 kV	Summer 2012	\$7.1 million	No new substations	SEC
Davis/Chapman/ Dale Mabry	1	No new right of way required	14.0 mi	230 kV	Summer 2012	\$18 million	Chapman – complete 230 kV ring bus	None

**THIS PAGE LEFT INTENTIONALLY BLANK.**

## CHAPTER V

### OTHER PLANNING ASSUMPTIONS AND INFORMATION

#### Transmission Constraints and Impacts

Based on an assessment of the Tampa Electric transmission system using year 2005 Florida Reliability Coordinating Council (FRCC) databank models, no transmission constraints exist, that violate the criteria stated in the Generation and Transmission Reliability Criteria section of this document.

#### Expansion Plan Economics and Fuel Forecast

The overall economics and cost-effectiveness of the plan were analyzed using Tampa Electric's Integrated Resource Planning process. As part of this process, Tampa Electric evaluated various planning and operating alternatives to current operations, with objectives including meeting compliance requirements in the most cost-effective and reliable manner, maximizing operational flexibility and minimizing total costs.

Early in the study process, many alternatives were screened on a qualitative and quantitative basis to determine those alternatives that were the most feasible overall. Those alternatives that failed to meet the qualitative and quantitative considerations were eliminated. This phase of the study resulted in a set of feasible alternatives that were considered in a more detailed economic analysis.

Fuel commodity price forecasting for base, high and low forecasts is done by careful analysis of historical, and current prices combined with and price forecasts obtained from various consultants and agencies. These sources include the Energy Information Administration, Hill & Associates, PIRA Energy Group, Coal Daily, and oil, natural gas, and propane pricing publications and periodicals which include: *Inside FERC* and *Platt's Oilgram*. Additionally, NYMEX forward pricing curves are utilized in conjunction with the forecasted data to derive forecast pricing.

High and low fuel price projections represent alternative forecasts to the company's base case outlook. The high and low price projections are defined by natural gas and oil prices varying 35% above or below the base case. The high and low price projections represent a reasonable level of uncertainty for the oil and gas prices used in the base forecast.

Only base case forecasts are prepared for coal fuels because of the fuels' relatively low price volatility. Base case analysis and forecasts include a large number of coal sources and diverse qualities. The individual price forecasts contained within the base forecast capture the market pressures and sensitivities that would otherwise be reflected in high and low case scenarios.

## **Generating Unit Performance Assumptions**

Tampa Electric's generating unit performance assumptions are used to evaluate long-range system operating costs associated with particular generation expansion plans. Generating units are characterized by several different performance parameters. These parameters include capacity, heat rate, unit derations, planned maintenance weeks, and unplanned outage rates. The unit performance projections are based on historical data trends, engineering judgement, time since last planned outage, and recent equipment performance. The first five years of planned outages are based on a forecasted outage schedule, and the planned outages for the balance of the years are based on an average of the first five years.

The five-year forecasted outage schedule is based on unit-specific maintenance needs, material lead-time, labor availability, and the need to supply our customers with power in the most economical manner. Unplanned outage rate projections are based on an average of three years of historical data adjusted, if necessary, to account for current unit conditions.

## **Financial Assumptions**

Tampa Electric makes numerous financial assumptions as part of the preparation for its Ten-Year Site Plan process. These assumptions are based on the current financial status of the company, the market for securities, and the best available forecast of future conditions. The primary financial assumptions include the FPSC-approved Allowance for Funds Used During Construction (AFUDC) rate, capitalization ratios, financing cost rates, tax rates, and FPSC-approved depreciation rates.

- Per the Florida Administrative Code, an amount for AFUDC is recorded by the company during the construction phase of each capital project. This rate is set by the FPSC and represents the cost of money invested in the applicable project while it is under construction. This cost is capitalized, becomes part of the project investment, and is recovered over the life of the asset. The AFUDC rate assumed in the Ten-Year Site Plan represents the company's currently approved AFUDC rate.
- The capitalization ratios represent the percentages of incremental long-term capital that are expected to be issued to finance the capital projects identified in the Ten-Year Site Plan.
- The financing cost rates reflect the incremental cost of capital associated with each of the sources of long-term financing.
- Tax rates include federal income tax, state income tax, and miscellaneous taxes including property tax.

- Depreciation represents the annual cost to amortize the total original investment in a plant over its useful life less net salvage value. This provides for the recovery of plant investment. The assumed book life for each capital project within the Ten-Year Site Plan represents the average expected life for that type of investment.

### **Integrated Resource Planning Process**

Tampa Electric's Integrated Resource Planning process was designed to evaluate demand side and supply side resources on a fair and consistent basis to satisfy future energy requirements in a cost-effective and reliable manner, while considering the interests of utility customers and shareholders.

The process incorporates a reliability analysis to determine timing of future needs and an economic analysis to determine what resource alternatives best meet future system demand and energy requirements. Initially, a demand and energy forecast, which excludes incremental DSM programs, is developed. Then a supply plan based on the system requirements, which excludes incremental DSM, is developed. This interim supply plan becomes the basis for potential avoided unit(s) in a comprehensive cost-effective analysis of the DSM programs. Once the cost-effective DSM programs are determined, the system demand and energy requirements are revised to include the effects of these programs on reducing system peak and energy requirements. The process is repeated to incorporate the incremental DSM programs and supply side resources.

The cost-effectiveness of DSM programs is based on the following standard Commission tests: the Rate Impact Measure (RIM), the Total Resource Cost (TRC), and the Participants Tests. Using the FPSC's standard cost-effectiveness methodology, each measure is evaluated based on different marketing and incentive assumptions. Utility plant avoidance assumptions for generation, transmission, and distribution are used in this analysis. All measures that pass the RIM, TRC, and Participants Tests in the DSM analysis are considered for utility program adoption. Each adopted measure is quantified into annual kW/kWh savings and is reflected in the demand and energy forecast. Measures with the highest RIM values are generally adopted first. Tampa Electric evaluates DSM measures using a spreadsheet that comports with Rule 25-17.008, F.A.C., and the FPSC's prescribed cost-effectiveness methodology.

Generating resources to be considered are determined through an alternative technology screening analysis, which is designed to determine the economic viability of a wide range of generating technologies for the Tampa Electric service area.

The technologies that pass the screening are included in a supply side analysis, which examines various supply side alternatives for meeting future capacity requirements.

Tampa Electric uses the PROVIEW module of STRATEGIST, a computer model developed by New Energy Associates, to evaluate the supply side resources. PROVIEW uses a dynamic programming approach to develop an estimate of the timing and type of capacity additions which would most economically meet the system demand and energy requirements. Dynamic programming compares all feasible combinations of generating unit additions, which satisfy the specified reliability criteria, and determines the schedule of additions that have the lowest revenue requirements. The model uses production costing analysis and incremental capital and O&M expenses to project the revenue requirements and rank each plan.

A detailed cost analysis for each of the top ranked resource plans is performed using the PROMOD economic dispatch model in conjunction with an incremental capital revenue requirement calculation. The capital expenditures associated with each capacity addition are obtained based on the type of generating unit, fuel type, capital spending curve, and in-service year. The fixed charges resulting from the capital expenditures are expressed in present worth dollars for comparison. The fuel and the operating and maintenance costs associated with each scenario are projected based on economic dispatch of all the energy resources on our system. The projected operating expense, expressed in present worth dollars, is combined with the fixed charges to obtain the total present worth of revenue requirements for each alternative plan.

## **Strategic Concerns**

Strategic concerns affect the type, capacity, and/or timing of future generation resource requirements. Concerns such as competitive pressures, environmental legislation, and plan acceptance are not easily quantified. These strategic concerns are considered within the Integrated Resource Planning process to ensure that an economically viable expansion plan is selected which has the flexibility for the company to respond to future technological and economic changes. The resulting expansion plan may include self-build generation, market purchase options or other viable supply and demand-side alternatives.

In the 2006 planning process, Tampa Electric determined that it has a need for capacity in the summer of 2006 through 2012 and the winter of 2006 through 2011 over and above its identified capacity additions. To address these requirements, the company entered into a firm purchase power agreement with Progress Energy Florida for 50 MW from January 2006 through March of 2007 and Calpine Energy Services for 170 MW from May 2006 through April 2011. The winter of 2008 capacity need of 230 MW is driven by the planned outage required for the Big Bend unit 3 Selective Catalytic Reduction (SCR) system installations. The SCR project will require one unit each year from Big Bend be taken out of service. The SCR project outages will be January through mid April from 2007 through 2010. In order to complete the Selective Catalytic Reduction system installations (SCR) by the required Consent Decree (CD) dates.

As the scheduled SCR outages and scheduled construction start dates of new units for those outages approaches, TEC will continue to look for competitive purchase power agreements that may replace or delay the scheduled new units. Such alternatives would be considered if better suited to the overall objective of providing reliable power in the most cost effective manner.



## Generation and Transmission Reliability Criteria

### Generation

Tampa Electric currently uses two criteria to measure the reliability of its generating system. The company utilizes a 20% reserve margin criteria and a 7% minimum summer supply side reserve margin criteria. Tampa Electric's approach to calculating percent reserves are consistent with that outlined in the settlement agreement. The calculation of the minimum 20% reserve margin employs an industry accepted method of using total available generating and firm purchased power capacity (capacity less planned maintenance and contracted unit sales) and subtracting the annual firm peak load, then dividing by the firm peak load, and multiplying by 100%. Since the reserve margin calculation assumes no forced outages, Tampa Electric includes the purchase power contract with Invenergy for the Hardee Power Station in its available capacity. Contractually, Hardee Power Station is planned to be available to Tampa Electric at the time of system peak. Also, the capacity dedicated to any firm unit or station power sales at the time of system peak is subtracted from Tampa Electric's available capacity.

Tampa Electric's summer supply-side reserve margin is calculated by dividing the difference of projected supply-side resources and projected total peak demand by the forecasted firm peak demand. The total peak demand includes the summer firm peak demand, and interruptible and load management loads.

### Transmission

The following criteria are used as guidelines for proposing system expansion and/or improvement projects. A detailed engineering study must be performed prior to making a prudent decision to initiate a project.

Tampa Electric Company complies with the planning criteria contained in the FRCC Standards Handbook and the North American Electric Reliability Council (NERC) Standards. In addition, Tampa Electric's specific criteria for normal system operation and single contingency operation are applied as follows:

### Generation Dispatch Modeled

The generation dispatched in the planning models is dictated on an economic basis and is calculated by the Economic Dispatch (ECDI) function of the PSS/E loadflow software. The ECDI function schedules the unit dispatch so that the total generation cost required to meet the projected load is minimized. This is the generation scenario contained in the power flow cases submitted to fulfill the requirements of FERC Form 715 and the Florida Reliability Coordinating Council (FRCC).

Since varying load levels and unplanned and planned unit outages can result in a system dispatch that varies significantly from a base plan, bulk transmission planners also investigate several scenarios that may stress Tampa Electric's transmission system. These additional generation sensitivities are analyzed to ensure the integrity of the bulk transmission system under maximized bulk power flows.

### Transmission System Planning Loading Limits Criteria

Tampa Electric follows the FRCC planning criteria as contained in of the FRCC Standards Handbook and NERC Standards. In addition to FRCC criteria, Tampa Electric utilizes company-specific planning criteria.

The following table summarizes the thresholds, which alert planners to problematic transmission lines and transformers.

<b>Transmission System Loading Limits</b>	
<b>Transmission System Conditions</b>	<b>Maximum Acceptable Loading Limit for Transformers and Transmission Lines</b>
All elements in service	100%
Single Contingency (pre-switching)	115%
Single Contingency (post-switching)	100%
Bus Outages (pre-switching)	115%
Bus Outages (post-switching)	100%

The transmission system is planned to allow voltage control on the 13.2 kV distribution buses between 1.023 and 1.043 per unit. For screening purposes, this criterion can be approximated by the following transmission system voltage limits.

<b>Transmission System Voltage Limits</b>			
<b>Transmission System Conditions</b>	<b>Industrial Substation Buses at point-of-service</b>	<b>69 kV Buses</b>	<b>138 kV and 230 kV Buses</b>
Single Contingency (pre-switching)	0.925 - 1.050 p.u.	0.925 - 1.050 p.u.	0.950 - 1.060 p.u.
Single Contingency (post-switching)	0.925 - 1.050 p.u.	0.925 - 1.050 p.u.	0.950 - 1.060 p.u.
Bus Outages	0.925 - 1.050 p.u.	0.925 - 1.050 p.u.	0.950 - 1.060 p.u.

### **Available Transmission Transfer Capability (ATC) Criteria**

Tampa Electric Company complies with the FRCC ATC calculation methodology as well as the principles contained in the NERC Standards relating to ATC.

### **Transmission Planning Assessment Practices**

#### **Base Case Operating Conditions**

The Transmission Planning department ensures that the Tampa Electric Company transmission system can support peak and off-peak system load levels without violation of the loading and voltage criteria stated in the Generation and Transmission Reliability Criteria section of this document.

#### **Single Contingency Planning Criteria**

The Tampa Electric Company transmission system is designed such that any single branch (transmission line or autotransformer) can be removed from service up to the forecasted peak load level without any violations of the criteria stated in the Generation and Transmission Reliability Criteria section of this document.

**Multiple Contingency Planning Criteria**

Double contingencies involving two branches out of service simultaneously are analyzed at 70% and 100% of peak load level. The Tampa Electric Company transmission system is designed such that these double contingencies do not cause violation of FRCC criteria.

**First Contingency Total Transfer Capability Considerations**

The following First Contingency Total Transfer Capability (FCTTC) limits for Tampa Electric Company's multiple-circuit corridors must be observed:

<b>Tie Line Corridor</b>	<b>FCTTC</b>
Lake Tarpon - Sheldon Rd. 230 kV (FPC)	1,100 MVA
Big Bend - Manatee 230 kV (FPL)	1,700 MVA

**Transmission Construction and Upgrade Plans**

A detailed list of the construction projects can be found in Chapter IV, Schedule 10. This list represents the latest transmission expansion plan available. However, due to the timing of this document in relationship to our internal planning schedule, this plan may change in the near future.

**Supply Side Resources Procurement Process**

Tampa Electric will manage the procurement process in accordance with established policies and procedures. Prospective suppliers of supply side resources as well as suppliers of equipment and services will be identified using various data base resources and competitive bid evaluations, and will be used in developing award recommendations to management.

This process will allow for future supply side resources to be supplied from self-build, purchase power, or competitively bid third parties. Consistent with company practice, bidders will be encouraged to propose incentive arrangements that promote development and implementation of cost savings and process improvement recommendations.

### **DSM Energy Savings Durability**

Tampa Electric verifies the durability of energy savings from its conservation and load management programs by several methods. First, Tampa Electric has established a monitoring and evaluation process where historical analysis validates the energy savings. These include:

- (1) periodic system load reduction analyses for residential load management (Prime Time) to confirm the accuracy of Tampa Electric's load reduction estimation formulas;
- (2) billing analysis of various program participants compared to control groups to minimize the impact of weather abnormalities;
- (3) periodic DOE2 modeling of various program participants to evaluate savings achieved in residential programs involving building components;
- (4) end-use sampling of building segments to validate savings achieved in Conservation Value and Commercial Indoor Lighting programs; and
- (5) in commercial programs such as Standby Generator and Commercial Load Management, the reductions are verified through metering of loads under control to determine the demand and energy savings.

Second, the programs are designed to promote the use of high-efficiency equipment having permanent installation characteristics. Specifically, those programs that promote the installation of energy efficient measures or equipment (heat pumps, hard-wired lighting fixtures, ceiling insulation, air distribution system repairs, DX commercial cooling units) have program standards that require the new equipment to be installed in a permanent manner thus insuring their durability.

### **Tampa Electric's Renewable Energy Program**


The renewable generation mix consists of an 18 kW photovoltaic array installed at the Museum of Science and Industry (MOSI) as well as a 4 kW photovoltaic array installed at a local middle school in partnership with the School District of Hillsborough County. Additionally, TEC utilizes a 30 kW Capstone micro turbine that operates on methane at a Hillsborough County landfill.

## CHAPTER VI

### ENVIRONMENTAL AND LAND USE INFORMATION

The future generating capacity additions identified in Chapter IV could occur at H.L. Culbreath Bayside Power station, Polk Power Station, or Big Bend Power Station. The H.L. Culbreath Bayside Power Station site is located in Hillsborough County on Port Sutton Road (See Figure VI-1), Polk Power station site is located in southwest Polk County close to the Hillsborough and Hardee County lines (See Figure VI-2) and Big Bend Power Station is located in Hillsborough County on Big Bend Road (See Figure VI-3). All facilities are currently permitted as existing power plant sites. Additional land use requirements and/or alternative site locations are not currently under consideration.


Figure VI-1



F.J. GANNON / BAYSIDE LOCATION MAP

SOURCE: USGS QUAD, TAMPA, FL 1981

Figure VI-2



TAMPA ELECTRIC COMPANY  
TEN-YEAR SITE PLAN  
FOR ELECTRICAL GENERATING FACILITIES  
AND ASSOCIATED TRANSMISSION LINES

FILE NAME 40-0020.DWG  
REVISION 3-9-2000.MMS

SITE LOCATION OF POLK POWER STATION

SOURCES: FDOT MAP, FLA, ECT



Figure VI-3

