

21 West Church Street
Jacksonville, Florida 32202-3139



March 30, 2006

ELECTRIC

WATER

SEWER

Michael S. Haff
Bureau of Electric Reliability/Conservation
Public Service Commission
Capital Circle Office Center
2540 Shumard Oak Boulevard
Tallahassee, Florida 32399-0850

Dear Mr. Haff:

Attached you will find 25 copies of JEA's 2006 Ten Year Site Plan filing. If you have any questions regarding this response or any additional questions, please contact me at (904) 665-7109 or Mary Guyton-Baker at (904) 665-6216.

Thank You,

A handwritten signature in black ink that reads 'Don Gilbert'.

Don Gilbert,
Manager, Electric System Planning

DOCUMENT NUMBER-DATE

03145 APR-7 06

FPSC-COMMISSION CLERK

Ten Year Site Plan



Building Community®

April 2006

DOCUMENT NUMBER-DATE

03145 APR-7g

FPSC-COMMISSION CLERK

Table of Contents

| | |
|---|-----------|
| 1.0 Introduction | 1 |
| 2.0 Existing Facilities | 2 |
| 2.1 Power Supply | 2 |
| 2.2 Transmission | 5 |
| 2.3 Demand Side Management..... | 6 |
| 2.4 Green/Clean Power Programs | 6 |
| 3.0 Fuel Price Forecast..... | 8 |
| 4.0 Load and Energy Forecast..... | 9 |
| 5.0 Facility Requirements..... | 10 |
| 5.1 Future Resource Needs | 10 |
| 5.2 Taylor Energy Center (TEC) Coal-Fired Unit..... | 10 |
| 5.3 Resource Plan..... | 11 |
| 6.0 Glossary..... | 12 |
| 6.1 List of Abbreviations | 12 |

APPENDIX A: Ten Year Site Plan Schedules

| | |
|--------------|--|
| Schedule 1 | Existing Generating Facilities |
| Schedule 2.1 | History and Forecast of Energy Consumption and Number of Customers by Class |
| Schedule 2.2 | History and Forecast of Energy Consumption and Number of Customers by Class |
| Schedule 3 | History and Forecast of Seasonal Peak Demand and Annual Net Energy For Load |
| Schedule 4 | Previous Year Actual and Two-Year Forecast of Peak Demand and Net Energy for Load by Month |
| Schedule 5 | Fuel Requirements |
| Schedule 6.1 | Energy Sources - GWH |
| Schedule 6.2 | Energy Sources - Percent |

| | |
|-------------|--|
| Schedule 7 | Forecast of Capacity, Demand, and Scheduled Maintenance at Time of Peak |
| Schedule 8 | Planned and Prospective Generating Facility Additions and Changes |
| Schedule 9 | Status Report and Specifications of Proposed Generating Facilities: Brandy Branch Combined Cycle |
| Schedule 10 | Status Report and Specifications of Proposed Directly Associated Transmission Lines |

List of Figures

| | |
|--|----|
| 5-1 Resource Needs After Committed Units | 10 |
| 5-2 Reference Plan | 11 |

1.0 Introduction

The objective of JEA's Ten-Year Site Plan is to develop an environmentally sound power supply strategy, which provides reliable electric service at the lowest practical cost. This report represents the 2006 Ten Year Site Plan for JEA covering a planning period from 2006 to 2015.

2.0 Existing Facilities

2.1 Power Supply

Electric System Summary

JEA's electric service area covers all of Duval County and portions of Clay and St. Johns Counties. JEA's service area covers approximately 900 square miles.

The generating capability of JEA's system currently consists of the Kennedy, Northside, and Brandy Branch generating stations, and joint ownership in St. Johns River Power Park and Scherer generating stations. The total net capability of JEA's generation system is 3,553 MW in the winter and 3,389 MW in the summer. Details of the existing facilities are displayed in TYSP Schedule 1.

JEA's transmission system consists of bulk power transmission facilities operating at 69 kV or higher. This includes all transmission lines and associated facilities where each transmission line ends at the substation's termination structure. JEA owns 728 circuit-miles of transmission lines at five voltage levels: 69kV, 138kV, 230kV, and 500kV. JEA's transmission system includes a 230 kV open loop surrounding JEA's service territory. JEA is currently interconnected with Florida Power & Light (FP&L), Seminole Electric Cooperative (SECI), Florida Public Utilities (FPU) and the City of Jacksonville Beach. Interconnections with FP&L are at 230 kV to the Sampson and Duval Substations. The interconnection to SECI is at 230 kV and the interconnection to FPU is at 138 kV

JEA and FP&L jointly own two 500 kV transmission lines that are interconnected with Georgia Integrated Transmission System. JEA, FP&L, Progress Energy and the City of Tallahassee each own transmission interconnections with Georgia Integrated Transmission System. JEA's ownership entitlement over these transmission lines is 1,228 out of 3,600 MW of import capability. JEA's system is interconnected with the 500 kV transmission lines at FPL's Duval Substation.

Jointly Owned Generating Units

The St. Johns River Power Park (SJRPP) is jointly owned by JEA (80 percent) and FP&L (20 percent). SJRPP consists of two nominal 638 MW bituminous coal fired units located north of the Northside Generating Station. Unit 1 began commercial operation in March of 1987 and Unit 2 followed in May of 1988. Both owners are entitled to 50 percent of the output of SJRPP. Since FP&L's ownership is only 20 percent, the remaining 30 percent of capacity and energy output is reflected as a firm sale from JEA. The two units have operated efficiently since commercial operation. To reduce fuel

costs and increase fuel diversity, a blend of petroleum coke and coal is currently being burned in the units.

JEA and FP&L have purchased an undivided interest in Georgia Power Company's Robert W. Scherer Unit 4. Unit 4 is a coal-fired generating unit with a net output of 846 MW located in Monroe County, Georgia. JEA purchased 150 megawatts of Scherer Unit 4 in July 1991 and purchased an additional 50 megawatts on June 1, 1995. Georgia Integrated Transmission System delivers the power from the unit to the jointly owned 500 kV transmission lines.

Purchased Power

Unit Power Sales

Southern Company and JEA entered a Unit Power Sales (UPS) contract in which JEA currently purchases 200 MW of firm capacity and energy from specific Southern Company coal units through May 31, 2010. JEA has the unilateral option, upon three years notice, to cancel 150 MW of the UPS. In this plan, JEA will retain 200 MW of UPS during the contract term and reduce available capacity by 200 MW at the end of the contract term beginning summer 2010.

The Energy Authority

The Energy Authority (TEA), actively trades energy with a large number of counterparties throughout the United States and is generally able to acquire capacity and energy from other market participants when any of TEA's members, including JEA, require additional resources.

TEA generally acquires the necessary short-term purchase for the season of need based on market conditions. TEA identifies a number of potential suppliers within Florida and Georgia. TEA has reserved firm transmission rights across the Georgia ITS to the Florida/Georgia border, therefore capacity from generating units located in Georgia should provide similar levels of reliability to capacity available within Florida. TEA, with input from JEA, selects the best offer. TEA then enters into back to back power purchase agreements with the supplier and with the purchaser, JEA.

TEA's ability to acquire capacity and/or energy and TEA's firm transmission rights across the Georgia ITS gives JEA a degree of assurance that a plan which includes short-term market purchases is viable. Since their inception, TEA has purchased capacity and energy on behalf of JEA for six seasonal periods. Of these six seasons, approximately 65% of the purchases were out of state resources and approximately

35% were Florida resources. In this Ten Year Site Plan, JEA identifies one seasonal need for capacity or energy during the winter 2012 of 70 MW.

Clean Power

As part of JEA's Green Works initiative, JEA has agreed to supply 7.5 percent of its peak demand with renewable resources by 2015. In 2004, JEA issued a Request for Proposal (RFP) for renewable resources. As a result of this RFP, JEA is in negotiation for 22 MW of renewable resources. These resources are included in JEA 2005 TYSP.

Also, JEA is continuing its contract negotiations with Biomass Industries Group, Inc. (BIG). JEA has contracted to purchase 120 MW firm renewable energy from a gasified biomass fueled electric generation plant proposed to be constructed by BIG in South Florida. The proposed facility is to be fueled by an energy crop (bamboo and E-grass) to be grown by BIG.

Cogeneration

JEA has encouraged and continues to monitor opportunities for cogeneration. Cogeneration facilities reduce the demand from JEA's system and/or provide additional capacity to the system. JEA purchases power from four customer-owned qualifying facilities (QF's), as defined in the Public Utilities Regulatory Policy Act of 1978, having a total installed summer peak capacity of 17 MW and winter peak capacity of 19 MW. JEA purchases energy from these QF's on as-available (non-firm) basis.

The following JEA customers have Qualifying Facilities located within JEA's service territory.

| Cogenerator Name | Unit Type | In-Service Date | Net Capability ³ – MW | |
|----------------------|------------------|-----------------|----------------------------------|-----------|
| | | | Summer | Winter |
| Anheiser Busch | COG ¹ | Apr-88 | 8 | 9 |
| Baptist Hospital | COG | Oct-82 | 7 | 8 |
| Ring Power Landfill | SPP ² | Apr-92 | 1 | 1 |
| St Vincents Hospital | COG | Dec-91 | 1 | 1 |
| Notes: | | | 17 | 19 |

1 Cogenerator

2 Small Power Producer

3 Net generating capability, not net generation sold to the JEA

Power Sales Agreements

Florida Public Utilities Company

JEA also furnishes wholesale power to Florida Public Utilities Company (FPU) for resale in the City of Fernandina Beach in Nassau County, north of Jacksonville. JEA is contractually committed to supply FPU until December 31, 2007. Currently, FPU does not have a contract with JEA to renew this sale. Therefore, starting January 2008, sales to FPU are not included in JEA's load and energy forecast. As of March 14, 2006, FPU has provided written interest to negotiate an extension or new contract with JEA. Sales to FPU in 2005 totaled 496 GWh (3.6 percent of JEA's total system energy requirements).

2.2 Transmission

JEA continues to monitor and upgrade the bulk power transmission system as necessary to provide reliable electric service to its customers. JEA continually reviews needs and options for increasing the capability of the transmission system. JEA has set forth the following planning criteria for the transmission system:

- Plan to limit the loading of transmission lines and autotransformers to provide safe and reliable transmission service under normal and single contingency conditions.
- Plan the transmission system to withstand single contingencies without loss of customer load. (A single contingency is the unexpected failure of any one line, transformer or generator.)
- Plan the transmission system to operate within 5 percent of nominal voltage during normal and single contingency conditions.
- Plan the transmission system so that circuit breakers can interrupt the maximum available breaker fault current.
- Plan substation relays to sense breaker failures and clear faults in sufficient time to avoid generator instability problems.
- Plan to provide lead time for transmission projects of approximately 3 to 5 years.
- Plan to meet the Florida Reliability Coordinating Council's (FRCC) guidelines on how the Florida electric utilities plan to operate. These guidelines are similar to JEA's transmission planning criteria discussed previously.

- Plan to meet or exceed the FRCC's reliability guidelines for transmission system interface Available Transfer Capabilities. This includes the use of single contingency criteria as well as considering the needs for operating reserve requirements, capacity benefit margins, and those reliability margins as outlined in industry-standard publications.
- Plan to meet or exceed specific subparts of those transmission system reliability-planning criteria published by the North American Electric Reliability Coordinating Council (NERC), including Planning Criteria Categories A, B, C.2 and C.5. Meet or exceed these criteria generally as they are interpreted by the Florida Reliability Coordinating Council, as updated from time to time.

2.3 Demand Side Management

In 2004, JEA studied numerous DSM measures, evaluated the measures using the Commission approved Florida Integrated Resource Evaluator (FIRE) model and developed goals and a plan based upon these results. The Rate-Impact Measure or RIM test was used to determine the cost-effectiveness of the DSM alternatives appropriate for a municipal utility. Some investor-owned utilities in the state also use the RIM test to determine cost-effective DSM alternatives.

None of the alternatives tested were found to be cost-effective for JEA. The inability to find cost-effective DSM measures was primarily due to the low cost of new generation, high efficiency of new generation, low interest rates, and low fuel price projections. In August 2004, the PSC approved JEA's Plan for zero DSM goals for 2005-2014.

JEA agreed to continue several DSM programs, including residential energy audits, commercial energy audits, and community conservation initiatives. With the rising costs of all fuel types, JEA continues to look for cost effective DSM measures.

2.4 Green/Clean Power Programs

In 2001 JEA developed a Green Power Program to encourage the widespread application of renewable energy technology in its service territory. JEA has established two Clean Power Capacity goals. The first, contained in JEA's internal Clean Power Strategic Initiative, calls for a minimum of 4% clean power capacity by 2007. The second, as stated in JEA's Memorandum of Understanding with the American Lung Association and Sierra Club, calls for a minimum of 7.5% clean power capacity by 2015.

As part of the Green Power Program, JEA implemented the solar incentive program in early 2002. Under the terms of the program, JEA provides cash incentives for

customers to install solar photovoltaic and solar thermal systems at their homes or business. As of January 2006, JEA has provided incentives to over 800 solar systems installed throughout the community resulting in 9 MWs towards our Clean Power Goals. JEA also owns approximately 223 kw of solar photovoltaic modules throughout the city of Jacksonville including systems at all high schools in the JEA service area and one of the largest photovoltaic systems in the southeast at the Jacksonville International Airport (50 KW).

Also, JEA owns and operates three internal combustion engine generators located at the Girvin Road Landfill. This facility was placed in service in July, 1997 and is fueled by gas produced by the landfill (the gas consists of approximately 52% methane and 48% carbon dioxide and nitrogen). The facility originally had four generators with an aggregate net capacity of 3.0 MW. Since that time, gas generation has declined and one generator has been removed and placed in service at the Buckman Wastewater Treatment facility. JEA also receives approximately 1500 kw of landfill gas from the North Landfill which is pumped to the Northside Generating Station and used to generate power in Unit 3. JEA will continue to monitor and evaluate these and other programs in order to determine the most cost-effective ways of encouraging customers to conserve energy.

In April 2004, JEA received 16 renewable energy proposals in response to a renewable energy RFP issued by JEA in February 2004. The proposals were reviewed for their technical and economic merit. Two proposals were selected for contract negotiations: development of a gas to energy project at the Trailridge Landfill in Baldwin, Florida and utilization of Jacksonville's yard waste as a biomass fuel in an existing Jacksonville boiler. The landfill project will provide a 9.6 MW facility that will utilize the landfill gas generated from the Trailridge Landfill and will recover gas that is currently being flared. When completed, this facility will be one of the largest landfill gas-to-energy projects in the Southeast. The biomass facility is located at a former paper mill in downtown Jacksonville. The existing boiler at the site proposes to burn yard and tree trimming debris from the City of Jacksonville's yard waste collection program. The fuel represents 13 MW of renewable energy. It is JEA's intent to establish long-term, purchased power agreements with these projects.

In 2005, JEA initiated a Green Home and Yard Coalition comprised of various community stakeholders throughout Northeast Florida. This coalition's focus is on promoting "green" building practices in home construction to improve the overall energy and water efficiency and health of the home. The initial goal of this group is to develop a green strategy for Northeast Florida home building.

3.0 Fuel Price Forecast

JEA's fuel price forecast is a major input in the development of JEA's future resource plan. JEA uses a diverse mix of fuels; the forecast includes coal, natural gas, residual fuel oil, diesel fuel, and petroleum coke.

A specific price forecasts for St John's River Power Park (SJRPP) was provided by SJRPP Fuels. Eastern and off-shore coals are the primary fuels burned at SJRPP. In addition, the SJRPP forecast is based on a 28 percent blend of petroleum coke and includes limestone and diesel fuel components. JEA developed its forecast of western coal for Scherer Unit 4 based on existing contracts and non-volatile escalation of spot prices.

The fuel price forecast for JEA's natural gas supply takes into account commodity and transportation components. For natural gas, the transportation portion is based on JEA's purchase of 40,000 mmBtu/day of firm transportation on the Florida Gas Transmission Company (FGT) system under rate schedule FTS-1 and 14,000 mmBtu/day under rate schedule FTS-2. In addition, JEA receives 20,000 mmBtu/day of delivered gas volumes from El Paso Municipal (EPM). The EPM volume will increase to 31,000 mmBtu/day effective June 2005 and to 61,000 mmBtu/day effective June 2006. The EPM volumes are currently supplied via the FGT system.

A blend of residual fuel oil and natural gas is burned in Northside Unit 3. The price forecast for residual fuel oil is based on the allowable sulfur level of 1.8 percent. Forecasts are also provided for high and low sulfur diesel fuel. The 1970's-vintage combustion turbine units at Kennedy and Northside Generating Stations are permitted to burn high sulfur diesel. The new combustion turbine units at Brandy Branch and Kennedy are permitted to burn low sulfur diesel as a backup to natural gas. For operational reasons, all Kennedy combustion turbine units currently burn low sulfur diesel fuel. The Brandy Branch facility use ultra low sulfur diesel as back up fuel.

Northside Units 1 and 2 have been repowered to operate on a blend of 80% petroleum coke and 20% coal. In addition, limestone is blended with the petroleum coke for SO₂ removal. The price forecast for petroleum coke includes limestone and is based on a conservative estimate of the long term petroleum coke market.

4.0 Load and Energy Forecast

JEA's winter and summer hourly net integrated system peak demand for 2005 were 2,794 MW and 2,891 MW respectively. JEA's net energy for load for calendar year 2005 was 13,696 GWH. For the ten year forecasted period, JEA's winter peak demand is expected to increase at an average 2.8 percent per year and the summer peak demand will increase at an average 2.0 percent per year. The net energy for load is forecasted to grow at an average rate of 2.2 percent per year for the ten year period.

JEA's base case forecast of peak demand and energy is based on a trend analysis of weather normalized historical data. JEA's trend analysis methodology has dramatically increased the accuracy of JEA's forecasts. Prior to implementing the trend analysis methodology in 1996, JEA's five-year average absolute error for its one-year-ahead sales forecast was 3.67%. Since implementing the trend analysis methodology JEA's most recent five-year average absolute error has been 0.46%. In addition to achieving this eight-fold improvement in forecast accuracy, JEA has also experienced a twelve-fold decrease in the cycle time to produce the forecast.

Effective January 2008, FPU's wholesale supply contract with JEA ends. At the current time, FPU does not have a contract with JEA to renew this sale. This will result in a decrease in demand and energy which is reflected on the base case forecast of Schedules 2 and 3.

5.0 Facility Requirements

5.1 Future Resource Needs

Based on the peak demand and energy forecasts, existing supply resources and contracts, and transmission considerations, JEA has evaluated future supply capacity needs for the electric system. Table 5-1 displays the likely need for capacity when assuming the base case load forecast for JEA's system for a ten-year period beginning in 2006.

5.2 Taylor Energy Center (TEC) Coal-Fired Unit

JEA in conjunction with FMPA, RCID, and the City of Tallahassee are looking at a possible coal plant at a site in Taylor County Florida. We have received alternative power supply proposals which are currently being evaluated. Decisions are forthcoming on accepting the alternative proposals, submitting the request for "need for power", and settling land purchase contracts. The anticipated in service date is scheduled for Summer 2012. For the purposes of this analysis, JEA has included this unit in its capacity mix beginning June 2012.

Table 5-1
Resource Needs After Committed Units
Forecast of Capacity and Demand at Time Of Peak
Winter

| Year | Installed Capacity MW | Firm Capacity | | QF MW | Available Capacity MW | Firm Peak Demand MW | Reserve Margin Before Maintenance | | Capacity Required For 15% Reserves MW |
|------|-----------------------|---------------|-----------|-------|-----------------------|---------------------|-----------------------------------|---------|---------------------------------------|
| | | Import MW | Export MW | | | | MW | Percent | |
| 2006 | 3,546 | 207 | 376 | 0 | 3,378 | 2,831 | 547 | 19% | 0 |
| 2007 | 3,586 | 207 | 376 | 0 | 3,417 | 2,924 | 493 | 17% | 0 |
| 2008 | 3,586 | 229 | 376 | 0 | 3,439 | 2,921 | 518 | 18% | 0 |
| 2009 | 3,523 | 229 | 376 | 0 | 3,376 | 3,015 | 361 | 12% | 91 |
| 2010 | 3,516 | 229 | 376 | 0 | 3,369 | 3,111 | 258 | 8% | 208 |
| 2011 | 3,516 | 22 | 376 | 0 | 3,162 | 3,207 | (45) | -1% | 526 |
| 2012 | 3,516 | 22 | 376 | 0 | 3,162 | 3,307 | (145) | -4% | 641 |
| 2013 | 3,516 | 22 | 376 | 0 | 3,162 | 3,407 | (245) | -7% | 756 |
| 2014 | 3,516 | 22 | 376 | 0 | 3,162 | 3,510 | (348) | -10% | 874 |
| 2015 | 3,516 | 22 | 376 | 0 | 3,162 | 3,614 | (452) | -12% | 994 |

Summer

| Year | Installed Capacity MW | Firm Capacity | | QF MW | Available Capacity MW | Firm Peak Demand MW | Reserve Margin Before Maintenance | | Capacity Required For 15% Reserves MW |
|------|-----------------------|---------------|-----------|-------|-----------------------|---------------------|-----------------------------------|---------|---------------------------------------|
| | | Import MW | Export MW | | | | MW | Percent | |
| 2006 | 3,424 | 207 | 383 | 0 | 3,248 | 2,651 | 597 | 23% | 0 |
| 2007 | 3,433 | 229 | 383 | 0 | 3,279 | 2,716 | 563 | 21% | 0 |
| 2008 | 3,433 | 229 | 383 | 0 | 3,279 | 2,698 | 581 | 22% | 0 |
| 2009 | 3,382 | 229 | 383 | 0 | 3,228 | 2,761 | 467 | 17% | 0 |
| 2010 | 3,375 | 22 | 383 | 0 | 3,014 | 2,824 | 190 | 7% | 234 |
| 2011 | 3,375 | 22 | 383 | 0 | 3,014 | 2,888 | 126 | 4% | 307 |
| 2012 | 3,375 | 22 | 383 | 0 | 3,014 | 2,950 | 64 | 2% | 379 |
| 2013 | 3,375 | 22 | 383 | 0 | 3,014 | 3,014 | (0) | 0% | 452 |
| 2014 | 3,375 | 22 | 383 | 0 | 3,014 | 3,078 | (64) | -2% | 526 |
| 2015 | 3,375 | 22 | 383 | 0 | 3,014 | 3,158 | (144) | -5% | 618 |

Committed Units:

1. 2006 Clean Power Purchases (22 MW).

5.3 Resource Plan

The analysis of JEA's electric system to determine the current plan included a review of existing electric supply resources, forecasts of customer energy requirements and peak demands, forecasts of fuel prices and availability, and an analysis of alternatives for resources to meet future capacity and energy needs.

Forecasts of system peak demand growth and energy consumption were utilized for the resource plan. A range of demand growth and energy consumption was reviewed, with the base case peak demand indicating a need for additional capacity to meet system reserve requirements beginning in the year 2009. This need encompasses the inclusion of existing supply resources and transmission system considerations.

In addition to cost considerations, environmental and land use considerations were factored into the resource plans. This ensured that the plans selected were socially and environmentally responsible and demonstrated JEA's total commitment to the community.

Based on modeling of the JEA system, forecast of demand and energy, forecast of fuel prices and availability, and environmental considerations, Table 5-2 presents the least-cost expansion plan which meets strategic goals. The expansion plan demonstrates strength with small variance in supply alternatives over the numerous sensitivities.

| Table 5-2 Reference Plan | | |
|-------------------------------------|------------------|---|
| Year | Season | Expansion Plan |
| 2006 | Winter | Brandy Branch Plant Peak Firing Upgrades (17.3 MW) Northside Units 1 & 2 LP Turbine Upgrades (18 MW) |
| 2007 | Winter | Purchase Clean Power (22 MW) Kennedy CT 7 Peak Firing Upgrades (4.1 MW) |
| 2008 | | |
| 2009 | Winter | Build 1 - 177 MW 7FA GT Kennedy CT 3 – Reserve Shutdown |
| 2010 | Winter | Build 1 - 177 MW 7FA GT |
| 2011 | Winter | Build 1 - 177 MW 7FA GT |
| 2012 | Winter Summer | Purchase 70 MW Seasonal from TEA Build TEC Pulverized Coal (236 MW) |
| 2013 | | |
| 2014 | Winter | Build 1-248 MW Greenfield CFB |
| 2015 | | |

6.0 Glossary

6.1 List of Abbreviations

Type of Generation Units

| | |
|----|--|
| CC | Combined Cycle |
| CT | Combined Cycle – Combustion Turbine Portion |
| CW | Combined Cycle – Steam Turbine Portion, Waste Heat Boiler (only) |
| GT | Combustion Turbine |
| FC | Fluidized Bed Combustion |
| IC | Internal Combustion |
| ST | Steam Turbine, Boiler, Non-Nuclear |

Status of Generation Units

| | |
|----|--|
| FC | Existing generator planned for conversion to another fuel or energy source |
| M | Generating unit put in deactivated shutdown status |
| P | Planned, not under construction |
| RT | Existing generator scheduled to be retired |
| RP | Proposed for repowering or life extension |
| TS | Construction complete, not yet in commercial operation |
| U | Under construction, less than 50% complete |
| V | Under construction, more than 50% complete |

Types of Fuel

| | |
|-----|---------------------|
| BIT | Bituminous Coal |
| FO2 | No. 2 Fuel Oil |
| FO6 | No. 6 Fuel Oil |
| MTE | Methane |
| NG | Natural Gas |
| SUB | Sub-bituminous Coal |
| PC | Petroleum Coke |

Fuel Transportation Methods

| | |
|----|----------|
| PL | Pipeline |
| RR | Railroad |
| TK | Truck |
| WA | Water |

Appendix A
Ten-Year Site Plan
Schedules

Ten-Year Site Plan Schedules

The following Appendix presents the schedules required by the Florida Public Service Commission to be included as part of the Ten-Year Site Plan.

**Schedule 1
Existing Generating Facilities
As of January 1, 2006**

| (1) | (2) | (3) | (4) | (5) | (6) | (7) | (8) | (9) | (10) | (11) | (12) | (13) | (14) | (15) |
|----------------------------|-------------|----------|-----------|-----------|------|----------------|------|-----------------------------|---------------------------|----------------------|-------------------|--------------|-----------|--------|
| Plant Name | Unit Number | Location | Unit Type | Fuel Type | | Fuel Transport | | Commercial In-Service Mo/Yr | Expected Retirement Mo/Yr | Gen Max Nameplate kW | Net MW Capability | | Ownership | Status |
| | | | | Primary | Alt. | Primary | Alt. | | | | Summer | Winter | | |
| Kennedy | | | | | | | | | | <u>372,400</u> | <u>210</u> | <u>254</u> | | |
| | 3 | 12-031 | GT | FO2 | | WA | TK | 7/1973 | (a) | 168,600 | 51 | 63 | Utility | |
| | 4 | 12-031 | GT | FO2 | | WA | TK | 7/1973 | | 168,600 | 51 | 63 | Utility | (b) |
| | 5 | 12-031 | GT | FO2 | | WA | TK | 7/1973 | | 168,600 | 51 | 63 | Utility | (b) |
| | 7 | 12-031 | GT | NG | FO2 | PL | WA | 6/2000 | | 203,800 | 159 | 191 | Utility | |
| Northside | | | | | | | | | | <u>1,158,700</u> | <u>1,285</u> | <u>1,319</u> | | |
| | 1 | 12-031 | ST | PC | BIT | WA | RR | 2003 | (a) | 297,500 | 275 | 275 | Utility | |
| | 2 | 12-031 | ST | PC | BIT | WA | RR | 2002 | (a) | 297,500 | 275 | 275 | Utility | |
| | 3 | 12-031 | ST | NG | FO6 | PL | WA | 7/1977 | (a) | 563,700 | 523 | 523 | Utility | |
| | 3-6 | 12-031 | GT | FO2 | | WA | TK | 1/1975 | (a) | 248,400 | 212 | 246 | Utility | |
| Brandy Branch | | | | | | | | | | <u>676,000</u> | <u>691</u> | <u>759</u> | | |
| | 1 | | GT | NG | FO2 | PL | TK | 5/2001 | (a) | 203,800 | 159 | 191 | Utility | |
| | 2 | | CT | NG | FO2 | PL | TK | 5/2001 | (a) | 203,800 | 159 | 191 | Utility | |
| | 3 | | CT | NG | FO2 | PL | TK | 5/2001 | (a) | 203,800 | 159 | 191 | Utility | |
| | 4 | | CC | NG | FO2 | PL | TK | 1/2005 | (a) | 268,400 | 215 | 185 | Utility | |
| Girvin Landfill | 1-4 | 12-301 | IC | NG | | PL | | 6/1997 | (a) | 1.2 | 1.2 | 1.2 | Utility | |
| St. Johns River Power Park | | | | | | | | | | <u>1,359,200</u> | <u>1,002</u> | <u>1,020</u> | | |
| | 1 | 12-301 | ST | BIT/PC | | RR | WA | 3/1987 | 3/2027 | 679,600 | 501 | 510 | Joint | (c) |
| | 2 | 12-301 | ST | BIT/PC | | RR | WA | 5/1988 | 5/2028 | 679,600 | 501 | 510 | Joint | (c) |
| Scherer | 4 | 13-207 | ST | SUB | BIT | RR | RR | 2/1989 | 2/2029 | 846,000 | 200 | 200 | Joint | (d) |
| JEA System Total | | | | | | | | | | | 3,389 | 3,553 | | |

NOTE:

- (a) Units expected to be maintained throughout the study period.
- (b) Placed in Reserve Shutdown 4/15/05.
- (c) Net capability reflects the JEA's 80% ownership of Power Park. Nameplate is original nameplate of the unit.
- (d) Nameplate and net capability reflects the JEA's 23.64% ownership in Scherer 4.
- (e) Numbers may not add due to rounding.

Schedule 2.1
History And Forecast of Energy Consumption
and Number of Customers By Class

| (1) | (2) | (3) | (4) | (5) | (6) | (7) | (8) | (9) | (10) |
|---------------|----------------------|--------------------------|-----------------------|------------|--------------------------|-----------------------|------------|--------------------------|-----------------------|
| Calendar Year | Rual and Residential | | | Commercial | | | Industrial | | |
| | GWH Sales | Average No. of Customers | Average kWh/ Customer | GWH Sales | Average No. of Customers | Average kWh/ Customer | GWH Sales | Average No. of Customers | Average kWh/ Customer |
| 1994 | 3,909 | 278,682 | 14,027 | 897 | 29,571 | 30,334 | 4,048 | 2,731 | 1,482,241 |
| 1995 | 4,137 | 283,551 | 14,590 | 937 | 29,972 | 31,263 | 4,174 | 2,742 | 1,522,247 |
| 1996 | 4,391 | 288,947 | 15,197 | 937 | 30,162 | 31,066 | 4,353 | 2,975 | 1,463,193 |
| 1997 | 4,165 | 295,916 | 14,075 | 949 | 30,709 | 30,903 | 4,526 | 3,025 | 1,496,198 |
| 1998 | 4,643 | 301,883 | 15,380 | 1,035 | 31,297 | 33,070 | 4,835 | 3,094 | 1,562,702 |
| 1999 | 4,529 | 305,917 | 14,805 | 1,036 | 31,873 | 32,504 | 5,130 | 3,203 | 1,601,623 |
| 2000 | 4,701 | 312,103 | 15,062 | 1,079 | 32,351 | 33,353 | 5,205 | 3,309 | 1,572,983 |
| 2001 | 4,884 | 319,532 | 15,285 | 1,104 | 32,990 | 33,465 | 5,411 | 3,450 | 1,568,406 |
| 2002 | 5,108 | 326,362 | 15,651 | 1,157 | 33,841 | 34,189 | 5,479 | 3,475 | 1,576,691 |
| 2003 | 5,226 | 332,492 | 15,718 | 1,184 | 33,762 | 35,069 | 5,605 | 3,630 | 1,544,077 |
| 2004 | 5,400 | 348,320 | 15,503 | 1,185 | 32,123 | 36,889 | 5,396 | 3,638 | 1,483,233 |
| 2005 | 5,550 | 358,770 | 15,469 | 1,249 | 33,087 | 37,738 | 5,686 | 3,747 | 1,517,473 |
| 2006 | 5,716 | 369,533 | 15,468 | 1,286 | 34,080 | 37,735 | 5,857 | 3,859 | 1,517,751 |
| 2007 | 5,887 | 380,619 | 15,467 | 1,325 | 35,102 | 37,747 | 6,033 | 3,975 | 1,517,736 |
| 2008 | 6,064 | 392,038 | 15,468 | 1,365 | 36,155 | 37,754 | 6,214 | 4,094 | 1,517,831 |
| 2009 | 6,246 | 403,799 | 15,468 | 1,406 | 37,240 | 37,755 | 6,400 | 4,217 | 1,517,667 |
| 2010 | 6,433 | 415,913 | 15,467 | 1,448 | 38,357 | 37,751 | 6,592 | 4,344 | 1,517,495 |
| 2011 | 6,626 | 428,390 | 15,467 | 1,491 | 39,508 | 37,739 | 6,790 | 4,474 | 1,517,658 |
| 2012 | 6,825 | 441,242 | 15,468 | 1,536 | 40,693 | 37,746 | 6,994 | 4,608 | 1,517,795 |
| 2013 | 7,030 | 454,479 | 15,468 | 1,582 | 41,914 | 37,744 | 7,204 | 4,746 | 1,517,910 |
| 2014 | 7,241 | 468,113 | 15,468 | 1,629 | 43,171 | 37,734 | 7,420 | 4,888 | 1,518,003 |
| 2015 | 7,458 | 482,156 | 15,468 | 1,678 | 44,466 | 37,737 | 7,643 | 5,035 | 1,517,974 |

Schedule 2.2
History And Forecast of Energy Consumption
and Number of Customers By Class

| Calendar Year | (11) | (12) | (13) | (14) | (15) | (16) | (17) | (18) |
|---------------|-------------------------------|---------------------------------------|---------------------------------------|----------------------|--------------------------|-------------------------|-------------------------------|------------------------|
| | Street & Highway Lighting GWH | Other Sales to Ultimate Customers GWH | Total Sales to Ultimate Customers GWH | Sales For Resale GWH | Utility Use & Losses GWH | Net Energy For Load GWH | Other Customers (Average No.) | Total No. of Customers |
| 1994 | 63 | 0 | 8,917 | 304 | 388 | 9,609 | 19 | 311,003 |
| 1995 | 72 | 0 | 9,320 | 339 | 667 | 10,326 | 21 | 316,286 |
| 1996 | 70 | 0 | 9,751 | 363 | 401 | 10,515 | 21 | 322,105 |
| 1997 | 71 | 0 | 9,711 | 383 | 571 | 10,665 | 22 | 329,672 |
| 1998 | 77 | 0 | 10,590 | 438 | 442 | 11,470 | 21 | 336,295 |
| 1999 | 86 | 0 | 10,781 | 454 | 547 | 11,782 | 19 | 341,012 |
| 2000 | 120 | 0 | 11,105 | 482 | 603 | 12,190 | 19 | 347,782 |
| 2001 | 109 | 0 | 11,508 | 453 | 361 | 12,322 | 22 | 355,994 |
| 2002 | 112 | 0 | 11,856 | 446 | 681 | 12,983 | 20 | 363,698 |
| 2003 | 115 | 0 | 12,130 | 453 | 595 | 13,178 | 20 | 369,904 |
| 2004 | 76 | 0 | 12,057 | 468 | 718 | 13,243 | 27 | 384,108 |
| 2005 | 111 | 0 | 12,596 | 486 | 615 | 13,696 | 28 | 395,632 |
| 2006 | 115 | 0 | 12,974 | 500 | 691 | 14,165 | 29 | 407,501 |
| 2007 | 118 | 0 | 13,363 | 515 | 563 | 14,441 | 30 | 419,726 |
| 2008 | 122 | 0 | 13,765 | 0 | 767 | 14,532 | 31 | 432,318 |
| 2009 | 126 | 0 | 14,178 | 0 | 698 | 14,876 | 32 | 445,288 |
| 2010 | 130 | 0 | 14,603 | 0 | 655 | 15,258 | 33 | 458,647 |
| 2011 | 134 | 0 | 15,041 | 0 | 601 | 15,642 | 34 | 472,406 |
| 2012 | 138 | 0 | 15,493 | 0 | 574 | 16,067 | 35 | 486,578 |
| 2013 | 142 | 0 | 15,958 | 0 | 461 | 16,419 | 36 | 501,175 |
| 2014 | 146 | 0 | 16,436 | 0 | 374 | 16,810 | 37 | 516,209 |
| 2015 | 150 | 0 | 16,929 | 0 | 278 | 17,207 | 38 | 531,695 |

Schedule 3.1
History and Forecast of Summer Peak Demand
(MW)

| (1) | (2) | (3) | (4) | (5) | (6) | (7) | (8) | (9) | (10) | (11) | (12) | (13) |
|---------------|--------------|--------------------|-----------------|------------|---------------------------------|--------------------------|------------|----------------------|--------------|-------------|------------------------------------|------------|
| Calendar Year | Total Demand | Interruptible Load | Load Management | | QF Load Served By QF Generation | Incremental Conservation | | Net Firm Peak Demand | Time Of Peak | | Cumulative Conservation Since 1980 | |
| | | | Residential | Comm./Ind. | | Residential | Comm./Ind. | | Date | Hour Ending | Residential | Comm./Ind. |
| 1991 | 1,756 | 0 | 0 | 0 | 0 | 0 | 0 | 1,756 | 7/24/1991 | 1700 | 0 | 0 |
| 1992 | 1,881 | 0 | 0 | 0 | 0 | 0 | 0 | 1,881 | 7/9/1992 | 1700 | 0 | 0 |
| 1993 | 1,998 | 0 | 0 | 0 | 0 | 0 | 0 | 1,998 | 7/29/1993 | 1700 | 0 | 0 |
| 1994 | 1,918 | 0 | 0 | 0 | 0 | 0 | 0 | 1,918 | 7/18/1994 | 1700 | 0 | 0 |
| 1995 | 2,067 | 0 | 0 | 0 | 0 | 0 | 0 | 2,067 | 8/14/1995 | 1700 | 0 | 0 |
| 1996 | 2,114 | 0 | 0 | 0 | 0 | 0 | 0 | 2,114 | 6/25/1996 | 1800 | 0 | 0 |
| 1997 | 2,131 | 0 | 0 | 0 | 0 | 0 | 0 | 2,131 | 7/28/1997 | 1800 | 0 | 0 |
| 1998 | 2,338 | 0 | 0 | 0 | 0 | 0 | 0 | 2,338 | 7/1/1998 | 1800 | 0 | 0 |
| 1999 | 2,427 | 0 | 0 | 0 | 0 | 0 | 0 | 2,427 | 8/2/1999 | 1600 | 0 | 0 |
| 2000 | 2,380 | 0 | 0 | 0 | 0 | 0 | 0 | 2,380 | 7/20/2000 | 1400 | 0 | 0 |
| 2001 | 2,389 | 0 | 0 | 0 | 0 | 0 | 0 | 2,389 | 8/8/2001 | 1800 | 0 | 0 |
| 2002 | 2,530 | 0 | 0 | 0 | 0 | 0 | 0 | 2,530 | 7/19/2002 | 1600 | 0 | 0 |
| 2003 | 2,485 | 0 | 0 | 0 | 0 | 0 | 0 | 2,485 | 7/10/2003 | 1600 | 0 | 0 |
| 2004 | 2,539 | 0 | 0 | 0 | 0 | 0 | 0 | 2,539 | 8/2/2004 | 1600 | 0 | 0 |
| 2005 | 2,760 | 0 | 0 | 0 | 0 | 0 | 0 | 2,891 | 8/17/2006 | 1800 | 0 | 0 |
| 2006 | 2,826 | 175 | 0 | 0 | 0 | 0 | 0 | 2,651 | --- | --- | 0 | 0 |
| 2007 | 2,893 | 177 | 0 | 0 | 0 | 0 | 0 | 2,716 | --- | --- | 0 | 0 |
| 2008 | 2,878 | 180 | 0 | 0 | 0 | 0 | 0 | 2,698 | --- | --- | 0 | 0 |
| 2009 | 2,944 | 183 | 0 | 0 | 0 | 0 | 0 | 2,761 | --- | --- | 0 | 0 |
| 2010 | 3,009 | 185 | 0 | 0 | 0 | 0 | 0 | 2,824 | --- | --- | 0 | 0 |
| 2011 | 3,076 | 188 | 0 | 0 | 0 | 0 | 0 | 2,888 | --- | --- | 0 | 0 |
| 2012 | 3,141 | 191 | 0 | 0 | 0 | 0 | 0 | 2,950 | --- | --- | 0 | 0 |
| 2013 | 3,208 | 194 | 0 | 0 | 0 | 0 | 0 | 3,014 | --- | --- | 0 | 0 |
| 2014 | 3,275 | 197 | 0 | 0 | 0 | 0 | 0 | 3,078 | --- | --- | 0 | 0 |
| 2015 | 3,358 | 200 | 0 | 0 | 0 | 0 | 0 | 3,158 | --- | --- | 0 | 0 |

Schedule 3.2
History and Forecast of Winter Peak Demand
(MW)

| (1) | (2) | (3) | (4) | (5) | (6) | (7) | (8) | (9) | (10) | (11) | (12) | (13) |
|---------------|--------------|--------------------|-----------------|------------|---------------------------------|--------------------------|------------|----------------------|--------------|-------------|------------------------------------|------------|
| Calendar Year | Total Demand | Interruptible Load | Load Management | | QF Load Served By QF Generation | Incremental Conservation | | Net Firm Peak Demand | Time Of Peak | | Cumulative Conservation Since 1980 | |
| | | | Residential | Comm./Ind. | | Residential | Comm./ind. | | Date | Hour Ending | Residential | Comm./Ind. |
| 1991 | 1,725 | 0 | 0 | 0 | 0 | 0 | 0 | 1,725 | 2/16/1991 | 1000 | 0 | 0 |
| 1992 | 1,881 | 0 | 0 | 0 | 0 | 0 | 0 | 1,881 | 1/17/1992 | 800 | 0 | 0 |
| 1993 | 1,791 | 0 | 0 | 0 | 0 | 0 | 0 | 1,791 | 3/15/1993 | 0800 | 0 | 0 |
| 1994 | 1,942 | 0 | 0 | 0 | 0 | 0 | 0 | 1,942 | 2/3/1994 | 0800 | 0 | 0 |
| 1995 | 2,190 | 0 | 0 | 0 | 0 | 0 | 0 | 2,190 | 2/9/1995 | 0800 | 0 | 0 |
| 1996 | 2,401 | 0 | 0 | 0 | 0 | 0 | 0 | 2,401 | 2/5/1996 | 0800 | 0 | 0 |
| 1997 | 2,084 | 0 | 0 | 0 | 0 | 0 | 0 | 2,084 | 12/20/1996 | 0900 | 0 | 0 |
| 1998 | 1,975 | 0 | 0 | 0 | 0 | 0 | 0 | 1,975 | 12/15/1997 | 1900 | 0 | 0 |
| 1999 | 2,403 | 0 | 0 | 0 | 0 | 0 | 0 | 2,403 | 1/6/1999 | 0800 | 0 | 0 |
| 2000 | 2,478 | 0 | 0 | 0 | 0 | 0 | 0 | 2,478 | 1/27/2000 | 0800 | 0 | 0 |
| 2001 | 2,666 | 0 | 0 | 0 | 0 | 0 | 0 | 2,666 | 1/3/2001 | 0800 | 0 | 0 |
| 2002 | 2,607 | 0 | 0 | 0 | 0 | 0 | 0 | 2,607 | 1/4/2002 | 0800 | 0 | 0 |
| 2003 | 3,055 | 0 | 0 | 0 | 0 | 0 | 0 | 3,055 | 1/24/2003 | 0800 | 0 | 0 |
| 2004 | 2,668 | 0 | 0 | 0 | 0 | 0 | 0 | 2,668 | 1/29/2004 | 0700 | 0 | 0 |
| 2005 | 2,794 | 0 | 0 | 0 | 0 | 0 | 0 | 2,794 | 1/24/2005 | --- | 0 | 0 |
| 2006 | 2,919 | 0 | 0 | 0 | 0 | 0 | 0 | 2,919 | 2/14/2006 | --- | 0 | 0 |
| 2007 | 3,099 | 175 | 0 | 0 | 0 | 0 | 0 | 2,924 | --- | --- | 0 | 0 |
| 2008 | 3,099 | 178 | 0 | 0 | 0 | 0 | 0 | 2,921 | --- | --- | 0 | 0 |
| 2009 | 3,195 | 180 | 0 | 0 | 0 | 0 | 0 | 3,015 | --- | --- | 0 | 0 |
| 2010 | 3,294 | 183 | 0 | 0 | 0 | 0 | 0 | 3,111 | --- | --- | 0 | 0 |
| 2011 | 3,393 | 186 | 0 | 0 | 0 | 0 | 0 | 3,207 | --- | --- | 0 | 0 |
| 2012 | 3,496 | 189 | 0 | 0 | 0 | 0 | 0 | 3,307 | --- | --- | 0 | 0 |
| 2013 | 3,599 | 192 | 0 | 0 | 0 | 0 | 0 | 3,407 | --- | --- | 0 | 0 |
| 2014 | 3,704 | 194 | 0 | 0 | 0 | 0 | 0 | 3,510 | --- | --- | 0 | 0 |
| 2015 | 3,811 | 197 | 0 | 0 | 0 | 0 | 0 | 3,614 | --- | --- | 0 | 0 |

Schedule 3.3
History and Forecast of Annual Net Energy For Load
(GWH)

| (1) | (2) | (3) | (4) | (5) | (6) | (7) | (8) | (9) | (10) | (11) |
|---------------|-----------------------|--------------------|-----------------|------------|---------------------------------|--------------------------|------------|---------------------|------------------------------------|------------|
| Calendar Year | Total Energy For Load | Interruptible Load | Load Management | | QF Load Served By QF Generation | Incremental Conservation | | Net Energy For Load | Cumulative Conservation Since 1980 | |
| | | | Residential | Comm./Ind. | | Residential | Comm./ind. | | Residential | Comm./Ind. |
| 1991 | 8,835 | 0 | 0 | 0 | 0 | 0 | 0 | 8,835 | 0 | 0 |
| 1992 | 9,028 | 0 | 0 | 0 | 0 | 0 | 0 | 9,028 | 0 | 0 |
| 1993 | 9,609 | 0 | 0 | 0 | 0 | 0 | 0 | 9,609 | 0 | 0 |
| 1994 | 9,609 | 0 | 0 | 0 | 0 | 0 | 0 | 9,609 | 0 | 0 |
| 1995 | 10,326 | 0 | 0 | 0 | 0 | 0 | 0 | 10,326 | 0 | 0 |
| 1996 | 10,515 | 0 | 0 | 0 | 0 | 0 | 0 | 10,515 | 0 | 0 |
| 1997 | 10,665 | 0 | 0 | 0 | 0 | 0 | 0 | 10,665 | 0 | 0 |
| 1998 | 11,470 | 0 | 0 | 0 | 0 | 0 | 0 | 11,470 | 0 | 0 |
| 1999 | 11,782 | 0 | 0 | 0 | 0 | 0 | 0 | 11,782 | 0 | 0 |
| 2000 | 12,190 | 0 | 0 | 0 | 0 | 0 | 0 | 12,190 | 0 | 0 |
| 2001 | 12,322 | 0 | 0 | 0 | 0 | 0 | 0 | 12,322 | 0 | 0 |
| 2002 | 12,983 | 0 | 0 | 0 | 0 | 0 | 0 | 12,983 | 0 | 0 |
| 2003 | 13,204 | 0 | 0 | 0 | 0 | 0 | 0 | 13,204 | 0 | 0 |
| 2004 | 13,243 | 0 | 0 | 0 | 0 | 0 | 0 | 13,243 | 0 | 0 |
| 2005 | 13,696 | 0 | 0 | 0 | 0 | 0 | 0 | 13,696 | 0 | 0 |
| 2006 | 14,165 | 0 | 0 | 0 | 0 | 0 | 0 | 14,165 | 0 | 0 |
| 2007 | 14,441 | 0 | 0 | 0 | 0 | 0 | 0 | 14,441 | 0 | 0 |
| 2008 | 14,532 | 0 | 0 | 0 | 0 | 0 | 0 | 14,532 | 0 | 0 |
| 2009 | 14,876 | 0 | 0 | 0 | 0 | 0 | 0 | 14,876 | 0 | 0 |
| 2010 | 15,258 | 0 | 0 | 0 | 0 | 0 | 0 | 15,258 | 0 | 0 |
| 2011 | 15,642 | 0 | 0 | 0 | 0 | 0 | 0 | 15,642 | 0 | 0 |
| 2012 | 16,067 | 0 | 0 | 0 | 0 | 0 | 0 | 16,067 | 0 | 0 |
| 2013 | 16,419 | 0 | 0 | 0 | 0 | 0 | 0 | 16,419 | 0 | 0 |
| 2014 | 16,810 | 0 | 0 | 0 | 0 | 0 | 0 | 16,810 | 0 | 0 |
| 2015 | 17,207 | 0 | 0 | 0 | 0 | 0 | 0 | 17,207 | 0 | 0 |

Schedule 4
Previous Year Actual and Two Year Forecast of Peak Demand
And Net Energy For Load By Month
Base Case

| (1) | (2) | (3) | (4) | (5) | (6) | (7) |
|-----------|------------------|---------------------------|------------------|---------------------------|------------------|---------------------------|
| Month | Actual 2005 | | Forecast 2006 | | Forecast 2007 | |
| | Peak Demand (MW) | Net Energy For load (GWH) | Peak Demand (MW) | Net Energy For load (GWH) | Peak Demand (MW) | Net Energy For load (GWH) |
| January | 2,860 | 1,086 | 2,831 | 1,145 | 2,924 | 1,175 |
| February | 2,272 | 956 | 2,571 | 986 | 2,655 | 1,013 |
| March | 2,194 | 1,020 | 2,177 | 1,064 | 2,249 | 1,093 |
| April | 1,847 | 933 | 1,888 | 1,035 | 1,934 | 1,063 |
| May | 2,417 | 1,097 | 2,211 | 1,171 | 2,265 | 1,203 |
| June | 2,653 | 1,260 | 2,526 | 1,300 | 2,588 | 1,335 |
| July | 2,755 | 1,416 | 2,651 | 1,472 | 2,716 | 1,511 |
| August | 2,815 | 1,446 | 2,590 | 1,431 | 2,654 | 1,469 |
| September | 2,556 | 1,275 | 2,436 | 1,253 | 2,496 | 1,286 |
| October | 2,289 | 1,122 | 2,368 | 1,115 | 2,366 | 1,110 |
| November | 1,990 | 957 | 2,111 | 1,050 | 2,109 | 1,045 |
| December | 2,453 | 1,128 | 2,503 | 1,145 | 2,500 | 1,139 |
| Total | | 13,696 | | 14,165 | | 14,441 |

**Schedule 5
Fuel Requirements**

| | (1) | (2) | (3) | (4) | (5) | (6) | (7) | (8) | (9) | (10) | (11) | (12) | (13) | (14) |
|---|-----------------|--------|--------------|----------------|--------|--------|--------|--------|--------|--------|--------|--------|--------|--------|
| | Fuel | Type | Units | Actual 2005 | 2006 | 2007 | 2008 | 2009 | 2010 | 2011 | 2012 | 2013 | 2014 | 2015 |
| (1) | NUCLEAR | | TRILLION BTU | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| (2) | COAL | | 1000 TON | 2,567 | 2,021 | 2,947 | 2,966 | 3,026 | 3,069 | 3,208 | 2,943 | 3,053 | 2,772 | 2,815 |
| (3) | RESIDUAL | STEAM | 1000 BBL | 1,453 | 1,181 | 1,111 | 1,192 | 1,151 | 1,149 | 1,435 | 1,129 | 1,213 | 848 | 888 |
| (4) | | CC | 1000 BBL | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| (5) | | CT/GT | 1000 BBL | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| (6) | | TOTAL: | 1000 BBL | 1,453 | 1,181 | 1,111 | 1,192 | 1,151 | 1,149 | 1,435 | 1,129 | 1,213 | 848 | 888 |
| (7) | DISTILLATE | STEAM | 1000 BBL | 47 | 37 | 54 | 55 | 56 | 57 | 59 | 54 | 56 | 51 | 52 |
| (8) | | CC | 1000 BBL | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| (9) | | CT/GT | 1000 BBL | 90 | 25 | 47 | 49 | 42 | 230 | 159 | 104 | 134 | 52 | 112 |
| (10) | | TOTAL: | 1000 BBL | 137 | 63 | 102 | 104 | 98 | 286 | 218 | 158 | 190 | 104 | 164 |
| (12) | NATURAL GAS | STEAM | 1000 MCF | 1,844 | 1,421 | 1,365 | 1,455 | 1,415 | 1,404 | 1,681 | 1,373 | 1,458 | 1,069 | 1,132 |
| (13) | | CC | 1000 MCF | 6,140 | 13,592 | 11,881 | 12,867 | 13,682 | 17,787 | 20,209 | 17,119 | 17,542 | 13,548 | 14,727 |
| (14) | | CT/GT | 1000 MCF | 1,567 | 409 | 502 | 586 | 689 | 3,638 | 3,635 | 2,611 | 2,740 | 1,596 | 2,139 |
| (15) | | TOTAL: | 1000 MCF | 9,552 | 15,423 | 13,748 | 14,908 | 15,786 | 22,828 | 25,525 | 21,103 | 21,740 | 16,213 | 17,997 |
| (16) | PETROLEUM COKE | | 1000 TON | 1,460 | 1,860 | 2,787 | 2,830 | 2,770 | 2,924 | 3,022 | 2,907 | 2,903 | 2,892 | 2,902 |
| (20) | OTHER (SPECIFY) | | TRILLION BTU | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| <p>NOTE: 1. Coal includes JEA's share of SJRPP, JEA's share of Scherer 4 and Northside Coal.</p> | | | | | | | | | | | | | | |

**Schedule 6.1
Energy Sources (GWH)**

| (1) | (2) | (3) | (4) | (5) | | | | | | | | | |
|---------------------|----------------------------------|-------|---------|----------------------------------|--------|--------|--------|--------|--------|--------|--------|--------|--------|
| | | | | (6) | (7) | (8) | (9) | (10) | (11) | (12) | (13) | (14) | (15) |
| Fuel | Type | Units | Actuals | Annual Firm Inter-Region Intchg. | | | | | | | | | |
| | | | | 2005 | 2006 | 2007 | 2008 | 2009 | 2010 | 2011 | 2012 | 2013 | 2014 |
| (1) | Annual Firm Inter-Region Intchg. | GWH | 1,824 | 1,489 | 1,586 | 1,377 | 1,596 | 650 | 0 | 1 | 0 | 0 | |
| (2) | NUCLEAR | GWH | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | |
| (3) | COAL | GWH | 5,794 | 4,536 | 4,762 | 4,646 | 4,886 | 4,855 | 5,115 | 5,064 | 5,271 | 4,773 | 4,834 |
| (4) | RESIDUAL | STEAM | 861 | 662 | 625 | 661 | 642 | 661 | 823 | 628 | 684 | 462 | 493 |
| (5) | | GWH | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| (6) | | CT | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| (7) | TOTAL | GWH | 861 | 662 | 625 | 661 | 642 | 661 | 823 | 628 | 684 | 462 | 493 |
| (8) | DISTILLATE | STEAM | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| (9) | | GWH | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| (10) | | CC | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| (11) | | CT | 28 | 28 | 23 | 23 | 19 | 108 | 75 | 49 | 64 | 24 | 52 |
| (12) | TOTAL | GWH | 28 | 28 | 23 | 23 | 19 | 108 | 75 | 49 | 64 | 24 | 52 |
| (13) | NATURAL GAS | STEAM | 169 | 117 | 110 | 117 | 113 | 117 | 145 | 111 | 121 | 82 | 87 |
| (14) | | GWH | 951 | 1,849 | 1,606 | 1,763 | 1,874 | 2,518 | 2,875 | 2,368 | 2,431 | 1,816 | 1,991 |
| (15) | | CC | 142 | 36 | 45 | 55 | 72 | 414 | 396 | 278 | 312 | 162 | 232 |
| (16) | | CT | 1,262 | 2,002 | 1,761 | 1,935 | 2,059 | 3,049 | 3,416 | 2,757 | 2,864 | 2,059 | 2,311 |
| (17) | NUG | GWH | 0 | 154 | 187 | 187 | 187 | 187 | 187 | 187 | 187 | 187 | 187 |
| (18) | HYDRO | GWH | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| (19) | Petroleum Coke | GWH | 3,926 | 5,311 | 5,497 | 5,703 | 5,488 | 5,748 | 6,027 | 7,381 | 7,349 | 9,305 | 9,330 |
| (20) | OTHER (SPECIFY) | GWH | 2 | | | | | | | | | | |
| NET ENERGY FOR LOAD | | | 13,696 | 14,165 | 14,441 | 14,532 | 14,876 | 15,258 | 15,642 | 16,067 | 16,419 | 16,810 | 17,207 |

NOTE: 1. Coal includes JEA's share of SJRPP, Scherer 4 and Northside Coal.

**Schedule 6.2
Energy Sources (Percent)**

| | (1) | (2) | (3) | (4) | (6) | (7) | (8) | (9) | (10) | (11) | (12) | (13) | (14) | (15) |
|------|----------------------------------|-------|-------|-----------------|--------|--------|--------|--------|--------|--------|--------|--------|--------|--------|
| | Fuel | Type | Units | Actuals 2005 | 2006 | 2007 | 2008 | 2009 | 2010 | 2011 | 2012 | 2013 | 2014 | 2015 |
| (1) | Annual Firm Inter-Region Intchg. | | % | 13.3% | 10.5% | 11.0% | 9.5% | 10.7% | 4.3% | 0.0% | 0.0% | 0.0% | 0.0% | 0.0% |
| (2) | NUCLEAR | | % | 0.0% | 0.0% | 0.0% | 0.0% | 0.0% | 0.0% | 0.0% | 0.0% | 0.0% | 0.0% | 0.0% |
| (3) | COAL | | % | 42.3% | 32.0% | 33.0% | 32.0% | 32.8% | 31.8% | 32.7% | 31.5% | 32.1% | 28.4% | 28.1% |
| (4) | RESIDUAL | STEAM | % | 6.3% | 4.7% | 4.3% | 4.5% | 4.3% | 4.3% | 5.3% | 3.9% | 4.2% | 2.7% | 2.9% |
| (5) | | CC | % | 0.0% | 0.0% | 0.0% | 0.0% | 0.0% | 0.0% | 0.0% | 0.0% | 0.0% | 0.0% | 0.0% |
| (6) | | CT | % | 0.0% | 0.0% | 0.0% | 0.0% | 0.0% | 0.0% | 0.0% | 0.0% | 0.0% | 0.0% | 0.0% |
| (7) | | TOTAL | % | 6.3% | 4.7% | 4.3% | 4.5% | 4.3% | 4.3% | 5.3% | 3.9% | 4.2% | 2.7% | 2.9% |
| (8) | DISTILLATE | STEAM | % | 0.0% | 0.0% | 0.0% | 0.0% | 0.0% | 0.0% | 0.0% | 0.0% | 0.0% | 0.0% | 0.0% |
| (9) | | CC | % | 0.0% | 0.0% | 0.0% | 0.0% | 0.0% | 0.0% | 0.0% | 0.0% | 0.0% | 0.0% | 0.0% |
| (10) | | CT | % | 0.2% | 0.1% | 0.2% | 0.2% | 0.1% | 0.7% | 0.5% | 0.3% | 0.4% | 0.1% | 0.3% |
| (11) | | TOTAL | % | 0.2% | 0.1% | 0.2% | 0.2% | 0.1% | 0.7% | 0.5% | 0.3% | 0.4% | 0.1% | 0.3% |
| (12) | NATURAL GAS | STEAM | % | 1.2% | 0.8% | 0.8% | 0.8% | 0.8% | 0.8% | 0.9% | 0.7% | 0.7% | 0.5% | 0.5% |
| (13) | | CC | % | 6.9% | 13.1% | 11.1% | 12.1% | 12.6% | 16.5% | 18.4% | 14.7% | 14.8% | 10.8% | 11.6% |
| (14) | | CT | % | 1.0% | 0.3% | 0.3% | 0.4% | 0.5% | 2.7% | 2.5% | 1.7% | 1.9% | 1.0% | 1.3% |
| (15) | | TOTAL | % | 9.2% | 14.1% | 12.2% | 13.3% | 13.8% | 20.0% | 21.8% | 17.2% | 17.4% | 12.3% | 13.4% |
| (16) | NUG | | % | 0.0% | 1.1% | 1.3% | 1.3% | 1.3% | 1.2% | 1.2% | 1.2% | 1.1% | 1.1% | 1.1% |
| (17) | HYDRO | | % | 0.0% | 0.0% | 0.0% | 0.0% | 0.0% | 0.0% | 0.0% | 0.0% | 0.0% | 0.0% | 0.0% |
| (18) | Petroleum Coke | | % | 28.7% | 37.5% | 38.1% | 39.2% | 36.9% | 37.7% | 38.5% | 45.9% | 44.8% | 55.4% | 54.2% |
| (19) | OTHER (SPECIFY) | | % | 0.0% | 0.0% | 0.0% | 0.0% | 0.0% | 0.0% | 0.0% | 0.0% | 0.0% | 0.0% | 0.0% |
| (20) | NET ENERGY FOR LOAD | | % | 100.0% | 100.0% | 100.0% | 100.0% | 100.0% | 100.0% | 100.0% | 100.0% | 100.0% | 100.0% | 100.0% |

NOTE:

1. Coal includes JEA's share of SJRPP, Scherer 4 and Northside Coal.

**Schedule 7
Forecast of Capacity, Demand, and Scheduled Maintenance at Time Of Peak**

Winter

| Year | Installed Capacity MW | Firm Capacity | | QF MW | Available Capacity MW | Firm Peak Demand MW | Reserve Margin Before Maintenance | | Scheduled Maintenance MW | Reserve Margin After Maintenance | | |
|------|--------------------------|---------------|--------------|----------|--------------------------|------------------------|-----------------------------------|---------|-----------------------------|----------------------------------|-----|---------|
| | | Import MW | Export MW | | | | MW | Percent | | MW | MW | Percent |
| | | | | | | | | | | | | |
| 2006 | 3,553 | 207 | 383 | 0 | 3,378 | 2,831 | 547 | 19% | 0 | 547 | 19% | |
| 2007 | 3,593 | 207 | 383 | 0 | 3,417 | 2,924 | 493 | 17% | 0 | 493 | 17% | |
| 2008 | 3,593 | 229 | 383 | 0 | 3,439 | 2,921 | 518 | 18% | 0 | 518 | 18% | |
| 2009 | 3,721 | 229 | 383 | 0 | 3,567 | 3,015 | 552 | 18% | 0 | 552 | 18% | |
| 2010 | 3,905 | 229 | 383 | 0 | 3,751 | 3,111 | 640 | 21% | 0 | 640 | 21% | |
| 2011 | 4,096 | 22 | 383 | 0 | 3,735 | 3,207 | 528 | 16% | 0 | 528 | 16% | |
| 2012 | 4,096 | 92 | 383 | 0 | 3,805 | 3,307 | 498 | 15% | 0 | 498 | 15% | |
| 2013 | 4,332 | 22 | 383 | 0 | 3,971 | 3,407 | 564 | 17% | 0 | 564 | 17% | |
| 2014 | 4,582 | 22 | 383 | 0 | 4,221 | 3,510 | 711 | 20% | 0 | 711 | 20% | |
| 2015 | 4,582 | 22 | 383 | 0 | 4,221 | 3,614 | 607 | 17% | 0 | 607 | 17% | |

Summer

| Year | Installed Capacity MW | Firm Capacity | | QF MW | Available Capacity MW | Firm Peak Demand MW | Reserve Margin Before Maintenance | | Scheduled Maintenance MW | Reserve Margin After Maintenance | | |
|------|--------------------------|---------------|--------------|----------|--------------------------|------------------------|-----------------------------------|---------|-----------------------------|----------------------------------|-----|---------|
| | | Import MW | Export MW | | | | MW | Percent | | MW | MW | Percent |
| | | | | | | | | | | | | |
| 2006 | 3,417 | 207 | 376 | 0 | 3,248 | 2,651 | 597 | 23% | 0 | 597 | 23% | |
| 2007 | 3,426 | 229 | 376 | 0 | 3,279 | 2,716 | 563 | 21% | 0 | 563 | 21% | |
| 2008 | 3,426 | 229 | 376 | 0 | 3,279 | 2,698 | 581 | 22% | 0 | 581 | 22% | |
| 2009 | 3,534 | 229 | 376 | 0 | 3,387 | 2,761 | 626 | 23% | 0 | 626 | 23% | |
| 2010 | 3,686 | 22 | 376 | 0 | 3,332 | 2,824 | 508 | 18% | 0 | 508 | 18% | |
| 2011 | 3,845 | 22 | 376 | 0 | 3,491 | 2,888 | 603 | 21% | 0 | 603 | 21% | |
| 2012 | 4,081 | 22 | 376 | 0 | 3,727 | 2,950 | 777 | 26% | 0 | 777 | 26% | |
| 2013 | 4,081 | 22 | 376 | 0 | 3,727 | 3,014 | 713 | 24% | 0 | 713 | 24% | |
| 2014 | 4,331 | 22 | 376 | 0 | 3,977 | 3,078 | 899 | 29% | 0 | 899 | 29% | |
| 2015 | 4,331 | 22 | 376 | 0 | 3,977 | 3,158 | 819 | 26% | 0 | 819 | 26% | |

Schedule 8

Planned and Prospective Generating Facility and Purchased Power Additions and Changes

| (1) | (2) | (3) | (4) | (5) | (6) | (7) | (8) | (9) | (10) | (11) | (12) | (13) | (14) | (15) |
|--|----------|----------------------|-----------|-----------|-----------|----------------|-----------|-------------------------|-----------------------------------|------------------------------|----------------------|----------------|-----------|--------|
| Plant Name | Unit No. | Location | Unit Type | Fuel Type | | Fuel Transport | | Construction Start Date | Commercial/Change In-Service Date | Expected Retirement/Shutdown | Gen Max Nameplate kW | Net Capability | | Status |
| | | | | Primary | Alternate | Primary | Alternate | | | | | Summer MW | Winter MW | |
| Planned and Prospective Generating Facility Changes | | | | | | | | | | | | | | |
| Brandy Branch | 4 | Brandy Branch | CC | NG | FO2 | PL | TK | | 04/01/06 | | | 13.0 | 13.0 | A |
| Brandy Branch | 1 | Brandy Branch | GT | NG | FO2 | PL | TK | | 06/01/06 | | | 3.8 | 4.1 | A |
| Northside | 1 | Northside | ST | PC | BIT | WA | RR | | 6/2006 | | | 8.9 | 8.9 | A |
| Northside | 2 | Northside | ST | PC | BIT | WA | RR | | 12/2006 | | | 8.9 | 8.9 | A |
| Kennedy | 7 | Kennedy | GT | NG | FO2 | PL | TK | | 6/2007 | | | 3.8 | 4.1 | A |
| Kennedy | 3 | Kennedy | GT | NG | FO2 | PL | TK | | | 01/01/09 | | 51.0 | 62.7 | RS |
| Planned and Prospective Generating Facility Additions | | | | | | | | | | | | | | |
| CT - 7FA | 1 | Greenfield | GT | NG | FO2 | PL | TK | | 12/01/08 | | | 158.6 | 191.2 | P |
| CT - 7FA | 2 | Greenfield | GT | NG | FO2 | PL | TK | | 12/01/09 | | | 158.6 | 191.2 | P |
| CT - 7FA | 3 | Greenfield | GT | NG | FO2 | PL | TK | | 12/01/10 | | | 158.6 | 191.2 | P |
| PCoal | 1 | Taylor Energy Center | FC | Bit | Coal | WA | WA | | 06/01/12 | | | 236.0 | 236.0 | P |
| CFB | 4 | Greenfield | FC | PC | Coal | WA | WA | | 12/01/13 | | | 248.0 | 248.0 | P |
| Planned and Prospective Purchased Power Additions | | | | | | | | | | | | | | |
| Trail Ridge | | | | | | | | | 01/01/07 | 01/01/17 | | 9.1 | 9.1 | P |
| Jefferson Surfit | | | | | | | | | 01/01/07 | 01/01/17 | | 13.0 | 13.0 | P |
| TEA | | | | | | | | | 12/01/11 | 03/15/12 | | 0.0 | 70.0 | P |
| UPS | | | | | | | | | | 05/31/10 | | 200.0 | 200.0 | R |

Schedule 9.0
Status Report and Specifications of Proposed Generating Facilities

| | | | |
|--|----------------------------------|------------|----------|
| (1) Plant Name and Unit Number: | Greenfield Units 1-3 | | |
| (2) Capacity: | <u>Gas</u> | <u>Oil</u> | |
| (3) Summer MW | 149 MW | 158 MW | |
| (4) Winter MW | 186 MW | 191 MW | |
| (5) Technology Type: | Simple Cycle Combustion Turbine | | |
| (6) Anticipated Construction Timing: | Unit 1 | Unit 2 | Unit 3 |
| (7) Field Construction Start-date: | | | |
| (8) Commercial In-Service date: | 12/15/08 | 12/15/09 | 12/15/10 |
| (9) Fuel | | | |
| (10) Primary | Natural Gas | | |
| (11) Alternate | Diesel Fuel Oil | | |
| (12) Air Pollution Control Strategy: | Low NO _x Burners | | |
| (13) Cooling Method: | N/A | | |
| (14) Total Site Area: | | | |
| (15) Construction Status: | Planned | | |
| (16) Certification Status: | Not Required | | |
| (17) Status with Federal Agencies: | Not Filed | | |
| (18) Projected Unit Performance Data: | | | |
| (19) Planned Outage Factor (POF): | 1.00 percent | | |
| (20) Forced Outage Factor (FOF): | 2.00 percent | | |
| (21) Equivalent Availability Factor (EAF): | 97.00 percent | | |
| (22) Resulting Capacity Factor (%): | 5.0 – 10.0 percent | | |
| (23) Average Net Operating Heat Rate (ANOHR): | 10,816 Btu/kWh | | |
| (24) Projected Unit Financial Data: | | | |
| (25) Book Life: | 30 years | | |
| (26) Total Installed Cost (In-Service year \$/kW): | \$ 735.02 | | |
| (27) Direct Construction Cost (\$/kW): | Included in total installed cost | | |
| (28) AFUDC Amount (\$/kW): | Included in total installed cost | | |
| (29) Escalation (\$/kW): | Included in total installed cost | | |
| (30) Fixed O&M (\$/kW-yr): | \$ 4.98 | | |
| (31) Variable O&M (\$/MWh): | \$ 18.78 | | |

Schedule 9.1
Status Report and Specifications of Proposed Generating Facilities

| | |
|--|--|
| (1) Plant Name and Unit Number: | Taylor Energy Center (TEC) Unit 1 |
| (2) Capacity: | JEA Portion |
| (3) Summer MW | 236 MW |
| (4) Winter MW | 236 MW |
| (5) Technology Type: | Supercritical Pulverized Coal |
| (6) Anticipated Construction Timing: | |
| (7) Field Construction Start-date: | 2008 |
| (8) Commercial In-Service date: | 6/1/2012 |
| (9) Fuel | |
| (10) Primary | Bituminous Coal |
| (11) Alternate | N/A |
| (12) Air Pollution Control Strategy: | Engineering Review in Progress |
| (13) Cooling Method: | Engineering Review in Progress |
| (14) Total Site Area: | 3,300 Acres |
| (15) Construction Status: | Planned |
| (16) Certification Status: | FPSC Need Filing Expected Spring/Summer 2006 |
| (17) Status with Federal Agencies: | Preliminary Review |
| (18) Projected Unit Performance Data: | |
| (19) Planned Outage Factor (POF): | |
| (20) Forced Outage Factor (FOF): | |
| (21) Equivalent Availability Factor (EAF): | |
| (22) Resulting Capacity Factor (%): | |
| (23) Average Net Operating Heat Rate (ANOHR): | |
| (24) Projected Unit Financial Data: | |
| (25) Book Life: | |
| (26) Total Installed Cost (In-Service year \$/kW): | |
| (27) Direct Construction Cost (\$/kW): | |
| (28) AFUDC Amount (\$/kW): | |
| (29) Escalation (\$/kW): | |
| (30) Fixed O&M (\$/kW-yr): | |
| (31) Variable O&M (\$/MWh): | |

Schedule 9.2
Status Report and Specifications of Proposed Generating Facilities

| | | |
|------|---|----------------------------------|
| (1) | Plant Name and Unit Number: | Greenfield Unit 4 |
| (2) | Capacity: | |
| (3) | Summer MW | 248 MW |
| (4) | Winter MW | 248 MW |
| (5) | Technology Type: | Circulating Fluidized Bed |
| (6) | Anticipated Construction Timing: | |
| (7) | Field Construction Start-date: | |
| (8) | Commercial In-Service date: | Winter 2014 |
| (9) | Fuel | |
| (10) | Primary | Petroleum Coke |
| (11) | Alternate | Bituminous Coal |
| (12) | Air Pollution Control Strategy: | In Planning Phase |
| (13) | Cooling Method: | In Planning Phase |
| (14) | Total Site Area: | |
| (15) | Construction Status: | In Planning Phase |
| (16) | Certification Status: | Not Filed |
| (17) | Status with Federal Agencies: | In Planning Phase |
| (18) | Projected Unit Performance Data: | |
| (19) | Planned Outage Factor (POF): | 1.50 percent |
| (20) | Forced Outage Factor (FOF): | 5.00 percent |
| (21) | Equivalent Availability Factor (EAF): | 93.5 percent |
| (22) | Resulting Capacity Factor (%): | 85.0 percent |
| (23) | Average Net Operating Heat Rate (ANOHR): | 9,151 Btu/kWh |
| (24) | Projected Unit Financial Data: | |
| (25) | Book Life: | 30 years |
| (26) | Total Installed Cost (In-Service year \$/kW): | \$2,774 |
| (27) | Direct Construction Cost (\$/kW): | Included in total installed cost |
| (28) | AFUDC Amount (\$/kW): | Included in total installed cost |
| (29) | Escalation (\$/kW): | Included in total installed cost |
| (30) | Fixed O&M (\$/kW-yr): | 39.34 |
| (31) | Variable O&M (\$/MWh): | 6.40 |

| Schedule 10 Status Report and Specifications of Proposed Directly Associated Transmission Lines | |
|--|-----------------------------|
| (1) Point of Origin and Termination | No Updates To Report |
| (2) Number of Lines | |
| (3) Right of Way | |
| (4) Line Length | |
| (5) Voltage | |
| (6) Anticipated Construction Time | |
| (7) Anticipated Capital Investment | |
| (8) Substations | |
| (9) Participation with Other Utilities | |

