

One Energy Place  
Pensacola, Florida 32520

850.444.6111



August 26, 1999

Ms. Blanca S. Bayo, Director  
Division of Records and Reporting  
Florida Public Service Commission  
2540 Shumard Oak Boulevard  
Tallahassee FL 32399-0870

Dear Ms. Bayo:

RE: Docket No. 981591-EG

Enclosed for official filing are an original and fifteen copies of the rebuttal testimony of T. S. Spangenberg and D. A. Shell on behalf of Gulf Power Company in the above docket. Also enclosed are revisions to T. S. Spangenberg's Direct testimony and page 9 of his exhibit.

Sincerely,

*Susan D. Ritenour*  
Susan D. Ritenour  
Assistant Secretary and Assistant Treasurer

- ACK \_\_\_\_\_
- AFA \_\_\_\_\_
- APP \_\_\_\_\_
- CAF \_\_\_\_\_
- CMU \_\_\_\_\_
- CTT \_\_\_\_\_
- EEF Shell \_\_\_\_\_
- LEF 1 \_\_\_\_\_
- LIN 3+ org \_\_\_\_\_
- OPC \_\_\_\_\_
- RAT \_\_\_\_\_
- SEL 1 \_\_\_\_\_
- WAS \_\_\_\_\_
- OTH \_\_\_\_\_

lw  
Enclosures  
cc: Beggs & Lane  
Jeffrey A. Stone, Esquire

*Page 9*  
DOCUMENT NUMBER-DATE  
10240 AUG 26 89  
FPSC-RECORDS/REPORTING

*Spangenberg*  
DOCUMENT NUMBER-DATE  
10241 AUG 26 89  
FPSC-RECORDS/REPORTING

*Shell*  
DOCUMENT NUMBER-DATE  
10242 AUG 26 89  
FPSC-RECORDS/REPORTING

BEFORE THE FLORIDA PUBLIC SERVICE COMMISSION

In re: Petition for authority to implement )  
Good Cents Conversion Program by )  
Gulf Power Company )  
\_\_\_\_\_ )

Docket No. 981591-EG

Certificate of Service

I HEREBY CERTIFY that a copy of the foregoing has been furnished  
this 26th day of August 1999 by U.S. Mail or hand delivery to the following:

Tiffany R. Collins, Esquire  
Staff Counsel  
FL Public Service Commission  
2540 Shumard Oak Boulevard  
Tallahassee FL 32399-0863

Ansley Watson, Jr., Esquire  
Macfarlane Ferguson & McMullen  
P. O. Box 1531  
Tampa FL 33601



JEFFREY A. STONE  
Florida Bar No. 325953  
RUSSELL A. BADDERS  
Florida Bar No. 0007455  
Beggs & Lane  
P. O. Box 12950  
Pensacola FL 32576  
850 432-2451  
Attorneys for Gulf Power Company

**ORIGINAL**

1 annual electrical energy consumption is a reduction of  
2 1,030 kWh at the meter. When the reduction in the  
3 participant's natural gas requirements is included,  
4 the typical impact is the conservation of 33.7 million  
5 Btu's of energy per year per participant at the meter.

6

7 Q. Were any recognized methodologies used to assess the  
8 cost effectiveness of the GoodCents Conversion  
9 Program?

10 A. Yes. The Commission has an established, approved  
11 methodology for assessing the cost effectiveness of  
12 energy conservation programs. This approved  
13 methodology is described in the publication "Florida  
14 Public Service Commission Cost Effectiveness Manual  
15 for Demand Side Management Programs and Self-Service  
16 Wheeling Proposals" adopted by the Commission in Rule  
17 25-17.008, Florida Administrative Code. The approved  
18 methodology was used in performing the assessments of  
19 the Program. The manual sets forth three critical  
20 cost-effectiveness tests, the Ratepayer Impact Measure  
21 (RIM) Test, the Participant's Test, and the Total  
22 Resource Cost (TRC) Test. In order to be cost-  
23 effective under any of these tests, a program must have  
24 a benefits to cost ratio greater than 1.0.

25

26

1 Q. Using the approved methodology just described, is the  
2 GoodCents Conversion Program cost effective?

3 A. Yes. As depicted in Schedule TSS-1, all three key  
4 measures were at least 1.00. In other words, the  
5 GoodCents Conversion Program passes all three tests of  
6 cost-effectiveness specified in the Commission's  
7 manual on cost effectiveness of conservation programs.

8  
9 Q. Please describe the assumptions that have been  
10 incorporated in the cost-effectiveness analysis for the  
11 GoodCents Conversion Program.

12 A. The base home for modeling purposes is a 1680 square  
13 foot home with an inefficient central air conditioning  
14 unit having an effective Seasonal Energy Efficiency  
15 Ratio (SEER) of 7.0 and a central gas furnace with a  
16 68% Annual Fuel Utilization Efficiency (AFUE). In  
17 Gulf's assumptions, the entire existing heating and  
18 cooling system has been removed and replaced with a  
19 heat pump having a SEER of 11.0 and a Heating Season  
20 Performance Factor (HSPF) of 7.4.

21  
22 Q. Are the assumptions incorporated in the cost-  
23 effectiveness analysis regarding summer peak demand,  
24 winter peak demand and annual energy usage reasonable?

25 A. Yes. These cost effectiveness evaluations are the  
26 result of the aforementioned system assumptions input

1           electrical demand, the use of promotional incentives  
2           was considered because those seem to be one of the  
3           most effective tools in today's marketplace for  
4           encouraging consumer action. However, the company  
5           wanted to ensure that all promotional offerings to  
6           customers were cost-effective. In all our  
7           considerations for potential HVAC upgrade programs,  
8           with the natural exception of our geothermal  
9           initiatives, we assumed that the cooling aspect of  
10          existing and replacement systems would be the  
11          traditional refrigerant cycle with air-to-air heat  
12          exchange. For the heating cycle we analyzed electric  
13          resistance heat, gas furnaces, and air-to-air heat  
14          pumps. While knowing that 7.0 SEER was a good average  
15          for existing systems, we also considered higher SEER's,  
16          i.e. newer equipment, for the system being replaced,  
17          realizing that the higher SEER's would make the cost-  
18          effectiveness tests more difficult to pass. The  
19          company did everything reasonable to ensure rigor in  
20          its analyses. The cost effectiveness tests results for  
21          these other variations are shown in Schedule TSS-1 and  
22          indicate that the only combination that passed the  
23          necessary cost-effectiveness tests was going from a gas  
24          furnace, regardless of equipment vintage, to a heat  
25          pump. In short, an attempt was made to include the

## Cost Effectiveness Analysis Cooling and Heating Efficiency Enhancement Program

Existing System		New System		Cost Effectiveness		
<u>Heating</u>	<u>Cooling</u>	<u>Heating</u>	<u>Cooling</u>	<u>RIM</u>	<u>PART</u>	<u>TRC</u>
68% AFUE Gas Furnace	7 SEER A/C	7.4 HSPF Heat Pump	11 SEER Heat Pump	1.74	1.65	2.20
68% AFUE Gas Furnace	7 SEER A/C	25% Free Riders 7.4 HSPF Heat Pump	11 SEER Heat Pump	1.59	1.60	2.12
68% AFUE Gas Furnace	7 SEER A/C	15 Yr. Program Life 7.4 HSPF Heat Pump	11 SEER Heat Pump	1.49	1.09	1.30
68% AFUE Gas Furnace	8 SEER A/C	7.4 HSPF Heat Pump	11 SEER Heat Pump	2.45	1.45	1.85
68% AFUE Gas Furnace	10 SEER A/C	7.4 HSPF Heat Pump	11 SEER Heat Pump	1.41	1.14	1.32
68% AFUE Gas Furnace	10 SEER A/C	15 Yr. Program Life 7.4 HSPF Heat Pump	11 SEER Heat Pump	1.19	1.39	1.88
Gas or Resistance Heat	7 SEER A/C	Gas or Resistance Heat	11 SEER A/C	1.06	0.87	0.93
Gas or Resistance Heat	8 SEER A/C	Gas or Resistance Heat	11 SEER A/C	0.95	0.60	0.60
Resistance Heat	7 SEER A/C	7.4 HSPF Heat Pump	11 SEER Heat Pump	0.75	1.46	1.07
Resistance Heat	8 SEER A/C	7.4 HSPF Heat Pump	11 SEER Heat Pump	0.66	1.26	0.82