

BEFORE THE FLORIDA PUBLIC SERVICE COMMISSION

DOCKET NO: 000154-SU

IN RE: PROPOSED RULE 25-30.432, F.A.C., WASTEWATER TREATMENT
PLANT USED AND USEFUL CALCULATIONS

NOTICE OF CHANGE

TO


ALL INTERESTED PERSONS

ISSUED: November 7, 2002

NOTICE is hereby given pursuant to Section 120.54, Florida Statutes, that the Florida Public Service Commission has approved a change to proposed Rule 25-30.432, Florida Administrative Code.

The attached Notice of Change will appear in the November 15, 2002, edition of the Florida Administrative Weekly.

By DIRECTION of the Florida Public Service Commission, this 7th day of November, 2002.



BLANCA S. BAYÓ, Director
Division of the Commission Clerk
and Administrative Services

(S E A L)

CTM

DOCUMENT NUMBER-DATE

12254 NOV-78

FPSC-DE. ASSISTANT CLERK

NOTICE OF CHANGE.
DOCKET NO. 000154-SU
PAGE 2

FLORIDA PUBLIC SERVICE COMMISSION

DIVISION OF APPEALS

DOCKET NO. 000154-SU

RULE NO: RULE TITLE:

25-30.432 Wastewater Treatment Plant Used and Useful
Calculations

NOTICE OF CHANGE

Notice is hereby given that the following changes have been made to the proposed rule in accordance with subparagraph 120.54(3)(d)1., F.S., published in Volume 28, No. 30, July 26, 2002, issue of the Florida Administrative Weekly:

25-30.432 Wastewater Treatment Plant Used and Useful Calculations. The flow data to be used in the numerator of the equation for calculating the used and useful percentage of a wastewater treatment plant shall be the same period or basis (such as annual average daily flow, three-month average daily flow, maximum month average daily flow) as the period or basis stated for the permitted capacity on the most recent operating permit issued by the Florida Department of Environmental Protection (DEP). The DEP permitted capacity shall be used in the denominator of the equation. ~~If there are differences between the capacities of the~~

NOTICE OF CHANGE
DOCKET NO. 000154-SU
PAGE 3

~~individual components of the wastewater treatment plant, the Commission may calculate a used and useful percentage for each individual component of the treatment plant using the actual capacity of the component in the denominator.~~ In determining the used and useful amount, the Commission will also consider other factors such as the allowance for growth pursuant to section 367.081(2)(a)2., F.S., infiltration and inflow, the extent to which the area served by the plant is built out, whether the permitted capacity differs from the design capacity, whether there are differences between the actual capacities of the individual components of the wastewater treatment plant and the permitted capacity of the plant, and whether flows have decreased due to conservation or a reduction in the number of customers. This rule does not apply to reuse projects pursuant to section 367.0817(3), F.S., or investment for environmental compliance pursuant to section 367.081(2)(a)2.c., F.S.

Specific Authority: 350.127(2), 367.121(1)(f), FS.

Law Implemented: 367.081(2), FS.

History: New.