



September 4, 2025

VIA: ELECTRONIC FILING

Mr. Adam J. Teitzman
Commission Clerk
Florida Public Service Commission
2540 Shumard Oak Boulevard
Tallahassee, Florida 32399-0850

Re: Fuel and Purchased Power Cost Recovery Clause with Generating Performance
Incentive Factor; FPSC Docket No. 20250001-EI

Dear Mr. Teitzman:

Attached for filing in the above docket is Tampa Electric Company's Projection Testimony for the period January 2026 through December 2026, as follows:

- Prepared Direct Testimony of Adam L. Parke and Exhibit ALP-2.

Thank you for your assistance in connection with this matter.

Sincerely,

A handwritten signature in blue ink that reads 'Malcolm N. Means'.

Malcolm N. Means

MNM/bml
Attachment

cc: All Parties of Record (w/encl.)

CERTIFICATE OF SERVICE

I HEREBY CERTIFY that a true and correct copy of the foregoing Projection Testimony, filed on behalf of Tampa Electric Company, has been furnished by electronic mail on this 4th day of September 2025 to the following:

Ryan Sandy
Office of the General Counsel
Florida Public Service Commission
2540 Shumard Oak Boulevard
Tallahassee, FL 32399-0850
sbrownle@psc.state.fl.us
rsandy@psc.state.fl.us
discovery-gcl@psc.state.fl.us

Walter Trierweiler
Charles Rehwinkel
Patricia A. Christensen
Mary Wessling
Octavio Ponce
Austin Watrous
Office of Public Counsel
111 West Madison Street, Room 812
Tallahassee, FL 32399-1400
Trierweiler.Walt@leg.state.fl.us
Rehwinkel.charles@leg.state.fl.us
christensen.patty@leg.state.fl.us
wessling.mary@leg.state.fl.us
ponce.octavio@leg.state.fl.us
watrous.austin@leg.state.fl.us

Dianne M. Triplett
Duke Energy Florida
299 First Avenue North
St. Petersburg, FL 33701
Dianne.triplett@duke-energy.com
FLRegulatoryLegal@duke-energy.com

Beth Keating
Gunster, Yoakley & Stewart, P.A.
215 S. Monroe St., Suite 601
Tallahassee, FL 32301
bkeating@gunster.com

Maria Moncada
David M. Lee
Florida Power & Light Company
700 Universe Boulevard
Juno Beach, FL 33408-0420
maria.moncada@fpl.com
david.lee@fpl.com

Kenneth Hoffman
Vice President, Regulatory Relations
Florida Power & Light Company
215 South Monroe Street, Suite 810
Tallahassee, FL 32301-1859
ken.hoffman@fpl.com

Mike Cassel
Regulatory and Governmental Affairs
Florida Public Utilities Company
Florida Division of Chesapeake Utilities Corp.
208 Wildlight Ave.
Yulee, FL 32097
mcassel@fpuc.com

Robert Scheffel Wright
John LaVia, III
Gardner, Bist, Wiener, Wadsworth, Bowden,
Bush, Dee, LaVia & Wright, P.A.
1300 Thomaswood Drive
Tallahassee, FL 32308
shef@gbwlegal.com
jlavia@gbwlegal.com

Matthew R. Bernier
Robert Pickles
Stephanie A. Cuello
Duke Energy Florida
106 East College Avenue, Suite 800
Tallahassee, FL 32301-7740
Matthew.bernier@duke-energy.com
Robert.pickles@duke-energy.com
Stephanie.Cuello@duke-energy.com

Jon C Moyle, Jr.
Moyle Law Firm
118 North Gadsden Street
Tallahassee, FL 32301
jmoyle@moylelaw.com
mqualls@moylelaw.com

Michelle D. Napier
1635 Meathe Drive
West Palm Beach, FL 33411
mnapier@fpuc.com

James W. Brew
Laura W. Baker
Sarah B. Newman
Stone Mattheis Xenopoulos & Brew, PC
1025 Thomas Jefferson Street, NW
Eighth Floor, West Tower
Washington, D.C. 20007-5201
jbrew@smxblaw.com
lwb@smxblaw.com
sbn@smxblaw.com

Peter J. Mattheis
Michael K. Lavanga
Joseph R. Briscar
Stone Law Firm
1025 Thomas Jefferson St., NW
Suite 800 West
Washington, DC 20007-5201
pjm@smxblaw.com
mkl@smxblaw.com
jrb@smxblaw.com



ATTORNEY



BEFORE THE
FLORIDA PUBLIC SERVICE COMMISSION

DOCKET NO. 20250001-EI
FUEL & PURCHASED POWER COST RECOVERY
AND
CAPACITY COST RECOVERY

GENERATING PERFORMANCE INCENTIVE FACTOR
PROJECTIONS
JANUARY 2026 THROUGH DECEMBER 2026

TESTIMONY AND EXHIBIT
OF
ADAM L. PARKE

FILED: SEPTEMBER 4, 2025

BEFORE THE FLORIDA PUBLIC SERVICE COMMISSION

PREPARED DIRECT TESTIMONY

OF

ADAM L. PARKE

Q. Please state your name, address, occupation, and employer.

A. My name is Adam L. Parke. My business address is 3600 Midtown Drive, Tampa, Florida 33607. I am employed by Tampa Electric Company ("Tampa Electric" or "company") in the position of Supervisor, Mechanical Reliability in the Asset Management department.

Q. Please provide a brief description of your educational background and work experience.

A. I received a Bachelor of Science degree in Mechanical Engineering from the University of South Florida in 1999 and a Master of Business Administration in 2012 from the University of Tampa. I have accumulated 18 years of experience in the electric utility industry, with experience in the areas of generation planning, plant engineering/ maintenance, and plant operations engineer. In my previous role as a Senior Engineer, I was

1 responsible for the balance of plant equipment on the Big
2 Bend Modernization project to convert Big Bend Unit 1
3 from a coal unit to a combined-cycle unit. In my current
4 role as Supervisor, Mechanical Reliability, I am
5 responsible for supervising the development and
6 implementation of fleet wide maintenance and inspection
7 programs for boilers, high energy piping, and turbines to
8 help ensure equipment operational reliability.

9
10 **Q.** What is the purpose of your testimony?

11
12 **A.** My testimony describes Tampa Electric's methodology for
13 determining the various factors required to compute the
14 Generating Performance Incentive Factor ("GPIF") as
15 ordered by the Commission.

16
17 **Q.** Have you prepared an exhibit to support your direct
18 testimony?

19
20 **A.** Yes. Exhibit No. ALP-2, consisting of two documents, was
21 prepared under my direction and supervision. Document No.
22 1 contains the GPIF schedules. Document No. 2 is a summary
23 of the GPIF targets for the 2026 period.

24
25 **Q.** Which generating units on Tampa Electric's system are

1 included in the determination of the GPIF?

2
3 **A.** Four natural gas combined cycle ("CC") units are included.
4 These are Big Bend Unit 1 CC, Polk Unit 2, and Bayside
5 Units 1 and 2.

6
7 **Q.** Does your exhibit comply with the Commission's approved
8 GPIF methodology?

9
10 **A.** Yes. In accordance with the GPIF Manual, the GPIF units
11 selected represent no less than 80 percent of the
12 estimated system net generation. The units Tampa Electric
13 proposes to use for the period January 2026 through
14 December 2026 represent the top 81 percent of the total
15 forecasted system net generation for this period. It
16 includes generation from the Big Bend Unit 1 CC,
17 commissioned in December 2022. Tampa Electric included
18 Big Bend Unit 1 CC as it is the most efficient unit and
19 makes up 32 percent of our generation.

20
21 To account for the concerns presented in the testimony of
22 Commission Staff witness Sidney W. Matlock during the 2005
23 fuel hearing, Tampa Electric removes outliers from the
24 calculation of the GPIF targets. The methodology was
25 approved by the Commission in Order No. PSC-2006-1057-

1 FOF-EI issued in Docket No. 20060001-EI on December 22,
2 2006.

3
4 **Q.** Did Tampa Electric identify any outages as outliers?

5
6 **A.** Yes, Tampa Electric identified and removed Big Bend Unit
7 1 CC and Bayside Unit 2 outages as outliers based on the
8 outlier criteria established in Order No. PSC-2006-1057-
9 FOF-EI.

10
11 **Q.** Did Tampa Electric make any other adjustments?

12
13 **A.** Yes. As allowed per Section 4.3 of the GPIF Implementation
14 Manual, the company adjusted the Forced Outage and
15 Maintenance Outage Factors to reflect recent unit
16 performance and known unit modifications or equipment
17 changes.

18
19 **Q.** Please describe how Tampa Electric developed the various
20 factors associated with GPIF.

21
22 **A.** The company established targets for equivalent
23 availability and heat rate for each unit considered for
24 the 2026 period. The company determined a range of
25 potential improvements and degradations for each of these

1 metrics.

2

3 **Q.** How were the target values for unit availability
4 determined?

5

6 **A.** Tampa Electric subtracted the Planned Outage Factor
7 ("POF") and the Equivalent Unplanned Outage Factor
8 ("EUOF") from 100 percent to determine the target
9 Equivalent Availability Factor ("EAF"). The factors for
10 each of the four units included within the GPIF are shown
11 on page 5 of Document No. 1.

12

13 To give an example for the 2026 period, the projected
14 EUOF for Bayside Unit 1 is 1.7 percent, the POF is 28.8
15 percent. Therefore, the target EAF for Bayside Unit 1
16 equals 69.6 percent or:

17

$$18 \quad 100\% - (1.7\% + 28.8\%) = 69.6\%$$

19

20 This is shown on Page 4, column 3 of Document No. 1.

21

22 **Q.** How was the potential for unit availability improvement
23 determined?

24

25 **A.** Maximum equivalent availability is derived using the

following formula:

$$EAF_{MAX} = 1 - [0.80 (EUOF_T) + 0.95 (POF_T)]$$

The factors included in the above equations are the same factors that determine the target equivalent availability. Calculating the maximum incentive points, a 20 percent reduction in EUOF, plus a five percent reduction in the POF is necessary. Continuing with the Bayside Unit 1 example:

$$EAF_{MAX} = 1 - [0.80 (1.7\%) + 0.95 (28.8\%)] = 71.3\%$$

This is shown on page 4, column 4 of Document No. 1.

Q. How was the potential for unit availability degradation determined?

A. The potential for unit availability degradation is significantly greater than the potential for unit availability improvement. This concept was discussed extensively during the development of the incentive. To incorporate this biased effect into the unit availability tables, Tampa Electric uses a potential degradation range equal to twice the potential improvement. Consequently,

1 minimum equivalent availability is calculated using the
2 following formula:

$$3 \quad \text{EAF}_{\text{MIN}} = 1 - [1.40 (\text{EUOF}_T) + 1.10 (\text{POF}_T)]$$

4
5 Again, continuing using the Bayside Unit 1 example,

$$6 \quad \text{EAF}_{\text{MIN}} = 1 - [1.40 (1.7\%) + 1.10 (28.8\%)] = 66.0\%$$

7
8 The equivalent availability maximum and minimum for the
9 other four units are computed in a similar manner.

10
11 **Q.** How did Tampa Electric determine the Planned Outage,
12 Maintenance Outage, and Forced Outage Factors?

13
14 **A.** The company's planned outages for January 2026 through
15 December 2026 are shown on page 15 of Document No. 1.
16 Three GPIF units have a major planned outage of 28 days
17 or greater in 2026; therefore, three Critical Path Method
18 Diagrams are provided.

19
20 The company calculates Planned Outage Factors for each
21 unit. For example, Bayside Unit 1 is scheduled for a
22 planned outage more than 28 days from February 1, 2026,
23 to May 11, 2026. There are 2,520 total planned outage
24 hours scheduled for the 2026 period out of a total of
25 8,760 hours during this 12-month period. Consequently,

1 the POF for Bayside Unit 1 is 28.8 percent or:

$$\frac{2,520}{8,760} \times 100\% = 28.8\%$$

2
3
4
5 The factor for each unit is shown on pages 5 and 11 through
6 14 of Document No. 1. Big Bend Unit 1 CC has a POF of 7.9
7 percent, Polk Unit 2 has a POF of 9.0 percent, Bayside
8 Unit 1 has a POF of 28.8 percent and Bayside Unit 2 has
9 a POF of 3.6 percent.

10
11 **Q.** How did you determine the Forced Outage and Maintenance
12 Outage Factors for each unit?

13
14 **A.** Projected factors are based upon historical unit
15 performance. For each unit, the three most recent July
16 through June annual periods formed the basis of the target
17 development. The company analyzes historical data and
18 target values to assure applicability to current
19 conditions of operation. This provides assurance that any
20 periods of abnormal operations or recent trends having
21 material effect can be taken into consideration. These
22 target factors are additive and result in a EUOF of 1.7
23 percent for Bayside Unit 1. The EUOF of Bayside Unit 1 is
24 verified by the data shown on page 13, lines 3, 5, 10,
25 and 11 of Document No. 1 and calculated using the

following formula:

$$\text{EUOF} = \frac{(\text{EFOH} + \text{EMOH})}{\text{PH}} \times 100\%$$

Or

$$\text{EUOF} = \frac{(55 + 92)}{8,760} \times 100\% = 1.7\%$$

Relative to Bayside Unit 1, the EUOF of 1.7 percent forms the basis of the equivalent availability target development as shown on pages 4 and 5 of Document No. 1.

Big Bend Unit 1 CC

The projected EUOF for this unit is 3.0 percent. The unit will have one planned outage longer than 28 days in 2026, and the POF is 7.9 percent. Therefore, the target equivalent availability for this unit is 89.0 percent.

Polk Unit 2

The projected EUOF for this unit is 4.2 percent. The unit will have two planned outages in 2026, and the POF is 9.0 percent. Therefore, the target equivalent availability for this unit is 86.7 percent.

1 **Bayside Unit 1**

2 The projected EUOF for this unit is 1.7 percent. The unit
3 will have one planned outage longer than 28 days in 2026,
4 and the POF is 28.8 percent. Therefore, the target
5 equivalent availability for this unit is 69.6 percent.

6
7 **Bayside Unit 2**

8 The projected EUOF for this unit is 6.3 percent. There
9 are no planned outages longer than 28 days scheduled for
10 2026, and the POF is 3.6 percent. Therefore, the target
11 equivalent availability for this unit is 90.1 percent.

12
13 **Q.** Please summarize your testimony regarding EAF.

14
15 **A.** The GPIF system weighted EAF of 85.5 percent is shown on
16 page 5 of Document No. 1.

17
18 **Q.** Why are Forced and Maintenance Outage Factors adjusted
19 for planned outage hours?

20
21 **A.** The adjustment makes the factors more accurate and
22 comparable. A unit in a planned outage stage or reserve
23 shutdown stage cannot incur a forced or maintenance
24 outage. To demonstrate the effects of a planned outage,
25 note the Equivalent Unplanned Outage Rate and Equivalent

Unplanned Outage Factor for Bayside Unit 1 on page 13 of Document No. 1. Except for the months of February, March April, May, October and November, the Equivalent Unplanned Outage Rate and Equivalent Unplanned Outage Factor are equal. This is because no planned outages are scheduled for these months. During the months of planned outages, the Equivalent Unplanned Outage Rate exceeds the Equivalent Unplanned Outage Factor due to the scheduled planned outages. Therefore, the adjusted factors apply to the period hours after the planned outage hours have been extracted.

Q. Does this mean that both rate and factor data are used in calculated data?

A. Yes. Rates provide a proper and accurate method of determining unit metrics, which are subsequently converted to factors. Therefore,

$$\text{EFOF} + \text{EMOF} + \text{POF} + \text{EAF} = 100\%$$

Since factors are additive, they are easier to work with and to understand.

Q. Has Tampa Electric prepared the necessary heat rate data

1 required for the determination of the GPIF?

2
3 **A.** Yes. Tampa Electric developed target heat rates and ranges
4 of potential operation as required and adjusted them to
5 reflect the aforementioned agreed-upon GPIF methodology.
6

7 **Q.** How did Tampa Electric determine the targets?
8

9 **A.** Net heat rate data for the three most recent July through
10 June annual periods formed the basis for the target
11 development. The company analyzes historical data and the
12 target values to assure applicability to current
13 conditions of operation. This provides assurance that any
14 period of abnormal operations or equipment modifications
15 having material effect on heat rate can be taken into
16 consideration.
17

18 **Q.** How did the company determine the ranges of heat rate
19 improvement and heat rate degradation?
20

21 **A.** The company determined the ranges through analysis of
22 historical net heat rate and net output factor data. This
23 is the same data from which the net heat rate versus net
24 output factor curves have been developed for each unit.
25 This information is shown on pages 24 through 27 of

Document No. 1.

Q. Please elaborate on the analysis used in the determination of the ranges.

A. The net heat rate versus net output factor curves are the result of a first order curve fit to historical data. The company determined the standard error of the estimate of this data and applied a factor to produce a band of potential improvement and degradation. The computer program for each unit performed both the curve fit and the standard error of the estimate. These curves are also used in post-period adjustments to actual heat rates to account for unanticipated changes in unit dispatch and fuel.

Q. Please summarize your heat rate projection (Btu/Net kWh) and the range about each target to allow for potential improvement or degradation for the 2026 period.

A. The heat rate target for Big Bend Unit 1 CC is 6,403 Btu/Net kWh with a range of ± 249 Btu/Net kWh. The heat rate target for Polk Unit 2 is 7,131 Btu/Net kWh with a range of ± 134 Btu/Net kWh. The heat rate for Bayside Unit 1 is 7,242 Btu/Net kWh with a range of ± 300 Btu/Net kWh.

1 The heat rate target for Bayside Unit 2 is 7,572 Btu/Net
2 kWh with a range of ± 285 Btu/Net kWh. A zone of tolerance
3 of ± 75 Btu/Net kWh is included within a range for each
4 target. This is shown on pages 7 through 10 of Document
5 No. 1.

6
7 **Q.** Do these heat rate targets and ranges meet the
8 Commission's requirements?

9
10 **A.** Yes.

11
12 **Q.** After determining the target values and ranges for average
13 net operating heat rate and equivalent availability, what
14 is the next step in determining the GPIF targets?

15
16 **A.** The next step is to calculate the savings and weighting
17 factor to be used for both average net operating heat
18 rate and equivalent availability. This is shown in
19 Document No. 1, pages 7 through 10. The company performed
20 the baseline production costing analysis to calculate the
21 total system fuel cost if all units operated at target
22 heat rate and target availability for the period. This
23 total system fuel cost of \$734,055,680 is shown on
24 Document No. 1, page 6, column 2. Tampa Electric performed
25 multiple production cost simulations to calculate total

1 system fuel cost with each unit individually operating at
2 maximum improvement in equivalent availability and each
3 station operating at maximum improvement in average net
4 operating heat rate. The respective savings are shown on
5 page 6, column 4 of Document No. 1.

6
7 Column 4 totals \$24,456,710, which reflects the savings
8 if all of the units operated at maximum improvement. The
9 company then calculates a weighting factor for each metric
10 by dividing unit savings by the total. For Bayside Unit
11 1, the weighting factor for average net operating heat
12 rate is 11.80 percent as shown in the right-hand column
13 on Document No. 1, page 6. Pages 7 through 10 of Document
14 No. 1 show the point table, the Fuel Savings/(Loss) and
15 the equivalent availability or heat rate value. The
16 individual weighting factor is also shown. For example,
17 as shown on page 9 of Document No. 1, if Bayside Unit 1,
18 operates at 6,943, the adjusted actual average heat rate,
19 fuel savings would equal \$2,886,900 and +10 average net
20 operating heat rate points would be awarded.

21
22 The GPIF Reward/Penalty table on page 2 of Document No.
23 1 is a summary of the tables on pages 7 through 10. The
24 left-hand column of this document shows the incentive
25 points for Tampa Electric. The center column shows the

1 total fuel savings and is the same amount as shown on
2 page 6, column 4, or \$24,456,710. The right-hand column
3 of page 2 is the estimated reward or penalty based upon
4 performance.

5
6 **Q.** How did the company determine the maximum allowed
7 incentive?

8
9 **A.** Referring to page 3, line 14, the estimated average common
10 equity for the period January 2026 through December 2026
11 is \$5,762,210,477. This produces the maximum allowed
12 jurisdictional incentive of \$19,356,023 shown on line 21.

13
14 **Q.** Are there any constraints set forth by the Commission
15 regarding the magnitude of incentive dollars?

16
17 **A.** Yes. As Order No. PSC-2013-0665-FOF-EI, issued in Docket
18 No. 20130001-EI on December 18, 2013, states, incentive
19 dollars are not to exceed 50 percent of fuel savings.
20 Page 2 of Document No. 1 demonstrates that this constraint
21 is met, limiting total potential reward and penalty
22 incentive dollars to \$12,228,355.

23
24 **Q.** Please summarize your direct testimony.
25

1 **A.** Tampa Electric has complied with the Commission's
2 directions, philosophy, and methodology in its
3 determination of the GPIF. The GPIF is determined by the
4 following formula for calculating Generating Performance
5 Incentive Points (GPIP).

$$\begin{aligned} \text{GPIP} = & (0.0608 \text{ EAP}_{\text{BBCC1}} + 0.1019 \text{ EAP}_{\text{PK2}} \\ & + 0.1702 \text{ EAP}_{\text{BAY1}} + 0.0857 \text{ EAP}_{\text{BAY2}} \\ & + 0.2810 \text{ HRP}_{\text{BBCC1}} + 0.1127 \text{ HRP}_{\text{PK2}} \\ & + 0.1180 \text{ HRP}_{\text{BAY1}} + 0.0696 \text{ HRP}_{\text{BAY2}}) \end{aligned}$$

11
12 Where:

13 GPIP = Generating Performance Incentive Points

14 EAP = Equivalent Availability Points awarded/deducted
15 for Big Bend Unit 1 CC, Polk Unit 2 and Bayside
16 Units 1 and 2.

17 HRP = Average Net Heat Rate Points awarded/deducted for
18 Big Bend Unit 1 CC, Polk Unit 2 and Bayside Units
19 1 and 2.

20
21 **Q.** Have you prepared a document summarizing the GPIF targets
22 for the January 2026 through December 2026 period?

23
24 **A.** Yes. Document No. 2 entitled "Summary of GPIF Targets"
25 provides the availability and heat rate targets for each

1 unit.

2

3 **Q.** Does this conclude your direct testimony?

4

5 **A.** Yes, it does.

6

7

8

9

10

11

12

13

14

15

16

17

18

19

20

21

22

23

24

25

EXHIBIT TO THE TESTIMONY

OF

ADAM L. PARKE

DOCUMENT NO. 1

GPIF SCHEDULES

JANUARY 2026 – DECEMBER 2026

**TAMPA ELECTRIC COMPANY
GENERATING PERFORMANCE INCENTIVE FACTOR
JANUARY 2026 - DECEMBER 2026
TARGETS
TABLE OF CONTENTS**

<u>SCHEDULE</u>	<u>PAGE</u>
GPIF REWARD / PENALTY TABLE	2
GPIF CALCULATION OF MAXIMUM ALLOWED INCENTIVE DOLLARS	3
GPIF TARGET AND RANGE SUMMARY	4
COMPARISON OF GPIF TARGETS VS PRIOR PERIOD ACTUAL PERFORMANCE	5
DERIVATION OF WEIGHTING FACTORS	6
GPIF TARGET AND RANGE SUMMARY	7 - 10
ESTIMATED UNIT PERFORMANCE DATA	11 - 14
ESTIMATED PLANNED OUTAGE SCHEDULE	15
CRITICAL PATH METHOD DIAGRAMS	16 - 19
FORCED & MAINTENANCE OUTAGE FACTOR GRAPHS	20 - 23
HEAT RATE VS NET OUTPUT FACTOR GRAPHS	24 - 27
GENERATING UNITS IN GPIF (TABLE 4.2 IN THE MANUAL)	28
UNIT RATINGS AS OF JULY 2025	29
PROJECTED PERCENT GENERATION BY UNIT	30

TAMPA ELECTRIC COMPANY
GENERATING PERFORMANCE INCENTIVE FACTOR
REWARD / PENALTY TABLE
JANUARY 2026 - DECEMBER 2026

GENERATING PERFORMANCE INCENTIVE POINTS (GPIP)	FUEL SAVINGS / (LOSS) (\$000)	GENERATING PERFORMANCE INCENTIVE FACTOR (\$000)
+10	24,456.7	12,228.4
+9	22,011.0	11,005.5
+8	19,565.4	9,782.7
+7	17,119.7	8,559.8
+6	14,674.0	7,337.0
+5	12,228.4	6,114.2
+4	9,782.7	4,891.3
+3	7,337.0	3,668.5
+2	4,891.3	2,445.7
+1	2,445.7	1,222.8
0	0.0	0.0
-1	(3,788.3)	(1,222.8)
-2	(7,576.6)	(2,445.7)
-3	(11,364.9)	(3,668.5)
-4	(15,153.2)	(4,891.3)
-5	(18,941.5)	(6,114.2)
-6	(22,729.8)	(7,337.0)
-7	(26,518.1)	(8,559.8)
-8	(30,306.4)	(9,782.7)
-9	(34,094.7)	(11,005.5)
-10	(37,883.0)	(12,228.4)

**TAMPA ELECTRIC COMPANY
GENERATING PERFORMANCE INCENTIVE FACTOR
CALCULATION OF MAXIMUM ALLOWED INCENTIVE DOLLARS
JANUARY 2026 - DECEMBER 2026**

Line 1	Beginning of period balance of common equity:	\$	5,882,340	
	End of month common equity:			
Line 2	Month of January	2026	\$	5,936,501,266
Line 3	Month of February	2026	\$	5,993,141,045
Line 4	Month of March	2026	\$	6,047,946,155
Line 5	Month of April	2026	\$	6,102,751,266
Line 6	Month of May	2026	\$	6,159,391,045
Line 7	Month of June	2026	\$	6,214,196,155
Line 8	Month of July	2026	\$	6,269,001,266
Line 9	Month of August	2026	\$	6,325,641,045
Line 10	Month of September	2026	\$	6,380,446,155
Line 11	Month of October	2026	\$	6,435,251,266
Line 12	Month of November	2026	\$	6,491,891,045
Line 13	Month of December	2026	\$	6,546,696,155
Line 14	(Summation of line 1 through line 13 divided by 13)	\$	5,762,210,477	
Line 15	25 Basis points			0.0025
Line 16	Revenue Expansion Factor			74.42%
Line 17	Maximum Allowed Incentive Dollars (line 14 times line 15 divided by line 16)	\$	19,356,023	
Line 18	Jurisdictional Sales		20,781,051	MWH
Line 19	Total Sales		20,781,051	MWH
Line 20	Jurisdictional Separation Factor (line 18 divided by line 19)			100.00%
Line 21	Maximum Allowed Jurisdictional Incentive Dollars (line 17 times line 20)	\$	19,356,023	
Line 22	Incentive Cap (50% of projected fuel savings at 10 GPIF-point level from Sheet No. 3.515)	\$	12,228,355	
Line 23	Maximum Allowed GPIF Reward (at 10 GPIF-point level) (the lesser of line 21 and line 22)	\$	12,228,355	

Note: Line 22 and 23 are as approved by Commission order PSC-13-0665-FOF-EI dated 12/18/13 effective 1/1/14.

TAMPA ELECTRIC COMPANY
GPIF TARGET AND RANGE SUMMARY
JANUARY 2026 - DECEMBER 2026

EQUIVALENT AVAILABILITY

PLANT / UNIT	WEIGHTING FACTOR (%)	EAF TARGET (%)	EAF RANGE		MAX. FUEL SAVINGS (\$000)	MAX. FUEL LOSS (\$000)
			MAX. (%)	MIN. (%)		
BIG BEND CC 1	6.08%	89.0	90.0	87.0	1,487.8	(2,051.1)
POLK 2	10.19%	86.7	88.0	84.1	2,493.0	(5,510.2)
BAYSIDE 1	17.02%	69.6	71.3	66.0	4,162.5	(7,239.2)
BAYSIDE 2	8.57%	90.1	91.6	87.3	2,095.9	(8,865.0)
GPIF SYSTEM	41.87%					

AVERAGE NET OPERATING HEAT RATE

PLANT / UNIT	WEIGHTING FACTOR (%)	ANOHR Btu/kwh	TARGET NOF	ANOHR RANGE		MAX. FUEL SAVINGS (\$000)	MAX. FUEL LOSS (\$000)
				MIN.	MAX.		
BIG BEND CC 1	28.10%	6,403	82.8	6,155	6,652	6,873.0	(6,873.0)
POLK 2	11.27%	7,131	63.5	6,996	7,265	2,755.9	(2,755.9)
BAYSIDE 1	11.80%	7,242	68.4	6,943	7,542	2,886.9	(2,886.9)
BAYSIDE 2	6.96%	7,572	48.8	7,287	7,857	1,701.8	(1,701.8)
GPIF SYSTEM	58.13%						

TAMPA ELECTRIC COMPANY
COMPARISON OF GPIF TARGETS VS PRIOR PERIOD ACTUAL PERFORMANCE

EQUIVALENT AVAILABILITY (%)														
PLANT / UNIT	WEIGHTING FACTOR (%)	NORMALIZED WEIGHTING FACTOR	TARGET PERIOD JAN 26 - DEC 26			ACTUAL PERFORMANCE JAN 24 - DEC 24			ACTUAL PERFORMANCE JAN 23 - DEC 23			ACTUAL PERFORMANCE JAN 22 - DEC 22		
			POF	EUOF	EUOR	POF	EUOF	EUOR	POF	EUOF	EUOR	POF	EUOF	EUOR
BIG BEND CC 1	6.08%	14.5%	7.9	3.0	4.7	6.3	4.2	4.4	10.0	17.5	19.4	NA	NA	NA
POLK 2	10.19%	24.3%	9.0	4.2	4.7	6.4	2.8	3.0	5.3	3.9	4.1	4.6	4.6	4.9
BAYSIDE 1	17.02%	40.7%	28.8	1.7	2.4	4.5	2.4	2.5	7.8	1.3	1.4	21.7	3.5	4.5
BAYSIDE 2	8.57%	20.5%	3.6	6.3	6.5	30.2	15.1	28.2	14.9	1.6	1.9	6.1	3.2	3.4
GPIF SYSTEM	41.87%	100.0%	15.8	3.4	4.1	10.5	5.3	8.2	9.0	4.3	4.8	11.2	3.2	3.7
GPIF SYSTEM WEIGHTED EQUIVALENT AVAILABILITY (%)			80.8			84.2			86.7			85.6		
			3 PERIOD AVERAGE POF EUOF EUOR			3 PERIOD AVERAGE EAF								
			10.2 4.3 5.5			85.5								
AVERAGE NET OPERATING HEAT RATE (Btu/kWh)														
PLANT / UNIT	WEIGHTING FACTOR (%)	NORMALIZED WEIGHTING FACTOR	TARGET HEAT RATE JAN 26 - DEC 26			ADJUSTED ACTUAL PERFORMANCE HEAT RATE JAN 24 - DEC 24			ADJUSTED ACTUAL PERFORMANCE HEAT RATE JAN 23 - DEC 23			ADJUSTED ACTUAL PERFORMANCE HEAT RATE JAN 22 - DEC 22		
BIG BEND CC 1	28.10%	48.3%	6,403			6,475			6,553			6,102		
POLK 2	11.27%	19.4%	7,131			7,218			7,115			7,088		
BAYSIDE 1	11.80%	20.3%	7,242			7,145			7,258			7,342		
BAYSIDE 2	6.96%	12.0%	7,572			7,338			7,568			7,546		
GPIF SYSTEM	58.13%	100.0%												
GPIF SYSTEM WEIGHTED AVERAGE HEAT RATE (Btu/kWh)			6,855			6,858			6,926			6,718		

TAMPA ELECTRIC COMPANY
DERIVATION OF WEIGHTING FACTORS
JANUARY 2026 - DECEMBER 2026
PRODUCTION COSTING SIMULATION
FUEL COST (\$000)

UNIT PERFORMANCE INDICATOR	AT TARGET (1)	AT MAXIMUM IMPROVEMENT (2)	SAVINGS (3)	WEIGHTING FACTOR (% OF SAVINGS)
EQUIVALENT AVAILABILITY				
EA ₃ BIG BEND CC 1	734,055.68	732,567.93	1,487.75	6.08%
EA ₂ POLK 2	734,055.68	731,562.64	2,493.04	10.19%
EA ₃ BAYSIDE 1	734,055.68	729,893.20	4,162.48	17.02%
EA ₄ BAYSIDE 2	734,055.68	731,959.75	2,095.93	8.57%
AVERAGE HEAT RATE				
AHR ₃ BIG BEND CC 1	734,055.68	727,182.72	6,872.95	28.10%
AHR ₂ POLK 2	734,055.68	731,299.81	2,755.87	11.27%
AHR ₃ BAYSIDE 1	734,055.68	731,168.78	2,886.90	11.80%
AHR ₄ BAYSIDE 2	734,055.68	732,353.88	1,701.79	6.96%
TOTAL SAVINGS			24,456.71	100.00%

- (1) Fuel Adjustment Base Case - All unit performance indicators at target.
(2) All other units performance indicators at target.
(3) Expressed in replacement energy cost.

GPIF TARGET AND RANGE SUMMARY

JANUARY 2026 - DECEMBER 2026

BIG BEND CC 1

EQUIVALENT AVAILABILITY POINTS	FUEL SAVINGS / (LOSS) (\$000)	ADJUSTED ACTUAL EQUIVALENT AVAILABILITY	AVERAGE HEAT RATE POINTS	FUEL SAVINGS / (LOSS) (\$000)	ADJUSTED ACTUAL AVERAGE HEAT RATE
+10	1,487.8	90.0	+10	6,873.0	6,155
+9	1,339.0	89.9	+9	6,185.7	6,172
+8	1,190.2	89.8	+8	5,498.4	6,190
+7	1,041.4	89.7	+7	4,811.1	6,207
+6	892.7	89.6	+6	4,123.8	6,224
+5	743.9	89.5	+5	3,436.5	6,242
+4	595.1	89.4	+4	2,749.2	6,259
+3	446.3	89.3	+3	2,061.9	6,276
+2	297.6	89.2	+2	1,374.6	6,294
+1	148.8	89.1	+1	687.3	6,311
					6,328
0	0.0	89.0	0	0.0	6,403
					6,478
-1	(205.1)	88.8	-1	(687.3)	6,496
-2	(410.2)	88.6	-2	(1,374.6)	6,513
-3	(615.3)	88.4	-3	(2,061.9)	6,530
-4	(820.4)	88.2	-4	(2,749.2)	6,548
-5	(1,025.5)	88.0	-5	(3,436.5)	6,565
-6	(1,230.7)	87.8	-6	(4,123.8)	6,582
-7	(1,435.8)	87.6	-7	(4,811.1)	6,600
-8	(1,640.9)	87.4	-8	(5,498.4)	6,617
-9	(1,846.0)	87.2	-9	(6,185.7)	6,635
-10	(2,051.1)	87.0	-10	(6,873.0)	6,652

Weighting Factor =

6.08%

Weighting Factor =

28.10%

TAMPA ELECTRIC COMPANY
GPIF TARGET AND RANGE SUMMARY

JANUARY 2026 - DECEMBER 2026

POLK 2

EQUIVALENT AVAILABILITY POINTS	FUEL SAVINGS / (LOSS) (\$000)	ADJUSTED ACTUAL EQUIVALENT AVAILABILITY	AVERAGE HEAT RATE POINTS	FUEL SAVINGS / (LOSS) (\$000)	ADJUSTED ACTUAL AVERAGE HEAT RATE
+10	2,493.0	88.0	+10	2,755.9	6,996
+9	2,243.7	87.9	+9	2,480.3	7,002
+8	1,994.4	87.8	+8	2,204.7	7,008
+7	1,745.1	87.6	+7	1,929.1	7,014
+6	1,495.8	87.5	+6	1,653.5	7,020
+5	1,246.5	87.4	+5	1,377.9	7,026
+4	997.2	87.2	+4	1,102.3	7,032
+3	747.9	87.1	+3	826.8	7,038
+2	498.6	87.0	+2	551.2	7,044
+1	249.3	86.8	+1	275.6	7,050
					7,056
0	0.0	86.7	0	0.0	7,131
					7,206
-1	(551.0)	86.5	-1	(275.6)	7,211
-2	(1,102.0)	86.2	-2	(551.2)	7,217
-3	(1,653.1)	85.9	-3	(826.8)	7,223
-4	(2,204.1)	85.7	-4	(1,102.3)	7,229
-5	(2,755.1)	85.4	-5	(1,377.9)	7,235
-6	(3,306.1)	85.1	-6	(1,653.5)	7,241
-7	(3,857.2)	84.9	-7	(1,929.1)	7,247
-8	(4,408.2)	84.6	-8	(2,204.7)	7,253
-9	(4,959.2)	84.4	-9	(2,480.3)	7,259
-10	(5,510.2)	84.1	-10	(2,755.9)	7,265
Weighting Factor =		10.19%	Weighting Factor =		11.27%

TAMPA ELECTRIC COMPANY
GPIF TARGET AND RANGE SUMMARY
JANUARY 2026 - DECEMBER 2026

BAYSIDE 1

EQUIVALENT AVAILABILITY POINTS	FUEL SAVINGS / (LOSS) (\$000)	ADJUSTED ACTUAL EQUIVALENT AVAILABILITY	AVERAGE HEAT RATE POINTS	FUEL SAVINGS / (LOSS) (\$000)	ADJUSTED ACTUAL AVERAGE HEAT RATE
+10	4,162.5	71.3	+10	2,886.9	6,943
+9	3,746.2	71.2	+9	2,598.2	6,965
+8	3,330.0	71.0	+8	2,309.5	6,988
+7	2,913.7	70.8	+7	2,020.8	7,010
+6	2,497.5	70.6	+6	1,732.1	7,033
+5	2,081.2	70.4	+5	1,443.4	7,055
+4	1,665.0	70.3	+4	1,154.8	7,078
+3	1,248.7	70.1	+3	866.1	7,100
+2	832.5	69.9	+2	577.4	7,123
+1	416.2	69.7	+1	288.7	7,145
					7,167
0	0.0	69.6	0	0.0	7,242
					7,317
-1	(723.9)	69.2	-1	(288.7)	7,340
-2	(1,447.8)	68.8	-2	(577.4)	7,362
-3	(2,171.7)	68.5	-3	(866.1)	7,385
-4	(2,895.7)	68.1	-4	(1,154.8)	7,407
-5	(3,619.6)	67.8	-5	(1,443.4)	7,430
-6	(4,343.5)	67.4	-6	(1,732.1)	7,452
-7	(5,067.4)	67.1	-7	(2,020.8)	7,475
-8	(5,791.3)	66.7	-8	(2,309.5)	7,497
-9	(6,515.2)	66.4	-9	(2,598.2)	7,520
-10	(7,239.2)	66.0	-10	(2,886.9)	7,542
Weighting Factor =		17.02%	Weighting Factor =		11.80%

TAMPA ELECTRIC COMPANY
GPIF TARGET AND RANGE SUMMARY

JANUARY 2026 - DECEMBER 2026

BAYSIDE 2

EQUIVALENT AVAILABILITY POINTS	FUEL SAVINGS / (LOSS) (\$000)	ADJUSTED ACTUAL EQUIVALENT AVAILABILITY	AVERAGE HEAT RATE POINTS	FUEL SAVINGS / (LOSS) (\$000)	ADJUSTED ACTUAL AVERAGE HEAT RATE
+10	2,095.9	91.6	+10	1,701.8	7,287
+9	1,886.3	91.4	+9	1,531.6	7,308
+8	1,676.7	91.3	+8	1,361.4	7,329
+7	1,467.2	91.1	+7	1,191.3	7,350
+6	1,257.6	91.0	+6	1,021.1	7,371
+5	1,048.0	90.9	+5	850.9	7,392
+4	838.4	90.7	+4	680.7	7,413
+3	628.8	90.6	+3	510.5	7,434
+2	419.2	90.4	+2	340.4	7,455
+1	209.6	90.3	+1	170.2	7,476
					7,497
0	0.0	90.1	0	0.0	7,572
					7,647
-1	(886.5)	89.8	-1	(170.2)	7,668
-2	(1,773.0)	89.6	-2	(340.4)	7,689
-3	(2,659.5)	89.3	-3	(510.5)	7,710
-4	(3,546.0)	89.0	-4	(680.7)	7,731
-5	(4,432.5)	88.7	-5	(850.9)	7,752
-6	(5,319.0)	88.4	-6	(1,021.1)	7,773
-7	(6,205.5)	88.1	-7	(1,191.3)	7,794
-8	(7,092.0)	87.8	-8	(1,361.4)	7,815
-9	(7,978.5)	87.5	-9	(1,531.6)	7,836
-10	(8,865.0)	87.3	-10	(1,701.8)	7,857
Weighting Factor =		8.57%	Weighting Factor =		6.96%

TAMPA ELECTRIC COMPANY
ESTIMATED UNIT PERFORMANCE DATA
JANUARY 2026 - DECEMBER 2026

PLANT/UNIT	MONTH OF:	MONTH OF:	MONTH OF:	MONTH OF:	MONTH OF:	MONTH OF:	MONTH OF:	MONTH OF:	MONTH OF:	MONTH OF:	MONTH OF:	MONTH OF:	PERIOD
BIG BEND CC 1	Jan-26	Feb-26	Mar-26	Apr-26	May-26	Jun-26	Jul-26	Aug-26	Sep-26	Oct-26	Nov-26	Dec-26	2026
1. EAF (%)	96.7	96.7	74.9	48.4	93.6	96.7	96.7	96.7	96.7	81.1	93.5	96.7	89.0
2. POF	0.0	0.0	22.6	50.0	3.2	0.0	0.0	0.0	0.0	16.1	3.3	0.0	7.9
3. EUOF	3.3	3.3	2.5	1.6	3.2	3.3	3.3	3.3	3.3	2.7	3.2	3.3	3.0
4. EUOR	3.3	3.3	3.3	3.3	3.3	3.3	3.3	3.3	3.3	3.3	3.3	3.3	3.3
5. PH	744	672	744	720	744	720	744	744	720	744	720	744	8,760
6. SH	744	601	744	520	744	720	744	744	553	648	720	582	7,713
7. RSH	0	0	0	0	0	0	0	0	0	0	0	0	0
8. UH	0	71	0	200	0	0	0	0	167	96	0	162	1,047
9. POH	0	0	168	360	24	0	0	0	0	120	24	0	696
10. EFOH	13	12	10	6	13	13	13	13	13	11	12	13	140
11. EMOH	11	10	9	6	11	11	11	11	11	10	11	11	124
12. OPER BTU (GBTU)	4,395	3,304	4,220	1,391	3,975	4,139	4,566	4,527	3,192	3,225	3,892	3,298	44,012
13. NET GEN (MWH)	685,795	510,645	654,884	203,163	616,805	649,004	723,336	716,194	500,774	496,033	604,879	511,656	6,873,167
14. ANOHR (Btu/kwh)	6,408	6,470	6,444	6,846	6,444	6,378	6,313	6,321	6,374	6,502	6,434	6,445	6,403
15. NOF (%)	82.3	75.9	78.6	37.0	78.6	85.4	92.2	91.2	85.8	72.6	79.6	78.5	82.8
16. NPC (MW)	1,120	1,120	1,120	1,055	1,055	1,055	1,055	1,055	1,055	1,055	1,055	1,120	1,077
17. ANOHR EQUATION	ANOHR = NOF(-9.677) + 7.204												

TAMPA ELECTRIC COMPANY
ESTIMATED UNIT PERFORMANCE DATA
JANUARY 2026 - DECEMBER 2026

PLANT/UNIT	MONTH OF:	MONTH OF:	MONTH OF:	MONTH OF:	MONTH OF:	MONTH OF:	MONTH OF:	MONTH OF:	MONTH OF:	MONTH OF:	MONTH OF:	MONTH OF:	PERIOD
POLK 2	Jan-26	Feb-26	Mar-26	Apr-26	May-26	Jun-26	Jul-26	Aug-26	Sep-26	Oct-26	Nov-26	Dec-26	2026
1. EAF (%)	89.2	88.5	95.3	95.3	95.3	82.6	83.0	95.3	85.8	83.0	50.8	95.3	86.7
2. POF	6.5	7.1	0.0	0.0	0.0	13.3	12.9	0.0	10.0	12.9	46.7	0.0	9.0
3. EUOF	4.4	4.3	4.7	4.7	4.7	4.0	4.1	4.7	4.2	4.1	2.5	4.7	4.2
4. EUOR	4.7	4.7	4.7	4.7	4.7	4.7	4.7	4.7	4.7	4.7	4.7	4.7	4.7
5. PH	744	672	744	720	744	720	744	744	720	744	720	744	8,760
6. SH	744	212	706	720	700	705	326	744	669	562	339	744	7,004
7. RSH	0	0	0	0	0	0	0	0	0	0	0	0	0
8. UH	0	460	38	0	44	15	418	0	51	182	381	0	1,756
9. POH	48	48	0	0	0	96	96	0	72	96	336	0	792
10. EFOH	12	10	12	12	12	10	11	12	11	11	6	12	132
11. EMOH	21	19	22	22	22	19	20	22	20	20	12	22	240
12. OPER BTU (GBTU)	3,541	1,105	3,155	4,136	3,479	2,891	1,254	4,351	3,516	2,577	1,518	3,876	35,401
13. NET GEN (MWH)	493,699	154,745	438,724	585,978	488,862	402,690	174,222	617,190	495,609	360,693	211,271	541,019	4,964,703
14. ANOHR (Btu/kwh)	7,173	7,143	7,192	7,058	7,116	7,180	7,199	7,050	7,095	7,145	7,183	7,164	7,131
15. NOF (%)	55.6	61.1	52.0	77.1	66.2	54.1	50.7	78.6	70.2	60.8	53.6	57.1	63.5
16. NPC (MW)	1,194	1,194	1,194	1,055	1,055	1,055	1,055	1,055	1,055	1,055	1,163	1,273	1,117
17. ANOHR EQUATION	ANOHR = NOF(-5.342) + 7,470												

TAMPA ELECTRIC COMPANY
ESTIMATED UNIT PERFORMANCE DATA
JANUARY 2026 - DECEMBER 2026

PLANT/UNIT	MONTH OF:	MONTH OF:	MONTH OF:	MONTH OF:	MONTH OF:	MONTH OF:	MONTH OF:	MONTH OF:	MONTH OF:	MONTH OF:	MONTH OF:	MONTH OF:	PERIOD
BAYSIDE 1	Jan-26	Feb-26	Mar-26	Apr-26	May-26	Jun-26	Jul-26	Aug-26	Sep-26	Oct-26	Nov-26	Dec-26	2026
1. EAF (%)	97.6	0.0	0.0	0.0	63.0	97.6	97.6	97.6	97.6	85.0	94.4	97.6	69.6
2. POF	0.0	100.0	100.0	100.0	35.5	0.0	0.0	0.0	0.0	12.9	3.3	0.0	28.8
3. EUOF	2.4	0.0	0.0	0.0	1.5	2.4	2.4	2.4	2.4	2.1	2.3	2.4	1.7
4. EUOR	0.0	0.0	0.0	0.0	2.4	2.4	2.4	2.4	2.4	2.4	2.4	2.4	2.4
5. PH	744	672	744	720	744	720	744	744	720	744	720	744	8,760
6. SH	0	0	0	0	323	720	744	685	543	744	602	245	4,606
7. RSH	726	0	0	0	146	0	0	59	177	0	78	481	1650
8. UH	18	672	744	720	275	0	18	0	0	0	40	18	2,504
9. POH	0	672	744	720	264	0	0	0	0	96	24	0	2,520
10. EFOH	7	0	0	0	4	6	7	7	6	6	6	7	55
11. EMOH	11	0	0	0	7	11	11	11	11	10	10	11	92
12. OPER BTU (GBTU)	0	0	0	0	1,195	2,598	3,435	2,370	2,490	2,672	2,235	876	17,965
13. NET GEN (MWH)	0	0	0	0	164,756	357,444	486,385	324,774	352,221	367,477	308,404	119,039	2,480,500
14. ANOHR (Btu/kwh)	0	0	0	0	7,250	7,268	7,063	7,297	7,069	7,272	7,247	7,356	7,242
15. NOF (%)	0.0	0.0	0.0	0.0	67.6	65.8	86.6	62.8	85.9	65.4	67.9	56.9	68.4
16. NPC (MW)	854	854	854	755	755	755	755	755	755	755	755	854	788
17. ANOHR EQUATION	ANOHR = NOF(-9.872) + 7,917												

TAMPA ELECTRIC COMPANY
ESTIMATED UNIT PERFORMANCE DATA
JANUARY 2026 - DECEMBER 2026


PLANT/UNIT	MONTH OF:	MONTH OF:	MONTH OF:	MONTH OF:	MONTH OF:	MONTH OF:	MONTH OF:	MONTH OF:	MONTH OF:	MONTH OF:	MONTH OF:	MONTH OF:	PERIOD
BAYSIDE 2	Jan-26	Feb-26	Mar-26	Apr-26	May-26	Jun-26	Jul-26	Aug-26	Sep-26	Oct-26	Nov-26	Dec-26	2026
1. EAF (%)	93.5	90.1	81.4	93.5	93.5	93.5	93.5	93.5	93.5	93.5	81.0	81.4	90.1
2. POF	0.0	3.6	12.9	0.0	0.0	0.0	0.0	0.0	0.0	0.0	13.3	12.9	3.6
3. EUOF	6.5	6.3	5.7	6.5	6.5	6.5	6.5	6.5	6.5	6.5	5.7	5.7	6.3
4. EUOR	6.5	6.5	6.5	6.5	6.5	6.5	6.5	6.5	6.5	6.5	6.5	6.5	6.5
5. PH	744	672	744	720	744	720	744	744	720	744	720	744	8,760
6. SH	71	571	335	720	633	623	732	602	660	691	447	137	6,222
7. RSH	624	35	271	0	62	50	0	93	13	4	136	469	1674
8. UH	49	66	138	47	49	47	49	49	47	49	137	138	864
9. POH	0	24	96	0	0	0	0	0	0	0	96	96	312
10. EFOH	8	7	7	8	8	8	8	8	8	8	7	7	92
11. EMOH	41	35	35	39	41	39	41	41	39	41	34	35	460
12. OPER BTU (GBTU)	295	2,617	1,077	3,055	2,225	2,216	3,215	1,918	2,902	2,564	1,363	378	23,929
13. NET GEN (MWH)	38,918	349,400	138,925	410,219	292,353	291,625	433,593	249,719	391,428	338,839	176,779	48,194	3,159,993
14. ANOHR (Btu/kwh)	7,576	7,491	7,753	7,448	7,610	7,600	7,414	7,680	7,413	7,567	7,709	7,836	7,572
15. NOF (%)	48.6	54.2	36.7	57.1	46.3	46.9	59.4	41.6	59.4	49.1	39.6	31.2	48.8
16. NPC (MW)	1,129	1,129	1,129	998	998	998	998	998	998	998	998	1,129	1,041
17. ANOHR EQUATION	ANOHR = NOF(-14.979) + 8,303												

TAMPA ELECTRIC COMPANY
ESTIMATED PLANNED OUTAGE SCHEDULE
GPIF UNITS
JANUARY 2026 - DECEMBER 2026


PLANT / UNIT	PLANNED OUTAGE DATES	OUTAGE DESCRIPTION
+ BB CC1	Mar 22 - May 04	BB CT5 Outage
+ Polk 2 CC	Sep 03 - Nov 21 May 31 - Aug 03	PK CT2 Outage PK CT5 Outage
+ BAYSIDE 1	Feb 01 - May 11	ST1 Major Outage and Refurbishment

+ These units have CPM included. CPM for units with less than or equal to 4 weeks are not included.

TAMPA ELECTRIC COMPANY
CRITICAL PATH METHOD DIAGRAMS
GPIF UNITS > FOUR WEEKS
JANUARY 2026 - DECEMBER 2026




TAMPA ELECTRIC COMPANY
CRITICAL PATH METHOD DIAGRAMS
GPIF UNITS > FOUR WEEKS
JANUARY 2026 - DECEMBER 2026




TAMPA ELECTRIC COMPANY
Polk 2 CC
PLANNED OUTAGE 2026
PROJECTED CPM

TAMPA ELECTRIC COMPANY
CRITICAL PATH METHOD DIAGRAMS
GPIF UNITS > FOUR WEEKS
JANUARY 2026 - DECEMBER 2026




TAMPA ELECTRIC COMPANY
Polk 2 CC
PLANNED OUTAGE 2026
PROJECTED CPM

TAMPA ELECTRIC COMPANY
CRITICAL PATH METHOD DIAGRAMS
GPIF UNITS > FOUR WEEKS
JANUARY 2026 - DECEMBER 2026




TAMPA ELECTRIC COMPANY
BAYSIDE 1
PLANNED OUTAGE 2026
PROJECTED CPM


Big Bend CC 1
EFOR




Big Bend CC 1
EMOR




Polk Unit 2
EFOR




Polk Unit 2
EMOR




Bayside Unit 1
EFOR




Bayside Unit 1
EMOR




Bayside Unit 2
EFOR




Bayside Unit 2
EMOR








**Tampa Electric Company
Heat Rate vs Net Output Factor
Bayside Unit 1**



□ JUL 22 - JUN 23 ○ JUL 23 - JUN 24 △ JUL 24 - JUL 25 — Linear (3 Year Trend)

Tampa Electric Company Heat Rate vs Net Output Factor Bayside Unit 2



**TAMPA ELECTRIC COMPANY
GENERATING UNITS IN GPIF
TABLE 4.2
JANUARY 2026 - DECEMBER 2026**

<u>PLANT / UNIT</u>	<u>ANNUAL GROSS MDC (MW)</u>	<u>ANNUAL NET NDC (MW)</u>
BIG BEND CC 1	1,108	1,077
POLK 2	1,130	1,101
BAYSIDE 1	797	788
BAYSIDE 2	1,053	1,042
GPIF TOTAL	<u>4,088</u>	<u>4,008</u>
SYSTEM TOTAL	6,538	6,431
% OF SYSTEM TOTAL	62.5%	62.3%

TAMPA ELECTRIC COMPANY
UNIT RATINGS
JANUARY 2026 - DECEMBER 2026

<u>PLANT / UNIT</u>	<u>ANNUAL GROSS MDC (MW)</u>	<u>ANNUAL NET NDC (MW)</u>
BAYSIDE 1	797	788
BAYSIDE 2	1,053	1,042
BAYSIDE 3	59	58
BAYSIDE 4	59	58
BAYSIDE 5	59	58
BAYSIDE 6	59	58
BAYSIDE TOTAL	<u>2,084</u>	<u>2,060</u>
BIG BEND 1	1,108	1,077
BIG BEND 4	395	380
BIG BEND CT4	59	58
BIG BEND TOTAL	<u>1,562</u>	<u>1,514</u>
POLK 1	189	187
POLK 2	1,130	1,101
POLK TOTAL	<u>1,318</u>	<u>1,288</u>
SOLAR	1,499	1,495
BATTERY		
SOLAR TOTAL	<u>1,499</u>	<u>1,495</u>
MPS 1 - 4	75	73
MACDILL TOTAL	<u>75</u>	<u>73</u>
SYSTEM TOTAL	<u>6,538</u>	<u>6,431</u>

TAMPA ELECTRIC COMPANY
PERCENT GENERATION BY UNIT
JANUARY 2026 - DECEMBER 2026

PLANT	UNIT	NET OUTPUT MWH	PERCENT OF PROJECTED OUTPUT	PERCENT CUMULATIVE PROJECTED OUTPUT
BIG BEND	1	6,873,167	31.9%	31.9%
POLK	2	4,964,703	23.0%	54.9%
SOLAR		3,158,187	14.7%	69.6%
BAYSIDE	2	3,159,993	14.7%	84.2%
BAYSIDE	1	2,480,500	11.5%	95.8%
BIG BEND	4	691,750	3.2%	99.0%
POLK	1	158,673	0.7%	99.7%
MACDILL	1&2	33,399	0.2%	99.9%
BIG BEND CT	4	9,705	0.0%	99.9%
BAYSIDE	6	6,168	0.0%	99.9%
BAYSIDE	5	6,847	0.0%	100.0%
BAYSIDE	3	4,490	0.0%	100.0%
BAYSIDE	4	2,650	0.0%	100.0%

TOTAL GENERATION	21,550,231	100.0%
------------------	------------	--------

GENERATION BY COAL UNITS: <u>691,750</u> MWH	GENERATION BY NATURAL GAS UNITS: <u>17,700,294</u> MWH
--	--

% GENERATION BY COAL UNITS: <u>3.2%</u>	% GENERATION BY NATURAL GAS UNITS: <u>82.1%</u>
---	---

GENERATION BY SOLAR UNITS: <u>3,158,187</u> MWH	GENERATION BY GPIF UNITS: <u>17,478,363</u> MWH
---	---

% GENERATION BY SOLAR UNITS: <u>14.7%</u>	% GENERATION BY GPIF UNITS: <u>81.1%</u>
---	--

:

EXHIBIT TO THE TESTIMONY

OF

ADAM L. PARKE

DOCUMENT NO. 2

SUMMARY OF GPIF TARGETS
JANUARY 2026 - DECEMBER 2026

TAMPA ELECTRIC COMPANY
SUMMARY OF GPIF TARGETS
JANUARY 2026 - DECEMBER 2026

Unit	Availability			Net Heat Rate
	EAF	POF	EUOF	
Big Bend CC 1¹	89.0	7.9	3.0	6,403
Polk 2²	86.7	9.0	4.2	7,131
Bayside 1³	69.6	28.8	1.7	7,242
Bayside 2⁴	90.1	3.6	6.3	7,572

1 Original Sheet 8.401.20E, Page 12

2 Original Sheet 8.401.20E, Page 13

3 Original Sheet 8.401.20E, Page 14

4 Original Sheet 8.401.20E, Page 15