

ORIGINAL

DEPARTMENT OF STATE
TALLAHASSEE, FLORIDA

98 APR 22 AM 11:31

RECEIVED

FLORIDA PUBLIC SERVICE COMMISSION

UNDOCKETED

RULE TITLE:

RULE NO.:

Flows to be used for Wastewater Treatment
Plant Used and Useful Calculations

25-30.432

PURPOSE AND EFFECT: To adopt a rule specifying the time period to be used in the equation for calculating the used and useful percentage of wastewater treatment plant.

SUBJECT AREA TO BE ADDRESSED: Flow data for calculating wastewater treatment plant used and useful.

SPECIFIC AUTHORITY: 350.127(2), 367.121(1)(f), FS

LAW IMPLEMENTED: 367.081(2), FS

IF REQUESTED AND NOT DEEMED UNNECESSARY BY THE AGENCY HEAD, A RULE DEVELOPMENT WORKSHOP WILL BE HELD AT A TIME, DATE AND PLACE TO BE ANNOUNCED.

THE WORKSHOP REQUEST MUST BE SUBMITTED IN WRITING WITHIN 21 DAYS OF THE DATE OF THIS NOTICE TO THE COMMISSION'S DIVISION OF APPEALS,

ATTENTION CHRISTIANA T. MOORE, 2540 SHUMARD OAK BOULEVARD,
TALLAHASSEE, FL 32399-0850.

THE PERSON TO BE CONTACTED REGARDING THE PROPOSED RULE DEVELOPMENT IS: Robert Crouch, Florida Public Service Commission, 2540 Shumard Oak Blvd., Tallahassee, FL 32399-0862.

THE PRELIMINARY TEXT OF THE PROPOSED RULE DEVELOPMENT IS:

25-30.432 Flow data to be used for Wastewater Treatment Plant

Used and Useful Calculations. The used and useful percentage of wastewater treatment plant shall be calculated using a ratio of actual flows to the permitted plant capacity. The denominator

DOCUMENT NUMBER-DATE

04538 APR 22 88

FPSC REGISTRATION

VCK
AFA
APP
CAF
CMU
CTR
EAG
LTP
LW
OPD
RCH
SEP

shall be the plant capacity as stated on the permit issued by the Department of Environmental Protection (DEP) for the utility's treatment plant. The numerator shall be the flow data stated in the same period or basis as the denominator. If no basis or period is specified on the DEP permit, the maximum monthly average daily flow from the test year shall be used in the numerator.

Specific Authority: 350.127(2), 367.121(1)(f), FS.

Law Implemented: 367.081(2), FS.

History: New _____