

One Energy Place
Pensacola, Florida 32520

850.444.6111



July 19, 1999

Ms. Blanca S. Bayo, Director
Division of Records and Reporting
Florida Public Service Commission
2540 Shumard Oak Boulevard
Tallahassee FL 32399-0870

Dear Ms. Bayo:

RE: COMMISSION STAFF'S MINIMUM FILING REQUIREMENTS IN
SUPPORT OF THE MONTHLY FUEL AND PURCHASED POWER COST
RECOVERY CHARGE IN DOCKET NO. 990001-EI

Attached are the Actual Unit Performance Data Schedules and
the Actual Unit Outage Data Schedules for June, 1999, Retail
Cost Recovery Charges for Plant Crist, Plant Smith, and Plant
Daniel. These schedules are being sent separate from the
monthly filing.

Sincerely,

Susan D. Ritenour

Susan D. Ritenour
Assistant Secretary and Assistant Treasurer

lw

Attachment

cc: Florida Public Service Commission
Sid Matlock

AFA _____
APP _____
CAF _____
CBM _____
CTR _____
EAG _____
LEG _____
MAS _____
OPC _____
RRR _____
SEC _____
WAW _____
OTH _____

MAIL ROOM
99 JUL 20 AM 9 17
FLORIDA PUBLIC SERVICE COMMISSION
DOCUMENT NUMBER-DATE
08592 JUL 20 99
FPSC-RECORDS/REPORTING

ACTUAL UNIT PERFORMANCE DATA

GULF POWER COMPANY

PERIOD OF: January 1999 - December 1999

CRIST 6	Jan '99	Feb '99	Mar '99	Apr '99	May '99	Jun '99							
1. EAF (%)	99.6	100.0	92.5	33.3	95.6	99.8							
2. PH	744.0	672.0	744.0	719.0	744.0	720.0							
3. SH	744.0	672.0	688.2	239.6	734.3	720.0							
4. RSH	0.0	0.0	0.0	0.0	0	0							
5. UH	0.0	0.0	55.8	479.4	9.7	0							
6. POH	0.0	0.0	0.0	479.4	0	0							
7. FOH	0.0	0.0	55.8	0.0	9.7	0							
8. MOH	0.0	0.0	0.0	0.0	0	0							
9. PFOH	6.1	0.0	0.0	1.0	32.5	0							
10. LR pf (MW)	136.0	0.0	0.0	117.0	141.6	0							
11. PMOH	0.0	0.0	0.0	0.0	11.7	2.8							
12. LR pm (MW)	0.0	0.0	0.0	0.0	202.7	122.0							
13. NSC (MW)	302.0	302.0	302.0	302.0	302.0	302.0							
14. Oper MBtu	1438869.0	1403794.0	1555582.0	605673.0	1536238.0	1673530.0							
15. Net Gen (MWH)	132650.0	128788.0	145890.0	57070.0	151329.0	163418.0							
16. ANOHR (Btu/KWH)	10847.0	10900.0	10663.0	10613.0	10152.0	10241.0							
17. NOF %	59.0	63.5	70.2	78.9	68.2	75.2							
18. NPC (MW)	302.0	302.0	302.0	302.0	302.0	302.0							
19. ANOHR Equation	$10\% / AKW * [150.42 - 49.59 * FEB - 32.29 * MAR - 26.52 * APR - 29.06 * MAY - 45.84 * OCT]$ + 9,985												

ACTUAL UNIT PERFORMANCE DATA

GULF POWER COMPANY

PERIOD OF: January 1999 - December 1999

CRIST 7	Jan '99	Feb '99	Mar '99	Apr '99	May '99	Jun '99							
1. EAF (%)	84.9	22.1	87.1	80.3	99.7	87.2							
2. PH	744.0	672.0	744.0	719.0	744.0	720.0							
3. SH	639.2	149.0	653.4	582.0	744.0	629.9							
4. RSH	0.0	0.0	0.0	0.0	0	0							
5. UH	104.8	523.0	90.6	137.0	0	90.1							
6. POH	48.6	523.0	0.0	0.0	0	0							
7. FOH	0.0	0.0	90.6	137.0	0	48.5							
8. MOH	56.2	0.0	0.0	0.0	0	41.6							
9. PFOH	47.8	3.5	21.3	15.8	4.7	13.7							
10. LR pf (MW)	81.8	59.0	128.5	141.0	219.6	79.0							
11. PMOH	0.0	0.0	0.0	0.0	0	0							
12. LR pm (MW)	0.0	0.0	0.0	0.0	0	0							
13. NSC (MW)	495.0	495.0	495.0	495.0	495.0	467.0							
14. Oper MBtu	2302619.0	558976.0	2838943.0	2614743.0	3054672.0	2580422.0							
15. Net Gen (MWH)	224939.0	52587.0	279681.0	257964.0	298853.0	257852.0							
16. ANOHR (Btu/KWH)	10237.0	10630.0	10151.0	10136.0	10221.0	10007.0							
17. NOF %	71.1	71.3	86.5	89.5	81.1	87.7							
18. NPC (MW)	495.0	495.0	495.0	495.0	495.0	467.0							
19. ANOHR Equation	$10^6 / AKW * [299.56 + 157.29 * MAY + 93.18 * JUL + 45.08 * AUG]$ <p>+ 9,485</p>												

ACTUAL UNIT PERFORMANCE DATA

GULF POWER COMPANY

PERIOD OF: January 1999 - December 1999

	Jan '99	Feb '99	Mar '99	Apr '99	May '99	Jun '99							
SMITH 1													
1. EAF (%)	95.9	6.1	0.0	40.7	83.9	100							
2. PH	744.0	672.0	744.0	719.0	744.0	720.0							
3. SH	719.0	41.2	0.0	307.7	625.4	720.0							
4. RSH	0.0	0.0	0.0	0.0	0	0							
5. UH	25.0	630.8	744.0	411.3	118.6	0							
6. POH	0.0	600.0	744.0	306.5	0	0							
7. FOH	25.0	30.8	0.0	104.8	0	0							
8. MOH	0.0	0.0	0.0	0.0	118.6	0							
9. PFOH	8.9	3.0	0.0	52.6	4.8	7.4							
10. LR pf (MW)	20.4	9.0	0.0	30.5	32.9	27.4							
11. PMOH	13.9	0.0	0.0	71.5	0	0							
12. LR pm (MW)	48.3	0.0	0.0	12.0	0	0							
13. NSC (MW)	162.0	162.0	162.0	162.0	162.0	162.0							
14. Oper MBtu	1022368.0	54920.0	0.0	400166.0	889255.0	1084922.0							
15. Net Gen (MWH)	101650.0	5716.0	0.0	40530.0	90110.0	107604.0							
16. ANOHR (Btu/KWH)	10058.0	9608.0	0.0	9873.0	9869.0	10083.0							
17. NOF %	87.3	85.6	0.0	81.3	88.9	92.3							
18. NPC (MW)	162.0	162.0	162.0	162.0	162.0	162.0							
19. ANOHR Equation	$10^6 / AKW * [63.65 + 14.44 * JAN + 17.67 * FEB + 12.53 * MAR + 11.92 * JUL]$ $+ 9,775$												

ACTUAL UNIT PERFORMANCE DATA

GULF POWER COMPANY

PERIOD OF: January 1999 - December 1999

	Jan '99	Feb '99	Mar '99	Apr '99	May '99	Jun '99							
SMITH 2													
1. EAF (%)	99.4	100.0	100.0	100.0	54.3	99.9							
2. PH	744.0	672.0	744.0	719.0	744.0	720.0							
3. SH	742.5	672.0	744.0	719.0	404.2	720.0							
4. RSH	0.0	0.0	0.0	0.0	0	0							
5. UH	1.5	0.0	0.0	0.0	339.8	0							
6. POH	0.0	0.0	0.0	0.0	339.8	0							
7. FOH	1.5	0.0	0.0	0.0	0	0							
8. MOH	0.0	0.0	0.0	0.0	0	0							
9. PFOH	2.3	0.0	0.0	0.0	0	3.6							
10. LR pf (MW)	80.3	0.0	0.0	0.0	0	41.6							
11. PMOH	8.3	0.0	0.0	0.0	0	0							
12. LR pm (MW)	55.0	0.0	0.0	0.0	0	0							
13. NSC (MW)	193.0	193.0	193.0	193.0	193.0	193.0							
14. Oper MBtu	1311903.0	1197565.0	1389169.0	1311974.0	733668.0	1325583.0							
15. Net Gen (MWH)	132222.0	118969.0	138859.0	131743.0	72763.0	130634.0							
16. ANOHR (Btu/KWH)	9922.0	10066.0	10004.0	9959.0	10083.0	10147.0							
17. NOF %	92.3	91.7	96.7	94.9	93.3	94.0							
18. NPC (MW)	193.0	193.0	193.0	193.0	193.0	193.0							
19. ANOHR Equation	$10^6 / AKW * [-14.48 + 15.27 * JAN + 41.91 * MAR + 30.74 * JUL + 25.75 * AUG]$ + 10,284												

ACTUAL UNIT PERFORMANCE DATA

GULF POWER COMPANY

PERIOD OF: January 1999 - December 1999

	DANIEL 1	Jan '99	Feb '99	Mar '99	Apr '99	May '99	Jun '99							
1.	EAF (%)	53.4	89.5	72.9	70.4	80.4	99.5							
2.	PH	744.0	672.0	744.0	719.0	744.0	720.0							
3.	SH	414.9	656.2	577.8	535.5	629.3	720.0							
4.	RSH	0.0	0.0	0.0	0.0	0	0							
5.	UH	329.1	15.8	166.2	183.5	114.7	0							
6.	POH	0.0	0.0	0.0	183.5	0	0							
7.	FOH	179.1	15.8	166.2	0.0	18.2	0							
8.	MOH	150.0	0.0	0.0	0.0	96.5	0							
9.	PFOH	231.9	355.8	190.2	112.5	95.6	36.0							
10.	LR pf (MW)	36.4	73.2	89.8	123.6	167.2	54.2							
11.	PMOH	0.0	0.0	0.0	0.0	0	0							
12.	LR pm (MW)	0.0	0.0	0.0	0.0	0	0							
13.	NSC (MW)	478.0	478.0	478.0	478.0	510.0	510.0							
14.	Oper MBtu	1522450.0	2479138.0	2526087.0	2336804.0	2641153.0	3020785.0							
15.	Net Gen (MWH)	144037.0	240317.0	245007.0	227175.0	251578.0	303866.0							
16.	ANOHR (Btu/KWH)	10570.0	10316.0	10310.0	10286.0	10498.0	9941.0							
17.	NOF %	72.6	76.6	88.7	88.8	78.4	82.8							
18.	NPC (MW)	478.0	478.0	478.0	478.0	510.0	510.0							
19.	ANOHR Equation	$10^6 / AKW * [-39.36 - 41.46 * MAR + 60.97 * OCT]$ $+ 12,144 - 0.00374 * LSRF / AKW$												

ACTUAL UNIT PERFORMANCE DATA

GULF POWER COMPANY

PERIOD OF: January 1999 - December 1999

	DANIEL 2	Jan '99	Feb '99	Mar '99	Apr '99	May '99	Jun '99							
1.	EAF (%)	69.2	11.2	0.0	19.5	93.0	94.7							
2.	PH	744.0	672.0	744.0	719.0	744.0	720.0							
3.	SH	704.7	117.4	0.0	199.5	699.2	710.5							
4.	RSH	0.0	0.0	0.0	0.0	0	0							
5.	UH	39.3	554.6	744.0	519.5	44.8	9.5							
6.	POH	0.0	554.6	744.0	452.8	0	0							
7.	FOH	39.3	0.0	0.0	63.9	0	9.5							
8.	MOH	0.0	0.0	0.0	2.8	44.8	0							
9.	PFOH	687.1	117.4	0.0	122.9	29.6	109.7							
10.	LR pf (MW)	131.9	172.8	0.0	229.5	120.6	134.7							
11.	PMOH	0.0	0.0	0.0	0.0	0	0							
12.	LR pm (MW)	0.0	0.0	0.0	0.0	0	0							
13.	NSC (MW)	478.0	478.0	478.0	478.0	510.0	510.0							
14.	Oper MBtu	2448241.0	425854.0	0.0	689462.0	2960076.0	2902900.0							
15.	Net Gen (MWH)	231504.0	39266.0	0.0	63973.0	296745.0	291267.0							
16.	ANOHR (Btu/KWH)	10575.0	10845.0	0.0	10777.0	9975.0	9966.0							
17.	NOF %	68.7	70.0	0.0	67.1	83.2	80.4							
18.	NPC (MW)	478.0	478.0	478.0	478.0	510.0	510.0							
19.	ANOHR Equation	$10^6 / AKW * [60.76 - 60.56 * JAN - 52.82 * FEB - 44.61 * MAR - 37.43 * OCT]$ $+ 11,284 - 0.00261 * LSRF / AKW$												

