

ORIGINAL



TAMPA ELECTRIC

TAMPA ELECTRIC COMPANY

BEFORE THE

FLORIDA PUBLIC SERVICE COMMISSION

DOCKET NO. 992014-EI

TESTIMONY
AND EXHIBIT OF

MARK D. WARD

DOCUMENT NUMBER-DATE

01212 JAN 27 8

1 BEFORE THE FLORIDA PUBLIC SERVICE COMMISSION

2 PREPARED DIRECT TESTIMONY

3 OF

4 MARK D. WARD

5
6 Q. Please state your name, address and occupation.

7
8 A. My name is Mark D. Ward. My business address is 702
9 North Franklin Street, Tampa, Florida 33602. I am
10 employed by Tampa Electric Company ("Tampa Electric" or
11 "company") as Manager, Energy Supply.

12
13 Q. What is your educational background and business
14 experience?

15
16 A. I received a Bachelor of Science Degree in Mechanical
17 Engineering in 1984 from the University of Alabama in
18 Huntsville. Prior to my employment with Tampa Electric,
19 I held a number of engineering and manager positions with
20 various aerospace companies and the Department of
21 Defense. In 1996, I began my employment as a Consulting
22 Engineer with Tampa Electric's Generation Planning
23 department. In 1997, I was promoted to Manager, Resource
24 Planning. I was responsible for managing Tampa
25 Electric's resource planning activities that included

1 energy resource utilization studies, production cost
2 studies, system reliability studies, and the company's
3 integrated resource planning process. In late 1999, I
4 was promoted to Manager, Energy Supply where I am
5 responsible for coordinating activities associated with
6 repowering Gannon Station ("Gannon Repowering Project").
7

8 Q. Have you previously testified before the Florida Public
9 Service Commission ("Commission")?
10

11 A. Yes. In Docket No. 990001-EI, I supported Tampa
12 Electric's calculation of fuel and purchased power costs
13 associated with the Gannon Unit 6 accident and
14 established that the purchased power agreement between
15 the company and Hardee Power Partners was prudent and
16 reasonable. I have also participated in the Commission's
17 Ten-Year Site Plan review process.
18

19 Q. What is the purpose of your testimony?
20

21 A. The purpose of my testimony is to explain the analytical
22 basis underlying Tampa Electric's conclusion that the
23 Gannon Repowering Project is the most reasonable and
24 prudent means for the company to comply with the
25 requirements of the Consent Final Judgement ("CFJ"),

1 entered into by and between Tampa Electric and the
2 Florida Department of Environmental Protection ("DEP"),
3 while meeting our customers' need for reliable service.
4 My testimony provides an overview of the cost-
5 effectiveness studies developed and utilized including an
6 explanation of the methodology. It also provides a
7 description of the alternatives and assumptions used in
8 the analysis along with sensitivities considered, and a
9 summary of the results. Finally, my testimony provides
10 an overview on how the Gannon Repowering Project impacts
11 Tampa Electric's system and state reliability.
12

13 Q. Have you prepared an exhibit supporting your testimony in
14 this proceeding?
15

16 A. Yes. My Exhibit No. 1 (MDW-1), consisting of one document
17 titled "Gannon Resource Utilization Study", was prepared
18 under my direction and supervision.
19

20 Q. Is this the same "Gannon Resource Utilization Study"
21 originally submitted in this proceeding as "Appendix B"
22 of the "Comprehensive Clean Air Compliance Plan"?
23

24 A. Yes, however, this study has been revised and updated. I
25 will address these changes later in my testimony.

1 Q. What has been Tampa Electric's Resource Planning
2 Department's ("Resource Planning") role in connection
3 with the Gannon Repowering Project?
4

5 A. Resource Planning has always worked closely with the
6 company's Environmental Planning Department in evaluating
7 viable and cost-effective alternatives to comply with
8 environmental requirements. The department had a
9 significant role in evaluating Clean Air Act ("CAA")
10 Phase I and Phase II compliance alternatives and in
11 recommending the company's ultimate compliance plan.
12

13 In addition to the environmental concerns, a significant
14 consideration for the company in reviewing compliance
15 alternatives is the need to provide reliable and cost-
16 effective additions to its mix of generating resources to
17 meet its customers growing demands for electricity.
18 Accordingly, Resource Planning developed and evaluated
19 multiple alternatives that complied with the more
20 stringent environmental requirements of the Environmental
21 Protection Agency ("EPA") and the Florida Department of
22 Environmental Protection ("DEP") while reliably meeting
23 our increasing customer demand at reasonable prices.
24

25 The more stringent environmental requirements proposed by

1 the EPA and the DEP are in relation to the EPA's revised
2 interpretation of maintenance relative to Section 114 of
3 the New Source Review ("NSR") Standards. This
4 interpretation would require Tampa Electric's Gannon
5 Station units to meet the present NSR Standards which are
6 significantly lower than the emissions imposed by the
7 CAA.

8
9 Q. Please describe the methodology typically utilized by
10 Resource Planning in evaluating the most cost-effective
11 alternatives.

12
13 A. Tampa Electric employs an integrated resource planning
14 process as submitted and approved by the Commission in
15 Docket 930551-EG, whereby combinations of supply-side and
16 demand-side resources are evaluated on a fair and
17 consistent basis to satisfy future capacity and energy
18 requirements in a cost-effective and reliable manner.

19
20 PROMOD, a widely used and accepted industry standard
21 production costing computer model developed by New Energy
22 Associates, is used to calculate the fuel and purchased
23 power expense associated with each alternative. PROMOD
24 simulates an economic dispatch for Tampa Electric's
25 generating system based on incremental production energy

1 costs. The PROMOD model is used to simulate unit
2 operating characteristics and system dispatch effects
3 associated with different compliance alternatives.
4

5 PROSCREEN, another widely used and accepted industry
6 standard computer model developed by New Energy
7 Associates, is used to calculate incremental revenue
8 requirements associated with generation capital
9 expenditures, transmission and distribution capital
10 expenditures, generating unit operating and maintenance
11 ("O&M") costs, and sulfur dioxide ("SO₂") allowance costs.
12 PROSCREEN is a planning tool used to evaluate long-range
13 system operating costs associated with particular
14 generation expansion plans.
15

16 As part of the integrated resource planning process,
17 impacts of demand-side management ("DSM") were included
18 in the analysis. For all alternatives, Tampa Electric
19 incorporated the proposed available cost-effective
20 conservation measures that resulted in the Commission-
21 approved DSM goals in Docket No. 971007-EG, Order No.
22 PSC-99-1942-FOF-EG, issued October 1, 1999, and as
23 discussed in the direct testimony of Tampa Electric
24 Witness Howard Bryant.
25

1 Q. Please describe, more specifically, the methodology
2 utilized by Resource Planning in evaluating alternatives
3 given the requirements for reduced emissions while
4 satisfying increasing customer demand for reliable
5 electric service at reasonable costs.

6
7 A. Resource Planning utilized its planning process as
8 described above. First, we identified viable resource
9 alternatives that may meet our dual objectives. We
10 completed a screening process that initially eliminated
11 several resource alternatives because they either failed
12 to meet environmental requirements; failed to meet the
13 company's reliability criteria; were technically
14 infeasible; failed to meet operational criteria (e. g.
15 dispatching flexibility, maintenance scheduling); or
16 showed obvious disadvantages, economic or otherwise,
17 relative to other alternatives.

18
19 A detailed economic analysis was conducted on each
20 alternative that passed the initial screening phase to
21 determine its relative cost-effectiveness. This
22 evaluation compared the cumulative present worth revenue
23 requirements of each alternative against a reference
24 case. The differential between each alternative and the
25 reference case resulted in the "incremental" costs or

1 savings associated with each alternative. The revenue
2 requirements for each alternative included the capital
3 costs associated with generation and transmission
4 resource additions, fixed and variable O&M, and fuel and
5 purchased power expenses. In addition, because some
6 alternatives involved replacing the existing Gannon
7 Station with generation sources located away from Tampa
8 Electric's major load center, other transmission impacts
9 including system losses were quantified for each
10 alternative.

11
12 Q. What common assumptions were used in the analyses?

13
14 A. Resource Planning used several common assumptions for
15 each alternative considered in its analysis. The unit
16 performance parameters for Tampa Electric's existing and
17 planned generating units, including generating unit
18 capacity, heat rate, unit availability, fuel availability
19 and price, were common to each alternative. These
20 assumptions were developed based on historical operating
21 experience, engineering judgment, and planned utilization
22 of the aggregate resources. Specifically, unit capacity
23 and heat rate projections were based on historical unit
24 performance test values that were adjusted as needed for
25 current and planned unit operations. These common

1 assumptions along with the company's customer demand and
2 energy forecast are consistent with those used in Tampa
3 Electric's Fuel and Interchange Forecast for Year 2000 as
4 filed with the Commission in Docket No. 990001-EI.

5
6 Another common assumption relates to our system
7 reliability criteria. Resource Planning used the
8 planning reserve margin adopted by Tampa Electric in
9 December 1999 as a result of a stipulation approved by
10 the Commission. In addition, Tampa Electric informed the
11 Commission in a letter dated December 23, 1999 of its
12 intent to include a minimum seven percent summer supply-
13 side reserve contribution to the minimum 20 percent firm
14 reserve margin target established in the stipulation.
15 The company has until the summer of 2004 to achieve this
16 minimum reserve level, and this level was the basis for
17 adding new resources on the Tampa Electric system for all
18 of the alternatives considered.

19
20 Tampa Electric's Fuels Department developed the fuel
21 assumptions that were used in all of the alternatives.
22 These assumptions were based on the fuel price forecast
23 included in the company's fuel adjustment proceedings and
24 used for internal business planning purposes. This
25 forecast is described in more detail in the direct

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25

testimony of Tampa Electric witness Mark Hornick.

For all alternatives, the incremental transmission system capital improvements and losses associated with each alternative were quantified via transmission load flow analyses. The additional cost for capacity and energy needed to offset the transmission impacts on Tampa Electric's transmission system for each of the alternatives were based on the location of replacement generation sites or replacement power sources. The transmission impacts to Tampa Electric's system are described in more detail in the direct testimony of Tampa Electric Witness Greg Ramon.

Finally, TECO Energy's Treasury Department provided the common financial assumptions including values for tax rates, debt to equity ratio, debt rate, equity rate, preferred rate, discount rate, and Allowance for Funds Used During Construction ("AFUDC") rate. Tampa Electric's Load Forecasting Section provided the inflation and escalation rate assumptions. These assumptions are summarized in Table B-1 on Page B-3 of my Exhibit.

1 Q. Were there any other assumptions that were common to all
2 alternatives considered?

3
4 A. Yes. In accordance with the requirements of the CFJ,
5 nitrogen oxide ("NO_x") control technology must be
6 installed on the Big Bend coal units beginning in 2007
7 with completion by 2010. Although the NO_x control
8 technology has not yet been determined, selective
9 catalytic reduction ("SCR") technology was used as a
10 proxy for the purpose of the analysis. The Environmental
11 Planning Department accordingly estimated the cost of
12 installing and operating SCR systems on the Big Bend
13 units.

14
15 Q. Please describe the initial alternatives you considered.

16
17 A. Resource Planning initially considered a wide range of
18 alternatives. In summary, they included the following
19 with many variations of each:

20
21 • Install environmental controls - Retrofit the Gannon
22 units with flue gas desulfurization ("FGD") and SCRs
23 for SO₂ and NO_x control, respectively.

24
25 • Switch Fuels - Convert Gannon units to burn natural gas

1 instead of coal.

2
3 • Replace Capacity - Shutdown all Gannon Station coal
4 units and build replacement generation.

5
6 • Purchase Power - Shutdown all Gannon Station coal units
7 and purchase replacement power from other Florida
8 resources.

9
10 • Repower Gannon Station - Repower various combinations
11 of the six Gannon coal units utilizing both "F" and "G"
12 combined cycle ("CC") technologies with various in-
13 service dates. Operating assumptions for "F" and "G"
14 series CC units are listed in Table B-3 on Page B-6 of
15 my Exhibit.

16
17 Q. What alternatives were eliminated by your initial
18 screening process and why?

19
20 A. The screening process eliminated alternatives that were
21 technically infeasible; did not comply with environmental
22 regulations; failed to meet the company's reliability
23 criteria; did not meet operational criteria; or had
24 obvious disadvantages, economic or otherwise, over other
25 alternatives.

1 The fuel-switching alternative was eliminated for various
2 reasons. The gas-converted Gannon units, although having
3 efficiencies and fuel prices similar to new combustion
4 turbines ("CTs"), would have higher maintenance costs,
5 potentially lower reliability, and less operating
6 flexibility than new CTs. The resulting higher variable
7 costs of the units would have significant impacts on
8 system dispatch and fuel costs than other alternatives
9 considered. In addition, this fuel-switching alternative
10 may trigger Prevention of Significant Deterioration
11 ("PSD") or NSR permitting which may require the
12 installation of SCRs to meet NO_x emission requirements.
13 The potential capital and O&M costs associated with the
14 environmental equipment and the higher fuel costs of this
15 alternative lead to its elimination from further
16 consideration at that time.

17
18 We also eliminated alternatives that involved shutting
19 down Gannon Station coal units and building replacement
20 generation at the Polk Power Station site or at
21 undetermined greenfield sites. These alternatives were
22 eliminated because of the significant impacts on the
23 statewide transmission grid and the significant costs
24 associated with mitigating these impacts for both Tampa
25 Electric and the state.

1 Several Gannon Station repowering alternatives were
2 eliminated in the initial phase of the process. The
3 operating characteristics of "F" and "G" combined cycle
4 technologies were compared with those of the existing
5 Gannon units to determine the best fit for integrating
6 these technologies with the existing units' equipment.
7 The "G" technology was eliminated due to the equipment
8 manufacturer's reluctance to sell the CTs for repowering
9 applications and our concerns about the limited track
10 record for the technology with so few "G" turbines in
11 service. Gannon Units 1 and 2 were considered less
12 attractive as repowering candidates due to output and
13 operating characteristics. Gannon Units 3 and 4 were
14 chosen over Gannon Unit 6 because of the reliability
15 advantage of having two steam turbines available instead
16 of one.

17
18 Q. Please describe the alternatives that were selected for
19 further evaluation.

20
21 A. From initial evaluations of alternatives, certain
22 variations of alternatives were determined to be
23 potentially feasible solutions for the company. The
24 alternatives selected for final evaluation included the
25 *Environmentally Adjusted Alternative*, the Gannon Non-

1 *Repower Replacement Alternative, the Purchased Power*
2 *Alternative, and the Gannon Repowering Alternative.*

3
4 The *Environmentally Adjusted Alternative*, the reference
5 case, involved retrofitting all six Gannon coal units
6 with FGD and SCR systems to address SO₂ and NO_x emissions,
7 respectively. This reference case was selected for
8 further evaluation because it met the more stringent
9 environmental Best Available Control Technology ("BACT")
10 requirements of the EPA. This alternative enables the
11 company to continue to burn coal and avoids the
12 significant transmission impacts associated with shutting
13 down Gannon Station.

14
15 The *Gannon Non-Repower Replacement Alternative* involved
16 shutting down Gannon Units 1 through 6 over a period of
17 12 months beginning in 2003. The units would be replaced
18 with three "F" technology combined cycle units
19 constructed at the Gannon site. "F" combined cycle
20 technology was chosen for the replacement generation
21 because the technology is currently available and
22 technically proven. The company has experience with this
23 technology from its existing operations at the Polk Power
24 Station and is planning to use "F" technology for the
25 future CTs at the Polk Power Station as well. Therefore,

1 additional opportunities for cost savings in terms of
2 spare parts, operations, etc. are created. In addition
3 to the three replacement units, two CTs with in-service
4 dates of 2003 and 2006 would be constructed at Polk Power
5 Station and a "G" technology combined cycle unit would be
6 built at an undetermined future site in 2007. This "G"
7 Frame machine is a more viable supply option by 2007, at
8 which time the technology should have established an
9 operating and performance history.

10
11 The *Purchased Power Alternative* assumes that Gannon
12 Station's coal units would be shut down and Tampa
13 Electric would enter into one or more long-term purchased
14 power agreements with third parties for replacement
15 power.

16
17 Also selected for further evaluation was the *Gannon*
18 *Repowering Alternative*. This alternative integrates new
19 dual-fueled 7FA CTs, new heat recovery steam generators
20 ("HRSGs"), and the existing steam turbines of Gannon
21 units in a phased repowering to combined cycle.

22
23 The expansion plans associated with each alternative are
24 included in my Exhibit in Table B-4 on Page B-9.

25

1 Q. To evaluate the market for purchase power, did the
2 company assess the long term availability,
3 deliverability, and price for purchase power
4 alternatives?

5
6 A. Yes. Through various sources, Tampa Electric evaluated
7 the availability and all-in costs for Independent Power
8 Producers (IPP) and Utility projects. This information
9 was used to develop a reasonable proxy to establish a
10 baseline for assessing the Purchase Power alternative.

11
12 The evaluation included specific project information
13 including financing structure, capital cost, installation
14 cost, water and land, and expected permitting expense to
15 develop a proxy for the fixed cost component of purchase
16 power. The variable operating expense was developed
17 from generally accepted industry information at
18 comparable operating conditions. The resultant
19 combination of fixed and variable expenses produced an
20 all-in cost (less wheeling) for the Purchase Power
21 alternative. Wheeling charges, transmission impacts, and
22 transmission losses were applied separately in the
23 economics of the Purchase Power alternative.

24
25 Q. Please describe the assumptions used in evaluating the

1 *Purchased Power Alternative.*

2

3 A. Capacity and energy prices for the purchased power were
4 based on published combined cycle technology costs
5 applicable to the Florida market. Installed capital
6 costs, estimated to be \$450 per kilowatt (1999 dollars),
7 included all direct and indirect costs (e.g. owners'
8 costs, switchyard costs, land, interest during
9 construction, etc.). These costs were modeled using the
10 set of representative financing assumptions for third
11 party resources as shown in Table B-2b on Page B-4 of my
12 Exhibit and using a standard discounted cash flow
13 analysis.

14

15 The capacity component of the costs was determined using
16 two constraints. First, the cost for capacity and fixed
17 O&M on a \$/kW/year basis was levelized over the time
18 period of the analysis. Secondly, the resulting internal
19 rate of return ("IRR") of the analysis was equal to the
20 weighted average cost of capital ("WACC").

21

22 The energy component of the power purchase was set equal
23 to the total of variable costs (fuel and variable O&M).
24 By setting the energy component of the purchased power
25 cost equal to variable costs, the analysis simulated an

1 economically efficient energy market that has prices
2 based on marginal costs. Solving for an IRR equal to the
3 WACC provides the minimum additional cash flow that would
4 meet the requirements of equity and debt investors. This
5 approach is conservative in that it simulates the
6 marginal or breakeven investment.

7
8 Since we do not know the location of the ultimate
9 resource(s), an "average" case transmission load flow
10 analysis was performed. It assumed the replacement power
11 would be purchased from several announced projects within
12 Florida. These assumptions and resources are described
13 in more detail in Mr. Ramon's direct testimony. In
14 determining the transmission impacts and wheeling charges
15 associated with the replacement power, a percentage
16 weighting of the total purchased power was estimated from
17 each hypothetical project.

18
19 A financial risk adjustment was also included in the cost
20 of purchased power to capture Tampa Electric's financial
21 risk associated with entering into a long-term contract
22 for purchased power. This adjustment reflects the
23 additional cost associated with maintaining higher equity
24 amounts under the Standard and Poors' methodology. This
25 methodology imputes purchased power capacity payments as

1 a debt equivalent. The rating agencies require
2 additional equity in order to maintain the financial
3 strength needed to justify current bond ratings.
4

5 Q. Are there other costs associated with the Purchased Power
6 Alternative that were not included in the analysis?
7

8 A. Yes. Statewide transmission impacts (i.e. bulk
9 transmission reactive devices and the cost of generation
10 to cover statewide system losses not quantified through
11 contractual energy rates); stranded costs; environmental
12 insurance/indemnification of Tampa Electric by third
13 party power providers to guarantee Tampa Electric's
14 compliance with the CFJ; and dismantling costs were not
15 included in the analysis. These costs were omitted due to
16 the significance of transmission impacts already
17 quantified in the analysis. Omission of these additional
18 costs leads to a more conservative analysis to the
19 benefit of the Purchased Power Alternative.
20

21 Q. Please describe the assumptions used in evaluating the
22 *Gannon Repowering Alternative*.
23

24 A. The *Gannon Repowering Alternative* includes integrating
25 six new dual-fuel fired GE 7FA CTs and six HRSGs with the

1 existing Gannon Units 3, 4 and 5's steam turbines.
2 Specifically the first phase includes integrating three
3 CTs and three HRSGs with the Gannon Unit 5 steam turbine.
4 The second phase of repowering includes integrating three
5 additional CTs and three HRSGs with the existing steam
6 turbines/generators of Gannon Units 3 and 4.

7
8 The repowered Gannon Station generating units would burn
9 natural gas as the primary fuel source and distillate oil
10 as a backup fuel. However, in modeling the fuel costs
11 for these units, it was assumed that the primary fuel was
12 firm natural gas and the secondary fuel was interruptible
13 natural gas with unlimited availability. We assumed
14 100,000 MMBtu/day of firm natural gas with 50,000
15 MMBtu/day dedicated to the first repowered unit and
16 50,000 MMBtu/day dedicated to the subsequent repowered
17 units.

18
19 The repowered Gannon Station unit performance parameters
20 are shown in Table B-3 on Page B-6 of the Exhibit.

21
22 The book values associated with the existing Gannon
23 Station coal-related assets were considered sunk costs
24 and were treated accordingly in the determination of
25 cumulative incremental revenue requirement impacts.

1 However, the impact of recovering these costs on an
2 accelerated schedule due to the earlier retirement of
3 these assets was factored into the analysis.
4

5 Q. With these four remaining alternatives, what process was
6 used to determine the most cost-effective alternative?
7

8 A. A detailed economic analysis was completed to determine
9 the cumulative present worth revenue requirements
10 ("CPWRR") for each alternative. The values were
11 represented in 1999 dollars for comparability.
12

13 Each alternative was compared incrementally to the
14 *Environmentally Adjusted Alternative*, the reference case.
15 The results are shown in the risk curves included in my
16 Exhibit as Figure B-1 on Page B-11.
17

18 In addition, selected sensitivity analyses were completed
19 on each alternative to determine the relative impact that
20 changes in key assumptions might have on the total system
21 revenue requirements.
22

23 Q. Please summarize the results of your analyses.
24
25

1 A. Based upon this analysis, the Gannon Repowering
2 Alternative offered the greatest savings. The savings
3 were \$349.1 million (CPWRR in 1999 dollars) compared to
4 the Environmentally Adjusted Alternative, the reference
5 case. The Non-Repower Alternative and Purchased Power
6 Alternative showed CPWRR savings of approximately \$297.6
7 million and \$12.2 million, respectively, relative to the
8 Environmentally Adjusted Alternative.

9
10 The CPWRR of the Purchased Power Alternative was \$336.9
11 million higher than the Gannon Repowering Alternative.
12 The difference in CPWRR was primarily due to the
13 significant costs associated with maintaining the
14 reliability of the peninsular Florida transmission grid
15 should Gannon Station be shutdown. The incremental
16 transmission capital revenue requirements and
17 transmission system losses alone amounted to \$188.5
18 million (CPWRR) of the total differential between this
19 alternative and the Gannon Repowering Alternative.

20
21 The Gannon Non-Repower Replacement Alternative was closer
22 in cost to the Gannon Repowering Alternative with a
23 differential CPWRR of \$51.5 million. This option showed
24 greater fuel savings over the repowering option due to
25 the utilization of the more efficient "G" combined cycle

1 technology scheduled for in-service by 2007. However,
2 the fuel savings were realized later in the study period
3 and, as a result, the magnitude of the savings was not
4 significant enough to overcome the higher capital and O&M
5 costs of this alternative.
6

7 Q. Did Resource Planning conduct any sensitivities in its
8 cost-effectiveness analyses?
9

10 A. Yes, we conducted sensitivities on SO₂ allowance costs,
11 natural gas transportation charges, and natural gas
12 commodity prices.
13

14 Q. Please summarize the results of these sensitivity
15 analyses.
16

17 A. The first sensitivity was an evaluation utilizing a lower
18 SO₂ allowance price. This sensitivity assumed that the
19 forecasted price of an allowance would eventually
20 approach a value comparable to the operating cost of an
21 FGD system (approximately \$90 per allowance). The re-
22 marketing of excess SO₂ allowances was assumed for each
23 alternative. By lowering the market value of these
24 allowances, the credit back to customers was reduced and,
25 therefore, the overall revenue requirements were higher.

1 This sensitivity increased the incremental CPWRR of each
2 alternative by between \$12.0 and \$13.2 million depending
3 on the alternative relative to the *Environmentally*
4 *Adjusted Alternative*. The *Purchase Power Alternative*
5 exceeds the *Environmentally Adjusted Alternative* by \$1.0
6 million in this sensitivity.

7
8 The second sensitivity assumed higher natural gas
9 transportation costs. Firm gas transportation costs for
10 Tampa Electric's gas-fired units were assumed to be 25
11 cents per MMBtu higher than the base assumption.
12 Relative to the *Environmentally Adjusted Alternative*,
13 this increase in transportation costs increased the
14 incremental CPWRR by approximately \$40.3 million for the
15 *Gannon Repowering Alternative* and \$36.6 million for the
16 *Gannon Non-Repowering Alternative*. The incremental CPWRR
17 of the *Purchased Power Alternative* rose \$57.0 million,
18 \$44.8 million higher than the *Environmentally Adjusted*
19 *Alternative*. The impact to the *Purchased Power*
20 *Alternative* was higher because all gas utilized for
21 purchased power was assumed to be firm, whereas the
22 repower and non-repower replacement options assumed a
23 combination of firm and interruptible gas transportation.

1 The third sensitivity completed assumed a high natural
2 gas price forecast for the commodity only. This resulted
3 in a significant impact to the CPWRR for each
4 alternative. The CPWRR savings decreased by \$207.9 and
5 \$200.5 million for the *Gannon Repowering Alternative* and
6 the *Gannon Non-Repowering Replacement Alternative*,
7 respectively, relative to the *Environmentally Adjusted*
8 *Alternative*. The *Purchased Power Alternative* actually
9 showed a net cost of approximately \$199.4 million,
10 relative to the *Environmentally Adjusted Alternative*.

11
12 Through all sensitivities, the *Gannon Repowering*
13 *Alternative* remained the most cost-effective alternative.
14 This was because each alternative included natural gas-
15 fired combined cycle technology and, therefore, would be
16 impacted similarly by the natural gas and SO₂ allowance
17 sensitivities. The results of the sensitivity analyses
18 are shown in the graphs on Pages B-13 and B-14 of my
19 Exhibit.

20
21 Q. Was a low coal price sensitivity performed?

22
23 A. No. As discussed in Witness Hornick's testimony, coal
24 prices are not expected to fall below current prices.
25

1 Q. Did you conduct a sensitivity to quantify the effect of
2 conservation programs on the alternatives considered by
3 Tampa Electric?
4

5 A. No. The Gannon re-powering project results in an avoided
6 unit with similar characteristics as the avoided unit
7 identified using Tampa Electric's resource plan without
8 the re-powering project. Given this similarity, Witness
9 Bryant's testimony addresses more specifically the fact
10 that there would be a very minimal impact, if any at all,
11 on available conservation. Therefore, Tampa Electric saw
12 no reason to conduct a conservation sensitivity.
13

14 Q. Earlier in this testimony you mentioned your Exhibit had
15 been revised from the original "Gannon Resource
16 Utilization Study". Please describe the revisions.
17

18 A. Minor refinements to the estimates used in the analysis
19 have been incorporated into my testimony. For the
20 Purchase Power Alternative, the associated transmission
21 and distribution capital costs and system transmission
22 loss impacts were better quantified. Minor improvements
23 to the transmission and distribution capital cost in
24 other alternatives were also included. Also, in the
25 original study, the high gas commodity and high gas

1 transportation impacts were not applied to the purchase
2 power case sensitivities.

3
4 Q. Does the *Gannon Repowering Alternative* satisfy Tampa
5 Electric's environmental, reliability, and other
6 operational requirements?

7
8 A. Yes, the *Gannon Repowering Alternative* provides customers
9 of Tampa Electric with the most cost-effective option for
10 significantly reducing emissions while maintaining system
11 generation and transmission reliability and maximizing
12 operational flexibility. Specifically, this alternative
13 is expected to result in reduced emissions of SO₂, NO_x,
14 and PM by as much as 80 percent, 85 percent, and 45
15 percent below 1997 levels, respectively. These meet the
16 DEP's required emission reduction levels.

17
18 From a reliability standpoint, this alternative addresses
19 several issues. By installing highly efficient and
20 reliable natural gas-fired combined cycle technology,
21 concerns over reduced efficiencies and availabilities of
22 aging coal units are addressed.

23
24 The *Gannon Repowering Alternative* also maintains the
25 reliability of the peninsular Florida transmission system

1 in a cost-effective manner and, overall, has the lowest
2 impact to Tampa Electric's and peninsular Florida's
3 transmission system. Significant expenditures would be
4 required to maintain transmission system reliability if
5 an alternative were selected that necessitated shutting
6 down Gannon Station and purchasing replacement power or
7 building replacement capacity at a different site.

8
9 After considering this detailed analysis and all
10 environmental factors and agency requirements, the Gannon
11 Repowering Alternative emerged as the most cost-effective
12 alternative and the best solution for the company.

13
14 Q. Describe in more detail how the Gannon Repowering Project
15 improves Tampa Electric's reliability.

16
17 A. The combined cycle capacity resulting from the Gannon
18 Repowering Project is expected to have an estimated
19 equivalent availability factor ("EAF") of 91 percent.
20 This EAF, approximately 18 percent higher than Gannon
21 Station's current EAF, significantly improves the
22 station's equivalent capacity to serve retail customers.
23 The improved availability results from the differences
24 between natural gas and coal technology and the relative
25 age of the coal-based generating equipment. The higher

1 availability of the repowered units equates to more
2 energy being available during periods of peak operating
3 hours. This reduces Tampa Electric customers' exposure
4 to energy price spikes during periods when capacity is
5 tight or during peak demand conditions.

6
7 Q. Are there other aspects to the Gannon Repowering Project
8 that improve system reliability?

9
10 A. Most likely, yes. Tampa Electric is evaluating a
11 repowered Gannon Unit 5 configuration that will enable
12 one of the three CTs to operate in a simple cycle mode.
13 This would provide 180 MW of available capacity, 24
14 percent of the total capacity, in the event that Unit 5's
15 steam turbine experiences an outage.

16
17 The repowering of Units 3 and 4 involves integrating two
18 steam turbines with three CTs and three HRSGs. In this
19 configuration, if one of the steam turbines is out of
20 service, the three CTs, the three HRSGs and the remaining
21 steam turbine will remain operational at a reduced
22 capacity. Aside from occasional outages, the Gannon
23 Units 3, 4, and 5 steam turbines have historically
24 provided over 99 percent availability. If a CT loss
25 occurs in either repowered unit, the remaining generating

1 equipment will continue to be operational. As stated in
2 the direct testimony of Tampa Electric Witness Charles R.
3 Black, the dual fuel capability will allow the repowered
4 units to operate during short interruptions to the gas
5 supply.

6
7 Q. What effect will this project have on Gannon Station's
8 capacity?

9
10 A. The Gannon Repowering Project will result in increased
11 capacity even though only three of the six existing steam
12 turbines/generators will be utilized. The capacity will
13 increase incrementally by 272 MW (nominal) in 2003 and 23
14 MW (nominal) in 2004 for a total incremental increase of
15 295 MW (nominal) by the completion of the Gannon
16 Repowering Project.

17
18 Q. What impacts will the Gannon Repowering Project have on
19 Tampa Electric's planned reserve margins?

20
21 A. The Gannon Repowering Project enables the company to
22 achieve its 20 percent minimum firm reserve margin for
23 both winter and summer periods by the summer of 2004 in
24 accordance with the stipulation approved by this
25 Commission in the reserve margin docket, PSC 992507-5-EU,

1 issued December 22, 1999. It also helps the company meet
2 its seven percent minimum summer supply-side reserve
3 margin criterion.

4
5 Q. How will the Gannon Repowering Project impact peninsular
6 Florida's reserve margins?

7
8 A. The Gannon Repowering Project's capacity will not only
9 contribute to Tampa Electric's system, but will also
10 contribute to statewide reserve margins by being made
11 available to peninsular Florida's firm customers during
12 emergency capacity and energy conditions.

13
14 Q. Please summarize your testimony.

15
16 A. Tampa Electric has evaluated the most cost-effective
17 means of meeting the stringent environmental requirements
18 of the CFJ while simultaneously satisfying increasing
19 customer demand for reliable electricity at reasonable
20 prices. The company utilized its integrated resource
21 planning process to determine the most cost-effective
22 resource option. As part of the process, common
23 assumptions were developed and applied to a wide range of
24 alternatives. Many alternatives and variations of the
25 alternatives were eliminated from further evaluation if

1 they were technically infeasible; did not comply with
2 environmental regulations; failed to meet the company's
3 reliability criteria; or had obvious disadvantages,
4 economic or otherwise, over other alternatives. As a
5 result, the company further evaluated four viable
6 alternatives; the *Environmentally Adjusted Alternative*,
7 the *Gannon Non-Repower Replacement Alternative*, the
8 *Purchased Power Alternative*, and the *Gannon Repowering*
9 *Alternative*.

10
11 Cost estimates for each alternative were compiled on a
12 CPWRR basis and reported in 1999 dollars. Each
13 alternative was compared incrementally to the
14 *Environmentally Adjusted Alternative*, the reference case,
15 to produce risk curves. Based upon this analysis, the
16 *Gannon Repowering Alternative* was the most cost-effective
17 alternative. Throughout the sensitivity analyses for
18 natural gas commodity and transportation prices, and SO₂
19 allowance prices, the *Gannon Repowering Alternative*
20 remained the most cost-effective alternative. Therefore,
21 after considering this detailed analysis and all
22 environmental factors and agency pressures, it was clear
23 that the *Gannon Repowering Alternative* was the most cost-
24 effective alternative and the best solution for the
25 company, its customers, and the state of Florida.

1 Not only does the Gannon Repowering Project address many
2 requirements of the CFJ entered into by and between Tampa
3 Electric and DEP; it also enhances the company's and
4 peninsular Florida's reliability and enables the company
5 to meet the reserve margin requirements contained in the
6 stipulation approved by this Commission in the reserve
7 margin docket on December 22, 1999. The project will
8 provide incremental capacity that helps Tampa Electric
9 and peninsular Florida achieve the planning reserve
10 margin criteria. Also, the repowered units will have a
11 higher availability and equivalent capacity than the
12 existing Gannon coal-fired units. For all of these
13 reasons, the Gannon Repowering Project is prudent and the
14 most cost effective means for Tampa Electric to achieve
15 compliance with the CAA and the CFJ while reliably
16 serving its customers' growing demand and energy needs.

17
18 Q. Does that conclude your testimony?

19
20 A. Yes it does.
21
22
23
24
25

TAMPA ELECTRIC COMPANY
DOCKET NO. 992014-EI
WITNESS: MARK D. WARD
EXHIBIT NO. _____ (MDW-1)

TAMPA ELECTRIC COMPANY
EXHIBIT OF MARK D. WARD

INDEX

DOCUMENT NO.	TITLE	PAGE
1	Gannon Resource Utilization Study	1

APPENDIX B

GANNON RESOURCE UTILIZATION STUDY

Overview

Tampa Electric periodically completes resource utilization studies, evaluating various planning and operating alternatives to current operations, with objectives ranging from meeting compliance requirements in the most cost-effective and reliable manner to maximizing operational flexibility and minimizing operational costs. The most recent resource utilization study, involving the Gannon coal units, began in late 1998 and continued into 1999.

In the 1998/99 study, Tampa Electric evaluated various options for Gannon Station designed to address a variety of issues. These issues included: the anticipated designation of the Tampa Bay region as an ozone non-attainment area; the anticipated promulgation of new ambient air standards including fine particulate matter (PM_{2.5}); local community environmental issues: the probability of higher natural gas availability (announcements of several proposed pipeline projects had occurred); the reduced efficiency and availability of the aging Gannon units, and the fact that considerable maintenance would be required to maintain acceptable performance levels from these units exacerbating the existing issue with the Environmental Protection Agency (EPA) over its interpretation of maintenance relative to Section 114 of the New Source Review (NSR) Standards

Many alternatives were evaluated in the Gannon utilization study including the following:

- Fuel switching the Gannon units from coal to natural gas;
- Repowering the Gannon coal units;
- Installing flue gas desulfurization (FGD) and selective catalytic reduction (SCR) systems on all of the Gannon coal units;
- Placing Gannon Station on reserve standby and purchasing replacement power to serve Tampa Electric's power requirements; and
- Placing Gannon Station on reserve standby and building replacement generation

Several alternatives were eliminated from further consideration during the initial screening process for various reasons (e.g. cost, technological issues, statewide transmission system reliability issues, etc.). Of the remaining alternatives, the repowering of Gannon Units 3, 4, and 5 was determined to be the most cost-effective alternative while meeting reliability and environmental considerations.

The Gannon utilization study was updated in the fall of 1999 to include NO_x control on the Big Bend coal units as a result of the Consent Final Judgement (CFJ) with the Florida Department of Environmental Protection (DEP) which requires, among other things, the repowering of Gannon Units 3, 4, and 5 by the end of 2004 and the installation of NO_x control technology on the Big Bend coal units beginning in 2007 with completion by the end of 2010. The events leading up to the CFJ are as follows:

On November 3, 1999, despite Tampa Electric's longstanding efforts to reach a mutually agreeable settlement with the EPA, the Department of Justice (DOJ) sued Tampa Electric and seven other electric utilities on behalf of EPA for alleged violations of the Clean Air Act ("CAA") associated with this NSR issue. At issue are the coal-fired Gannon Units 3, 4, and 6, and Big Bend Units 1 and 2.

Following this federal action, DEP also contended that Tampa Electric had not applied for appropriate air permits for certain unit maintenance projects at Gannon and Big Bend Stations and, therefore, had operated the coal-fired units without Best Available Control Technology (BACT) for NO_x, SO₂, and PM. Following negotiations within the CAA 30-day notice period, DEP and Tampa Electric reached a settlement. On December 7, 1999, DEP and Tampa Electric entered into a CFJ which addresses the DEP claims that Tampa Electric modified and then operated its generating units at Big Bend and Gannon without first obtaining permits authorizing the modifications and without installing BACT to control NO_x, SO₂, and PM.

As a key element of the CFJ, all coal-related assets including coal-handling equipment will be retired. The steam turbines/generators and associated non-coal related equipment from Units 1 and 2 will be shut down and placed on reserve standby coincident with the repowering of Unit 5. Unit 6 will be shut down and placed on reserve standby by the end of 2004. These units will be available to Tampa Electric as future supply-side resource options via repowering to meet the growing demand and energy needs of its customers. The company does not currently have plans to utilize the units, but it may, at some time in the future, repower or convert the units to natural gas if those options prove to be cost-effective.

The study was also updated with the most current planning assumptions initially including minimum reliability criteria of 15 percent firm reserve margin with a minimum 7 percent reserve margin from supply-side resources. The reserve margin criteria of 15 percent was subsequently updated to 20 percent based on the stipulation between the FPSC and the three Florida investor owned utilities to carry a 20 percent reserve margin.

Sensitivities on natural gas commodity prices, transportation prices, and SO₂ allowance treatment were included in the study. The Gannon Repowering Alternative remained the most cost-effective alternative in all of these sensitivities.

Assumptions

Economic and Financial Assumptions

- The economic and financial assumptions used to determine the cumulative present worth revenue requirements (CPWRR) associated with each compliance alternative are summarized in Table B-1. This table shows key parameters such as inflation rates, income tax rates, rates of return, other discount rates, and the allowance for funds used during construction (AFUDC) rate.
- Financial assumptions for each alternative evaluated are provided in Tables B-2a and B-2b.

**TABLE B-1
TAMPA ELECTRIC COMPANY
FINANCIAL ASSUMPTIONS**

INFLATION/ESCALATION	
O&M	
1999	1.9%
2000	2.1%
2001+	2.3%
CAPITAL	
1999	1.5%
2000	2.0%
2001+	2.2%
TAX RATE	
OTHER TAXES	1.49%
FEDERAL & STATE	38.58%
FINANCIAL CAPITALIZATION RATIOS	
DEBT	41.80%
PREFERRED	0.00%
COMMON EQUITY	58.20%
RATE OF RETURN	
DEBT	7.75%
PREFERRED	10.66%
COMMON EQUITY	12.75%
DISCOUNT RATE	9.41%
AFUDC RATE	7.79%

TABLE B-2a
TAMPA ELECTRIC COMPANY
COST ASSUMPTIONS FOR COMPLIANCE ALTERNATIVES

COMPONENTS OF COMPLIANCE ALTERNATIVES	GANNON REPOWERING UNIT 3/4 & UNIT 5	COMMON FUTURE CTS (IN ALL EXPANSION PLANS)	GANNON REPLACEMENT PLAN FUTURE CC "F" FRAME	GANNON REPLACEMENT PLAN FUTURE CC "G" FRAME
NOMINAL COST * \$/kW	\$366	\$295	\$439	\$427
ANNUAL FIXED CAPITAL \$9\$000/unit	\$3,454	\$0	\$2,283	\$2,283
ANNUAL FIXED O&M \$9\$000/unit	\$4,600	\$368	\$3,067	\$3,067
VARIABLE O&M \$9\$/MWH	\$0.57	\$2.80	\$0.57	\$0.57
TAX LIFE	20 Years	15 Years	20 Years	20 Years
BOOK LIFE	30 Years	30 Years	30 Years	30 Years
IN-SERVICE DATE	May 2004	Oct 2000	May 2003	Jan 2007

* Nominal costs are based on winter unit capabilities and do not include AFUDC and Transmission & Distribution

TABLE B-2b
TAMPA ELECTRIC COMPANY
COST ASSUMPTIONS FOR PURCHASE POWER ALTERNATIVE

PURCHASED POWER ALTERNATIVE	VALUE
Levelized Capacity Component	73.99 \$/kW-YR
Energy Component (2003\$)	26.07 \$/MWH
Wheeling Component (2003\$)	17.9 \$/kW-YR
CAPITALIZATION RATIOS	
Debt	75.0%
Common Equity	25.0%
RATE OF RETURN	
Debt	8.5%
Common Equity	15.0%
Risk Adjustment Factor Per Standard & Poor's Method	25.0%

Fuel Assumptions

- For the Gannon Repowering Alternative, natural gas availability was assumed to be 100 percent. However, 100,000 MMBtu/day of firm gas was assumed for the Gannon Repowering Alternative with 50,000 MMBtu/day dedicated to the first repowered unit and 50,000 MMBtu/day dedicated to the subsequent repowered units.
- Natural gas transportation costs of \$0.55/MMBtu and \$0.80/MMBtu were used for the base case and high transportation case sensitivity, respectively.
- The fuel assumptions for existing and future units were based on the company's current Fuel and Interchange Forecast for year 2000 and beyond.
- The purchase power fuel availability was assumed to be 100 percent with firm transportation. This assumes that the power provider would not have dual fuel capability.

Environmental Control Technology Assumptions

- Sargent & Lundy was contracted to prepare a study to develop more detailed capital cost estimates, along with schedule, staffing requirements, O&M costs, and thermodynamic performance for the repowering alternative. In addition, another study was performed by Sargent & Lundy to develop cost estimates for retrofitting Gannon Units 5 and 6 with FGD systems and SCR's for use in the previously mentioned environmentally adjusted alternative. The results of this FGD/SCR study were extrapolated for developing estimates for all of the Gannon units.
- Although the NO_x control technology to be utilized with the Big Bend coal units has not yet been determined, an estimated cost of installing SCRs on these units was substituted for the purpose of this analysis.

Load Assumptions

- Load forecasts used in the analysis are from the company's 2000 Fuel and Interchange Forecast.

Unit Operating Assumptions

- Unit operating parameters used in the analysis are from the company's 2000 Fuel and Interchange Forecast
- Operating assumptions for each alternative evaluated are provided in Table B-3.

**TABLE B-3
TAMPA ELECTRIC COMPANY
OPERATING ASSUMPTIONS**

COMPONENTS OF COMPLIANCE ALTERNATIVES	WINTER CAPACITY MW	SUMMER DERATION MW	HEAT RATE* Mbtu/MWh	EQUIVALENT AVAILABILITY FACTOR** %
GANNON REPOWERING				
UNIT 3/4	802	91	7.050	91.0%
UNIT 5	796	98	7.080	91.0%
EXISTING GANNON STATION				
UNIT 1	114	0	11.909	75.6%
UNIT 2	113	0	12.028	66.5%
UNIT 3	155	10	11.413	81.1%
UNIT 4	189	10	11.047	69.8%
UNIT 5	242	10	10.196	75.2%
UNIT 6	392	20	10.376	72.2%
COMMON FUTURE CT'S (In all expansion plans)	180	25	10.580	94.0%
GANNON REPLACEMENT PLAN				
FUTURE CC'S USING GE "F" FRAME CT'S USING WESTINGHOUSE "G" FRAME CT'S	523	78	7.081	91.0%
	675	103	6.590	91.0%

* Heat rates of Gannon Repowering Units 3/4 and 5 are higher heating values (HHV) and based on average ambient temperatures
* EAF's are based on Winter Capacity

Purchased Power Assumptions

- The incremental capital cost of maintaining transmission system reliability of the transmission grid associated with placing Gannon Station on reserve standby was estimated conservatively at \$71 million (20-year CPW in 1999 dollars). This assumes the medium case scenario with firm purchased power being provided from several areas with peninsular Florida.
- In addition to these transmission capital costs required to maintain transmission system reliability, further investigation and consultation with Power Technologies Inc. (PTI) indicates that significant bulk transmission system reactive power devices will be required for TEC or Florida system voltage support. Based on preliminary estimates, these devices could cost as much as \$50 million (20-year CPW in 1999 dollars). Because a detailed analysis of these requirements has not been made, this economic cost was not included in this assessment.

- In evaluating impacts to the state transmission system related to this project, it became apparent that transmission losses will increase well above the amount accounted for by utility transmission tariff loss percentages. Contractual tariff losses were included in the analysis and were quantified with an effective loss rate of 2.17%. However, actual incremental transmission losses throughout the state will greatly exceed this contractual rate. As this is not an actual economic cost to Tampa Electric, it was not included in this assessment.
- Generic assumptions for an IPP-financed combined cycle plant were used to calculate the price of replacement power.
- For the purposes of determining wheeling charges, transmission impacts, and transmission losses associated with replacement power, the power was assumed to be purchased from several power projects throughout Florida that are associated with various independent power producers (i.e. Duke/New Smyrna Beach, Okeechobee Generating Company, Reliant, Constellation and Panda). A percentage, estimated for each project, was utilized to calculate weighted average wheeling charges, transmission losses, and transmission impacts.
- A financial risk adjustment was included in the cost of purchased power to capture the impact on the company related to the financial risk associated with entering a long-term contract for purchased power.

Repowering Assumptions

- Gannon Units 3, 4, and 5 were selected to be repowered based on the generation requirements for meeting expansion plan criteria, the physical operating characteristics of the existing equipment, and the overall condition and age of the existing units.
- The configuration of the repowered units is as follows: The first phase of the repowering includes integrating three new dual-fuel (natural gas and oil) fired GE 7FA combustion turbines and three new heat recovery steam generators (HRSGs) with the existing Gannon Unit 5's steam turbine. The second phase of the repowering includes integrating three more new GE 7FA combustion turbines and three new HRSGs with the two existing steam turbines associated with Gannon Units 3 and 4.
- The capital costs associated with the existing Gannon Station were considered sunk costs, and were treated as such in the determination of customer rates and overall revenue requirement impacts. However, the impact of recovering these dollars on a faster schedule (due to the advanced retirement date) than previous life estimates was factored into the analysis.

Methodology

Initial Screening

Early in the resource utilization study many alternatives were screened on a qualitative and quantitative basis to determine those alternatives that were the most feasible options, overall. Those alternatives that failed to meet environmental acceptability, economics, technical feasibility, operational criteria, maintainability, and reliability were eliminated. This phase of the study resulted in a set of feasible alternatives that were considered in the more detailed economic analysis.

Alternatives Evaluated

A description of the Gannon utilization study alternatives chosen by Tampa Electric for quantitative evaluation are listed below. The generation expansion plans associated with each alternative are shown in Table B-4.

1) Environmentally Adjusted Alternative

This alternative has an all-CT expansion plan. It also includes the installation of environmental equipment that meets the more stringent interpretations of the NSR standards proposed by the EPA. The environmental equipment includes the addition of FGD and SCR systems on all of the Gannon coal units.

In this alternative, NO_x control technology is installed on the Big Bend coal units beginning in 2007 with completion by the end of 2010.

2) Gannon Repowering Alternative

The Gannon Repower Alternative meets the more stringent interpretations of the NSR standards proposed by the EPA and the requirements of the CFJ by repowering Gannon Units 3, 4, and 5 with natural gas-fired technology by the end of 2004. The first phase of the repowering includes integrating three new dual-fuel (natural gas and oil) fired GE 7FA combustion turbines and three new HRSGs with the existing Gannon Unit 5's steam turbine. The second phase of the repowering includes integrating three more new GE 7FA combustion turbines and three new HRSGs with the two existing steam turbines associated with Gannon Units 3 and 4. The Gannon Repowering Alternative also includes the installation of SCR systems for all of the CTs utilized in the repowering.

In this alternative, NO_x control technology is installed on the Big Bend coal units beginning in 2007 with completion by the end of 2010.

3) Gannon Non-Repower Replacement Alternative

The Gannon Non-Repower Replacement Alternative meets the more stringent interpretations of the NSR standards proposed by the EPA by

retiring the existing Gannon coal assets by 2004 and replacing the retired generation with on-site GE 7FA combined cycle technology. The replacement units were all equipped with SCRs.

This alternative also includes NO_x control technology on the Big Bend coal units beginning 2007 with completion by the end of 2010.

4) Purchased Power Alternative

The Purchased Power Alternative meets the more stringent interpretations of the NSR standards proposed by the EPA by retiring the Gannon coal-fired units and purchasing capacity and energy to meet system demand and energy requirements. The transmission cost of maintaining the reliability of the transmission grid associated with the placing Gannon Station on reserve standby was included in this alternative. An adjustment to the cost of purchased power was made to reflect the financial risk to Tampa Electric associated with entering a long-term contract for purchased power.

This alternative also includes NO_x control technology on the Big Bend coal units beginning 2007 with completion by the end of 2010.

**TABLE B-4
TAMPA ELECTRIC COMPANY
EXPANSION PLANS FOR EACH COMPLIANCE ALTERNATIVE**

YEAR	ENVIRONMENTALLY ADJUSTED ALTERNATIVE	GANNON REPOWERING ALTERNATIVE	GANNON NON-REPOWERING REPLACEMENT ALTERNATIVE	PURCHASED POWER ALTERNATIVE
2000	HPS CT2B Polk CT (Oct)	HPS CT2B Polk CT (Oct)	HPS CT2B Polk CT (Oct)	HPS CT2B Polk CT (Oct)
2001	—	—	—	—
2002	Polk CT (May)	Polk CT (May)	Polk CT (May)	Polk CT (May)
2003	Polk CT (May)	Repower 5 (May) LTRS Gannon 1 & 2	Gannon "F" CC Polk CT LTRS Gannon 1, 2, & 5	Firm purchase to replace Gannon Repowering Alternative
2004	Polk CT (May)	Repower 3 & 4 (May) LTRS Gannon 6	2 ea - Gannon "F" CC LTRS Gannon 3, 4, & 6	Firm purchase to replace Gannon Repowering Alternative
2005	Polk CT (May)	Polk CT	—	Polk CT
2006	—	Polk CT	Polk CT	Polk CT
2007	Future Site CT	—	Future Site "G" CC	—
2008	Future Site CT	Polk CT	—	Polk CT
2009	Future Site CT	Future Site CT	—	Future Site CT

Economic Analysis

The analysis compares the related costs of each utilization alternative based on incremental CPWRR. The relative costs were developed on an incremental basis relative to the Environmentally Adjusted Alternative assumptions. The CPWRR include system fuel and purchase power expense, incremental generation capital, incremental transmission and distribution capital, incremental O&M expense, incremental SO₂ allowance costs, depreciation, working capital, incremental transmission losses, transmission wheeling expense and other incremental costs associated with the compliance alternatives and construction of new generating resources.

PROMOD, a production costing computer model, was used to determine fuel and purchased power expense associated with each of the alternatives. PROMOD simulates an economic dispatch of Tampa Electric's generating system based on incremental production costs. In addition to fuel and purchase power expense, PROMOD simulates the unit operating characteristic impacts, and system dispatch effects associated with different compliance alternatives.

PROSCREEN, another planning model, was used to develop incremental capital revenue requirements, SO₂ allowance costs and incremental O&M expense associated with each alternative. The incremental capital revenue requirements and incremental O&M expenses were added to the fuel costs, purchase power expense, incremental transmission wheeling expense, and incremental transmission system losses expense to determine the total revenue requirements of each alternative. Also incorporated were Gannon Station coal working capital reductions, depreciation timing impact associated with the earlier retirement of coal-related Gannon Station assets and the financial risk adjustment associated with purchased power contracts.

The financial risk adjustment was included in the cost of purchased power to capture the impact on the company of the financial risk associated with entering a long term contract for purchased power. This adjustment reflects the additional cost associated with maintaining the higher equity amounts required by rating agencies in order to maintain the financial strength needed to justify current bond ratings. The financial risk adjustment was calculated using Standard and Poors methodology which imputes purchased power capacity payments as a debt equivalent. The financial adjustment represents the imputed cost of this higher source of capital that replaces lower cost debt.

The units to be repowered in the Gannon Repowering Alternative were selected based on the generation requirements for meeting expansion plan criteria, the physical operating characteristics of the existing equipment, and the overall condition and age of the existing units.

Study Results


Base Analysis

The incremental CPWRR in 1999 dollars for all of the alternatives evaluated are provided in Figure B-1. These incremental CPWRR are differentials to the Environmentally Adjusted Alternative and provide a graphical summary of the results from the quantitative analysis. The analysis concluded that the Gannon Repowering Alternative was the most cost-effective option for environmental compliance.

The Environmentally Adjusted Alternative was used as the basis for comparison to each of the other alternatives. The incremental CPWRR of the other alternatives show a savings relative to the Environmentally Adjusted Alternative over the study period.

The incremental CPWRR of the Purchased Power Alternative was \$337.0 million higher than the Gannon Repowering Alternative. This is due primarily to the transmission costs associated with maintaining transmission reliability after Gannon Station is placed on reserve standby.

The Gannon Non-Repower Replacement Alternative was \$51.5 million higher in cost than the Gannon Repowering Alternative. Although this option resulted in lower overall fuel costs due to the higher efficiency of the "G" technology included in the expansion plan, the fuel savings were not great enough to offset the higher capital costs and O&M expense of the Gannon Non-Repower replacement alternative. The capital costs were higher due to expansion plan differences and because the plan did not make use of existing equipment at Gannon Station (i.e. steam turbines). Higher O&M expense was associated with this expansion plan. In the optimization of the expansion plan for this alternative, "G" combined cycle technology was restricted from the early years of the planning window due to technology risk.



Sensitivities

To ensure that the Gannon Repowering Alternative was prudent given a wide range of contingencies, Tampa Electric completed a series of additional analyses incorporating various sensitivities. These additional analyses include sensitivities on lower SO₂ allowance prices and higher natural gas transportation and commodity prices. The results of these sensitivities on the Gannon Repowering Alternative are provided in Figures B-2, B-3, and B-4.



The lower SO₂ allowance price sensitivity assumed that the forecasted price of an allowance would eventually drop to a value that approaches the operating cost of an FGD system on a \$/Ton basis. Remarketing excess SO₂ allowances was assumed in the base analysis of each alternative. By lowering the market value of these allowances, the credit back to the customer is reduced and, therefore, the overall revenue requirements are higher. Relative to the Environmentally Adjusted Alternative, the lower SO₂ allowance reduced the differential CPWRR by approximately \$12.0 million for the Gannon Non-Repowering Alternative and by \$13.2 million dollars for the Gannon Repowering Alternative. The incremental CPWRR of the Purchased Power Alternative was increased by approximately \$13.2 million making it the highest cost alternative at \$1 million over the CPWRR of the Environmentally Adjusted Alternative.


In the higher natural gas transportation sensitivity, transportation costs for Tampa Electric's gas-fired units were assumed to be higher by 25 cents per MMBtu over

the base assumption. Relative to the Environmentally Adjusted Alternative, this increase in transportation cost reduced the CPWRR savings by approximately \$36.6 million for the Gannon Non-Repowering Alternative and by \$40.3 million dollars for the Gannon Repowering Alternative. The Purchased Power Alternative assumed 100 percent firm natural gas whereas the repowering and non-repower replacement alternatives assumed a combination of firm and interruptible gas. Therefore, the increase to the CPWRR of the Purchased Power Alternative was greater at approximately \$57.0 million. This increase changed the order of the alternatives making the Purchased Power Alternative higher in cost by \$44.8 million relative to the Environmentally Adjusted Alternative.

The high natural gas sensitivity used a high price forecast for the commodity only. A significant impact to the CPWRR of each alternative resulted from raising the natural gas price. The incremental CPWRR increased by \$200.5 million for the Gannon Non-Repowering Alternative and by \$207.9 million dollars for the Gannon Repowering Alternative. The incremental CPWRR of the Purchased Power Alternative was increased by approximately \$211.6 million dollars and exceeded the CPWRR of the Environmentally Adjusted Alternative by \$199.4 million. The relative order of the Gannon Non-Repowering and Gannon Repowering alternatives remained the same.

Through all sensitivities the Gannon Repowering Alternative remained the most cost-effective alternative. This was expected considering that each alternative included natural gas-fired combined cycle technology and, therefore, would be impacted similarly by the natural gas and SO₂ allowance sensitivities.





Conclusion

The Gannon Repowering Alternative has been shown to be the most cost-effective option for Tampa Electric's customers when compared to other alternatives. This alternative has significantly lower CPWRR, both annually and over the entire study period, in the base analysis and each sensitivity evaluated.

This alternative would result in significant reductions in SO₂, NO_x, and PM as shown in Figures 7.1, 7.2, and 7.3, respectively, of the Compliance Plan. It is anticipated that emissions of SO₂, NO_x, and PM would be reduced as much as 80 percent, 85 percent, and 45 percent below 1997 levels, respectively. The Gannon Repowering Alternative is also a key component of Tampa Electric's agreement with DEP and meets the more stringent interpretation of the NSR proposed by the EPA.

From a reliability standpoint, this alternative addresses several issues. The issues of reduced efficiency and availability of aging coal units and meeting the incremental power requirements are addressed by installing highly efficient and reliable natural gas-fired combined cycle technology.

The Gannon Repowering Alternative maintains the reliability of the peninsular Florida transmission system in a cost-effective manner and has, overall, the lowest impact to Tampa Electric's transmission system. Significant expenditures would be required to maintain transmission system reliability if an alternative were selected that necessitated

placing Gannon Station on reserve standby (i.e. purchasing replacement power or building replacement capacity at a different site).

Tampa Electric's utilization study concluded that the Gannon Repowering Alternative provides Tampa Electric's customers with the most cost-effective option for significantly reducing emissions while maintaining system reliability, statewide transmission grid reliability, and maximizing operational flexibility.