

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25

TESTIMONY OF DAVID L. ORR
BEFORE THE FLORIDA PUBLIC SERVICE COMMISSION
REGARDING THE APPLICATION FOR INCREASE
IN WATER RATES IN ORANGE COUNTY
BY WEDGEFIELD UTILITIES, INC.
DOCKET NO. 991437-WU

Q. Please state your name and business address.

A. My name is David L. Orr and my business address is 200 Weathersfield Avenue, Altamonte Springs, FL 32714.

Q. By whom are you employed and in what capacity?

A. I am employed by Utilities, Inc., the parent company of Wedgefield Utilities, Inc. Presently, I serve as the Regional Operations Manager and I am responsible for the administration and operation of 36 water and wastewater systems in the counties of Lake, Marion, Orange, and Seminole in Florida. The systems serve from 39 connections up to almost 10,000 connections and are all subsidiaries of Utilities, Inc.

1 **Q. State briefly your professional and educational**
2 **experience.**

3 A. I hold a Bachelor of Science degree in
4 Environmental Engineering from the University of
5 Central Florida. I am currently certified as an
6 Engineer Intern (EI) in the State of Florida, and
7 I am currently pursuing my Masters in Business
8 Administration through Rollins College.
9 Utilities, Inc. employed me in January 1997 in
10 the capacity of Assistant Operations Manager. In
11 that capacity my responsibilities included
12 evaluating the operation of several systems in
13 Florida, assisting in the assimilation of systems
14 after acquisition, and completing special
15 assignments under the direction of the Vice
16 President, Don Rasmussen. In late 1998, I was
17 promoted to the position of Regional Operations
18 Manager assuming responsibility of managing the
19 overall operation of four (4) affiliated
20 companies. In March of 2000, I was asked to
21 manage the 36 systems currently under my
22 direction.

23
24
25

1 **Q. What is the purpose of your testimony?**
2 A. The purpose of my testimony is to address Issues
3 3 and 5 as listed in Appendix A of Order No. PSC-
4 00-1895-PCO-WU, the order establishing procedure
5 for this case. These issues address the
6 determination of used and useful for source of
7 supply and pumping, water treatment, and storage
8 plant as well as the appropriate allowance for
9 unaccounted for water.
10
11 **Q. Did you prepare, or have responsibility for the**
12 **preparation of, any part of the Minimum Filing**
13 **Requirement (MFR) filed in this docket?**
14 A. Yes. I was responsible for the preparation of
15 the Engineering, or "F" Schedules, as well as
16 compiling some of the Additional Engineering
17 Information required by PSC Rule 25-30.440,
18 Florida Administrative Code and submitting the
19 "F" schedules and Additional Engineering
20 Information to our corporate office for inclusion
21 into the final documents. I am co-sponsoring,
22 along with Ms. Nicholas, the Engineering portions
23 of the MFR, which are a part of Exhibit (ELN-
24 1)_____.
25

1 Q. Are you familiar with the testimony filed by Mr.
2 Seidman in this case that addresses Issue Nos. 1
3 and 2 as they regard the appropriate methods for
4 determining used and useful for source of supply
5 and pumping, for water treatment and for storage
6 plant for Wedgefield?

7 A. Yes.

8
9 Q. Do you agree with Mr. Seidman's conclusions, and
10 did you use the methods he recommended, in your
11 calculations?

12 A. Yes to both questions. I compared the maximum
13 level of demand against the firm reliable
14 capacity for each major classification of plant
15 facilities.

16
17 Q. Are you familiar with the testimony filed by Mr.
18 Seidman in this case that addresses Issue No. 4
19 regarding the appropriate period to consider for
20 customer peak demand?

21 A. Yes.

22

23

24

25

1 **Q. And do you agree with Mr. Seidman's conclusion,**
2 **and did you use the period he recommended in your**
3 **calculations?**

4 **A. Again yes to both questions. I used a maximum day**
5 **demand in my calculations.**

6

7 ISSUE NO. 3

8 **Q. Based on the methodologies determined in Issues**
9 **one and two, what is the appropriate used and**
10 **useful percentage for these components of the**
11 **Wedgfield system?**

12 **A. The appropriate used and useful percentage for**
13 **each of the components (source of supply and**
14 **pumping, water treatment, and storage plant) is**
15 **100%.**

16

17 **Q. Are your calculations for the used and useful**
18 **percentage included in the MFR?**

19 **A. Yes. They can be found at Schedule F-5. Schedule**
20 **F-8 is the schedule supporting the calculation of**
21 **customer growth that is an integral part of the**
22 **used and useful calculation, and Schedule F-3**
23 **shows the information on customer demand.**

24

1 **Q. Please explain the used and useful calculation**
2 **for Source of Supply and Pumping Plant (Supply**
3 **Plant) .**

4 A. Used and Useful for Supply Plant was calculated
5 by dividing customer demand by the firm reliable
6 capacity of the supply plant. Public water
7 systems are required to be able to operate with
8 the largest well out of service. Wedgefield has
9 two active wells. So the firm reliable capacity
10 is the capacity of the smaller well, which is 400
11 gpm or 576,000 GPD for a 24-hour day. The
12 customer demand is the sum of the maximum day
13 demand plus fire flow demand plus an allowance
14 for the demand associated with customer growth
15 over the five years after the test year.

16

17 **Q. What was the maximum day demand for the test year**
18 **included in the MFR?**

19 A. The maximum day demand for the test year was
20 583,000 GPD and occurred on July 2, 1998.

21

22 **Q. Do you have any changes to that maximum day**
23 **demand?**

24 A. Yes. I reviewed the maximum day because it
25 occurred in a different month and season than the

1 next five peak days. When I did so, I found the
2 maximum day for the year occurred on a day when
3 flows were being used for a fire. As Mr. Seidman
4 pointed out in his testimony, the maximum day
5 used for used and useful calculations should
6 exclude any abnormal or unusual events. When that
7 was taken into consideration, I determined that
8 the maximum day, with no abnormal or unusual
9 events, was 532,000 GPD and it occurred on April
10 13, 1999. That value should be substituted into
11 my calculation on Schedule F-5.

12

13 **Q. Did you make any adjustments for unaccounted for**
14 **water in the customer demand?**

15 A. No, I did not.

16

17 **Q. Would it be appropriate to do so?**

18 A. I believe it would. Since Wedgefield has been
19 operating the system, we have made an effort to
20 further identify sources of unaccounted for water
21 and reduce it, if economically effective. I will
22 address that subject later in my testimony with
23 regard to Issue No. 5. But, as discussed by Mr.
24 Seidman, we have concluded that a reasonable
25 level of unaccounted for water for this system is

1 13%. This compares to an experienced level during
2 the test year of 27.1%. The difference of 14.1%
3 equates to 40,429 GPD "excess" unaccounted for
4 water for the test year.

5

6 **Q. With all of the factors you have discussed and**
7 **taken into consideration, what is your**
8 **calculation of used and useful for Source of**
9 **Supply and Pumping Plant?**

10 A. The used and useful for Source of Supply and
11 Pumping Plant is 100%. A summary of the
12 calculation, based on the restated Maximum Day
13 Demand and an adjustment for unaccounted for
14 water, is shown on my Exhibit (DLO-1)_____.

15

16 **Q. Now, would you please explain your used and**
17 **useful calculation for Water Treatment Plant?**

18 A. The used and useful for Water Treatment Plant was
19 calculated by dividing customer demand by the
20 firm reliable capacity of the treatment plant,
21 just as was done in calculating the Used and
22 Useful for Supply Plant.

23

24

25

1 **Q. Would you please describe the water treatment**
2 **process at Wedgefield?**

3 A. The water treatment process consists of pre-
4 treatment chlorination of the raw water from the
5 wells followed by aeration, ion exchange, post-
6 treatment chlorination, and then corrosion
7 control inhibitor addition before final
8 distribution to the system. The aeration process
9 performs several functions, the most noticeable
10 to customers being the improvement to taste and
11 odor by the removal of hydrogen sulfide from the
12 water. Most people are familiar with sulfur as
13 being the source of a rotten egg smell. The ion
14 exchange process essentially "softens" the water
15 by removing dissolved minerals. Hard water can
16 have an unacceptable mineral taste and cause
17 scaling on plumbing fixtures, within hot water
18 heaters, and on dishes and glasses. The ion
19 exchange process softens water completely to zero
20 hardness. However, very soft water has its
21 disadvantages also, such as causing corrosion to
22 plumbing fixtures, washing machines and hot water
23 heaters. Because of this, a balance must be
24 maintained. Blending softened water with
25 unsoftened water does this. Water with 150-300

1 mg/L of calcium carbonate (CaCO₃) is considered
2 hard. At Wedgefield, the raw water has a
3 hardness of approximately 270 mg/L. The water is
4 treated and blended to a hardness of
5 approximately 115 mg/L to 135 mg/L, which is
6 considered to be moderately hard. Water with
7 hardness below 75 mg/L is considered soft.
8 Wedgefield keeps the hardness above that level to
9 prevent corrosion problems. Also, we add a
10 polyphosphate solution called Aquadene into the
11 water to assist in providing adequate water
12 quality for our Wedgefield customers.

13
14 **Q. Do many homeowners at Wedgefield have their own**
15 **personal water softeners?**

16 A. Yes. A significant number of the homes that were
17 built before Wedgefield took over operation have
18 water softeners. These homeowners, if they still
19 prefer to soften their water further, need to be
20 sure that they don't over soften their water, or
21 they will experience corrosion problems in their
22 equipment. They should, therefore, try to keep
23 their final water hardness between 75 mg/L and
24 100 mg/L.

25

1 **Q. What is the Firm Reliable Capacity of the**
2 **Treatment Plant as shown on Schedule F-5 of the**
3 **MFR?**

4 A. The Firm Reliable Capacity as shown on Schedule
5 F-5 of the MFR is 500,000 GPD.

6
7 **Q. How did you arrive at that amount?**

8 A. The ion exchange units were refurbished in June,
9 1998, right at the beginning of the test year.
10 The units had not been performing to our
11 satisfaction and were not providing consistent
12 treatment. At the time the MFR's were being
13 prepared, we did not have sufficient operating
14 experience for the refurbished units upon which
15 to base the actual operating capacity. I
16 determined capacity based upon the grains per
17 gallon exchange rate capacity of the ion exchange
18 media as specified by the manufacturer. The
19 resulting capacity was 1,000,000 GPD for the two
20 units, or 500,000 GPD of Firm Reliable Capacity.

21
22
23
24

1 **Q. Has adequate time passed for you to verify the**
2 **actual operating capacity of the units?**

3 A. Yes. The actual hydraulic throughput capacity of
4 the plant is 1,056,000 gallons per day and the
5 Firm Reliable Capacity is 528,000 GPD.

6

7 **Q. How did you arrive at the value of 528,000**
8 **gallons per day?**

9 A. The operation of the ion exchange units has
10 greatly improved since the refurbishment in June
11 of 1998. Currently, we send approximately 200
12 gallons per minute through the ion exchange unit,
13 which results in an output hardness at or near
14 zero mg/L. We blend this with approximately 200
15 gallons per minute of water that bypasses the ion
16 exchange units at a hardness of approximately 270
17 mg/L. We can therefore soften to our desired
18 value of approximately 135 mg/L. This hardness
19 level can be further reduced in the final blended
20 output by throttling back on the bypass and
21 increasing the flow through the ion exchange
22 units. However, this reduces the total
23 throughput of the units because you must increase
24 the head on the pumps on the influent side of the
25 water treatment system.

1 Based upon our operational experience, each unit
2 has the ability to handle 400 gpm total
3 throughput, or 576,000 GPD on a 24 hour basis.
4 However, the resin used in the ion exchange
5 process must be back washed, regenerated and
6 rinsed regularly to remove the impurities
7 collected on them and to maintain their function.
8 These impurities are disposed of by piping them
9 to the wastewater system for treatment. This
10 process requires an average of two hours a day
11 per unit. Therefore, a unit can be available only
12 22 hours a day, which limits the maximum
13 available capacity of a unit to 528,000 GPD.

14

15 **Q. Is the customer demand faced by the Treatment**
16 **Plant the same as for the Supply Plant?**

17 A. Yes, it is.

18

19 **Q. With all of the factors you have discussed and**
20 **taken into consideration, what is your**
21 **calculation of used and useful for Treatment**
22 **Plant?**

23 A. The used and useful for Treatment Plant is 100%.
24 A summary of the calculation, based on the
25 restated Maximum Day Demand and Firm Reliable

1 Capacity, and an adjustment for unaccounted for
2 water is shown on my Exhibit (DLO-1)_____.

3

4 **Q. Now, please address your calculation of used and**
5 **useful for the storage plant. First, would you**
6 **describe the storage tank at Wedgefield?**

7 A. The storage tank at Wedgefield is a little
8 different from the typical tank. It is a double
9 ringed plant. That is, it has an inner tank and
10 an outer tank within the same structure. The
11 inner tank holds the raw water from the wells
12 after aeration and pre-chlorination. The water
13 is then drawn from the inner ring, through the
14 water treatment process and then deposited into
15 the outer ring of the tank as finished water.
16 The total capacity of the tank is 350,000
17 gallons.

18

19 **Q. Why does it have two rings?**

20 A. The inner ring is used to store water that has
21 been aerated and pre-chlorinated, but not treated
22 for hardness. The outer ring is used to store
23 finished water. The purpose of storing pre-
24 treated water is to provide a steady source of
25 aerated and chlorinated water to the ion exchange

1 units. For purposes of emergencies however, the
2 water in both rings is available.

3

4 **Q. What is the Firm Reliable Capacity of the Storage**
5 **Plant?**

6 A. The Firm Reliable Capacity of the Storage Tank is
7 315,000 GPD, which is the total capacity of
8 350,000 GPD less 10% for dead storage. Dead
9 storage is that portion of the bottom of the tank
10 that is below the level of the outlet pipes and
11 cannot be accessed.

12

13 **Q. What is the demand the storage tank must be ready**
14 **to serve?**

15 A. Storage serves several functions. It provides
16 equalization of flow. It provides capacity
17 during an emergency, such as during a plant shut
18 down. And it provides for fire flows that require
19 gpm capacity greater than can be provided
20 directly by the wells and treatment plant. This
21 combined demand is represented by an equalization
22 component equal to one-half of the maximum day
23 demand, an emergency component represented by
24 one-quarter of the maximum day demand and a fire
25 flow component. As with the other components

1 discussed, these demand components are adjusted
2 for growth, fire demand, and unaccounted for
3 water factors.

4

5 **Q. With all of the factors you have discussed and**
6 **taken into consideration, what is your**
7 **calculation of used and useful for Storage Plant?**

8 A. The used and useful for Storage Plant is 100%. A
9 summary of this calculation, based on the
10 restated Maximum Day Demand and an adjustment for
11 unaccounted for water is shown on my Exhibit
12 (DLO-1)_____.

13

14 ISSUE NO. 5

15 **Q. Both you and Mr. Seidman have recommended that a**
16 **13% level of unaccounted for water is appropriate**
17 **for Wedgefield. Do you have some information to**
18 **support that recommendation?**

19 A. Yes. As Mr. Seidman mentioned, we initiated a
20 leak detection program because of our concern
21 that the unaccounted for water level was
22 historically in the 20-30% range. That program
23 included not only leak detection, but also a
24 search for un-metered uses of water. As indicated
25 on Schedule F-1 of the MFR, since the test year

1 we have metered previously un-metered uses that
2 account for about 3% of the gallons pumped. We
3 were also able to detect and repair a significant
4 major leak. We will continue to monitor the
5 system. However, monthly water audits since the
6 end of the test year reflect what has been a
7 reasonable and attainable ongoing level of
8 unaccounted for water. That is a known factor
9 that can now be taken into consideration in the
10 used and useful plant determinations and in
11 adjustments to chemical and electric expenses
12 that are consumption related. I have prepared
13 Exhibit (DLO-2)_____, which summarizes the
14 unaccounted for water levels for the test year,
15 updated for the months since the end of the test
16 year.

17

18 **Q. Have you calculated the volume of "excess"**
19 **unaccounted for water to be used as an adjustment**
20 **to the demand flows?**

21 A. Yes. Consistent with the approach used by the PSC
22 Staff, I multiplied the difference between the
23 27.1 % actual unaccounted for water and the 13%
24 "reasonable" unaccounted for water, times the
25 average daily flow of 286,731 GPD. For purposes

1 of determining used and useful, the "excess"
2 unaccounted for water is $0.141 \times 286,731$ GPD, or
3 40,429 GPD.

4

5 **Q. Does that conclude your direct testimony?**

6 A. Yes it does.

Docket No.: 991437-WU
 David L. Orr, EI
 (DLO-1) Exhibit No.: _____
 Restated Used and Useful Calculations

Restated Used and Useful Calculations for Source of Supply and Pumping Plant, Storage Plant and Water Treatment Plant.

		<u>Test Year</u>
1	Source of Supply and Pumping Plant:	
2	Capacity:	
3	Well No. 1: (400 gpm)	576,000 GPD
4	Well No. 2: (600 gpm)	864,000 GPD
5	Total (1000 gpm)	1,440,000 GPD
6	Largest Well out of Service	(864,000) GPD
7	Firm Reliable Capacity	576,000 GPD
8	Demand:	
9	Maximum Day Demand (4/13/99)	532,000 GPD
10	Property needed, Rule 25-30.431 (5 Year = 13.05%)	69,426 GPD
11	Fire Demand (500 gpm x 2 hours)	60,000 GPD
	Unaccounted For Water Allowance	(40,429)
12	Total	620,997 GPD
13		
14	Used & Useful %	108%
15		
16	Storage Plant:	
17	Capacity:	
18	Ground Storage Tank	350,000 gallons
19	Less 10% Dead Storage	35,000 gallons
20	Firm Reliable Capacity	315,000 gallons
21	Demand:	
22	Emergency (1/2 Maximum Day Demand)	266,000
23	Equilization (1/4 Maximum Day Demand)	133,000
24	Property needed, Rule 25-30.431 (5 Year=13.05%x(Emerg + Equal))	52,070
25	Fire Demand (500 gpm x 2 hours)	60,000
	Unaccounted For Water Allowance	(40,429)
26	Total	470,641
27		
28	Used & Useful %	149%
29		
30	Water Treatment Plant:	
31	Capacity:	
32	Ion Exchange Unit No. 1 (400 gpm x 1320 minutes)	528,000
33	Ion Exchange Unit No. 2 (400 gpm x 1320 minutes)	528,000
34	Total (800 gpm)	1,056,000
35	Largest Unit out of Service	(528,000)
36	Firm Reliable Capacity	528,000
37	Demand:	
38	Maximum Day Demand (4/13/99)	532,000
39	Property needed, Rule 25-30.431 (5 Year = 13.05%)	69,426
40	Unaccounted For Water Allowance	(40,429)
	Fire Demand (500 gpm x 2 hours)	60,000
41	Total	620,997
42		
43	Used & Useful %	118%
44		

Docket No.: 991437-WU
 David L. Orr, EI
 (DLO-2) Exhibit No.: _____
 Unaccounted for Water Calculations

Updated Unaccounted for Water Calculation showing the improvement since previously unmetered uses have been added to the billing system and the effect of repairing the major leak in August 1999.

Month/ Year	(1) Total Gallons Pumped (000,000's)	(2) Gallons Purchased (000,000's)	(3) Gallons Sold (000,000's)	(4) Other Uses (000,000's)	(5) Unaccounted For Water (1)+(2)-(3)-(4) (000,000's)	(6) % Unaccounted For Water
Jul-98	9.195	0	7.114	0.630	1.451	15.8%
Aug-98	7.197	0	5.233	0.004	1.960	27.2%
Sep-98	6.870	0	5.869	0.007	0.994	14.5%
Oct-98	7.688	0	5.832	0.006	1.850	24.1%
Nov-98	7.953	0	6.800	0.002	1.151	14.5%
Dec-98	8.235	0	5.700	0.000	2.535	30.8%
Jan-99	7.852	0	5.689	0.004	2.159	27.5%
Feb-99	7.871	0	5.282	0.006	2.583	32.8%
Mar-99	10.750	0	7.402	0.004	3.344	31.1%
Apr-99	12.256	0	8.551	0.021	3.684	30.1%
May-99	9.892	0	6.047	0.021	3.824	38.7%
Jun-99	8.898	0	6.106	0.004	2.788	31.3%
Total	104.657	0	75.625	0.709	28.323	27.1%

Upon detection of the high unaccounted for water use, a leak detection program was initiated. To date approximately 3% of the annual total gallons pumped has been accounted for through the metering of previously unmetered uses.

In August 1999 a substantial leak was located and repaired. An audit of the system is ongoing.

Jul-99	10.496	0	6.341	0.009	4.146	39.5%
Aug-99	10.070	0	6.524	0.004	3.542	35.2%
Total	20.566	0	12.865	0.013	7.688	37.4%

Since the metered uses were added to the system and the leak fixed in August of 1999.

Sep-99	6.859	0	5.836	0.000	1.023	14.9%
Oct-99	6.541	0	4.581	0.044	1.916	29.3%
Nov-99	6.676	0	6.102	0.004	0.570	8.5%
Dec-99	6.490	0	5.671	0.005	0.814	12.5%
Jan-00	7.003	0	6.884	0.020	0.099	1.4%
Feb-00	7.086	0	7.028	0.023	0.035	0.5%
Mar-00	9.097	0	7.254	0.046	1.797	19.8%
Apr-00	9.442	0	8.635	0.037	0.770	8.2%
May-00	10.926	0	10.199	0.064	0.663	6.1%
Jun-00	10.260	0	8.373	0.014	1.873	18.3%
Jul-00	8.438	0	7.863	0.066	0.509	6.0%
Aug-00	9.120	0	7.519	0.048	1.553	17.0%
Sep-00	7.599	0	5.866	0.000	1.733	22.8%
Total	105.537	0.000	91.811	0.371	13.355	12.7%