

BEFORE THE FLORIDA PUBLIC SERVICE COMMISSION

In Re: Petition for Determination of)
Need for the Osprey Energy Center in)
Polk County by Seminole Electric)
Cooperative, Inc. and Calpine)
Construction Finance Company, L.P.)
_____)

DOCKET NO. 001748 -EC
FILED: December 4, 2000

DIRECT TESTIMONY AND EXHIBITS

OF

KENNETH J. SLATER

ON BEHALF OF

CALPINE CONSTRUCTION FINANCE
COMPANY, L.P.

DOCUMENT NUMBER-DATE

 DEC -4 8

FPSC-REGDORS/REPORTING

IN RE: PETITION FOR DETERMINATION OF NEED
FOR THE OSPREY ENERGY CENTER

DIRECT TESTIMONY OF KENNETH J. SLATER

1 Q: Please state your name and business address.

2 A: My name is Kenneth J. Slater. My business address is 3370
3 Habersham Road, Atlanta, Georgia 30305.

4
5 Q: By whom are you employed and in what positions?

6 A: I am President and Chief Executive Officer of Slater
7 Consulting, which I founded in August 1990. The firm is a
8 small engineering-economic and management consultancy with
9 particular expertise in energy and public utility matters.
10 The services, which the firm offers to various participants in
11 the utility business, include analysis of supply/demand
12 options, reliability, operating situations and events, new
13 technologies and industry developments, strategic decisions,
14 public policy matters and ratemaking issues.

15
16 Q: Please describe your duties with Slater Consulting.

17 A: I am the President and Chief Executive Officer of Slater
18 Consulting. Although I am responsible for the overall
19 management and operation of the Company, I spend most of my
20 time working on client projects.

21

DIRECT TESTIMONY OF KENNETH J. SLATER

PROFESSIONAL QUALIFICATIONS AND EXPERIENCE

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24

Q: Please summarize your educational background and experience.

A: I obtained a Bachelor of Science degree in Pure Mathematics and Physics in 1960 and a Bachelor of Engineering degree in Electrical Engineering in 1962, both at the University of Sydney, Australia. I also received a Master of Applied Science degree in Management Sciences at the University of Waterloo in Ontario, Canada in 1974.

Q: Please summarize your employment history and work experience.

A: I have almost forty years of experience in the energy and utility industries in the United States, Canada and Australia. Prior to founding Slater Consulting, I was Senior Vice President and Chief Engineer at Energy Management Associates, Inc. ("EMA") in Atlanta, where I worked from 1983 to 1990. At EMA, after initially contributing to the firm's utility software development functions, I became the head of its consulting practice, leading or making significant contributions to a number of consulting engagements related to valuation or analysis of power supplies and power supply contracts, supply/demand planning, damages assessments, operating reserve requirements, replacement power cost calculations, utility merger valuations, operational integration of utility systems, power pooling, system

DIRECT TESTIMONY OF KENNETH J. SLATER

1 reliability, ratemaking, power dispatching and gas supply
2 studies. From 1969 until 1983, I worked in the Canadian
3 utility industry. From 1975 to 1983, I ran my own firm,
4 Slater Energy Consultants, Inc., in Toronto, Canada and
5 consulted widely in Canada and the United States for
6 utilities, governments, public enquiry commissions, utility
7 customers and other consulting firms. It was during this time
8 and my time at EMA that I was a major developer of PROMOD
9 III®, (now renamed PROMOD IV®), a widely recognized electric
10 utility planning and reliability model.

11 From 1969 through 1974, I worked as an Engineer, and then
12 as a Senior Engineer at Ontario Hydro, where I headed the
13 Production Development Section of the utility's Operating
14 Department. There I developed computer models, including one
15 which, for more than 20 years, produced the daily generation
16 schedules for the Ontario Hydro system, and another, the
17 original PROMOD, which was used for coordination and
18 optimization of production planning and resource management.
19 In 1974 and 1975, I worked as Manager of Engineering at the
20 Ontario Energy Board (Ontario's utility regulatory commission)
21 and in 1975 and 1976, I served as Research Director for the
22 Royal Commission on Electric Power Planning (also in Ontario).

23 Prior to 1969, I was employed by the Electricity
24 Commission of New South Wales, the largest electric utility in
25 Australia, where I was responsible for the day-to-day

DIRECT TESTIMONY OF KENNETH J. SLATER

1 operation of one of the six regions comprising that system.
2 A copy of my resume' is included as Exhibit KJS-1.

3

4 **Q: Have you previously testified before regulatory authorities or**
5 **courts?**

6 A: Yes. I have provided expert testimony in regulatory
7 proceedings in California, Florida, Georgia, Idaho, Indiana,
8 Iowa, Louisiana, New Mexico, New York, Nova Scotia, Ontario,
9 Pennsylvania, Prince Edward Island, South Carolina, Texas,
10 Virginia, and Wisconsin, and at the Federal Energy Regulatory
11 Commission. I have also appeared in Federal Bankruptcy Court
12 and state courts in Florida, Nebraska, Texas and Virginia, and
13 in civil arbitration proceedings in Louisiana, Nevada, New
14 England, and Pennsylvania. I have also served on many
15 occasions as an expert examiner for a Royal Commission in
16 Ontario that was charged with studying and evaluating electric
17 power planning in the Province of Ontario. I have also served
18 as a member of a panel of arbitrator/valuers in a proceeding
19 under the American Arbitration Association concerned with the
20 value of a cogeneration plant.

21

22 **Q: Are you a registered professional engineer?**

23 A: Yes, I am a registered professional engineer in Ontario.

24

DIRECT TESTIMONY OF KENNETH J. SLATER

PURPOSE AND SUMMARY OF TESTIMONY

1

2 **Q: What is the purpose of your testimony in this proceeding?**

3 **A:** I am testifying on behalf of Calpine Construction Finance
4 Company, L.P. ("Calpine") to provide the results of various
5 analyses, prepared by me or under my direction and
6 supervision, that address various aspects of the Osprey Energy
7 Center (the "Osprey Project" or simply the "Project") and its
8 projected impacts on the Peninsular Florida power supply
9 system. Specifically, my testimony addresses:

- 10 1. how the Osprey Project will operate in the Peninsular
11 Florida power supply system;
- 12 2. the impacts that the Osprey Project will have on overall
13 fuel consumption, power supply costs, and emissions from
14 electricity generation for Peninsular Florida power
15 supply;
- 16 3. the cost-effectiveness of the Osprey Project as a power
17 supply resource for Peninsular Florida; and
- 18 4. the impact of the Osprey Project's presence on Peninsular
19 Florida reserves and reliability.

20

21 **Q: Please summarize your understanding of the Osprey Project.**

22 **A:** I understand the Osprey Project to be a 529 megawatt ("MW")
23 natural gas-fired combined cycle electric generating plant
24 that will be located in Auburndale, Florida, and

DIRECT TESTIMONY OF KENNETH J. SLATER

1 inter-connected to the Peninsular Florida power supply grid at
2 the Recker Substation of Tampa Electric Company ("TECO"). The
3 Project will have summer generating capability of
4 approximately 496 MW and winter capability of approximately
5 578 MW, without duct-firing and power augmentation. The
6 Project will utilize advanced technology Siemens-Westinghouse
7 Model 501F combustion turbines in a combined cycle
8 configuration. This design is typical of modern, efficient,
9 advanced technology power plants. Finally, although the fact
10 does not impact my analyses, because my analyses address the
11 operation of the Osprey Project within Peninsular Florida
12 considered as a whole, I understand that Calpine will sell 350
13 MW of firm capacity and associated energy to Seminole
14 beginning in 2004.

15
16 **Q: Please summarize the main conclusions of your testimony.**

17 **A:** My staff and I prepared analyses of the Peninsular Florida
18 power supply system with and without the Osprey Project using
19 the PROMOD IV® production modeling program. Based on these
20 analyses, it is my opinion that the Osprey Project will make
21 significant and economically valuable contributions to the
22 Peninsular Florida power supply system. Even modeled with
23 conservative assumptions, the Osprey Project is projected:

24 1. to operate at annual capacity factors between 86 and 93

DIRECT TESTIMONY OF KENNETH J. SLATER

1 percent for the entire analysis period, which in our
2 modeling was the first ten years of the Project's
3 commercial life;

4 2. to provide significant savings -- 6 trillion to 9
5 trillion Btu per year -- of primary energy used to
6 generate electricity for use in Peninsular Florida;

7 3. to result in significant savings of petroleum fuels and
8 coal;

9 4. to improve the overall efficiency of electricity
10 production and natural gas use in and for Peninsular
11 Florida;

12 5. to result in wholesale power supply cost savings of
13 approximately \$794 million (Net Present Value) over the
14 first ten years of the Projects's operations;

15 6. to provide enhanced reliability of the power supply
16 system in Peninsular Florida; and

17 7. to result in significant reductions -- approximately
18 8,000 to 23,000 tons per year -- in combined emissions of
19 sulfur dioxide and nitrogen oxides from the generation of
20 Peninsular Florida's power supply.

21 The results are substantially the same under both our
22 base case assumptions and under "sensitivity cases" that we
23 modeled in which we analyzed the Project's operations and
24 impacts assuming a higher natural gas price forecast, lower
25 load growth, and higher load growth in Peninsular Florida.

DIRECT TESTIMONY OF KENNETH J. SLATER

1 Q: Are you sponsoring any exhibits to your testimony?

2 A: Yes. I am sponsoring the following exhibits.

3 KJS-1. Resume' of Kenneth John Slater.

4 KJS-2. Fuel Price Assumptions for PROMOD IV® Analyses of
5 Osprey Project Operations.

6 KJS-3. Efficiency and Cost-Effectiveness of Peninsular
7 Florida Generating Units, 2003.

8 KJS-4. Efficiency and Cost-Effectiveness of Peninsular
9 Florida Generating Units, 2008.

10 KJS-5. Peninsular Florida Summary of Existing Capacity As
11 of January 1, 2000.

12 KJS-6. Peninsular Florida, Historical and Projected Summer
13 and Winter Firm Peak Demands, 1991-2012.

14 KJS-7. Peninsular Florida, Historical and Projected Net
15 Energy for Load and Number of Customers, 1991-2012.

16 KJS-8. Osprey Energy Center - Summary of Projected
17 Operations, 2003-2012.

18 KJS-9. Osprey Energy Center - Summary of Projected
19 Operations, 2003-2012, Higher Natural Gas Price
20 Sensitivity Analysis.

21 KJS-10. Osprey Energy Center - Summary of Projected
22 Operations, 2003-2012, Load Growth Sensitivity
23 Analyses.

24 KJS-11. Illustration of Impacts of Osprey Energy Center on

DIRECT TESTIMONY OF KENNETH J. SLATER

- 1 Operations of Other Peninsular Florida Power
2 Plants.
- 3 KJS-12. Market Indicators - Average Electric Production
4 Costs by NERC Region, 1997-1999.
- 5 KJS-13. Peninsular Florida, Impacts of Osprey Energy Center
6 on Average Electricity Generation Heat Rates and
7 Total Fuel Consumption, 2003-2012.
- 8 KJS-14. Peninsular Florida, Fuel Consumption Impacts of
9 Osprey Energy Center, 2003-2012.
- 10 KJS-15. Peninsular Florida, Summary of Projected Wholesale
11 Energy Cost Savings Due to Osprey Energy Center,
12 Base Case, 2003-2012.
- 13 KJS-16. Peninsular Florida, Summary of Projected Wholesale
14 Energy Cost Savings Due to Osprey Energy Center,
15 Higher Fuel Price Sensitivity Case, 2003-2012.
- 16 KJS-17. Peninsular Florida, Summary of Projected Wholesale
17 Energy Cost Savings Due to Osprey Energy Center,
18 Low Load Growth Sensitivity Case, 2003-2012.
- 19 KJS-18. Peninsular Florida, Summary of Projected Wholesale
20 Energy Cost Savings Due to Osprey Energy Center,
21 High Load Growth Sensitivity Case, 2003-2012.
- 22 KJS-19. Comparison of Peninsular Florida Planned and
23 Proposed Generating Units.
- 24 KJS-20. Summary of Peninsular Florida Capacity, Demand, and
25 Reserve Margin at Time of Summer Peak, Without and

DIRECT TESTIMONY OF KENNETH J. SLATER

1 With Osprey Energy Center.

2 KJS-21. Summary of Peninsular Florida Capacity, Demand, and
3 Reserve Margin at Time of Winter Peak, Without and
4 With Osprey Energy Center.

5 KJS-22. Peninsular Florida, Emissions Impacts of Osprey
6 Energy Center, 2003-2012.

7 I am also sponsoring the projected annual output values
8 in Table II-2 in Volume II of the Exhibits in support of
9 Seminole's and Calpine's joint petition for determination of
10 need for the Osprey Energy Center (the "Joint Petition") filed
11 on December 4, 2000 (the "Joint Petition") and Tables II-4,
12 II-5, II-6, II-7, II-8, II-9, II-10, II-11, II-12, II-13.A,
13 II-13.B, II-14, II-15.A, II-15.B, II-16, II-17, II-18.A, II-
14 II-18.B, and II-18.C of those Exhibits. I am also sponsoring
15 the text associated with these tables in Volume II of the
16 Exhibits to the Joint Petition, and Appendix II-C to those
17 Exhibits, which is titled DESCRIPTION of PROMOD IV® GENERATION
18 MODELING PROGRAM.

19

20 MODELS, ASSUMPTIONS, AND METHODOLOGY

21 Q: How did you analyze the operations of the Osprey Project
22 within the Peninsular Florida power supply system and the
23 impacts of the Project on that system?

24 A: Under my direction and supervision, Slater Consulting prepared

DIRECT TESTIMONY OF KENNETH J. SLATER

1 several analyses of the Peninsular Florida power supply
2 system, both with and without the Osprey Project, using the
3 PROMOD IV® computer modeling program. Our analyses treated
4 the Peninsular Florida power supply system as an integrated
5 system. Our analyses studied the period beginning with the
6 first year that the Osprey Project is expected to be in
7 service and continued for ten years. Thus, our analyses begin
8 with the Osprey Project coming into commercial service in 2003
9 and continue through 2012. I should note that our analyses
10 actually covered the period through 2014 in order to avoid
11 certain artificial results that may occur in power system
12 modeling when the system is modeled as effectively "shutting
13 down" at the end of the analysis period. (This can occur
14 because if the model is programmed not to have to serve load
15 after a certain date, it will simply postpone maintenance.)

16 The analyses that we performed included a base case and
17 three sensitivity cases, one with a higher natural gas price
18 forecast, one with a lower load growth forecast, and one with
19 a higher load growth forecast.

20

21 **Q: Please briefly describe the PROMOD IV® computer model,**
22 **including a summary of the main input variables used by the**
23 **model and the main output data produced by the model.**

24 **A: PROMOD IV® is a widely known and widely used model that**

DIRECT TESTIMONY OF KENNETH J. SLATER

1 simulates the operations of electric power systems. PROMOD
2 IV® is primarily used as a production costing model and can
3 also be used to evaluate electric system reliability. A brief
4 description of PROMOD IV® is included in Appendix C to Volume
5 II of the Exhibits accompanying the Joint Petition. PROMOD
6 IV® can be used to prepare utility fuel budget forecasts,
7 evaluate the economics and operations of proposed generating
8 capacity additions, project utility operating costs, estimate
9 the prices of firm power and energy in defined markets,
10 project hourly marginal energy costs, and calculate avoided
11 energy costs.

12 The inputs to PROMOD IV® include generating unit data for
13 existing and planned power plants in a defined power supply
14 system, fuel consumption and fuel cost data, load and other
15 utility system data, and data regarding transactions both
16 within and external to the system. The primary outputs are
17 individual utility or system production costs, generation by
18 unit, fuel usage, and reliability information. PROMOD IV®
19 utilizes computationally efficient algorithms that yield
20 results identical to those that would be produced with direct
21 specification of values for all availability states of all
22 units in a power supply system.

23

DIRECT TESTIMONY OF KENNETH J. SLATER

1 Q: Who uses the PROMOD IV® model?

2 A: A significant number of electric utility companies in North
3 America have used and continue to use PROMOD IV®. To the best
4 of my knowledge, all four of the major investor-owned
5 utilities in Florida, Seminole, and some of the larger
6 municipal utilities in Florida, have used PROMOD IV®.

7

8 Q: Before leading us through your detailed results, please
9 summarize the cost structure and performance you have assumed
10 for the Osprey Energy Center.

11 A: I have assumed that the heat rate of the Osprey Energy Center
12 Project will be 6,800 Btu per kilowatt-hour ("kWh") at full
13 load. I assumed that the variable operating and maintenance
14 cost of the Osprey Energy Center Project will be \$1.85 per
15 megawatt-hour ("MWH") in 2000, escalating at 3.0 percent per
16 year. I should add that I also made the conservative
17 assumption that the Osprey Project would have exactly the same
18 heat rate characteristics as all of the other similar
19 technology, new gas-fired combined cycle units planned for
20 Florida except FPL's proposed repowering projects at Sanford
21 and Ft. Myers. I made this assumption in order to avoid
22 "favoring" the Osprey Project in our dispatch modeling,
23 despite the fact that the available evidence indicates that
24 the Osprey Project would in fact be slightly more cost-

DIRECT TESTIMONY OF KENNETH J. SLATER

1 effective than nearly all of the other planned gas-fired
2 combined cycle units. For FPL's proposed repowering projects,
3 I used heat rate information extracted from FPL's permit
4 applications to the Florida Department of Environmental
5 Protection; these data indicate that, as one would expect, the
6 repowering projects are somewhat less efficient than the other
7 new, "greenfield" plants. For example, our analyses indicate
8 that, on an "as-dispatched" basis, FPL's repowering projects
9 will have heat rates of approximately 7,150 to 7,280 Btu/kWh,
10 as compared to heat rates of approximately 6,970 to 7,040
11 Btu/kWh for the new combined cycle units, e.g., the Osprey
12 Project, Cane Island 3, Okeechobee, Payne Creek, Hines 2, Duke
13 New Smyrna Beach, and Purdom. This information is shown in
14 Exhibits _____ and _____ (KJS-3 and KJS-4).

15

16 **Q: Did your analyses include the possibility of the Osprey**
17 **Project's having increased output capability from duct-firing**
18 **and power augmentation?**

19 **A:** No. Our modeling analyses were conducted assuming no output
20 from duct-firing or power augmentation. If included in the
21 Project's final design configuration, these features would
22 increase the Project's output during peak conditions and
23 further enhance the reliability of the Peninsular Florida
24 power supply system.

DIRECT TESTIMONY OF KENNETH J. SLATER

1 Q: Did you model the Osprey Project as an additional unit, i.e.,
2 a unit that was assumed to be brought into service in addition
3 to all other power plants planned for Peninsular Florida, or
4 did you assume that the Osprey Project would displace another
5 unit or units that might otherwise have been built by Florida
6 retail-serving utilities or other entities?

7 A: I modeled the Osprey Project as an additional unit, that is,
8 as one that was incorporated into the Peninsular Florida power
9 supply system in addition to all other existing and planned
10 units. The planned units were identified through my review of
11 all of the ten-year site plans that were submitted to the
12 Florida Public Service Commission this year.

13

14 Q: Why did you model the Osprey Project in this manner?

15 A: I modeled the Osprey Project in this way because it will give
16 the most conservative results regarding the cost savings
17 impacts, the fuel savings impacts, and the emissions impacts
18 of the Project. This is a conservative assumption because it
19 models the impacts of the Osprey Project within a more
20 efficient system.

21

22

23 Q: Has anything changed since you prepared your analyses?

24 A: Since I originally prepared my analyses reported here, Calpine

DIRECT TESTIMONY OF KENNETH J. SLATER

1 and Seminole have executed an agreement by which Calpine will
2 sell Seminole 350 MW of firm capacity from the Osprey Project
3 beginning in 2004. This agreement has caused Seminole's
4 previously planned 2004 combined cycle unit to be taken out of
5 the generation expansion plan.

6
7 **Q: How would the Osprey Project affect power supply costs if it**
8 **were developed as a "displacement" unit instead of as an**
9 **"additional" unit?**

10 **A:** The Osprey Project's actual impact on power supply costs would
11 depend on the precise terms of the contract or contracts that
12 Calpine entered into with the utilities whose units were
13 displaced by the Project. However, if one were to model the
14 Project's impact on Peninsular Florida power supply costs
15 treating the system as an integrated whole, the Osprey Project
16 would show greater fuel savings, cost savings, and emissions
17 reductions than in the analyses that we performed treating the
18 Project as an "additional" unit. This is because in the
19 "displacement" case, there is less new, efficient gas-fired
20 combined cycle capacity (like the Osprey Project) in the
21 Peninsular Florida system, and thus the Project would be
22 operating within a system which was, overall, less efficient
23 and more costly to run, which would result directly in its
24 providing greater fuel savings and power supply cost

DIRECT TESTIMONY OF KENNETH J. SLATER

1 reductions.

2 In fact, this would now be expected to be the case
3 because of the agreement between Seminole and Calpine for the
4 purchase by Seminole of 350 MW of firm capacity from the
5 Project, instead of building its own combined cycle unit in
6 2004 as previously planned. This means that my reported
7 results actually understate the cost savings, fuel savings,
8 and emissions reduction benefits of the Osprey Project because
9 now, without Seminole's 2004 combined cycle unit, the Osprey
10 Project will be operating within a slightly less efficient
11 system, thus yielding greater benefits from its operation.

12

13 **Q: What, if any, documents did your review in preparing your**
14 **analyses?**

15 **A:** We initially reviewed the 1999 Regional Load & Resource Plan
16 published in July 1999 by the Florida Reliability Coordinating
17 Council (the "FRCC 1999 Resource Plan") and all ten-year site
18 plans submitted to the Commission in the spring of 2000. We
19 also reviewed the 2000 Regional Load & Resource Plan published
20 by the FRCC in July 2000.

21

22 **Q: What assumptions did you make regarding future fuel prices**
23 **over the period that you analyzed?**

24 **A:** In developing the fuel price projections for our analyses, we

DIRECT TESTIMONY OF KENNETH J. SLATER

1 examined historical Florida-specific fuel costs for
2 electricity generation and evaluated the major publicly
3 available fuel price forecasts, which are presented in the
4 Energy Information Administration's ("EIA") Annual Energy
5 Outlook 2000 publication. Our base case fuel price
6 projections were based primarily on the forecasts prepared by
7 EIA but with the gas price projections following those of
8 Resource Data International, Inc. ("RDI"). For the higher gas
9 price sensitivity case, we assumed the EIA projections (the
10 EIA's "reference case") for all fuels. Exhibit ____ (KJS-2)
11 shows the projected fuel prices for both our base case
12 analysis and for the higher natural gas price sensitivity
13 case.

14
15 **Q: What assumptions did you make regarding the electric power**
16 **plants that would be available to serve Peninsular Florida?**

17 **A:** The assumptions used in our evaluations regarding available
18 power plants to provide capacity and energy to Peninsular
19 Florida are summarized in Exhibits ____ and ____ (KJS-3 and
20 KJS-4), which present the projected Peninsular Florida
21 generating fleet for 2003 and 2008, respectively. For
22 reference, Exhibit ____ (KJS-5) presents a summary of
23 existing capacity as of January 1, 2000. These data were
24 obtained from the FRCC 2000 Resource Plan.

DIRECT TESTIMONY OF KENNETH J. SLATER

1 Q: What assumptions did you make regarding the growth rates of
2 summer and winter peak demands and energy consumption in
3 Peninsular Florida?

4 A: Exhibit _____ (KJS-6) presents the historical and projected
5 summer and winter firm peak demands for Peninsular Florida.
6 Exhibit _____ (KJS-7) presents the historical and projected
7 net energy for load, number of customers, and load factor for
8 Peninsular Florida. For the base case, the load forecast was
9 developed on a company-by-company basis from the 2000 ten-year
10 site plans. Some adjustments were necessary to account for
11 loads which were included in more than one site plan, for one
12 system which does not file a site plan, and for some
13 overstatement of load management impact. We reconciled our
14 company-by-company forecasts with the FRCC 1999 Resource Plan
15 in order to achieve accuracy and completeness.

16
17 Q: What assumptions did you make regarding imports of electric
18 power from outside Peninsular Florida and exports of power
19 from Peninsular Florida to other regions?

20 A: We assumed that imports into Peninsular Florida would be as
21 projected in the FRCC 1999 Resource Plan. We assumed that
22 there would be no significant exports of power from Peninsular
23 Florida to other regions.

24

DIRECT TESTIMONY OF KENNETH J. SLATER

1 Q: What assumptions did you make regarding the effects of energy
2 conservation and demand-side management programs?

3 A: We generally assumed that the forecasts of peak demands and
4 net energy for load presented in the FRCC 1999 Resource Plan
5 and the 2000 ten-year site plans reflected the achievement of
6 the Florida retail-serving utilities' Commission-approved
7 energy conservation goals. There was one exception to this
8 assumption, however: the FRCC projections and some of the site
9 plans assume that net energy for load (total energy
10 consumption) will reflect maximum possible reductions from
11 interruptible, load management, and other energy conservation
12 measures and programs. In my opinion, this systematically
13 understates total energy consumption because it assumes far
14 greater reductions in energy use from interruptible and load
15 management customers than are actually realized. Accordingly,
16 we adjusted the net energy for load projections upward to
17 reflect more realistic energy consumption levels where
18 necessary.

19

20 Q: How was transmission modeled or treated in your analyses?

21 A: We modeled Peninsular Florida as an integrated power supply
22 system, with all generation resources available to serve all
23 loads. Transmission was assumed to be costless for all
24 transactions, such that the most efficient generation

DIRECT TESTIMONY OF KENNETH J. SLATER

1 resources would be dispatched to serve the Peninsular Florida
2 load, without regard to transmission constraints or tariffs.

3

4 **Q: Do you consider this to be a realistic assumption?**

5 **A:** Yes. Because it is not known what transmission augmentations
6 will be carried out in the FRCC region in the next twelve
7 years, it is best to make an assumption which would not favor
8 the Osprey Project over any other new project or over existing
9 generation. We made such an assumption.

10

11 **Q: What, if any, effect would altering this assumption have on**
12 **your analyses of the operations of the Osprey Energy Center?**

13 **A:** Altering this assumption would likely have very little effect
14 on the actual dispatch of the Osprey Project.

15

16 **Q: Did you review any documents that you understood to be**
17 **confidential or proprietary to Calpine or Seminole?**

18 **A:** No.

19

20 **Q: Do you consider any of your input or output data to be**
21 **confidential, proprietary business information from Slater**
22 **Consulting's perspective?**

23 **A:** Yes. Our compilation of the generating units and their
24 dispatch characteristics, and to some extent the load forecast

DIRECT TESTIMONY OF KENNETH J. SLATER

1 data, are the intellectual work product of Slater Consulting,
2 developed through significant and substantial effort. We
3 consider this to be confidential, proprietary business
4 information, but we are, of course, willing to disclose it
5 pursuant to appropriate confidentiality protections.

6
7 **OPERATIONS OF THE OSPREY ENERGY CENTER**

8 **Q: What does your base case analysis show regarding the projected**
9 **operations of the Osprey Energy Center?**

10 **A:** For the base case, our analyses show that the Osprey Energy
11 Center will generally produce between 4,000 and 4,400
12 gigawatt-hours ("GWH") annually, indicating annual capacity
13 factors between 86 and 93 percent, for the 2003-2012 analysis
14 period. Exhibit ____ (KJS-8) shows the projected annual
15 energy production from the Osprey Project and the annual
16 capacity factors based on the indicated output amounts.

17 Our analyses also indicate that, in peak demand periods,
18 the Project will make sales equal to the Project's full rated
19 capacity, subject only to outages.

20
21 **Q: What do your analyses show regarding the projected operations**
22 **of the Osprey Project if natural gas prices are higher than**
23 **your base case forecast?**

24 **A:** Exhibit ____ (KJS-9) displays the results of this

DIRECT TESTIMONY OF KENNETH J. SLATER

1 sensitivity analysis, and shows that the Osprey Project will
2 produce between 3,900 and 4,400 GWH annually in this case.
3 That is, it will operate at annual capacity factors between 83
4 and 92 percent.

5
6 **Q: What do your analyses show regarding the projected operations**
7 **of the Osprey Project if Peninsular Florida's load growth is**
8 **higher or lower than in your base case?**

9 A: Exhibit _____ (KJS-10) shows that load growth will have
10 virtually no impact on the operations of the Osprey Project.

11

12 **Q: What, if any, impacts will the Osprey Project's operation have**
13 **on other power plants in Peninsular Florida?**

14 A: Generally, the Project will cause less efficient and more
15 costly plants to operate at lower output levels. Exhibit
16 _____ (KJS-11) shows the modeled impacts of the Osprey
17 Project's operations on other units supplying Peninsular
18 Florida during two representative days in 2005, one a June
19 weekday and one a December weekday. Of course, the actual
20 impacts would depend on the actual availability status of all
21 units in Peninsular Florida on any given day.

22

23 **Q: In your opinion, how likely is it that the Osprey Project**
24 **would make any significant amount of power sales outside**

DIRECT TESTIMONY OF KENNETH J. SLATER

1 **Peninsular Florida?**

2 A: Based on my general knowledge of the Florida and Southeastern
3 Electric Reliability Council ("SERC") markets, including both
4 existing and planned generating capacity for both, and the
5 transmission systems in both markets, I believe that it would
6 be highly unlikely that the Project would make any significant
7 amount of sales outside Peninsular Florida. This is generally
8 because Florida's generation resources are high-cost.

9

10 **Q: Are you aware of other evidence that supports your opinion**
11 **that the Osprey Project will not make significant sales of**
12 **power outside Peninsular Florida?**

13 A: Yes, I am. The PowerDAT® data base maintained by Resource
14 Data International, Inc. and reported on a regular basis in
15 Public Utilities Fortnightly shows that the average generation
16 cost (defined as fuel cost plus reported non-fuel operating
17 and maintenance cost) in the FRCC region, i.e., Peninsular
18 Florida, was the highest of all of the reliability regions in
19 the United States for 1997, 1998, and 1999. Exhibit _____
20 (KJS-12) shows that for 1999, the FRCC region's average
21 generating cost was 2.59 cents per kWh, which equals \$25.90
22 per MWh. The region with the next highest cost was the
23 Electric Reliability Council of Texas ("ERCOT"), with an
24 average cost of \$24.10 per MWh. The average cost for

DIRECT TESTIMONY OF KENNETH J. SLATER

1 electricity generation in Florida's nearest neighbor regions
2 was significantly less than in the FRCC region: the average
3 cost for the SERC region was \$17.60, approximately 32 percent
4 less than in FRCC, the average cost for the Southwestern Power
5 Pool ("SPP") region was \$21.10 per MWH, approximately 19
6 percent less than in FRCC, and the average cost for the East
7 Central America Reliability ("ECAR") region was \$21.20 per
8 MWH, approximately 18 percent less than in FRCC.

9 In addition, I am aware from reading the power generation
10 trade press that there are significant amounts of new,
11 efficient, relatively low-cost capacity being installed in
12 SERC, ECAR, and other regions. The addition of this new
13 capacity will further reduce the economic viability of power
14 exports from Florida to other regions.

15
16 FUEL CONSUMPTION IMPACTS OF THE OSPREY ENERGY CENTER

17 Q: What, if any, effects will the Osprey Project have on the
18 total consumption of primary fuels used to generate the
19 electric power supply for Peninsular Florida?

20 A: Exhibit _____ (KJS-13) shows the estimated impacts of the
21 Osprey Project's operations on total primary energy
22 consumption for generating Peninsular Florida's electricity
23 supply for each year from 2003 through 2012. Our modeling
24 analyses show that the Osprey Project can be expected to

DIRECT TESTIMONY OF KENNETH J. SLATER

1 reduce total fuel consumption by roughly 6 trillion Btu per
2 year to 9 trillion Btu per year over the analysis period.
3 This is a tremendous amount of energy: 6 trillion Btu is
4 approximately the amount of energy in 6 million Mcf
5 (equivalent to 6 billion cubic feet) of natural gas, or the
6 amount of energy in 1 million barrels of residual fuel oil.

7

8 **Q: What effects will the Osprey Project have on the specific**
9 **fuels used to generate the electric power supply for**
10 **Peninsular Florida?**

11 **A:** Exhibit _____ (KJS-14) shows the impacts of the Osprey
12 Project's operations on the total use of natural gas, No. 6
13 (residual) fuel oil, No. 2 fuel oil, nuclear, and coal and
14 other solid fuels to generate Peninsular Florida's electricity
15 supply for the 2003-2012 analysis period. Page 1 of 2 of
16 this exhibit shows the impact on fuel use in millions of Btu,
17 and page 2 of 2 of the exhibit shows the impact in terms of
18 gigawatt-hours (i.e., thousands of megawatt-hours) generated
19 using each fuel type. Generally, the Project results in
20 significant decreases in the use of coal and No. 6 oil, with
21 a corresponding increase in natural gas use. The Project's
22 specific impacts are also illustrated in Exhibit _____
23 (KJS-11), which shows the expected impacts of the Osprey
24 Project's operations on the operations of other units in

DIRECT TESTIMONY OF KENNETH J. SLATER

1 Peninsular Florida during representative days.

2

3 **Q: It is relatively easy to understand how the Osprey Project,**
4 **with its relatively low heat rate, would reduce the use of gas**
5 **or oil used in less efficient power plants. Can you explain,**
6 **however, how the Osprey Project would displace generation from**
7 **coal-fired power plants?**

8 **A: Of course. Certain coal plants, while they have relatively**
9 **low fuel costs, also have relatively high non-fuel operating**
10 **and maintenance ("O&M") costs. Because dispatch decisions are**
11 **based on total variable costs, in some instances, the sum of**
12 **the Osprey Project's incremental fuel and non-fuel variable**
13 **O&M cost (and the corresponding costs for the other planned**
14 **gas-fired combined cycle units as well) will be less than the**
15 **sum of those costs for coal units. This results in the**
16 **economic dispatch decision being to operate the Osprey Project**
17 **at higher output levels and the relatively higher-cost coal**
18 **units at lower levels.**

19

20 **Q: Please summarize the impact of the Osprey Project's operations**
21 **on the consumption of petroleum fuels for electricity**
22 **generation for Peninsular Florida?**

23 **A: The Osprey Project's operations will result in significant**
24 **reductions in the use of petroleum fuels for electricity**

DIRECT TESTIMONY OF KENNETH J. SLATER

1 generation for Peninsular Florida. For example, Exhibit ____
2 (KJS-14) shows savings of approximately 13,122 billion Btu of
3 No. 6 oil and another 518 billion Btu of No. 2 oil in 2004.
4 This translates to a total savings of petroleum fuels of 13.6
5 trillion Btu, or approximately 2.2 million barrels for 2004.

6

7 **Q: Will the Osprey Project have any effect on the overall**
8 **efficiency of natural gas use in Florida?**

9 A: Yes. The Osprey Project will increase the overall efficiency
10 of natural gas use in Florida. This will occur as the Osprey
11 Project, with its heat rate of approximately 6,970 Btu/kWh (as
12 dispatched), is dispatched economically in preference to other
13 gas-fired units with less efficient heat rates, e.g., the
14 numerous gas-fired steam units in Florida that have heat rates
15 in the range of 10,000 to 11,000 Btu/kWh.

16

17 **Q: What, if any, effect will the Osprey Project have on the**
18 **overall efficiency of electricity generation for Peninsular**
19 **Florida?**

20 A: The Osprey Project will significantly increase the overall
21 efficiency of electricity generation for Peninsular Florida.
22 Exhibit _____ (KJS-13) shows not only that the Project will
23 result in overall savings of 6 trillion to 9 trillion Btu per
24 year for electricity generation, but that the Project will

DIRECT TESTIMONY OF KENNETH J. SLATER

1 also reduce the average heat rate for Peninsular Florida
2 electricity generation by 24 to 44 Btu per kilowatt-hour, a
3 reduction on the order of 0.4 percent. This is a significant
4 improvement in the overall efficiency of producing
5 approximately 200,000,000 MWH of electricity per year for the
6 fourth largest state in the nation.

7
8 **Q: Why will the Osprey Project have these effects?**

9 **A:** The Osprey Project will have these fuel and energy savings
10 effects because it is significantly more efficient and cost-
11 effective than the vast majority of electric generating plants
12 that currently exist in Peninsular Florida and at least as
13 efficient as virtually all of the new capacity that is planned
14 for Peninsular Florida. Exhibit _____ (KJS-3) shows the
15 estimated dispatch costs and heat rates (as assumed in our
16 PROMOD IV® modeling) for all of the power plants that are
17 expected to be serving Peninsular Florida in 2003. The Osprey
18 Project's dispatch cost of \$28.09 per MWH is lower than the
19 dispatch costs of approximately 34,000 MW of the total
20 capacity of approximately 47,000 MW (including 3,877 MW of
21 nuclear capacity operated as "must run" generation) that is
22 projected to be available to serve Peninsular Florida in that
23 year. In addition, the Osprey Project's heat rate of 6,967
24 Btu per kWh (as dispatched in 2003) is more efficient than

DIRECT TESTIMONY OF KENNETH J. SLATER

1 virtually all of the generating capacity that is projected to
2 be available to serve Peninsular Florida in that year.
3 Similarly, Exhibit _____ (KJS-4) shows the estimated dispatch
4 costs and heat rates for all of the power plants that are
5 expected to be serving Peninsular Florida in 2008. The Osprey
6 Project's dispatch cost of \$32.57 per MWH is lower than the
7 dispatch costs of approximately 38,000 MW of the total of
8 approximately 51,000 MW (again including 3,877 MW of nuclear
9 as "must run") that is projected to be available to serve
10 Peninsular Florida in that year. In addition, the Osprey
11 Project's as-dispatched heat rate of 6,984 Btu per kWh (as
12 dispatched in 2008) is more efficient than virtually all of
13 the generating capacity that is projected to be available to
14 serve Peninsular Florida in that year.

15

16 **Q: Will there be any adverse effect on primary fuel consumption**
17 **and the efficiency of electricity generation for Peninsular**
18 **Florida if the Osprey Project is not brought into service as**
19 **requested by Calpine in this proceeding?**

20 **A: Yes.** If the Osprey Project is either delayed or not brought
21 into operation at all, Florida will lose the primary fuel
22 savings benefits that the Project will provide. As shown
23 above, these primary fuel savings are quite significant -- on
24 the order of 6 trillion to 9 trillion Btu per year for each

DIRECT TESTIMONY OF KENNETH J. SLATER

1 year of the Project's operation.

2

3

COST-EFFECTIVENESS OF THE OSPREY ENERGY CENTER

4 **Q: Did your analyses address the cost-effectiveness of the Osprey**
5 **Project as an additional power supply resource in the**
6 **Peninsular Florida power supply system?**

7 **A: Yes.** Our analyses addressed the Project's cost-effectiveness
8 by evaluating the impact that it would have as an incremental
9 power supply resource added into the Peninsular Florida power
10 supply system in addition to all other planned additions, as
11 indicated by the ten-year site plans filed with the Commission
12 this year. Basically, our analyses modeled the total power
13 supply costs for serving Peninsular Florida without the Osprey
14 Project and with the Project. The difference in costs
15 represents the cost savings properly attributable to the
16 Osprey Project.

17

18 **Q: And what did your analyses show?**

19 **A: Our "base case" analyses and our sensitivity analyses showed**
20 **that the Osprey Project will provide significant power supply**
21 **cost savings to Peninsular Florida. Exhibit _____ (KJS-15)**
22 **shows that for the base case, the Project would result in**
23 **power supply cost savings between \$113 million and \$204**
24 **million per year (in nominal terms), with projected total**

DIRECT TESTIMONY OF KENNETH J. SLATER

1 savings of \$794 million in Net Present Value terms over the
2 Project's first ten years of operations (2003-2012).

3 For the higher natural gas price sensitivity case,
4 Exhibit _____ (KJS-16) shows that the Project will provide
5 power supply cost savings between \$115 million and \$218
6 million per year (in nominal terms), with projected total
7 savings of \$806 million in Net Present Value terms over the
8 Project's first ten years of operations (2003-2012).

9 For the low load growth sensitivity case, Exhibit _____
10 (KJS-17) shows that the Project will provide power supply cost
11 savings between \$47 million and \$219 million per year (in
12 nominal terms), with projected total savings of \$627 million
13 in Net Present Value terms over the Project's first ten years
14 of operations (2003-2012).

15 For the high load growth sensitivity case, Exhibit _____
16 (KJS-18) shows that the Project will provide power supply cost
17 savings between \$88 million and \$410 million per year (in
18 nominal terms), with projected total savings of \$1.12 billion
19 in Net Present Value terms over the Project's first ten years
20 of operations (2003-2012).

DIRECT TESTIMONY OF KENNETH J. SLATER

1 Q: How do these total cost savings translate into reductions in
2 the estimated wholesale cost of power for Peninsular Florida?

3 A: Exhibit _____ (KJS-15) shows that for the base case, the
4 estimated reduction in the average wholesale cost of power for
5 Peninsular Florida is approximately \$0.54 to \$0.84 per MWH
6 over the 2003-2012 study period. Exhibit _____ (KJS-16)
7 shows that the impact of the Osprey Project in the higher
8 natural gas price scenario is approximately \$0.55 to \$0.88 per
9 MWH over the study period. Exhibit _____ (KJS-17) shows that
10 for the low load growth scenario, the impact of the Osprey
11 Project would be a reduction in average power supply costs of
12 approximately \$0.23 to \$0.94 per MWH, and that for the high
13 load growth scenario, the impact of the Osprey Project would
14 be a reduction in average power supply costs of approximately
15 \$0.41 to \$1.47 per MWH.

16
17 Q: What, if any, effect would the fact that the Osprey Project is
18 now going to fulfill Seminole's 2004 capacity need have on
19 these cost reduction impacts?

20 A: The fact that the Osprey Project is now committed to serving
21 Seminole's 2004 need will presumably cause Seminole's
22 previously planned 2004 combined cycle unit to drop out of the
23 projected statewide power supply plan. In turn, because the
24 Osprey Project will now be operating within a slightly less

DIRECT TESTIMONY OF KENNETH J. SLATER

1 efficient system, this will cause the cost reduction benefits
2 available from the Osprey Project's operation to be slightly
3 greater than the values reported above.

4

5 **Q: Will the Osprey Project be the most cost-effective alternative**
6 **available to serve Peninsular Florida's needs for cost-**
7 **effective, reliable power?**

8 **A:** In my opinion, yes. The Osprey Project has a favorable heat
9 rate and favorable direct construction costs, as reported by
10 Calpine, when compared to other generating units that are
11 planned or proposed for Peninsular Florida. Combining these
12 factors with the fact that the Project will not be included in
13 any retail-serving utility's rate base, but rather the
14 Project's output will only be purchased for resale to the
15 customers of retail-serving utilities, such as Seminole's
16 member cooperative utility systems that obtain their wholesale
17 power from Seminole, when such purchases are cost-effective,
18 it is obvious that it is the most cost-effective alternative
19 available. Exhibit _____ (KJS-19) lists planned and proposed
20 generating units for Peninsular Florida. Among the gas-fired
21 combined cycle units, the Osprey Project compares quite
22 favorably: only the Cane Island 3 unit has comparable heat
23 rates and lower construction costs. Most of the proposed
24 combined cycle capacity has significantly higher direct

DIRECT TESTIMONY OF KENNETH J. SLATER

1 construction costs.

2

3 Q: What, if anything, could prevent the Osprey Project from being
4 a cost-effective power supply resource in the Peninsular
5 Florida region?

6 A: Only highly unlikely developments, such as the total failure
7 of the Project to become operational or a technological change
8 so dramatic as to make all of the existing and planned
9 Peninsular Florida generating capacity obsolete, could cause
10 the Osprey Project not to be cost-effective.

11

12 Q: How does the Osprey Project compare to other existing and
13 planned Peninsular Florida power plants in terms of its
14 projected operating costs?

15 A: In terms of its operating costs, the Osprey Project compares
16 quite favorably to all existing generating plants in
17 Peninsular Florida except those fueled by nuclear fuel and
18 some of those fueled by coal. Referring back to Exhibit
19 _____ (KJS-3), the Commission will see that the Osprey
20 Project is more cost-effective, in terms of its dispatch
21 costs, than approximately 34,000 MW out of the total of 47,000
22 MW (including nuclear as "must run") available to serve
23 Peninsular Florida in 2003. Similarly, Exhibit _____ (KJS-4)
24 shows that the Project is more cost-effective than

DIRECT TESTIMONY OF KENNETH J. SLATER

1 approximately 38,000 MW of the total of approximately 51,000
2 MW (including nuclear as "must run") of capacity that is
3 projected to be available to serve Peninsular Florida in 2008.
4 As noted above, the Project also compares favorably to other
5 planned and proposed gas-fired combined cycle units.

6 I should add that in our modeling, we intentionally
7 assumed identical heat rate characteristics for all of the new
8 gas-fired combined cycle capacity. We did so in order to be
9 conservative with respect to the Osprey Project's impacts and
10 operations.

11

12 Q: One of the criteria that the Commission must consider in a
13 need determination proceeding is whether the proposed power
14 plant will contribute to meeting the need for adequate
15 electricity at a reasonable cost. As you understand this
16 term, will the Osprey Project contribute to meeting Florida's
17 need for adequate electricity at a reasonable cost?

18 A: Yes. In the simplest terms, the Osprey Project is available
19 to Peninsular Florida, and our PROMOD IV® modeling analyses
20 show that it will save between \$627 million and \$1.12 billion
21 in power supply costs for Peninsular Florida in the first ten
22 years of its life, depending on variations in fuel prices and
23 load growth rates. Clearly, if Florida can obtain its needed
24 power supply at savings between half a billion and more than

DIRECT TESTIMONY OF KENNETH J. SLATER

1 one billion dollars, it would only be reasonable to take
2 advantage of the opportunity. Given the availability of these
3 savings, paying the extra half billion dollars or more would
4 represent paying an unreasonable amount for needed power.

5

6 **Q: Will the Project have any effect on potential "price spikes"**
7 **for wholesale power in Peninsular Florida?**

8 **A:** Yes, the Project can be expected to suppress and reduce the
9 magnitude of prices in basically all hours when the Project is
10 available to serve. (The Project would be expected to be
11 available to serve continuously during all summer and winter
12 peak periods, except for unplanned or forced outages.) While
13 our modeling analyses did not address extreme peak conditions,
14 it is obvious that the Project's presence would suppress
15 prices in any extremely tight supply conditions that might be
16 experienced in Peninsular Florida.

17

18 **Q: What, if any, value would the Project have with respect to**
19 **other services? For example, would the Project suppress the**
20 **price of ancillary services in Peninsular Florida?**

21 **A:** Generally, the Project will also suppress the cost or price of
22 other services, including ancillary services. (Ancillary
23 services are defined by the Federal Energy Regulatory
24 Commission as (a) Scheduling, System Control and Dispatch

DIRECT TESTIMONY OF KENNETH J. SLATER

1 Service; (b) Reactive Supply and Voltage Control from
2 Generation Sources Service; (c) Regulation and Frequency
3 Response Service; (d) Energy Imbalance Service; (e) Operating
4 Reserve - Spinning Reserve Service; and (f) Operating Reserve
5 Supplemental Reserve Service.) While our PROMOD IV® analyses
6 only addressed the Osprey Project's value in supplying energy
7 and did not include any analyses of the Project's impact on
8 the prices of ancillary services, from my experience I can say
9 that the Project's presence will suppress the prices of
10 ancillary services in Peninsular Florida, especially the
11 prices of the various types of reserve services. These
12 effects are likely to be quite significant in Florida once the
13 transmission function is transferred to some form of regional
14 transmission organization that would have the responsibility
15 for procuring ancillary services in the market.

16

17 Q: Do your analyses take account of the value of economic
18 production (e.g., fertilizer, chemicals, services, food
19 products, and so on) that could, and presumably would, be
20 realized by commercial enterprises in Florida if they were
21 able to stay in operation as a result of the Project's
22 presence and operation?

23 A: No. Our analyses address only the direct impacts on power
24 supply costs. The value of maintaining electric service is

DIRECT TESTIMONY OF KENNETH J. SLATER

1 generally significantly greater than the cost of providing
2 incremental energy, even in instances where power supplies are
3 tight and incremental power is available only at extremely
4 high prices, for example, \$1,000 or more per MWH. In my
5 experience, the value of "lost production" is frequently
6 several times that amount.

7

8 **Q: What, if anything, do your analyses of the Osprey Energy**
9 **Center's operations show regarding the need for the Project?**

10 **A:** Our analyses show that the Project will meet significant need
11 in Peninsular Florida for cost-effective power, even if the
12 Project were added onto the projected Peninsular Florida
13 generating fleet in addition to all other planned resources.
14 This is demonstrated by the significant, even dramatic, power
15 supply cost reductions that the Osprey Project will provide.

16 Again, as I indicated above, these analyses provide the
17 most conservative estimate of the Project's contributions to
18 Peninsular Florida, because they model the Project's
19 operations against the backdrop of the greatest amount of new
20 efficient generation in the area. Given that the bulk of the
21 Osprey Project's capacity is now committed to Seminole, with
22 the corresponding replacement of Seminole's previously planned
23 2004 combined cycle unit in the statewide generation expansion
24 plan, the Project can be expected to provide even greater

DIRECT TESTIMONY OF KENNETH J. SLATER

1 total benefits in terms of reduced power supply costs.

2

3 **Q: Based on your analyses, and in your opinion, will there be any**
4 **adverse effects on total power supply costs for Peninsular**
5 **Florida if the Osprey Project is not brought into service as**
6 **requested by Calpine and Seminole?**

7 A: Yes. Our analyses demonstrate quite clearly that the Project
8 will provide significant, even dramatic, benefits to
9 Peninsular Florida if and when it is brought into service as
10 proposed by Calpine and Seminole. With respect to power
11 supply costs, if the Project were not brought into service as
12 proposed by Calpine and Seminole, Florida would lose these
13 benefits, specifically the projected cost savings of about
14 \$800 million (Net Present Value) over the Project's first ten
15 years of operation. Losing these benefits would be a
16 significant adverse effect of the Project's not being brought
17 into service as requested by Calpine and Seminole. Similarly,
18 delaying the Project's commercial operation will cost Florida
19 amounts on the order of \$150 million annually for each year of
20 delay.

21

22

DIRECT TESTIMONY OF KENNETH J. SLATER

RELIABILITY IMPACTS OF THE OSPREY ENERGY CENTER

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24

Q: How should the Commission evaluate the impact of the Osprey Energy Center on the reliability of the power supply system for Peninsular Florida?

A: The Commission should include the Osprey Project in its reliability evaluation for Peninsular Florida as a committed resource, in this case to Seminole.

Q: What impact will the Osprey Project have on the reliability of Peninsular Florida's power supply system?

A: The Osprey Project will improve Peninsular Florida reliability by increasing Peninsular Florida reserve margins by approximately 1.1 to 1.3 percent in both summer and winter seasons following the Project's achievement of commercial in-service status. For example, Exhibit _____ (KJS-20) shows that in the summer of 2003, the Project will increase Peninsular Florida's reserve margin from 15.3 percent to 16.5 percent. Exhibit _____ (KJS-21) shows similar improvement in winter reserve margins.

Q: What, if any, impact would the availability of the Osprey Project have on the ability of Peninsular Florida's retail-serving utilities to maintain service to their retail customers during periods when power supply was short relative

DIRECT TESTIMONY OF KENNETH J. SLATER

1 to demand?

2 A: The Osprey Project will have significant beneficial effects on
3 the ability of Peninsular Florida retail-serving utilities to
4 maintain uninterrupted service to their firm and non-firm
5 customers. This would apply not only during extreme seasonal
6 peak demand conditions, but any time that supply was "tight"
7 relative to demand. Such conditions have occurred in what are
8 typically regarded as "shoulder" months when demand was higher
9 than projected (though far below annual peak levels) but
10 supply was tight due to scheduled maintenance outages and
11 unexpected outages of generating units.

12 In an extreme winter peak event, the Project's capacity
13 of approximately 578 MW would enable Florida's retail-serving
14 utilities to maintain service to between 115,000 and 165,000
15 residential customers, at an average coincident peak demand of
16 3.5 to 5.0 kilowatts per household. Even in less extreme
17 conditions, the Project's capacity would enable Florida
18 retail-serving utilities to maintain service to more of their
19 customers without implementing direct load control measures or
20 without interrupting service to commercial and industrial
21 interruptible customers. In an extreme summer event, the
22 Project's summer capacity of 496 MW would enable Florida's
23 retail-serving utilities to maintain service to between 99,000
24 and 142,000 residential customers or equivalent load.

DIRECT TESTIMONY OF KENNETH J. SLATER

1 Q: In your opinion, would it be accurate to say that Florida has
2 a need for the Osprey Project from a reliability perspective?

3 A: Yes. Given the firm commitment of 350 MW of the Project's
4 capacity to Seminole and the availability of the balance of
5 the Project's capacity to Seminole on a reserve capacity
6 option basis, the Osprey Project will enhance the reliability
7 of Seminole's system and of Peninsular Florida's electric
8 power supply system as a whole.

9

10 Q: Will there be any adverse effects on the reliability of the
11 Peninsular Florida power supply system if the Osprey Project
12 is not brought into service as requested by Calpine and
13 Seminole?

14 A: Yes. Reserve margins will be less, by a measurable,
15 significant amount, than if the Project is added. More
16 significantly, in practical terms, Peninsular Florida
17 utilities will be unable to serve approximately 500 MW of load
18 (up to approximately 660 MW of load with duct-firing and power
19 augmentation) that they could serve if the Project were
20 constructed as sought by Calpine and Seminole. This means
21 that, in periods when supply is short relative to demand, the
22 equivalent of 99,000 to 185,000 homes will not be served, or
23 will have their service interrupted, if the Project is not
24 built. The actual impacts could be felt by residential

DIRECT TESTIMONY OF KENNETH J. SLATER

1 customers or by industrial and commercial customers who would
2 have to shut down their operations as a result of power supply
3 shortages. The actual amount of load affected depends on the
4 season and the final configuration of the Project.

5
6 IMPACTS OF THE OSPREY ENERGY CENTER ON ENVIRONMENTAL
7 EMISSIONS FROM ELECTRICITY GENERATION

8 Q: Did you evaluate the impacts of the Osprey Energy Center's
9 operations on the emissions of pollutants that are associated
10 with electricity generation?

11 A: Yes. Our PROMOD IV® analyses evaluate the impacts on total
12 emissions of sulfur dioxide and nitrogen oxides from the
13 operation of the power plants included in our analyses. In
14 this application, we evaluated the emissions of sulfur dioxide
15 and nitrogen oxides in the various cases with and without the
16 Osprey Project included as a power supply resource for
17 Peninsular Florida.

18
19 Q: What are the projected impacts of the Osprey Energy Center on
20 the emissions of sulfur dioxide and nitrogen oxides associated
21 with producing the electric power supply for Peninsular
22 Florida?

23 A: Exhibit _____ (KJS-22) shows that with the Osprey Project in
24 service in our base case scenario, the emissions of sulfur
25 dioxide are approximately 4,600 to 16,000 tons per year less

DIRECT TESTIMONY OF KENNETH J. SLATER

1 than if the Osprey Project is not in service. Similarly,
2 Exhibit _____ (KJS-22) shows that the Osprey Energy Center's
3 operations are expected to result in reductions of nitrogen
4 oxides emissions of approximately 3,900 to 7,000 tons per
5 year.

6

7 **Q: Will there be any adverse effects on Florida's environment if**
8 **the Osprey Project is not brought into service as requested by**
9 **Calpine and Seminole in this proceeding?**

10 **A: Yes.** The combined emissions of sulfur dioxide and nitrogen
11 oxides from producing Peninsular Florida's electricity supply
12 will be more than eight thousand tons greater in each year
13 that the Osprey Project's operation is delayed.

14

15 **Q: Does this conclude your direct testimony?**

16 **A: Yes.** It does.

17

BEFORE THE FLORIDA PUBLIC SERVICE COMMISSION

In Re: Petition for Determination of)
Need for the Osprey Energy Center in)
Polk County by Seminole Electric)
Cooperative, Inc. and Calpine)
Construction Finance Company, L.P.)

DOCKET NO. _____-EC

FILED: December 4, 2000

EXHIBITS

OF

KENNETH J. SLATER

ON BEHALF OF

**CALPINE CONSTRUCTION FINANCE
COMPANY, L.P.**

Technical Qualifications
and
Professional Experience

Osprey Energy Center
Calpine
Witness: Kenneth J. Slater
Exhibit _____ (KJS-1)
Page 1 of 10

Kenneth John Slater

EDUCATION

B.Sc., Pure Mathematics and Physics, Sydney University, 1960
B.E., Electrical Engineering, Sydney University, 1962
M.A.Sc., Management Sciences, University of Waterloo, 1974

PROFESSIONAL AFFILIATIONS

Association of Professional Engineers of Ontario
- Registered Professional Engineer
Institute of Electrical and Electronic Engineers
- Member of Power Engineering Society
- Past member of Power System Engineering Committee
- Past member of System Economics subcommittee and working group

EXPERIENCE

1957-62 Mr. Slater was a Junior Professional Officer at the Electricity Commission of New South Wales attending university and undergoing on-the-job training in power station and substation design, construction, protection, maintenance, and operation.

1962-67 Mr. Slater was a Professional Engineer Grades 1 and 2 at The Electricity Commission of New South Wales, engaged in a variety of functions within the areas of Power Station Construction, Generation Planning, System Operation and Load Dispatch.

1967-69 As Assistant Engineer Area Operations/Sydney West (Professional Engineer, Grade 3) with the Electricity Commission of New South Wales, Mr. Slater was responsible for the day-to-day operation of the Sydney West Area (approximately 20% of the State System).

He supervised the day-to-day work of more than 18 operators as they provided safe working conditions for Commission staff and others on system apparatus, and as they provided safe, secure, reliable and economic operation of this portion of the State System.

He performed the liaison function with head office staff, other divisions and customers on all operating activities, directed the performance of complicated operating procedures and trained both regular and emergency operators.

While he was in this and his previous position, Mr. Slater was responsible for the design and manufacture of the live line testing devices used by the Commissions' operators and linemen.

As well, he assumed responsibility for the preparation and execution of "black start" exercises and for the arrangement and detailing of complicated switching for major rearrangements and commissionings on the State System. He also developed original computer applications.

1969-74

As Engineer, and then Senior Engineer, heading the Production Development Section of Ontario Hydro's Operating Department, Mr. Slater was engaged in developing computational procedures and computer programs for Production Economics and Resource Management.

Major contributions included (1) the development and implementation of the computer program which, for more than 20 years, produced the daily generation schedule for the Ontario Hydro System, (2) the formulation of a Stochastic System Model to coordinate and optimize the production planning, maintenance planning, interchange planning and resource management of the Ontario Hydro System, and (3) the development of PROMOD, a Probabilistic Production Cost and Reliability model, the first version of the "core" of the Stochastic Model in (2) above.

As a member of the project group implementing the Operating Department's Data Acquisition and Computer System, he headed a work unit responsible for providing the application programs related to generation scheduling, power interchange and resource management. Also, he held responsibilities in the areas of policy determination, analytical techniques and the planning of future applications.

1974-75 As Manager of Engineering at the Ontario Energy Board, Mr. Slater was heavily involved in public hearings into Ontario Hydro's System Expansion Plans and Financial Policies, and into Ontario Hydro's Bulk Power Rates.

During this time, he provided much of the power system engineering input necessary for the start-up and formulation of the public hearing process related to Ontario Hydro. He also provided the engineering input for the regulation of Ontario's three major investor owned gas utilities.

1975-76 For 12 months, Mr. Slater was a private consultant contracted to the Royal Commission on Electric Power Planning, in Ontario, as its Research Director. During this time, he directed and participated in various studies of different aspects of electricity supply. He was also a member of the panel of expert examiners in a number of the Royal Commission's public hearings.

1976-83 As President of Slater Energy Consultants, Inc., in Toronto, Mr. Slater performed or made major contributions to a number of important assignments at the forefront of the electrical energy industry. These included:

- The Export of Electrical Power
.... a study for the Ontario Ministry of Industry and Tourism.
- Load Management Studies
.... for the Detroit Edison Company.
- California Utilities Increased Integration Study
.... for San Diego Gas & Electric Company, Southern California Edison Company, Los Angeles Department of Water and Power, and Pacific Gas and Electric Company.
- Bradley-Milton 500 kV Transmission Lines
.... a study for the Ontario Ministry of Energy and the Interested Citizens Group (Halton Hills).
- Solar Energy and the Conventional Energy Industries
.... a study for the Canadian Ministry of Energy, Mines and Resources.
- The Expert Examiner for the Ontario Royal Commission on Electric Power Planning during hearings into Priority Projects.

- Various Studies into Unconventional Electrical Resources
.... for the P.E.I. Institute of Man and Resources and the P.E.I
Energy Corporation.
- Analysis and Expert Testimony in Support of Lower Demand
Rates for Lake Ontario Steel Company Limited, Ivaco
Industries Limited and Atlas Steels.
- Claims for Consequential Damages of the Roseton Boiler
Implosions
.... for Consolidated Edison Company, Central Hudson Power
Company and Niagara Mohawk Power Corporation.
- A study of the Potential for Megawatt Scale Wind Power
Plants in Electrical Utilities
.... for the Canadian Ministry of Energy, Mines and Resources.

These studies have included the need to create special and unique power system models and solution techniques and have addressed significant issues of major importance in the electricity supply industry. Mr. Slater also has carried out assignments for the following clients;

Nova Scotia Power Corporation.
The Government of Prince Edward Island.
The New Brunswick Electric Power Commission.
Ontario Energy Corporation.
Ontario Energy Board.
Go-Home Lake Cottagers Associations.
Saskatchewan Power Corporation.
FMC Corporation.
FMC of Canada Limited.
ERCO Industries Limited.
Canadian Occidental Petroleum Ltd.
State Energy Commission (Western Australia).
Toronto District Heating Corporation.

In connection with his consulting activities, Mr. Slater gave expert testimony in the state of Idaho and in the provinces of Ontario and Prince Edward Island.

Mr. Slater also was a principal developer of PROMOD III, a proprietary electric utility production cost and reliability model owned by Energy Management Associates, Inc.. This model was used by over seventy utilities in Canada, the United States, Japan and Australia. Its wide acceptance made it the "Industry Standard" in the U.S..

1983-90

As Vice President and Chief Engineer for Energy Management Associates, Inc., Mr. Slater was responsible for giving technical direction for the development and maintenance of Energy Management Associates, Inc., state-of-the-art software products. As Senior Vice President and Chief Engineer, Mr. Slater was head of the Energy Management Associates, Inc.'s utility consulting practice. He led or made significant contributions to a number of important consulting engagements, including:

- . Study and regulatory testimony concerning the value to the Idaho Power Company system of the interruptibility provisions in F.M.C.'s supply contract.
- . Generation planning studies for Cincinnati Gas and Electric Company, San Diego Gas & Electric Company and the City of Austin Electric Utility Department.
- . Assistance to legal counsel during regulatory litigation regarding the hostile takeover of a major Canadian gas utility holding company (Union Enterprises), including definition and examination of issues, selection of witnesses, and analysis of the opposing case.
- . Development and demonstration of a method for the allocation of the Inland Power Pool's operating reserve requirement among its members.
- . Analysis of replacement power costs during the outage of Niagara Mohawk Power Corporation's Nine Mile Point #1 nuclear unit.
- . Reserve margin assessments for Public Service Company of Indiana, Allegheny Power System Inc., Iowa Electric Light & Power Company, San Diego Gas & Electric Company, and El Paso Electric Company.

- . Examination of the gas supply situation in Southern California and regulatory testimony regarding the "unbundling" of storage service.
- . Evaluation of the operational, planning and financial impacts of merging two large Eastern U.S. electric utilities.
- . Study and regulatory testimony regarding the value and appropriate level of interruptible demand for the Union Gas system.
- . Evaluation of the benefits of increased operational integration of a group of electric utilities.
- . Assistance for Tucson Electric Power Co. and its legal counsel during arbitration of its dispute with San Diego Gas and Electric Company regarding the operation of a large power sale agreement.
- . Analysis of the economics of a third A/C transmission line linking California and Oregon.
- . A seminar on "Power Pooling and Inter-Utility Interconnections" for the management of the Central Electricity Generating Board and other parties involved in U.K. privatisation.
- . Determination of the benefits of pool membership for two electric utilities in the Northeast U.S..
- . Assistance for Riley Stoker Corporation and its legal counsel with the arbitration of direct and consequential damages arising out of the late completion and early poor performance of two major coal-fired generating units. The work included case examination and development, detailed reconstruction of events, analysis of all financial and economic consequences of project delay and performance with separation of fault, analysis of opponent's case and assistance with cross-examination, direct and rebuttal testimony, and assistance with oral and written argument.

Mr. Slater's consulting assignments included the areas of power system planning, operations, reliability, economics, ratemaking and assessment of the worth of unconventional resources. He appeared as an expert witness in regulatory hearings in Idaho, Iowa, Indiana, Florida, California, Texas, Ontario and Nova Scotia and in civil arbitration proceedings in Louisiana and Pennsylvania.

Mr. Slater continued to contribute to the development of E.M.A.'s utility software products. His contributions included being a principal developer of SENDOUT, E.M.A.'s proprietary supply model for gas utilities.

1990- In August 1990, Mr. Slater returned to working in his own practice, in Atlanta, where he heads a small corporation, Slater Consulting, which provides consulting services and expert testimony for various different participants in the utility industry.

Slater Consulting assignments, led by Mr. Slater, have included:

- Assistance to legal council for creditors of a bankrupt utility.
- Analysis and testimony for Texas - New Mexico Power Company regarding prudent alternatives to their decision to build TNP ONE Unit 2.
- Assistance and analysis for a utility and its legal counsel during litigation regarding damages sustained because of interference in a proposed merger of that utility with another utility.
- Analyses and testimony before the New York PSC for Sithe Energies, Inc., in certification proceedings and in numerous avoided cost and buy-back rate proceedings.
- Analyses and testimony for the Independent Power Producers of New York in QF curtailment, buy-back rate and back-up rate proceedings before the New York PSC.
- Analysis and testimony for Southwestern Public Service Co. at FERC and before the New Mexico Public Service Commission regarding the lack of production cost savings from the proposed merger of Central & South West Utilities with El Paso Electric Company.
- Analyses and testimony before the Public Service Commission for Independent Power Producers in Florida regarding QF curtailment.

- Analyses and testimony in Civil Court cases for Independent Power Producers in Florida regarding the correct implementation of contractual dispatchability provisions.
- Testimony before regulatory commissions in New York, Pennsylvania, Texas, Florida and Louisiana regarding various aspects of emerging competition.
- Analyses and testimony before the Georgia Public Service Commission on behalf of Mid-Georgia Co-gen and others regarding avoided costs on the Georgia Power / Southern Company system.
- Analysis and testimony before the Georgia Public Service Commission on behalf of Georgia Power Company regarding the Prudence of Georgia Power's 1978-1980 investment in the Rocky Mountain pumped storage plant.
- Testimony before the regulatory commissions of Texas, Virginia and Wisconsin regarding the fair allocation of utility revenue requirements to individual customer classes.
- Testimony before the United States Bankruptcy Court regarding the value of the non-nuclear assets of Cajun Electric Power Co-operative, Inc.
- Analyses for Sithe Energies, Inc. of the future dispatch and associated energy revenues for numerous generating resources in the Northeast United States.
- Operational planning analyses for Sithe Energies, Inc. regarding numerous existing and new generating resources in the Northeast United States.
- Analyses and testimony in Courts and before arbitrators for the non-operating owners of the South Texas Nuclear Project, the Cooper nuclear unit in Nebraska, and the Millstone 3 nuclear unit in Connecticut concerning the replacement power costs during extended outages.

In connection with these and other assignments, Mr. Slater has appeared as an expert in regulatory proceedings in Florida, Georgia, Louisiana, New Mexico, New York, Pennsylvania, South Carolina, Virginia, Wisconsin and Texas, and at the Federal Energy Regulatory Commission. He has also appeared in Federal Bankruptcy Court, state courts in Virginia, Nebraska, Texas and Florida, and civil arbitration proceedings in Nevada and Pennsylvania.

PUBLICATIONS & PRESENTATIONS

- "Meeting System Demand"
Canada-USSR Electric Power Working Group Electrical Seminar.
Montreal, March, 1973.
- "Stochastic Model for Use in Determining Optimal Power System Operating Strategies."
Power Devices and Systems Group, Electrical Engineering Department.
University of Toronto - 1973.
- "Economy-Security Functions in Power System Operations"
IEEE Power System Economic Subcommittee Work Group Paper
IEEE Special Publication 75 CH0960-6-PWR-1975.
- "Economy-Security Functions in Power System Operations - A Summary Introduction."
IEEE Power System Economics Subcommittee Working Group Paper
IEEE T.P.A.S. Sept/Oct 1975 p. 1618.
- "A Large Hydro-Thermal Scheduling Model"
TIMS/ORSA
Miami, November 1976.
- "Generation System Modeling for Planning and Operations"
Atlantic Regional Thermal Conference
Charlottetown, June 1978.
- "The Feasibility of Electricity Export from CANDU Nuclear Generation"
Canadian Nuclear Association
Ottawa, June 1978.
- "Evaluation of the Worth of System Scale Wind Generation to the Prince Edward Island Electrical Grid."
IEEE Canadian Conference
Toronto, October 1979.
- "The Results of a Study Examining The Possible Impact of Solar Space Heating on the Electrical Utility in New Brunswick."
The Potential Impacts of the Deployment of Solar Heating on Electrical Utilities - A workshop sponsored by the Canadian Department of Energy, Mines and Resources
Ottawa, May 1980.

"Reliability Indices: Their Meanings and Differences"

Planmetrics/Energy Management Associates, Inc. 8th Annual National
Utilities Conference
Chicago, May 1980.

"Description and Bibliography of Major Economy-Security Functions

Part I - Description

Part II - Bibliography (1959-1972)

Part III - Bibliography (1973-1979)"

IEEE Power System Economics Subcommittee Working Group
Papers(3).

IEEE TPAS January 1981, p.211, p.214. p.224.

"PROMOD III Evaluation of the Worth of Grid Connected WECS."

Fifth Annual Wind Energy Symposium. Ryerson Polytechnical Institute
Toronto, December 1982.

"Probabilistic Simulation in Power System Production Models"

China-U.S.A. Power System Meeting, Electrical Power Research
Institute of China

Tianjin, China, June 1985.

"Computer Modeling of Wheeling Arrangements"

Electricity Consumers Resource Council Seminar

Washington, D.C. September 1985.

"Power Systems Reliability Improvement Benefits - A Framework for Analysis"

ASME Energy-Sources Technology Conference

Dallas, February 1987.

**FUEL PRICE ASSUMPTIONS FOR PROMOD IV(R) ANALYSES OF
OSPREY PROJECT OPERATIONS, BASE CASE**

(All Values in cents/mmbtu)

| <u>Year</u> | <u>COAL</u> | | <u>#2 OIL</u> | | <u>#6 OIL</u> | | <u>GAS</u> | | | |
|-------------|---------------------|----------------------|---------------------|----------------------|---------------------|----------------------|---------------------|---------------|----------------------|---------------|
| | <u>Lowest Price</u> | <u>Highest Price</u> | <u>Lowest Price</u> | <u>Highest Price</u> | <u>Lowest Price</u> | <u>Highest Price</u> | <u>Lowest Price</u> | | <u>Highest Price</u> | |
| | | | | | | | <u>Winter</u> | <u>Summer</u> | <u>Winter</u> | <u>Summer</u> |
| 2000 | 158.3 | 248.2 | 558.2 | 656.1 | 365.2 | 489.2 | 346.4 | 346.2 | 377.6 | 380.1 |
| 2001 | 157.0 | 246.2 | 510.6 | 600.1 | 323.9 | 433.9 | 376.7 | 347.4 | 410.8 | 381.4 |
| 2002 | 162.5 | 254.8 | 496.1 | 583.1 | 315.5 | 422.6 | 377.2 | 347.4 | 411.4 | 381.4 |
| 2003 | 168.0 | 263.3 | 528.5 | 621.2 | 329.3 | 441.1 | 382.6 | 358.1 | 417.3 | 393.2 |
| 2004 | 173.4 | 271.9 | 561.0 | 659.4 | 343.1 | 459.6 | 393.4 | 368.9 | 429.1 | 405.0 |
| 2005 | 178.3 | 279.6 | 593.0 | 697.0 | 357.1 | 478.3 | 404.2 | 379.7 | 440.9 | 416.8 |
| 2006 | 182.3 | 285.9 | 614.2 | 721.9 | 368.2 | 493.3 | 415.1 | 390.7 | 452.9 | 428.8 |
| 2007 | 186.4 | 292.3 | 636.1 | 747.7 | 379.8 | 508.7 | 427.3 | 404.0 | 466.1 | 443.3 |
| 2008 | 190.6 | 298.9 | 658.8 | 774.4 | 391.6 | 524.6 | 440.7 | 417.6 | 480.8 | 458.3 |
| 2009 | 194.9 | 305.6 | 682.3 | 802.0 | 403.9 | 541.0 | 454.6 | 431.8 | 496.0 | 473.7 |
| 2010 | 199.3 | 312.5 | 706.7 | 830.6 | 416.5 | 558.0 | 468.9 | 446.4 | 511.7 | 489.7 |
| 2011 | 203.7 | 319.4 | 727.3 | 854.9 | 430.7 | 576.9 | 483.8 | 461.4 | 527.9 | 506.1 |
| 2012 | 208.3 | 326.5 | 748.6 | 879.9 | 445.3 | 596.5 | 499.1 | 477.0 | 544.7 | 523.1 |

**FUEL PRICE ASSUMPTIONS FOR PROMOD IV(R) ANALYSES OF
OSPREY PROJECT OPERATIONS, HIGHER GAS PRICE CASE**

(All Values in cents/mmbtu)

| <u>Year</u> | <u>COAL</u> | | <u>#2 OIL</u> | | <u>#6 OIL</u> | | <u>GAS</u> | | | |
|-------------|---------------|----------------|---------------|----------------|---------------|----------------|---------------------|---------------|----------------------|---------------|
| | <u>Lowest</u> | <u>Highest</u> | <u>Lowest</u> | <u>Highest</u> | <u>Lowest</u> | <u>Highest</u> | <u>Lowest Price</u> | | <u>Highest Price</u> | |
| | <u>Price</u> | <u>Price</u> | <u>Price</u> | <u>Price</u> | <u>Price</u> | <u>Price</u> | <u>Winter</u> | <u>Summer</u> | <u>Winter</u> | <u>Summer</u> |
| | | | | | | | | | | |
| 2000 | 158.3 | 248.2 | 558.2 | 656.1 | 365.2 | 489.2 | 346.4 | 346.2 | 377.6 | 380.1 |
| 2001 | 157.0 | 246.2 | 510.6 | 600.1 | 323.9 | 433.9 | 376.7 | 347.4 | 410.8 | 381.4 |
| 2002 | 162.5 | 254.8 | 496.1 | 583.1 | 315.5 | 422.6 | 382.6 | 358.1 | 417.3 | 393.2 |
| 2003 | 168.0 | 263.3 | 528.5 | 621.2 | 329.3 | 441.1 | 393.4 | 368.9 | 429.1 | 405.0 |
| 2004 | 173.4 | 271.9 | 561.0 | 659.4 | 343.1 | 459.6 | 404.2 | 379.7 | 440.9 | 416.8 |
| 2005 | 178.3 | 279.6 | 593.0 | 697.0 | 357.1 | 478.3 | 415.1 | 390.7 | 452.9 | 428.8 |
| 2006 | 182.3 | 285.9 | 614.2 | 721.9 | 368.2 | 493.3 | 430.9 | 411.3 | 470.1 | 451.3 |
| 2007 | 186.4 | 292.3 | 636.1 | 747.7 | 379.8 | 508.7 | 451.9 | 432.8 | 493.2 | 474.9 |
| 2008 | 190.6 | 298.9 | 658.8 | 774.4 | 391.6 | 524.6 | 474.0 | 455.4 | 517.3 | 499.7 |
| 2009 | 194.9 | 305.6 | 682.3 | 802.0 | 403.9 | 541.0 | 497.2 | 479.2 | 542.7 | 525.7 |
| 2010 | 199.3 | 312.5 | 706.7 | 830.6 | 416.5 | 558.0 | 521.6 | 504.2 | 569.4 | 553.0 |
| 2011 | 203.7 | 319.4 | 727.3 | 854.9 | 430.7 | 576.9 | 544.1 | 524.3 | 594.0 | 574.9 |
| 2012 | 208.3 | 326.5 | 748.6 | 879.9 | 445.3 | 596.5 | 564.5 | 545.1 | 616.4 | 597.7 |

EFFICIENCY AND COST-EFFECTIVENESS OF PENINSULAR FLORIDA GENERATING UNITS, 2003

| Plant | Unit | Summer Capacity (MW) | Average Annual Heat Rate (Btu/kwh) | Average Annual Dispatch Cost (\$/MWh) |
|---------------------------------------|------|----------------------------|--|---|
| <u>Nuclear</u> | | | | |
| CRYSTAL | 3 | 805 | Must Run at Maximum Available Capacity | |
| STLUCIE | 1 | 839 | Must Run at Maximum Available Capacity | |
| STLUCIE | 2 | 839 | Must Run at Maximum Available Capacity | |
| TURKEYPT | 3 | 697 | Must Run at Maximum Available Capacity | |
| TURKEYPT | 4 | 697 | Must Run at Maximum Available Capacity | |
| <u>Coal and Petroleum Coke</u> | | | | |
| BIG BEND | 1 | 421 | 9,965 | 30.29 |
| BIG BEND | 2 | 421 | 9,972 | 30.57 |
| BIG BEND | 3 | 428 | 9,956 | 28.72 |
| BIG BEND | 4 | 442 | 9,943 | 26.93 |
| CRYSTAL | 1 | 386 | 9,679 | 25.40 |
| CRYSTAL | 2 | 488 | 9,596 | 25.26 |
| CRYSTAL | 4 | 714 | 9,094 | 23.67 |
| CRYSTAL | 5 | 697 | 9,092 | 23.41 |
| DEERHAVN | 2 | 228 | 10,608 | 25.20 |
| GANNON | 1 | 0 | 9,688 | 31.24 |
| GANNON | 2 | 0 | 9,671 | 31.19 |
| GANNON | 6 | 362 | 10,246 | 35.01 |
| MCINTOSH | 3 | 338 | 9,093 | 23.65 |
| NORTHSID | 1 | 265 | 9,753 | 23.34 |
| NORTHSID | 2 | 265 | 13,156 | 29.42 |
| SCHERER | 4 | 846 | 9,949 | 24.53 |
| SEMINOLE | 1 | 638 | 10,041 | 26.38 |
| SEMINOLE | 2 | 638 | 10,041 | 26.28 |
| ST JOHNS | 1 | 624 | 9,179 | 22.26 |
| ST JOHNS | 2 | 638 | 9,258 | 22.88 |
| STANTON | 1 | 442 | 9,777 | 24.99 |
| STANTON | 2 | 446 | 9,079 | 22.85 |

New Gas Combined Cycle

| | | | | |
|----------|----|------|-------|-------|
| BAYSIDE | 1 | 707 | 7,236 | 29.38 |
| BRANDY B | 4 | 482 | 7,176 | 29.68 |
| CANE IS | 3 | 260 | 6,999 | 28.11 |
| FT MYERS | 3 | 1446 | 7,145 | 29.08 |
| HINES EC | 1 | 470 | 7,049 | 28.30 |
| HINES EC | 2 | 0 | 7,002 | 29.59 |
| KELLEY | 4 | 113 | 8,362 | 36.91 |
| N SMYRNA | 1 | 520 | 6,971 | 28.04 |
| OKEECHOB | 1 | 260 | 6,965 | 27.76 |
| OKEECHOB | 2 | 260 | 6,966 | 27.76 |
| OSPREY | 1 | 520 | 6,967 | 28.09 |
| PAYNECRK | 3 | 520 | 7,001 | 28.14 |
| PURDOM | 8 | 260 | 6,995 | 28.10 |
| SANFORD | 14 | 964 | 7,206 | 29.29 |
| SANFORD | 15 | 964 | 7,208 | 29.29 |

Other Units

| | | | | |
|----------|---|-----|-----------------------|-------|
| ANCLOTE | 1 | 503 | 10,952 | 69.84 |
| ANCLOTE | 2 | 503 | 10,485 | 66.36 |
| AVONPKG1 | 1 | 29 | No Significant Output | |
| AVONPKG2 | 2 | 29 | No Significant Output | |
| BARTOW | 1 | 115 | 9,982 | 39.38 |
| BARTOW | 2 | 117 | 9,983 | 39.81 |
| BARTOW | 3 | 208 | 9,975 | 38.84 |
| BARTOWGT | 1 | 46 | No Significant Output | |
| BARTOWGT | 2 | 46 | No Significant Output | |
| BARTOWGT | 3 | 46 | No Significant Output | |
| BARTOWGT | 4 | 49 | No Significant Output | |
| BAYBROGT | 1 | 47 | No Significant Output | |
| BAYBROGT | 2 | 47 | No Significant Output | |
| BAYBROGT | 3 | 47 | No Significant Output | |
| BAYBROGT | 4 | 47 | No Significant Output | |
| BGBENDGT | 1 | 12 | No Significant Output | |
| BGBENDGT | 2 | 61 | 11,635 | 75.05 |
| BGBENDGT | 3 | 61 | 11,635 | 75.10 |
| BRANDY B | 1 | 0 | 11,224 | 56.71 |
| BRANDY B | 2 | 0 | 11,266 | 56.96 |
| BRANDY B | 3 | 153 | 11,383 | 56.01 |
| CANE GT | 1 | 30 | 11,166 | 50.91 |
| CANE ISL | 2 | 108 | 9,583 | 42.41 |
| CAPECNVR | 1 | 405 | 9,437 | 40.46 |
| CAPECNVR | 2 | 408 | 9,441 | 40.66 |
| CUDJOE D | 1 | 5 | No Significant Output | |
| CUTLER | 5 | 71 | 11,720 | 45.14 |
| CUTLER | 6 | 144 | 11,741 | 45.33 |

| | | | | |
|----------|----|-----|-----------------------|-------|
| DEBARYGT | 1 | 54 | No Significant Output | |
| DEBARYGT | 2 | 54 | 11,730 | 76.32 |
| DEBARYGT | 3 | 54 | No Significant Output | |
| DEBARYGT | 4 | 54 | No Significant Output | |
| DEBARYGT | 5 | 54 | No Significant Output | |
| DEBARYGT | 6 | 54 | No Significant Output | |
| DEBARYGT | 7 | 88 | 11,890 | 76.92 |
| DEBARYGT | 8 | 88 | 11,890 | 76.97 |
| DEBARYGT | 9 | 88 | 11,880 | 76.91 |
| DEBARYGT | 10 | 88 | 11,880 | 77.09 |
| DEERHAVN | 1 | 85 | 10,604 | 45.57 |
| DRHVN GT | 1 | 18 | 14,471 | 68.60 |
| DRHVN GT | 2 | 18 | 14,471 | 68.80 |
| DRHVN GT | 3 | 75 | 14,471 | 68.15 |
| EVERGL T | 1 | 35 | 17,121 | 74.24 |
| EVERGL T | 2 | 35 | 17,121 | 74.10 |
| EVERGL T | 3 | 35 | 17,121 | 73.81 |
| EVERGL T | 4 | 35 | 17,121 | 73.86 |
| EVERGL T | 5 | 35 | 17,121 | 73.60 |
| EVERGL T | 6 | 35 | 17,121 | 73.92 |
| EVERGL T | 7 | 35 | 17,121 | 73.65 |
| EVERGL T | 8 | 35 | 17,121 | 73.39 |
| EVERGL T | 9 | 35 | 17,121 | 73.35 |
| EVERGL T | 10 | 35 | 17,121 | 73.46 |
| EVERGL T | 11 | 35 | 17,121 | 73.04 |
| EVERGL T | 12 | 35 | No Significant Output | |
| EVERGLDS | 1 | 221 | 9,550 | 38.49 |
| EVERGLDS | 2 | 221 | 9,557 | 38.63 |
| EVERGLDS | 3 | 375 | 9,944 | 39.71 |
| EVERGLDS | 4 | 410 | 9,925 | 39.66 |
| FTMYER T | 1 | 54 | No Significant Output | |
| FTMYER T | 2 | 54 | No Significant Output | |
| FTMYER T | 3 | 54 | No Significant Output | |
| FTMYER T | 4 | 54 | No Significant Output | |
| FTMYER T | 5 | 54 | No Significant Output | |
| FTMYER T | 6 | 54 | No Significant Output | |
| FTMYER T | 7 | 54 | No Significant Output | |
| FTMYER T | 8 | 54 | No Significant Output | |
| FTMYER T | 9 | 54 | No Significant Output | |
| FTMYER T | 10 | 54 | No Significant Output | |
| FTMYER T | 11 | 54 | No Significant Output | |
| FTMYER T | 12 | 54 | No Significant Output | |
| FTMYERCT | 13 | 153 | 11,302 | 52.34 |
| FTMYERCT | 14 | 153 | 11,311 | 52.38 |
| GANNONGT | 1 | 12 | No Significant Output | |
| HANSELCC | 2 | 48 | 9,817 | 46.24 |
| HANSELIC | 8 | 3 | 9,300 | 43.19 |

| | | | | |
|----------|----|-----|-----------------------|-------|
| HANSELIC | 14 | 2 | 9,300 | 43.23 |
| HANSELIC | 15 | 2 | 9,300 | 43.25 |
| HANSELIC | 16 | 2 | 9,300 | 43.25 |
| HANSELIC | 17 | 2 | 9,300 | 43.23 |
| HANSELIC | 18 | 2 | No Significant Output | |
| HANSELIC | 19 | 3 | No Significant Output | |
| HANSELIC | 20 | 3 | 9,300 | 43.25 |
| HARDEE | 1 | 224 | 7,300 | 34.54 |
| HARDEECT | 1 | 74 | 9,732 | 45.33 |
| HIGGNSGT | 1 | 29 | No Significant Output | |
| HIGGNSGT | 2 | 29 | No Significant Output | |
| HIGGNSGT | 3 | 35 | No Significant Output | |
| HIGGNSGT | 4 | 35 | No Significant Output | |
| HOOKERS | 1 | 0 | No Significant Output | |
| HOOKERS | 2 | 0 | No Significant Output | |
| HOOKERS | 3 | 0 | No Significant Output | |
| HOOKERS | 4 | 0 | No Significant Output | |
| HOOKERS | 5 | 0 | No Significant Output | |
| HOPKINGT | 1 | 12 | 14,029 | 60.59 |
| HOPKINGT | 2 | 24 | 13,597 | 63.57 |
| HOPKINS | 1 | 75 | 11,357 | 47.25 |
| HOPKINS | 2 | 238 | 10,652 | 41.92 |
| IND RIVR | 1 | 88 | 10,033 | 42.34 |
| IND RIVR | 2 | 201 | 9,982 | 39.50 |
| IND RIVR | 3 | 319 | 10,469 | 41.65 |
| INDRVRGT | 1 | 37 | 11,540 | 52.40 |
| INDRVRGT | 2 | 37 | 11,540 | 52.51 |
| INDRVRGT | 3 | 108 | 11,100 | 50.84 |
| INDRVRGT | 4 | 108 | 11,100 | 50.84 |
| INTER GT | 1 | 47 | No Significant Output | |
| INTER GT | 2 | 47 | No Significant Output | |
| INTER GT | 3 | 47 | No Significant Output | |
| INTER GT | 4 | 47 | No Significant Output | |
| INTER GT | 5 | 47 | No Significant Output | |
| INTER GT | 6 | 47 | No Significant Output | |
| INTER GT | 7 | 83 | 12,210 | 79.38 |
| INTER GT | 8 | 83 | No Significant Output | |
| INTER GT | 9 | 83 | No Significant Output | |
| INTER GT | 10 | 83 | 12,030 | 77.69 |
| INTER GT | 11 | 143 | 12,030 | 78.03 |
| INTER GT | 12 | 76 | 12,572 | 59.75 |
| INTER GT | 13 | 76 | 12,558 | 59.59 |
| INTER GT | 14 | 76 | 12,523 | 59.47 |
| IVEY IC | 1 | 4 | 9,300 | 42.70 |
| IVEY IC | 2 | 5 | 9,300 | 42.71 |
| IVEY IC | 3 | 9 | 12,280 | 54.15 |
| IVEY IC | 4 | 6 | 12,280 | 54.23 |

| | | | | |
|----------|----|-----|-----------------------|-------|
| IVEY IC | 5 | 4 | 9,300 | 42.70 |
| IVEY IC | 6 | 18 | 9,300 | 42.70 |
| KELLY | 7 | 23 | 16,441 | 68.60 |
| KELLY GT | 1 | 14 | No Significant Output | |
| KELLY GT | 2 | 14 | No Significant Output | |
| KELLY GT | 3 | 14 | No Significant Output | |
| KENEDYGT | 3 | 54 | No Significant Output | |
| KENEDYGT | 4 | 54 | No Significant Output | |
| KENEDYGT | 5 | 54 | No Significant Output | |
| KENEDYGT | 7 | 153 | 11,380 | 56.05 |
| KING | 5 | 8 | 10,483 | 42.59 |
| KING | 6 | 17 | 12,842 | 51.73 |
| KING | 7 | 32 | 12,858 | 54.99 |
| KING | 8 | 50 | 12,710 | 52.43 |
| KING DSL | 1 | 5 | No Significant Output | |
| KING GT | 9 | 23 | 10,500 | 51.01 |
| LARSEN | 8 | 102 | 10,610 | 42.77 |
| LARSENGT | 2 | 10 | No Significant Output | |
| LARSENGT | 3 | 10 | No Significant Output | |
| LAUDER T | 1 | 36 | 15,908 | 66.47 |
| LAUDER T | 2 | 35 | 15,908 | 66.46 |
| LAUDER T | 3 | 35 | 15,908 | 66.53 |
| LAUDER T | 4 | 35 | 15,908 | 66.47 |
| LAUDER T | 5 | 35 | 15,908 | 66.54 |
| LAUDER T | 6 | 35 | 15,908 | 66.44 |
| LAUDER T | 7 | 35 | 15,908 | 66.55 |
| LAUDER T | 8 | 35 | 15,908 | 66.59 |
| LAUDER T | 9 | 35 | 15,908 | 66.62 |
| LAUDER T | 10 | 35 | 15,908 | 66.61 |
| LAUDER T | 11 | 35 | 15,908 | 66.70 |
| LAUDER T | 12 | 35 | 15,908 | 66.71 |
| LAUDER T | 13 | 35 | 16,227 | 67.94 |
| LAUDER T | 14 | 35 | 16,227 | 67.94 |
| LAUDER T | 15 | 35 | 16,227 | 67.92 |
| LAUDER T | 16 | 35 | 16,227 | 68.11 |
| LAUDER T | 17 | 35 | 16,227 | 68.09 |
| LAUDER T | 18 | 35 | 16,227 | 68.04 |
| LAUDER T | 19 | 35 | 16,227 | 68.02 |
| LAUDER T | 20 | 35 | 16,227 | 68.19 |
| LAUDER T | 21 | 35 | 16,227 | 68.28 |
| LAUDER T | 22 | 32 | 16,227 | 68.21 |
| LAUDER T | 23 | 32 | 16,227 | 68.15 |
| LAUDER T | 24 | 35 | 16,227 | 68.35 |
| LAUDERCC | 4 | 440 | 7,640 | 32.83 |
| LAUDERCC | 5 | 440 | 7,654 | 33.48 |
| MANATEE | 1 | 819 | 9,928 | 39.50 |
| MANATEE | 2 | 819 | 9,909 | 39.50 |

| | | | | |
|----------|---|-----|-----------------------|-------|
| MARATHON | 1 | 8 | No Significant Output | |
| MARATHON | 2 | 5 | 9,300 | 42.70 |
| MARATHON | 3 | 8 | 12,280 | 54.18 |
| MARTIN | 1 | 814 | 8,904 | 36.37 |
| MARTIN | 2 | 816 | 8,939 | 36.16 |
| MARTINCC | 3 | 445 | 7,232 | 31.20 |
| MARTINCC | 4 | 445 | 7,235 | 31.08 |
| MARTINCT | 1 | 153 | 11,266 | 52.39 |
| MARTINCT | 2 | 153 | 11,266 | 52.38 |
| MCINT GT | 1 | 17 | 15,000 | 65.71 |
| MCINT IC | 1 | 5 | No Significant Output | |
| MCINTOSH | 1 | 87 | 10,815 | 43.98 |
| MCINTOSH | 2 | 103 | 10,274 | 40.96 |
| MCINTOSH | 5 | 310 | 7,262 | 30.03 |
| NORTH GT | 3 | 52 | No Significant Output | |
| NORTH GT | 4 | 52 | No Significant Output | |
| NORTH GT | 5 | 52 | No Significant Output | |
| NORTH GT | 6 | 52 | No Significant Output | |
| NORTHSID | 3 | 505 | 9,688 | 40.75 |
| OLEAN GT | 1 | 153 | 11,291 | 52.41 |
| OLEAN GT | 2 | 153 | 11,303 | 52.48 |
| OLEAN GT | 3 | 153 | 11,301 | 52.43 |
| OLEAN GT | 4 | 153 | 11,316 | 52.50 |
| OLEAN GT | 5 | 153 | 11,325 | 52.51 |
| PHILLIPS | 1 | 17 | 13,500 | 55.45 |
| PHILLIPS | 2 | 17 | 13,500 | 55.48 |
| POLK CT | 2 | 153 | 11,366 | 54.72 |
| POLK CT | 3 | 153 | 11,348 | 54.74 |
| POLKIGCC | 1 | 250 | 10,079 | 29.97 |
| PURDOM | 7 | 48 | 16,947 | 69.23 |
| PURDOMGT | 1 | 12 | No Significant Output | |
| PURDOMGT | 2 | 12 | No Significant Output | |
| PUTNAMCC | 1 | 249 | 9,115 | 39.31 |
| PUTNAMCC | 2 | 249 | 9,114 | 39.36 |
| REEDYCRK | 1 | 35 | 10,400 | 45.89 |
| RIOPINGT | 1 | 15 | No Significant Output | |
| RIVIERA | 3 | 290 | 9,729 | 37.23 |
| RIVIERA | 4 | 290 | 9,729 | 37.52 |
| SANFORD | 3 | 153 | 8,877 | 40.06 |
| SEM CT | 1 | 153 | 11,357 | 54.83 |
| SMITH | 1 | 7 | 18,840 | 75.52 |
| SMITH | 2 | 7 | 18,822 | 75.58 |
| SMITH | 3 | 22 | 16,777 | 70.99 |
| SMITH | 4 | 32 | 16,798 | 71.08 |
| SMITH D | 1 | 9 | No Significant Output | |
| SMITH CC | 1 | 32 | 10,400 | 48.43 |
| SMITH GT | 1 | 26 | No Significant Output | |

| | | | | |
|----------|---|-----|--------|-----------------------|
| SMITH ST | 1 | 3 | | No Significant Output |
| SMITH ST | 2 | 2 | | No Significant Output |
| SMITH ST | 3 | 6 | | No Significant Output |
| ST CLOUD | 1 | 4 | | No Significant Output |
| ST CLOUD | 2 | 6 | | No Significant Output |
| ST CLOUD | 3 | 6 | | No Significant Output |
| ST CLOUD | 4 | 12 | 10,696 | 73.23 |
| STOCK DS | 1 | 9 | 9,300 | 64.95 |
| STOCK DS | 2 | 9 | 9,300 | 65.06 |
| STOCK GT | 1 | 21 | | No Significant Output |
| STOCK GT | 2 | 16 | | No Significant Output |
| STOCK GT | 3 | 16 | | No Significant Output |
| STOCK IC | 1 | 6 | | No Significant Output |
| SUWAN GT | 1 | 54 | | No Significant Output |
| SUWAN GT | 2 | 54 | | No Significant Output |
| SUWAN GT | 3 | 54 | | No Significant Output |
| SUWANNEE | 1 | 33 | 11,729 | 51.07 |
| SUWANNEE | 2 | 32 | 11,733 | 51.09 |
| SUWANNEE | 3 | 80 | 11,750 | 51.17 |
| SWOOPEIC | 1 | 5 | | No Significant Output |
| TIGERBAY | 1 | 194 | 7,553 | 32.32 |
| TURKEYIC | 1 | 14 | | No Significant Output |
| TURKEYPT | 1 | 410 | 9,433 | 39.54 |
| TURKEYPT | 2 | 400 | 9,395 | 39.80 |
| TURNERGT | 1 | 15 | | No Significant Output |
| TURNERGT | 2 | 15 | | No Significant Output |
| TURNERGT | 3 | 65 | | No Significant Output |
| TURNERGT | 4 | 65 | | No Significant Output |
| UNIV FLA | 1 | 36 | 11,166 | 50.41 |
| VERO BCH | 1 | 13 | 13,041 | 52.60 |
| VERO BCH | 2 | 13 | 8,928 | 36.66 |
| VERO BCH | 3 | 33 | 13,141 | 54.47 |
| VERO BCH | 4 | 56 | 11,739 | 48.61 |
| VERO BCH | 5 | 35 | 11,171 | 45.71 |

NUGs

| | | | | |
|-----------|---|-----|--|--|
| AGRICHEM | 1 | 6 | | |
| AS-AVAIL | 1 | 63 | | |
| BAY CTY | 1 | 11 | | |
| BIOENRGY | 1 | 10 | | |
| BROWARDS | 1 | 54 | | |
| BROWARDS | 2 | 56 | | |
| CARGILL | 2 | 15 | | |
| CEDARBAY | 1 | 250 | | |
| CFR BIOGN | 1 | 74 | | |
| DADE CTY | 1 | 43 | | |

| | | |
|----------|---|-----|
| ELDORADO | 1 | 114 |
| FLASTONE | 1 | 133 |
| HILLSBOR | 1 | 26 |
| INDIANTN | 1 | 330 |
| LAKE CTY | 1 | 13 |
| LAKECOGN | 1 | 110 |
| LFC JEFF | 1 | 9 |
| LFC MADS | 1 | 9 |
| MULB-FPC | 1 | 79 |
| ORANGE | 1 | 22 |
| ORLANDO | 1 | 79 |
| PALMBCH | 1 | 44 |
| PASCO | 1 | 109 |
| PASCOCTY | 1 | 23 |
| PINELLAS | 1 | 40 |
| PINELLAS | 2 | 15 |
| RIDGE | 1 | 40 |
| ROYSTER | 1 | 31 |
| TAMPACTY | 1 | 19 |
| JEA-QFs | | 17 |

External Purchases

| | | |
|--------------|---|------|
| ENERGY | 1 | 23 |
| SOUTHERN CO. | | 1615 |

Source: PROMOD IV(R) analyses prepared by Slater Consulting

EFFICIENCY AND COST-EFFECTIVENESS OF PENINSULAR FLORIDA GENERATING UNITS, 2008

| Plant | Unit | Summer Capacity (MW) | Average Annual Heat Rate (Btu/kwh) | Average Annual Dispatch Cost (\$/MWh) |
|---------------------------------------|------|----------------------------|--|---|
| <u>Nuclear</u> | | | | |
| CRYSTAL | 3 | 805 | Must Run at Maximum Available Capacity | |
| STLUCIE | 1 | 839 | Must Run at Maximum Available Capacity | |
| STLUCIE | 2 | 839 | Must Run at Maximum Available Capacity | |
| TURKEYPT | 3 | 697 | Must Run at Maximum Available Capacity | |
| TURKEYPT | 4 | 697 | Must Run at Maximum Available Capacity | |
| <u>Coal and Petroleum Coke</u> | | | | |
| BIG BEND | 1 | 421 | 10,017 | 34.67 |
| BIG BEND | 2 | 421 | 10,018 | 35.01 |
| BIG BEND | 3 | 428 | 9,998 | 32.60 |
| BIG BEND | 4 | 442 | 9,980 | 30.78 |
| CRYSTAL | 1 | 386 | 9,682 | 28.16 |
| CRYSTAL | 2 | 488 | 9,600 | 28.04 |
| CRYSTAL | 4 | 714 | 9,124 | 26.57 |
| CRYSTAL | 5 | 697 | 9,121 | 26.10 |
| DEERHAVN | 2 | 228 | 10,609 | 28.60 |
| MCINTOSH | 3 | 338 | 9,099 | 26.95 |
| MCINTOSH | 4 | 288 | 8,492 | 24.19 |
| NORTHSID | 1 | 265 | 9,786 | 26.49 |
| NORTHSID | 2 | 265 | 13,421 | 34.04 |
| SCHERER | 4 | 846 | 9,969 | 27.53 |
| SEMINOLE | 1 | 638 | 10,089 | 29.97 |
| SEMINOLE | 2 | 638 | 10,077 | 29.62 |
| ST JOHNS | 1 | 624 | 9,204 | 25.31 |
| ST JOHNS | 2 | 638 | 9,288 | 25.77 |
| STANTON | 1 | 442 | 9,782 | 27.70 |
| STANTON | 2 | 446 | 9,086 | 26.03 |
| <u>New Gas Combined Cycle</u> | | | | |
| BAYSIDE | 1 | 707 | 7,221 | 34.15 |
| BAYSIDE | 2 | 715 | 7,186 | 34.01 |

| | | | | |
|----------|----|------|-------|-------|
| BRANDY B | 4 | 482 | 7,254 | 34.71 |
| CANE IS | 3 | 260 | 7,026 | 32.74 |
| FT MYERS | 3 | 1446 | 7,203 | 33.90 |
| GREEN CC | 1 | 260 | 6,979 | 32.57 |
| HINES EC | 1 | 470 | 7,082 | 32.95 |
| HINES EC | 2 | 520 | 7,005 | 32.69 |
| HINES EC | 3 | 520 | 7,016 | 32.67 |
| HINES EC | 4 | 520 | 7,020 | 32.74 |
| KELLEY | 4 | 113 | 8,536 | 43.43 |
| MARTINCC | 5 | 380 | 6,804 | 31.96 |
| MARTINCC | 6 | 380 | 6,804 | 31.96 |
| N SMYRNA | 1 | 520 | 6,992 | 32.62 |
| OKEECHOB | 1 | 260 | 6,978 | 32.44 |
| OKEECHOB | 2 | 260 | 6,977 | 32.56 |
| OSPREY | 1 | 520 | 6,984 | 32.57 |
| PAYNECRK | 3 | 520 | 7,037 | 32.76 |
| PURDOM | 8 | 260 | 7,009 | 32.69 |
| SANFORD | 14 | 964 | 7,276 | 34.17 |
| SANFORD | 15 | 964 | 7,282 | 34.17 |
| SEMIN CC | 4 | 260 | 7,010 | 32.67 |
| SEMIN CC | 5 | 260 | 7,011 | 32.67 |
| UNKNOWCC | 1 | 364 | 6,981 | 32.53 |
| UNKNOWCC | 2 | 364 | 6,990 | 32.63 |

Other Units

| | | | | |
|----------|---|-----|-----------------------|-------|
| ANCLOTE | 1 | 503 | 11,581 | 90.11 |
| ANCLOTE | 2 | 503 | 11,378 | 89.16 |
| BARTOW | 1 | 115 | 9,971 | 46.89 |
| BARTOW | 2 | 117 | 10,003 | 46.60 |
| BARTOW | 3 | 208 | 9,978 | 46.05 |
| BARTOWGT | 1 | 46 | No Significant Output | |
| BARTOWGT | 2 | 46 | No Significant Output | |
| BARTOWGT | 3 | 46 | No Significant Output | |
| BARTOWGT | 4 | 49 | No Significant Output | |
| BGBENDGT | 1 | 12 | No Significant Output | |
| BGBENDGT | 2 | 61 | No Significant Output | |
| BGBENDGT | 3 | 61 | No Significant Output | |
| BRANDY B | 3 | 153 | 11,464 | 65.79 |
| CANE GT | 1 | 30 | 11,166 | 59.41 |
| CANE ISL | 2 | 108 | 9,581 | 49.24 |
| CAPECNVR | 1 | 405 | 9,444 | 48.37 |
| CAPECNVR | 2 | 408 | 9,444 | 48.47 |
| CUDJOE D | 1 | 5 | No Significant Output | |
| CUTLER | 5 | 71 | 11,721 | 52.49 |
| CUTLER | 6 | 144 | 11,734 | 52.59 |
| DEBARYGT | 1 | 54 | No Significant Output | |

| | | | | |
|----------|----|-----|--------|-----------------------|
| DEBARYGT | 2 | 54 | | No Significant Output |
| DEBARYGT | 3 | 54 | | No Significant Output |
| DEBARYGT | 4 | 54 | | No Significant Output |
| DEBARYGT | 5 | 54 | | No Significant Output |
| DEBARYGT | 6 | 54 | | No Significant Output |
| DEBARYGT | 7 | 88 | | No Significant Output |
| DEBARYGT | 8 | 88 | | No Significant Output |
| DEBARYGT | 9 | 88 | | No Significant Output |
| DEBARYGT | 10 | 88 | | No Significant Output |
| DEERHAVN | 1 | 85 | 10,609 | 52.93 |
| DRHVN GT | 1 | 18 | | No Significant Output |
| DRHVN GT | 2 | 18 | | No Significant Output |
| DRHVN GT | 3 | 75 | | No Significant Output |
| EVERGL T | 1 | 35 | | No Significant Output |
| EVERGL T | 2 | 35 | | No Significant Output |
| EVERGL T | 3 | 35 | | No Significant Output |
| EVERGL T | 4 | 35 | | No Significant Output |
| EVERGL T | 5 | 35 | | No Significant Output |
| EVERGL T | 6 | 35 | | No Significant Output |
| EVERGL T | 7 | 35 | | No Significant Output |
| EVERGL T | 8 | 35 | | No Significant Output |
| EVERGL T | 9 | 35 | | No Significant Output |
| EVERGL T | 10 | 35 | | No Significant Output |
| EVERGL T | 11 | 35 | | No Significant Output |
| EVERGL T | 12 | 35 | | No Significant Output |
| EVERGLDS | 1 | 221 | 9,546 | 44.78 |
| EVERGLDS | 2 | 221 | 9,551 | 44.71 |
| EVERGLDS | 3 | 375 | 9,897 | 45.90 |
| EVERGLDS | 4 | 410 | 9,892 | 45.91 |
| FTMYER T | 1 | 54 | | No Significant Output |
| FTMYER T | 2 | 54 | | No Significant Output |
| FTMYER T | 3 | 54 | | No Significant Output |
| FTMYER T | 4 | 54 | | No Significant Output |
| FTMYER T | 5 | 54 | | No Significant Output |
| FTMYER T | 6 | 54 | | No Significant Output |
| FTMYER T | 7 | 54 | | No Significant Output |
| FTMYER T | 8 | 54 | | No Significant Output |
| FTMYER T | 9 | 54 | | No Significant Output |
| FTMYER T | 10 | 54 | | No Significant Output |
| FTMYER T | 11 | 54 | | No Significant Output |
| FTMYER T | 12 | 54 | | No Significant Output |
| FTMYERCT | 13 | 153 | 11,343 | 61.30 |
| FTMYERCT | 14 | 153 | 11,355 | 61.33 |
| GANNONGT | 1 | 12 | | No Significant Output |
| HANSELCC | 2 | 48 | 9,777 | 53.15 |
| HANSELIC | 8 | 3 | 9,300 | 50.48 |
| HANSELIC | 14 | 2 | 9,300 | 50.50 |

| | | | | |
|----------|----|-----|-----------------------|-------|
| HANSELIC | 15 | 2 | 9,300 | 50.41 |
| HANSELIC | 16 | 2 | 9,300 | 50.51 |
| HANSELIC | 17 | 2 | 9,300 | 50.42 |
| HANSELIC | 18 | 2 | No Significant Output | |
| HANSELIC | 19 | 3 | No Significant Output | |
| HANSELIC | 20 | 3 | 9,300 | 50.40 |
| HARDEE | 1 | 224 | 7,300 | 39.97 |
| HARDEECT | 1 | 74 | 9,732 | 52.50 |
| HOPKINGT | 1 | 12 | No Significant Output | |
| HOPKINGT | 2 | 24 | No Significant Output | |
| HOPKINS | 1 | 75 | 11,386 | 54.86 |
| HOPKINS | 2 | 238 | 10,636 | 48.54 |
| IND RIVR | 1 | 88 | 10,026 | 49.15 |
| IND RIVR | 2 | 201 | 9,971 | 45.80 |
| IND RIVR | 3 | 319 | 10,463 | 48.23 |
| INDRVRGT | 1 | 37 | 11,540 | 60.96 |
| INDRVRGT | 2 | 37 | 11,540 | 61.06 |
| INDRVRGT | 3 | 108 | 11,100 | 59.03 |
| INDRVRGT | 4 | 108 | 11,100 | 59.15 |
| INTER GT | 1 | 47 | No Significant Output | |
| INTER GT | 2 | 47 | No Significant Output | |
| INTER GT | 3 | 47 | No Significant Output | |
| INTER GT | 4 | 47 | No Significant Output | |
| INTER GT | 5 | 47 | No Significant Output | |
| INTER GT | 6 | 47 | No Significant Output | |
| INTER GT | 7 | 83 | No Significant Output | |
| INTER GT | 8 | 83 | No Significant Output | |
| INTER GT | 9 | 83 | No Significant Output | |
| INTER GT | 10 | 83 | No Significant Output | |
| INTER GT | 11 | 143 | No Significant Output | |
| INTER GT | 12 | 76 | 12,588 | 69.17 |
| INTER GT | 13 | 76 | 12,583 | 69.28 |
| INTER GT | 14 | 76 | 12,567 | 69.23 |
| IVEY IC | 1 | 4 | 9,300 | 50.59 |
| IVEY IC | 2 | 5 | 9,300 | 50.60 |
| IVEY IC | 3 | 9 | 12,280 | 64.70 |
| IVEY IC | 4 | 6 | No Significant Output | |
| IVEY IC | 5 | 4 | 9,300 | 50.58 |
| IVEY IC | 6 | 18 | 9,300 | 50.58 |
| KELLY | 7 | 23 | 16,878 | 81.75 |
| KELLY GT | 1 | 14 | No Significant Output | |
| KELLY GT | 2 | 14 | No Significant Output | |
| KELLY GT | 3 | 14 | No Significant Output | |
| KENEDYGT | 3 | 54 | No Significant Output | |
| KENEDYGT | 4 | 54 | No Significant Output | |
| KENEDYGT | 5 | 54 | No Significant Output | |
| KENEDYGT | 7 | 153 | 11,306 | 65.11 |

| | | | | |
|----------|----|-----|-----------------------|-------|
| KING | 5 | 8 | 10,479 | 49.55 |
| KING | 6 | 17 | 12,844 | 60.53 |
| KING | 7 | 32 | 12,942 | 64.15 |
| KING | 8 | 50 | 12,728 | 61.06 |
| KING DSL | 1 | 5 | No Significant Output | |
| KING GT | 9 | 23 | 10,500 | 59.26 |
| LARSEN | 8 | 102 | 10,610 | 49.95 |
| LARSENGT | 2 | 10 | No Significant Output | |
| LARSENGT | 3 | 10 | No Significant Output | |
| LAUDER T | 1 | 36 | No Significant Output | |
| LAUDER T | 2 | 35 | No Significant Output | |
| LAUDER T | 3 | 35 | No Significant Output | |
| LAUDER T | 4 | 35 | No Significant Output | |
| LAUDER T | 5 | 35 | No Significant Output | |
| LAUDER T | 6 | 35 | No Significant Output | |
| LAUDER T | 7 | 35 | No Significant Output | |
| LAUDER T | 8 | 35 | No Significant Output | |
| LAUDER T | 9 | 35 | No Significant Output | |
| LAUDER T | 10 | 35 | No Significant Output | |
| LAUDER T | 11 | 35 | No Significant Output | |
| LAUDER T | 12 | 35 | No Significant Output | |
| LAUDER T | 13 | 35 | No Significant Output | |
| LAUDER T | 14 | 35 | No Significant Output | |
| LAUDER T | 15 | 35 | No Significant Output | |
| LAUDER T | 16 | 35 | No Significant Output | |
| LAUDER T | 17 | 35 | No Significant Output | |
| LAUDER T | 18 | 35 | No Significant Output | |
| LAUDER T | 19 | 35 | No Significant Output | |
| LAUDER T | 20 | 35 | No Significant Output | |
| LAUDER T | 21 | 35 | No Significant Output | |
| LAUDER T | 22 | 32 | No Significant Output | |
| LAUDER T | 23 | 32 | No Significant Output | |
| LAUDER T | 24 | 35 | No Significant Output | |
| LAUDERCC | 4 | 440 | 7,667 | 38.21 |
| LAUDERCC | 5 | 440 | 7,680 | 38.95 |
| MANATEE | 1 | 819 | 9,857 | 46.72 |
| MANATEE | 2 | 819 | 9,695 | 45.92 |
| MARATHON | 1 | 8 | No Significant Output | |
| MARATHON | 2 | 5 | 9,300 | 50.59 |
| MARATHON | 3 | 8 | 12,280 | 64.24 |
| MARTIN | 1 | 814 | 8,941 | 42.10 |
| MARTIN | 2 | 816 | 8,970 | 42.34 |
| MARTINCC | 3 | 445 | 7,263 | 36.26 |
| MARTINCC | 4 | 445 | 7,265 | 36.26 |
| MARTINCT | 1 | 153 | 11,327 | 61.28 |
| MARTINCT | 2 | 153 | 11,335 | 61.29 |
| MCINT GT | 1 | 17 | No Significant Output | |

| | | | | |
|----------|---|-----|-----------------------|-------|
| MCINT IC | 1 | 5 | No Significant Output | |
| MCINTOSH | 1 | 87 | 10,814 | 50.91 |
| MCINTOSH | 2 | 103 | 10,282 | 47.50 |
| MCINTOSH | 5 | 310 | 7,460 | 35.57 |
| NORTH GT | 3 | 52 | No Significant Output | |
| NORTH GT | 4 | 52 | No Significant Output | |
| NORTH GT | 5 | 52 | No Significant Output | |
| NORTH GT | 6 | 52 | No Significant Output | |
| NORTHSID | 3 | 505 | 9,653 | 50.48 |
| OLEAN GT | 1 | 153 | 11,364 | 61.32 |
| OLEAN GT | 2 | 153 | 11,345 | 61.24 |
| OLEAN GT | 3 | 153 | 11,352 | 61.25 |
| OLEAN GT | 4 | 153 | 11,367 | 61.24 |
| OLEAN GT | 5 | 153 | 11,366 | 61.31 |
| PHILLIPS | 1 | 17 | 13,500 | 65.92 |
| PHILLIPS | 2 | 17 | 13,500 | 65.92 |
| POLK CT | 2 | 153 | 11,353 | 63.94 |
| POLK CT | 3 | 153 | 11,368 | 63.99 |
| POLK CT | 4 | 153 | 11,393 | 64.00 |
| POLK CT | 5 | 153 | 11,345 | 63.89 |
| POLK CT | 6 | 153 | 11,336 | 63.85 |
| POLKIGCC | 1 | 250 | 10,267 | 35.35 |
| PURDOM | 7 | 48 | 18,726 | 87.68 |
| PURDOMGT | 1 | 0 | No Significant Output | |
| PURDOMGT | 2 | 12 | No Significant Output | |
| PUTNAMCC | 1 | 249 | 9,114 | 45.67 |
| PUTNAMCC | 2 | 249 | 9,110 | 45.70 |
| REEDYCRK | 1 | 35 | 10,400 | 53.12 |
| RIVIERA | 3 | 290 | 9,728 | 43.93 |
| RIVIERA | 4 | 290 | 9,738 | 44.25 |
| SANFORD | 3 | 153 | 8,877 | 47.44 |
| SEM CT | 1 | 153 | 11,383 | 64.07 |
| SEM CT | 2 | 153 | 11,422 | 64.21 |
| SEM CT | 3 | 153 | 11,375 | 64.01 |
| SMITH | 1 | 7 | No Significant Output | |
| SMITH | 2 | 7 | No Significant Output | |
| SMITH | 3 | 22 | 16,685 | 82.15 |
| SMITH | 4 | 32 | 16,495 | 81.24 |
| SMITH D | 1 | 9 | No Significant Output | |
| SMITH CC | 1 | 32 | 10,400 | 56.17 |
| SMITH GT | 1 | 26 | No Significant Output | |
| SMITH ST | 1 | 3 | No Significant Output | |
| SMITH ST | 2 | 2 | No Significant Output | |
| SMITH ST | 3 | 6 | No Significant Output | |
| ST CLOUD | 1 | 4 | No Significant Output | |
| ST CLOUD | 2 | 6 | No Significant Output | |
| ST CLOUD | 3 | 6 | No Significant Output | |

| | | | | |
|----------|---|-----|-----------------------|-------|
| ST CLOUD | 4 | 12 | No Significant Output | |
| STOCK DS | 1 | 9 | No Significant Output | |
| STOCK DS | 2 | 9 | No Significant Output | |
| STOCK GT | 1 | 21 | No Significant Output | |
| STOCK GT | 2 | 16 | No Significant Output | |
| STOCK GT | 3 | 16 | No Significant Output | |
| STOCK IC | 1 | 6 | No Significant Output | |
| SUWAN GT | 1 | 54 | No Significant Output | |
| SUWAN GT | 2 | 54 | No Significant Output | |
| SUWAN GT | 3 | 54 | No Significant Output | |
| SWOOPEIC | 1 | 5 | No Significant Output | |
| TIGERBAY | 1 | 194 | 7,577 | 37.45 |
| TURKEYIC | 1 | 14 | No Significant Output | |
| TURKEYPT | 1 | 410 | 9,406 | 46.87 |
| TURKEYPT | 2 | 400 | 9,420 | 46.90 |
| TURNERGT | 3 | 65 | No Significant Output | |
| TURNERGT | 4 | 65 | No Significant Output | |
| UNIV FLA | 1 | 36 | 11,166 | 58.41 |
| VERO BCH | 1 | 13 | 13,115 | 61.76 |
| VERO BCH | 2 | 13 | 8,931 | 42.62 |
| VERO BCH | 3 | 33 | 13,164 | 63.46 |
| VERO BCH | 4 | 56 | 11,785 | 56.74 |
| VERO BCH | 5 | 35 | 11,183 | 53.25 |

NUGs

| | | |
|----------|---|-----|
| AS-AVAIL | 1 | 63 |
| BAY CTY | 1 | 11 |
| BROWARDS | 1 | 54 |
| BROWARDS | 2 | 56 |
| CARGILL | 2 | 15 |
| CEDARBAY | 1 | 250 |
| CFRBIIGN | 1 | 74 |
| DADE CTY | 1 | 43 |
| ELDORADO | 1 | 114 |
| HILLSBOR | 1 | 26 |
| INDIANTN | 1 | 330 |
| LAKE CTY | 1 | 13 |
| LAKECOGN | 1 | 110 |
| LFC JEFF | 1 | 9 |
| LFC MADS | 1 | 9 |
| MULB-FPC | 1 | 79 |
| ORANGE | 1 | 22 |
| ORLANDO | 1 | 79 |
| PALMBCH | 1 | 44 |
| PASCO | 1 | 109 |
| PASCOCTY | 1 | 23 |

| | | |
|----------|---|----|
| PINELLAS | 1 | 40 |
| PINELLAS | 2 | 15 |
| RIDGE | 1 | 40 |
| ROYSTER | 1 | 31 |
| TAMPACTY | 1 | 19 |
| JEA-QFs | | 17 |

External Purchases

| | | |
|--------------|---|------|
| ENTERGY | 1 | 23 |
| SOUTHERN CO. | | 1615 |

Source: PROMOD IV(R) analyses prepared by Slater Consulting.

**PENINSULAR FLORIDA
 SUMMARY OF EXISTING CAPACITY
 AS OF JANUARY 1, 2000**

| UTILITY | NET CAPABILITY | |
|---|-----------------------|---------------|
| | SUMMER | WINTER |
| FLORIDA KEYS ELECTRIC COOPERATIVE ASSOC., INC | 22 | 22 |
| FLORIDA MUNICIPAL POWER AGENCY | 498 | 527 |
| FLORIDA POWER CORPORATION | 7,525 | 8,277 |
| FLORIDA POWER & LIGHT COMPANY | 16,444 | 17,234 |
| FORT PIERCE UTILITIES AUTHORITY | 119 | 119 |
| GAINESVILLE REGIONAL UTILITIES | 550 | 563 |
| CITY OF HOMESTEAD | 60 | 60 |
| JACKSONVILLE ELECTRIC AUTHORITY | 2,626 | 2,749 |
| UTILITY BOARD OF THE CITY OF KEY WEST | 52 | 52 |
| KISSIMMEE UTILITY AUTHORITY | 172 | 190 |
| CITY OF LAKELAND | 615 | 650 |
| CITY OF LAKE WORTH UTILITIES | 127 | 138 |
| UTILITIES COMMISSION OF NEW SMYRNA BEACH | 24 | 24 |
| OCALA ELECTRIC UTILITY | 11 | 11 |
| ORLANDO UTILITIES COMMISSION | 1,028 | 1,072 |
| REEDY CREEK IMPROVEMENT DISTRICT | 48 | 49 |
| SEMINOLE ELECTRIC COOPERATIVE INC. | 1,331 | 1,345 |
| CITY OF ST. CLOUD | 22 | 21 |
| CITY OF TALLAHASSEE | 429 | 449 |
| TAMPA ELECTRIC COMPANY | 3,455 | 3,594 |
| CITY OF VERO BEACH | 150 | 155 |
| TOTALS | | |
| FRCC UTILITIES EXISTING CAPACITY | 35,308 | 37,301 |
| NON-UTILITY GENERATING FACILITIES (FIRM) | 2,060 | 2,124 |
| NON-UTILITY GENERATING FACILITIES (NON-FIRM) | 89 | 111 |
| MERCHANT PLANT FACILITIES (FIRM) | 593 | 593 |
| MERCHANT PLANT FACILITIES (NON-FIRM) | 15 | 26 |
| TOTAL PENINSULAR FLORIDA EXISTING CAPACITY | 38,065 | 40,155 |

Data Source:

Florida Reliability Coordinating Council

2000 Regional Load & Resource Plan, Peninsular Florida, July 2000

PENINSULAR FLORIDA, HISTORICAL AND PROJECTED SUMMER AND WINTER FIRM PEAK DEMANDS

1991-2012

ACTUAL PEAK DEMAND (MW)

| | 1991 | 1992 | 1993 | 1994 | 1995 | 1996 | 1997 | 1998 |
|---------------|--------|--------|--------|--------|--------|--------|--------|--------|
| SUMMER | 27,662 | 28,930 | 29,748 | 29,321 | 31,801 | 32,315 | 32,924 | 37,153 |
| WINTER | 28,179 | 27,215 | 28,149 | 32,618 | 34,552 | 34,762 | 30,932 | 35,907 |

PROJECTED FIRM PEAK DEMAND (MW)

| | 1999 (Actual) | 2000 | 2001 | 2002 | 2003 | 2004 | 2005 | 2006 |
|---------------|------------------|--------|--------|--------|--------|--------|--------|--------|
| SUMMER | 37,493 | 34,832 | 35,560 | 36,432 | 37,313 | 38,164 | 39,065 | 40,347 |
| WINTER | 40,178 | 36,814 | 37,753 | 38,679 | 39,592 | 40,551 | 41,585 | 42,541 |

PROJECTED FIRM PEAK DEMAND (MW)

| | 2007 | 2008 | 2009 | 2010 | 2011 | 2012 |
|---------------|--------|--------|--------|--------|--------|--------|
| SUMMER | 41,255 | 42,094 | 42,980 | 43,895 | 44,830 | 45,785 |
| WINTER | 43,445 | 44,386 | 45,316 | 46,281 | 47,266 | 48,272 |

Data Source:

Florida Reliability Coordinating Council,
 1991-2009 values, 2000 Regional Load & Resource Plan, Peninsular Florida, July 2000.
 2010-2012 values extrapolated at the FRCC projected average annual compound growth rates for 2006-2009.
 1991-1999 actual peak demand values exclude interruptible load and load management reductions.
 2000-2012 forecasted firm peak demand values include projected interruptible load and load management
 reduction values, and are non-coincident.

**PENINSULAR FLORIDA, HISTORICAL AND
 PROJECTED NET ENERGY FOR LOAD
 AND NUMBER OF CUSTOMERS**

1991 - 2012

ACTUAL NET ENERGY FOR LOAD (GWH)

| | 1991 | 1992 | 1993 | 1994 | 1995 | 1996 | 1997 | 1998 |
|-------------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| ENERGY | 146,786 | 147,728 | 153,269 | 159,353 | 168,982 | 173,327 | 175,534 | 187,868 |
| LOAD FACTOR | 60.58% | 58.29% | 58.82% | 62.04% | 59.14% | 57.26% | 57.64% | 57.72% |
| CUSTOMERS | 6,155,380 | 6,269,358 | 6,410,797 | 6,550,760 | 6,687,155 | 6,812,603 | 6,948,888 | 7,091,803 |

PROJECTED NET ENERGY FOR LOAD (GWH)

| | 1999 (Actual) | 2000 | 2001 | 2002 | 2003 | 2004 | 2005 | 2006 |
|-------------|------------------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| ENERGY | 188,598 | 196,042 | 200,188 | 204,779 | 209,853 | 214,507 | 218,950 | 223,453 |
| LOAD FACTOR | 57.42% | 55.70% | 62.08% | 61.92% | 61.93% | 61.85% | 61.64% | 61.34% |
| CUSTOMERS | 7,555,341 | 7,517,881 | 7,688,054 | 7,832,016 | 7,974,676 | 8,113,738 | 8,249,138 | 8,380,749 |

PROJECTED NET ENERGY FOR LOAD (GWH)

| | 2007 | 2008 | 2009 | 2010 | 2011 | 2012 |
|-------------|-----------|-----------|-----------|-----------|-----------|-----------|
| ENERGY | 227,798 | 232,032 | 236,224 | 240,641 | 245,141 | 249,725 |
| LOAD FACTOR | 61.13% | 60.97% | 60.75% | 59.36% | 59.21% | 58.89% |
| CUSTOMERS | 8,510,779 | 8,640,757 | 8,771,153 | 8,905,264 | 9,041,425 | 9,179,669 |

Data Source:

Florida Reliability Coordinating Council,
 1991-2009 Energy values, 2000 Regional Load & Resource Plan, Peninsular Florida, July 2000.
 2010-2012 Energy values extrapolated at the FRCC projected average annual compound growth rates for 2006-2009.
 Load factor values were calculated from these energy values and the peak demand values in Table 4.
 1991-2009 Customer values, 2000 Regional Load & Resource Plan, Peninsular Florida, July 2000.
 2010-2012 Customer values extrapolated at the FRCC projected average annual compound growth rates for 2006-2009.

**OSPREY ENERGY CENTER
SUMMARY OF PROJECTED OPERATIONS
2003-2012**

| <u>Year</u> | <u>PROJECTED GENERATION (GWH)</u> | <u>ANNUAL CAPACITY FACTOR %</u> |
|-------------|---|---|
| 2003 | 2,624 | 95.5% |
| 2004 | 4,379 | 92.7% |
| 2005 | 4,293 | 91.1% |
| 2006 | 4,279 | 90.8% |
| 2007 | 4,333 | 92.0% |
| 2008 | 4,254 | 90.0% |
| 2009 | 4,172 | 88.6% |
| 2010 | 4,301 | 91.3% |
| 2011 | 4,070 | 86.4% |
| 2012 | 4,389 | 92.9% |

Source: PROMOD IV(R) analyses prepared by Slater Consulting.

Note: The Project is scheduled to come into service on June 1, 2003. The annual capacity factor reported for 2003 is calculated on the basis of the Project's operations for the period June 1 - December 31, 2003.

OSPREY ENERGY CENTER
SUMMARY OF PROJECTED OPERATIONS, 2003-2012
HIGHER NATURAL GAS PRICE SENSITIVITY ANALYSIS

| <u>Year</u> | <u>PROJECTED GENERATION (GWH)</u> | <u>ANNUAL CAPACITY FACTOR %</u> |
|-------------|---|---|
| 2003 | 2,616 | 95.1% |
| 2004 | 4,351 | 92.1% |
| 2005 | 4,264 | 90.5% |
| 2006 | 4,229 | 89.8% |
| 2007 | 4,266 | 90.6% |
| 2008 | 4,149 | 87.8% |
| 2009 | 4,066 | 86.3% |
| 2010 | 4,161 | 88.3% |
| 2011 | 3,935 | 83.5% |
| 2012 | 4,265 | 90.3% |

Source: PROMOD IV(R) analyses prepared by Slater Consulting.

Notes: (1) The Project is scheduled to come into service on June 1, 2003. The annual capacity factor reported for 2003 is calculated on the basis of the Project's operations for the period June 1 - December 31, 2003.

(2) The Base Case fuel price projections were developed by Slater Consulting based on actual data and the U. S. Energy Information Administration's 2000 Annual Energy Outlook Reference Case Forecast, but with the natural gas price escalations moderated to be more in keeping with the Standard & Poor's DRI forecast, which was included in the EIA's publication as a comparison forecast. The fuel prices for this sensitivity case were the same as for the Base Case except that the prices of natural gas were projected to escalate at the growth rates projected in the EIA Reference Case Forecast.


**OSPREY ENERGY CENTER
SUMMARY OF PROJECTED OPERATIONS
LOAD GROWTH SENSITIVITY ANALYSES, 2003-2012**

| <u>Year</u> | LOW LOAD GROWTH | | BASE LOAD | | HIGH LOAD GROWTH | |
|-------------|---|---|---|---|---|---|
| | PROJECTED GENERATION (GWH) | ANNUAL CAPACITY FACTOR % | PROJECTED GENERATION (GWH) | ANNUAL CAPACITY FACTOR % | PROJECTED GENERATION (GWH) | ANNUAL CAPACITY FACTOR % |
| 2003 | 2,622 | 95.4% | 2,624 | 95.5% | 2,633 | 95.8% |
| 2004 | 4,364 | 92.4% | 4,379 | 92.7% | 4,400 | 93.1% |
| 2005 | 4,279 | 90.8% | 4,293 | 91.1% | 4,307 | 91.4% |
| 2006 | 4,270 | 90.6% | 4,279 | 90.8% | 4,214 | 89.4% |
| 2007 | 4,139 | 87.9% | 4,333 | 92.0% | 4,441 | 94.3% |
| 2008 | 4,402 | 93.2% | 4,254 | 90.0% | 4,032 | 85.4% |
| 2009 | 4,065 | 86.3% | 4,172 | 88.6% | 4,365 | 92.7% |
| 2010 | 4,357 | 92.5% | 4,301 | 91.3% | 4,267 | 90.6% |
| 2011 | 4,216 | 89.5% | 4,070 | 86.4% | 4,284 | 90.9% |
| 2012 | 4,190 | 88.7% | 4,389 | 92.9% | 4,455 | 94.3% |


Source: PROMOD IV(R) analyses prepared by Slater Consulting.

Assumptions: The Base Case scenario was developed by Slater Consulting based on actual data and consideration of published sources, including the 1999 FRCC Regional Load & Resource Plan and Florida utilities' 2000 ten-year site plans. The Low Load Growth scenario reflects growth rates 0.5 percent per year less than in the Base Case. The High Load Growth scenario reflects growth rates 1.0 percent per year greater than in the Base Case.


PENINSULAR FLORIDA GENERATION - WITHOUT OSPREY
 Weekday June 2005




PENINSULAR FLORIDA GENERATION - WITH OSPREY
 Weekday June 2005













PENINSULAR FLORIDA GENERATION - WITHOUT OSPREY
 Weekday December 2005



PENINSULAR FLORIDA GENERATION - WITH OSPREY
 Weekday December 2005



Market Indicators

| NERC Region | MONTHLY TRENDS | | | | Year Ago Percent Change | JANUARY through DECEMBER | | | 1998-1999 Percent Change | |
|---|---------------------------|-----------|-----------|-----------|-------------------------------|--------------------------|---------|---------|--------------------------------|---------|
| | Oct. 1999 | Nov. 1999 | Dec. 1999 | Dec. 1998 | | 1997 | 1998 | 1999 | | |
| NPCC  | Electric Generation (gWh) | 16,900 | 17,277 | 18,876 | 14,917 | 26.54% | 182,537 | 182,468 | 231,281 | 26.75% |
| | Production Costs (¢/kWh) | 2.41 | 2.35 | 2.28 | 2.36 | -3.22% | 2.48 | 2.30 | 2.39 | 3.65% |
| | Retail Rates (¢/kWh) | 10.19 | 9.83 | 9.65 | 10.09 | -2.58% | 10.81 | 10.45 | 10.11 | -3.25% |
| MAAC  | Electric Generation (gWh) | 18,924 | 18,925 | 18,789 | 19,777 | -5.00% | 210,399 | 228,685 | 252,746 | 10.52% |
| | Production Costs (¢/kWh) | 2.28 | 2.19 | 2.21 | 1.83 | 20.45% | 2.11 | 1.91 | 2.23 | 16.60% |
| | Retail Rates (¢/kWh) | 7.53 | 7.35 | 7.41 | 8.18 | -10.15% | 8.86 | 8.69 | 8.09 | -6.90% |
| SERC  | Electric Generation (gWh) | 62,249 | 58,045 | 65,901 | 61,472 | 7.20% | 734,118 | 763,603 | 793,411 | 3.90% |
| | Production Costs (¢/kWh) | 1.76 | 1.77 | 1.72 | 1.72 | 0.06% | 1.79 | 1.78 | 1.76 | -0.96% |
| | Retail Rates (¢/kWh) | 5.71 | 5.50 | 5.53 | 5.49 | 0.18% | 5.81 | 5.77 | 5.71 | -1.04% |
| FRCC  | Electric Generation (gWh) | 14,169 | 12,328 | 12,908 | 11,963 | 7.90% | 141,111 | 160,611 | 173,061 | 7.75% |
| | Production Costs (¢/kWh) | 2.89 | 2.76 | 2.43 | 2.33 | 4.37% | 2.67 | 2.39 | 2.59 | 8.40% |
| | Retail Rates (¢/kWh) | 6.88 | 6.90 | 6.85 | 7.06 | -2.27% | 7.30 | 7.13 | 6.96 | -2.38% |
| ECAR  | Electric Generation (gWh) | 44,321 | 43,829 | 48,515 | 44,598 | 8.78% | 529,312 | 526,524 | 560,974 | 6.54% |
| | Production Costs (¢/kWh) | 2.17 | 2.14 | 2.13 | 1.87 | 13.63% | 1.86 | 1.87 | 2.12 | 13.83% |
| | Retail Rates (¢/kWh) | 5.97 | 5.91 | 5.86 | 5.89 | 0.34% | 6.03 | 5.98 | 6.01 | 0.50% |
| MAIN  | Electric Generation (gWh) | 19,231 | 18,992 | 20,268 | 19,895 | 1.88% | 216,491 | 222,092 | 252,018 | 13.47% |
| | Production Costs (¢/kWh) | 1.87 | 1.88 | 1.79 | 1.99 | -10.12% | 2.09 | 2.05 | 1.84 | -10.42% |
| | Retail Rates (¢/kWh) | 6.22 | 5.98 | 5.93 | 6.40 | -6.56% | 6.78 | 6.75 | 6.43 | -4.74% |
| MAPP  | Electric Generation (gWh) | 13,282 | 12,703 | 14,241 | 13,496 | 5.52% | 151,337 | 153,972 | 161,491 | 4.88% |
| | Production Costs (¢/kWh) | 1.35 | 1.37 | 1.39 | 1.44 | -3.41% | 1.50 | 1.51 | 1.42 | -5.77% |
| | Retail Rates (¢/kWh) | 5.50 | 5.57 | 5.62 | 5.49 | 1.46% | 5.68 | 5.75 | 5.79 | 0.70% |
| ERCOT  | Electric Generation (gWh) | 22,973 | 20,370 | 22,048 | 17,796 | 23.89% | 226,751 | 240,026 | 287,310 | 19.70% |
| | Production Costs (¢/kWh) | 2.54 | 2.40 | 2.33 | 1.98 | 18.18% | 2.13 | 2.12 | 2.41 | 13.62% |
| | Retail Rates (¢/kWh) | 6.50 | 5.88 | 5.75 | 5.75 | 2.26% | 6.18 | 6.12 | 6.09 | -0.49% |
| SPP  | Electric Generation (gWh) | 15,144 | 14,715 | 16,133 | 13,562 | 18.95% | 164,934 | 174,334 | 200,862 | 15.22% |
| | Production Costs (¢/kWh) | 2.12 | 2.08 | 2.06 | 1.80 | 14.33% | 1.98 | 1.89 | 2.11 | 11.14% |
| | Retail Rates (¢/kWh) | 5.45 | 5.08 | 5.07 | 5.11 | -0.59% | 5.60 | 5.58 | 5.52 | -1.08% |
| WSCC  | Electric Generation (gWh) | 51,552 | 49,931 | 53,929 | 48,391 | 11.44% | 561,608 | 551,533 | 628,226 | 13.91% |
| | Production Costs (¢/kWh) | 1.86 | 1.67 | 1.58 | 1.47 | 7.28% | 1.56 | 1.50 | 1.60 | 6.87% |
| | Retail Rates (¢/kWh) | 7.30 | 6.64 | 6.75 | 6.56 | 7.11% | 7.18 | 6.95 | 6.89 | -0.86% |

Source: POWERdat Database. POWERdat is a registered trademark of Resource Data International Inc. (RDI) • Boulder, Colo. • 303-444-7788. ©2000 All rights reserved. Note: Monthly production costs are estimated using current fuel prices and most recently reported nonfuel O&M costs for all regulated companies (IOUs, munis, co-ops & federal).

**PENINSULAR FLORIDA, IMPACTS OF OSPREY ENERGY CENTER
ON AVERAGE ELECTRICITY GENERATION HEAT RATES AND
TOTAL FUEL CONSUMPTION, 2003-2012**

| <u>Year</u> | <u>Average Heat Rate (btu/kwh)</u> | | | <u>Total Primary Energy (1000*mmbtu)</u> | | <u>Osprey Net Energy</u> |
|-------------|------------------------------------|------------------------|-------------------|--|------------------------|---------------------------------|
| | <u>Without Osprey</u> | <u>With Osprey</u> | <u>Difference</u> | <u>Without Osprey</u> | <u>With Osprey</u> | <u>Savings (1000*mmbtu)</u> |
| 2003 | 8,864.4 | 8,837.4 | 27.0 | 1,850,893 | 1,845,257 | 5,636 |
| 2004 | 8,781.6 | 8,737.8 | 43.7 | 1,874,198 | 1,864,864 | 9,334 |
| 2005 | 8,747.8 | 8,707.6 | 40.2 | 1,905,197 | 1,896,431 | 8,766 |
| 2006 | 8,662.8 | 8,626.6 | 36.2 | 1,925,724 | 1,917,686 | 8,038 |
| 2007 | 8,606.0 | 8,567.4 | 38.7 | 1,949,829 | 1,941,069 | 8,760 |
| 2008 | 8,576.2 | 8,540.5 | 35.7 | 1,976,351 | 1,968,125 | 8,226 |
| 2009 | 8,536.7 | 8,512.4 | 24.3 | 2,003,095 | 1,997,395 | 5,700 |
| 2010 | 8,546.1 | 8,518.9 | 27.3 | 2,041,883 | 2,035,372 | 6,511 |
| 2011 | 8,553.6 | 8,517.0 | 36.6 | 2,081,005 | 2,072,094 | 8,911 |
| 2012 | 8,575.3 | 8,540.2 | 35.1 | 2,124,464 | 2,115,761 | 8,703 |

Source: PROMOD IV(R) analyses prepared by Slater Consulting.

PENINSULAR FLORIDA FUEL CONSUMPTION IMPACTS OF OSPREY ENERGY CENTER, 2003-2012

(All Values in 1,000 x MMBtu)

| Year | <u>Nuclear</u> | | | <u>Coal and Other Solid Fuels</u> | | | <u>Natural Gas</u> | | | <u>No. 6 Oil</u> | | | <u>No. 2 Oil</u> | | |
|------|-----------------------|--------------------|--------------------|-----------------------------------|--------------------|--------------------|-----------------------|--------------------|--------------------|-----------------------|--------------------|--------------------|-----------------------|--------------------|--------------------|
| | <u>Without Osprey</u> | <u>With Osprey</u> | <u>Differ-ence</u> | <u>Without Osprey</u> | <u>With Osprey</u> | <u>Differ-ence</u> | <u>Without Osprey</u> | <u>With Osprey</u> | <u>Differ-ence</u> | <u>Without Osprey</u> | <u>With Osprey</u> | <u>Differ-ence</u> | <u>Without Osprey</u> | <u>With Osprey</u> | <u>Differ-ence</u> |
| 2003 | 295,404 | 295,404 | 0 | 769,940 | 766,231 | 3,709 | 663,815 | 669,766 | (5,951) | 118,105 | 110,713 | 7,392 | 3,629 | 3,143 | 486 |
| 2004 | 321,616 | 321,616 | 0 | 754,909 | 740,695 | 14,214 | 704,970 | 723,490 | (18,520) | 89,530 | 76,408 | 13,122 | 3,173 | 2,655 | 518 |
| 2005 | 316,996 | 316,996 | 0 | 751,478 | 743,067 | 8,411 | 745,061 | 755,649 | (10,588) | 88,372 | 77,868 | 10,504 | 3,290 | 2,851 | 439 |
| 2006 | 303,928 | 303,928 | 0 | 743,161 | 733,395 | 9,766 | 791,044 | 801,777 | (10,733) | 84,927 | 76,126 | 8,801 | 2,664 | 2,460 | 204 |
| 2007 | 312,117 | 312,117 | 0 | 716,668 | 705,680 | 10,988 | 829,301 | 846,518 | (17,217) | 89,310 | 74,427 | 14,883 | 2,433 | 2,327 | 106 |
| 2008 | 326,697 | 326,697 | 0 | 711,361 | 703,313 | 8,048 | 863,388 | 874,371 | (10,983) | 72,295 | 61,396 | 10,899 | 2,610 | 2,348 | 262 |
| 2009 | 294,962 | 294,962 | 0 | 716,748 | 712,157 | 4,591 | 897,024 | 905,427 | (8,403) | 91,584 | 82,485 | 9,099 | 2,777 | 2,364 | 413 |
| 2010 | 321,069 | 321,069 | 0 | 716,779 | 708,527 | 8,252 | 917,233 | 927,076 | (9,843) | 84,616 | 76,538 | 8,078 | 2,186 | 2,162 | 24 |
| 2011 | 316,945 | 316,945 | 0 | 723,043 | 709,318 | 13,725 | 937,705 | 952,935 | (15,230) | 100,807 | 90,683 | 10,124 | 2,505 | 2,213 | 292 |
| 2012 | 331,247 | 331,247 | 0 | 734,896 | 723,896 | 11,000 | 946,332 | 957,427 | (11,095) | 108,899 | 100,566 | 8,333 | 3,090 | 2,625 | 465 |

Source: PROMOD IV(R) analyses prepared by Slater Consulting.

**PENINSULAR FLORIDA, SUMMARY OF PROJECTED WHOLESALE ENERGY
COST SAVINGS DUE TO OSPREY ENERGY CENTER,
BASE CASE, 2003-2012**

| <u>YEAR</u> | FRCC | AVERAGE ANNUAL | AVERAGE ANNUAL | WHOLESALE | ESTIMATED | CUMULATIVE |
|-------------|--------------------------------|---|--|------------------------------|--------------------------------|-----------------------------------|
| | NET ENERGY FOR LOAD | MARGINAL ENERGY COST WITH OSPREY | MARGINAL ENERGY COST WITHOUT OSPREY | PRICE SUPPRESSION | SAVINGS FROM OSPREY | NPV @ 10% 2000 DOLLARS |
| | <u>(GWH)</u> | <u>(\$/MWH)</u> | <u>(\$/MWH)</u> | <u>(\$/MWH)</u> | <u>(\$MILLION)</u> | <u>(\$MILLION)</u> |
| 2003 | 208,800 | 32.83 | 33.37 | 0.54 | 113 | 85 |
| 2004 | 213,424 | 31.81 | 32.55 | 0.74 | 158 | 193 |
| 2005 | 217,791 | 32.92 | 33.67 | 0.75 | 163 | 294 |
| 2006 | 222,299 | 33.36 | 33.96 | 0.60 | 133 | 369 |
| 2007 | 226,565 | 33.75 | 34.48 | 0.73 | 165 | 454 |
| 2008 | 230,447 | 34.34 | 34.96 | 0.62 | 143 | 521 |
| 2009 | 234,645 | 35.85 | 36.60 | 0.75 | 176 | 595 |
| 2010 | 238,924 | 36.77 | 37.51 | 0.74 | 177 | 664 |
| 2011 | 243,289 | 38.81 | 39.65 | 0.84 | 204 | 735 |
| 2012 | 247,742 | 40.27 | 41.02 | 0.75 | 186 | 794 |

Source: PROMOD IV(R) analyses prepared by Slater Consulting.

**PENINSULAR FLORIDA, SUMMARY OF PROJECTED WHOLESALE ENERGY
COST SAVINGS DUE TO OSPREY ENERGY CENTER,
HIGHER FUEL PRICE SENSITIVITY CASE, 2003-2012**

| <u>YEAR</u> | <u>FRCC NET ENERGY FOR LOAD (GWH)</u> | <u>AVERAGE ANNUAL MARGINAL ENERGY COST WITH OSPREY (\$/MWH)</u> | <u>AVERAGE ANNUAL MARGINAL ENERGY COST WITHOUT OSPREY (\$/MWH)</u> | <u>WHOLESALE PRICE SUPPRESSION (\$/MWH)</u> | <u>ESTIMATED SAVINGS FROM OSPREY (\$MILLION)</u> | <u>CUMULATIVE NPV @ 10% 2000 DOLLARS (\$MILLION)</u> |
|-------------|---|---|--|---|--|--|
| 2003 | 208,800 | 32.88 | 33.43 | 0.55 | 115 | 86 |
| 2004 | 213,424 | 31.92 | 32.59 | 0.67 | 143 | 184 |
| 2005 | 217,791 | 33.06 | 33.81 | 0.75 | 163 | 285 |
| 2006 | 222,299 | 33.71 | 34.35 | 0.64 | 142 | 366 |
| 2007 | 226,565 | 34.49 | 35.22 | 0.73 | 165 | 451 |
| 2008 | 230,447 | 35.43 | 36.09 | 0.66 | 152 | 522 |
| 2009 | 234,645 | 37.29 | 38.03 | 0.74 | 174 | 595 |
| 2010 | 238,924 | 38.76 | 39.53 | 0.77 | 184 | 666 |
| 2011 | 243,289 | 41.04 | 41.87 | 0.83 | 202 | 737 |
| 2012 | 247,742 | 42.63 | 43.51 | 0.88 | 218 | 806 |

Source: PROMOD IV(R) analyses prepared by Slater Consulting.

Note: The Base Case fuel price projections were developed by Slater Consulting based on actual data and the U. S. Energy Information Administration's 2000 Annual Energy Outlook Reference Case Forecast, but with the natural gas price escalations moderated to be more in keeping with the Standard & Poor's DRI forecast, which was included in the EIA's publication as a comparison forecast. The fuel prices for this sensitivity case were the same as for the Base Case except that the prices of natural gas were projected to escalate at the growth rates projected in the EIA's Reference Case Forecast.

**PENINSULAR FLORIDA, SUMMARY OF PROJECTED WHOLESALE ENERGY
COST SAVINGS DUE TO OSPREY ENERGY CENTER,
LOW LOAD GROWTH SENSITIVITY CASE, 2003-2012**

| YEAR | FRCC NET ENERGY FOR LOAD (GWH) | AVERAGE ANNUAL MARGINAL ENERGY COST WITH OSPREY (\$/MWH) | AVERAGE ANNUAL MARGINAL ENERGY COST WITHOUT OSPREY (\$/MWH) | WHOLESALE PRICE SUPPRESSION (\$/MWH) | ESTIMATED SAVINGS FROM OSPREY (\$MILLION) | CUMULATIVE NPV @ 10% 2000 DOLLARS (\$MILLION) |
|-------------|---|---|--|---|--|--|
| 2003 | 205,684 | 32.46 | 32.69 | 0.23 | 47 | 36 |
| 2004 | 209,187 | 30.97 | 31.62 | 0.65 | 136 | 128 |
| 2005 | 212,400 | 32.10 | 32.84 | 0.74 | 157 | 226 |
| 2006 | 215,713 | 32.26 | 32.85 | 0.59 | 127 | 298 |
| 2007 | 218,754 | 32.58 | 33.14 | 0.56 | 123 | 361 |
| 2008 | 221,389 | 33.09 | 33.56 | 0.47 | 104 | 409 |
| 2009 | 224,295 | 34.12 | 34.75 | 0.63 | 141 | 469 |
| 2010 | 227,242 | 34.96 | 35.56 | 0.60 | 136 | 522 |
| 2011 | 230,238 | 36.64 | 37.08 | 0.44 | 101 | 557 |
| 2012 | 233,280 | 37.46 | 38.40 | 0.94 | 219 | 627 |

Source: PROMOD IV(R) analyses prepared by Slater Consulting.

Note: This Low Load Growth scenario reflects growth rates 0.5 percent per year less than in the Base Case.

**PENINSULAR FLORIDA, SUMMARY OF PROJECTED WHOLESALE ENERGY
COST SAVINGS DUE TO OSPREY ENERGY CENTER,
HIGH LOAD GROWTH SENSITIVITY CASE, 2003-2012**

| YEAR | FRCC NET ENERGY FOR LOAD (GWH) | AVERAGE ANNUAL MARGINAL ENERGY COST WITH OSPREY (\$/MWH) | AVERAGE ANNUAL MARGINAL ENERGY COST WITHOUT OSPREY (\$/MWH) | WHOLESALE PRICE SUPPRESSION (\$/MWH) | ESTIMATED SAVINGS FROM OSPREY (\$MILLION) | CUMULATIVE NPV @ 10% 2000 DOLLARS (\$MILLION) |
|-------------|---|---|--|---|--|--|
| 2003 | 215,127 | 34.16 | 34.57 | 0.41 | 88 | 66 |
| 2004 | 222,089 | 33.44 | 34.29 | 0.85 | 189 | 195 |
| 2005 | 228,900 | 35.07 | 35.99 | 0.92 | 211 | 326 |
| 2006 | 235,976 | 35.94 | 36.75 | 0.81 | 191 | 434 |
| 2007 | 242,907 | 36.59 | 37.43 | 0.84 | 204 | 539 |
| 2008 | 249,539 | 38.02 | 39.04 | 1.02 | 255 | 657 |
| 2009 | 256,627 | 40.26 | 41.26 | 1.00 | 257 | 766 |
| 2010 | 263,921 | 42.51 | 43.51 | 1.00 | 264 | 868 |
| 2011 | 271,429 | 46.36 | 47.63 | 1.27 | 345 | 989 |
| 2012 | 279,162 | 49.17 | 50.64 | 1.47 | 410 | 1,119 |

Source: PROMOD IV(R) analyses prepared by Slater Consulting.

Note: This High Load Growth scenario reflects growth rates 1.0 percent per year greater than in the Base Case.

COMPARISON OF PENINSULAR FLORIDA PLANNED AND PROPOSED GENERATING UNITS

| PLANNED & PROPOSED UTILITY/UNIT | IN-SERVICE YEAR | SUMMER CAPACITY MW | WINTER CAPACITY MW | PRIMARY FUEL | ALTERNATE FUEL | HEAT RATE (Btu/kWH) | EQUIVALENT AVAILABILITY FACTOR % | TOTAL INSTALLED COST (\$/KW) 1/ | DIRECT CONSTRUCTION COST (\$/KW) 1/ | TECHNOLOGY TYPE |
|---------------------------------|-----------------|--------------------|--------------------|--------------|----------------|---------------------|----------------------------------|---------------------------------|-------------------------------------|-----------------------|
| OLEANDER 2/ | 2002 | 777 | 910 | GAS | NO. 2 | 9,700 | 97 | N/A | \$235 | COMBUSTION TURBINE |
| OSPREY ENERGY 3/ | 2003 | 498 | 578 | GAS | NONE | 6,800 | 94 | N/A | \$357 | COMBINED CYCLE |
| FPL/MARTIN CT | 2001 | 298 | 362 | GAS | NO. 2 | 10,450 | 98 | \$371 | \$523 | COMBUSTION TURBINE |
| FPL/FT.MYERS | 2002 | 930 | 1,073 | GAS | NONE | 6,830 | 96 | \$557 | \$502 | COMB. CYCLE/REPOWER |
| FPL/SANFORD 4-5 | 2002 | 1,132 | 1,342 | GAS | NONE | 6,860 | 96 | \$703 | \$591 | COMB. CYCLE/REPOWER |
| FPL/FT.MYERS CT | 2003 | 298 | 362 | GAS | NO. 2 | 10,450 | 98 | \$378 | \$323 | COMBUSTION TURBINE |
| FPL/MARTIN 5-6 | 2006 | 788 | 858 | GAS | NO. 2 | 6,346 | 96 | \$679 | \$484 | COMBINED CYCLE |
| FPL/UNSITE | 2007 | 394 | 429 | GAS | NO. 2 | 6,830 | 96 | \$783 | \$552 | COMBINED CYCLE |
| FPL/UNSITE | 2008 | 394 | 429 | GAS | NO. 2 | 6,830 | 96 | \$798 | \$552 | COMBINED CYCLE |
| FPL/UNSITE | 2009 | 394 | 429 | GAS | NO. 2 | 6,830 | 96 | \$812 | \$552 | COMBINED CYCLE |
| TALLAH/PURDOM 8 | 2000 | 233 | 262 | GAS | NO. 2 | 6,940 | NR | \$483 | \$434 | COMBINED CYCLE |
| FPC/INTRCSS 12-14 | 2000 | 240 | 282 | GAS | NO. 2 | 13,272 | 91 | NOT REPORTED | NOT REPORTED | COMBUSTION TURBINE |
| FPC/HINES 2 | 2003 | 495 | 567 | GAS | NO. 2 | 7,306 | 91 | NOT REPORTED | NOT REPORTED | COMBINED CYCLE |
| FPC/HINES 3 | 2005 | 495 | 567 | GAS | NO. 2 | 7,306 | 91 | NOT REPORTED | NOT REPORTED | COMBINED CYCLE |
| FPC/HINES 4 | 2007 | 495 | 567 | GAS | NO. 2 | 7,306 | 91 | NOT REPORTED | NOT REPORTED | COMBINED CYCLE |
| FPC/HINES 5 | 2009 | 495 | 567 | GAS | NO. 2 | 7,306 | 91 | NOT REPORTED | NOT REPORTED | COMBINED CYCLE |
| TECO/POLK 2 | 2000 | 155 | 180 | GAS | NO. 2 | 10,580 | 94 | NOT REPORTED | NOT REPORTED | COMBUSTION TURBINE |
| TECO/POLK 3 | 2002 | 155 | 180 | GAS | NO. 2 | 10,580 | 94 | NOT REPORTED | NOT REPORTED | COMBUSTION TURBINE |
| TECO/BAYSIDE 1 | 2003 | 698 | 796 | GAS | NO. 2 | 7,080 | 91 | NOT REPORTED | NOT REPORTED | COMBINED CYCLE |
| TECO/BAYSIDE 2 | 2004 | 711 | 802 | GAS | NO. 2 | 7,050 | 91 | NOT REPORTED | NOT REPORTED | COMBINED CYCLE |
| TECO/POLK 4-6 | 2005 | 465 | 540 | GAS | NO. 2 | 10,580 | 94 | NOT REPORTED | NOT REPORTED | COMBUSTION TURBINE |
| TECO/UNSITE | 2009 | 155 | 180 | GAS | NO. 2 | 10,580 | 94 | NOT REPORTED | NOT REPORTED | COMBUSTION TURBINE |
| GVLLE/J.R. KELLY | 2001 | 110 | 110 | GAS | NO. 2 | 8,000 | 84 | \$375 | \$368 | COMBINED CYCLE |
| SEC/PAYNE CRK 4/ | 2002 | 488 | 572 | GAS | NO. 2 | 6,170 | 93 | \$412 | \$378 | COMBINED CYCLE |
| FMPA-KUA CANE 3 | 2001 | 244 | 267 | GAS | NO. 2 | 6,815 | 92 | \$430 | \$320 | COMBINED CYCLE |
| LKLAND McINTSH 5 | 2002 | 337 | 384 | GAS | NO. 2 | 6,523 | 91 | \$749 | \$671 | COMBINED CYCLE |
| LKLAND McINTSH 4 | 2004 | 288 | 288 | PET.COKE | COAL | 8,452 | 81 | \$1,617 | \$1,317 | PRESSURE FLUID BED |
| LKLAND McINTSH 6 | 2009 | 32 | 46 | GAS | NO. 2 | 10,624 | 98 | \$992 | \$742 | COMBUSTION TURBINE |
| JEA KENNEDY CT 7 | 2000 | 149 | 186 | GAS | NO. 2 | 11,120 | 97 | NOT REPORTED | \$261 | COMBUSTION TURBINE |
| JEA BANDY CT 1-3 | 2001 | 149 | 186 | GAS | NO. 2 | 11,120 | 97 | NOT REPORTED | \$264 | COMBUSTION TURBINE |
| JEA NORTHSID 1-2 | 2002 | 265 | 265 | ET. COK | COAL | 9,946 | 90 | NOT REPORTED | \$658 | CIRCULATING FLUID BED |

DATA SOURCES:

- 1/ TOTAL INSTALLED COST AND DIRECT CONSTRUCTION COST DATA IS REPORTED DIRECTLY FROM THE INDIVIDUAL UTILITY'S 2000 TEN-YEAR SITE PLAN, SCHEDULE 9.
- 2/ OLEANDER POWER PROJECT DATA IS BASED ON INFORMATION FILED IN THE APRIL 2000 TEN-YEAR SITE PLAN, AND INCLUDES THE COST OF DIRECTLY ASSOCIATED TRANSMISSION LINES.
- 3/ OSPREY ENERGY CENTER DATA IS BASED ON INFORMATION FROM NEED DETERMINATION AND TEN-YEAR SITE PLAN FILINGS AND INCLUDE THE COSTS OF DIRECTLY ASSOCIATED TRANSMISSION LINES. HEAT RATE IS CALCULATED BASED ON HIGHER HEATING VALUE (HHV).
- 4/ SEMINOLE ELECTRIC COOPERATIVE'S HEAT RATE FOR THE PAYNE CREEK UNIT 3 IS REPORTED BASED ON LOWER HEATING VALUE (LHV).

**SUMMARY OF PENINSULAR FLORIDA CAPACITY, DEMAND, AND RESERVE MARGIN
AT TIME OF SUMMER PEAK WITHOUT OSPREY ENERGY CENTER**

| Year | NET INSTALLED CAPACITY (MW) | NET CONTRACT FIRM INTERCHG (MW) | PROJECTED FIRM NET TO GRID FROM NUG (MW) | TOTAL AVAILABLE CAPACITY (MW) | TOTAL PEAK DEMAND (MW) | RESERVE MARGIN W/O EXERCISING LOAD MGMT. & INT. | | LOAD MGMT. & INT. (MW) | FIRM PEAK DEMAND (MW) | RESERVE MARGIN WITH EXERCISING LOAD MGMT. & INT. | |
|------|--------------------------------------|---|--|--|---------------------------------|---|-----------|---------------------------------|--------------------------------|--|-------|
| | | | | | | (MW) | % OF PEAK | | | (MW) | (MW) |
| 2000 | 36,033 | 1,697 | 2,653 | 40,383 | 37,728 | 2,655 | 7.04 | 2,896 | 34,832 | 5,551 | 15.94 |
| 2001 | 38,244 | 1,699 | 2,653 | 42,596 | 38,445 | 4,151 | 10.80 | 2,885 | 35,560 | 7,036 | 19.79 |
| 2002 | 39,380 | 1,675 | 2,906 | 43,961 | 39,282 | 4,679 | 11.91 | 2,850 | 36,432 | 7,529 | 20.67 |
| 2003 | 41,484 | 1,583 | 3,221 | 46,288 | 40,157 | 6,131 | 15.27 | 2,844 | 37,313 | 8,975 | 24.05 |
| 2004 | 42,615 | 1,583 | 2,768 | 46,966 | 41,004 | 5,962 | 14.54 | 2,840 | 38,164 | 8,802 | 23.06 |
| 2005 | 43,211 | 1,583 | 2,658 | 47,452 | 41,905 | 5,547 | 13.24 | 2,840 | 39,065 | 8,387 | 21.47 |
| 2006 | 44,651 | 1,583 | 2,525 | 48,759 | 43,190 | 5,569 | 12.89 | 2,843 | 40,347 | 8,412 | 20.85 |
| 2007 | 45,364 | 1,583 | 2,220 | 49,167 | 44,097 | 5,070 | 11.50 | 2,842 | 41,255 | 7,912 | 19.18 |
| 2008 | 46,393 | 1,583 | 2,205 | 50,181 | 44,926 | 5,255 | 11.70 | 2,832 | 42,094 | 8,087 | 19.21 |
| 2009 | 47,100 | 1,583 | 2,096 | 50,779 | 45,810 | 4,969 | 10.85 | 2,830 | 42,980 | 7,799 | 18.15 |

1/ 777 MW - 300 MW = 447 MW OF OLEANDER POWER PROJECT ADDED TO THE INSTALLED CAPACITY COLUMN STARTING IN 2002, SEMINOLE ELECTRIC COOPERATIVE WILL PURCHASE 300 MW UNDER CONTRACT STARTING IN DECEMBER 2002.

**SUMMARY OF PENINSULAR FLORIDA CAPACITY, DEMAND, AND RESERVE MARGIN
AT TIME OF SUMMER PEAK WITH OSPREY ENERGY CENTER, 496 MW IN 2003**

| Year | NET INSTALLED CAPACITY (MW) | NET CONTRACT FIRM INTERCHG (MW) | PROJECTED FIRM NET TO GRID FROM NUG (MW) | TOTAL AVAILABLE CAPACITY (MW) | TOTAL PEAK DEMAND (MW) | RESERVE MARGIN W/O EXERCISING LOAD MGMT. & INT. | | LOAD MGMT. & INT. (MW) | FIRM PEAK DEMAND (MW) | RESERVE MARGIN WITH EXERCISING LOAD MGMT. & INT. | |
|------|--------------------------------------|---|--|--|---------------------------------|---|-----------|---------------------------------|--------------------------------|--|-------|
| | | | | | | (MW) | % OF PEAK | | | (MW) | (MW) |
| 2000 | 36,033 | 1,697 | 2,653 | 40,383 | 37,728 | 2,655 | 7.04 | 2,896 | 34,832 | 5,551 | 15.94 |
| 2001 | 38,244 | 1,699 | 2,653 | 42,596 | 38,445 | 4,151 | 10.80 | 2,885 | 35,560 | 7,036 | 19.79 |
| 2002 | 39,380 | 1,675 | 2,906 | 43,961 | 39,282 | 4,679 | 11.91 | 2,850 | 36,432 | 7,529 | 20.67 |
| 2003 | 41,980 | 1,583 | 3,221 | 46,784 | 40,157 | 6,627 | 16.50 | 2,844 | 37,313 | 9,471 | 25.38 |
| 2004 | 43,111 | 1,583 | 2,768 | 47,462 | 41,004 | 6,458 | 15.75 | 2,840 | 38,164 | 9,298 | 24.36 |
| 2005 | 43,707 | 1,583 | 2,658 | 47,948 | 41,905 | 6,043 | 14.42 | 2,840 | 39,065 | 8,883 | 22.74 |
| 2006 | 45,147 | 1,583 | 2,525 | 49,255 | 43,190 | 6,065 | 14.04 | 2,843 | 40,347 | 8,908 | 22.08 |
| 2007 | 45,860 | 1,583 | 2,220 | 49,663 | 44,097 | 5,566 | 12.62 | 2,842 | 41,255 | 8,408 | 20.38 |
| 2008 | 46,889 | 1,583 | 2,205 | 50,677 | 44,926 | 5,751 | 12.80 | 2,832 | 42,094 | 8,583 | 20.39 |
| 2009 | 47,596 | 1,583 | 2,096 | 51,275 | 45,810 | 5,465 | 11.93 | 2,830 | 42,980 | 8,295 | 19.30 |

1/ 496 MW OF OSPREY ENERGY CENTER ADDED TO THE INSTALLED CAPACITY COLUMN STARTING IN 2003

2/ 777 MW - 300 MW = 477 MW OF OLEANDER POWER PROJECT ADDED TO THE INSTALLED CAPACITY COLUMN STARTING IN 2002, SEMINOLE ELECTRIC COOPERATIVE WILL PURCHASE 300 MW UNDER CONTRACT STARTING IN DECEMBER 2002.

SOURCES: Florida Reliability Coordinating Council, 2000 Regional Load & Resource Plan, Peninsular Florida, July, 2000
Calpine Construction Finance Company, L.P.

**SUMMARY OF PENINSULAR FLORIDA CAPACITY, DEMAND, AND RESERVE MARGIN
AT TIME OF WINTER PEAK WITHOUT OSPREY ENERGY CENTER**

| Year | INSTALLED CAPACITY (MW) | NET | PROJECTED | TOTAL AVAILABLE CAPACITY (MW) | TOTAL PEAK DEMAND (MW) | RESERVE MARGIN W/O EXERCISING | | LOAD MGMT. & INT. (MW) | FIRM PEAK DEMAND (MW) | RESERVE MARGIN WITH EXERCISING | |
|---------|-------------------------------|--------------------------------------|---|--|---------------------------------|----------------------------------|-----------|---------------------------------|--------------------------------|-----------------------------------|-----------|
| | | CONTRACT FIRM INTERCHG (MW) | FIRM NET TO GRID FROM NUG (MW) | | | LOAD MGMT. & INT. (MW) | % OF PEAK | | | LOAD MGMT. & INT. (MW) | % OF PEAK |
| 2000/01 | 39,342 | 1,786 | 2,717 | 43,845 | 40,894 | 2,951 | 7.22 | 4,080 | 36,814 | 7,031 | 19.10 |
| 2001/02 | 40,075 | 1,688 | 3,002 | 44,765 | 41,811 | 2,954 | 7.07 | 4,058 | 37,753 | 7,012 | 18.57 |
| 2002/03 | 43,513 | 1,583 | 3,365 | 48,461 | 42,739 | 5,722 | 13.39 | 4,060 | 38,679 | 9,782 | 25.29 |
| 2003/04 | 45,329 | 1,583 | 2,912 | 49,824 | 43,663 | 6,161 | 14.11 | 4,071 | 39,592 | 10,232 | 25.84 |
| 2004/05 | 45,881 | 1,583 | 2,802 | 50,266 | 44,638 | 5,628 | 12.61 | 4,087 | 40,551 | 9,715 | 23.96 |
| 2005/06 | 46,845 | 1,583 | 2,669 | 51,097 | 45,694 | 5,403 | 11.82 | 4,109 | 41,585 | 9,512 | 22.87 |
| 2006/07 | 48,177 | 1,583 | 2,324 | 52,084 | 46,668 | 5,416 | 11.61 | 4,127 | 42,541 | 9,543 | 22.43 |
| 2007/08 | 49,520 | 1,583 | 2,309 | 53,412 | 47,573 | 5,839 | 12.27 | 4,128 | 43,445 | 9,967 | 22.94 |
| 2008/09 | 50,129 | 1,583 | 2,200 | 53,912 | 48,531 | 5,381 | 11.09 | 4,145 | 44,386 | 9,526 | 21.46 |
| 2009/10 | 51,316 | 1,583 | 1,778 | 54,677 | 49,478 | 5,199 | 10.51 | 4,162 | 45,316 | 9,361 | 20.66 |

1/ 910 MW - 340 MW = 570 MW OF OLEANDER POWER PROJECT ADDED TO THE INSTALLED CAPACITY COLUMN STARTING IN 2002/03, SEMINOLE ELECTRIC COOPERATIVE WILL PURCHASE 340 MW UNDER CONTRACT STARTING IN DECEMBER 2002.

**SUMMARY OF PENINSULAR FLORIDA CAPACITY, DEMAND, AND RESERVE MARGIN
AT TIME OF WINTER PEAK WITH OSPREY ENERGY CENTER, 578 MW IN 2003/04**

| Year | INSTALLED CAPACITY (MW) | NET | PROJECTED | TOTAL AVAILABLE CAPACITY (MW) | TOTAL PEAK DEMAND (MW) | RESERVE MARGIN W/O EXERCISING | | LOAD MGMT. & INT. (MW) | FIRM PEAK DEMAND (MW) | RESERVE MARGIN WITH EXERCISING | |
|---------|-------------------------------|--------------------------------------|---|--|---------------------------------|----------------------------------|-----------|---------------------------------|--------------------------------|-----------------------------------|-----------|
| | | CONTRACT FIRM INTERCHG (MW) | FIRM NET TO GRID FROM NUG (MW) | | | LOAD MGMT. & INT. (MW) | % OF PEAK | | | LOAD MGMT. & INT. (MW) | % OF PEAK |
| 2000/01 | 39,342 | 1,786 | 2,717 | 43,845 | 40,894 | 2,951 | 7.22 | 4,080 | 36,814 | 7,031 | 19.10 |
| 2001/02 | 40,075 | 1,688 | 3,002 | 44,765 | 41,811 | 2,954 | 7.07 | 4,058 | 37,753 | 7,012 | 18.57 |
| 2002/03 | 43,520 | 1,583 | 3,365 | 48,468 | 42,739 | 5,729 | 13.40 | 4,060 | 38,679 | 9,789 | 25.31 |
| 2003/04 | 45,914 | 1,583 | 2,912 | 50,409 | 43,663 | 6,746 | 15.45 | 4,071 | 39,592 | 10,817 | 27.32 |
| 2004/05 | 46,466 | 1,583 | 2,802 | 50,851 | 44,638 | 6,213 | 13.92 | 4,087 | 40,551 | 10,300 | 25.40 |
| 2005/06 | 47,430 | 1,583 | 2,669 | 51,682 | 45,694 | 5,988 | 13.10 | 4,109 | 41,585 | 10,097 | 24.28 |
| 2006/07 | 48,762 | 1,583 | 2,324 | 52,669 | 46,668 | 6,001 | 12.86 | 4,127 | 42,541 | 10,128 | 23.81 |
| 2007/08 | 50,105 | 1,583 | 2,309 | 53,997 | 47,573 | 6,424 | 13.50 | 4,128 | 43,445 | 10,552 | 24.29 |
| 2008/09 | 50,714 | 1,583 | 2,200 | 54,497 | 48,531 | 5,966 | 12.29 | 4,145 | 44,386 | 10,111 | 22.78 |
| 2009/10 | 51,901 | 1,583 | 1,778 | 55,262 | 49,478 | 5,784 | 11.69 | 4,162 | 45,316 | 9,946 | 21.95 |

1/ 578 MW OF OSPREY ENERGY CENTER ADDED TO THE INSTALLED CAPACITY COLUMN STARTING IN 2003/04

2/ 910 MW - 340 MW = 577 MW OF OLEANDER POWER PROJECT ADDED TO THE INSTALLED CAPACITY COLUMN STARTING IN 2002/03, SEMINOLE ELECTRIC COOPERATIVE WILL PURCHASE 340 MW UNDER CONTRACT STARTING IN DECEMBER 2002.

SOURCES: Florida Reliability Coordinating Council, 2000 Regional Load & Resource Plan, Peninsular Florida, July, 2000
Calpine Construction Finance Company, L.P.

PENINSULAR FLORIDA EMISSIONS IMPACTS OF OSPREY ENERGY CENTER, 2003-2012

(All Values in 1000's lbs)

| <u>Year</u> | <u>Sulfur Dioxide</u> | | <u>Nitrogen Oxides</u> | |
|-------------|---------------------------|------------------------|---------------------------|------------------------|
| | <u>Without Osprey</u> | <u>With Osprey</u> | <u>Without Osprey</u> | <u>With Osprey</u> |
| 2003 | 759,691 | 767,350 | 458,702 | 452,861 |
| 2004 | 702,289 | 669,806 | 426,740 | 412,805 |
| 2005 | 695,946 | 674,697 | 423,137 | 413,850 |
| 2006 | 677,817 | 654,902 | 417,541 | 405,467 |
| 2007 | 658,449 | 632,952 | 405,652 | 392,771 |
| 2008 | 639,130 | 611,603 | 391,615 | 382,230 |
| 2009 | 669,806 | 660,623 | 408,957 | 401,142 |
| 2010 | 679,140 | 657,030 | 410,514 | 400,657 |
| 2011 | 702,883 | 677,446 | 418,612 | 407,683 |
| 2012 | 743,653 | 720,617 | 437,591 | 426,875 |

Source: PROMOD IV(R) analyses prepared by Slater Consulting.