



John T. Butler
Senior Attorney
Florida Power & Light Company
700 Universe Boulevard
Juno Beach, FL 33408-0420
(561) 304-5639
(561) 691-7135 (Facsimile)
E-mail: john_butler@fpl.com

August 24, 2007

RECEIVED-FPSC
07 AUG 24 PM 1:01
COMMISSION
CLERK

-VIA HAND DELIVERY -

Ms. Ann Cole
Commission Clerk
Florida Public Service Commission
2540 Shumard Oak Blvd.
Tallahassee, FL 32399-0850


Re: Docket No. 070301-EI

Dear Ms. Cole:

I am enclosing for filing in the above docket the original and fifteen (15) copies of the prefiled testimony and exhibits of Florida Power & Light Company witness Manuel B. Miranda.

Please contact me if you have any questions about this transmittal.

Sincerely,


John T. Butler

CMP 2
COM 5
CTR 1

ECR Enclosure

GCL 2 cc: Counsel for Parties of Record (w/encl.)

OPC

RCA 1

SCR

SGA


SEC

OTH

CERTIFICATE OF SERVICE
Docket No. 070301-EI

I HEREBY CERTIFY that a true and correct copy of the pre-filed testimony and exhibits of Florida Power & Light Company witness Manuel B. Miranda has been furnished by overnight delivery on the 23rd day of August, 2007, to the following:

Lorena Holley, Esq. Division of Legal Services Florida Public Service Commission 2540 Shumard Oak Blvd. Tallahassee, Florida 32399-0850	Charles J. Beck, Esq. Office of Public Counsel c/o The Florida Legislature 111 West Madison Street, Room 812 Tallahassee, Florida 32399
Beth Keating Ackerman Law Firm 106 E. College Ave., Suite 1200 Tallahassee, FL 32301	AT&T Florida J.Meza/E. Edenfield/J. Kay c/o Ms. Nancy H. Sims 150 South Monroe Street, Suite 400 Tallahassee, FL 32301-1556
Davis Law Firm Maria T. Browne 1919 Pennsylvania Ave., N.W., Suite 200 Washington, DC 20006	Embarq Florida, Inc. Susan S. Masterson Mail Stop: FLTLHO0102 1313 Blair Stone Rd. Tallahassee, FL 32301
Municipal Underground Utilities Consortium Thomas G. Bradford, Deputy Town Manager c/o Town of Palm Beach 360 South County Road Palm Beach, FL 33480	Town of Jupiter Island The Honorable Charles Falcone, Mayor c/o Donald R. Hubbs, Asst. Town Manager P.O. Box 7 Hobe Sound, FL 33475
Verizon Florida LLC Dulaney L. O'Roark, III 6 Concourse Parkway, Suite 600 Atlanta, GA 30328	Young Law Firm R. Scheffel Wright/John LaVia c/o Municipal Underground Consortium 225 S. Adams Street, Suite 200 Tallahassee, FL 32301

By: 
John T. Butler
Fla. Bar No. 283479

**BEFORE THE FLORIDA
PUBLIC SERVICE COMMISSION**

**DOCKET NO. 070301-EI
FLORIDA POWER & LIGHT COMPANY**

COMMISSION
CLERK

07 AUG 24 PM 1:07

RECEIVED-EPSC

**IN RE: FLORIDA POWER & LIGHT COMPANY'S 2007
ELECTRIC INFRASTRUCTURE STORM HARDENING PLAN
FILED PURSUANT TO RULE 25-6.0342 F.A.C.**

AUGUST 24, 2007

DIRECT TESTIMONY & EXHIBITS OF:

MANUEL B. MIRANDA

DOCUMENT NUMBER-DATE
07587 AUG 24 5
COMMISSION CLERK

1 **BEFORE THE FLORIDA PUBLIC SERVICE COMMISSION**

2 **FLORIDA POWER & LIGHT COMPANY**

3 **DIRECT TESTIMONY OF MANUEL B. MIRANDA**

4 **DOCKET NO. 070301-EI**

5 **AUGUST 24, 2007**

6

7 **Q. Please state your name and business address.**

8 A. My name is Manuel (Manny) B. Miranda. My business address is Florida
9 Power & Light Company, 9250 W. Flagler Street, Miami, Florida, 33174.

10 **Q. By whom are you employed and what is your position?**

11 A. I am employed by Florida Power & Light Company (FPL or the Company) as
12 Vice President, Distribution Central Maintenance.

13 **Q. Please describe your duties and responsibilities.**

14 A. I am responsible for the coordination and execution of all contracted
15 functions, which include contractor performance and ancillary services,
16 including the equipment repair center, vegetation, cable rehabilitation,
17 environmental, pole inspections and street lights.

18 **Q. Please describe your educational background and professional
19 experience.**

20 A. I have a Bachelor of Science degree in Mechanical Engineering from the

21 University of Miami and a Master of Business Administration from Nova
22 Southeastern University. I joined FPL in 1982 and have served in a variety of
23 positions in marketing and distribution operations. I have been a distribution

1 area manager, director of distribution operations support, and director of
2 distribution operations. Finally, until just recently, I was Vice President,
3 Distribution System Performance, responsible for executing FPL's Storm
4 Secure Plan, including developing FPL's hardening plan, new construction
5 standards, product engineering, research and development, and overseeing the
6 direct engineering and construction of infrastructure improvements made as a
7 result of our hardening plan.

8 **Q. Are you sponsoring any exhibits in this case?**

9 A. Yes. I am sponsoring the following three exhibits:

- 10 • MBM-1, FPL's Electric Infrastructure Storm Hardening Plan
11 (Plan);
- 12 • MBM-2, Critical Infrastructure Projects to be Completed in 2008
13 and 2009; and
- 14 • MBM-3, Davies Consulting, Inc. Storm Pole Replacement
15 Analysis.

16 **Q. What is the purpose of your testimony?**

17 A. The purpose of my testimony is to present FPL's Plan which was filed with
18 the FPSC on May 7, 2007. I will provide an overview of the Plan (including
19 its relationship to FPL's other storm initiatives), FPL's "three prong
20 approach" hardening strategy, costs for 2007-2009 and expected benefits
21 resulting from hardening. I will also explain that FPL's Plan is a cost-effective
22 approach that will result in less storm damage, less storm restoration time and
23 costs and, therefore, is in the best interest of its customers. Finally, I will

1 explain that the Plan reflects FPL's detailed deployment strategy for 2007,
2 that more limited detail is available at this time for 2008 or 2009, and that FPL
3 intends to provide updated data to the Florida Public Service Commission
4 (FPSC) Staff and interested persons concerning the 2008 and 2009
5 deployment strategy as that information becomes available. My testimony
6 concludes that, for these reasons, FPL's Plan complies with Rule 25-6.0342
7 and should be approved by the Commission.

8

9 **BACKGROUND AND HISTORY OF HARDENING EFFORTS**

10 **Q. What events prompted FPL to initiate its hardening activities?**

11 A. The 2004 and 2005 hurricane seasons were the most extraordinary and
12 challenging on record for FPL and its customers. There were five direct
13 landfalls and two indirect impacts in FPL's service territory, resulting in
14 significant customer outages and requiring extraordinary efforts to rebuild and
15 restore the electric infrastructure. This experience, coupled with forecasters'
16 predictions of decades of heightened tropical cyclonic activities, compelled
17 FPL to re-examine and evaluate the facts about our electrical system
18 infrastructure. FPL concluded that a change in design, construction and
19 operation of that infrastructure is required. As a result, in January 2006, FPL
20 filed its Storm Secure Plan with the Florida Public Service Commission
21 (FPSC).

1 **Q. What were the key areas of focus contained in FPL's Storm Secure Plan?**

2 A. This comprehensive plan for increased storm preparedness included the
3 following four areas: hardening FPL's electric network; investing in
4 underground conversions; modifying FPL's pole inspection program; and
5 enhancing FPL's vegetation management activities.

6 **Q. Was the FPSC also undertaking its own initiatives regarding storm
7 preparedness and electric infrastructure hardening?**

8 A. Yes. Beginning in 2006, the FPSC began to develop its own requirements for
9 electric utilities to improve their storm preparedness and to harden their
10 electric infrastructure. This included: requiring electric utilities to implement
11 8-year and 6-year pole inspection programs for distribution poles and
12 transmission structures, respectively; requiring electric utilities to address 10
13 storm preparedness initiatives (which include more frequent tree trimming);
14 adopting new CIAC rules for underground construction; and adopting Rule
15 25-6.0342, which directed FPL and other investor owned utilities to file
16 detailed electric infrastructure hardening plans by May 7, 2007.

17 **Q. Did FPL participate in developing these initiatives and is FPL complying
18 with their requirements?**

19 A. Yes. FPL participated in the various Staff workshops, meetings and
20 proceedings and has also complied with all of their requirements. This
21 includes implementing the approved pole inspection programs and 10 storm
22 preparedness initiatives as well as filing its Plan. In addition, to promote

1 overhead to underground conversions, FPL filed (and ultimately received
2 approval for) its Governmental Adjustment Factor (GAF).

3 **Q. Can you provide the estimated 2007 costs associated with these**
4 **initiatives?**

5 A. Yes. For 2007, FPL estimates that the cost for implementing its 8 year
6 distribution pole inspection program is approximately \$40 million. For the 10
7 storm preparedness initiatives, which includes increased tree trimming and
8 transmission pole inspections, costs for 2007 are estimated to be
9 approximately \$90 million. The 2007 costs for FPL's Plan are estimated to be
10 approximately \$48.5 million to \$61.5 million. I will provide more information
11 on these costs later.

12 **Q. What was the focus of the FPSC's requirement for electric utilities to file**
13 **hardening plans?**

14 A. This last major initiative is intended to strengthen the overhead electric
15 infrastructure to better withstand the strong winds, or damage caused by
16 "wind only" created by hurricanes. The pole inspection programs already in
17 place should provide for improved storm pole performance, as it will replace
18 or reinforce poles that are overloaded and/or lack sufficient strength.
19 Likewise, the FPSC's direction to increase vegetation management activities,
20 including the trimming of vegetation along all feeders serving critical
21 infrastructure facilities prior to storm season, already addresses vegetation
22 related outages and this should improve storm as well as day to day reliability.

1 Finally, FPL's GAF Tariff, which was facilitated by the FPSC's new CIAC
2 rules, already provides encouragement for more underground construction.

3

4 **FPL'S STRATEGY TO STRENGTHEN / MITIGATE / RESTORE**

5 **Q. Please provide an overview of FPL's long term overall strategy to**
6 **strengthen its system, mitigate damage and customer outages and restore**
7 **customers in the least amount of time.**

8 A. Without fundamental and significant changes in the way we construct and
9 harden our infrastructure to prevent outages, FPL believes the level of
10 disruptions to its infrastructure from future storms would be much like that
11 experienced in the 2004 and 2005 hurricane seasons. Therefore, as I
12 previously discussed, FPL announced and began to implement its Storm
13 Secure initiative. The other Storm Secure initiatives, including pole
14 inspections, increased vegetation management activities, and the investment in
15 underground have all been approved and implemented. It is time now to
16 address the most important remaining element of storm preparedness:
17 hardening the infrastructure itself.

18

19 In May 2007, FPL filed its Plan, a very targeted and cost-effective approach to
20 harden its system against the effects of strong winds.

21 It is important to keep in mind that this initial Plan filing is only a first step,
22 based on current systems, processes, technologies and equipment. FPL fully

1 expects that opportunities will present themselves for improvement and
2 refinements to this Plan as additional experience is gained, new systems and
3 processes are employed, improved storm forensics provide more and better
4 data to be collected and analyzed, and new technologies become available.
5 FPL's system is diverse, complex and geographically large. Hardening this
6 system is a monumental task and will take many years to complete. FPL is
7 committed to the goal of cost-effective system hardening and will continue to
8 look for opportunities to improve and refine them in a cost-effective manner.

9 **Q. Do you see similarities between the current efforts taking place today**
10 **within the electric industry in Florida and what happened in the building**
11 **industry following Hurricane Andrew?**

12 A. Yes. I can recall the protests from the building industry when new and stricter
13 building codes were being introduced and discussed in an attempt to limit the
14 damage and destruction to buildings and homes seen as a result of Hurricane
15 Andrew. These changes, which included requiring stronger roofs, doors, and
16 windows, were all being challenged as a result of potentially significant
17 increases in housing and building construction costs, unproven building
18 techniques, and the lack of data to justify the cost-effectiveness of the new
19 codes. Yet today, 15 years later, we realize that the building industry did not
20 collapse, that technology advances have provided less expensive and better
21 materials that are lighter and stronger (e.g., light-weight shutters that are clear
22 and window glass that can withstand hurricane force winds), that homes built
23 to current standards are withstanding hurricanes better than homes built before

1 the current building code; and that homes today are more valued by
2 homeowners if they include more of the current advanced hurricane protection
3 applications, techniques, and technologies.

4 The electric industry in Florida is facing similar challenges and questions
5 regarding the hardening of its infrastructure. Issues and concerns are being
6 raised about cost impacts and lack of currently available data to support
7 cost/benefit analyses. However, while these challenges and questions should
8 be appropriately addressed, FPL believes it should not wait for all of the
9 questions to be answered. While FPL's Plan could be subsequently modified
10 as better forensic data becomes available, construction techniques are
11 improved and new technologies provide less costly and improved hardening
12 products, FPL believes that, on behalf of its customers, we must begin to take
13 action now.

14 **OVERVIEW OF FPL'S PLAN**

15 **Q. What is the underlying philosophy behind FPL's Plan?**

16 A. Two key conclusions drawn by FPL from its own 2004 and 2005 storms
17 experience and forensic data form the basis for FPL's Plan.: (1) For Hurricane
18 Wilma, wind was the predominant root cause of distribution pole breakage;
19 and (2) FPL's transmission structures, which are already built to the NESC's
20 EWL, performed well overall in the face of Hurricane Wilma's winds.

21 **Q. Please provide some additional details on these two conclusions.**

1 A. The Technical Report: Post Hurricane Wilma Engineering Analysis (Report)
2 conducted by and issued by KEMA, Inc. in January 2006 was filed and
3 extensively reviewed in FPSC Docket No. 060038-EI. It shows that, based on
4 its Hurricane Wilma forensic analysis, “Wind Only” was the highest
5 contributing factor for FPL distribution wood poles failures (52%) and that
6 this cause of failure was two and one half times greater than any other cause
7 of failure identified, e.g., trees, presence of deterioration, and possible design
8 overload.

9
10 For transmission structures, the Report also showed that Hurricane Wilma
11 caused 100 transmission structures to fail, which is only about 0.1% of the
12 total transmission structures (over 68,000) in FPL’s system. This failure rate is
13 significantly lower than the failure rate for distribution poles during Hurricane
14 Wilma (approximately 1%).

15
16 FPL concluded that, without fundamental and significant changes in the way
17 distribution facilities are constructed and hardened to prevent outages, the
18 level of disruptions to its infrastructure and customers from future storms
19 could be much like that experienced in the 2004 and 2005 storms.

20 **Q. What is the basic approach to infrastructure hardening under FPL’s**
21 **Plan?**

22 A. To harden its distribution infrastructure, FPL proposes a three prong
23 approach:

- 1 • applies extreme wind-loading criteria (EWL) proactively to
2 infrastructure that serves critical customers (e.g., hospitals and 911
3 centers);
- 4 • targets strengthening existing infrastructure, up to and including EWL,
5 that serves community needs (e.g., gas stations and grocery stores)
6 with optimal modifications using various cost-effective engineering
7 tools; and
- 8 • employs revised Design Guidelines to apply EWL to new OH
9 construction, major planned work, relocation projects and daily work
10 activities to move FPL's system toward overall EWL hardening
11 gradually over time.

12 This three prong approach specifically targets certain distribution facilities
13 and utilizes various engineering tools and options to cost-effectively harden
14 the system.

15 **Q. Please explain the first prong of FPL's hardening approach, EWL for**
16 **critical facilities.**

17 A. To apply the NESC extreme wind map for Florida, FPL proposes to divide its
18 implementation of EWL into three wind regions, corresponding to extreme
19 winds of 105, 130 and 145 mph, except for the sparsely populated extreme
20 southern tip of FPL's service territory which will be designed for 150 mph.
21 This three zone approach is an efficient approach taking into consideration
22 work methods efficiencies, training, engineering, other administrative aspects,
23 and meeting EWL in the counties within each region.

1 EWL will be applied proactively to CIF feeders and any associated laterals
2 serving critical customers. These facilities are critical and essential to the
3 health, safety, welfare and security of the public. Examples of customers
4 served by these facilities include hospitals, 911 centers, special needs shelters,
5 water treatment plants, and fire stations. Initially, FPL is targeting acute care
6 facilities, i.e., major hospitals.

7
8 Additionally, EWL will be applied to poles included in FPL's Targeted
9 Critical Pole (TCP) Program. If these poles fail, restoration efforts can be
10 significantly impacted. These would include poles associated with overhead
11 limited access highway crossings (necessary to keep roads open and safe) and
12 poles with "01 switches" (the first pole outside of a substation that is critical
13 to FPL's restoration process).

14 **Q. Please explain the second prong of FPL's hardening approach,**
15 **Incremental Hardening.**

16 A. The objective of Incremental Hardening is to optimize the existing distribution
17 infrastructure and increase the overall wind profile of a feeder to higher wind
18 rating (up to and including EWL) by utilizing cost-effective engineering
19 options to eliminate poles with the lowest wind ratings in the feeder. For
20 instance, a feeder's overall wind rating can be increased by utilizing cost-
21 effective options in FPL's "design toolkit" (e.g., storm guying, relocating
22 equipment, installing an intermediate pole, upgrading the pole class,
23 undergrounding facilities) to target improvements in individual poles with the

1 lowest wind ratings. Initially, Incremental Hardening, will target “community
2 projects”, which are feeders that have been identified as serving community
3 needs such as grocery stores, gas stations, and pharmacies. Typically, these
4 types of businesses are located along major thoroughfares and provide easy
5 access to the community.

6 **Q. Please explain the third prong to FPL’s hardening approach, revised
7 Design Guidelines.**

8 A. FPL’s Design Guidelines will apply EWL for new construction, major
9 planned work, relocation projects and daily work activities. These guidelines
10 primarily are associated with changes in pole class, pole type, and desired
11 span lengths to be utilized. Standardizing these processes will ensure this type
12 of construction work aligns with FPL’s overall hardening strategy. Depending
13 on the scope of work performed in a particular project this will result in EWL
14 for an entire circuit or EWL hardening on one or a small number of poles.
15 The purpose of this prong of FPL’s Plan is to help ensure that FPL continues
16 to move toward our ultimate goal of a fully hardened distribution system and
17 avoid the replacement of these facilities at a considerable expense later.

18

19 **DEPLOYMENT PLANS FOR 2007 - 2009**

20 **Q. What are FPL’s deployment plans for 2007?**

21 A. For 2007, FPL plans to utilize EWL to harden 34 feeders and associated
22 laterals, serving 28 CIF customers and 4 system-critical facilities. The TCP
23 Program will also focus on EWL hardening for 43 OH highway crossings on

1 Interstate 75 and the Florida Turnpike in Miami-Dade and Broward Counties
2 and 78 "01 Switch" poles. Details of where these projects are located are
3 included on Page 41 of FPL's Plan. Additionally, FPL will complete
4 Incremental Hardening on feeders serving 34 community projects. These
5 projects are located primarily in Miami-Dade, Broward, and Palm Beach
6 Counties where FPL has its highest density of customers. Details of where
7 these projects are located are included on Page 42 of FPL's Plan. FPL has
8 previously provided two CDs of detailed engineering construction drawings
9 for these projects to Staff and all parties.

10

11 FPL's 2007 deployment plan will result in hardening approximately 145 OH
12 circuit miles, encompassing 5,800 poles. However, over 50% of those 5,800
13 poles already meet EWL and do not require any additional hardening. FPL
14 will be replacing approximately 2,100 poles and installing approximately 700
15 new intermediate poles.

16 **Q. What are FPL's deployment plans for 2008 and 2009?**

17 A. Since FPL's plans for 2008 and 2009 are undergoing review as a result FPL's
18 normal budgeting approval process, precise detail plans for 2008 and 2009 are
19 not available. However, consistent with its overall approach FPL will continue
20 to address CIF hardening, critical poles, and community projects and utilize
21 its Design Guidelines. For 2008, FPL estimates that it will EWL harden
22 approximately 45-60 feeders and incrementally harden 15-30 feeders. For
23 2009, FPL estimates have not been finalized. While the exact number and

1 which feeders will be hardened in 2008 and 2009 have not been determined
2 yet, FPL intends to complete EWL hardening for all hospitals and 911 centers
3 by the end of 2009. These projects are identified on MBM-2 and FPL has
4 provided a copy of all available route and engineering data for these 2008-
5 2009 projects to Staff and all parties.

6 **Q. Does FPL plan to provide additional updated details for its 2008 and 2009**
7 **deployment plans?**

8 A. Yes. FPL plans to file annual updates to its Plan. For example, before the end
9 of 2007, FPL will provide detailed plans with engineering construction
10 drawings or line diagrams of the specific circuits being hardened in 2008
11 along with their associated costs.

12

13 **HARDENING COSTS 2007 - 2009**

14 **Q. What are the current cost estimates for 2007 hardening efforts?**

15 A. FPL's most recent cost estimates for 2007 hardening efforts is a range of
16 \$48.5 – \$61.5 million. CIF and major thoroughfares are expected to cost \$29 -
17 \$37 million, major planned expansion, rebuild, or relocations are expected to
18 cost \$14 - \$16.5 million and new distribution facilities, major planned
19 expansion, re-build and relocations are expected to cost \$5.5 - \$8 million.

20 **Q. Why is FPL still providing ranges of cost estimates for 2007?**

21 A. To date, FPL has completed construction on over 50% of its 2007 CIF,
22 Incremental Hardening and highway crossings projects. Most of the remaining

1 projects are still in construction and one final project's design remains to be
2 finalized before preparing for bid.

3 **Q. What are the cost estimates for 2008 and 2009?**

4 A. Cost estimates for 2008 range from \$75 - \$125 million. For 2009, current cost
5 estimates range from \$100 - \$150 million.

6 **Q. Does FPL plan to provide additional updates to 2008 and 2009 costs?**

7 A. Yes. When FPL files its annual updates to the Plan, we will include updates to
8 the associated cost estimates.

9

10 **BENEFITS ASSOCIATED WITH FPL'S STORM HARDENING**
11 **EFFORTS**

12 **Q. Does FPL expect that implementing the Plan will result in benefits for**
13 **FPL and its customers?**

14 A. Most definitely. FPL is confident that its hardening investment today will
15 result in permanent improvements to the storm resilience of its distribution
16 system and that, in turn, this will benefit FPL and its customers far into the
17 future. These benefits will take many forms, but FPL anticipates that the two
18 major types of benefits will be a reduction in storm and non-storm restoration
19 costs ("Restoration Cost Savings"), and a reduction in customer outages.

20 **Q. Has FPL estimated the Restoration Cost Savings that will result from**
21 **implementing the Plan?**

22 A. Yes. FPL conducted an analysis to determine the relationship between the
23 expected Restoration Cost Savings from the planned hardening activities and

1 the estimated cost of those activities. This analysis utilizes the estimated
2 average Restoration Cost Savings per mile of feeder for all planned hardening
3 activities, rather than for each activity separately because FPL does not have
4 sufficient information at this time to distinguish between the benefits
5 attributable to one type of hardening activity versus another. The Restoration
6 Cost Savings have to be expressed as a range at this time, because of the
7 uncertainties inherent in estimating them based on current information.

8 **Q. What are the uncertainties that you are referring to?**

9 A. While there are numerous areas of uncertainty, two are particularly important.
10 First, while FPL's experience shows that systems designed to withstand
11 stronger winds have greater overall resiliency to storms, there is little directly
12 measured data on the improved resilience, and hence reduced Restoration
13 Cost Savings, resulting from hardening such facilities. Second, no one can
14 know for sure how frequently FPL's service territory will be impacted by
15 strong hurricanes.

16 **Q. What sources of data has FPL utilized to estimate the improved resilience
17 of hardened distribution facilities?**

18 A. FPL has relied primarily upon the following four sources of data.

19

20 First, FPL has its experience from the 2004-2005 hurricane seasons, which
21 provided substantial insight into the specific causes of pole failures (and hence
22 both the nature and magnitude of potential improvements in storm resilience
23 that could result from addressing those causes).

1 Second, part of the work that KEMA performed for FPL following the 2005
2 storm season addressed KEMA's evaluation of the potential storm-resilience
3 improvements that could be expected from hardening activities.

4
5 Third, FPL has been able to compare the performance during the strong winds
6 of hurricane Wilma between transmission poles (which were designed to
7 EWL standards and fared well) and its distribution poles (which generally
8 were not designed to EWL standards and experienced a significant number of
9 "wind only" failures).

10
11 Finally, an independent analysis prepared by Davies Consulting, Inc. in
12 February 2006 addressed the impact of hurricanes with varying strength on
13 pole replacements for FPL and nine other utilities. The results of this analysis,
14 which are depicted in graph form in Exhibit MBM-3, show that there is a
15 strong correlation between the percentage of poles requiring replacement and
16 the strength of the storms. It also showed that FPL's pole replacement rates
17 were lower than those of other utilities for storms of comparable strengths.
18 FPL believes that a key factor in FPL's superior pole performance was FPL's
19 Grade B construction standard, whereas all of the other utilities in this
20 analysis built their distribution systems to meet Grade C construction. This
21 substantiates that systems designed to withstand stronger winds (i.e., Grade C
22 vs. Grade B vs. EWL) indeed have greater overall resiliency in storms.

1 **Q. Does the assumed frequency of storms affect the estimate of cumulative**
2 **Restoration Cost Savings over time?**

3 A. Yes. As I mentioned earlier, no one is in a position to know for sure the
4 frequency or the intensity of strong hurricanes that may impact FPL's service
5 territory. However, the experience of the 2004-2005 hurricane seasons as well
6 as some recent meteorological analyses, suggest that we may be in a period of
7 increased hurricane activity, such that a frequency of at least once every three
8 years may be more representative. The estimate of cumulative Restoration
9 Cost Savings over time will be directly affected by how frequently storms hit
10 FPL's service territory.

11 **Q. Taking these uncertainties into account, what range of Restoration Cost**
12 **Savings does FPL estimate?**

13 A. FPL estimates that, over an analytical study period of 30 years, the net present
14 value of Restoration Cost Savings per mile of hardened feeder would be
15 approximately 45% - 70% of the cost to harden that feeder at a storm
16 frequency of once every 3-5 years. Of course, there are factors that could
17 cause the Restoration Costs Savings to exceed the hardening costs. These
18 would include a higher frequency of storms, storms of greater intensity similar
19 to Hurricane Wilma, improvement in construction processes and/or realized
20 technological improvements. For instance, if a storm of Hurricane Wilma's
21 intensity occurred once every three years, the associated net present value of
22 Restoration Cost Savings would then become approximately equal to the
23 hardening costs.

1 **Q. The second major type of benefit you identified was a reduction in**
2 **customer outages resulting from its hardening activities. Please explain**
3 **the impact on customer outages that you expect FPL's hardening**
4 **activities to have.**

5 A. The improved performance of FPL's feeders will result in less feeder damage,
6 fewer feeder outages and fewer customer outages. FPL believes that, in
7 conjunction with fully implementing its pole inspection program and
8 increased vegetation management activities, once its system is hardened,
9 fewer customer outages will occur and overall distribution restoration time
10 will be significantly reduced.

11

12 **COST-EFFECTIVENESS OF FPL'S PLAN**

13 **Q. Do you believe FPL's Plan meets the desired objectives of enhancing**
14 **reliability and reducing restoration costs and outage times in a prudent,**
15 **practical and cost-effective manner?**

16 A. Yes. As described earlier, FPL's Plan enhances reliability, both storm and
17 non-storm, reduces the number of customer outages and reduces the overall
18 restoration time. Additionally, FPL's plan is cost-effective.

19 **Q. Please explain why you believe FPL's plan is cost-effective?**

20 A. A commonly accepted definition of cost-effective is an activity that produces
21 optimum results for a given level of expenditure. As I discussed earlier, there
22 are uncertainties that limit FPL's ability to quantify precisely the results and
23 benefits associated with its hardening activities, but experience from the 2004

1 and 2005 storm seasons dictate that action should be taken. Therefore, what
2 becomes important from an economic perspective is to ensure that the desired
3 outcome is achieved as efficiently as possible. FPL's Plan is very targeted,
4 efficient and produces optimum results. It focuses initially on critical
5 infrastructure facilities and community projects, where the most customers
6 will receive the most benefits as quickly as possible. For the facilities that
7 will be hardened to EWL standards, each pole location is evaluated to
8 determine how it can be strengthened to meet those standards at the least cost
9 and with the least disruption. And for community projects, the approach is
10 even more targeted, specifically focusing on "weak link" poles, where
11 hardening a few poles can significantly increase the strength of an entire pole
12 line. FPL's targeted approach will also allow for modifications and
13 refinements to be employed as more experience is gained, more and better
14 forensics data and analysis becomes available, and new systems and
15 technologies enter the market.

16
17 **COMPLIANCE WITH RULE 25-6.0342**

- 18 **Q. Is FPL's plan in compliance with Rule 25-6.0342?**
- 19 **A.** Yes. As required by Rule 25-6.0342, FPL's Plan contains a detailed
20 description of the FPL's construction standards, policies, practices and
21 practices that we will employ to enhance the reliability of overhead and
22 underground electrical transmission and distribution. FPL's Plan: (1)
23 demonstrates that FPL's transmission and distribution facilities comply with

1 or exceed the National Electrical Safety Code; (2) adopts EWL standards for
2 critical infrastructure facilities, new overhead construction, major planned
3 work, relocation projects and daily work activities; (3) is designed to mitigate
4 damage to underground and supporting overhead facilities due to flooding and
5 storm surges; (4) provides for the placement of new and replacement
6 distribution facilities pursuant to Rule 25-6.0341; (5) contains deployment
7 plans for 2007 – 2009 along with costs and benefits; (6) contains Attachment
8 Standards and Procedures; and (7) includes input from joint pole owners and
9 other attaching entities.

10 **Q. Does this conclude your direct testimony?**

11 A. Yes.

**FPL
2007 ELECTRIC
INFRASTRUCTURE STORM
HARDENING PLAN**

**FILED
MAY 7, 2007
RULE 25-6.0342 F.A.C**

EXHIBIT MBM-1

Florida Power & Light Company

**Electric Infrastructure
Storm Hardening Plan**
(Rule 25-6.0342, F.A.C.)

May 7, 2007

Florida Power & Light Company **Electric Infrastructure Storm Hardening Plan**

EXECUTIVE SUMMARY

The 2004 and 2005 hurricane seasons were the most extraordinary and challenging on record for FPL and its customers. Five direct landfalls and two indirect impacts in the service territory, resulting in significant customer outages and requiring extraordinary efforts to rebuild and restore the electric infrastructure compels us to examine and evaluate the facts from this experience. A change in design, construction and operation of the electrical system infrastructure is indicated as we face, according to forecasters, two decades of heightened tropical cyclonic activity.

On January 30, 2006, FPL responded to this challenge by filing its Storm Secure Plan with the Florida Public Service Commission (FPSC). This comprehensive plan for increased storm preparedness included the following four areas: hardening the electric network; investing in underground conversions; modifying the pole inspection program; and enhancing vegetation management activities. The FPSC has subsequently approved FPL's plan for:

- 8 year distribution and 6 year transmission pole inspection cycles
- continue a three year average cycle for feeders, implement a six year average tree trimming cycle for lateral circuits, and trim all circuits serving critical customers before each storm season
- a Governmental Adjustment Factor (GAF), 25% investment, to promote applicable local government sponsored overhead to underground conversions.

On February 1, 2007, the FPSC adopted Rule 25-6.0342 which directs FPL and other investor owned utilities to file detailed electric infrastructure hardening plans by May 7, 2007. This document contains FPL's detailed plan.

Two key conclusions drawn by FPL from the 2004 and 2005 storms experience and FPL forensic data analysis form the basis for the FPL plan. They are that:

1. For Hurricane Wilma, wind was the predominant root cause of distribution pole breakage.
2. FPL's transmission poles, which are already built to the National Electrical Safety Code (NESC) extreme wind loading criteria (EWL), performed well overall.

Although no electrical system can be made fully resistant to hurricane impacts, we believe that FPL's proposed hardening plan will mitigate the impact of future storms. The following highlights FPL's proposed hardening plan for its distribution system:

- Implement a three prong approach for distribution infrastructure hardening. The three prongs, each of which serves a different purpose under the plan, are EWL; Incremental Hardening, and Design Guidelines. This approach will allow FPL to begin obtaining hardening benefits across our entire service territory promptly and cost-effectively.
- Apply EWL to existing and new feeders (main distribution lines) as well as any associated laterals directly serving Critical Infrastructure Facilities (CIF) (i.e., critical customers such as hospitals and 911 centers, and certain poles critical to operations and efficient restoration). Feeders are the backbone and therefore a critical component of FPL's overhead distribution system. Feeder performance can have a substantial impact on the overall service reliability to our customers.
- Apply Incremental Hardening to certain existing feeders so that, with targeted cost-effective modifications, the entire feeders' wind profile can be increased, up to and including EWL. Initially, Incremental Hardening will focus on "community projects", meaning feeders serving essential community needs such as grocery stores, gas stations and pharmacies.
- Implement system-wide FPL Design Guidelines containing criteria which will apply EWL to the design and construction of all new overhead facilities, major planned work, relocation projects, as well as daily work activities. These guidelines primarily are associated with changes in pole class, pole type and desired span lengths.

FPL's filing also includes information regarding research and development projects and initiatives being pursued in order to identify new ways of strengthening our electrical infrastructure. These initiatives include seeking out and evaluating new products, work methods, and construction techniques. This also includes collaborative research efforts with the Public Utility Research Center (PURC), where initial focus areas are undergrounding, wind testing and vegetation management.

In 2007, FPL plans to utilize EWL to harden 34 feeders and any associated laterals directly serving 28 CIF customers. Additionally, FPL plans to EWL harden Critical Poles in 43 highway crossings of I-75 and the Florida Turnpike, as well as 78 additional Critical Poles at locations elsewhere in the service territory. FPL plans to apply Incremental Hardening to feeders associated with 34 community projects. In total, the proposed 2007 deployment plan corresponds to approximately 145 overhead circuit miles. FPL estimates its 2007 expenditures will range from \$40 - \$70 million. These

estimates are based upon current work methods, products, and equipment and assume the necessary resources will be available to execute the plan.

FPL has not yet finalized hardening plans for 2008 and 2009. At this time, our preliminary 2008 and 2009 plans propose hardening an additional 80 -150 feeders each year, impacting approximately 300-600 miles per year. Costs are estimated at this time to be \$75 - \$125 million in 2008 and \$100 - \$150 million in 2009.

As noted, FPL's transmission system is already built to EWL standards and performed well in the 2004 and 2005 storm seasons. However to further improve its transmission and substation system, FPL has commenced the replacement of single pole un-guyed wood transmission structures and ceramic post insulators on concrete poles to meet higher, more current design standards. Replacing them has previously been approved by the Commission as part of FPL's "Storm Preparedness Initiatives," in Order No. PSC-06-0781-PAA-EI, Docket No. 060198-EI, dated September 19, 2006 (the "Storm Initiatives Order"). Based on replacement over a 10-15 year period, the estimated annual cost will range from \$5 million - \$8 million. For 2007, FPL estimates these costs to be \$7 million.

FPL's storm hardening plan should result in less storm damage to the electrical infrastructure and therefore less restoration time and cost. For example, in another Hurricane Wilma type event, FPL estimates that hardened feeder pole failure rates and associated restoration time, based on construction man-hours, will be reduced. More generally, FPL's Storm Secure initiatives, including its storm hardening plan, pole inspections, and increased vegetation management activities, can be reasonably expected to reduce future storm restoration costs compared to what they would be without those initiatives. The costs and benefits of FPL's response to the Commission's requirement in Docket No. 060198-EI for 10-point storm implementation plans are discussed in FPL's "Storm Preparedness Initiatives" document, which was filed, reviewed and approved in that docket and is incorporated herein by reference. Hardening the system, increasing pole inspections, enhancing line clearing activities, promoting underground, along with various storm preparedness initiatives will all have an impact on reducing storm damage, reducing or preventing outages, and reducing the overall storm restoration times. Additionally, there will be day-to-day reliability benefits realized. Finally, improved systems and processes, including improved storm forensics, will allow for more and better data to be collected, evaluated and analyzed. Of course, FPL's system is very diverse and geographically large so it will take many years of sustained effort to achieve the full benefits of storm hardening.

While there will be benefits from FPL's Storm Secure initiatives, it is impossible at this time to estimate the full extent of the benefits with any

FPL Electric Infrastructure Storm Hardening Plan - May 7, 2007

precision. The actions that FPL is taking and proposing to adopt pursuant to this storm hardening plan represent industry leading changes in construction standards, maintenance practices and restoration processes. The analyses and forensic observations performed after Hurricanes Katrina and Wilma serve as the foundation for FPL's hardening efforts, but there is presently limited or no historical data available for purposes of conducting overall cost/benefit analyses on many of these new actions. As additional storm experience, more and better data, new improved processes, products and materials become available, better detailed cost /benefit analysis will be able to be performed and more cost-effective hardening solutions implemented. In the meantime, FPL believes that implementing its current hardening approach (targeting critical infrastructure for EWL, the application of Incremental Hardening for community projects, and the utilization of the Design Guidelines) is in the best interest of its customers.

In conclusion, without fundamental and significant changes in the way we construct and harden our infrastructure to prevent outages, FPL believes the level of disruptions to its infrastructure from future storms would be much like that experienced in the 2004 and 2005 hurricanes season. It is important to note, however, that regardless of FPL's Storm Secure initiatives, when severe weather events impact our state – outages will occur. It is FPL's intention, however, to take the steps necessary to mitigate such impact. The tactical and strategic initiatives and plans FPL is pursuing, including the hardening plans included in this filing, not only address the resiliency of FPL's system to future severe weather events, but also provide for an increased level of day-to-day reliability for our customers. As new technologies become available and process enhancements and other improvement opportunities are identified, FPL will continue to make refinements to these plans.

FPL Electric Infrastructure Storm Hardening Plan - May 7, 2007

INTRODUCTION

In compliance with Rule 25-6.0342, the following provides details on Florida Power & Light's (FPL) electric distribution and transmission infrastructure storm hardening plans.

DISTRIBUTION

1.0 HISTORY / BACKGROUND

Two extraordinary hurricane seasons in 2004 and 2005 have made it clear that significant changes are required in the way that Florida utilities design, construct and operate their electrical systems. This is particularly true for FPL's service territory, which during this time frame experienced the direct hit of five hurricanes and the indirect impact of two others. Standards that have worked well and provided customers with reliable service in the past need to be enhanced going forward. Florida generally, and South Florida in particular, are much more heavily and densely populated than they were at the time of Hurricane Andrew; customers' expectations have changed; and there is evidence that we are in a more active part of a multi-decade hurricane cycle and can expect more frequent storm events. Even if 2004 and 2005 were anomalies, as long-term statistics suggest, FPL must be prepared for further, significant storm activity in the years ahead.

The issue is not whether changes should be made, but what those changes should be. Although no electrical system can be rendered fully resistant to hurricane impacts, FPL's Storm Secure Plan, which was filed on January 30, 2006, outlined changes that FPL proposes to make to benefit our customers and the communities it serves. FPL's approach to new construction, system upgrades and maintenance will provide significant improvements in FPL's system's resiliency to storms and our restoration time after a storm passes. Additionally, it will ensure that a critical mass of providers of basic services, essential to the health and safety of our communities, will have electric service as promptly as possible after a hurricane strike.

The foundation for FPL's detailed hardening plan is the extensive analyses that FPL conducted either directly, or with the aid of external resources, such as KEMA Incorporated. These analyses included detailed forensic observations of how the system performed after Hurricanes Katrina and Wilma. One key finding from the Hurricane Wilma forensic data was that "wind" was the predominant root cause of distribution pole breakage as opposed to, for example, trees or other flying debris. This key data and the overall performance of FPL's transmission poles, which are already built to the NESC extreme wind criteria, forms the basis for FPL's proposal that certain parts of its distribution system be built to this highest criteria.

FPL Electric Infrastructure Storm Hardening Plan - May 7, 2007

FPL's Storm Secure Plan contains 4 key elements: (1) hardening the electric infrastructure; (2) investing in underground conversions; (3) increasing the pole inspection program activities; and (4) enhancing our line clearing and vegetation management activities.

In 2006, FPL began to address each one of these 4 elements. For example: (1) FPL initiated and completed several "hardening" pilot projects, including work done at the Port Everglades, as well as several major hospitals; (2) FPL developed and filed a tariff, the Governmental Adjustment Factor (GAF), to promote the conversion of overhead distribution to underground, by providing a 25% investment for applicable local government-sponsored conversions; (3) FPL initiated its 8 year pole inspection program for distribution wood poles and 6 year inspection program for transmission structures; (4) FPL obtained approval to continue its 3 year average cycle for main-line feeders and implement a 6 year average trim cycle for its lateral lines. Additionally, FPL completed all of the 2005 storm repair follow-up work.

It is important to keep in mind that in order to achieve changes to the resiliency of FPL's system, it will take many years of sustained effort. FPL's system cannot be changed overnight. It is very large, geographically diverse and all parts of the system are susceptible to hurricane impact.

Additionally, it is important to not focus on any one aspect. Electrical systems are exposed to a variety of different failure modes under the stress of hurricane conditions and typically each specific failure mode only accounts for a relative small proportion of the total damage. For example, FPL and every other utility experience pole breakage during hurricane conditions. However, even if FPL had experienced zero pole failures during the 2004 and 2005 storms, there still would have been millions of customers without power.

Overtime, substantial improvements to FPL's system will have cost implications for customers. To help control those costs and to get the most system improvement possible, as soon as possible, we have carefully developed our programs to focus early efforts on those parts of the system where the greatest impacts for a given level of investment can be achieved.

2.0 NATIONAL ELECTRICAL SAFETY CODE (NESC) REQUIREMENTS

The NESC is an American National Standard Institute (ANSI – C2) standard that has evolved over the years. As stated in the NESC, "The purpose of these standards is the practical safeguarding of persons during the installation, operation, or maintenance of electric supply and communication lines and associated equipment." The standards cover a wide range of topics including grounding, overhead lines, clearances, strength and loading, underground, and rules for the operation of lines and equipment. The NESC

is currently revised on a 5 year cycle, with the latest edition being 2007. This is the edition presently adopted by the Florida Administrative Code.

The NESC specifies grades of construction on the basis of the required strengths for safety. The relative order of grades of distribution construction is B, C, and N, with Grade B being the highest or strongest. The grade of construction required is determined by the voltage of the circuits involved and what they cross over. Grade C is typically the NESC minimum standard for most electrical distribution facilities. Grade B is only required when crossing railroad tracks, limited-access highways, and navigable waterways requiring waterway crossing permits.

FPL has historically designed its distribution facilities based on the loading as specified in the NESC- Rule 250 B. Combined ice and wind loading for Grade B construction. While this has resulted in a very strong and reliable distribution system, the Rule 250 B criterion is not intended to design facilities for the sorts of extreme wind speed that can be experienced during hurricanes.

2.1 Extreme Wind Loading Criteria (EWL)

EWL is calculated using the wind speeds shown in Figure 250-2(d) of the NESC for Florida. The loading increases significantly with an increase in the wind speed since the wind loading formula uses the square of the wind speed.

Once the load is determined, it is multiplied by the appropriate Load Factor based on the Grade of Construction. This "factored" load is then used to determine the required structure (pole) strength. The strength of various poles is dependent on the material from which they are made. The strength of wood poles is published in ANSI O.5. The strength of poles made from other materials is provided by the manufacturer. Once the strength of a pole is known, it is multiplied by a Strength Factor based on the grade of construction and the material from which the pole is made. This "factored" strength then has to be equal to or greater than the "factored" load.

All facilities that are to be attached to the pole must also be accounted for when determining the desired strength of the structure. This includes the wind load on the pole itself, as well as the conductors, transformers, communication cables and equipment on the pole. The design loading impact to meet EWL usually requires some combination of stronger poles and shorter span lengths (distance between poles) to reduce the wind loading imposed on the conductors and cables. The NESC requires the use of EWL for facilities that exceed 60 feet above ground or water level – normally transmission level structures.

2.2 FPL Compliance

FPL has historically utilized Grade B construction for all distribution lines, other than during a brief period (1993-2004) when, based on a probabilistic study of hurricanes at that time, a portion of FPL's territory utilized Grade C construction. Since Grade B is stronger than Grade C construction, FPL's distribution facilities comply with and, in most cases, exceed the minimum requirements of the NESC. FPL's Distribution Engineering Reference Manual (DERM) and Distribution Construction Standards (DCS) are revised as required to ensure compliance with all applicable rules and regulations. For the purpose of implementing FPL's hardening plan, addenda to the DERM and DCS have been developed to address the specific requirements needed to meet the NESC EWL.

3.0 INFRASTRUCTURE HARDENING STRATEGY

FPL's distribution infrastructure consists of feeders (main distribution lines) and laterals (fused circuits that run off feeder lines), both of which carry primary voltage, as well as lines that carry secondary voltage (e.g., services). To harden its distribution infrastructure, FPL is proposing a three pronged approach: EWL; Incremental Hardening; and revised Design Guidelines. The initial focus of applying EWL will be on feeders and any associated laterals directly serving critical customers, as well as, certain critical poles. Feeders are the backbone and therefore a critical component of FPL's overall distribution overhead system. Feeder reliability can have a substantial impact on overall service reliability to our customers. The next prong, Incremental Hardening, will target existing feeders, that with targeted modifications, the entire feeder's wind profile can be increased, up to and including EWL. The third prong will be the system-wide implementation of FPL's proposed Design Guidelines, which apply EWL criteria to the design and construction of all new overhead facilities, major planned work, relocation projects and daily work activities. This three pronged approach allows FPL to obtain hardening benefits more promptly and cost-effectively across its entire electric system. FPL will continue to evaluate its approach as new products and more cost-effective work methods are developed. The application of this three pronged approach is explained in Section 5.0 below.

4.0 EXTREME WIND SPEED REGIONS FOR APPLICATION OF EWL

To apply the NESC extreme wind map for Florida, FPL proposes to implement the application of EWL into three wind regions, corresponding to expected extreme winds of 105, 130 and 145 mph.

FPL reviewed its practices and procedures and determined that the most effective option for implementation of the extreme wind map would also be by county. Each of the counties that FPL serves was evaluated by applying the highest wind rating for that county.

FPL decided on the three extreme wind regions of 105, 130 and 145 mph for the following reasons:

- A smaller number of wind regions generate advantages through efficiency of work methods, training, engineering and administrative aspects such as standards development and deployment.
- 105, 130 and 145 mph is a well balanced approach to meet the EWL criteria in the counties within each region.




Figure 4-1 FPL Extreme Wind Regions (Meter/Sec)

Note: One exception will be made to the three wind regions, for the sparsely populated extreme southern tip of FPL's service territory. The design EWL wind speed for this area will be 150 mph.

5.0 APPLICATION OF NEW DESIGN AND CONSTRUCTION STANDARDS

5.1 EWL

EWL will be applied to Top CIF feeders and any associated laterals directly serving critical customers. These facilities are critical and essential to the health, safety, welfare and security of the public. Examples of customers served by these facilities include hospitals, 911 Centers, special needs shelters, water treatment plants, police and fire stations. To help identify these facilities, FPL has established a partnership with local Emergency Operations Centers, who assisted in providing input and selecting the most critical facilities. Based on this list, FPL's proposed plan is to harden these

facilities to EWL where feasible, practical, and cost-effective. In the first phase of applying EWL, FPL is targeting acute care facilities, i.e. major hospitals.

EWL will also be applied to poles included in FPL's Targeted Critical Pole (TCP) Program. FPL's TCP Program focuses on poles that can impact restoration efforts. The initial focus of this program includes poles associated with overhead limited access highway crossings. If these poles fail they can impede the flow of traffic and emergency vehicles. Priority will be given to potential evacuation routes or those highways used to provide relief efforts soon after the storm. TCP's also include the first distribution pole out of a substation. If these poles fail, an entire feeder and associated laterals would lose service. All TCP's will be hardened to EWL where feasible, practical, and cost-effective.

5.2 Incremental Hardening

The objective of Incremental Hardening is to optimize the existing distribution infrastructure and increase the overall wind profile of a feeder to a higher wind rating, up to and including EWL. Incremental hardening will apply appropriate combinations of cost-effective engineering options (e.g., storm guying, relocation, adding intermediate poles, upgrading the pole, etc.) to eliminate weaker links and take advantage of the existing storm resilience of a feeder. Incrementally hardening a feeder may not always achieve EWL, however, this approach will position FPL to do so in the future.

Figures 5-1 and 5-2 illustrate an example of incremental hardening. In this example the wind rating of the two highlighted poles falls below the wind profile of the remaining portion of the feeder. The wind rating gap between Pole 2 and Pole 3 is considered the "natural breakpoint." All poles whose wind rating is below the rating on Pole 3 will be upgraded.




Figure 5-1: Feeder Wind Profile Before Incremental Hardening




Figure 5-2: Feeder Wind Profile After Incremental Hardening

By targeting poles 1 and 2 for upgrading and installing an intermediate pole before pole 1, the feeder's overall wind profile has been raised to a higher wind rating in a cost-effective manner.

Initially, incremental hardening will target "community projects". Community Projects are associated with feeders that serve community needs such as grocery stores, gas stations and pharmacies. These types of services have also been identified as an essential need within the communities FPL serves. Typically these types of businesses are located nearby major thoroughfares and provide easy access to the community.

FPL will also focus on incremental hardening of poles that are critical during restoration events, but are not TCP's. These critical poles have additional electrical equipment or facilities attached such as automated feeder switches, capacitor banks and multiple circuits.

5.3 Design Guidelines for New Construction

FPL is proposing to utilize its revised Design Guidelines and processes to apply EWL for new construction, major planned work, relocation projects and daily work activities. Depending on the scope of the work that is performed in a particular project, this could result in EWL hardening for an entire circuit (in the case of large-scale projects) or in EWL hardening of one or a small number of poles (in the case of small projects) so that the affected circuit will be in a position to be fully EWL hardened in the future. These guidelines primarily are associated with changes in pole class, pole type and desired span lengths to be utilized. Standardizing these processes will ensure that this type of construction work aligns with FPL's hardening strategy.

FPL's pole sizing guidelines now provide for a minimum installation of Class 2 wood poles for all new feeder and three-phase lateral work in cases where previous designs might have called for a Class 3 wood pole. For two-phase and single-phase lateral work, a Class 3 wood pole is now required, where

previous designs might have called for a Class 5 wood pole. For service and secondary work, a minimum of a Class 4 wood pole is to be used, where previously Class 5 or 6 wood poles could have been used. For critical poles, FPL is proposing to install concrete poles at accessible locations. These changes position FPL for hardening complete existing circuits to EWL in the future.

The following Table 5-1 illustrates a sample comparison of the Present Standard vs. Proposed Hardening Guidelines and the average percentage increase in wind rating. MPH calculations are dependent on various factors, including span length, equipment and attachments, framing, etc. Variations in any of these factors may yield different results.

Pole Type	Present Guideline	New Guideline	Average % Increase in Wind Rating
Critical Pole	Class 3 (wood)	Class III-H (concrete)	23%
Feeder Pole	Class 3 (wood)	Class 2 (wood)	11%
Lateral Pole	Class 5 (wood)	Class 3 (wood)	22%
Service Pole	Class 5 (wood)	Class 4 (wood)	11%

Table 5-1 Design Guidelines Pole Recommendations

FPL's Distribution Design Guidelines are included in the Appendix, which is attached to this filing.

5.4 Hardening Existing Facilities

To determine how a circuit or critical pole will be hardened, a field survey of the circuit facilities must be performed. By capturing detailed information at each pole location such as pole type, class, span distance, attachments, wire size and framing, a comprehensive windloading analysis can be performed to determine the current wind rating of each pole, and ultimately the circuit itself. This data is then used to identify the specific pole locations within the circuit that do not meet the desired wind rating. Once locations have been identified, recommendations to increase the allowable wind rating of the pole can be made.

FPL proposes to utilize a "design toolkit" that focuses on evaluating and using cost-effective hardening options for each location. Examples of options in the toolkit include the following:

- Storm Guying – Install one guy in each direction perpendicular to the line of lead. This is a very cost-effective option; however, proper field conditions need to be present to allow for installation.
- Equipment Relocation – Equipment on a pole may be moved to a near-by stronger pole or one with a higher allowable wind rating.
- Intermediate Pole – Install a single pole when long span lengths are present. By reducing the span length, the wind rating of both adjacent poles is increased.
- Upgrading Pole Class – Replace the existing pole for a higher class pole to increase the pole's wind rating.
- Undergrounding Facilities – Utilize if there are significant barriers to build overhead or if it is a more cost-effective option for a specific application

These options are not mutually exclusive and when used in combination with sound engineering practices, can provide a cost-effective method to harden a circuit.

Design recommendations on any given project, will take into account hardening (making facilities more resilient to storm force winds), mitigation (if circuit fails, how can damage be minimized), as well as restoration (improving the efficiency of restoration in the event of failure). Since multiple factors can contribute to losing power after a storm, utilizing this pronged approach will help in reducing the amount of work required to restore power to a damaged circuit.


6.0 DEPLOYMENT PLANS

2006 Projects

In 2006, FPL made an industry-leading move by piloting EWL, the standard for transmission construction, in four distribution infrastructure hardening projects. These projects included hardening the distribution facilities serving: Port Everglades; Port of Palm Beach; St. Mary's Hospital; Jackson Memorial Hospital and Mount Sinai Medical Center. These facilities were initially selected because they are part of the critical South Florida infrastructure network that provides fuel and emergency health care after a hurricane. In total, these four projects required more than 30,000 man hours of work, retrofitting 14 feeders and replacing more than 500 poles. These projects brought additional challenges, such as installing larger poles in established neighborhoods, coordination with customers and maintenance of traffic. However, completing these pilot projects not only increased the storm resilience of some of Florida's most vital infrastructure, it also provided valuable insight into implementing storm hardening on a broader, system-wide effort.



Mount Sinai Hospital project on Miami Beach required special equipment, traffic control and coordination with the community.



Wood poles replaced with spun concrete on Jackson Memorial Hospital project

FPL Electric Infrastructure Storm Hardening Plan - May 7, 2007


2007 Deployment Plan

In 2007, FPL proposes to utilize EWL to harden thirty four (34) feeders and the associated laterals directly serving (28) twenty eight CIF customers and four system critical facilities. The TCP Program will also focus on hardening to EWL approximately 43 overhead Highway Crossings on Interstate 75 and the Turnpike in Miami-Dade and Broward counties and seventy eight (78) additional critical poles, each being the first feeder pole outside of a substation. These 78 poles have been targeted because of their criticality in expediting restoration efforts and have been prioritized so that circuits with the largest customer counts are completed first.

In addition to the facilities serving CIF customers, FPL plans to complete Incremental Hardening on feeders associated with thirty-four (34) community projects. The majority of these are located in the Tri-County area (Miami-Dade, Broward, and Palm Beach counties) where FPL has its highest density of customers.

Lists of the CIF Customers and Community Projects' feeders planned for 2007 are included in the Appendix to this filing. Below is map which helps to identify where these projects are located.


Figure 6-1 – 2007 Feeder Hardening Map



Deployment plans and estimates utilizing the application of design guidelines were developed based upon historical new pole installations and replacements, expansion plans, as well as known relocation projects. The proposed 2007 deployment plan corresponds to approximately 145 overhead circuit miles and includes approximately 5,800 poles. It is estimated that over 50% of the 5,800 poles included in the 145 overhead circuit miles already meet EWL and will not require any additional hardening.



CIF Feeder serving VA Hospital in Palm Beach County hardened to EWL



EWL hardening CIF Feeder serving Halifax Hospital in Central Florida

2008 Deployment Plan

In 2008, FPL will continue to address CIF hardening, critical poles, and community projects, and will continue to utilize the Design Guidelines. FPL estimates it will harden approximately 85-125 feeders, most of which serve CIF customers and community projects.

2009 Deployment Plan

In 2009, FPL will continue to address CIF hardening, critical poles and community projects, and will continue to utilize the Design Guidelines. FPL estimates it will harden in the range of 80-150 feeders, most of which will serve CIF customers and community projects.

7.0 DESIGN AND CONSTRUCTION STANDARDS

7.1 Distribution Engineering Reference Manual (DERM)

FPL publishes its DERM to convey the standards of distribution design. The DERM provides FPL's designers with a reference for designing distribution facilities. This reference manual contains background information, engineering considerations, examples of necessary calculations and tables developed from the calculations. The tables are a guide for general applications whereas the examples provide the designers with the method to design facilities not included in the Tables. When the proposed criteria are adopted, FPL will publish and issue an "Addendum" to its DERM as a supplemental publication to enable the designers to design distribution facilities based on the 2007 NESC EWL criteria. A copy of the proposed DERM Addendum is included in the Appendix attached to this filing.

7.2 Distribution Construction Standards (DCS)

FPL's DCS provides the designers and the construction crews with information needed to build the distribution facilities. Designers use the manual to convey instructions to the field. The field crews use the manual to construct the facilities. The DCS contains drawings and instructions on clearances, framing (how facilities will be arranged on the pole), grounding, guying, equipment, and the assembly of the various parts. When the proposed criteria are adopted, FPL will publish and issue an "Addendum" to its DCS as a supplemental publication to enable the field crews to build distribution facilities based on the 2007 NESC EWL criteria. A copy of the proposed DCS Addendum is included in the Appendix attached to this filing.

7.3 Design Guidelines

FPL has developed Design Guidelines and a Quick Reference Guide to allow the field designers a simple reference document when the details provided in the DERM and DCS are not needed to develop the design plan. The intention of this document is to standardize designs for hardening as it relates to new construction, major planned work, relocations as well as daily work activities. These guidelines are primarily associated with changes in pole class, pole type and desired span lengths for overhead construction. In addition, FPL has proposed additional hardening guidelines for poles that are deemed critical for general operations or during restoration events. A copy of the Design Guidelines and the Quick Reference Guide are included in the Appendix.

8.0 ATTACHMENTS BY OTHER ENTITIES

8.1 Attachment Standards and Procedures

There are attachments by other entities to FPL poles throughout its service area. These attachments are made by Incumbent Local Exchange Carriers (ILEC), Cable TV Companies (CATV), Telecommunication Carriers and Governmental Entities (Non-ILEC). Additionally, FPL attaches to ILEC poles. The standards and procedures for these attachments, created to ensure conformance to FPL's standards and hardening plans as required by the FPSC, are attached and included in the Appendix.

8.2 Input from Attaching Entities

On March 22, 2007, FPL mailed an informational package regarding its 2007-2009 hardening plans as well as the current draft of its "Attachment Standards and Procedures" to all attaching entities. In total, over 95 packages were sent to these entities which included cable TV, telecommunication, and telephone companies as well as city and county agencies. FPL requested attaching entities to provide their input to FPL by April 23, 2007, including their costs and benefits associated with FPL's proposed hardening plans. Additionally, to provide these attaching entities an opportunity to better understand FPL's plans, FPL held a meeting at its General Offices in Miami, Florida on April 12, 2007. 15 representatives from cable TV, telephone and telecommunication companies, as well as one city agency, attended. At the meeting, several of the attaching entities requested, and FPL agreed to provide, additional details concerning FPL's 2007 deployment plans. On April 16, 2007, FPL provided to these attaching entities a CD containing engineering drawings, where completed, or asset management circuit

drawings for those designs not completed, for all 72 circuits that FPL is planning to harden in 2007.

To date, FPL has received comments from 6 attaching entities. FCTA was the only attaching entity to provide specific comments on FPL's construction and attachment standards. FPL has incorporated several of the FCTA's recommended changes into its standards. For example, at FCTA's suggestion, FPL has clarified the language in its attachment standards regarding overlash of cable. AT&T Florida (BellSouth) and Embarq expressed difficulties with providing accurate estimated cost impacts, stating that more time and/or information is required. Both AT&T Florida and FCTA also suggested further dialogue to better understand the plans and provide more accurate cost estimates. FPL agrees that a meeting or workshop would be beneficial. Palm Beach County suggested further discussions between the County and FPL regarding the selection of critical facilities and community projects in Palm Beach County. FPL will be contacting the County in the near future to have those discussions. Cost impacts and benefits that were provided are included in Section 11, Costs and Benefits. The complete comments received from attaching entities are attached and included in the Appendix.

9.0 RESEARCH AND DEVELOPMENT

Design and construction to NESC EWL involves more than just engineering reference manuals and construction standards. Efforts are also underway to seek out and evaluate new products, work methods, and construction techniques that will enable FPL to cost-effectively build to this increased standard. Concurrent with this effort, FPL is also evaluating its existing construction practices to ensure they are adequate to meet EWL. Examples of these efforts include:

- FPL conducted a supplier symposium in June 2006 that included over 50 companies that manufacture and supply electrical transmission and distribution equipment. This event highlighted FPL's effort to build to extreme wind and solicited input and assistance from these organizations to become innovative as FPL makes changes to its construction standards and methods. Some examples of ideas generated during this meeting included lighter concrete poles and composite material poles
- As part of the KEMA involvement with FPL's Storm Secure effort, additional data was gathered regarding other utilities hardening efforts. Some of the companies included in this effort were Tokyo and Chubu Electric, Guam Power, Hydro Quebec, Arizona Public Service, Southern California Edison, and Kansas City Power and Light.
- Different types of pole technologies; including steel, iron, several formulations of concrete, wood and composite materials; are presently under various stages of evaluation.

- A comprehensive evaluation of available composite material poles is underway. This has included inspections of manufacturing facilities, observation of certified strength testing to ANSI standards, installation of several poles at FPL's Miami Training and Methods Center, and engineering calculations involving flexibility of these poles.
- FPL is evaluating heavy-duty field equipment that will allow for the installation of heavier concrete poles without the use of costly cranes. At the same time, joint efforts between FPL and concrete manufacturers to develop a lighter weight/same strength concrete pole are on-going.
- Utilizing lessons learned from previous storms, FPL is also evaluating: design changes to streetlight brackets; stronger bracing of steel cross-arms on wood poles; attachment of riser shields to poles; construction techniques for slack spans; mechanical service disconnect devices. FPL is also performing tests on how best to attach wire to insulators
- As part of the efforts to strengthen existing installations, specifications and application guidelines are being written to use a newly developed pole reinforcement method called the ET Truss. This enables a pole to be strengthened cost-effectively, avoiding a pole replacement.
- For underground facilities, FPL is piloting the use of a below-grade switch that could be better able to withstand the affects of wind and flooding.
- FPL is actively engaged in a collaborative research effort with the Public Utility Research Center (PURC), all Florida investor owned utilities, Co-ops, and Municipalities. Initial focus areas are undergrounding, wind testing and vegetation management.
- FPL is involved with the Florida International University "Wall of Wind" storm hardening research project. This 2-fan system generates up to 120 mph winds and includes a water-injection system to simulate horizontally-flowing rainfall under hurricane conditions. FPL has already tested certain equipment including single and three phase transformers, capacitor bank, riser u-guard, and various streetlight brackets. Over time, this test facility will be able to generate wind speeds up to 150 mph.



Testing wind resilience of streetlights at FIU Wall of Wind

FPL expects that these efforts will lead to new standards, processes, products and work methods that will provide cost-effective measures to strengthen the electrical infrastructure.

10.0 UNDERGROUND DISTRIBUTION FACILITIES

10.1 Underground Systems

FPL's current underground construction systems include the following design applications:

- Pad-mounted, above grade transformers and switch gear for typical URD subdivision and small commercial areas.
- Concrete encased duct and manhole systems with above grade vaults in designated areas of high load density, where it is feasible, practical and cost-effective, for example, in Miami Beach, Fort Lauderdale and Sarasota.
- Secondary network systems with redundant throw-over, as in downtown Miami.

The current FPL system has approximately 66,300 total miles of distribution infrastructure. Underground power lines make up 37% (24,700 miles) of this total with about 7% (1,700 miles) being in concrete encased duct bank. In the past five years, over 60% of all new distribution construction throughout the FPL service territory has been installed underground. In the tri-county area of Miami-Dade, Broward and Palm Beach Counties, where local ordinances for Underground Residential Distribution (URD) construction exist, approximately 90% of new construction was installed underground.

10.2 Equipment Technologies

The standard FPL URD equipment for all new underground residential distribution (pad-mounted transformers, switch cabinets, etc.) is dead-front made from stainless steel, or in combination with mild steel. Stainless steel equipment has the advantage of extended service life due to its resistance to weathering and corrosion, but has a considerably higher initial cost. Dead-front equipment (i.e., without energized parts exposed on the operating side of the equipment) is more reliable, and more resistant to flooding.

FPL does not presently use submersible equipment. Past installations which were in high-density downtown sidewalk vaults have experienced reliability issues, require large installation spaces and are costly to build and maintain.

Currently, FPL has a pilot project on Jupiter Island to test a Vista Gear (i.e., a below grade, submersible URD type switch) to determine whether it offers some added storm flooding resiliency.

10.3 Installation Practices

FPL complies with existing local ordinances when constructing underground systems. The Florida Building Code leaves the responsibility of determining adequate floodplains to each municipality which usually base their local ordinances on Federal Emergency Management Agency 100-year flood criteria.

10.4 Hardening and Storm Preparedness

Approximately 20% of FPL's underground distribution infrastructure is within the Category 1 - Category 3 floodplain as defined by the Florida Department of Community Affairs. However, FPL has not historically been as severely impacted by storm surge from hurricanes as it has been by wind. Recognizing that underground equipment is less impacted by predominantly wind events, FPL proposed the Governmental Adjustment Factor (GAF) tariff to promote conversion of electric facilities from overhead to underground. Through the GAF, which was approved by the Commission on April 24, 2007, FPL provides a 25% investment for the cost of qualified local government-sponsored conversion projects.

FPL has guidelines in place for the prompt post-storm inspection and mitigation of damage to equipment exposed to flooding or storm surge. These guidelines outline the necessary steps to purge any sand and water that has invaded the equipment and to restore it to service.

11.0 PROJECTED COSTS AND BENEFITS

11.1 Costs

FPL

In 2007, FPL plans to harden 72 feeders, which provide service to critical infrastructure and special community needs. Additionally, FPL is beginning to implement hardening criteria for new construction, major relocations and other work. Utilizing current work methods, products and equipment, this work is estimated to cost from \$40 to \$70 million.

In 2008 and 2009, FPL expects to continue this strategy for hardening its infrastructure, including targeting 85-125 circuits in 2008 and 80-150 in 2009. Each year the plan focuses on circuits with increasing lengths, potentially translating into higher program costs. The projected costs for 2008 and 2009 are \$75 to \$125 million and \$100 to \$150 million, respectively. These estimates are based upon current work methods, products, and equipment and assume the necessary resources will be available to execute the plan.

Attaching Entities

Two of the attaching entities, AT&T Florida and Fibernet, provided cost estimates specifically for 2007. AT&T Florida estimated costs of \$4.4 million and Fibernet estimated costs of approximately \$15,600. AT&T Florida and Fibernet did not provide cost estimates for 2008 and 2009. In addition, Embarq provided cost estimates ranging from \$14.0 million to \$35.0 million for the period 2007-2009. At this time, FPL has not closely scrutinized the basis for the attaching entities' cost estimates. However FPL notes that Embarq's \$14 million cost estimate is based on an assumption that FPL will harden 20% of its poles in the first 3 years of the plan, while the \$35 million estimate is based on hardening 50% of the poles during that period. Both of these pole replacement assumptions are inconsistent with FPL's hardening plan and are substantially overstated. FPL has approximately 1.1 million poles, so Embarq's 20%-50% pole replacement assumptions would imply that FPL would replace between 220,000 and 550,000 poles over the period 2007-2009. In fact, FPL estimates that its replacements over that period will total only about 5 to 10 percent of Embarq's assumptions. FCTA, AT&T Florida and Embarq also noted that pole rental rates would likely be impacted. The FCTA, City of Hollywood and Palm Beach County did not quantify any estimated cost impacts. The complete comments received from attaching entities are attached and included in the Appendix.

11.2 Benefits

FPL

For category 1, 2 and 3 hurricanes, FPL's storm hardening plan should result in less storm damage to the electrical infrastructure and therefore less restoration time and cost. For example, in another Hurricane Wilma type event, FPL estimates that hardened feeder pole failure rates and associated restoration time, based on construction man-hours, will be reduced. More generally, FPL's Storm Secure initiatives, including its storm hardening plan, pole inspections, and increased vegetation management activities, can be reasonably expected to reduce future storm restoration costs compared to what they would be without those initiatives. The costs and benefits of FPL's response to the Commission's requirement in Docket No. 060198-EI for 10-point storm implementation plans are discussed in FPL's "Storm Preparedness Initiatives" document, which was filed, reviewed and approved in that docket and is incorporated herein by reference. Hardening the system, increasing pole inspections, enhancing line clearing activities, promoting underground, along with various storm preparedness initiatives will all have an impact on reducing storm damage, reducing or preventing outages, and reducing the overall storm restoration times. Additionally, there will be day-to-day reliability benefits realized. Finally, improved systems and processes, including improved storm forensics, will allow for more and better data to be collected, evaluated and analyzed. Of course, FPL's system is very diverse and geographically large so it will take many years of sustained effort to achieve the full benefits of storm hardening.

While there will be benefits from FPL's Storm Secure initiatives, it is impossible at this time to estimate the full extent of the benefits with any precision. The actions that FPL is taking and proposing to adopt pursuant to this storm hardening plan represent industry leading changes in construction standards, maintenance practices and restoration processes. The analyses and forensic observations performed after Hurricanes Katrina and Wilma serve as the foundation for FPL's hardening efforts, but there is presently limited or no historical data available for purposes of conducting overall cost/benefit analyses on many of these new actions. As additional storm experience, more and better data, new improved processes, products and materials become available, better detailed cost /benefit analysis will be able to be performed and more cost-effective hardening solutions implemented. In the meantime, FPL believes that implementing its current hardening approach (targeting critical infrastructure for EWL, the application of Incremental Hardening for community projects, and the utilization of the Design Guidelines is in the best interest of its customers.

Attaching Entities

AT&T Florida noted that the most significant benefit would be the potential reduction of storm outages at its commercial facilities; however, the benefit could not be quantified at this time. Embarg commented that benefits will not be known until the next storm. The remaining attaching entities provided no comments on benefits.

FPL Electric Infrastructure Storm Hardening Plan - May 7, 2007

TRANSMISSION

1.0 HISTORY / BACKGROUND

While FPL's transmission facilities were also affected by the 2004 and 2005 storms, the damage experienced was significantly less than the damage experienced by distribution facilities. A primary reason for this is due to the fact that transmission structures are already constructed to meet EWL. However, FPL's Storm Secure Plan identifies several initiatives specifically addressing the transmission infrastructure. In 2006, FPL increased its inspection cycle of transmission structures to a six year cycle, consistent with the FPSC order issued in April 2006.

2.0 NESC REQUIREMENTS AND COMPLIANCE

FPL transmission line structural designs are mandated by Florida Statute Section 366.04, which requires that all high voltage transmission structures satisfy the requirements specified by the NESC. ANSI C2 addresses EWL criteria (Rule 250C) and covers all wind sensitive factors and wind related effects that need to be considered in the design calculations. FPL transmission structures are designed to meet EWL under NESC Rule 250 C and are constructed to meet Grade B Construction under NESC Sections 25 and 26.

3.0 DETERMINATION OF EXTREME WIND SPEEDS FOR APPLICATION OF EWL

For transmission structures, FPL interpolates the NESC wind load contours (Figure 250-2d) into 5 mph intervals. Based on the global position system (GPS) coordinates, transmission structures are designed for the upper wind speed of each interpolated 5 mph wind contour interval.

4.0 DESIGN AND CONSTRUCTION STANDARDS

FPL's transmission and substation system is already designed for EWL using the following design standards:

NESC

- As required by Florida Statute Section 366.04

American Society of Civil Engineers (ASCE)

- Minimum Design Loads for Buildings & Other Structures "ASCE/SEI 7-05"

- Design of Steel Transmission Pole Structures "ASCE/SEI 48-05"
- No. 74: Guidelines for Electrical Transmission Line Structural Loading
- No. 91: Design of Guyed Electrical Transmission Structures
- ASCE/PCI, Guide for the Design of Prestressed Concrete Poles

Institute of Electrical and Electronics Engineers

- IEEE Standard 751 – 1990, IEEE Trial-Use Design Guide for Wood Transmission Structures

FPL's transmission construction standards are incorporated into the following two books as summarized below:

Transmission Structure Standards (TSS)

The TSS includes drawings showing the framing and configuration of both current and historical transmission structures. Each structure standard drawing includes dimensions, material lists, and any applicable transmission installation specification (TIS) standards.

Transmission Installation Specification (TIS)

The TIS includes installation and testing procedures for various transmission components. The book contains the following sections:

1. Anchors & Foundations
2. Bonding & Grounding
3. Conductor & Conductor Fittings
4. Poles & Structures
5. Right-of-Way Items
6. Insulator & Arrester
7. Fiber Optics

Construction or installation specifications that are unique to a particular location and not incorporated in either standard referenced above are incorporated in the construction package for the individual project.

5.0 DEPLOYMENT STRATEGY

Since FPL's transmission and substation system is already designed for EWL, FPL does not believe there is a general need for further hardening of that system. However, based on experience with the performance of the system, including specific lessons learned from the 2004-2005 storm seasons FPL has the following two transmission Storm Secure initiatives which have been previously approved by the Commission as part of FPL's "Storm Preparedness Initiatives" in Order NO. PSC-06-0781-PAA-EI, Docket No. 060198-EI, dated September 19, 2006.

1. Single Pole Un-Guyed Wood Transmission Structures

FPL has implemented a comprehensive plan for replacing existing single pole un-guyed wood transmission structures with FPL's current design standards. Although designed for EWL, these structures accounted for 68% of all the transmission structures requiring replacement during the 2004-2005 storm seasons.

2. Ceramic Post Transmission Line Insulators

FPL has implemented a comprehensive plan for replacing existing ceramic post insulators on concrete poles with FPL's current design standards. Although designed for EWL, ceramic post insulators on concrete poles accounted for 68% of all the insulators replaced as a result of the 2004-2005 storm seasons.

FPL forecasts completion of these two storm secure initiatives over the next 10 to 15 years. For the single pole un-guyed wood transmission structure initiative, approximately 300 structures will be targeted for replacement each year. For the replacement of ceramic post insulators on square concrete poles, approximately 450 structures will be targeted for re-insulation each year.

FPL will prioritize its two transmission storm secure initiatives based on factors including proximity to high wind areas, system importance, customer count, and coordination with the distribution CIF storm initiative. Other economic efficiencies, such as performing work on multiple transmission line sections within the same corridor, are also considered.

In 2007, transmission has focused efforts starting in the tri-county areas of Miami-Dade, Broward, and Palm Beach Counties where the code specified wind speeds are higher.

FPL will provide updates of these transmission storm secure initiatives in its annual March 1 filing with the FPSC.

6.0 COSTS AND BENEFITS

FPL estimates the total cost for the two transmission structure hardening initiatives to be approximately \$80 million. Based on replacement over a 10-15 year period, the estimated annual cost of the program will range from approximately \$5 million to \$8 million. For 2007, FPL estimates these costs to be \$7 million.

Docket No. 070301-EI
FPL Storm Hardening Plan
Exhibit MBM-1 Page 31 of 223



Distribution Design Guidelines

The following guidelines will be used to standardize the design of FPL's overhead distribution facilities when practical, feasible and cost effective.

General

1. Every attempt should be made to place new or replacement poles in private easements or as close to the front edge of property (right of way line) as practical.
2. Overhead pole lines should be placed in front lot lines or accessible locations where feasible.
3. Concrete poles are not to be placed in inaccessible locations or locations that could potentially become inaccessible.
4. When performing work that will affect an existing Top CIF feeder, always contact Storm Secure regional project manager prior to design.
5. When performing new construction, the new pole line will be designed to meet Extreme Wind Load (EWL).

As always, good engineering judgment, safety, reliability, and cost effectiveness should be considered.

In addition to these guidelines, all distribution facilities shall be engineered to meet the minimum requirements set forth in all applicable standards and codes including but not limited to the National Electrical Safety Code (NESC), and Utility Accommodation Guide.



New Construction / Existing / Maintenance

1. When installing and/or replacing a feeder, lateral or service pole on an existing pole line, please reference the pole sizing guidelines listed under the Hardening Design Guidelines section (page 5 of 6) to determine pole class and type.
2. When performing work that will affect a Top CIF feeder, always contact Storm Secure regional project manager prior to design.
3. When extending an existing pole line, the existing pole type, wood or concrete, should be used as a guide for the new poles, while still maintaining the minimum requirements as set forth in these guidelines.

Relocation

1. When relocating either a concrete or wood pole line for a highway improvement project, the existing type pole line should be used as a guide for replacements.
2. When performing work that will affect a Top CIF feeder, always contact Storm Secure regional project manager prior to design.
3. Agency relocation projects should be coordinated with Distribution Planning to take into account potential feeder boundary changes.



Hardening Design Guidelines

The following hardening guidelines will standardize the design of FPL's overhead distribution facilities when feasible, practical and cost effective. Foreign pole owners are required to discuss design requirements with FPL prior to construction. FPL will assist with identifying the critical poles.

1. Concrete poles are preferred in the cases where replacement costs would be extremely high (i.e. Duct system riser pole, corner poles with multiple circuits, critical poles, etc). Please reference the Critical Pole list below for more information.
2. The following list comprises what will be considered critical poles. When installing and/or replacing an accessible critical pole, use concrete. If the pole is inaccessible, use a Class 2 wood pole, or consider relocating the equipment to an accessible concrete pole.

Critical Pole List
1 st switch out of the substation ¹
Automated Feeder Switches (AFS)
Interstate / Highway Crossings ^{1,2}
Capacitor Banks
Poles with multiple primary risers
3 Phase Reclosers
Aerial Auto Transformers
Multi-Circuit Poles ³
3 phase transformer banks (3-100 kVA and larger)
Regulators
Primary Meter

¹⁾ Every attempt should be made to install storm guys where feasible and practical.


²⁾ Refer to the Crossing Multi-Lane Limited Access Highways section for details (pg.4 of 6)

³⁾ Contact Storm Secure regional project manager before designing a new multi-circuit line.



Crossing Multi-lane Limited Access Highways

1. Underground installation is the preferred design for all NEW crossings (1, 2 or 3 phase) of multi-lane limited access highways. If underground construction is not feasible or if working on an existing overhead crossing, reference the Overhead Highway Crossing schematic as shown below.
2. Underground crossing for 1 or 2 phases should be designed for potential three phase feeder size cable.
3. For accessible overhead crossings, use concrete poles (III-H or Spun) for the crossing poles and Class 2 wood poles for the adjacent poles. For inaccessible overhead crossings, Class 2 wood poles should be used for the crossing poles and adjacent poles.
4. Every attempt should be made to install storm guys for the highway crossing poles. Storm guys are not required on the adjacent poles.
5. Install disconnect switches on adjacent poles on both sides of the crossing to isolate the feeder section in case of a restoration event. Disconnect switches are to be installed in accessible locations that can be reached with aerial equipment. If there is no load between the nearest existing disconnect switch and the crossing, an additional switch is not required.



Overhead Highway Crossing Schematic



Pole Sizing Guidelines

1. The following tables should be used as guidelines to help determine pole class and type, when installing and/or replacing a feeder, lateral or service pole.
2. When performing work that will affect a Top CIF feeder/customer always contact Storm Secure regional project manager prior to design.

**Feeder or Three
 Phase Lateral:**

Pole Line Description	New Construction ¹	Existing Infrastructure ²	Installing or Replacing a Critical Pole ³
Existing Wood	Use Class 2 Wood Pole to meet EWL	Use Class 2 Wood Poles	Use III-H (Accessible) or Use Class 2 Wood (Inaccessible)
Existing Concrete	Use III-H Concrete Pole to meet EWL	Use III-H Concrete Poles	Use III-H Concrete Poles

**Single or Two
 Phase Lateral:**

Pole Line Description	New Construction ¹	Existing Infrastructure ²	Installing or Replacing a Critical Pole ³
Existing Wood	Use Class 3 Wood Pole to meet EWL	Use Class 3 Wood Poles	Use III-H (Accessible) or Use Class 2 Wood (Inaccessible)
Existing Concrete	Use III-G ⁴ or III-H poles to meet EWL	Use III-G ⁴ or III-H poles to match existing line	Use III-H Concrete Poles

¹⁾ To be used when extending or relocating a pole line. For span length details, see table below.

²⁾ To be used when replacing a pole or installing an intermediate pole within an existing pole line.

³⁾ Reference Critical Pole List on pg.3 of 6.

⁴⁾ Use of III-G poles should be limited to existing concrete lateral pole lines whose wire size is less than or equal to #1/0 Aluminum.

Facility	Phases(s)	Wire size	Pole size	Recommended Span Length ⁵ (FPL with 2 attachments – FPL ONLY)		
				105 MPH	130 MPH	145 MPH
Feeder		3#568 ACAR	Class 2	180' - 230'	135' - 200'	100' - 150'
		3#3/0 AAAC	Class 2	180' - 250'	180' - 250'	125' - 250'
Lateral	3 PH	3#1/0 AAAC	Class 2	180' - 250'	180' - 250'	155' - 250'
	2 PH	2#1/0 AAAC	Class 3	180' - 250'	180' - 250'	170' - 250'
	1 PH	1#1/0 AAAC	Class 3	180' - 250'	180' - 250'	180 - 250'

⁵⁾ The lower number equates to the maximum span for FPL primary and 2 foreign attachments. The higher number equates to the maximum span for FPL primary only. Reference the addendum DERM tables when adding additional attachment(s) or equipment. Remember to always contact the Storm Secure regional project manager when working on a Top CIF feeder.



Service / Secondary / Street Light / Outdoor Light Poles

When installing or replacing a secondary, service or street light pole, a minimum Class 4 Wood pole should be used. Specific calculations may require a higher class pole for large Quadruplex wire.

As always, good engineering judgment, safety, reliability, and cost effectiveness should be considered.

In addition to these guidelines, all distribution facilities shall be engineered to meet the minimum requirements set forth in all applicable standards and codes including but not limited to the National Electrical Safety Code (NESC) and Utility Accommodation Guide.



2007 Hardening Design Guidelines Quick Reference Guide



Docket No. 070301-EI
 FPL Storm Hardening Plan
 Exhibit MBM-1 Page 38 of 223

Feeder or Three Phase Lateral:

Pole Line Description	New Construction ¹	Existing Infrastructure ²	Installing or Replacing a Critical Pole
Existing Wood	Use Class 2 Wood Pole to meet EWL	Use Class 2 Wood Poles	Use III-H (Accessible) or Use Class 2 Wood (Inaccessible)
Existing Concrete	Use III-H Concrete Pole to meet EWL	Use III-H Concrete Poles	Use III-H Concrete Poles

Single or Two Phase Lateral:

Pole Line Description	New Construction ¹	Existing Infrastructure ²	Installing or Replacing a Critical Pole
Existing Wood	Use Class 3 Wood Pole to meet EWL	Use Class 3 Wood Poles	Use III-H (Accessible) or Use Class 2 Wood (Inaccessible)
Existing Concrete	Use III-G or III-H poles to meet EWL	Use III-G or III-H poles to match existing line	Use III-H Concrete Poles

¹To be used when extending or relocating a pole line. For span length details, use the table below.

²To be used when replacing a pole or installing an intermediate pole within an existing pole line.

Facility	Phases(s)	Wire size	Pole size	Recommended Span Length ³ (FPL with 2 attachments – FPL ONLY)		
				105 MPH	130 MPH	145 MPH
Feeder		3#568 ACAR	Class 2	180' - 230'	135' - 200'	100' - 150'
		3#3/0 AAAC	Class 2	180' - 250'	180' - 250'	125' - 250'
Lateral	3 PH	3#1/0 AAAC	Class 2	180' - 250'	180' - 250'	155' - 250'
	2 PH	2#1/0 AAAC	Class 3	180' - 250'	180' - 250'	170' - 250'
	1 PH	1#1/0 AAAC	Class 3	180' - 250'	180' - 250'	180 - 250'

³The lower number equates to the maximum span for FPL primary and 2 foreign attachments. The higher number equates to the maximum span for FPL primary only. Reference the addendum DERM tables when adding additional attachment(s) or equipment. Remember to always contact the Storm Secure regional project manager when working on a Top CIF feeder. As always, good engineering judgment, safety, reliability, and cost effectiveness should be considered.

Critical Pole Identifier			
Replace with III-H Square Concrete Pole (Class 2 if inaccessible)			
Critical Poles	DCS Reference ⁴	Critical Poles	DCS Reference ⁴
1 st switch out of substation	UH-15.0.0 Fig 2 UH-15.3.1	Automated Feeder Switches (AFS)	C-9.2.0
Interstate Crossings	E-10.0.0 Fig 3	Aerial Auto Transformers	I-9.0.0
Poles with two 3 phase risers	UH-15.2.0	3 phase transformer banks 3 – 100 kVA and larger	I-52.0.2
Multi-circuit poles	Frame as existing	Capacitor Banks	J-2.0.2 & J-2.0.3
Three-phase reclosers	C-8.0.0	Regulators	I-10.1.1
Primary Meter	K-28.0.0		

⁴All references are to the Distribution Construction Standards (DCS).




2007 Hardening Design Guidelines Quick Reference Guide



Docket No. 070301-EI
 FPL Storm Hardening Plan
 Exhibit MBM-1 Page 39 of 223

105 MPH
 130 MPH
 145 MPH

Wind Zone	County
130	Alachua
105	Baker
105	Bradford
130	Brevard
145	Broward
130	Charlotte
130	Clay
145	Collier
105	Columbia
145	Miami-Dade
130	De Soto
130	Duval
130	Flagler
130	Glades
130	Hardee
130	Hendry
130	Highlands
145	Indian River
130	Lee
130	Manatee
145	Martin
145	Monroe
130	Nassau
130	Okeechobee
130	Osceola
130	Orange
145	Palm Beach
130	Putnam
130	Sarasota
130	Seminole
130	St Johns
145	St Lucie
105	Suwannee
105	Union
130	Volusia



2007 CIF Customer Circuits Planned for Hardening to EWL

Region	County	CIF Customer
North	Brevard	Cape Canaveral Hospital
	Brevard	Holmes Regional Medical Center
	Brevard	Holmes Regional Medical Center
	Columbia	VA Hospital
	Union	Lake Butler Hospital
	Volusia	Halifax Hospital
	Volusia	Halifax Hospital
East	Palm Beach	Bethesda Memorial Hospital
	Palm Beach	Columbia Hospital
	Palm Beach	Good Samaritan Hospital
	Palm Beach	Good Samaritan Hospital
	Palm Beach	VA Hospital
	St Lucie	St. Lucie Medical Center
South	St Lucie	FPL System Critical
	Broward	Cleveland Clinic
	Broward	Florida Medical Center
	Broward	Imperial Point Medical Center
	Broward	Memorial Regional Hospital
	Miami-Dade	Aventura Hospital
	Miami-Dade	Aventura Hospital
	Miami-Dade	Baptist Hospital
	Miami-Dade	Baptist Hospital
	Miami-Dade	Coral Gables Hospital
	Miami-Dade	Jackson South Community Hospital
	Miami-Dade	Larkin Community Hospital
	Miami-Dade	Mercy Hospital
	Miami-Dade	North Shore Medical Center
	Miami-Dade	Palmetto General Hospital
	Miami-Dade	Parkway Regional Medical Center
West	Miami-Dade	FPL System Critical (3)
	Collier	Naples Community Hospital
	Lee	Lee Memorial Hospital
	Manatee	Blake Medical Center
	Manatee	Manatee Memorial Hospital
	Manatee	Manatee Memorial Hospital
	Sarasota	Sarasota Memorial Hospital

2007 Community Project feeders planned for Incremental Hardening

Region	County	Feeder Number
East	Martin	401133
	Martin	407164
	Martin	408764
	Palm Beach	400433
	Palm Beach	400537
	Palm Beach	402831
	Palm Beach	403931
	Palm Beach	404032
	Palm Beach	405265
	Palm Beach	408032
	Palm Beach	409631
	Palm Beach	410663
	West Palm	407736
South	Broward	700139
	Broward	700440
	Broward	700639
	Broward	700937
	Broward	701931
	Broward	702033
	Broward	703032
	Broward	703631
	Broward	705866
	Broward	706533
	Broward	707663
	Miami-Dade	800432
	Miami-Dade	802431
	Miami-Dade	803938
	Miami-Dade	804432
	Miami-Dade	807034
	Miami-Dade	807431
Miami-Dade	807834	
Miami-Dade	808268	
Miami-Dade	808269	
Miami-Dade	809036	



Distribution Engineering Reference Manual

FPL *Section 4 – Overhead Line Design*

Distribution Engineering Reference Manual (DERM)

Section 4 – Overhead Line Design

ADDENDUM FOR EXTREME WIND LOADING

FPL

DISTRIBUTION ENGINEERING REFERENCE MANUAL

DATE:
March 21, 2007

PREPARED BY:
Distribution Product
Engineering

ADDENDUM FOR EXTREME WIND LOADING

Table of Contents

Introduction.....	4
4.2.2 Poles Structures and Guying.....	5
A. Poles, General Information.....	5
1. Pole Brands.....	5
2. Design Specifications.....	5
Figure 4.2.2 –1 Wind Regions by County.....	7
3. Wood Pole Strength.....	8
4. Concrete Pole Strength.....	8
B. Wind Loading.....	11
1. Wind Loading on poles.....	11
2. Wind Loading on conductors.....	17
3. Wind Loading on equipment.....	18
C. Storm Guying.....	41
4.2.3 Pole Framing.....	44
A. Slack Span Construction.....	44
B. Targeted Poles.....	45
C. Distribution Design Guidelines.....	45

FPL

DISTRIBUTION ENGINEERING REFERENCE MANUAL

DATE:
 March 21, 2007

PREPARED BY:
 Distribution Product
 Engineering

ADDENDUM FOR EXTREME WIND LOADING

Tables

Table Number	Description	Page
4.2.2.1	Extreme Wind Strength Factors & Load Factors	5
4.2.2.2	Velocity pressure Exposure coefficient (k_z) and Gust Response Factors (G_{RF})	6
4.2.2.3	Concrete Pole Ratings	9
4.2.2.4	Allowable Ground Line Moments for Poles	15
4.2.2.5	Wind Force on Conductors and Equipment - 105 MPH	20
4.2.2.6	Wind Force on Conductors and Equipment - 130 MPH	21
4.2.2.7	Wind Force on Conductors and Equipment - 145 MPH	22
4.2.2.8	Transverse Pole Loading Due to Extreme Wind - 105 MPH Maximum Span Length	29
4.2.2.9	Transverse Pole Loading Due to Extreme Wind - 130 MPH Maximum Span Length	33
4.2.2.10	Transverse Pole Loading Due to Extreme Wind - 145 MPH Maximum Span Length	37
4.2.2.11	Storm Guy Strength	42
4.2.2.12	Slack Span Length & Sag	44

FPL

DISTRIBUTION ENGINEERING REFERENCE MANUAL

DATE:
March 21, 2007

PREPARED BY:
Distribution Product
Engineering

ADDENDUM FOR EXTREME WIND LOADING

Storm Secure

Distribution Overhead Line Design for Extreme Wind Loading

ADDENDUM TO
DISTRIBUTION ENGINEERING REFERENCE MANUAL (DERM)

Introduction

In 2006, FPL introduced the concept of "STORM SECURE". One part of this concept is to harden the electrical system by adopting new standards based on extreme wind velocity criteria. The Florida Public Service Commission and the Florida Administrative Code have adopted the 2007 NESC for the applicable standard of construction.

FPL designs its distribution facilities based on the loading as specified in the 2007 National Electrical Safety Code (NESC) using Grade B Construction. The NESC specifies three weather conditions to consider for calculating loads:

- Rule 250 B. Combined ice and wind loading (FPL current standard construction)
- Rule 250 C. Extreme wind loading
- Rule 250 D. Extreme ice with concurrent wind loading (this is a new loading condition in the 2007 NESC that will not impact FPL).

Prior to the hardening effort, FPL has been designing overhead distribution using the loads calculated under Rule 250 B. This addendum provides the designers the information needed to design projects using Rule 250 C, grade B (extreme wind loading) to calculate the loads, when it is determined that the particular pole line is to be designed to meet extreme wind loading (EWL) requirements. The NESC extreme wind map identifies 7 Basic Wind Speeds throughout Florida. In order to minimize the design effort to accommodate these 7 wind speeds, FPL has created 3 wind regions with designated wind speeds of 105 mph, 130 mph, and 145 mph. The Map shown in Figure 4.2.2-1 identifies the counties within our service territory that fall into the 3 wind regions. Whenever extreme wind designs are deployed, they will be designed to the identified wind speed for the location of the work to be done.

4.2.2 Poles Structures and Guying

A. Poles, General Information

1. Pole Brands

The pole brand includes the pole length & class, the type of treatment, the manufacturer, the date the pole was manufactured and FPL.

Wood Poles – This brand is located at 15' from the bottom of the pole.

Square (cast) Concrete poles – the brand up until 2007 was located 15' from the bottom. New specifications now require the brand to be at 20' from the bottom of the pole.

Distribution Spun Concrete poles – The brand information is on a metal tag that is located 20' from the bottom of the pole.

2. Design Specifications

The NESC specifies 3 Grades of construction: Grade B, Grade C, and Grade N with Grade B being the strongest of the three. These grades of construction are the basis for the required strengths for safety. FPL uses Grade B Construction for all distribution facilities. This means that the calculated loads must be multiplied by "Load Factors" and the calculated or specified strength of structures must be multiplied by "Strength Factors". The Strength multiplied by the Strength Factor (SF) must be equal to, or greater than the Load multiplied by the Load Factor (LF).

Equation 4.2.2-1

$$\text{Strength} \times \text{Strength Factor} \geq \text{Load} \times \text{Load Factor}$$

Table 4.2.2 – 1 below lists the Load Factors and Strength Factors for Grade B Construction from NESC Table 253-1 and Table 261-1A.

Table 4.2.2 - 1 Extreme Wind
Strength Factors & Load Factors

Strength of	Strength Factor
Wood Poles	0.75
Concrete Poles	1.00
Composite Poles	1.00
Support Hardware	1.00
Guy Wire	0.90
Guy Anchor and Foundation	1.00
	Load Factor
Extreme Wind Loads	1.00

FPL
 PREPARED BY:
 Distribution Product
 Engineering

DISTRIBUTION ENGINEERING REFERENCE MANUAL

DATE:
 March 21, 2007

ADDENDUM FOR EXTREME WIND LOADING

FPL uses the NESC Extreme Wind Loading for its design criteria. As such, identify the wind speed for the job location and determine the load based on the following formula.

Equation 4.2.2-2

$$\text{Load in pounds} = 0.00256 \times (V_{mph})^2 \times k_z \times G_{RF} \times I \times C_f \times A(\text{ft}^2)$$

Where,

- 0.00256 - Velocity-Pressure Numerical Coefficient
- V - Velocity of wind in miles per hour (3 second gust)
- k_z - Velocity Pressure Exposure Coefficient
- G_{RF} - Gust Response Factor
- I - Importance Factor, 1.0 for utility structures and their supported facilities.
- C_f - Force Coefficient (Shape Factor)
 For Wood & Spun Concrete Poles = 1.0
 For Square Concrete Poles = 1.6
- A - Projected Wind Area, ft^2 .

The NESC provides formulas for calculating k_z and G_{RF} . However, Tables are also provided and Table 4.2.2-2 below shows the values needed for most distribution structures.

Table 4.2.2-2 Velocity pressure Exposure coefficient (k_z) and Gust Response Factors (G_{RF})

Height (h)	Structure		Equipment		Wire		
	k_z^1	G_{RF}^4	k_z^2	G_{RF}^5	k_z^3	G_{RF}^4 ($L \leq 250$ ft)	G_{RF}^4 ($250 < L \leq 500$ ft)
≤ 33	0.9	1.02	1.0	1.02	1.0	0.93	0.86
>33 to 50	1	0.97	1.1	0.97	1.1	0.88	0.82
>50 to 80	1.1	0.93	1.2	0.93	1.2	0.86	0.80

1. h for the pole k_z is to be the height of the pole above ground
2. h for the equipment k_z is the height of the center of the area of the equipment above ground
3. h for the wire k_z is the height of the wire above ground
4. h for the G_{RF} is the height above ground for the structure and the wire
5. h for the G_{RF} for the equipment is based on the height of the structure above ground
6. L = design wind span (average of span on both sides of structure)

The wind speeds to be used are shown in Figure 4.2.2 – 1

FPL


DISTRIBUTION ENGINEERING REFERENCE MANUAL

DATE:
 March 21, 2007

PREPARED BY:
 Distribution Product
 Engineering

ADDENDUM FOR EXTREME WIND LOADING

Figure 4.2.2 -1 Wind Regions by County



PREPARED BY:
Distribution Product
Engineering

ADDENDUM FOR EXTREME WIND LOADING

3. Wood Pole Strength

The strength of wood poles is specified in the American National Standard – ANSI O5.1-2002. In addition to strength of wood poles, this standard specifies dimensions, shape, sweep spiral grain, knots, and many other characteristics of wood poles.

A change from previous calculations shown in the DERM for allowable pole strength is that the circumference to be used is now considered to be the ground line circumference rather than the “fixity” point circumference. Another change is the strength factor to be used. For extreme wind the strength factor for wood poles is 0.75 (see Table 4.2.2-1)

Example 4.2.2-1:

Determine the pole strength for wind loading on a 45’/2 wood pole that is set 7 feet.

$$\text{Equation 4.2.2-3 } M_r = 0.000264fC^3$$

Where

- M_r = Moment (ultimate or long term bowing) measured in foot-pounds
- f = Fiber Stress (8000 or 1000 psi for Southern Yellow Pine)
- C = Circumference at ground Line

From Table G (DERM 4.2.2) circumference at Ground line = 40.1 inches

$$M_r = 0.000264 \times (8,000) \times (40.1)^3 = 136,184 \text{ ft.-lbs.}$$

This is the strength for the 45’/2 wood pole. However for design, apply the NESC Strength Factor of 0.75.

The strength of the 45’/2 wood pole = 136,184 x 0.75 = 102,138 ft.-lbs.

4. Concrete Pole Strength

The strength of concrete poles is based on the application of a designated load at a specified location on the pole. This load is measured in KIPS = 1,000 pounds per KIP. A 5 KIP pole is rated based on applying 5,000 pounds of load at two feet below the top of the pole. Most distribution

PREPARED BY:
 Distribution Product
 Engineering

ADDENDUM FOR EXTREME WIND LOADING

poles are rated by applying the load at two feet down from the top. However, for the type "O", "S", and "SU" poles, this load is applied at one foot down from the top. Like wood poles, concrete poles have a continuous rating (loads that are always on the pole) and a temporary rating (wind loads that come and go). Spun concrete poles (unlike other FPL distribution concrete poles) are designated by their KIP rating rather than a type (i.e., O, S, SU, III, III-G, III-H). Table 4.2.2-3 List the ratings (in KIPS) for the various concrete poles.

Table 4.2.2-3 Concrete Pole Ratings

Pole Type	Temporary Rating	Continuous Rating
O	0.85	0.26
S & SU	0.90	0.30
III	1.30	0.56
III-A	1.30	0.60
III-G	2.40	0.90
III-H	4.20	1.20
12 KIP (square)	8.40	2.40
Spun Concrete		
4.0 KIP	4.00	1.73
4.7 KIP	4.70	2.54
5.0 KIP	5.00	3.03

To calculate the strength of the pole use the following:

For O, S, SU,

$$M_r = \text{Rating (Table 4.2.2-3)} \times (\text{Pole Length} - \text{setting depth} - 1 \text{ foot})$$

Example: 35' Type SU for extreme wind loading

$$M_r = 0.9 \text{ KIPS} \times (35 - 7.5 - 1) = 23,850 \text{ ft-lbs}$$

For III, III-A, III-G, III-H

$$M_r = \text{Rating (Table 4.2.2-3)} \times (\text{Pole Length} - \text{setting depth} - 2 \text{ feet})$$

Example: 50' Type III-H for extreme wind loading

$$M_r = 4.2 \text{ KIPS} \times (50 - 11.5 - 2) = 153,300 \text{ ft-lbs}$$

FPL

DISTRIBUTION ENGINEERING REFERENCE MANUAL

DATE:
March 21, 2007

PREPARED BY:
Distribution Product
Engineering

ADDENDUM FOR EXTREME WIND LOADING

For Spun Concrete

$$M_r = \text{Rating (Table 4.2.2-3)} \times (\text{Pole Length} - \text{setting depth} - 2 \text{ feet})$$

Example: 50' / 4.7 KIP for extreme wind loading

$$M_r = 4.7 \text{ KIPS} \times (50 - 11 - 2) = 173,900 \text{ ft-lbs}$$

For pre-stressed concrete poles, the NESC extreme wind strength factor = 1.0. The values calculated above will be the correct strength for concrete poles.

PREPARED BY:
Distribution Product
Engineering

ADDENDUM FOR EXTREME WIND LOADING

B. Wind Loading

1. Wind Loading on poles.

To calculate the wind load on the pole (see DERM 4.2.2 C3.a):

- a. Calculate the area of the pole exposed to the wind

$$\text{Equation 4.2.2-4} \quad A = H_1 \left(\frac{a+b}{2} \right) \left(\frac{1}{12} \right)$$

A = projected area above ground line in square feet.
H₁ = the pole's height above the ground line in feet.

For wood and spun concrete poles,

a = diameter at top of pole in inches.
b = diameter of pole at ground line in inches.

For square concrete poles, dimensions a and b are the widths of one face at top and ground line respectively.

- b. Calculate the center of the area.

$$\text{Equation 4.2.2-5} \quad H_{CA} = \frac{H_1(b + 2a)}{3(b + a)}$$

H_{CA} is used to calculate the ground line moment due to the wind force.

- c. Calculate the wind force acting on the area (see Equation 4.2.2-2 with explanation of terms)

$$\text{Load in pounds} = 0.00256 \cdot (V_{\text{mph}})^2 \cdot k_z \cdot G_{RF} \cdot I \cdot C_f \cdot A(\text{ft}^2)$$

Example Calculation for Wood Pole

Pole Length/Class = 45'/2
Setting depth = 7' (from DCS D-3.0)
Wind Region = 145 mph

PREPARED BY:
 Distribution Product
 Engineering

ADDENDUM FOR EXTREME WIND LOADING

$$\text{Projected Area. } A = H_1(\text{ft.}) \times \frac{1 \text{ ft}}{12 \text{ in}} \times \left[\frac{a + b(\text{inches})}{2} \right]$$

From Table G, Page 71, the circumference at the top of a 45' / 2 pole is 25",

$$a = \frac{25''}{\pi} = 7.96''$$

The circumference at 38 ft. below the pole top 40.1", $b = \frac{40.1''}{\pi} = 12.76''$

$$A = \frac{38}{12} \times \left[\frac{7.96 + 12.76}{2} \right] = 32.81 \text{ sq. ft.}$$

$$\text{Height of center of area, } H_{CA} = \frac{H_1(b+2a)}{3(b+a)} = \frac{38(12.76 + 15.92)}{3(12.76 + 7.96)}$$

$$H_{CA} = \text{Moment Arm} = 17.53 \text{ ft.}$$

Wind Load on Pole =

$$0.00256 \times (145)^2 \times 1.0 \times 0.97 \times 1.0 \times 1.0 \times 32.81 = 1713 \text{ lbs}$$

Where:

k_z is based on $h = 38'$; $k_z = 1.0$

G_{RF} is based on $h = 38'$; $G_{RF} = 0.97$

$C_f = 1.0$ for wood and spun concrete poles

$C_f = 1.6$ for square concrete poles

This load must then be multiplied by the Load Factor, which for extreme wind equals 1.0 and the moment arm to obtain the Ground Line Moment (M_P) of the wind acting on the pole only.

Equation 4.2.2-6

$$M_P = \text{Wind Load} \times \text{Load Factor} \times \text{Moment Arm.}$$

$$M_P = 1713 \text{ lbs} \times 1 \times 17.53 \text{ ft.} = 30,030 \text{ ft. lbs.}$$

The strength of this pole, previously calculated is 102,138 ft.-lbs. The pole itself has used up 29% (30,030/102,138) of its capacity for 145 mph extreme wind. Subtracting the wind load from the strength leaves 72,108 ft.-lbs (102,138 – 30,030) for conductors and other attachments.

FPL

DISTRIBUTION ENGINEERING REFERENCE MANUAL

DATE:
March 21, 2007

PREPARED BY:
Distribution Product
Engineering

ADDENDUM FOR EXTREME WIND LOADING

Example Calculation for Square Concrete Pole

Pole Length/Class = 50'/III-H
Setting depth = 11.5' (from DCS D-3.0)
Wind Region = 145 mph

$$\text{Projected Area, } A = H_1(\text{ft.}) \times \frac{1 \text{ ft}}{12 \text{ in}} \times \left[\frac{a+b(\text{inches})}{2} \right]$$

From Table H, the width of the pole at the top $a = 9.00''$
The width at ground line, $b = 15.75''$

$$A = \frac{38.5}{12} \times \left[\frac{15.75+9.00}{2} \right] = 39.70 \text{ sq. ft.}$$

$$\text{Height of center of area, } H_{CA} = \frac{H_1(b+2a)}{3(b+a)} = \frac{38.5(15.75+18.00)}{3(15.75+9.00)}$$

$$H_{CA} = \text{Moment Arm} = 17.5 \text{ ft.}$$

Wind Load on Pole =

$$0.00256 \times (145)^2 \times 1.0 \times 0.97 \times 1.0 \times 1.6 \times 39.7 = \mathbf{3317 \text{ lbs}}$$

Where:

k_z is based on $h = 38.5'$; $k_z = 1.0$

G_{RF} is based on $h = 38.5'$; $G_{RF} = 0.97$

$C_f = 1.0$ for wood and spun concrete poles

$C_f = 1.6$ for square concrete poles

This load must then be multiplied by the Load Factor, which for extreme wind equals 1.0 and the moment arm to obtain the Ground Line Moment (M_P) of the wind acting on the pole only.

$$M_P = \text{Wind Load} \times \text{Load Factor} \times \text{Moment Arm.}$$

$$M_P = 3317 \text{ lbs} \times 1 \times 17.5 \text{ ft.} = 58,040 \text{ ft. lbs.}$$

The strength of this pole, previously calculated is 153,300 ft.-lbs. The pole itself has used up 38% (58,040/153,300) of its capacity for 145 mph extreme wind. Subtracting the wind load from the strength leaves 95,260 ft.-lbs (153,300 – 58,040) for conductors and other attachments.

PREPARED BY:
 Distribution Product
 Engineering

ADDENDUM FOR EXTREME WIND LOADING

Example Calculation for Spun Concrete Pole

Pole Length/Class = 50'/4.7 KIP
 Setting depth = 11' (from DCS D-3.0)
 Wind Region = 145 mph

$$\text{Projected Area. } A = H_1(\text{ft.}) \times \frac{1 \text{ ft}}{12 \text{ inc.}} \times \left[\frac{a + b(\text{inches})}{2} \right]$$

From Table H, the diameter of the pole at the top $a = 9.55''$
 The diameter at ground line, $b = 16.57''$

$$\text{So } A = \frac{39}{12} \times \left[\frac{9.55 + 16.57}{2} \right] = 42.45 \text{ sq. ft.}$$

$$\text{Height of center of area, } H_{CA} = \frac{H_1(b + 2a)}{3(b + a)} = \frac{39(16.57 + 19.1)}{3(16.57 + 9.55)}$$

$$H_{CA} = \text{Moment Arm} = 17.75 \text{ ft.}$$

Wind Load on Pole =

$$0.00256 \times (145)^2 \times 1.0 \times 0.97 \times 1.0 \times 1.0 \times 42.45 = \mathbf{2,216 \text{ lbs}}$$

Where:

k_z is based on $h = 39'$; $k_z = 1.0$

G_{RF} is based on $h = 39'$; $G_{RF} = 0.97$

$C_f = 1.0$ for wood and spun concrete poles

$C_f = 1.6$ for square concrete poles

This load must then be multiplied by the Load Factor, which for extreme wind equals 1.0 and the moment arm to obtain the Ground Line Moment (M_P) of the wind acting on the pole only.

$$M_P = \text{Wind Load} \times \text{Load Factor} \times \text{Moment Arm.}$$

$$M_P = 2,216 \text{ lbs} \times 1 \times 17.75 \text{ ft.} = 39,341 \text{ ft. lbs.}$$

The strength of this pole, previously calculated is 173,900 ft.-lbs. The pole itself has used up 23% (39,341/173,900) of its capacity for 145 mph extreme wind. Subtract the wind load from the strength leaves 134,559 ft.-lbs (173,900 – 39341) for conductors and other attachments.

Table 4.2.2-4 Lists the allowable groundline moments for various pole sizes.

FPL

DISTRIBUTION ENGINEERING REFERENCE MANUAL

DATE:
 March 21, 2007

PREPARED BY:
 Distribution Product
 Engineering

ADDENDUM FOR EXTREME WIND LOADING

Table 4.2.2-4 Allowable Ground Line Moments

Wood Poles (in earth)				
Pole Size	Setting Depth	Allowable Moment for Attachments at Designated Wind Speeds		
		105 mph	130 mph	145 mph
35/5	6	32178	28738	26324
35/4	6	42429	38656	36007
40/5	6.5	36936	31956	28460
40/4	6.5	48263	42812	38986
40/3	6.5	61567	55646	51489
40/2	6.5	76998	70607	66119
45/3	7	66363	58624	53190
45/2	7	86391	78000	72108
50/2	7	93535	82611	74941
55/2	7.5	99693	86174	76682
60/1	8	131634	113020	99951

FPL

DISTRIBUTION ENGINEERING REFERENCE MANUAL

DATE:
 March 21, 2007

PREPARED BY:
 Distribution Product
 Engineering

ADDENDUM FOR EXTREME WIND LOADING

Table 4.2.2-4 Allowable Ground Line Moments (cont.)

Square Concrete Poles (in earth)				
Pole Size	Setting Depth	Allowable Moment for Attachments at Designated Wind Speeds		
		105 mph	130 mph	145 mph
35/Type O	7	15426	11417	8602
35/SU	7.5	15323	10778	7588
35/III-G	9	48907	44275	41022
40/III-A	10	23777	17050	12327
40/III-G	9	56781	49950	45154
40/III-H	11.5	96450	88537	82981
40/12 KIP	13	191480	181610	174681
45/III-A	10	24142	14146	7127
45/III-G	9	62676	52592	45511
45/III-H	11.5	110053	98198	89874
45/12 KIP	13.5	222175	208520	198933
50/III-A	10	24111	10635	1173
50/III-G	9.5	67701	54539	45297
50/III-H	11.5	123164	107106	95831
50/12 KIP	13.5	252789	233067	219219
55/III-G	9.5	72176	55004	42947
55/III-H	12	133764	113283	98902
55/12 KIP	14	280155	254873	237121
60/III-H	12	144138	117993	99637
60/12 KIP	14	308835	276454	253719
65/III-H	12	149613	115197	91032

Spun Concrete Poles (in earth)				
Pole Size	Setting Depth	Allowable Moment for Attachments at Designated Wind Speeds		
		105 mph	130 mph	145 mph
50/4.7 KIP	11	153270	142277	134559
55/4.7 KIP	12	167116	153482	143910
60/5.0 KIP	12.5	190953	171477	157803
65/5.0 KIP	13	202928	177845	160233
70/5.0 KIP	13.5	214369	183392	161642

PREPARED BY:
Distribution Product
Engineering

ADDENDUM FOR EXTREME WIND LOADING

2. Wind Loading on conductors.

The wind loading on conductors is calculated in a similar method to the wind loading on the pole. The load in pounds per conductor uses Equation 4.2.2-2 with the appropriate factors for the attachment heights a shown in Table 4.2.2-2.

To calculate the wind load on the conductor:

- a. Determine the wind region (105 mph, 130 mph, or 145 mph)
- b. Calculate the attachment height to determine the k_z and G_{RF} (Table 4.2.2-2)
- c. The Importance Factor (I) and the Force Coefficient (C_f) are both equal to 1 for conductors.
- d. Calculate the area per foot of conductor
- e. Calculate the wind load per foot of conductor
- f. Calculate the total wind load on the conductor for the length of conductor exposed to the wind (Average of the Spans on either side of the pole).

Example:

Determine the wind load on a 170 foot length $[(180'\text{span} + 160'\text{span})/2]$ of 568.3 ACAR conductor that is attached at 30 feet above the ground in the 145 mph wind region.

From Table 4.2.2-2:

$$K_z = 1.0$$

$$G_{RF} = 0.93$$

Calculate the area per foot of conductor

Diameter = 0.879 inches (ref DCS F-7.0.0)

For a 1 foot length of conductor:

Projected Area.

$$A = 1(\text{ft.}) \times \left[\frac{\text{Conductor Diameter}(\text{inches})}{12(\text{inches} / \text{ft})} \right]$$

$$A = 1(\text{ft.}) \times \left[\frac{0.879(\text{inches})}{12(\text{inches} / \text{ft})} \right]$$

A = 0.073 Square Ft. for each foot of span length

The wind load in pounds per foot of span length (from Equation 4.2.2-2) is

$$\text{Load in pounds} = 0.00256 \times (V_{\text{mph}})^2 \times k_z \times G_{RF} \times I \times C_f \times A(\text{ft}^2)$$

PREPARED BY:
Distribution Product
Engineering

ADDENDUM FOR EXTREME WIND LOADING

$$\begin{aligned}\text{Load in pounds} &= 0.00256 \times (145)^2 \times 1 \times .93 \times 1 \times 1 \times .073 \\ \text{Load} &= 3.667 \text{ pounds per foot}\end{aligned}$$

$$\begin{aligned}\text{Total Load} &= \text{Length of conductor} \times \text{Load per foot of conductor} \\ &= 170 \times 3.667 \\ \text{Total Load} &= 623.3 \text{ pounds}\end{aligned}$$

This is the load that the wind exerts on the conductor attached at 30 above ground. This load will have to be applied to the pole to determine if the pole has the strength to support the load.

The wind load per foot of conductor for the three wind regions can be found in Table 4.2.2-5, Table 4.2.2- 6 and Table 4.2.2-7.

3. Wind Loading on equipment.

The wind loading on equipment is calculated in a similar method to the wind loading on the pole and the conductors. The load in pounds uses Equation 4.2.2-2 with the appropriate factors for the attachment heights a shown in Table 4.2.2-2 and the area of the equipment.

To calculate the wind load on the equipment:

- a. Determine the wind region (105 mph, 130 mph, or 145 mph)
- b. Calculate the attachment height to determine the k_z (Table 4.2.2-2) (For equipment, use the top mounting hole of the equipment bracket.)
- c. Use the height of the pole above ground to determine G_{RF} (Table 4.2.2-2)
- d. The Importance Factor (I) is equal to 1.
- e. The Force Coefficient (C_f) is equal to 1.0 for cylindrical equipment and 1.6 for rectangular equipment.
- f. Calculate the area of the equipment
- g. Calculate the wind load on the equipment

Example:

Determine the wind load on a 50 kVA transformer mounted at 28 feet on a pole that is 38 feet above the ground in the 145 mph wind region.

From Table 4.2.2-2:

$$K_z = 1.0 \text{ (Equipment } \leq 33' \text{ above ground)}$$

$$G_{RF} = 0.97 \text{ (Equipment based on Pole height } > 33' \text{ to } 50' \text{ above ground)}$$

$$C_f = 1.0$$

$$A = 4.44 \text{ square feet}$$

FPL

DISTRIBUTION ENGINEERING REFERENCE MANUAL

DATE:
March 21, 2007

PREPARED BY:
Distribution Product
Engineering

ADDENDUM FOR EXTREME WIND LOADING

The wind load in pounds from Equation 4.2.2-2 is

$$\text{Load in pounds} = 0.00256 \times (V_{\text{mph}})^2 \times k_z \times G_{RF} \times I \times C_f \times A(\text{ft}^2)$$

$$\begin{aligned} \text{Load in pounds} &= 0.00256 \times (145)^2 \times 1 \times .97 \times 1 \times 1 \times 4.44 \\ \text{Load} &= 231.8 \text{ pounds} \end{aligned}$$

This is the load that the wind exerts on the transformer attached at 28 feet above ground. This load will have to be applied to the pole to determine if the pole has the strength to support the load.

The wind load on equipment for the three wind regions can be found in Table 4.2.2-5 (105 mph), Table 4.2.2- 6 (130 mph) and Table 4.2.2-7 (145 mph).

FPL

DISTRIBUTION ENGINEERING REFERENCE MANUAL

DATE:
 March 21, 2007

PREPARED BY:
 Distribution Product
 Engineering

ADDENDUM FOR EXTREME WIND LOADING

Table 4.2.2-5 Wind Force on Conductors & Equipment

Wind Speed = 105 mph
 CONDUCTORS

Conductor	Diameter	Force in pounds per foot Conductor Height Above Ground		
		≤33'	>33' to 50'	>50' to 80'
568.3 MCM ACAR	0.879	1.923	2.001	2.134
3/0 AAAC	0.502	1.098	1.143	1.218
1/0 AAAC	0.398	0.871	0.906	0.966
#4 AAAC	0.250	0.547	0.569	0.607
3/0 TPX	1.238	2.708	2.819	3.005
1/0 TPX	1.026	2.244	2.336	2.490
6 DPX	0.496	1.085	1.129	1.204
CATV				
Feeder w/1/4"Msgnr	0.750	1.641	1.708	1.820
Trunk w/1/4"Msgnr	1.000	2.187	2.277	2.427
Telephone				
100 pr (24 GA BKMS) Self-Support	0.960	2.100	2.186	2.330
600 pr (24 GA BKMA w/3/8" Msgnr	2.295	5.020	5.225	5.571

Wind Speed = 105 mph
 EQUIPMENT

Transformers	Sq. Ft.	Pole Height in same range as Equipment Force in pounds at top mounting Bolt Height Above Ground			Pole height >33' to 50' Equipment Ht ≤33'
		≤33'	>33' to 50'	>50' to 80'	
25	3.75	108.0	112.9	118.1	102.7
50	4.44	127.8	133.7	139.9	121.6
75	4.81	138.5	144.9	151.5	131.7
100	6.55	188.6	197.3	206.3	179.3
167	10.83	311.8	326.1	341.1	296.5
Capacitors					
Switched (1)	19.91	573.2	599.6	627.1	545.1
Fixed (1)	16.89	486.2	508.6	532.0	462.4
Reclosers					
1 phase	4.00	115.2	120.5	126.0	109.5
3 phase (1)	16.89	486.2	508.6	532.0	462.4
Automation Switches					
Joslyn	8.89	255.9	267.7	280.0	243.4
Cooper	10.56	304.0	318.0	332.6	289.1
S&C	15.60	449.1	469.8	491.4	427.1
Riser - PVC U-Guard		Force in pounds per foot of riser Height Above Ground			
2" U-Guard	0.19	5.4	5.6	5.9	5.1
5" U-Guard	0.46	12.8	13.8	14.4	13.2

(1) The 1.6 C_r factor for rectangular shape is included in the Area shown for Capacitors and 3 Phase Recloser

FPL

DISTRIBUTION ENGINEERING REFERENCE MANUAL

DATE:
 March 21, 2007

PREPARED BY:
 Distribution Product
 Engineering

ADDENDUM FOR EXTREME WIND LOADING

Table 4.2.2-6 Wind Force on Conductors & Equipment

**Wind Speed = 130 mph
 CONDUCTORS**

Conductor	Diameter	Force in pounds per foot Conductor Height Above Ground		
		≤33'	>33' to 50'	>50' to 80'
568.3 MCM ACAR	0.879	2.947	3.068	3.270
3/0 AAAC	0.502	1.683	1.752	1.868
1/0 AAAC	0.398	1.334	1.389	1.481
#4 AAAC	0.250	0.838	0.872	0.930
3/0 TPX	1.238	4.151	4.321	4.606
1/0 TPX	1.026	3.440	3.581	3.817
6 DPX	0.496	1.663	1.731	1.845
CATV				
Feeder w/1/4"Msgnr	0.750	2.515	2.617	2.791
Trunk w/1/4"Msgnr	1.000	3.353	3.490	3.721
Telephone				
100 pr (24 GA BKMS) Self-Support	0.960	3.219	3.350	3.572
600 pr (24 GA BKMA w/3/8" Msgnr	2.295	7.695	8.009	8.539

**Wind Speed = 130 mph
 EQUIPMENT**

Transformers	Sq. Ft.	Pole Height in same range as Equipment Force in pounds at top mounting Bolt Height Above Ground			Pole height >33' to 50' Equipment Ht ≤33'
		≤33'	>33' to 50'	>50' to 80'	
25	3.75	165.5	173.1	181.1	157.4
50	4.44	195.9	205.0	214.4	186.3
75	4.81	212.3	222.0	232.2	201.9
100	6.55	289.0	302.4	316.3	274.9
167	10.83	477.9	499.9	522.9	454.5
Capacitors					
Switched (1)	19.91	878.6	919.1	961.3	835.5
Fixed (1)	16.89	745.3	779.7	815.5	708.8
Reclosers					
1 phase	4.00	176.5	184.7	193.1	167.9
3 phase (1)	16.89	745.3	779.7	815.5	708.8
Automation Switches					
Joslyn	8.89	392.3	410.4	429.2	373.1
Cooper	10.56	466.0	487.5	509.9	443.2
S&C	15.60	688.4	720.1	753.2	654.7
Riser - PVC U-Guard					
		Force in pounds per foot of riser Height Above Ground			
2" U-Guard	0.19	8.3	8.7	9.1	7.9
5" U-Guard	0.46	20.2	21.2	22.1	19.2

(1) The 1.6 C_f factor for rectangular shape is included in the Area shown for Capacitors and 3 Phase Recloser

FPL

DISTRIBUTION ENGINEERING REFERENCE MANUAL

DATE:
 March 21, 2007

PREPARED BY:
 Distribution Product
 Engineering

ADDENDUM FOR EXTREME WIND LOADING

Table 4.2.2-7 Wind Force on Conductors & Equipment

Wind Speed = 145 mph
 CONDUCTORS

Conductor	Diameter	Force in pounds per foot Conductor Height Above Ground		
		≤33'	>33' to 50'	>50' to 80'
568.3 MCM ACAR	0.879	3.667	3.816	4.069
3/0 AAAC	0.502	2.094	2.180	2.324
1/0 AAAC	0.398	1.660	1.728	1.842
#4 AAAC	0.250	1.043	1.085	1.157
3/0 TPX	1.238	5.164	5.375	5.731
1/0 TPX	1.026	4.280	4.455	4.749
6 DPX	0.496	2.069	2.154	2.296
CATV				
Feeder w/1/4"Msgnr	0.750	3.129	3.256	3.472
Trunk w/1/4"Msgnr	1.000	4.171	4.342	4.629
Telephone				
100 pr (24 GA BKMS) Self-Support	0.960	4.005	4.168	4.444
600 pr (24 GA BKMA w/3/8" Msgnr	2.295	9.573	9.964	10.623

Wind Speed = 145 mph
 EQUIPMENT

Transformers	Sq. Ft.	Pole Height in same range as Equipment Force in pounds at top mounting Bolt Height Above Ground			Pole height >33' to 50' Equipment Ht
		≤33'	>33' to 50'	>50' to 80'	
25	3.750	205.9	215.4	225.3	195.8
50	4.440	243.8	255.0	266.7	231.8
75	4.810	264.1	276.2	288.9	251.1
100	6.550	359.6	376.2	393.4	342.0
167	10.830	594.6	622.0	650.5	565.4
Capacitors					
Switched (1)	19.910	1093.1	1143.4	1195.9	1039.5
Fixed (1)	16.890	927.3	970.0	1014.5	881.8
Reclosers					
1 phase	4.000	219.6	229.7	240.3	208.8
3 phase (1)	16.890	927.3	970.0	1014.5	881.8
Automation Switches					
Joslyn	8.890	488.1	510.6	534.0	464.1
Cooper	10.560	579.7	606.5	634.3	551.3
S&C	15.600	856.4	895.9	937.1	814.5
Riser - PVC U-Guard					
		Force in pounds per foot of riser Height Above Ground			
2" U-Guard	0.188	10.3	10.8	11.3	9.8
5" U-Guard	0.458	25.2	26.3	27.5	23.9

(1) The 1.6 C_r factor for rectangular shape is included in the Area shown for Capacitors and 3 Phase Recloser

FPL

DISTRIBUTION ENGINEERING REFERENCE MANUAL

DATE:
March 21, 2007

PREPARED BY:
Distribution Product
Engineering

ADDENDUM FOR EXTREME WIND LOADING

The methodology to determine if a pole has the strength for a specific design or to determine the maximum span distance a specific size pole can support for framing, is the same as shown in the DERM 4.2.2 pages 12-15. The examples shown below show the calculations based on using the new tables for extreme wind loading. Note that the ground line is now the point used for the calculations rather than the "fixity" point.

Example:

Conductor: 3-568.3 MCM ACAR and #3/0 AAAC - Neutral
Framing: DCS page E-5.0.0 (Modified Vertical) and I-41.0.1 (for single
phase transformer)
Transformer: 50 kVA
CATV: Trunk
Telephone: 1-600 pair, 24 gauge, BKMA
Average Span Length = 150 feet
Attachment heights must be calculated using the framing identified and the
pole setting depths as shown in the Revised DCS page D-3.0.0

FPL

DISTRIBUTION ENGINEERING REFERENCE MANUAL

DATE:
 March 21, 2007

PREPARED BY:
 Distribution Product
 Engineering

ADDENDUM FOR EXTREME WIND LOADING

Case I: Determine if a 45'2 wood pole is strong enough for this design.

Calculate the moments on the pole.

CONDUCTORS	Number of Conductors	x	Wind Load Per Ft. (Table 4.2.2-7)	x	Avg. Span Length	x	Height Above Ground	=	MOMENT (ft.-lb.)
Primary									
568.3	1	x	3.816	x	150	x	39.00	=	22324
568.3	1	x	3.816	x	150	x	36.60	=	20950
568.3	1	x	3.816	x	150	x	34.60	=	19805
Neut. Sec. SLT									
3/0	1	x	2.094	x	150	x	29.4	=	9235
CATV - PROPOSED									
Trunk	1	x	4.171	x	150	x	23.6	=	14765
TELEPHONE									
600 pr 24 Ga BKMA	1	x	9.573	x	150	x	22.6	=	32452
TOTAL MOMENT DUE TO CONDUCTOR								=	119531
EQUIPMENT			Wind Load Force in lbs				Height Above Ground	=	MOMENT (ft.-lb.)
TRANSFORMERS	(SEE TABLE FOR INSTRUCTIONS)								
1 Phase	50 kva		231.8		x		29.9	=	6931
TOTAL MOMENT DUE TO EQUIPMENT								=	6931 ft.-lb.
TOTAL ALL MOMENTS								=	126462 ft.-lb.

From Table 4.2.2-4, the allowable moment for attachments to a 45'2 wood pole in a 145 mph wind region is 72,108 ft.-lbs. A 45'2 wood pole cannot be used.

FPL

DISTRIBUTION ENGINEERING REFERENCE MANUAL

DATE:
 March 21, 2007

PREPARED BY:
 Distribution Product
 Engineering

ADDENDUM FOR EXTREME WIND LOADING

Case II: Determine if a 50'/III-H square concrete pole is strong enough for this design

DCS D-3.0.0 shows a revised setting depth for square concrete poles. The new setting depth is generally 5 feet deeper than previous. A 50'/III-H square concrete pole is set 11.5 feet deep.

Re-calculate the moments based on attachment heights.

CONDUCTORS	Number of Conductors	x	Wind Load Per Ft. (Table 4.2.2-7)	x	Avg. Span Length	x	Height Above Ground	=	MOMENT (ft.-lb.)
Primary									
568.3	1	x	3.816	x	150	x	39.50	=	22610
568.3	1	x	3.816	x	150	x	37.08	=	21225
568.3	1	x	3.816	x	150	x	35.08	=	20080
Neut., Sec., St Lt									
3/0	1	x	2.094	x	150	x	29.92	=	9398
CATV - PROPOSED									
Trunk	1	x	4.171	x	150	x	24.08	=	15066
TELEPHONE									
600 pr 24 Ga BKMA	1	x	9.573	x	150	x	23.08	=	33142
TOTAL MOMENT DUE TO CONDUCTOR									= 121519
EQUIPMENT									
			Wind Load Force in lbs				Height Above Ground	=	MOMENT (ft.-lb.)
TRANSFORMERS (SEE TABLE FOR INSTRUCTIONS)									
1 Phase	50 kva		231.8		x		30.42	=	7051
TOTAL MOMENT DUE TO EQUIPMENT									= 7051 ft.-lb.
TOTAL ALL MOMENTS									= 128571 ft.-lb.

From Table 4.2.2-4, the allowable moment for attachments to a 50'/III-H square concrete pole in a 145 mph wind region is 95,831 ft-lbs. A 50'/III-H square concrete pole cannot be used.

FPL

DISTRIBUTION ENGINEERING REFERENCE MANUAL

DATE:
 March 21, 2007

PREPARED BY:
 Distribution Product
 Engineering

ADDENDUM FOR EXTREME WIND LOADING

Case III: Determine if a 50'/4.7 KIP spun concrete pole is strong enough for this design.

DCS D-3.0.0 shows the setting depths for spun concrete poles. A 50'/4.7 KIP spun concrete pole is set 11 feet deep.

Re-calculate the moments based on attachment heights.

CONDUCTORS	Number of Conductors	x	Wind Load Per Ft. (Table 4.2.2-7)	x	Avg. Span Length	x	Height Above Ground	=	MOMENT (ft.-lb.)
Primary									
568.3	1	x	3.816	x	150	x	40.00	=	22896
568.3	1	x	3.816	x	150	x	37.58	=	21511
568.3	1	x	3.816	x	150	x	35.58	=	20366
Neut. Sec., St Lt									
3/0	1	x	2.094	x	150	x	30.42	=	9555
CATV - PROPOSED									
Trunk	1	x	4.171	x	150	x	24.58	=	15378
TELEPHONE									
600 pr 24 Ga BKMA	1	x	9.573	x	150	x	23.58	=	33860
TOTAL MOMENT DUE TO CONDUCTOR								=	123566
EQUIPMENT									
			Wind Load Force in lbs				Height Above Ground	=	MOMENT (ft.-lb.)
TRANSFORMERS (SEE TABLE FOR INSTRUCTIONS)									
1 Phase	50 kva		231.8		x		30.92	=	7167
TOTAL MOMENT DUE TO EQUIPMENT								=	7167 ft.-lb.
TOTAL ALL MOMENTS								=	130733 ft.-lb.

From Table 4.2.2-4, the allowable moment for attachments to a 50'/4.7 KIP spun concrete pole in a 145 mph wind region is 134,559 ft-lbs. A 50'/4.7 KIP spun concrete pole can be used.

Using similar calculations from DERM 4.2.2 page 13, the maximum span distance for each of the poles above can be determined.

Determine the moment due to 1 foot of conductor moments

Subtract the moment due to the transformer from the total allowable moment

Divide the remaining allowable moment by the total 1 foot conductor moments.

FPL

DISTRIBUTION ENGINEERING REFERENCE MANUAL

DATE:
 March 21, 2007

PREPARED BY:
 Distribution Product
 Engineering

ADDENDUM FOR EXTREME WIND LOADING

CONDUCTORS	Number of Conductors	x	Wind Load Per Ft. (Table 4.2.2-7)	x	Avg. Span Length	x	Height Above Ground	=	MOMENT (ft.-lb.)
Primary									
568.3	1	x	3.816	x	1	x	39.00	=	149
568.3	1	x	3.816	x	1	x	36.60	=	140
568.3	1	x	3.816	x	1	x	34.60	=	132
Neut. Sec. St Lt									
3/0	1	x	2.094	x	1	x	29.4	=	62
CATV - PROPOSED									
Trunk	1	x	4.171	x	1	x	23.6	=	98
TELEPHONE									
600 pr 24 Ga BKMA	1	x	9.573	x	1	x	22.6	=	216
TOTAL MOMENT DUE TO CONDUCTOR								=	797
EQUIPMENT									
			Wind Load Force in lbs				Height Above Ground	=	MOMENT (ft.-lb.)
TRANSFORMERS (SEE TABLE FOR INSTRUCTIONS)									
1 Phase	50 kva		231.8		x		29.9	=	6931
TOTAL MOMENT DUE TO EQUIPMENT								=	6931 ft.-lb.
TOTAL ALL MOMENTS								=	7728 ft.-lb.

Maximum Allowable moment on 45/2 pole = 72108
 Transformer Moment 6931
 Available for conductors 65177
 Conductor Moments per foot of span = 797

Maximum span distance = 82 ft.

CONDUCTORS	Number of Conductors	x	Wind Load Per Ft. (Table 4.2.2-7)	x	Avg. Span Length	x	Height Above Ground	=	MOMENT (ft.-lb.)
Primary									
568.3	1	x	3.816	x	1	x	39.50	=	151
568.3	1	x	3.816	x	1	x	37.08	=	141
568.3	1	x	3.816	x	1	x	35.08	=	134
Neut. Sec. St Lt									
3/0	1	x	2.094	x	1	x	29.92	=	63
CATV - PROPOSED									
Trunk	1	x	4.171	x	1	x	24.08	=	100
TELEPHONE									
600 pr 24 Ga BKMA	1	x	9.573	x	1	x	23.08	=	221
TOTAL MOMENT DUE TO CONDUCTOR								=	810
EQUIPMENT									
			Wind Load Force in lbs				Height Above Ground	=	MOMENT (ft.-lb.)
TRANSFORMERS (SEE TABLE FOR INSTRUCTIONS)									
1 Phase	50 kva		231.8		x		30.42	=	7051
TOTAL MOMENT DUE TO EQUIPMENT								=	7051 ft.-lb.
TOTAL ALL MOMENTS								=	7861 ft.-lb.

Maximum Allowable moment on 50/III-H pole = 95831
 Transformer Moment 7051
 Available for conductors 88780
 Conductor Moments per foot of span = 810

Maximum span distance = 110 ft.

FPL

DISTRIBUTION ENGINEERING REFERENCE MANUAL

DATE:
 March 21, 2007

PREPARED BY:
 Distribution Product
 Engineering

ADDENDUM FOR EXTREME WIND LOADING

CONDUCTORS	Number of Conductors	x	Wind Load Per Ft. (Table 4.2.2-7)	x	Avg. Span Length	x	Height Above Ground	=	MOMENT (ft.-lb.)
Primary									
568.3	1	x	3.816	x	1	x	40.00	=	153
568.3	1	x	3.816	x	1	x	37.58	=	143
568.3	1	x	3.816	x	1	x	35.58	=	136
Neut. Sec., St Lt									
3/0	1	x	2.094	x	1	x	30.42	=	64
CATV - PROPOSED									
Trunk	1	x	4.171	x	1	x	24.58	=	103
TELEPHONE									
600 pr 24 Ga BKMA	1	x	9.573	x	1	x	23.58	=	226
TOTAL MOMENT DUE TO CONDUCTOR								=	824
EQUIPMENT			Wind Load Force in lbs				Height Above Ground	=	MOMENT (ft.-lb.)
TRANSFORMERS	(SEE TABLE FOR INSTRUCTIONS)								
1 Phase	50 kva		231.8		x		30.92	=	7167
TOTAL MOMENT DUE TO EQUIPMENT								=	7167 ft.-lb.
TOTAL ALL MOMENTS								=	7991 ft.-lb.

Maximum Allowable moment on 50'4.7 KIP po	134559
Transformer Moment	7167
Available for conductors	127392
Conductor Moments per foot of span =	824
Maximum span distance =	155 ft.

Maximum span distances for Modified Vertical Framing with various pole sizes and types, conductor sizes, CATV and Telephone Cables are listed in Table 4.2.2-8 (105 mph), Table 4.2.2-9 (130 mph), and Table 4.2.2-10 (145 mph). The span distances shown were calculated using 95% of the span distance calculated using the KEMA[®] Pole Design Calculation Toolkit[™] program. This will allow for slight variation in field conditions and rounding of values. Using the calculations described in this document may be slightly different than the table values. In some cases, the limiting factor is not the wind loading, but the required clearance above the ground and above other conductors or cables. For all joint use clearance calculations, the top joint user is considered to be attached at 23 feet above ground. When clearance is the limiting factor, the maximum span length for a specific pole is shown in bold italics. In some cases, the joint use clearance criteria cannot be met using the pole height indicated.

One other criterion incorporated in the tables is a maximum design span of 350 feet. Longer spans may be achieved, but need to be addressed on an individual basis.

FPL

DISTRIBUTION ENGINEERING REFERENCE MANUAL

DATE:
 March 21, 2007

PREPARED BY:
 Distribution Product
 Engineering

ADDENDUM FOR EXTREME WIND LOADING

Table 4.2.2-8

Transverse Pole Loading due to Extreme Wind - 105 MPH
 Maximum Span Length in Feet
 Modified Vertical Construction (DCS E-5.0.0)

Conductors		Wood Pole Height and Class					
		40/3	45/3	45/2	50/2	55/2	60/1
3-568 ACAR & 3/0 AAAC-N	FPL Only	296	281	350	342	324	350
	FPL With						
	1-100 pair	<i>100</i>	211	<i>250</i>	275	259	307
	1-600 pair	<i>100</i>	165	216	200	191	223
	1-CATV	<i>100</i>	209	<i>250</i>	273	257	304
	1-100 pair & 1 CATV	<i>100</i>	176	230	213	202	255
	1-600 pair & 1 CATV	<i>100</i>	144	188	174	166	194
3-568 ACAR & 3/0 AAAC-N & 3/0 TPX	FPL Only	206	195	273	256	224	283
	FPL With	(2)					
	1-100 pair		<i>150</i>	<i>150</i>	202	191	224
	1-600 pair		137	<i>150</i>	166	158	184
	1-CATV		<i>150</i>	<i>150</i>	200	190	222
	1-100 pair & 1 CATV		144	<i>150</i>	175	166	194
	1-600 pair & 1 CATV		123	<i>150</i>	148	142	164
3-3/0 & 1/0 N	FPL Only	350	350	350	350	350	350
	FPL With						
	1-100 pair	<i>100</i>	<i>250</i>	<i>250</i>	350	350	350
	1-600 pair	<i>100</i>	223	<i>250</i>	290	276	322
	1-CATV	<i>100</i>	<i>250</i>	<i>250</i>	350	350	350
	1-100 pair & 1 CATV	<i>100</i>	<i>250</i>	<i>250</i>	350	300	350
	1-600 pair & 1 CATV	<i>100</i>	186	<i>250</i>	283	215	268
3-3/0 & 1/0 N & 3/0 TPX	FPL Only	<i>250</i>	299	350	350	344	350
	FPL With	(2)					
	1-100 pair		<i>150</i>	<i>150</i>	<i>250</i>	276	323
	1-600 pair		<i>150</i>	<i>150</i>	212	201	234
	1-CATV		<i>150</i>	<i>150</i>	<i>250</i>	275	320
	1-100 pair & 1 CATV		<i>150</i>	<i>150</i>	225	214	268
	1-600 pair & 1 CATV		143	<i>150</i>	172	164	190

(1) Span Lengths Shown in *Italic* are Limited by Clearance Criteria

(2) Required clearance cannot be met with Pole length

FPL

DISTRIBUTION ENGINEERING REFERENCE MANUAL

DATE:
 March 21, 2007

PREPARED BY:
 Distribution Product
 Engineering

ADDENDUM FOR EXTREME WIND LOADING

Table 4.2.2-8

Transverse Pole Loading due to Extreme Wind - 105 MPH
 Maximum Span Length in Feet
 Modified Vertical Construction (DCS E-5.0.0)

Conductors		Wood Pole Height and Class					
		40/3	45/3	45/2	50/2	55/2	60/1
3-1/0 & 1/0 N	FPL Only	350	350	350	350	350	350
	FPL With						
	1-100 pair	<i>100</i>	<i>250</i>	<i>250</i>	350	350	350
	1-600 pair	<i>100</i>	<i>250</i>	<i>250</i>	325	311	350
	1-CATV	<i>100</i>	<i>250</i>	<i>250</i>	350	350	350
	1-100 pair & 1 CATV	<i>100</i>	<i>250</i>	<i>250</i>	350	340	350
	1-600 pair & 1 CATV	<i>100</i>	205	<i>250</i>	265	237	295
3-1/0 & 1/0 N & 3/0 TPX	FPL Only	<i>250</i>	348	350	350	350	350
	FPL With	(2)					
	1-100 pair		<i>150</i>	<i>150</i>	<i>250</i>	311	350
	1-600 pair		<i>150</i>	<i>150</i>	232	220	275
	1-CATV		<i>150</i>	<i>150</i>	<i>250</i>	308	350
	1-100 pair & 1 CATV		<i>150</i>	<i>150</i>	<i>250</i>	236	295
	1-600 pair & 1 CATV		<i>150</i>	<i>150</i>	199	189	219
2-1/0 & 1/0 N	FPL Only	350	350	350	350	350	350
	FPL With						
	1-100 pair	<i>150</i>	350	350	350	350	350
	1-600 pair	<i>150</i>	290	350	350	333	350
	1-CATV	<i>150</i>	350	350	350	350	350
	1-100 pair & 1 CATV	<i>150</i>	322	350	350	350	350
	1-600 pair & 1 CATV	<i>150</i>	214	301	284	266	308
2-1/0 & 1/0 N & 3/0 TPX	FPL Only	<i>300</i>	350	350	350	350	350
	FPL With	(2)					
	1-100 pair		<i>200</i>	<i>200</i>	<i>300</i>	333	350
	1-600 pair		198	<i>200</i>	262	229	285
	1-CATV		<i>200</i>	<i>200</i>	<i>300</i>	331	350
	1-100 pair & 1 CATV		<i>200</i>	<i>200</i>	281	265	308
	1-600 pair & 1 CATV		167	<i>200</i>	204	193	224
1-1/0 & 1/0 N	FPL Only	350	350	350	350	350	350
	FPL With						
	1-100 pair	<i>250</i>	350	350	350	350	350
	1-600 pair	<i>250</i>	306	350	350	350	350
	1-CATV	<i>250</i>	350	350	350	350	350
	1-100 pair & 1 CATV	<i>250</i>	345	350	350	350	350
	1-600 pair & 1 CATV	235	218	307	291	274	317
1-1/0 & 1/0 N & 3/0 TPX	FPL Only	350	350	350	350	350	350
	FPL With						
	1-100 pair	<i>150</i>	<i>250</i>	<i>250</i>	<i>300</i>	350	350
	1-600 pair	<i>150</i>	202	<i>250</i>	268	234	294
	1-CATV	<i>150</i>	<i>250</i>	<i>250</i>	<i>300</i>	350	350
	1-100 pair & 1 CATV	<i>150</i>	220	<i>250</i>	290	273	317
	1-600 pair & 1 CATV	<i>150</i>	168	219	207	194	226

(1) Span Lengths Shown in *Italic* are Limited by Clearance Criteria

(2) Required clearance cannot be met with Pole length

FPL

DISTRIBUTION ENGINEERING REFERENCE MANUAL

DATE:
 March 21, 2007

PREPARED BY:
 Distribution Product
 Engineering

ADDENDUM FOR EXTREME WIND LOADING

Table 4.2.2-8

Transverse Pole Loading due to Extreme Wind - 105 MPH
 Maximum Span Length in Feet
 Modified Vertical Construction (DCS E-5.0.0)

Conductors	Attachments	SQUARE CONCRETE POLE HEIGHT AND CLASS				
		45IIIG	45IIIH	50IIIH	55IIIH	60IIIH
3-568 & 3/0 N	FPL Only	274	350	350	350	350
	FPL With					
	1-100 pair	208	<i>100</i>	<i>250</i>	350	350
	1-600 pair	165	<i>100</i>	<i>250</i>	305	289
	1-CATV	206	<i>100</i>	<i>250</i>	350	350
	1-100 pair & 1 CATV	176	<i>100</i>	<i>250</i>	325	307
	1-600 pair & 1 CATV	144	<i>100</i>	<i>250</i>	266	235
	FPL Only	192	<i>250</i>	<i>300</i>	350	339
3-568 & 3/0 N & 3/0 TPX	FPL With	(2)	(2)			
	1-100 pair			<i>150</i>	<i>250</i>	289
	1-600 pair			<i>150</i>	237	223
	1-CATV			<i>150</i>	<i>250</i>	287
	1-100 pair & 1 CATV			<i>150</i>	<i>250</i>	235
	1-600 pair & 1 CATV			<i>150</i>	211	200
	FPL Only	350	350	350	350	350
3-3/0 & 1/0 N	FPL With					
	1-100 pair	<i>200</i>	<i>100</i>	<i>300</i>	<i>350</i>	<i>350</i>
	1-600 pair	<i>200</i>	<i>100</i>	<i>300</i>	<i>350</i>	<i>350</i>
	1-CATV	<i>200</i>	<i>100</i>	<i>300</i>	<i>350</i>	<i>350</i>
	1-100 pair & 1 CATV	<i>200</i>	<i>100</i>	<i>300</i>	<i>350</i>	<i>350</i>
	1-600 pair & 1 CATV	187	<i>100</i>	<i>300</i>	<i>350</i>	325
	FPL Only	297	<i>250</i>	350	350	350
3-3/0 & 1/0 N & 3/0 TPX	FPL With		(2)			
	1-100 pair	<i>100</i>		<i>150</i>	<i>250</i>	350
	1-600 pair	<i>100</i>		<i>150</i>	<i>250</i>	305
	1-CATV	<i>100</i>		<i>150</i>	<i>250</i>	350
	1-100 pair & 1 CATV	<i>100</i>		<i>150</i>	<i>250</i>	325
	1-600 pair & 1 CATV	<i>100</i>		<i>150</i>	<i>250</i>	266
	FPL Only	350	350	350	350	350
3-1/0 & 1/0 N	FPL With					
	1-100 pair	<i>200</i>	<i>100</i>	<i>300</i>	350	350
	1-600 pair	<i>200</i>	<i>100</i>	<i>300</i>	350	350
	1-CATV	<i>200</i>	<i>100</i>	<i>300</i>	350	350
	1-100 pair & 1 CATV	<i>200</i>	<i>100</i>	<i>300</i>	350	350
	1-600 pair & 1 CATV	<i>200</i>	<i>100</i>	<i>300</i>	350	350
	FPL Only	350	<i>250</i>	350	350	350
3-1/0 & 1/0 N & 3/0 TPX	FPL With		(2)			
	1-100 pair	<i>100</i>		<i>150</i>	<i>250</i>	350
	1-600 pair	<i>100</i>		<i>150</i>	<i>250</i>	350
	1-CATV	<i>100</i>		<i>150</i>	<i>250</i>	350
	1-100 pair & 1 CATV	<i>100</i>		<i>150</i>	<i>250</i>	350
	1-600 pair & 1 CATV	<i>100</i>		<i>150</i>	<i>250</i>	297

(1) Span Lengths Shown in *Italic* are Limited by Clearance Criteria
 (2) Required clearance cannot be met with Pole length

FPL

DISTRIBUTION ENGINEERING REFERENCE MANUAL

DATE:
 March 21, 2007

PREPARED BY:
 Distribution Product
 Engineering

ADDENDUM FOR EXTREME WIND LOADING

Table 4.2.2-8

Transverse Pole Loading due to Extreme Wind - 105 MPH
 Maximum Span Length in Feet
 Modified Vertical Construction (DCS E-5.0.0)

Conductors	Attachments	SPUN CONCRETE POLE HEIGHT AND CLASS			
		50' 4.7kip	55' 4.7kip	60' 5kip	65' 5kip
3-568 & 3/0 N	FPL Only	350	350	350	350
	FPL With				
	1-100 pair	<i>250</i>	350	350	350
	1-600 pair	<i>250</i>	350	350	350
	1-CATV	<i>250</i>	350	350	350
	1-100 pair & 1 CATV	<i>250</i>	350	350	350
1-600 pair & 1 CATV	<i>250</i>	333	339	321	
	FPL Only	350	350	350	350
3-568 & 3/0 N & 3/0 TPX	FPL With				
	1-100 pair	<i>150</i>	<i>250</i>	<i>300</i>	350
	1-600 pair	<i>150</i>	<i>250</i>	<i>300</i>	305
	1-CATV	<i>150</i>	<i>250</i>	<i>300</i>	350
	1-100 pair & 1 CATV	<i>150</i>	<i>250</i>	<i>300</i>	321
	1-600 pair & 1 CATV	<i>150</i>	<i>250</i>	288	272
	FPL Only	350	350	350	350
3-3/0 & 1/0 N	FPL With				
	1-100 pair	<i>300</i>	350	350	350
	1-600 pair	<i>300</i>	350	350	350
	1-CATV	<i>300</i>	350	350	350
	1-100 pair & 1 CATV	<i>300</i>	350	350	350
	1-600 pair & 1 CATV	<i>300</i>	429	438	411
	FPL Only	350	350	350	350
3-3/0 & 1/0 N & 3/0 TPX	FPL With				
	1-100 pair	<i>150</i>	<i>250</i>	<i>350</i>	350
	1-600 pair	<i>150</i>	<i>250</i>	<i>350</i>	350
	1-CATV	<i>150</i>	<i>250</i>	<i>350</i>	350
	1-100 pair & 1 CATV	<i>150</i>	<i>250</i>	<i>350</i>	350
	1-600 pair & 1 CATV	<i>150</i>	<i>250</i>	<i>350</i>	334
	FPL Only	350	350	350	350
3-350 CU & 2/0 CU N	FPL With				
	1-100 pair	<i>250</i>	350	350	350
	1-600 pair	<i>250</i>	350	350	350
	1-CATV	<i>250</i>	350	350	350
	1-100 pair & 1 CATV	<i>250</i>	350	350	350
	1-600 pair & 1 CATV	<i>250</i>	350	350	350
	FPL Only	350	350	350	350
3-350 CU & 2/0 CU N & 3/0 TPX	FPL With				
	1-100 pair	<i>200</i>	<i>250</i>	<i>350</i>	350
	1-600 pair	<i>200</i>	<i>250</i>	<i>350</i>	343
	1-CATV	<i>200</i>	<i>250</i>	<i>350</i>	350
	1-100 pair & 1 CATV	<i>200</i>	<i>250</i>	<i>350</i>	350
	1-600 pair & 1 CATV	<i>200</i>	<i>250</i>	323	302

- (1) Span Lengths Shown in *Italic* are Limited by Clearance Criteria
 (2) Required clearance cannot be met with Pole length

FPL

DISTRIBUTION ENGINEERING REFERENCE MANUAL

DATE:
 March 21, 2007

PREPARED BY:
 Distribution Product
 Engineering

ADDENDUM FOR EXTREME WIND LOADING

Table 4.2.2-9

Transverse Pole Loading due to Extreme Wind - 130 MPH
 Maximum Span Length in Feet
 Modified Vertical Construction (DCS E-5.0.0)

Conductors	Attachments	WOOD POLE HEIGHT AND CLASS					
		40/3	45/3	45/2	50/2	55/2	60/1
3-568 & 3/0 N	FPL Only	162	151	201	183	170	200
	FPL With						
	1-100 pair	<i>100</i>	122	162	147	137	160
	1-600 pair	<i>100</i>	95	127	115	107	125
	1-CATV	<i>100</i>	121	161	146	136	159
	1-100 pair & 1 CATV	<i>100</i>	102	135	123	114	133
	1-600 pair & 1 CATV	91	83	111	100	94	108
3-568 & 3/0 N & 3/0 TPX	FPL Only	122	112	149	137	126	148
	FPL With	(2)					
	1-100 pair		95	127	116	107	125
	1-600 pair		79	105	96	89	104
	1-CATV		95	126	116	107	124
	1-100 pair & 1 CATV		83	110	101	93	108
3-3/0 & 1/0 N	FPL Only	295	274	364	333	308	350
	FPL With						
	1-100 pair	<i>100</i>	181	<i>250</i>	219	203	237
	1-600 pair	<i>100</i>	128	171	155	145	167
	1-CATV	<i>100</i>	179	<i>250</i>	216	201	234
	1-100 pair & 1 CATV	<i>100</i>	140	186	168	158	182
3-3/0 & 1/0 N & 3/0 TPX	FPL Only	175	161	214	198	181	211
	FPL With	(2)					
	1-100 pair		128	171	157	145	168
	1-600 pair		101	134	122	113	131
	1-CATV		127	169	156	143	166
	1-100 pair & 1 CATV		106	143	130	121	139
3-1/0 & 1/0 N	FPL Only	350	350	350	350	350	350
	FPL With						
	1-100 pair	<i>100</i>	214	<i>250</i>	278	258	301
	1-600 pair	<i>100</i>	144	193	174	163	188
	1-CATV	<i>100</i>	211	<i>250</i>	275	256	297
	1-100 pair & 1 CATV	<i>100</i>	159	212	191	180	207
	1-600 pair & 1 CATV	<i>100</i>	118	158	142	133	153

(1) Span Lengths Shown in *Italic* are Limited by Clearance Criteria

(2) Required clearance cannot be met with Pole length

FPL

DISTRIBUTION ENGINEERING REFERENCE MANUAL

DATE:
 March 21, 2007

PREPARED BY:
 Distribution Product
 Engineering

ADDENDUM FOR EXTREME WIND LOADING

Table 4.2.2-9

Transverse Pole Loading due to Extreme Wind - 130 MPH
 Maximum Span Length in Feet
 Modified Vertical Construction (DCS E-5.0.0)

Conductors	Attachments	WOOD POLE HEIGHT AND CLASS					
		40/3	45/3	45/2	50/2	55/2	60/1
3-1/0 & 1/0 N & 3/0 TPX	FPL Only	203 (2)	186	267	230	211	264
	FPL With						
	1-100 pair		144	<i>150</i>	177	163	189
	1-600 pair		110	146	134	124	143
	1-CATV		143	<i>150</i>	175	162	187
	1-100 pair & 1 CATV		118	<i>150</i>	143	133	153
	1-600 pair & 1 CATV		94	126	114	106	123
2-1/0 & 1/0 N	FPL Only	350	350	350	350	350	350
	FPL With						
	1-100 pair	<i>200</i>	265	<i>350</i>	325	298	348
	1-600 pair	170	155	206	192	175	202
	1-CATV	<i>200</i>	261	347	318	294	340
	1-100 pair & 1 CATV	189	172	230	213	195	225
	1-600 pair & 1 CATV	136	123	163	153	139	161
2-1/0 & 1/0 N & 3/0 TPX	FPL Only	226 (2)	208	298	276	236	296
	FPL With						
	1-100 pair		155	<i>200</i>	191	175	203
	1-600 pair		114	151	142	129	149
	1-CATV		153	204	189	173	201
	1-100 pair & 1 CATV		123	163	151	139	161
	1-600 pair & 1 CATV		96	128	118	109	125
1-1/0 & 1/0 N	FPL Only	350	350	350	350	350	350
	FPL With						
	1-100 pair	<i>250</i>	308	<i>350</i>	<i>350</i>	349	<i>350</i>
	1-600 pair	179	163	218	202	186	216
	1-CATV	<i>250</i>	348	<i>350</i>	<i>350</i>	<i>350</i>	<i>350</i>
	1-100 pair & 1 CATV	222	203	292	271	232	288
	1-600 pair & 1 CATV	147	134	179	166	153	177
1-1/0 & 1/0 N & 3/0 TPX	FPL Only	274	257	341	309	285	333
	FPL With						
	1-100 pair	<i>150</i>	166	221	202	187	217
	1-600 pair	126	117	156	143	132	153
	1-CATV	<i>150</i>	178	<i>250</i>	217	200	233
	1-100 pair & 1 CATV	146	135	181	166	152	177
	1-600 pair & 1 CATV	110	102	135	125	115	133

(1) Span Lengths Shown in *Italic* are Limited by Clearance Criteria
 (2) Required clearance cannot be met with Pole length

FPL

DISTRIBUTION ENGINEERING REFERENCE MANUAL

DATE:
 March 21, 2007

PREPARED BY:
 Distribution Product
 Engineering

ADDENDUM FOR EXTREME WIND LOADING

Table 4.2.2-9

Transverse Pole Loading due to Extreme Wind - 130 MPH
 Maximum Span Length in Feet
 Modified Vertical Construction (DCS E-5.0.0)

Conductors	Attachments	SQUARE CONCRETE POLE HEIGHT AND CLASS				
		45IIIH	45IIIH	50IIIH	55IIIH	60IIIH
3-568 & 3/0 N	FPL Only	143	308	290	268	227
	FPL With					
	1-100 pair	115	<i>100</i>	216	200	182
	1-600 pair	90	<i>100</i>	170	156	143
	1-CATV	114	<i>100</i>	215	198	181
	1-100 pair & 1 CATV	96	<i>100</i>	181	166	153
	1-600 pair & 1 CATV	79	<i>100</i>	148	136	125
3-568 & 3/0 N & 3/0 TPX	FPL Only	105	213	200	186	169
	FPL With	(2)	(2)			
	1-100 pair			<i>150</i>	158	143
	1-600 pair			141	130	119
	1-CATV			<i>150</i>	157	143
	1-100 pair & 1 CATV			147	137	124
3-3/0 & 1/0 N	1-600 pair & 1 CATV			125	116	106
	FPL Only	259	350	350	350	350
	FPL With					
	1-100 pair	171	<i>100</i>	<i>300</i>	318	291
	1-600 pair	123	<i>100</i>	228	210	194
	1-CATV	169	<i>100</i>	<i>300</i>	314	287
	1-100 pair & 1 CATV	133	<i>100</i>	267	228	210
1-600 pair & 1 CATV	103	<i>100</i>	190	174	162	
3-3/0 & 1/0 N & 3/0 TPX	FPL Only	152	<i>150</i>	308	286	259
	FPL With	(2)	(2)			
	1-100 pair			<i>150</i>	213	194
	1-600 pair			<i>150</i>	165	151
	1-CATV			<i>150</i>	211	192
	1-100 pair & 1 CATV			<i>150</i>	176	161
3-1/0 & 1/0 N	1-600 pair & 1 CATV			<i>150</i>	143	131
	FPL Only	332	350	350	350	350
	FPL With					
	1-100 pair	<i>200</i>	<i>100</i>	<i>300</i>	350	345
	1-600 pair	138	<i>100</i>	277	236	218
	1-CATV	200	<i>100</i>	<i>300</i>	350	340
	1-100 pair & 1 CATV	151	<i>100</i>	<i>300</i>	280	257
1-600 pair & 1 CATV	113	<i>100</i>	210	192	178	
3-1/0 & 1/0 N & 3/0 TPX	FPL Only	177	<i>250</i>	350	334	302
	FPL With	(2)	(2)			
	1-100 pair			<i>150</i>	<i>250</i>	218
	1-600 pair			<i>150</i>	181	166
	1-CATV			<i>150</i>	237	216
	1-100 pair & 1 CATV			<i>150</i>	194	178
1-600 pair & 1 CATV			<i>150</i>	155	143	

(1) Span Lengths Shown in *Italic* are Limited by Clearance Criteria
 (2) Required clearance cannot be met with Pole length

FPL

DISTRIBUTION ENGINEERING REFERENCE MANUAL

DATE:
 March 21, 2007

PREPARED BY:
 Distribution Product
 Engineering

ADDENDUM FOR EXTREME WIND LOADING

Table 4.2.2-9

Transverse Pole Loading due to Extreme Wind - 130 MPH
 Maximum Span Length in Feet
 Modified Vertical Construction (DCS E-5.0.0)

Conductors	Attachments	SPUN CONCRETE POLE HEIGHT AND CLASS			
		50' 4.7kip	55' 4.7kip	60' 5kip	65' 5kip
3-568 & 3/0 N	FPL Only	350	350	350	337
	FPL With				
	1-100 pair	<i>250</i>	294	289	270
	1-600 pair	223	214	213	197
	1-CATV	<i>250</i>	292	287	268
	1-100 pair & 1 CATV	<i>250</i>	227	225	209
	1-600 pair & 1 CATV	195	185	185	170
3-568 & 3/0 N & 3/0 TPX	FPL Only	284	274	269	232
	FPL With				
	1-100 pair	<i>150</i>	216	213	197
	1-600 pair	<i>150</i>	178	176	162
	1-CATV	<i>150</i>	215	211	196
	1-100 pair & 1 CATV	<i>150</i>	187	184	170
	1-600 pair & 1 CATV	<i>150</i>	159	158	144
3-3/0 & 1/0 N	FPL Only	350	350	350	350
	FPL With				
	1-100 pair	<i>300</i>	350	350	350
	1-600 pair	<i>300</i>	310	307	282
	1-CATV	<i>300</i>	350	350	350
	1-100 pair & 1 CATV	<i>300</i>	336	333	307
	1-600 pair & 1 CATV	270	257	256	219
3-3/0 & 1/0 N & 3/0 TPX	FPL Only	350	350	350	350
	FPL With				
	1-100 pair	<i>150</i>	<i>250</i>	307	283
	1-600 pair	<i>150</i>	226	224	205
	1-CATV	<i>150</i>	<i>250</i>	305	280
	1-100 pair & 1 CATV	<i>150</i>	<i>250</i>	256	219
	1-600 pair & 1 CATV	<i>150</i>	196	195	178
3-350 CU & 2/0 CU N	FPL Only	350	350	350	350
	FPL With				
	1-100 pair	<i>250</i>	350	350	328
	1-600 pair	<i>250</i>	267	266	228
	1-CATV	<i>250</i>	350	350	325
	1-100 pair & 1 CATV	<i>250</i>	287	284	263
	1-600 pair & 1 CATV	221	211	211	194
3-350 CU & 2/0 CU N & 3/0 TPX	FPL Only	339	328	321	298
	FPL With				
	1-100 pair	<i>200</i>	<i>250</i>	266	228
	1-600 pair	<i>200</i>	201	200	183
	1-CATV	<i>200</i>	<i>250</i>	262	226
	1-100 pair & 1 CATV	<i>200</i>	213	210	194
	1-600 pair & 1 CATV	184	177	176	161

(1) Span Lengths Shown in *Italic* are Limited by Clearance Criteria

(2) Required clearance cannot be met with Pole length

FPL

DISTRIBUTION ENGINEERING REFERENCE MANUAL

DATE:
 March 21, 2007

PREPARED BY:
 Distribution Product
 Engineering

ADDENDUM FOR EXTREME WIND LOADING

Table 4.2.2-10

Transverse Pole Loading due to Extreme Wind - 145 MPH
 Maximum Span Length in Feet
 Modified Vertical Construction (DCS E-5.0.0)

Conductors		Wood Pole Height and Class					
		40/3	45/3	45/2	50/2	55/2	60/1
3-568 ACAR & 3/0 AAAC-N	FPL Only	121	110	150	134	122	143
	FPL With						
	1-100 pair	98	88	121	107	98	114
	1-600 pair	78	69	94	84	77	88
	1-CATV	97	87	120	106	97	113
	1-100 pair & 1 CATV	83	74	101	89	82	94
1-600 pair & 1 CATV	68	61	83	73	67	77	
3-568 ACAR & 3/0 AAAC-N & 3/0 TPX	FPL Only	90	82	111	100	90	105
	FPL With	(2)					
	1-100 pair		69	94	85	77	89
	1-600 pair		57	78	69	64	73
	1-CATV		69	94	85	76	88
	1-100 pair & 1 CATV		61	82	73	67	77
1-600 pair & 1 CATV		51	70	62	57	66	
3-3/0 & 1/0 N	FPL Only	203	186	272	226	205	257
	FPL With						
	1-100 pair	146	131	179	160	145	168
	1-600 pair	105	93	127	113	104	119
	1-CATV	144	130	177	158	143	166
	1-100 pair & 1 CATV	114	102	138	123	113	129
1-600 pair & 1 CATV	88	78	106	94	86	99	
3-3/0 & 1/0 N & 3/0 TPX	FPL Only	130	117	159	143	130	150
	FPL With	(2)					
	1-100 pair		93	127	114	104	120
	1-600 pair		73	100	88	81	93
	1-CATV		93	126	113	103	119
	1-100 pair & 1 CATV		78	105	95	86	99
1-600 pair & 1 CATV		64	86	77	70	81	

(1) Span Lengths Shown in *Italic* are Limited by Clearance Criteria

(2) Required clearance cannot be met with Pole length

FPL

DISTRIBUTION ENGINEERING REFERENCE MANUAL

DATE:
 March 21, 2007

PREPARED BY:
 Distribution Product
 Engineering

ADDENDUM FOR EXTREME WIND LOADING

Table 4.2.2-10

Transverse Pole Loading due to Extreme Wind - 145 MPH
 Maximum Span Length in Feet
 Modified Vertical Construction (DCS E-5.0.0)

Conductors		Wood Pole Height and Class					
		40/3	45/3	45/2	50/2	55/2	60/1
3-1/0 & 1/0 N	FPL Only	282	256	348	311	282	330
	FPL With						
	1-100 pair	<i>100</i>	156	212	188	173	200
	1-600 pair	<i>100</i>	105	143	126	117	134
	1-CATV	<i>100</i>	154	209	186	170	197
	1-100 pair & 1 CATV	<i>100</i>	116	157	140	128	146
	1-600 pair & 1 CATV	98	86	117	104	95	108
3-1/0 & 1/0 N & 3/0 TPX	FPL Only	151	136	184	167	151	174
	FPL With	(2)					
	1-100 pair		105	143	128	117	134
	1-600 pair		80	108	97	89	102
	1-CATV		105	142	127	116	133
	1-100 pair & 1 CATV		86	117	105	95	108
	1-600 pair & 1 CATV		68	93	84	76	86
2-1/0 & 1/0 N	FPL Only	350	334	350	350	350	350
	FPL With						
	1-100 pair	200	180	262	220	199	230
	1-600 pair	126	113	153	140	125	143
	1-CATV	196	177	258	217	195	226
	1-100 pair & 1 CATV	141	125	170	155	140	161
	1-600 pair & 1 CATV	101	89	122	111	100	114
2-1/0 & 1/0 N & 3/0 TPX	FPL Only	168	152	206	187	169	196
	FPL With	(2)					
	1-100 pair		113	153	140	125	144
	1-600 pair		83	112	103	92	105
	1-CATV		111	151	138	124	143
	1-100 pair & 1 CATV		89	122	110	100	114
	1-600 pair & 1 CATV		70	95	86	78	89
1-1/0 & 1/0 N	FPL Only	350	350	350	350	350	350
	FPL With						
	1-100 pair	231	208	305	276	232	288
	1-600 pair	133	119	162	147	133	154
	1-CATV	226	203	297	270	227	282
	1-100 pair & 1 CATV	150	135	182	167	151	174
	1-600 pair & 1 CATV	103	91	124	114	103	118
1-1/0 & 1/0 N & 3/0 TPX	FPL Only	188	174	237	210	191	221
	FPL With						
	1-100 pair	133	122	164	147	134	154
	1-600 pair	94	86	116	105	94	108
	1-CATV	131	120	162	146	132	152
	1-100 pair & 1 CATV	103	92	125	114	103	118
	1-600 pair & 1 CATV	78	70	96	87	78	90

(1) Span Lengths Shown in *Italic* are Limited by Clearance Criteria

(2) Required clearance cannot be met with Pole length

FPL

DISTRIBUTION ENGINEERING REFERENCE MANUAL

DATE:
 March 21, 2007

PREPARED BY:
 Distribution Product
 Engineering

ADDENDUM FOR EXTREME WIND LOADING

Table 4.2.2-10

Transverse Pole Loading due to Extreme Wind - 145 MPH
 Maximum Span Length in Feet
 Modified Vertical Construction (DCS E-5.0.0)

Conductors	Attachments	SQUARE CONCRETE POLE HEIGHT AND CLASS				
		45III G	45III H	50III H	55III H	60III H
3-568 & 3/0 N	FPL Only	99	209	193	174	154
	FPL With					
	1-100 pair	80	<i>100</i>	155	139	124
	1-600 pair	63	<i>100</i>	122	109	97
	1-CATV	79	<i>100</i>	154	138	123
	1-100 pair & 1 CATV	67	<i>100</i>	129	116	104
	1-600 pair & 1 CATV	55	<i>100</i>	105	95	85
	FPL Only	73	157	143	130	114
3-568 & 3/0 N & 3/0 TPX	FPL With	(2)	(2)			
	1-100 pair			122	110	97
	1-600 pair			101	90	81
	1-CATV			121	109	97
	1-100 pair & 1 CATV			105	95	85
	1-600 pair & 1 CATV			90	81	72
	FPL Only	167	350	349	314	278
3-3/0 & 1/0 N	FPL With					
	1-100 pair	119	<i>100</i>	230	206	184
	1-600 pair	85	<i>100</i>	163	146	131
	1-CATV	118	<i>100</i>	227	204	181
	1-100 pair & 1 CATV	92	<i>100</i>	178	159	143
	1-600 pair & 1 CATV	71	<i>100</i>	136	122	109
	FPL Only	105	225	204	186	164
3-3/0 & 1/0 N & 3/0 TPX	FPL With	(2)	(2)			
	1-100 pair			<i>150</i>	148	131
	1-600 pair			127	115	103
	1-CATV			<i>150</i>	147	130
	1-100 pair & 1 CATV			136	123	109
	1-600 pair & 1 CATV			111	100	89
	FPL Only	214	350	350	350	350
3-1/0 & 1/0 N	FPL With					
	1-100 pair	142	<i>100</i>	294	264	219
	1-600 pair	96	<i>100</i>	184	164	147
	1-CATV	140	<i>100</i>	290	260	215
	1-100 pair & 1 CATV	105	<i>100</i>	202	181	162
	1-600 pair & 1 CATV	79	<i>100</i>	150	134	121
	FPL Only	123	250	257	218	191
3-1/0 & 1/0 N & 3/0 TPX	FPL With		(2)			
	1-100 pair	96		<i>150</i>	167	147
	1-600 pair	73		140	126	112
	1-CATV	95		150	165	146
	1-100 pair & 1 CATV	78		150	135	121
	1-600 pair & 1 CATV	63		121	108	96

(1) Span Lengths Shown in *Italic* are Limited by Clearance Criteria

(2) Required clearance cannot be met with Pole length

FPL

DISTRIBUTION ENGINEERING REFERENCE MANUAL

DATE:
 March 21, 2007

PREPARED BY:
 Distribution Product
 Engineering

ADDENDUM FOR EXTREME WIND LOADING

Table 4.2.2-10

Transverse Pole Loading due to Extreme Wind - 145 MPH
 Maximum Span Length in Feet
 Modified Vertical Construction (DCS E-5.0.0)

Conductors	Attachments	SPUN CONCRETE POLE HEIGHT AND CLASS			
		50' 4.7kip	55' 4.7kip	60' 5kip	65' 5kip
3-568 & 3/0 N	FPL Only	291	276	267	227
	FPL With				
	1-100 pair	217	205	200	181
	1-600 pair	170	161	157	143
	1-CATV	215	203	198	181
	1-100 pair & 1 CATV	181	171	166	151
	1-600 pair & 1 CATV	148	140	137	124
3-568 & 3/0 N & 3/0 TPX	FPL Only	200	192	184	168
	FPL With				
	1-100 pair	<i>150</i>	162	157	143
	1-600 pair	141	134	130	118
	1-CATV	<i>150</i>	162	156	142
	1-100 pair & 1 CATV	147	141	137	124
	1-600 pair & 1 CATV	125	120	116	105
3-3/0 & 1/0 N	FPL Only	350	350	350	350
	FPL With				
	1-100 pair	<i>300</i>	328	317	288
	1-600 pair	229	217	212	191
	1-CATV	<i>300</i>	324	314	285
	1-100 pair & 1 CATV	267	235	230	207
	1-600 pair & 1 CATV	191	180	177	158
3-3/0 & 1/0 N & 3/0 TPX	FPL Only	309	296	283	257
	FPL With				
	1-100 pair	<i>150</i>	219	212	191
	1-600 pair	<i>150</i>	170	165	148
	1-CATV	<i>150</i>	218	210	189
	1-100 pair & 1 CATV	<i>150</i>	181	176	158
	1-600 pair & 1 CATV	<i>150</i>	147	143	128
3-350 CU & 2/0 CU N	FPL Only	350	350	341	313
	FPL With				
	1-100 pair	<i>250</i>	269	259	220
	1-600 pair	198	187	182	165
	1-CATV	<i>250</i>	266	257	219
	1-100 pair & 1 CATV	212	200	196	177
	1-600 pair & 1 CATV	168	159	156	140
3-350 CU & 2/0 CU N & 3/0 TPX	FPL Only	257	230	220	200
	FPL With				
	1-100 pair	198	189	182	165
	1-600 pair	159	151	147	132
	1-CATV	196	187	181	164
	1-100 pair & 1 CATV	168	161	156	140
	1-600 pair & 1 CATV	141	133	130	116

- (1) Span Lengths Shown in *Italic* are Limited by Clearance Criteria
- (2) Required clearance cannot be met with Pole length

PREPARED BY:
 Distribution Product
 Engineering

ADDENDUM FOR EXTREME WIND LOADING

C. Storm Guying

One method to overcome the overload on a pole due to transverse wind load is to add storm guys. Storm guys are installed in pairs(back to back) – one on each side of the pole perpendicular to the pole line. These guys should typically be installed 6 inches to 2 feet below the primary attachments.

Calculating the size of the guy wire is very much like calculating a deadend guy.

1. Calculate the transverse wind load on the pole, conductors and all attachments and equipment.
2. The load is then used to size the guy wire based on the load, the attachment height and lead length.
3. A final check should be made to verify that the strength of the pole above the guy attachment is adequate.

Using the example of Case I above for the 45'2 pole, calculate the size of the storm guys and anchors required for extreme wind loading.

1. Transverse wind loads:

Pole	=	Wind load on pole
Primary conductors	=	Wind Load per ft x span length x number of
Neutral	=	Wind Load per ft x span length
CATV	=	Wind Load per ft x span length
Telephone	=	Wind Load per ft x span length
Transformer	=	Wind Load

Load on Pole	=				1713 pounds
Primary	=	3.816 x 170 x 3	=	1946 pounds	
Neutral	=	2.094 x 170 x 1	=	356 pounds	
CATV	=	4.171 x 170 x 1	=	709 pounds	
Telephone	=	9.573 x 170 x 1	=	1627 pounds	
Transformer	=	231.8 x 1	=	232 pounds	
		Total Load	=	6583 pounds	

2. Determine the guy wire size and anchor size required for this installation.

To calculate the tension in the guy wire use the equation below

Equation 4.2.2-7
$$T_{DG} = \frac{T_{TWL}}{L} \times \sqrt{H_G^2 + L^2}$$

PREPARED BY:
 Distribution Product
 Engineering

ADDENDUM FOR EXTREME WIND LOADING

Where:

- T_{DG} = Tension in down guy
- T_{TWL} = Transverse Wind Load
- L = The down guy Lead length
- H_G = The attachment Height of the down guy

Use the total transverse wind load for the load to be guyed with the guy attached 6 inches below C phase primary (34.1') and a lead length of 20 feet.

$$T_{DG} = \frac{6583}{20} \sqrt{(34.1)^2 + (20)^2}$$

$$T_{DG} = 13,013 \text{ Pounds}$$

For extreme wind loading, the required strength of the guy wire is equal to the rated breaking strength of the guy wire x 0.9.

Table 4.2.2-11 Storm Guy Strength

Guy Size	Rated Breaking Strength (RBS)	Allowable Guy Tension .9 X RBS
5/16	11200	10080
7/16	20800	18720
9/16	33700	30330

For this example, a 7/16" guy will be installed in each direction perpendicular to the pole line. Use the tension in the down guy to select the appropriate anchor from DCS D-4.0.2. In this case, a 10" screw anchor will do the job.

3. One final check is to be sure that the pole length above the storm guy attachment has sufficient strength to support the load above it. Basically, this is just like calculating the strength of the total pole but now the "ground line" is at the storm guy attachment height and all of the facilities above this point will create a moment here.

With the top of the pole at 38' and the down guy at 34.1 feet, the length of pole exposed to the wind is now 38-34.1 = 3.9 ft.

Use equation 4.2.2-3 to determine the strength of this section of pole.

PREPARED BY:
 Distribution Product
 Engineering

ADDENDUM FOR EXTREME WIND LOADING

From Table G (DERM 4.2.2) circumference at 3.9 feet down from the top of the pole = 26.5 inches

$$M_r = 0.000264 \times (8,000) \times (26.5)^3 \times 0.75 = 29,478 \text{ ft.-lbs.}$$

Use equation 4.2.2-4 to find the area of this section of pole

$$A = 3.9 \left(\frac{25 + 26.5}{2} \right) \left(\frac{1}{12} \right) = 2.66 \text{ sqft}$$

Use equation 4.2.2-5 to find the center of the area of this section of pole

$$\text{Height of center of area, } H_{CA} = \frac{3.9(8.44 + 2(7.96))}{3(8.44 + 7.96)} = 1.93 \text{ ft}$$

Use equation 4.2.2-2 to find the wind load on this section of pole

$$\text{Load in pounds} = 0.00256 \times (145)^2 \times 1.0 \times 0.97 \times 1 \times 1 \times 2.66 = 139 \text{ pounds}$$

Use equation 4.2.2-6 to determine the moment due to the wind load on this section of the pole at the guy attachment point

$$\text{Moment} = 1.93 \times 139 = 269 \text{ ft lbs}$$

Determine the moment created by the wind load on the conductors

Primary	=	3.816	x	170	x	1	x	4.9	=	3179	Ft-Lbs
	=	3.816	x	170	x	1	x	2.5	=	1622	Ft-Lbs
	=	3.816	x	170	x	1	x	0.5	=	324	Ft-Lbs
										5125	Ft-Lbs

$$\text{Total Moment} = 269 + 5125 = 5393 \text{ Ft-Lbs}$$

This load is well under the strength calculated above and the design using storm guys will meet requirements.

PREPARED BY:
 Distribution Product
 Engineering

ADDENDUM FOR EXTREME WIND LOADING

4.2.3 Pole Framing

A. Slack Span Construction

Slack span construction is employed where it is impractical to follow conventional guying practices. The proper application is a pull-off from either a tangent pole or a properly guyed deadend pole to another properly guyed deadend pole. The intent is not to slack span to a stand alone (self-support) pole unless that pole has been properly sized for this application. Improper use of slack span construction can cause a pole to bow or lean which then can cause more slack in the conductors. More slack in the conductors can result in improper clearances and increased potential for conductors to make contact with each other.

DERM 4.4.5 page 1 shows the initial sag to be used when installing slack spans. The amount of sag shown, limits the per conductor tension to 50 pounds.

Slack Span design criteria:

1. Vertical construction is preferred for two and three phase installations (DCS E-5.7.1).
 Maintain 36" separation between phases at the poles.
2. Limit the span lengths to

Table 4.2.2-12 Slack Span Length & Sag

SLACK SPAN		
CONDUCTOR	MAXIMUM LENGTH	INITIAL SAG
568.3 ACAR	50'	3'-7"
3/0 AAAC	75'	2'-9"
1/0 AAAC	95'	2'-10"

3. Use class 2 poles minimum.
4. If crossarm construction is used, use the 9 foot heavy duty wood crossarms or the 8'6" steel crossarm for added horizontal spacing (DCS E-29.0.0 and E-29.1.0).

PREPARED BY:
Distribution Product
Engineering

ADDENDUM FOR EXTREME WIND LOADING

B. Targeted Poles

There are many poles in the distribution system identified as Targeted Poles. These poles are deemed critical by virtue of the equipment mounted on them or their importance to maintaining the system. As stated in The Distribution Design Guide "The following list comprises what will be considered targeted poles. When installing and/or replacing an accessible targeted pole, use a III-H concrete pole or a spun concrete pole for spans greater than 300 feet. If the pole is inaccessible, use a Class 2 pole, or consider relocating the equipment to an accessible concrete pole."

Targeted Pole List

"01" Feeder Switch Poles (first pole outside the substation)
Automated Feeder Switches
Interstate/Highway Crossings
Capacitor Banks
Multiple Primary Risers
3 Phase Reclosers
Aerial Auto Transformers
Multiple Circuits
3 phase Transformer Banks (3-100 kVA and larger)
Regulators
Primary Meter

The targeted pole also should meet the design criteria for wind loading as previously shown.

C. Distribution Design Guidelines

The Storm Secure Organization has developed a set of guidelines for Distribution Designers to use when designing or maintaining distribution facilities. The designer can go online to see the most current version.



Power Systems

Distribution Construction Standards

ADDENDUM TO

DECEMBER 2005 EDITION

(FOR 2007 HARDENING APPLICATIONS)

This book contains the current standards of distribution construction that have been updated to accommodate 'Hardened' installations for Florida Power & Light Company. These standards are updated periodically by the staff of the Distribution Product Engineering and Reliability Engineering departments. Changed or updated standards are denoted with an asterisk () in the table of contents. Non-standard field situations may arise that are not covered by this book. In those instances, please contact the Distribution Product Engineering department at 561 845-4831 for assistance. Current information on individual Product Engineers Responsibilities can be found in IN-FPL under Business Units Power Systems Distribution Reliability Products. This publication is also available in IN-FPL under Business Units Power Systems Reference Information Distribution Manuals Distribution Construction Standards (DCS) Drawings.*


The Power Systems-Distribution Construction Standards are the sole and exclusive property of Florida Power & Light Co (FPL). These standards were developed by FPL to establish uniform standards for construction and equipment applications throughout FPL's electric system.

The Distribution Construction Standards are proprietary business documents and are not to be duplicated or disclosed to any third party without the express written consent of Florida Power & Light Co.


**DISTRIBUTION CONSTRUCTION STANDARDS
 ADDENDUM TO DECEMBER 2005 EDITION**

<u>Section-Page</u>	<u>Title</u>	<u>Description of Revision</u>
C-7.0.0	Single Phase Recloser Three Phase Recloser on Concrete Poles	1 or 2 phases on class 3 and 3 phase on Concrete Pole
C-8.0.0	Poles	3 Phase on concrete poles
C-9.0.4	Distribution Automation Switches	New or Replacement poles to be concrete
C-9.0.5	Distribution Automation Switches	New or Replacement poles to be concrete
C-9.1.0	Commercial/Industrial Load Control	New or Replacement poles to be concrete
C-9.1.1	Wiring Diagram for CILC	New drawing
C-9.2.0	SCADA-MATE Switch	Added notes
C-9.2.1	SCADA-MATE Switch	New page with notes
C-9.2.2	SCADA-MATE Radio Repeater	Update drawing and notes
D-2.0.0	Pole Setting, Guying & Bracing	Revised criteria for guy strain insulators
D-3.0.0	Pole Setting Depths	New setting Depths and Soil Conditions
D-7.0.0	Method of attaching guys	Added spun concrete installation
D-7.0.1	Method of attaching guys	Revised criteria for guy strain insulators
D-13.0.0	Storm Guying	New standard for storm guys
E-3.0.0	Overhead Equipment Dimensions	Add drawing for spun concrete pole
E-5.0.0	Post Insulator Construction	Add insulator bracket for spun concrete pole
E-5.0.2	Installation of Hardware	Add insulator bracket for spun concrete pole
E-5.7.1	Slack Span Construction Vertical	Add table and minimum pole size. Revised note for FGI's
E-6.0.0	Tangent Construction Wood Crossarm	Added note for use of Steel Crossarm
E-6.0.1	Tangent Construction Steel Crossarm	Change for mounting Pole top bracket opposite of steel crossarm
E-8.0.0	Angle Construction Concrete Pole	Change for mounting Pole top bracket opposite of steel crossarm
E-5.29.0.0	Slack Span Construction	Add table and minimum pole size. Revised note for FGI's
E-5.29.1.0	Slack Span Construction Concrete Pole Installation Only	Add table
G-3.0.2	Pole Grounding	Added figure for spun concrete pole
H-4.0.0	Street Light Pole Weights	New setting depths
I-3.2.0	Transformer Pole Weight Loading	Revised Table and added note for New or Replacement Poles for 3-100kVA Transformer Banks to be concrete poles
I-9.0.0	Single Phase Step Down Transformer on URD Terminator Pole	Removed wood pole class
I-10.0.0	Single Phase Line Regulator Installation (Alternate Method)	Removed wood pole class
I-51.0.0	Wye Closed Delta Bank - Modified Vertical	New or Replacement Poles for 3-100kVA and larger Transformer Banks to be concrete poles
I-52.0.0	Wye-Wye Bank Crossarm Construction	New or Replacement Poles for 3-100kVA and larger Transformer Banks to be concrete poles
I-52.0.2	Wye-Wye Bank Modified Vertical Construction	New or Replacement Poles for 3-100kVA and larger Transformer Banks to be concrete poles
J-1.0.2	Capacitor Banks General	New or Replacement poles to be concrete
J-2.0.2	Capacitor Banks Single Phase Units	New or Replacement poles to be concrete
J-2.0.3	Capacitor Banks Single Phase w/Puts	New or Replacement poles to be concrete
K-28.0.0	Outdoor Primary Metering Cluster Mounted Underground Service	Changed to Maintenance Only for underground - use URD primary to pad mounted metering cabinet. Replacement poles to be concrete.
K-28.1.0	Outdoor Primary Metering Cluster Mounted Overhead Service	New or Replacement poles to be concrete
M-2.0.0	Distribution Circuits on Transmission Poles Universal Spun Concrete Pole	Added notes to reflect that no additional holes can be added to a Universal Spun Concrete Transmission Pole
UH-15.0.0	Primary and Feeder Riser Pole	New or Replacement poles to be concrete
UH-15.3.1	Three Phase Feeder Riser	New or Replacement poles to be concrete
Z-12.0.1	Spun Concrete Pole Diameter & weight	New page with spun concrete pole information


Docket No. 070301-E1
FPL Storm Hardening Plan
Exhibit MBM-1 Page 92 of 223




SINGLE PHASE INSTALLATION



TWO PHASE INSTALLATION



THREE PHASE INSTALLATION
(USE CONCRETE POLE)



NOTES:

1. WHERE CUTOUT IS USED AS A BY-PASS SWITCH, FUSE HOLDER SHALL BE REMOVED AND KEPT IN A CONVENIENT LOCATION ON THE POLE, FOR USE WHEN BY-PASSING RECLOSER. FASTEN FUSE HOLDER TO POLE WITH OPEN END OF BARREL DOWN.
2. LARGER RECLOSERS MUST BE PROPERLY ORIENTED WITH RESPECT TO SOURCE AND LOAD SIDES. KYLE TYPE H RECLOSERS DO NOT HAVE TO BE SO ORIENTED. BUT THEY SHOULD BE INSTALLED SO THAT THE COUNTER IS TOWARD THE POLE, MAKING IT EASIER TO READ.
3. INSTALL ARRESTERS ON SOURCE AND LOAD SIDE OF ALL RECLOSERS, TWO (2) REQUIRED PER PHASE. WHERE SPACE IS NOT AVAILABLE, INSTALL ARRESTERS ON ADJACENT POLE.
4. THREE PHASE INSTALLATIONS ARE TO BE IN ACCESSIBLE LOCATIONS ON CONCRETE POLES, CLASS III-H, 4.7 KIP SPUN, OR STRONGER WITH 8'-6" STEEL CROSSARM.
5. SINGLE PHASE OR TWO PHASE INSTALLATIONS ARE TO BE ON CLASS 3 WOOD POLES OR STRONGER.



OH & UG DISTRIBUTION SYSTEM STANDARDS

NO.	DATE	REVISION	ORIG.	DRAWN	APPR.
	1/9/07	ADDED POLE INFORMATION, NOTES 4 & 5	CEA	ELS	JJM
3	9/22/04	ADD ANIMAL GUARD	LFV	ELS	JJM
2	10/23/01	UPDATE DRAWING (TITLE CHANGE, NOTES, AND SHOW 3 SINGLE PHASE RECLOSERS)	CEA	JES	JJM
1	10/13/99	REMOVE BARREL FROM SINGLE & DOUBLE PHASE DETAIL	CEA	PRH	JJM

ORIGINATOR: ERB

DRAWN BY: H.V.

DATE: 11/11/64

APPROVED: J.J. MCEVOY
SUPERVISOR OH/UG PRODUCT
SUPPORT SERVICES


NO SCALE

C-8.0.0


THREE PHASE RECLOSER ON CONCRETE POLES TYPES 3H, 6H, R, RX, RV, W, AND WV

C-8.0.0

Docket No. 070301-EI
FPL Storm Hardening Plan
Exhibit MBM-1 Page 93 of 223




RECLOSER SIZE	JUMPER SIZE
25A-280A	#2/0 CU.
400A	#4/0 CU.
560A	350 KCMIL CU. (SEE NOTE 4.)



PLAN VIEW

1/2" x 6" COPPER STUD FOR ATTACHING HOT LINE CLAMP.
(M&S# 122-62500-1)



DETAIL "A"

NOTES:

1. LOAD/SOURCE BUSHINGS MAY NOT BE REVERSED.
2. INSTALL ARRESTERS ON SOURCE AND LOAD SIDE OF ALL RECLOSERS. ARRESTER MOUNTING BRACKET M&S# 334-552-001. TWO (2) REQUIRED. WHERE THIS ARRANGEMENT IS NOT UTILIZED, INSTALL INBOARD ARRESTERS ON ADJACENT POLE.
3. RECLOSER MOUNTING BRACKET M&S# 142-260-009.
4. A STIRRUP-HOTLINE CLAMP SYSTEM IS NOT AVAILABLE FOR 560A RECLOSURES. USE MECHANICAL CONNECTOR M&S# 102-700-008.
5. THREE PHASE RECLOSERS ARE TO BE INSTALLED IN ACCESSIBLE LOCATIONS ON CONCRETE POLES, CLASS III-H, 4.7 KIP SPUN, OR STRONGER, WITH 8'-6" STEEL CROSSARM.

SUPERSEDES C-8A LAST REVISED ON 7-1-86



OH & UG DISTRIBUTION SYSTEM STANDARDS

NO.	DATE	REVISION	ORIG.	DRAWN	APPR.
	1/9/07	ADDED POLE INFORMATION, NOTE 5	CEA	ELS	JJM
3	9/28/05	UPDATE DRAWING	CEA	ELS	JJM
2	9/22/04	ADD ANIMAL GUARD	LFV	ELS	JJM
1	6/30/93	REDRAW ON CAD, ADD TABLE FOR RECLOSER/JUMPER SIZE	IA	EMH	RJS

ORIGINATOR: IA



DRAWN BY: EMH

DATE: 7/01/86


APPROVED: R.J. SALESKY
DIRECTOR, DISTRIBUTION ENGINEERING
AND OPERATIONS SERVICES

NO SCALE

Docket No. 070301-EI
FPL Storm Hardening Plan
Exhibit MBM-1 Page 94 of 223



No.	DESCRIPTION
1	YAGI ANTENNA
2	10" X 1/2" BOLT
3	1 1/2" ROUND FLAT WASHER
4	1 1/4" GALVANIZED PIPE
5	1/2" SPRING WASHER
6	1/2" NUT
7	COAX CABLE
8	8" L-BRACKET
9	2" GALVANIZED PIPE



NOTES:

1. USE M&S #531-57000-4, AND BA FUSE, M&S #531-07800-2.
2. USE SECONDARY ARRESTER M&S #334-08500-3.
3. INSTALL CONTROL CABINETS OPPOSITE TO VEHICLE TRAFFIC FLOW.
4. DUE TO IMPEDANCE REQUIREMENTS, LENGTH OF 120V AC LINE CONDUCTOR SHALL BE 54 INCHES MINIMUM BETWEEN SECONDARY AND SWITCH JUNCTION BOX.
5. INSTALL SWITCHES IN ACCESSIBLE AREAS ONLY.
6. BOND 2" CONDUIT SIMILAR TO STANDARD G-9 AND G-10.
7. DESIGNER TO SPECIFY DIRECTION OF ANTENNA.
8. DUE TO CONTROL CABLE LENGTHS, POLE LENGTHS SHOULD NOT EXCEED 45' FOR WOOD POLES AND 50' FOR CONCRETE POLES.
9. GROUND DISTRIBUTION AUTOMATION SWITCH BRACKETS, SWITCH CONTROL CABINETS, AND RTU CABINETS.
10. NEW OR REPLACEMENT POLES ARE TO BE CONCRETE, CLASS III-H, 47 KIP SPUN, OR STRONGER.



OH & UG DISTRIBUTION SYSTEM STANDARDS

ORIGINATOR: C.A.

DRAWN BY: H. OHARRIZ

DATE: 4/18/90

APPROVED: J. McEVoy

NO SCALE

NO.	DATE	REVISION	ORIG.	DRAWN	APPR.
1	12/15/05	ADDED INFORMATION ON POLES	CEA	ELS	JJM

SUPERVISOR, OH/UG PRODUCT
SUPPORT SERVICES

C-9.0.5


DISTRIBUTION AUTOMATION SECTIONALIZING SWITCHES, RISER INSTALLATION

C-9.0.5

COOPER POWER SYSTEM VACUUM SWITCH 13 & 23 KV

Docket No. 070301-EI
FPL Storm Hardening Plan
Exhibit MBM-1 Page 95 of 223

C



NOTES:

1. NEW OR REPLACEMENT POLES ARE TO BE CONCRETE, CLASS III-H, 4.7 KIP SPUN, OR STRONGER, WITH STEEL CROSSARMS. IF 64" STEEL ARM IS USED, PUT B PHASE IN POLE TOP POSITION.
2. JUMPERS TO FEEDER AND BETWEEN SWITCHES TO BE 350 MCM SDBC.
3. USE MECHANICAL CONNECTORS TO ATTACH JUMPER TO FEEDER.
4. CUT JUMPERS BETWEEN SWITCHES LONG ENOUGH TO CONNECT TO FEEDER IF REQUIRED TO BY-PASS SECTIONALIZING SWITCH.
5. SEE C-9.04 FOR ADDITIONAL DETAILS.
6. FOR INSTALLATIONS WITH EXISTING RISER, THE RTU AND SWITCH CONTROL BOXES SHOULD EITHER BE BANDED TO THE POLE OR ATTACHED 90° FROM RISER.
7. SPECIFY DIRECTION OF ANTENNA AND MOUNTING FACE ON JOB SKETCH.
8. INSTALL ONLY IN ACCESSIBLE LOCATIONS.



OH & UG DISTRIBUTION SYSTEM STANDARDS

ORIGINATOR: CA

DRAWN BY: H. OHARRIZ

DATE: 10/02/90

APPROVED: R.K. CIELO
DIRECTOR, DISTRIBUTION ENGINEERING
AND SERVICE PLANNING


NO SCALE

NO.	DATE	REVISION	ORIG.	DRAWN	APPR.
2	11/15/06	ADDED INFORMATION ON POLES	CEA	ELS	JJM
1	10/7/04	ADD ANIMAL GUARD	LFV	ELS	JJM

C-9.1.0

COMMERCIAL/INDUSTRIAL LOAD
CONTROL (CILC) DISCONNECTING SWITCHES
(BRIDGES HORIZONTAL AUTO-VECTOR SWITCHES)

C-9.1.0



M&S # 270-274-505

NOTES:

1. BRING RISER SHIELD TO EVEN WITH THE BOTTOM OF THE CONTROL BOX.
2. SDR METER CABINET ON ADJACENT POLE.
3. BRING 120V SERVICE TO SDR METER CABINET
4. JUMPERS SHOULD BE SIZED ACCORDING TO CONDUCTOR AMPACITY ON THE LOAD SIDE (TO THE CUSTOMER). DO NOT SPLICE JUMPERS.
5. CONTROL BOX IS INCLUDED IN SWITCH M&S NUMBER.
6. SEE C-9.1.1 FOR ELECTRICAL LINE DRAWING.
7. NEW OR REPLACEMENT POLES ARE TO BE CONCRETE, CLASS III-H, 4.7 KIP SPUN, OR STRONGER.
8. INSTALL ONLY IN ACCESSIBLE LOCATIONS.

Docket No. 070301-EI
 FPL Storm Hardening Plan
 Exhibit MBM-1 Page 96 of 223


F P L
 OH & UG DISTRIBUTION SYSTEM STANDARDS

NO.	DATE	REVISION	ORIG.	DRAWN	APPR.
	11/15/06	ADDED INFOVATION ON POLES	CEA	ELS	JJM
4	10/6/05	UPDATE DRAWING	JFD	ELS	JJM
3	9/28/05	UPDATE DRAWING	CEA	ELS	JJM
2	10/07/04	ADD ANIMAL GUARD	LFV	ELS	JJM
1	6/17/03	ADD NOTE 5 AND M&S NUMBER	CEA	ELS	JJM

ORIGINATOR: CA

DRAWN BY: J. SHOUP

DATE: 9/16/99

APPROVED: J. McEVoy

NO SCALE


SUPERVISOR, OH/UG PRODUCT
SUPPORT SERVICES

C-9.1.1

COMMERCIAL/INDUSTRIAL LOAD
 CONTROL (CILC) DISCONNECTING SWITCHES
 (BRIDGES HORIZONTAL AUTO-VECTOR SWITCHES)

C-9.1.1

WIRING DIAGRAM FOR CILC SWITCH AND SDDR CABINET



NOTES:

1. THE ADDED ISOLATION TRANSFORMER AND RELAY IS TO MITIGATE SURGES THAT HAVE BLOWN FUSES IN THE PAST.

F P L
 OH & UG DISTRIBUTION SYSTEM STANDARDS

ORIGINATOR: CEA

DRAWN BY: E. SCHILLING

NO.	DATE	REVISION	ORIG.	DRAWN	APPR.
1	11/15/06	ORIGINAL DRAWING	CEA	ELS	JJM

DATE: 11/15/06

APPROVED

J. McEVoy

NO SCALE

SUPERVISOR, OH/UG PRODUCT
 SUPPORT SERVICES


C-9.2.0

SCADA-MATE SWITCH

C-9.2.0

Docket No. 070301-EI
 FPL Storm Hardening Plan
 Exhibit MBM-1 Page 98 of 223

C



SCADA-MATE SWITCH
 M&S # 270-275-005

SCADA-MATE CONTROL CABINET
 M&S # 270-275-102

NO.	DATE	REVISION	ORIG.	DRAWN	APPR.
8	11/15/05	MOVED NOTES TO NEXT PAGE	CEA	ELS	JJM
7	9/28/05	UPDATE DRAWING	CEA	ELS	JJM
	8/16/05	POLE, CROSSARM & ANIMAL GUARD INFORMATION	CEA	ELS	JJM
5	10/7/04	ADD ANIMAL GUARD	LFV	ELS	JJM
4	3/8/04	REVISE FRAMING AND NOTES	CEA	ELS	JJM
3	10/30/03	UPDATE DRAWING (DIMENSIONS AND NOTES)	CEA	ELS	JJM
2	6/16/03	UPDATE DRAWING (DIMENSIONS AND NOTES)	CEA	ELS	JJM
1	09/19/02	UPDATE DRAWING (DIMENSIONS AND NOTES)	CEA	JES	JJM

F P L
 OH & UG DISTRIBUTION SYSTEM STANDARDS

ORIGINATOR: CEA DRAWN BY: J. SHOUP

DATE: 06/06/01 APPROVED: J.J. MCEVOY
 SUPERVISOR, OH/UG PRODUCT SUPPORT SERVICES

NO SCALE

C-4.2.1

SCADA-MATE SWITCH

C-9.2.1

NOTES:

1. SCADA-MATE SWITCHES ARE TO BE INSTALLED IN ACCESSIBLE LOCATIONS ONLY.
2. ALL NEW OR REPLACEMENT POLES ARE TO BE CONCRETE, CLASS III-H, 4.7 KIP SPUN CONCRETE, OR STRONGER POLE CLASSES ARE TO BE INCREASED IF WIND LOADING GUIDELINES DICTATE
3. USE 8'-6" STEEL CROSSARMS.
4. FRAME IN-LINE BY-PASS SWITCHES ON CROSSARM WITH B PHASE IN POLE TOP POSITION (SIMILAR TO C-4.1.1), EXCEPT NO ARRESTERS ON CROSSARM).
5. BY-PASS SWITCHES MAY BE LOCATED ON EITHER SIDE OF POLE.
6. CONTACT DISTRIBUTION RELIABILITY PLANNING FOR SWITCH AND VOLTAGE SENSOR ORIENTATION.
7. ANIMAL PROTECTION COVERS FOR THE TERMINAL PADS ARE STANDARD FOR NEW AND RETROFIT INSTALLATIONS AND ARE INCLUDED WITH THE SWITCH.
8. INSTALL RISER POLE TYPE ARRESTERS, ONE PER PHASE, ON EACH SIDE OF THE AFS SWITCH BRACKET (TOTAL OF SIX ARRESTERS).
 -- 18KV FOR USE IN 23KV AREAS, M&S # 334-228-556
9. JUMPERS TO BE 568T FOR ALUMINUM FEEDERS, AMPACT TO FEEDER.
10. GROUND AFS SWITCH BRACKETS, CONTROL CABINET, AND ASSOCIATED EQUIPMENT (ANTENNA BRACKET, ETC.)
11. MOUNT ANTENNA VERTICALLY ON INVERTED 2'-6" STREET LIGHT BRACKET ON STREET SIDE OF POLE CLAMP ANTENNA SO FIBERGLASS PORTION IS FULLY ABOVE THE FLAT STEEL MOUNTING PLATE
12. MAINTAIN AT LEAST 18 INCHES CLEARANCE FROM TOP AND SIDE OF ANTENNA.
13. PUT AFS SWITCH NUMBER ON DOOR OF CONTROL BOX.
14. BOND #6 CU TO POLE BOND, USING CONNECTOR AT BOTTOM OF THE CONTROL BOX
15. SCADA-MATE VISIBLE AIR-CAP TO REMAIN CLOSED, UNLESS REQUIRED FOR VISIBLE SOLUTION.
16. CONNECT THE BATTERY TO THE CHARGING CIRCUIT INSIDE THE CONTROLLER BY FIRST OPENING THE CONTROL CABINET DOOR, OPENING THE SWING-OUT CONTROL PANEL, THEN CONNECTING THE BATTERY POSITIVE CONNECTOR TO THE BATTERY.

NEW STANDARD
 PREVIOUSLY PART OF
 C-9.2.0



F P L
 OIL & UG DISTRIBUTION SYSTEM STANDARDS

ORIGINATOR: CEA

DRAWN BY: E SCHILLING

DATE: 11/16/06


APPROVED: J.C. MCEVOY

NO SCALE


SUPERVISOR, OIL/UG PRODUCT
 SUPPORT SERVICES

NO.	DATE	REVISION	ORIG	DRAWN	APPR
1	11/16/06	ORIGINAL DRAWING	CEA	ELS	JJM


Docket No. 070301-EI
FPL Storm Hardening Plan
Exhibit MBM-1 Page 100 of 223



JOINT USE POLE-WITH 2' - 6" STREET LIGHT BRACKET
SCALE: N.T.S.



SCADA-MATE
REPEATER RADIO
M&S # 270-275-200



NOTES:

1. THE ILLUSTRATION TO THE LEFT SHOWS THE RADIO AS PROVIDED AND SHOWS THE PROPER MOUNTING TECHNIQUE, WITH THE CARRIAGE BOLTS POINTED DOWN AND A FLAT WASHER BETWEEN THE RADIO CASTING AND THE LOWER LOCKING NUT.
2. THE REPEATER IS TO BE INSTALLED ON A 2'-6" STREET LIGHT BRACKET OR ON AN EXISTING STREET LIGHT BRACKET, AS APPROPRIATE.
3. RADIO REPEATER IS TO BE INSTALLED ON HORIZONTAL PART OF BRACKET
4. SPLICE POWER CABLE IF NEEDED. POLARITY IS NOT AN ISSUE
5. USE 120V SOURCE

STANDARD RENUMBERED,
FORMERLY C-9.2.1



OH & UG DISTRIBUTION SYSTEM STANDARDS

ORIGINATOR: CEA

DRAWN BY: J. SHOUP

DATE: 06/06/01

APPROVED: J.J. MCEVOY

NO SCALE

SUPERVISOR, OH/UG PRODUCT
SUPPORT SERVICES

NO.	DATE	REVISION	ORIG.	DRAWN	APPR.
2	11/16/08	UPDATE DRAWING AND ADD NOTES	CEA	ELS	JJM
1	10/30/03	UPDATE DIMENSIONS	CEA	ELS	JJM

D-2.0.0

POLE SETTING, GUYING AND BRACING

D-2.0.0

DRAWINGS CONTAINED IN SECTION D SHOW DATA REFERRING TO THE SETTING, GUYING AND BRACING OF POLES. THE METHODS AND DATA GIVEN SHOULD BE ADHERED TO AS CLOSELY AS FIELD CONDITIONS PERMIT IN THE INTEREST OF UNIFORM CONSTRUCTION AND THE DEVELOPMENT OF MAXIMUM STRENGTH OF SUPPORTING STRUCTURES.

POLE SETTING

REFER TO STANDARD D-15 FOR INFORMATION AND DATA ON POLE AND ANCHOR STAKING.

POLES SHALL BE LOCATED IN ALIGNMENT AND SHALL BE SET TO STAND VERTICAL WHEN THE LINE IS COMPLETED. POLES LOCATED AT ANGLES, TERMINALS, CROSSINGS, OR POINTS OF EXCESSIVE STRAIN SHOULD BE CAREFULLY SELECTED FOR MAXIMUM STRENGTH.

WOOD POLES WHICH HAVE DECAYED AT THE GROUND LINE, BEYOND A POINT WHERE THEY MAY NO LONGER BE RELIED UPON AS AN ADEQUATE SUPPORT, MAY BE SPLINTED WHERE PRACTICABLE IF THEIR UPPER PORTION IS IN GOOD CONDITION AND IF SPLINTING IS NOT OBJECTIONABLE FROM THE STANDPOINT OF APPEARANCE OR OTHER REASON. AS AN EMERGENCY MEASURE, A POLE MAY BE STUBBED INSTEAD OF SPLINTED. CONCRETE POLES ARE NEVER SPLINTED EXCEPT IN EMERGENCIES.

GUYING

GUY ANCHORS SHALL, WHERE POSSIBLE, BE SO LOCATED THAT THE HORIZONTAL DISTANCE MEASURED FROM THE POLE AT THE GROUND LINE TO THE GUY ANCHOR WILL BE EQUAL TO THE HEIGHT ABOVE GROUND AT WHICH THE GUY IS ATTACHED TO THE POLE. GUYS SHALL BE ATTACHED TO THE POLES IN SUCH A MANNER AS TO INTERFERE AS LITTLE AS POSSIBLE WITH LINEMEN CLIMBING OR WORKING THEREON. THE GROUND END OF GUYS SHALL HAVE A GUY MARKER (GUY GUARD) INSTALLED AT ALL LOCATIONS.


NOTE: SETTING POLES AND ANCHORS IN OR ADJACENT TO WETLANDS AREAS MAY REQUIRE ENVIRONMENTAL CONTROL MEASURES. CONTACT THE ENVIRONMENTAL SPECIALIST FOR SPECIFIC REQUIREMENTS.

GUY STRAIN INSULATORS

NESC REQUIRES THAT ALL GUYS BE EFFECTIVELY GROUNDED. EFFECTIVELY GROUNDED CAN BE ACCOMPLISHED BY CONNECTING THE GUY WIRE TO A POLE BOND WHERE THE BOND IS CONNECTED TO A DRIVEN GROUND OR CONNECTED TO THE SYSTEM NEUTRAL. GROUNDING OF THE GUY IS NOT REQUIRED IF A FIBERGLASS GUY STRAIN INSULATOR (FGI) IS INSTALLED IN A MANNER TO PREVENT ANY CONTACT BETWEEN AN ENERGIZED CONDUCTOR AND THE GUY WIRE.

APPLICATION:

GUY STRAIN INSULATORS ARE USED ON WOOD POLES WHENEVER A GUY IS INSTALLED ABOVE THE NEUTRAL FOR 13KV AND ABOVE IN NON-CONTAMINATED AREAS. UNLESS REQUIRED DUE TO REDUCED CLEARANCES, GUY STRAIN INSULATORS ARE TYPICALLY NOT REQUIRED IN CONTAMINATED AREAS OR ON CONCRETE POLES SINCE ALL THE HARDWARE INCLUDING THE GUY WIRES ARE BONDED TO THE SYSTEM NEUTRAL AND / OR A DRIVEN GROUND.



GUY STRAIN INSULATORS CAN BE USED TO OBTAIN A 25% REDUCTION IN THE REQUIRED CLEARANCE BETWEEN THE GUY AND CONDUCTOR(S) WHERE NEEDED (SEE B-6, NOTE 8). ALL SLACK SPAN INSTALLATIONS ARE TO USE A GUY STRAIN INSULATOR WHERE THE SLACK CONDUCTORS ARE ADJACENT TO THE DOWNGUY. INSTALLATIONS WHERE A DOWNGUY GOES BETWEEN CONDUCTORS SHOULD ALSO USE A GUY STRAIN INSULATOR.

BONDED GUYS

WHERE THE GUY IS TO BE BONDED, ATTACH THE BOND WIRE TO THE GUY WIRE USING CONNECTOR M&S #120-44700-9. DO NOT ATTACH BOND WIRE TO PREFORMED GUY GRIP.

SUPERSEDES D-2.0.0 LAST REVISED ON 1-29-92



OH & UG DISTRIBUTION SYSTEM STANDARDS

ORIGINATOR: ARR

DRAWN BY: EMR

DATE: 9-30-94

APPROVED: R.J. SALESKY
 DIRECTOR, DISTRIBUTION ENGINEERING
 AND OPERATIONS SERVICES

NO SCALE

NO.	DATE	REVISION	ORIG.	DRAWN	APPR.
3	1/23/07	UPDATE NOTES	JNM	ELS	JJM
2	9/22/05	UPDATE DRAWING AND NOTES	JNM	ELS	JJM
1	8/29/03	ADD REF TO WETLANDS	JNM	ELS	JJM
0	9-30-94	REDRAWN ON CAD AND ADDED NESC REQUIREMENT	ARR	EMR	RJS

D-3.0.0

POLE SETTING DEPTHS AND SOIL CONDITIONS

D-3.0.0

POLE SETTING DEPTHS

MINIMUM POLE SETTING DEPTHS IN EARTH / GOOD SOIL (FT)

POLE LENGTH	TYPE "O"	CONCRETE POLES						WOOD POLES
		SU	III G	III A	III H	12 KIP	SPUN	WOOD
20							4.5	
25							5	
30							5.5	
35	7	7.5	9				6	
40			9	10	11.5	13	6.5	
45			9	10	11.5	13.5	7	
50			9.5	10	11.5	13.5	7	
55			9.5		12	14	7.5	
60					12	14	8	
65					12		8.5	
70						13.5	9	
75							9.5	
80							10	

MINIMUM POLE SETTING DEPTHS IN ROCK* (FT)

POLE LENGTH	TYPE "O"	CONCRETE POLES						WOOD POLES
		SU	III G	III A	III H	12 KIP	SPUN	WOOD
20							4	
25							4.5	
30							5	
35	6	6	7.5				5.5	
40			7.5	8	9.5	11	5.5	
45			7.5	8.5	9.5	11	6	
50			7.5	8.5	9.5	11	6	
55			8		9.5	11.5	6	
60					10	11.5	6.5	
65					10		6.5	
70						13.5	7	
75							7.5	
80							8	

* FOR SOILS THAT ARE 90% ROCK OR HARD CLAY.

POLE SETTING DETAILS AND SOIL CONDITIONS:

UNDER NORMAL CONDITIONS, A CONCRETE POLE CAN BE SET DIRECTLY INTO AN AUGURED HOLE, BACKFILLING WITH THE SOIL AUGURED FROM THE HOLE, TAMPING THE SOIL IN LAYERS FOR A GOOD TIGHT FIT.

IN SITUATIONS WHERE POLES HAVE A LARGE LOAD, IMBALANCE LOAD OR WHERE SOIL CONDITIONS ARE QUESTIONABLE, IT MAY REQUIRE ADDITIONAL CONSIDERATIONS, IN MOST CASES, ALL THAT MAY BE REQUIRED IS TO INCREASE THE BEARING SURFACE BELOW GRADE. THIS CAN BE ACHIEVED IN A NUMBER OF WAYS. THE EASIEST IS SETTING THE POLE DEEPER. ANOTHER METHOD IS TO AUGER THE SETTING HOLE, 8" TO 10" GREATER IN DIAMETER THAN THE POLE BUTT. BACKFILL WITH CONCRETE OR A FLOWABLE FILL, THIS WILL HELP MEET THE STRENGTH REQUIREMENTS AND ALLOW FOR EASY REMOVAL IF DAMAGE OCCURS TO THE POLE. FLOWABLE FILL IS A LOW STRENGTH, SLURRY-LIKE MATERIAL WITH THE CONSISTENCY OF PANCAKE BATTER, WHICH ARRIVES ON THE JOB SITE IN A READY MIX TRUCK. THE MATERIAL IS SELF-LEVELING AND REACHES 95 PERCENT OR MORE COMPACTION WITHIN A FEW HOURS OF PLACEMENT. IT GENERALLY IS MADE FROM A BLEND OF CEMENT, FLY ASH, SAND AND WATER.

IF FIELD CONDITIONS DICTATE THE NEED TO MAINTAIN THE WALLS OF AN AUGURED HOLE, USE A SOIL STABILIZER, M&S #522-125-575. A SODA ASH COMPCUND M&S #522-126-571 MAY BE NEEDED IN CONJUNCTION WITH THIS SOIL STABILIZER.

FOR LEANING POLES IN AREAS WITH NO STANDING WATER, A POLE SETTING FOAM IS AVAILABLE, M&S #522-100-000. IT EXPANDS TO FILL THE PERIPHERAL VOID BETWEEN THE POLE AND THE HOLE.

GENERAL GUIDLINES FOR TYPICAL SOILS:

GOOD SOIL


COMPACT WELL GRADED SAND AND GRAVEL, HARD CLAY OR WELL GRADED FINE AND COARSE SAND AND NO STANDING WATER. USE AS IS FOR BACKFILL.

MEDIUM SOIL

COMPACT FINE SAND AND CLAY, COMPACT SANDY LOAM, LOOSE COARSE SAND AND GRAVEL AND NO STANDING WATER. BACKFILL WITH ROCK, A 57 STONE OR SMALLER AND TAMPING EACH LAYER VERY WELL.

POOR SOIL

SOFT CLAY, CLAY LOAM, POORLY COMPACTED SAND OR CLAYS CONTAINING LARGE AMOUNTS OF SILTS, STANDING WATER DURING WET SEASON. MAY REQUIRE BACKFILLING THE HOLE WITH CONCRETE OR A FLOWABLE FILL.



OH & UG DISTRIBUTION SYSTEM STANDARDS

ORIGINATOR: A.A.

DRAWN BY: J.H.

DATE: 7-1-87

APPROVED: R. K. CIELO

NO SCALE

NO	DATE	REVISION	ORIG.	DRAWN	APPR
1	6/6/06	NEW DRAWING	RJD	ELS	JJM

DIRECTOR, DISTRIBUTION ENGINEERING
AND SERVICE PLANNING

D-7.0.0

METHODS OF ATTACHING GUYS FOR WOOD AND CONCRETE POLES

D-7.0.0

HEAVY DUTY ATTACHMENT

FOR GUYS TO 9/16" GALV. USE 3/4" BOLTS AND 4" SQUARE WASHERS. (CURVED WASHER ON WOOD POLES) (FLAT WASHER ON CONCRETE POLES)

USE THE HEAVY DUTY ATTACHMENT WITH 6" MOUNTING HOLES ON ALL SPUN CONCRETE POLES

MEDIUM DUTY ATTACHMENT

FOR GUYS TO 7/16" GALV. USE 5/8" BOLTS AND 4" SQUARE WASHERS. (CURVED WASHER ON WOOD POLES) (FLAT WASHER ON CONCRETE POLES)


SYMBOL  MEANS TO POLE BOND

STEEL CROSSARM ATTACHMENT

(SEE NOTE 1)

WOOD POLE ARRANGEMENT

CONCRETE POLE ARRANGEMENT



DETAIL A
CONNECT TAIL OF GUY WIRE TO POLE BOND

DETAIL B
CONNECT POLE BOND WIRE TO GUY WIRE BELOW GUY GRIP

- NOTES:**
1. ALL GUYS SHALL BE BONDED EXCEPT WHERE A GUY STRAIN INSULATOR IS USED. GUY STRAIN INSULATORS ARE USED ON WOOD DEADEND POLES WHENEVER A GUY IS INSTALLED ABOVE THE NEUTRAL FOR 13KV AND ABOVE IN NON-CONTAMINATED AREAS. THEY ARE NOT USED ON CONCRETE POLES AND ARE NOT REQUIRED ON WOOD DEADEND POLES (OR POLE GUYED FOR ANY REASON) IF PROTECTED BY SURGE ARRESTERS. IN CASES WHERE A DOWNGUY IS LOCATED ADJACENT TO CONDUCTORS, THE GUY SHALL EITHER USE A GUY STRAIN INSULATOR THAT IS LONG ENOUGH TO EXTEND BELOW THE LOWEST CONDUCTOR OR BE BONDED.
 2. GUY STRAIN INSULATORS CAN BE USED TO OBTAIN A 25% REDUCTION IN THE REQUIRED CLEARANCE BETWEEN THE GUY AND CONDUCTOR(S) WHERE NEEDED (SEE B-6, NOTE B). ALL SLACK SPAN INSTALLATIONS ARE TO USE A GUY STRAIN INSULATOR WHERE THE SLACK CONDUCTORS ARE ADJACENT TO THE DOWNGUY. INSTALLATIONS WHERE A DOWNGUY GOES BETWEEN CONDUCTORS SHOULD ALSO USE A GUY STRAIN INSULATOR.
 3. GUYS WITHOUT FIBERGLASS INSULATORS ARE TO BE BONDED TO THE POLE GROUND. GUYS WITH FIBERGLASS INSULATORS WILL NOT BE BONDED. SEE SECTION "G" FOR METHODS OF BONDING.
 4. WHERE THE GUY IS TO BE BONDED, ATTACH THE BOND WIRE TO THE GUY WIRE USING CONNECTOR M&S #120-44700-9. DO NOT ATTACH BOND WIRE TO PREFORMED GUY GRIP (OR ANY OTHER PART OF THE GUYING INSTALLATION).

SUPERSEDES D-7 LAST REVISED 1-4-88 (REMOVED LIGHT DUTY ATTACHMENT)



OH & UG DISTRIBUTION SYSTEM STANDARDS

NO.	DATE	REVISION	ORIG.	DRAWN	APPR.
4	1/23/07	ADD NOTE	JNM	ELS	JJM
4	6/30/03	ADD M&S #'S FOR GUY HOOKS	JNM	ELS	JJM
3	8/20/02	ADDED DETAILS A & B	JNM	JES	JJM
2	7/30/01	ADDED REFERENCE TO NOTE 4	JNM	JES	JJM
1	3/15/91	REVISED GUY GROUNDING	A.S	H.O.	G.W.H

ORIGINATOR: AS

DRAWN BY: JRF

DATE: 3/01/89

APPROVED: G. W. HAMMOND III
 DIRECTOR, DISTRIBUTION ENGINEERING AND SERVICE PLANNING


NO SCALE

D-7.0.1

METHOD OF ATTACHING GUYS
 FOR WOOD OR CONCRETE POLES

D-7.0.1


GUY STUB POLE OR MESSENGER DE FOR
 HENDRIX AERIAL SPACER CABLE SYSTEM
 GUY ATTACHMENTS ARE MOUNTED
 BACK TO BACK.



BONDING OF GUYS AT STUB POLES IS
 NECESSARY ONLY IF THERE ARE CIRCUITS
 ABOVE THE GUYS ON THE STUB POLE.

SEE NOTE 1

FIBERGLASS STRAIN INSULATORS ARE
 NOT USED ON CONCRETE POLES
 SEE NOTES ON SHEET D-7.0.0




ARM GUYS
 USE A GUY THIMBLE WHEN
 ATTACHING ARM GUYS
 (WITHOUT FIBERGLASS
 INSULATORS) TO BOLT EYES
 ON D.A. BOLTS.

SPAN GUYS
 SPAN GUYS ATTACH TO POLE
 BY SAME METHODS AS
 SHOWN FOR DOWN GUYS.

FIBERGLASS GUY STRAIN INSULATORS				
	18"	78"	90"	120"
5/16"	131-040-002 *	131-0520-001 *	N/A	N/A
7/16" & 9/16"	131-044-008	N/A	131-060-003	131-070-009

* FOR USE WITH MEDIUM DUTY GUY ATTACHMENT ONLY (M&S 142-186-003)



(SPAN GUY)

GUY ATTACHMENT USES SAME BOLT
 AS PRIMARY DEADEND FOR SINGLE
 PHASE OR VERTICAL PRIMARY.

THE FGI MUST EXTEND DOWN BELOW
 THE LOWEST ENERGIZED CONDUCTOR
 OR THE GUY WIRE MUST BE
 EFFECTIVELY GROUNDING.

GUY ATTACHMENT MOUNTED BACK TO BACK
 WITH NEUTRAL FORK.
 BOND NEUTRAL GUY TO SYSTEM NEUTRAL
 IF POLE BOND IS NOT AVAILABLE AND
 NEUTRAL IS MOUNTED ON SECONDARY
 SPOOL.

NOTE:

1. SHOWN IS PREFERRED METHOD FOR DEADENDING
 THE 1/2" (7#6 AWA) MESSENGER FOR THE
 HENDRIX AERIAL SPACER CABLE SYSTEM. USE
 HEAVY DUTY GUY HOOK (M&S 142-187-000) WITH
 3/4" BOLTS.

SUPERSEDES D-7A LAST REVISED ON 7-1-88



OH & UG DISTRIBUTION SYSTEM STANDARDS

ORIGINATOR: PMG

DRAWN BY: RAS

DATE: 8/9/96

APPROVED: J.J. MCEVOY

NO SCALE



SUPERVISOR, OH/UG PRODUCT
 SUPPORT SERVICES

NO.	DATE	REVISION	ORIG.	DRAWN	APPR.
	1/23/07	ADD NOTE	JNM	ELS	JJM
	9/21/05	ADD NOTE TO TABLE	JNM	ELS	JJM
2	6/30/03	ADD M&S #'S FOR GUY STRAIN INS.	JNM	ELS	JJM
1	7/28/99	ADD NOTE & CHANGE TEXT	JNM	PRH	JJM
0	8/9/96	CHANGED PORCELAIN SUSPENSION INSULATORS TO POLYMER	PMG	RAS	JJM


D-13.0.0

STORM GUYING

D-13.0.0



STORM GUYS USING DOWN GUYS



STORM GUY COMBINATION DOWN GUY AND SPAN GUY

STORM GUYS	
GUY SIZE	ALLOWABLE GUY TENSION
5/16	10080
7/16	18720
9/16	30330

NOTES:

1. STORM GUYS ARE INSTALLED BACK TO BACK PERPENDICULAR TO THE POLE LINE.
2. EITHER ONE OR BOTH OF THE STORM GUYS MAY BE INSTALLED AS SPAN GUYS TO A GUY STUB POLE.
3. ALL GUYS ARE TO BE EFFECTIVELY GROUNDED UNLESS FIBERGLASS GUY STRAIN INSULATORS ARE USED. (REFER TO D-2.0.0)
4. STORM GUYS ALSO MAY BE INSTALLED ON CROSSARM POLES.

MINIMUM STORM GUY SIZE MODIFIED VERTICAL FRAMING WITH JOINT USE			
RATIO OF LEAD LENGTH/ATTACHMENT HEIGHT	80%	90%	100%
1 & 2 PHASE LINES	5/16	5/16	5/16
3 PHASE LINES	7/16	7/16	7/16

OPTIMUM GUY IS WHERE LEAD LENGTH = ATTACHMENT HEIGHT (RATIO=100%)
 IF DOWN GUYS CANNOT BE INSTALLED SPAN GUYS TO GUY STUB POLES CAN BE USED

SEE DRAWING AND SPECIFICATIONS FOR GUY SIZE
 SPECIFICATIONS



F P L

OH & UG DISTRIBUTION SYSTEM STANDARDS

ORIGINATOR: JNM

DRAWN BY: E.SCHILLING

DATE: 1/23/07

APPROVED: J.J. McEVoy

NO SCALE


SUPERVISOR, OH/UG PRODUCT
 SUPPORT SERVICES

NO.	DATE	REVISION	ORIG.	DRAWN	APPR.
1	2/27/07	UPDATE DWG AND NOTES	JNM	ELS	JJM
0	1/23/07	ORIGINAL DRAWING	JNM	ELS	JJM

E-3.0.0

OVERHEAD EQUIPMENT DIMENSIONS

E-3.0.0




E

NOTE:

SOME DIMENSIONS WILL VARY SLIGHTLY WITH MANUFACTURER, TOLERANCES, ETC., BUT

SUPERSEDES E-3 LAST REVISED ON 3-1-89



OH & UG DISTRIBUTION SYSTEM STANDARDS

ORIGINATOR: ARR

DRAWN BY: EMH

DATE: 6-30-93

APPROVED: R. J. SALESKY
 DIRECTOR, DISTRIBUTION ENGINEERING AND OPERATIONS SERVICES

NO SCALE

NO.	DATE	REVISION	ORIG.	DRAWN	APPR.
2	12/5/06	UPDATE DRAWING	LFV	ELS	JJM
1	9-7-99	ADDED DETAIL OF 45KV POLYMER TIE TOP	JNM	PRH	JJM
0	6-30-93	CONVERTED TO CAD DRAWING	ARR	EMH	RJS

E-5.0.0

POST INSULATOR CONSTRUCTION
 EQUIPMENT & DIMENSIONS

E-5.0.0




FIG. 1
WOOD POLE





FIG. 2
SQUARE CONCRETE POLE




FIG. 3
SPUN CONCRETE POLE

ITEM	MATERIAL DESCRIPTION	M&S #
	TIE TOP OR SIDE CLAMP TYPE (AS REQUIRED)	131-11600-9 (13 KV AND 23 KV AREAS) 131-11650-5 (13 KV AND 23 KV AREAS) 131-11750-1 (23 KV SALT SPRAY)
	ADAPTER TO MOUNT INSULATORS TO WOOD POLES	140-040-010
	STUD BOLTS FOR MOUNTING INSULATORS (AS REQUIRED)	3/4" x 1-3/4" 143-09800-1 3/4" x 10" 143-10202-4 3/4" x 12" 143-10200-8 3/4" x 14" 143-10201-6 3/4" x 20" 143-10204-1 3/4" x 24" 143-10203-2 3/4" x 28" 143-10205-9
	SPOOL	144-405-004
	POLE TOP PIN BRACKET	141-248-005
	C-CHANNEL ADAPTER TO MOUNT INSULATOR TO SPUN CONCRETE POLES	140-040-050

NOTES:

1. VERTICAL SEPARATION BETWEEN PRIMARY CONDUCTORS AT POLES IS TO BE 36" MINIMUM IF AN ADJACENT POLE IS FRAMED HORIZONTAL OR TRIANGULAR.
2. PRIMARY TO NEUTRAL SEPARATION AT POLE IS DETERMINED BY MINIMUM MIDSAPAN SEPARATION (DERM 4.4.1) IN NO CASE SHALL SEPARATION AT THE POLE BE LESS THAN 40" FOR WOOD AND CONCRETE POLES. FOR TYPICAL SEPARATIONS FOR VARIOUS SPAN DISTANCES REFER TO DERM 4.4.6

SPUN CONCRETE INSULATOR ADAPTER MUST BE MOUNTED BELOW THE FRAMED SEPARATION POINT DAILY AGAINST POLES



OH & UG DISTRIBUTION SYSTEM STANDARDS

ORIGINATOR: ARR

DRAWN BY: JRF

NO.	DATE	REVISION	ORIG.	DRAWN	APPR.
2	8/02/01	UPDATE DRAWING (REVISE NOTE 2)	JAM	JES	JRM
1	6/30/93	REV DWG TO VERTICAL FRAMING STANDARD	ARR	MM	RJS

DATE: 1/1/90


APPROVED: R.K. CIELO
 DIRECTOR, DISTRIBUTION ENGINEERING
 AND SERVICE PLANNING

NO SCALE

E-5.0.2

INSTALLATION OF HARDWARE ON
 WOOD AND CONCRETE POLES

E-5.0.2



NOTES:

1. WHEN INSTALLING HARDWARE ON CONCRETE POLES, SPRING LOCKWASHERS ARE NOT REQUIRED.
2. USE DOUBLE COIL SPRING LOCKWASHER ON BOLTED ATTACHMENTS ON WOOD POLES.
3. USE 1 ROUND WASHER (M&S 145-3600-4) FOR 5/8" BOLT IN SLOT ONLY. WASHER NOT REQUIRED FOR 3/4" BOLT OR 5/8" BOLT IN BOTTOM HOLE.



OH & UG DISTRIBUTION SYSTEM STANDARDS

NO.	DATE	REVISION	ORIG.	DRAWN	APPR.
3	1/25/07	UPDATE C-CHANNEL NOTE	GAP	ELS	JJM
2	12/5/06	UPDATE DWG TO ADD SPUN CONCRETE POLE	LFV	ELS	JJM
1	5/23/03	REVISE L BRACKET & ADD 5/8" BOLT	JNM	ELS	JJM

ORIGINATOR: ARR

DRAWN BY: FRAGA

DATE: 6/30/93

APPROVED: R. J. SALESKY
 DIRECTOR, DISTRIBUTION ENGINEERING
 AND OPERATIONS SERVICES

NO SCALE

E-5.7.1

SLACK SPAN CONSTRUCTION
 VERTICAL FRAMING

E-5.7.1




FIG. 1
 THREE PHASE SLACK SPAN FROM THREE PHASE LINE, POLE A OR B TO POLE C




FIG. 3

THREE PHASE SLACK SPAN
 FROM 3Ø DEADEND




FIG. 2

SINGLE PHASE SLACK SPAN FROM SINGLE PHASE LINE

SLACK SPAN		
CONDUCTOR	MAXIMUM LENGTH	INITIAL SAG
568.3 ACAR	50'	3'-7"
3/0 AAAC	75'	2'-9"
1/0 AAAC	95'	2'-10"

- (A) LINE POST, CLAMP TOP INS
- (B) LINE POST, VERTICAL TIE TOP, MOUNTED HORIZONTALLY WITH FORMED TIE WIRE.

NOTES:

1. ENGINEER TO SPECIFY SLACK SPAN SAG. (SEE DERM 4.4.5, 4.4.10)
2. INSTALL INSULATOR AND CLAMP AS SHOWN IN DETAIL "A" SUCH THAT WEIGHT ON OUTER END OF CLAMP WOULD TIGHTEN RATHER THAN LOOSEN BOLT.
3. ANY INSULATORS USED AS SLACK SPAN INSULATORS MUST HAVE LONG TRUNNION BOLTS.
4. FOR PULL-OFFS INSTALL FUSE SWITCHES ON NEXT POLE.
5. SEE D-2.0.0 FOR GUYING INSTRUCTIONS AND FOR PROPER ARRESTER STATION SPACING SEE DERM 2.9.1
6. FIBERGLASS GUY INSULATORS (FGI'S) MUST EXTEND BEYOND LOWEST CONDUCTOR. FOR SLACK SPAN, FGI'S ARE REQUIRED ON BOTH WOOD AND CONCRETE POLES.
7. USE CLASS 2 POLE MINIMUM



OH & UG DISTRIBUTION SYSTEM STANDARDS

ORIGINATOR: PMG

DRAWN BY: RAS

DATE: 9/30/94

APPROVED: J.J. MCEVOY
 SUPERVISOR, OH/UG PRODUCT
 SUPPORT SERVICES

NO SCALE

NO.	DATE	REVISION	ORIG.	DRAWN	APPR.
5	1/23/07	ADD TABLE, NOTE 7 & REV NOTE 6	JNM	ELS	JJM
	7/1/03	EXTEND FGI PAST ENERGIZED CONDUCTOR ADD FIG 3	JNM	ELS	JJM
3	03/22/02	ADD DIMENSIONS FIGURE 1 & 2	JNM	JES	JJM
2	08/03/01	UPDATED DRAWING (ADDED NOTE #6)	JNM	JES	JJM
1	08/09/96	CHANGED PORCELAIN SUSPENSION INSULATORS TO POLYMER AND ADDED DEAD END CLAMP	PMG	RAS	JJM

E-6.0.0

TANGENT CONSTRUCTION
 WOOD CROSSARM

E-6.0.0





FIG. 1



DOUBLE ARM
 FIG. 2

SHORT STANDARD ARM
 (3-1/2" x 4-1/2" x 5'-6")
 M&S #150-11400-8
 FIG. 4

NOTES:

1. ALL POST INSULATORS SHOWN ARE 35KV TIE TOP. USE CLAMP TOPS WHERE INDICATED BY ANGLE AND SIDE PULL LIMITATIONS SHOWN ON E-4.0.1 THRU E-4.0.3. USE 45KV POST INSULATORS (CLAMP TYPE) ON 23KV CIRCUITS IN SALT CONTAMINATION AREAS. USE 45KV POST TIE TOP POLYMER INSULATORS ON 23KV CIRCUITS IN SEVERE SALT CONTAMINATED AREAS.
2. FIBERGLASS BRACE IS NOT REQUIRED IN SALT SPRAY AREAS WHERE HARDWARE IS BONDED.
3. PRIMARY TO NEUTRAL SEPARATION AT POLE IS DETERMINED BY MINIMUM MIDSPAN SEPARATION (DERM 4.4.1), IN NO CASE SHALL SEPARATION AT THE POLE BE LESS THAN 40" FOR WOOD POLES OR CONCRETE POLES.
4. WHEN INSTALLING AN 8"-6" STEEL CROSSARM (M&S 141-512-004) ON A WOOD POLE, USE HEAVY DUTY WOOD BRACES (M&S 141-084-002).




FIG. 3

SEE NOTE 4



OH & UG DISTRIBUTION SYSTEM STANDARDS

ORIGINATOR: PMG

DRAWN BY: RAS

DATE: 8/9/96

APPROVED: J.J. MCEVOY
 SUPERVISOR, OH/UG PRODUCT
 SUPPORT SERVICES






NO SCALE

NO.	DATE	REVISION	ORIG.	DRAWN	APPR.
	12/13/05	ADD NOTE 4	GAP	ELS	JJM
	4/1/04	REVISE FIG. 2	JNM	ELS	JJM
3	8/29/03	ADD M&S NUMBERS	JNM	ELS	JJM
2	8/04/01	UPDATE DRAWING (GENERAL TEXT REVISION)	JNM	JES	JJM
1	9/7/99	ADD REF TO 45KV POLYMER INSULATORS	JM	DLW	JJM
0	8/9/96	ADDED FIGURE 4	PMG	RAS	JJM

E-6.0.1

TANGENT CONSTRUCTION
 STEEL CROSSARM

E-6.0.1



C-CHANNEL ADAPTER TO MOUNT STEEL CROSSARM TO SPUN CONCRETE POLE. SEE E-5.0.2.

NOTES:

- ALL POST INSULATORS SHOWN ARE 35 KV TIE TOP. USE CLAMP TOPS WHERE INDICATED BY ANGLE AND SIDE PULL LIMITATIONS SHOWN ON E-4. USE 45 KV POST INSULATORS (CLAMP TYPE) ON 23 KV CIRCUITS IN SALT CONTAMINATION AREAS. INSULATORS ON 23KV CIRCUITS IN SEVERE SALT CONTAMINATED AREAS.
- WHEN INSTALLING A STEEL ARM OPPOSITE A POLE TOP BRACKET, A LARGER POLE TOP BRACKET, M&S 141-248-007, SHOULD BE USED THAT ACCEPTS 3/4" BOLTS. THIS WOULD APPLY TO TANGENT, ANGLE, OR DOUBLE DEADEND CONSTRUCTION.
- PRIMARY TO NEUTRAL SEPARATION AT POLE IS DETERMINED BY MINIMUM MIDSPAN SEPARATION (DERM 4.4.1), IN NO CASE SHALL SEPARATION AT THE POLE BE LESS THAN 40" FOR CONCRETE POLES OR WOOD POLES.
- STEEL ARMS MUST BE SOLIDLY GROUNDED WHEN INSTALLED ON CONCRETE POLES.
- IF THE NEUTRAL IS INSTALLED ON THE CROSSARM AND AN ARRESTER STATION IS REQUIRED ON THE POLE, THE ARRESTERS MUST BE INSTALLED ON THE ARM. OTHERWISE, ARRESTERS MAY BE INSTALLED AS SHOWN IN FIG. 5. WHEN ARRESTERS ARE INSTALLED ON THE ARM USE LUG CONNECTORS M&S #120-95000-2 OR 120-96000-8 TO SECURE GROUND LEADS.
- IF NEUTRAL IS INSTALLED ON THE CROSSARM AT AN ANGLE USE FIG. 4A AS A FRAMING STANDARD. USE FIG 4B IF NO ANGLE IS PRESENT.
- EACH ARRESTER GROUND LEAD SHOULD BE INDIVIDUALLY ATTACHED TO POLE BOND.



OH & UG DISTRIBUTION SYSTEM STANDARDS

NO.	DATE	REVISION	ORIG.	DRAWN	APPR.
6	1/25/07	ADD C-CHANNEL DWG & NOTE	GAP	ELS	JJM
	11/27/06	SHIFT CROSSARM & BRACKET DOWN ON FIG 5 AND DETAIL	GAP	ELS	JJM
	10/11/04	ADD ANIMAL GUARD	LFV	ELS	JJM
3	6/18/03	UPDATE DRAWING (NOTES)	LFV	ELS	JJM
2	9/7/99	ADD BOND WIRE UNDER CROSSARM	JM	DLW	JJM
1	9/7/99	ADD REF TO 45KV POLYMER INSULATORS	JM	DLW	JJM
0	9/30/94	ORIGINAL DRAWING	ARR	RAS	RJS

ORIGINATOR: ARR

DRAWN BY: RAS

DATE: 9/30/94

APPROVED: R. J. SALESKY
 DIRECTOR, DISTRIBUTION ENGINEERING
 AND OPERATIONS SERVICES

NO SCALE

E-8.0.0

ANGLE CONSTRUCTION
 CONCRETE POLE-STEEL CROSSARM

E-8.0.0





FIG. 1
 8'6" STEEL ARM, ANGLE TO 5 DEGREES,
 SINGLE ARM



OVER 5 DEGREES USE CLAMP TOPS
 AND APPROPRIATE CLAMP




FIG. 2
 8'6" STEEL ARM
 MEDIUM ANGLES, MAX 45 DEGREES
 DOUBLE ARM




FIG. 3
 5'4" STEEL ARM, 2 OR 3 CONDUCTORS,
 LARGE ANGLES, MAXIMUM 60 DEGREES





FIG. 4
 8'6" STEEL ARM, 2 OR 3 CONDUCTORS,
 LARGE ANGLES, MAXIMUM 60 DEGREES





FIG. 5
 8'6" STEEL ARM, 4 CONDUCTORS,
 LARGE ANGLES, MAXIMUM 60 DEGREES

NOTES:

1. ALL POST INSULATORS SHOWN ARE 35 KV. USE 45 KV POST INSULATORS AND 4 JD'S OR ONE POLYMER SUSPENSION INSULATOR ON 23KV CIRCUITS IN SALT CONTAMINATED AREAS. USE 45KV POST TIE TOP POLYMER INSULATORS ON 23KV CIRCUITS IN SEVERE SALT CONTAMINATED AREAS.
2. WHEN INSTALLING A STEEL ARM OPPOSITE A POLE TOP BRACKET, SEE E-6.0.1 FIG 5.
3. STEEL CROSSARMS ARE NOT RECOMMENDED FOR ANGLE CONSTRUCTION ON WOOD POLES.
4. FOR JUMPER SIZE SEE F-6.0.2.
5. FOR SPUN CONCRETE POLE INSTALLATIONS, USE THE C-CHANNEL ADAPTER SHOWN IN E-6.0.1.



OH & UG DISTRIBUTION SYSTEM STANDARDS

NO.	DATE	REVISION	ORIG.	DRAWN	APPR.
3	1/25/07	ADD NOTE 5	CAP	ELS	JJM
2	10/27/06	UPDATE NOTE 2	CAP	ELS	JJM
1	9/7/99	ADD REF TO 45KV POLYMER INSULATORS	JM	DLW	JJM
0	8/9/96	CHANGED PORCELAIN SUSPENSION INSULATORS TO POLYMER	PMG	RAS	JJM

ORIGINATOR: PMG

DRAWN BY: RAS

DATE: 8/9/96

APPROVED: J.J. MCEVOY
 SUPERVISOR, OH/UG PRODUCT
 SUPPORT SERVICES

NO SCALE

E-29.0.0

SLACK SPAN CONSTRUCTION

E-29.0.0




FIGURE 1
 THREE PHASE SLACK SPAN FROM THREE PHASE LINE




FIGURE 2
 SINGLE PHASE SLACK SPAN FROM THREE PHASE LINE




FIGURE 3
 SINGLE PHASE SLACK SPAN FROM SINGLE PHASE LINE

SLACK SPAN		
CONDUCTOR	MAXIMUM LENGTH	INITIAL SAG
568.3 ACAR	50'	3'-7"
3/0 AAAC	75'	2'-9"
1/0 AAAC	95'	2'-10"

- (A) LINE POST, CLAMP TOP INSULATOR
- (B) LINE POST, VERTICAL TIE-TOP, WITH FORMED TIE WIRE.
- (C) LINE POST, VERTICAL TIE TOP, MOUNTED HORIZONTALLY WITH FORMED TIE WIRE.




FIGURE 4
 THREE PHASE SLACK SPAN FROM THREE PHASE LINE USING STEEL CROSSARM (FOR MAINTENANCE ONLY)

NOTES:

1. ALL POST INSULATORS SHOWN ARE 35 KV TIE TOP OR CLAMP TOP. USE 45 KV POST INSULATORS ON 23 KV CIRCUITS IN SALT CONTAMINATED AREAS. USE 45KV POST TIE TOP POLYMER INSULATORS ON 23KV CIRCUITS IN SEVERE SALT CONTAMINATED AREAS.
2. PRIMARY TO NEUTRAL SEPARATION AT POLE IS DETERMINED BY MINIMUM MIDSPAN SEPARATION (DERM 4.4.1). IN NO CASE SHALL SEPARATION AT THE POLE BE LESS THAN 40" FOR WOOD OR CONCRETE POLES.
3. BASE OF INSULATOR MUST BE INSTALLED TIGHTLY AGAINST CROSSARM OR POLE
4. ENGINEER TO SPECIFY SLACK SPAN SAG. (SEE DERM 4.4.5, 4.4.10).
5. INSTALL INSULATOR AND CLAMP AS SHOWN IN DETAIL "A" SUCH THAT WEIGHT ON OUTER END OF CLAMP WOULD TIGHTEN RATHER THAN LOOSEN BOLT.
6. ANY INSULATORS USED AS SLACK SPAN INSULATORS MUST HAVE LONG TRUNNION BOLTS WITH LOCKNUT.
7. FOR JUMPER SIZE INFORMATION SEE F-6.0.2.
8. FIBERGLASS GUY INSULATOR (FIGURE 1) MUST EXTEND BELOW LOWEST ENERGIZED CONDUCTOR, OR THE GUY MUST BE BONDED.
9. USE CLASS 2 POLE MINIMUM.



OH & UG DISTRIBUTION SYSTEM STANDARDS

NO.	DATE	REVISION	ORIG.	DRAWN	APPR.
3	1/23/07	ADD TABLE, NOTE 9 & REV NOTE 8	JNM	ELS	JJM
2	03/22/02	ADD DIMENSIONS TO FIGURE 3.	JNM	JES	JJM
1	09/08/99	INSULATORS TO POLYMER	JNM	DLW	JJM
0	08/09/96	CHANGED PORCELAIN SUSPENSION INSULATORS TO POLYMER	PMG	RAS	JJM

ORIGINATOR: PMG

DRAWN BY: RAS

DATE: 8/9/96

APPROVED: J.J. MCEVOY

NO SCALE

SUPERVISOR, OH/UG PRODUCT SUPPORT SERVICES

E-29.1.0

SLACK SPAN CONSTRUCTION
 CONCRETE POLE INSTALLATION ONLY

E-29.1.0




FIGURE 1

3Ø 102" STEEL ARM DEAD END
 OFF 3Ø TANGENT ALLEY ARM





FIGURE 2

3Ø 102" STEEL ARM DEAD
 END OFF 3Ø TANGENT ARM

- Ⓐ LINE POST, CLAMP TOP INS
- Ⓑ LINE POST, VERTICAL TIE-TOP, WITH FORMED TIE WIRE.
- Ⓒ LINE POST, VERTICAL TIE TOP, MOUNTED HORIZONTALLY WITH FORMED TIE WIRE.

TIGHTEN BOLT AND
 LOCK NUT TO MAKE
 RIGID COUPLING
 SEE NOTE 5



DETAIL "A"

SLACK SPAN		
CONDUCTOR	MAXIMUM LENGTH	INITIAL SAG
568.3 ACAR	50'	3'-7"
3/0 AAAC	75'	2'-9"
1/0 AAAC	95'	2'-10"

NOTES:

1. ALL POST INSULATORS SHOWN ARE 35 kV TIE TOP OR CLAMP TOP. USE 45 kV POST INSULATORS ON 25 kV CIRCUITS IN SALT CONTAMINATED AREAS. USE 45KV POST TIE TOP POLYMER INSULATORS ON 23KV CIRCUITS IN SEVERE SALT CONTAMINATED AREAS.
2. PRIMARY TO NEUTRAL SEPARATION AT POLE IS DETERMINED BY MINIMUM MIDSPAN SEPARATION (DERM 4.4.1) IN NO CASE SHALL SEPARATION AT THE POLE BE LESS THAN 40" FOR WOOD OR CONCRETE POLES.
3. BASE OF INSULATOR MUST BE INSTALLED TIGHTLY AGAINST CROSSARM OR POLE.
4. ENGINEER TO SPECIFY SLACK SPAN SAG. (SEE DERM 4.4.5, 4.4.10).
5. INSTALL INSULATOR AND CLAMP AS SHOWN IN DETAIL "A" SUCH THAT WEIGHT ON OUTER END OF CLAMP WOULD TIGHTEN RATHER THAN LOOSEN BOLT.
6. ANY INSULATORS USED AS SLACK SPAN INSULATORS MUST HAVE LONG TRUNNION BOLTS.
7. FOR JUMPER SIZE INFORMATION SEE F-6.0.2.



OH & UG DISTRIBUTION SYSTEM STANDARDS

NO.	DATE	REVISION	ORIG.	DRAWN	APPR.
2	1/23/07	ADD TABLE	JNM	ELS	JJM
1	9/8/99	ADD REF TO 45KV POLYMER INSULATORS	JM	DLW	JJM
0	9/30/94	REVISED FIG 1 & 2 ADD BOLTED DEADEND CLAMP & NOTE 7	ARR	RAS	RJS

ORIGINATOR: ARR

DRAWN BY: RAS

DATE: 9/30/94

APPROVED: R. J. SALESKY

NO SCALE

DIRECTOR, DISTRIBUTION ENGINEERING
 AND OPERATIONS SERVICES

G-3.0.2

POLE GROUNDING

G-3.0.2




FIG. 3 CONCRETE POLE GROUNDING DETAIL




FIG. 4 DRILLING HOLE FOR GROUND ROD
 (USED ONLY WHEN DRIVING ROD IS IMPOSSIBLE)




FIG. 5 SPUN CONCRETE POLE GROUNDING DETAIL

NOTES:

8. UNGROUNDED HARDWARE WITHIN 2" OF GROUND WIRE OR OTHER GROUNDED HARDWARE SHOULD BE BONDED TO IT EXCEPT WHERE SPECIAL INSTRUCTIONS ARE GIVEN TO ISOLATE THE SAME.
9. DRIVEN GROUND RODS, WHERE POSSIBLE, SHOULD BE LOCATED TO AVOID INTERFERENCE WITH POSSIBLE FUTURE POLE REPLACEMENTS.
10. FOR GROUNDING REQUIREMENTS OF STREET LIGHT POLES SEE H-II.0.0 AND H-II.1.0 .
11. HOLE DIAMETER DEPENDS ON AVAILABILITY OF DRILL EQUIPMENT, WITH MAXIMUM 4" DIAMETER.
12. HOLE DEPTH DEPENDS ON ROCK DEPTH. DRILL ONLY AS DEEP AS NECESSARY TO GET THROUGH ROCK LAYERS, AND DRIVE ROD TO ADDITIONAL DEPTH NECESSARY TO ACHIEVE SPECIFIED RESISTANCE (MAXIMUM DEPTH, 40').
13. A LESSER DEPTH FOR THE CONCRETE CAP IS PERMITTED ONLY IF TOP SOIL CONDITIONS IN THE SOUTH FLORIDA AREA DO NOT PERMIT A FULL 3 FT. DEPTH.
14. GROUND LOOP SHOULD BE EXTENDED IF REQUIRED TO MAINTAIN MIN. 12" ABOVE FINAL GRADE.
15. BOTTOM OF LOOP MUST REMAIN SEPARATED FOR TEST PURPOSES.
16. LOOP TO BE INSTALLED ON EXISTING CONCRETE POLES DURING MAINTENANCE IF POSSIBLE AND PRACTICAL.

SUPERSEDES G-3.0.2 LAST REVISED ON 3-15-91

F P L
 OH & UG DISTRIBUTION SYSTEM STANDARDS

NO.	DATE	REVISION	ORIG.	DRAWN	APPR.
2	1/23/07	ADDED FIG 5 FOR SPUN CONCRETE POLE	RJO	ELS	JJM
1	9/30/94	REVISED MINIMUM GROUND DEPTH AND REMOVED OLD NOTE 14	JSB	MRB	RJS
0	3/15/91	ORIGINAL DRAWING	JSB	MRB	RJS

ORIGINATOR: JSB

DRAWN BY: MRB

DATE: 3/15/91

APPROVED: R.J. SALESKY
 DIRECTOR, DISTRIBUTION ENGINEERING
 AND OPERATIONS SERVICES

NO SCALE

H-4.0.0

**STREET LIGHT POLE WEIGHTS
 AND SETTING DEPTHS**

H-4.0.0

FIBERGLASS POLES

LENGTH OF POLE AND FINISH	M&S NUMBER	APPROXIMATE WEIGHT	MINIMUM SETTING DEPTH IN EARTH	MINIMUM SETTING DEPTH IN ROCK
20' WITH NATURAL FINISH	154-119-004	38 lbs.	4' - 6"	4' - 0"
13' WITH SMOOTH FINISH	154-118-008	23 lbs.	3' - 0"	3' - 0"

STANDARD CONCRETE POLES

LENGTH OF POLE AND TYPE	M&S NUMBER	APPROXIMATE WEIGHT	MINIMUM SETTING DEPTH IN EARTH	MINIMUM SETTING DEPTH IN ROCK
20' TYPE "O"	152-220-000	750 lbs.	4' - 6"	4' - 0"
35' TYPE "SU"	152-239-002	2,240 lbs.	7' - 6"	6' - 0"
35' TYPE "O"	152-225-001	2,240 lbs.	7' - 0"	6' - 0"
40' TYPE "IIIA"	152-351-007	4,674 lbs.	10' - 0"	8' - 0"
45' TYPE "IIIA"	152-352-003	4,924 lbs.	10' - 0"	8' - 6"
50' TYPE "IIIA"	152-353-000	5,324 lbs.	10' - 0"	8' - 6"

**DECORATIVE CONCRETE POLES
 (SEE NOTE 1)**

LENGTH OF POLE AND TYPE	M&S NUMBER	APPROXIMATE WEIGHT	MINIMUM SETTING DEPTH IN EARTH	MINIMUM SETTING DEPTH IN ROCK
18' - 6" WASHINGTON	152-230-005 152-231-508 152-231-605 152-231-700	970 lbs.	4' - 0"	4' - 0"
17' - 3" VICTORIAN	152-233-000 152-233-200 152-233-300	575 lbs.	4' - 3"	4' - 3"
37' OCTAGONAL	152-232-008	1,730 lbs.	7' - 0"	6' - 0"

NOTES:

- 1) THE USE OF A NYLON SLING IS REQUIRED FOR DECORATIVE CONCRETE POLES. THIS IS NECESSARY TO AVOID DAMAGING THE SURFACE OF POLES.
- 2) THE SETTING DEPTHS IN ROCK APPLY TO HOLES CONSISTING OF NOT LESS THAN 90% ROCK. THEY ARE ALSO APPLICABLE TO HOLES IN HARD CLAY.



F P L

OH & UG DISTRIBUTION SYSTEM STANDARDS

NO.	DATE	REVISION	ORIG.	DRAWN	APPR.
	1/9/07	UPDATE CHARTS	FLM	ELS	JJM
2	8/15/05	UPDATE CHARTS	SMS	ELS	JJM
1	6/29/05	UPDATE CHARTS	SMS	ELS	JJM
0	5/29/03	ORIGINAL DRAWING	SMS	ELS	JJM

ORIGINATOR: SMS DRAWN BY: ELS

DATE: 5/29/03 APPROVED: J.J. MCEVOY
 SUPERVISOR, OH/UG PRODUCT SUPPORT SERVICES NO SCALE

I-3.2.0

TRANSFORMER POLE WEIGHT LOADING

I-3.2.0

THE USUAL WIND-LOADING CALCULATIONS TO DETERMINE POLE CLASS REQUIREMENTS DO NOT CONSIDER PERMANENT LOAD SUCH AS A HEAVY TRANSFORMER. THIS TYPE OF LOAD CAN CAUSE A POLE TO BEND OR "BOW" OVER A PERIOD OF TIME, EVEN THOUGH CODE STRENGTH REQUIREMENTS ARE EXCEEDED BY A COMFORTABLE MARGIN, TO PREVENT THIS LONG-TERM DEFORMATION, THE TABLE AND CHART BELOW SHOULD BE USED TO DETERMINE THE MINIMUM CLASS OF POLE REQUIRED FOR A PARTICULAR TRANSFORMER WEIGHT. FOR INSTALLATION ON AN EXISTING POLE IN GOOD CONDITION, ONE CLASS SMALLER THAN INDICATED BELOW MAY BE USED.

WHERE LOAD GROWTH REQUIRING FUTURE TRANSFORMER REPLACEMENT CAN BE REASONABLY ANTICIPATED, A CLASS 3 POLE SHOULD BE THE MINIMUM SET FOR A TWO TRANSFORMER BANK.

IT WILL BE NOTED THAT AN OPEN DELTA BANK WILL, IN GENERAL, REQUIRE A LARGER POLE THAN CLOSED DELTA BANK. THIS IS CAUSED BY THE FACT THAT IN A CLOSED DELTA BANK THE TWO POWER TRANSFORMERS BALANCE EACH OTHER, AND CAUSE NO UNBALANCED MOMENT - AND IT IS THIS UNBALANCED MOMENT, NOT THE WEIGHT IN ITSELF, WHICH INITIATES POLE BOWING.

NOTE, HOWEVER, THAT THE INFORMATION BELOW CANNOT BE CONSIDERED A SUBSTITUTE FOR WIND LOADING CALCULATIONS. WIND LOADING SHOULD BE CONSIDERED SEPARATELY, AND THE METHOD DICTATING THE LARGER POLE SHOULD PREVAIL.

*NOTE - THE CHART AND TABLE BELOW ASSUME THE USE OF CLUSTER-MOUNTS. FOR ARM MOUNTED BANKS, TOTAL THE TRANSFORMER WEIGHT AND USE THE TABLE AS IF ALL WEIGHT WERE CONCENTRATED IN ONE TRANSFORMER.

EXAMPLES:

- a) ONE TRANSFORMER WEIGHING 1100 LB. REQUIRES A CLASS 4 POLE. (FROM TABLE)
- b) THREE CLUSTER MOUNTED TRANSFORMERS EACH WEIGHING 1100 LB. REQUIRE A CLASS 4 POLE. (FROM TABLE)
- c) ONE 1000 LB. AND ONE 400 LB. TRANSFORMER CLUSTER MOUNTED REQUIRES A CLASS 4 POLE. (EXAMPLE ON CHART)
- d) THREE ARM MOUNTED TRANSFORMERS EACH WEIGHING 600lb, REQUIRE A CLASS 2 POLE. (1800lb. TOTAL FROM TABLE)

**OPEN DELTA CLUSTER MOUNTED BANKS
POLE CLASS SELECTION CHART**




TABLE	
POLE CLASS	SINGLE TX. MAX. LBS.
5	900
4	1200
3	1500
2	2000

NOTE: STANDARD APPLIES TO OPEN DELTA CLUSTERS. ALL NEW CONSTRUCTION OR REPLACEMENT TRANSFORMER POLES WITH 3-100 KVA OR LARGER TRANSFORMERS TO BE TYPE III-H OR 4.7 KIP SPUN CONCRETE POLES AND ACCESSIBLE BY AERIAL EQUIPMENT. FOR INACCESSIBLE REPLACEMENT POLE USE A CLASS 2 WOOD POLE OR STRONGER.



OH & UG DISTRIBUTION SYSTEM STANDARDS

NO.	DATE	REVISION	ORIG.	DRAWN	APPR.
3	3/8/07	REMOVE REFERENCE TO 3 PHASE BANKS. INSERTED NOTE ON CONCRETE POLES.	RR	ELS	JRD
2	6/30/93	REVISE NOTES	ARR	JRG	RJS
1	1/29/92	ADDED CLASS 4 & 5 POLES	ARR	HO	RJS
0	1/29/92	ORIGINAL DRAWING	MLM	JRF	RKC

ORIGINATOR: MLM

DRAWN BY: JRF

DATE: 3/15/91

APPROVED: R.K. CIELO

NO SCALE

DIRECTOR, DISTRIBUTION ENGINEERING
AND SERVICE PLANNING

I-9.0.0

SINGLE PHASE STEPDOWN TRANSFORMER
 ON URD TERMINATOR POLE

I-9.0.0




FIG. 1




FIG. 2

ALTERNATE METHOD
 LOWERING TRANSFORMER
 AND TERMINATOR
 (SEE NOTE 2)




FIG. 3


ALTERNATE METHOD
 LOWERING TERMINATOR

TABLE 1

SIZE TX.	CONC. POLE TYPE REQ.	
	NEW	EXISTING
100 KVA		
167 KVA	ALL TYPE III OR BETTER	
333 KVA	ALL TYPE III OR BETTER	
1000 KVA	ALL TYPE III OR BETTER	

NOTES:

1. FRAMED ACCORDING TO FIG. 1, AN EXISTING TERMINATOR/ARRESTER NEED NOT BE RELOCATED. IF CLIMBING SPACE IS A CONCERN (AND SPACE PERMITS), LOWER THE TERMINATOR AND INSTALL THE TRANSFORMER ABOVE IT. SEE FIG. 3.
2. AUTO TRANSFORMER IS SHOWN (H2 & X2 COMMON TO ONE BUSHING), ON TWO WINDING TRANSFORMER, TIE H2 & X2 TOGETHER, AND GROUND.
3. #6 COPPER IS ADEQUATE TO CARRY THE CURRENTS INVOLVED. BECAUSE OF ITS MECHANICAL STRENGTH, #4 COPPER (OR BETTER) SHOULD BE USED FOR PRIMARY AND NEUTRAL JUMPERS.
4. VERTICAL CONFIGURATION AND A 333 KVA TRANSFORMER ARE SHOWN AS TYPICAL. ALL POLE MOUNTED STEP UP/DOWN TRANSFORMERS SHOULD HAVE MOUNTING LUGS COVERED IN DETAILS ON SHEET I-3. AVOID USING CLUSTER MOUNTS IF POSSIBLE (KEEP IT CLOSE TO POLE).
5. UNLESS OTHERWISE DIRECTED, PROTECT THE STEP DOWN TRANSFORMER WITH THE FOLLOWING FUSE SIZES AS A MINIMUM: 100 KVA, 8 AMP KS; 167 KVA, 15 AMP KS; 333 KVA, 25 AMP KS; 1000 KVA, 80 AMP KS ALSO SEE DCS I-19.0.0 AND I-19.2.0.
6. WHEN USED FOR OVERHEAD TO OVERHEAD TRANSFORMATION, THE MINIMUM FUSE SIZE IS 15 AMPS KS.
7. REFER TO I-53.1.3 FOR TRANSFORMER CONNECTION DIAGRAM.



OH & UG DISTRIBUTION SYSTEM STANDARDS

NO.	DATE	REVISION	ORIG.	DRAWN	APPR.
	2/14/07	REMOVED WOOD POLE CLASS REQ., ENGINEERS NOTE & NOTE 2	RR	ELS	JRD
3	9/16/05	UPDATE NOTE #6	IA	ELS	JJM
2	10/15/04	ADD ANIMAL GUARD	LFV	ELS	JJM
1	6/30/93	REDRAWN FROM MANUAL-COMBINED I-9.0.1 & I-9 SH. 2	MV	CB	RJS
0	3/1/89	ORIGINAL DRAWING	MV	CB	RJS

ORIGINATOR: MV

DRAWN BY: CB

DATE: 6/30/93


APPROVED: R.J. SALESKY
 DIRECTOR, DISTRIBUTION ENGINEERING
 AND OPERATIONS SERVICES

NO SCALE

I-10.0.0

**SINGLE PHASE
 LINE REGULATOR INSTALLATION
 (ALTERNATE METHOD)**

I-10.0.0



M&S NUMBER	REGULATOR KVA	CONC. POLE TYPE REQ.	
		NEW	EXISTING
327-070-004	76.2 (13 KV)		
327-102-003	167 (13 KV)		
327-100-001	144 (23 KV)		
327-102-500	288 (23 KV)		

NOTES:

- CROSSARM FRAMING SHOWN AS TYPICAL. MAY BE ADAPTED TO OTHER FRAMING AS REQUIRED.
- ONE PHASE OF THREE PHASE INSTALLATION ARE ILLUSTRATED. INSTALL A, B, & C PHASE REGULATORS ON THREE ADJACENT POLES.
- SOURCE AND LOAD SIDES MAY BE SWITCHED TO SUIT FIELD CONDITIONS. IN ANY EVENT "S" BUSHING MUST BE TAPPED SOURCE CONDUCTOR, AND "L" BUSHING TAPPED TO LOAD CONDUCTOR.
- DIMENSIONS SHOWN ASSUME CURRENTLY PURCHASED REGULATORS. OLDER MODELS MAY REQUIRE SOME DIMENSIONAL ADJUSTMENTS.
- INSULATOR USED WHEN CONNECTING TO MIDDLE PHASE.

SUPERSEDES I-10.0.0 LAST REVISED ON 1-29-92



OH & UG DISTRIBUTION SYSTEM STANDARDS

REMOVED WOOD POLE CLASS REQ.,
 ENGINEERS NOTE & NOTE 5, CHANGED
 POLE SYLE CONCRETE

NO.	DATE	REVISION	RR	ELS	JRD
3	10/15/04	ADD ANIMAL GUARD	LFV	ELS	JJM
2	5/22/01	ADDED CASE GROUND	GJP	JES	IA
1	7/23/99	UPDATE DRAWING REMOVE SOME TEXT	WPC	JES	JM
0	6/30/93	ORIGINAL REDRAWN-REVISED M&S NO. FOR BY-PASS SWITCH	IA	CL	FOR
NO.	DATE	REVISION	ORIG.	DRAWN	APPR.

ORIGINATOR: IA

DRAWN BY: CL

DATE: 6/30/93

APPROVED: R.J. SALESKY
 SUPERVISOR, OH/UG PRODUCT
 SUPPORT SERVICES

NO SCALE

I-51.0.0

WYE-CLOSED DELTA BANK
 13 & 23KV
 MODIFIED VERTICAL CONSTRUCTION

I-51.0.0




FIGURE 1





FIGURE 2

NOTES:

1. SEE SHEETS I-53.1.1 FOR SCHEMATIC DIAGRAMS OF TRANSFORMER CONNECTIONS.
2. DOUBLE PRIMARY BUSHING TRANSFORMERS ILLUSTRATED. FOR DETAILS OF SINGLE OR DOUBLE BUSHING GROUNDING. SEE SHEET I-5.0.0.
3. THE STRAP CONNECTING THE LOW VOLTAGE NEUTRAL TERMINAL TO THE TANK MUST BE REMOVED ON THE POWER TRANSFORMERS
4. SEE SECTION G-3.0.1 FOR GROUNDING DETAILS.
5. ALL NEW CONSTRUCTION OR REPLACEMENT TRANSFORMER POLES WITH 3-100 KVA OR LARGER TRANSFORMERS TO BE TYPE III-H OR 4.7 KIP SPUN CONCRETE POLES AND ACCESSIBLE BY AERIAL EQUIPMENT. FOR INACCESSIBLE REPLACEMENT POLE USE A CLASS 2 WOOD POLE OR STRONGER.



OH & UG DISTRIBUTION SYSTEM STANDARDS

NO.	DATE	REVISION	ORIG.	DRAWN	APPR.
2	3/8/07	INSERTED NOTE 5	RR	ELS	JRD
1	7/03/01	INCREASED MIN. DIMENSION	GJP	JES	IA
0	9/30/94	ORIGINAL DRAWING	ARR	RAS	RJS

ORIGINATOR: ARR

DRAWN BY: RAS

DATE: 9/30/94


APPROVED: R.J. SALESKY
 SUPERVISOR, OH/UG PRODUCT
 SUPPORT SERVICES

NO SCALE


I-52.0.0

WYE-WYE BANK
 13 & 23KV
 CROSSARM CONSTRUCTION

I-52.0.0



FRONT




SIDE

NOTES

1. SEE SHEET I-3.2.0 FOR POLE CLASS REQUIRED.
2. SEE SHEET I-53.1.1 FOR SCHEMATIC DIAGRAM OF TRANSFORMER CONNECTIONS.
3. SEE PAGE I-3.0.0 FOR DETAILS OF CLUSTER BRACKET INSTALLATION.
4. SEE SECTION "G" FOR GROUNDING DETAILS.
5. IN SALT SPRAY CONTAMINATED AREAS BOND ALL STEEL PINS AND MOUNTING BRACKETS, USE SALT SPRAY ARRESTERS AND CUTOUTS AND INSTALL SALT SPRAY TYPE TRANSFORMERS.
6. THE GROUNDING STRAP FROM THE LOW VOLTAGE NEUTRAL BUSHING TO THE TANK MUST BE REMOVED ON ALL THREE TRANSFORMERS.
7. ALL NEW CONSTRUCTION OR REPLACEMENT TRANSFORMER POLES WITH 3-100 KVA OR LARGER TRANSFORMERS TO BE TYPE III-H OR 4.7 KIP SPUN CONCRETE POLES AND ACCESSIBLE BY AERIAL EQUIPMENT. FOR INACCESSIBLE REPLACEMENT POLE USE A CLASS 2 WOOD POLE OR STRONGER.

SUPERSEDES I-52.0.0 LAST REVISED ON 3-1-89



OH & UG DISTRIBUTION SYSTEM STANDARDS

NO.	DATE	REVISION	ORIG.	DRAWN	APPR.
	3/8/07	INSERTED NOTE 7	RR	ELS	JRD
	7/03/01	INCREASED MIN. DIMENSION	GJP	JES	JA
2	9/30/94	ADDED DIMENSION TEXT	ARR	PTH	RJS
1		CHANGED SPOOLS	ARR	EF	RJS
0	5/13/93	REDRAWN FROM MANUAL AND ADDED NEW FRAME	MV	EMH	RJS

ORIGINATOR: MV

DRAWN BY: EMH

DATE: 5/13/93

APPROVED: R.J. SALESKY


NO SCALE

SUPERVISOR, OH/UG PRODUCT SUPPORT SERVICES

I-52.0.2


WYE-WYE BANK
 13 & 23KV
 MODIFIED VERTICAL CONSTRUCTION

I-52.0.2



NOTES:

1. DOUBLE PRIMARY BUSHING TRANSFORMERS ILLUSTRATED, FOR DETAILS OF SINGLE OR DOUBLE BUSHING GROUNDING. SEE SHEET I-5.0.0
2. THE STRAP CONNECTING THE LOW VOLTAGE NEUTRAL TERMINAL TO THE TANK MUST BE REMOVED ON ALL THREE TRANSFORMERS.
3. SEE SHEET I-3.2.0 FOR POLE CLASS REQUIRED.
4. SEE SHEET I-53.1.1 FOR SCHEMATIC DIAGRAM ON TRANSFORMER CONNECTIONS.
5. SEE PAGE I-3 FOR DETAILS OF CLUSTER BRACKET INSTALLATION.
6. SEE SECTION "C" FOR GROUNDING DETAILS.
7. IN SALT SPRAY CONTAMINATED AREAS BOND ALL BOLTS AND METAL MOUNTING BRACKETS.
8. ALL NEW CONSTRUCTION OR REPLACEMENT TRANSFORMER POLES WITH 3-100 KVA OR LARGER TRANSFORMERS TO BE TYPE III-H OR 4.7 KIP SPUN CONCRETE POLES AND ACCESSIBLE BY AERIAL EQUIPMENT. FOR INNACCESSIBLE REPLACEMENT POLE USE A CLASS 2 WOOD POLE OR STRONGER.



OH & UG DISTRIBUTION SYSTEM STANDARDS

NO.	DATE	REVISION	ORIG.	DRAWN	APPR.
3	10/20/05	ADD ARRESTERS TO TRANSFORMER TANKS	IA	ELS	JRD
2	10/18/04	ADD ANIMAL GUARD	LFV	ELS	JJM
1	7/03/01	INCREASED MIN. DIMENSION	GJP	JES	IA
0	9/30/94	ORIGINAL DRAWING	ARR	MRB	RJS

ORIGINATOR: ARR
 DRAWN BY: MRB
 DATE: 9/30/94
 APPROVED: R.J. SALESKY
 SUPERVISOR, OH/UG PRODUCT SUPPORT SERVICES
 NO SCALE

J-1.0.2

**CAPACITOR BANKS
 GENERAL**

J-1.0.2

CUTOUTS AND FUSING

FOR NEW INSTALLATIONS FUSED AT 80K OR LESS, 100 AMP CUTOUTS SHALL BE USED. EXISTING 200 AMP CUTOUTS SHOULD REMAIN IN SERVICE AS LONG AS THEY ARE IN GOOD CONDITION. (FUSES RATED AT 100 AMPS OR LESS, AND USED IN A 200 AMP. BARREL, REQUIRE A SPECIAL 200 AMP BUTTONHEAD. M&S #531-8100-5). IF THE FUSE TUBE ON AN EXISTING CUTOUT NEEDS TO BE REPLACED, THEN THE ENTIRE CUTOUT SHALL BE CHANGED OUT TO 100 AMPS.

CUTOUT INSTALLATION RECOMMENDATIONS

TO MINIMIZE CORROSION ON CONTACTS, CUTOUT FUSE BARRELS MUST ALWAYS REMAIN CLOSED WHEN THE BANK IS DE-ENERGIZED.

DO NOT WIREBRUSH THE CONTACTS ON THE CUTOUTS. THIS MAY DESTROY THE CONTACT PLATING AND LEAD TO POOR PERFORMANCE.

DO NOT USE INHIBITOR PASTE ON THE CONTACTS. ONLY APPROVED SWITCH LUBRICANT SHOULD BE USED WHEN REQUIRED.

FUSING TABLES

13 KV

PROTECTED BY STATION BREAKER

BANK SIZE (3 PHASE KVAR)	FUSE	FUSE M&S #
1200 KVAR	65 K	531-81300-4
600 KVAR	50 K	531-81200-8
300 KVAR	40 K	531-81700-0

23 KV

PROTECTED BY STATION BREAKER

BANK SIZE (3 PHASE KVAR)	FUSE	FUSE M&S #
1200 KVAR	40 K	531-81700-0
600 KVAR	40 K	531-81700-0

**LARGEST SIZE OF THREE-PHASE CAPACITOR
 BANK BEYOND A RECLOSER.**

PROTECTED BY RECLOSER (13KV)

BEYOND RECLOSER	GROUND TRIP SETTING	FUSE SIZE	MAX KVAR (3ø)	FUSE M&S #
160 RX	-	65 K	1200	531-81300-4
	154	50 K	600	531-81200-8
140 RX	-	65 K	1200	531-81300-4
	110	40 K	300	531-81700-0
	154	50 K	600	531-81200-8
100 RX	-	50 K	600	531-81200-8
	110	40 K	300	531-81700-0
70 RX	-	40 K	300	531-81700-0

PROTECTED BY RECLOSER (23KV)

BEYOND RECLOSER	GROUND TRIP SETTING	FUSE SIZE	MAX KVAR (3ø)	FUSE M&S #
160 RV THROUGH 70 RV	ALL VALUES	40 K	1200	531-81700-0

MOUNTING INSTALLATION:

ALL NEW OH CAPACITOR BANKS MUST BE INSTALLED ON CLASS III-H CONCRETE POLE OR EQUIVALENT.

SUPERSEDES J-1.0.2 LAST REVISED ON 6-22-95



OH & UG DISTRIBUTION SYSTEM STANDARDS

ORIGINATOR: VA

DRAWN BY: RAS

DATE: 8/9/96

APPROVED: J.J. MCEVOY

NO SCALE

SUPERVISOR, OH/UG PRODUCT
 SUPPORT SERVICES


NO.	DATE	REVISION	ORIG.	DRAWN	APPR.
1	12/5/06	ADD MOUNTING INSTALLATION NOTES	LFV	ELS	JJM
0	8/9/96	GENERAL REVISIONS	IA	RAS	JJM

J-2.0.2

300, 600, AND 1200 KVAR CAPACITOR BANKS
 USING SINGLE PHASE
 100 200, AND 400 KVAR UNITS
 13 AND 23 KV

J-2.0.2



MODIFIED VERTICAL CONSTRUCTION



9' WOOD ARM SHOWN AS TYPICAL. 64" OR 8" STEEL CROSS ARM MAY BE USED AS APPROPRIATE

ANIMAL GUARD

SEE CONSTRUCTION NOTES ON J-2.0.3



TO FUSE SWITCH SIMILAR TO J-2.0.3 FIGURE 3

OVERHEAD GROUNDWIRE VERTICAL CONSTRUCTION

NOTE:

1. ARRESTERS MUST BE CONNECTED SUCH THAT IN THE EVENT OF FAILURE, (DISCONNECTOR OPERATION) THE GROUND LEAD WILL NOT COME IN CLOSE PROXIMITY TO ENERGIZED CONDUCTORS OR EQUIPMENT.
2. POLE MUST BE CLASS III-H CONCRETE OR EQUIVALENT.

SUPERSEDES J-2.0.2 LAST REVISED ON 6-22-95



F P L

OH & UG DISTRIBUTION SYSTEM STANDARDS

NO.	DATE	REVISION	ORIG.	DRAWN	APPR.
4	12/5/06	UPDATE NOTES	LFV	ELS	JJM
3	10/18/04	ADD ANIMAL GUARD	LFV	ELS	JJM
2	07/27/01	UPDATE DRAWING (ADD NOTE)	LFV	JES	JJM
1	08/09/96	GENERAL REVISION	IA	RAS	JJM

ORIGINATOR: IA

DRAWN BY: RAS

DATE: 06/22/95

APPROVED: J.J. MCEVOY
 SUPERVISOR, OH/UG PRODUCT SUPPORT SERVICES

NO SCALE

J-2.0.3

300, 600, AND 1200 KVAR CAPACITOR BANK
 USING SINGLE PHASE
 100, 200, AND 400 KVAR UNITS
 13 AND 23 KV

J-2.0.3

MODIFIED VERTICAL CONSTRUCTION
 CAPACITOR BANKS EQUIPPED WITH POTENTIAL TRANSFORMERS





FIGURE 1

MODIFIED VERTICAL CONSTRUCTION

NOTES:

1. FOR FIXED BANKS, FUSE SWITCHES MUST BE INSTALLED ON OPPOSITE SIDE OF CAPACITOR BANK.
2. PORCELAIN ARRESTERS MUST ALWAYS REMAIN ENERGIZED EVEN WHEN THE BANK IS TAKEN OUT OF SERVICE, FOR LONG PERIODS.
3. EXISTING TRANSFORMER SERVICE FOR SWITCHED BANKS MUST NOT EXCEED 300 FEET. IF TRANSFORMER SERVICE IS NOT AVAILABLE WITHIN 300 FEET OR LESS USE CAPACITOR BANK EQUIPPED WITH RACK MOUNTED PT. SEE J-1.0.1 FOR M&S NUMBERS. DUE TO VOLTAGE REQUIREMENTS, FOR BANK SERVICES GREATER THAN 175 FEET USE #2 TRIPLEX INSTEAD OF #6 DUPLEX. FOR POTENTIAL REQUIREMENTS FOR CONTROLS OTHER THAN TIME OR RADIO CONSULT PLANNING DEPARTMENT.
4. FOR CONTROL CIRCUIT WIRING SEE J-3.0.2.
5. CLEARANCES SHOWN BETWEEN DEVICE ARM AND CAPACITOR BANK ARE RECOMMENDED FOR OPERATIONAL PURPOSES ONLY. REFER TO APPROPRIATE T&D PROCEDURES AND THE CAPACITOR SECTION OF SWITCHING MANUAL FOR INFORMATION PERTAINING TO SWITCHING CAPACITOR BANKS.
6. USE 9' ARM FOR ALL NEW CONSTRUCTION.
7. FOR 13KV AND 23KV APPLICATIONS, USE 3/4 A X FUSE M&S #531-600000-1 FOR RACK MOUNTED PT M&S #461-08813-0 (13KV) OR M&S #461-08823-7 (23KV).
8. THE CAPACITORS AND RACK SHALL BE GROUNDED PER THE BONDING NOTE ON J-1.0.1 AND THE PT SHALL BE GROUNDED PER I-5.0.0
9. POLE MUST BE CLASS III-H CONCRETE OR EQUIVALENT

SUPERSEDES J-2.0.3 LAST REVISED ON 6/22/95



OH & UG DISTRIBUTION SYSTEM STANDARDS

NO.	DATE	REVISION	ORIG.	DRAWN	APPR.
5	12/5/05	ADD NOTE 9	LFV	ELS	JJM
	10/18/04	ADD ANIMAL GUARDS	LFV	ELS	JJM
4	7/18/03	UPDATE DWG & REVISED NOTE 7	LFV	ELS	JJM
3	07/27/01	REVISED NOTES 2 AND 8	LFV	JES	JJM
2	9/22/99	REVISED NOTES 8 AND 8	LFV	JES	JJM
1	8/09/96	PLACED DRAWING IN REVISED FRAME	IA	RAS	JJM

ORIGINATOR: IA

DRAWN BY: RAS

DATE: 6/22/95


APPROVED: J.J. MCEVOY
 SUPERVISOR, OH/UG PRODUCT
 SUPPORT SERVICES

NO SCALE

K-28.0.0

OUTDOOR PRIMARY METERING
 INSTALLATION 13 & 23 KV
 CLUSTER MOUNTED UNDERGROUND SERVICE

K-28.0.0




NOTES:

1. THIS TYPE CONSTRUCTION CAN BE USED ON WOOD OR CONCRETE POLES. ON WOOD POLES WHICH NEED NOT BE CLIMBED, CONSTRUCTION MAY BE AS SHOWN ABOVE CONCRETE POLE. ON WOOD POLES WHICH MUST BE CLIMBED, PROTECTIVE DEVICES SHOULD BE CROSSARM MOUNTED TO FACILITATE OPERATION. REPLACEMENT POLES TO BE TYPE III-H OR 4.7 KIP SPUN CONCRETE POLES. FOR INACCESSIBLE REPLACEMENT POLE USE A CLASS 2 WOOD POLE.
2. ALL CONDUIT, METER CABINETS, RACK AND ONE PRIMARY TERMINAL OF PT'S TO BE GROUNDED TO SYSTEM NEUTRAL.
3. METER CABINET AND CONDUIT MAY BE MOUNTED ON ANY QUARTER OF POLE AS NECESSARY TO CLEAR OTHER EQUIPMENT.
4. PT'S ARE TO BE TAPPED TO LINE SIDE.
5. PLEASE SEE K-28.1.1 FOR WIRING DETAILS
6. PREFERRED INSTALLATION IS TO RUN URD PRIMARY TO PAD MOUNTED PRIMARY METER.

ITEM	DESCRIPTION	M & S NUMBER
1	15 KV, 3 POSITION PRI METERING MOUNTS	420-71000-6
2	25 KV, 3 POSITION PRI METERING MOUNTS	420-71010-3
3	9/C CONTROL CABLE-NON METALLIC LIQUID-TITE	422-42000-5
4	UT8 CABINET	420-00098-0
5	1 INCH PVC SCHEDULE 40	164-27500-9
6	1-1/4 INCH PVC SCHEDULE 40	164-27600-5

SUPERSEDES K-28 LAST REVISED ON 2-28-72



OH & UG DISTRIBUTION SYSTEM STANDARDS

ORIGINATOR: EM

DRAWN BY: E. HESS

DATE: 7/28/72

APPROVED: R.J. SALESKY
 DIRECTOR, DISTRIBUTION ENGINEERING
 AND OPERATIONS SERVICES


NO SCALE

NO.	DATE	REVISION	ORIG.	DRAWN	APPR.
6	2/23/07	UPDATE NOTE 1 & ADD NOTE 6	JNM	ELS	JJM
5	10/19/04	ADD ANIMAL GUARDS	LFV	ELS	JJM
4	9/5/03	UPDATE DRAWING	JFD	ELS	JJM
3	8/16/01	UPDATE DRAWING (TEXT AND CHART)	JFD	JES	JJM
2	10/6/99	MOVE UBT CAN AND UPDATE WIRING	JFD	JES	JJM
1	6/30/93	UPDATE ORIGINAL DRAWING	EM	EH	RJS
NO.	DATE	REVISION	ORIG.	DRAWN	APPR.

K-28.1.0

**OUTDOOR PRIMARY METERING
 INSTALLATION 13 & 23 KV - CLUSTER
 MOUNTED OVERHEAD SERVICE**

K-28.1.0



NOTES: POST INSULATOR CONSTRUCTION

1. THIS TYPE CONSTRUCTION CAN BE USED ON WOOD OR CONCRETE POLES. ALL NEW CONSTRUCTION OR REPLACEMENT POLES TO BE TYPE III-H OR 4.7 KIP SPUN CONCRETE POLES. FOR INACCESSIBLE REPLACEMENT POLE USE A CLASS 2 WOOD POLE.
2. ALL CONDUIT, METER CABINETS, RACK AND ONE PRIMARY TERMINAL OF PT'S TO BE GROUNDED TO SYSTEM NEUTRAL.
3. METER CABINET AND CONDUIT MAY BE MOUNTED ON ANY QUARTER OF POLE AS NECESSARY TO CLEAR OTHER EQUIPMENT.
4. PT'S ARE TO BE TAPPED TO LINE SIDE.
5. PLEASE SEE K-28.1.1 FOR WIRING DETAILS
6. FUSE SWITCHES OR DISCONNECT SWITCHES ARE TO BE INSTALLED ON THE LINE SIDE AHEAD OF THIS POLE.

NO.	DATE	REVISION	ORIG.	DRAWN	APPR.
7	2/23/07	REVISE NOTE 1	JNM	ELS	JJM
6	10/19/04	ADD ANIMAL GUARDS	LFV	ELS	JJM
5	10/30/03	UPDATE DRAWING	JFD	ELS	JJM
4	9/5/03	UPDATE DRAWING	JFD	ELS	JJM
3	7/23/01	UPDATE DRAWING (TEXT)	RAP	JES	JJM
2	10/6/99	MOVE UBT CAN AND UPDATE WIRING	JFD	JES	JJM
1	6/30/93	REDRAWN ON CAD ADD CABINETS	EM	EH	RJS



OH & UG DISTRIBUTION SYSTEM STANDARDS

ORIGINATOR: EM

DRAWN BY: E. HESS

DATE: 2/28/72

APPROVED: R.J. SALESKY
 DIRECTOR, DISTRIBUTION ENGINEERING
 AND OPERATIONS SERVICES

NO SCALE

K

M-2.0.0


DISTRIBUTION CIRCUITS ON
 TRANSMISSION POLES
 UNIVERSAL SPUN CONCRETE POLE

M-2.0.0

The universal pole has holes arranged as shown below. The Universal pole is designed specifically with the holes shown. NO additional holes can be added either in the field or the manufacturing stage. This hole arrangement will allow for standard distribuion framing:


1. Vertical with 36" separation between Phases
2. Tangent on 8'-6" Steel Crossarm
3. Tangent on 8'-6" Steel Alley Arm
4. Single phase Transformer
5. Lightning arrester Station

NOTE: UNIVERSAL POLES CANNOT BE FIELD DRILLED. Universal pole can be identified in the field by the M&S number on the pole brand. The universal pole M&S number starts with 155.



IN LINE
 "L" FACE

TRANSVERSE
 "S" FACE



OH & UG DISTRIBUTION SYSTEM STANDARDS

NO.	DATE	REVISION	ORIG.	DRAWN	APPR.
3	2/14/07	UPDATE DRAWING (TEXT)	JNM	ELS	JJM
2	3/15/04	UPDATE DRAWING (TEXT)	JNM	ELS	JJM
1	9/8/03	ORIGINAL DRAWING	JNM	ELS	JJM

ORIGINATOR: JNM DRAWN BY: ELS
 DATE: 9/8/03 APPROVED: J.J. MCEVOY
 SUPERVISOR, OH/UG PRODUCT SUPPORT SERVICES NO SCALE

M

UH-15.0.0

PRIMARY AND FEEDER RISER POLE
 POST INSULATOR AND VERTICAL
 DEADEND CONSTRUCTION

UH-15.0.0




FIG. 1
 STANDARD ARRANGEMENT ON TANGENT POLE




FIG. 2
 VERTICAL DEADEND CONSTRUCTION
 WOOD OR CONCRETE POLE (SEE NOTE 8&9)

NOTES:

1. FOR BONDING AND GROUNDING DETAILIS REFER TO SECTION "G".
2. INDIVIDUAL ARRESTER GROUND LEADS MUST BE LONG ENOUGH TO PERMIT PROPER OPERATION OF ISOLATOR.
3. PVC U-GUARD RISER SHOULD BE LOCATED ON POLE TO LEAVE SPACE FOR FUTURE STREET LIGHT BRACKETS.
4. PHASE IDENTIFICATION OF SWITCHES AND TERMINATORS SHOULD BE DETERMINED BY THE ASSOCIATED LINE CONDUCTORS RATHER THAN BY GEOGRAPHICAL LOCATION.
5. ADJUST MOUNTING ANGLE OF ARRESTERS SO SPACING BETWEEN LIVE PARTS IS 12" MIN.
6. USE ONLY DISCONNECT SWITCHES WITH 90° STOPS.
7. EACH ARRESTER GROUND LEAD SHOULD BE INDIVIDUALLY ATTACHED TO POLE BOND.
8. ALL NEW CONSTRUCTION OR REPLACEMENT "01" FEEDER SWITCH POLES TO BE TYPE III-H OR 4.7 KIP SPUN CONCRETE POLES AND ACCESSIBLE BY AERIAL EQUIPMENT. FOR INACCESSIBLE REPLACEMENT POLE USE A CLASS 2 WOOD POLE OR STRONGER.
9. ALL NEW CONSTRUCTION FEEDER SWITCH POLES ARE TO BE ACCESSIBLE.

SUPERSEDES UH-15.0.0 LAST REVISED ON 9-30-94



OH & UG DISTRIBUTION SYSTEM STANDARDS

ORIGINATOR: PMG

DRAWN BY: RAS

DATE: 9/30/94

APPROVED: JOSE R. DIAZ
 SUPERVISOR, OH/UG PRODUCT
 SUPPORT SERVICES

NO SCALE


NO.	DATE	REVISION	ORIG.	DRAWN	APPR.
7	2/27/07	ADD NOTE 8 AND 9	JJM	ELS	JJM
	9/17/03	UPDATE DRAWING	CEA	ELS	JJM
	9/17/03	ADD ANIMAL GUARDS	LFV	ELS	JJM
4	8/27/03	UPDATE DRAWING (NOTES)	LFV	ELS	JJM
3	6/18/03	UPDATE DRAWING (NOTES)	LFV	ELS	JJM
2	8/07/01	UPDATE DRAWING (TITLE AND DIMENSIONS)	RCB	JES	JJM
1	8/09/96	CHANGED PORCELAIN SUSPENSION INSULATORS TO POLYMER AND ADDED NEW MOUNTING BRACKET.	PMG	RAS	JJM

UH-15.3.1


THREE PHASE FEEDER RISER
 1000 KCMIL 15 OR 25 KV CABLE
 FOR SALT SPRAY AND NON SALT SPRAY AREAS

UH-15.3.1

PROCEDURE 49	MIU N°	MECA INVENTORY UNIT (PKG)								QUANTITY
		A	B	C	D	E	F	G	H	
09.3	1	D	S	H	R					1



* = GROUND WIRE IS ON LINE FACE, BUT IS SHOWN HERE FOR CLARITY.



NOTES:

1. ALL NEW CONSTRUCTION OR REPLACEMENT "01" FEEDER SWITCH POLES TO BE TYPE III-H OR 4.7 KIP SPUN CONCRETE POLES AND ACCESSIBLE BY AERIAL EQUIPMENT. FOR INACCESSIBLE REPLACEMENT POLE USE A CLASS 2 WOOD POLE OR STRONGER.
2. ALL NEW CONSTRUCTION FEEDER SWITCH POLES ARE TO BE ACCESSIBLE.
3. U-GUARD INSTALLATION SEE UH-14.0.1, UH-14.0.2 DETAILS.
4. FOR BONDING AND GROUNDING, SEE G-9.0.1 PVC U-GUARD DOES NOT REQUIRE BONDING.
5. INSTALL PVC U-GUARD ON POLE QUADRANTS OPPOSITE TRAFFIC FLOW WHENEVER POSSIBLE.
6. INVENTORY UNITS DO NOT INCLUDE PVC U-GUARD RISER.
7. PULL UNITS REQUIRED FOR PRIMARY CONDUCTORS. SEE MECA PROCEDURE 4931.1 FOR EXPLANATION.
8. ILLUSTRATIONS ARE PROPORTIONALLY DRAWN. PRODUCT CONFIGURATION MAY VARY PER SUPPLIER. DIMENSIONS SHALL TAKE PRECEDENCE.

MAJOR MATERIAL

3	SWITCHES
1	SWITCH BRACKET
1	POTHEAD EXTENSION BRACKET
1	L.A. BRACKET
3	TERMINATORS
3	ZINC OXIDE RISER POLE ARRESTERS
3	SINGLE SPOOLS, 2-1/2"
3	U-SUPPORTS
3	BRAIDS
3	GROUND STUDS

NON-SALT SPRAY AREAS

15 KV		25 KV	
270-38800-4	270-38800-4	270-38800-4	270-38800-4
141-18200-4	141-18200-4	141-18200-4	141-18200-4
163-47400-8	163-47400-8	163-47400-8	163-47400-8
334-55100-4	334-55100-4	334-55100-4	334-55100-4
163-51100-1	163-51100-1	163-51100-1	163-51100-1
334-22100-4	334-22800-9	334-22100-4	334-22800-9
160-30600-7	160-30600-7	160-30600-7	160-30600-7
161-50700-6	161-50700-6	161-50700-6	161-50700-6
103-92000-1	103-92000-1	103-92000-1	103-92000-1
122-65000-6	122-65000-6	122-65000-6	122-65000-6

SALT SPRAY AREAS

15 KV		25 KV	
270-39000-9	270-39000-9	270-39000-9	270-39000-9
141-18200-4	141-18200-4	141-18200-4	141-18200-4
163-47400-8	163-47400-8	163-47400-8	163-47400-8
334-55100-4	334-55100-4	334-55100-4	334-55100-4
163-51100-1	163-51100-1	163-51100-1	163-51100-1
334-22100-4	334-22800-9	334-22100-4	334-22800-9
160-30600-7	160-30600-7	160-30600-7	160-30600-7
161-50700-6	161-50700-6	161-50700-6	161-50700-6
103-92000-1	103-92000-1	103-92000-1	103-92000-1
122-65000-6	122-65000-6	122-65000-6	122-65000-6

* TERMINATOR 163-51100-1 CAN BE UTILIZED IN EITHER SALT SPRAY OR NON-SALT SPRAY AREAS.

SUPERSEDES UH-15-3-1 LAST REVISED ON 6-30-93

F P L

OH & UG DISTRIBUTION SYSTEM STANDARDS

ORIGINATOR: RWS

DRAWN BY: RAS

DATE: 6/30/93

APPROVED: R.J. SALESKY

NO SCALE

DIRECTOR, DISTRIBUTION ENGINEERING AND OPERATIONS SERVICES

NO.	DATE	REVISION	ORIG.	DRAWN	APPR.
4	2/27/07	REVISE NOTES & ADD NOTE 1 & 2	JNM	ELS	JJM
3	9/18/03	ADD ANIMAL GUARDS	LFV	ELS	JJM
2	8/27/03	UPDATE NOTE 2	LFV	ELS	JJM
1	9/30/94	REVISED SWITCH M&S NO., RESIZED DRAWING TO FIT & ADDED BORDER	RWS	RAS	RJS

Z-12.0.1

SPUN CONCRETE POLE
 POLE DIAMETER AND WEIGHT

Z-12.0.1

Spun Concrete Poles Dimensions				Spun Concrete Poles Approximate Weights in Pounds	
Distance From Top of Pole in Feet	50' and 55' Spun Concrete Pole	60' and 65' Spun Concrete Pole	70' Spun Concrete Pole	Length of Pole	Pole Weights
	Outside Dia. (Inches)	Outside Dia. (Inches)	Outside Dia. (Inches)		
0 (Top)	9.55	11.35	11.07	50'	5,650
2	9.91	11.71	11.50	55'	6,410
4	10.27	12.07	11.93	60'	8,770
6	10.63	12.43	12.37	65'	9,790
8	10.99	12.79	12.80	70'	12,230
10	11.35	13.15	13.23		
12	11.71	13.51	13.66		
14	12.07	13.87	14.09		
16	12.43	14.23	14.53		
18	12.79	14.59	14.96		
20	13.15	14.95	15.39		
22	13.51	15.31	15.82		
24	13.87	15.67	16.25		
26	14.23	16.03	16.69		
28	14.59	16.39	17.12		
30	14.95	16.75	17.55		
32	15.31	17.11	17.98		
34	15.67	17.47	18.41		
36	16.03	17.83	18.85		
38	16.39	18.19	19.28		
40	16.75	18.55	19.71		
42	17.11	18.91	20.14		
44	17.47	19.27	20.57		
46	17.83	19.63	21.01		
48	18.19	19.99	21.44		
50	18.55	20.35	21.87		
52	18.91	20.71	22.30		
54	19.27	21.07	22.73		
56	19.63	21.43	23.17		
58		21.79	23.60		
60		22.15	24.03		
62		22.51	24.46		
64		22.87	24.89		
66		23.23	25.33		
68			25.76		
70			26.19		
Taper (in/ft)	0.18	0.18	0.216		

NOTE: POLE BRAND IS LOCATED 20' FROM THE BUTT OF THE POLE ON ALL SIZES.



OH & UG DISTRIBUTION SYSTEM STANDARDS

ORIGINATOR: RJO

DRAWN BY: E.SCHILLING

NO.	DATE	REVISION	ORIG.	DRAWN	APPR.
2	12/18/06	UPDATE CHART	RJO	ELS	JJM
1	6/7/06	ORIGINAL	RJO	ELS	JJM

DATE: 6/7/06

APPROVED: J.J. McEVOY

NO SCALE

SUPERVISOR, OH / UG PRODUCT
 SUPPORT SERVICES

Z

ADDENDUM

**TO FPL'S PERMIT APPLICATION PROCESS MANUALS,
ATTACHMENT AGREEMENTS AND JOINT USE AGREEMENTS**

FPL ATTACHMENT STANDARDS AND PROCEDURES

MAY 4, 2007

TABLE OF CONTENTS

I.	SAFETY	4
II.	STANDARDS	5
	A. ATTACHMENT CRITERIA	5
	B. ATTACHMENT CLEARANCES	7
	C. WINDLOADING CRITERIA AND CALCULATIONS	9
III.	PROCEDURES	46
	A. PROCEDURES FOR JOINT USERS	47
	B. PROCEDURES FOR THIRD PARTIES (CATV AND TELECOM)	48
	C. PROCEDURES FOR GOVERNMENTAL ATTACHMENTS	50
	D. PROCEDURES FOR ATTACHMENTS TO TRANSMISSION POLES	51

I. SAFETY

SAFETY

It is the responsibility of the attacher to ensure that all persons involved with the application for attachment to FPL poles, and all persons involved with the field engineering, design, installation, construction and ongoing maintenance of these attachments, comply with all applicable federal, state and local safety laws and regulations including the Occupational Safety and Health Act, the National Electrical Safety Code (NESC), any requirements of FPL and any additional safety requirements requested by FPL.

It is also the responsibility of the attacher to warn its employees and contractors that electrical facilities are high voltage facilities and to inform these persons as to safety and precautionary measures which he or she must use when working on or near FPL poles and other facilities.

Proper guying of cables must be accomplished by the attacher.

To ensure that poles are always accessible for workers, particularly in locations inaccessible to bucket trucks, cable risers installed on FPL poles must not interfere with climbing space on the pole.

In all cases, second and third party attachments will be limited to the NESC designated communication space below the electrical supply space on all distribution carried poles with FPL attached. At no time may the communication/CATV worker encroach upon the electric supply space on the pole. Governmental Entities requesting attachments to FPL street light facilities may have certain attachments (i.e. banners, holiday decorations, etc) to those facilities provided that the attachments are installed in accordance with the terms and conditions of their agreements for the use of such facilities.

For any device emitting radio frequency (RF) radiation, to ensure the health and safety of utility workers, attacher shall install electric service disconnects as part of attacher's equipment to enable utility crews and personnel to disconnect power when working on the poles used for attacher's devices. FPL crews will be instructed to disconnect power to attacher's devices prior to working on the pole and to reconnect power to the devices when the work is complete. Furthermore, the attacher MUST label the device with language that advises the utility worker of the emission of RF radiation and advises the utility worker to disable the device.

II. STANDARDS

II. A. ATTACHMENT CRITERIA

No attachment or increase in bundle size of an existing attachment may be made to an FPL pole without prior approval by FPL's permit application vendor or an FPL engineer. (See the Procedures section.) Wireline and telecommunication antenna attachments may only be made to FPL distribution poles. Wireline attachments may be made to transmission poles ONLY if FPL distribution facilities are also attached to the pole. Electric service will be provided to an off-pole location. Power Supplies are not allowed on the pole. Governmental Entities requesting attachments to FPL street light facilities may have certain attachments (i.e. banners, holiday decorations, etc) to those facilities provided that the attachments are installed in accordance with the terms and conditions of their agreements for the use of such facilities.

Attachment Criteria

NON JOINT USE POLE (no telephone)




Fig. 1

1. The 1st cable attachment will be located at a height providing minimum clearance over roads, obstacles, etc.
2. All additional cable or antenna attachments will be located 1' above the highest existing communication cable, with antenna highest!

JOINT USE POLE (power & telephone)




Fig. 2

1. The 1st cable attachment will be located 1' above Telephone's highest cable Attachment
2. The 2nd cable attachment will be located 1' above the existing communication cable
3. The antenna attachment will be a minimum of 1' above highest communication cable

NOTE: No communication cable or antenna attachment will intrude on the 40" NESC code clearance space.

Space Allocation




Fig. 3

POLE ATTACHMENT LOCATION

1. Attachment is limited to the communication space or lower.
2. All main cable attachments shall be located either on the same side of the pole as FPL's neutral or on one adjacent side
3. No main line cable attachments shall be located on the side of the pole opposite FPL's neutral
4. Only 2 sides of the pole, FPL's neutral and one adjacent side, shall be occupied on any given pole
5. All electrical connections must be made off the pole
6. No more than two risers will be allowed per pole. FPL's service to Licensee may be one of these risers.




Fig. 4


IDENTIFICATION TAG

1. Each separate attachment shall be identified in accordance with FUCC's Foreign Attachment Guidelines specifications.
2. Each company shall register their unique ID tag with the FUCC's Joint Use Subcommittee
3. An ID Tag will be installed at every pole attachment.

II.B. ATTACHMENT CLEARANCES

It is the responsibility of the attacher to ensure that attachments are designed and constructed in accordance with the National Electrical Safety Code and these guidelines, and to secure any necessary permit, consent or certification from state, county or municipal authorities or from the owners of the property to construct and maintain attachments to FPL poles. Wireless antenna clearance requirements are the same as the clearance requirements for CATV and telecommunications facilities.

CLEARANCES OF COMMUNICATION CABLES TO FPL & OTHER FOREIGN UTILITIES



8

CLEARANCES OF COMMUNICATION CABLES TO FPL & OTHER FOREIGN UTILITIES				
DIMENSION (LETTER)	SEPARATION FROM FOREIGN UTILITIES TO	* FPL MINIMUM REQUIREMENT	** NESC MINIMUM REQUIREMENT	NESC APPLICABLE REFERENCE SECTION
A	STREETLIGHT BRACKET	4 INCHES	4 INCHES	238 C, TABLE 238-2
B	STREETLIGHT DRIP LOOP	12 INCHES	12 INCHES	238 D
C	TRANSFORMER BOTTOM	30 INCHES	30 INCHES	234 B, TABLE 234-1
D	SVC DRP LP, SECONDARY	40 INCHES	40 INCHES	235, TABLE 235-5
E	PRIMARY RISER SHIELD	3 INCHES	NONE	239 G1, EXCEPTION 1
F	PRIMARY RISER GROUND	40 INCHES	40 INCHES	239 G1
G	SVC DROF AND DRIP LOOP	12 INCHES	12 INCHES	235 C1, EXCEPTION 3
H	CUSTOMER OWNED SERVICE DRIP LOOP	40 INCHES	40 INCHES	TABLE 235-5
		16" IF COMMUNICATION CABLE AND RISER OPERATED BY SAME UTILITY		TABLE 235-5 EXCEPTION 3
I	SERVICE RISER	40 INCHES	40 INCHES	239 G7
J	MID SPAN	30 INCHES	30 INCHES	238-1
K	FOREIGN UTILITIES	12 INCHES	12 INCHES AT POLE; 4 INCHES ALONG SPAN	235 H
L	NEUTRAL	40 INCHES ***	30 INCHES	TABLE 235-5 EXCEPTION 6

* FOLLOW FPL MINIMUM ** NESC INFORMATION PROVIDED FOR REFERENCE ONLY *** WHERE NO SEC IS PLANNED BY FPL, 30" MIN CLEARANCE IS FEASIBLE BY COMMUNICATION IS BOUND TO FPL'S OVERLAPPING SYSTEM

II.C. WINDLOADING CRITERIA AND CALCULATIONS

Distribution Design Guidelines

The following guidelines will be used to standardize the design of FPL's overhead distribution facilities when practical, feasible and cost effective.

General

1. Every attempt should be made to place new or replacement poles in private easements or as close to the front edge of property (right of way line) as practical.
2. Overhead pole lines should be placed in front lot lines or accessible locations where feasible.
3. Concrete poles are not to be placed in inaccessible locations or locations that could potentially become inaccessible.
4. When performing work that will affect an existing Top CIF feeder, always contact Storm Secure regional project manager prior to design.
5. When performing new construction, the new pole line will be designed to meet Extreme Wind Load (EWL).

As always, good engineering judgment, safety, reliability, and cost effectiveness should be considered.

In addition to these guidelines, all distribution facilities shall be engineered to meet the minimum requirements set forth in all applicable standards and codes including but not limited to the National Electrical Safety Code (NESC), and Utility Accommodation Guide.

New Construction / Existing / Maintenance

1. When installing and/or replacing a feeder, lateral or service pole on an existing pole line, please reference the pole sizing guidelines listed under the Hardening Design Guidelines section (page 5 of 6) to determine pole class and type.
2. When performing work that will affect a Top CIF feeder, always contact Storm Secure regional project manager prior to design.
3. When extending an existing pole line, the existing pole type, wood or concrete, should be used as a guide for the new poles, while still maintaining the minimum requirements as set forth in these guidelines.

Relocation

1. When relocating either a concrete or wood pole line for a highway improvement project, the existing type pole line should be used as a guide for replacements.
2. When performing work that will affect a Top CIF feeder, always contact Storm Secure regional project manager prior to design.
3. Agency relocation projects should be coordinated with Distribution Planning to take into account potential feeder boundary changes.

Hardening Design Guidelines

The following hardening guidelines will standardize the design of FPL's overhead distribution facilities when feasible, practical and cost effective. Foreign pole owners are required to discuss design requirements with FPL prior to construction. FPL will assist with identifying the critical poles.


1. Concrete poles are preferred in the cases where replacement costs would be extremely high (i.e. Duct system riser pole, corner poles with multiple circuits, critical poles, etc). Please reference the Critical Pole list below for more information.
2. The following list comprises what will be considered critical poles. When installing and/or replacing an accessible critical pole, use concrete. If the pole is inaccessible, use a Class 2 wood pole, or consider relocating the equipment to an accessible concrete pole.

Critical Pole List
1 st switch out of the substation ¹
Automated Feeder Switches (AFS)
Interstate / Highway Crossings ^{1,2}
Capacitor Banks
Poles with multiple primary risers
3 Phase Reclosers
Aerial Auto Transformers
Multi-Circuit Poles ³
3 phase transformer banks (3-100 kVA and larger)
Regulators
Primary Meter

¹⁾ Every attempt should be made to install storm guys where feasible and practical.
²⁾ Refer to the Crossing Multi-Lane Limited Access Highways section for details (pg. 4 of 6)
³⁾ Contact Storm Secure regional project manager before designing a new multi-circuit line.

Crossing Multi-lane Limited Access Highways

1. Underground installation is the preferred design for all NEW crossings (1, 2 or 3 phase) of multi-lane limited access highways. If underground construction is not feasible or if working on an existing overhead crossing, reference the Overhead Highway Crossing schematic as shown below.
2. Underground crossing for 1 or 2 phases should be designed for potential three phase feeder size cable.
3. For accessible overhead crossings, use concrete poles (III-H or Spun) for the crossing poles and Class 2 wood poles for the adjacent poles. For inaccessible overhead crossings, Class 2 wood poles should be used for the crossing poles and adjacent poles.
4. Every attempt should be made to install storm guys for the highway crossing poles. Storm guys are not required on the adjacent poles.
5. Install disconnect switches on adjacent poles on both sides of the crossing to isolate the feeder section in case of a restoration event. Disconnect switches are to be installed in accessible locations that can be reached with aerial equipment. If there is no load between the nearest existing disconnect switch and the crossing, an additional switch is not required.



Overhead Highway Crossing Schematic

Pole Sizing Guidelines

1. The following tables should be used as guidelines to help determine pole class and type, when installing and/or replacing a feeder, lateral or service pole.
2. When performing work that will affect a Top CIF feeder/customer always contact Storm Secure regional project manager prior to design.

Feeder or Three Phase Lateral:

Pole Line Description	New Construction ¹	Existing Infrastructure ²	Installing or Replacing a Critical Pole ³
Existing Wood	Use Class 2 Wood Pole to meet EWL	Use Class 2 Wood Poles	Use III-H (Accessible) or Use Class 2 Wood (Inaccessible)
Existing Concrete	Use III-H Concrete Pole to meet EWL	Use III-H Concrete Poles	Use III-H Concrete Poles

Single or Two Phase Lateral:

Pole Line Description	New Construction ¹	Existing Infrastructure ²	Installing or Replacing a Critical Pole ³
Existing Wood	Use Class 3 Wood Pole to meet EWL	Use Class 3 Wood Poles	Use III-H (Accessible) or Use Class 2 Wood (Inaccessible)
Existing Concrete	Use III-G ⁴ or III-H poles to meet EWL	Use III-G ⁴ or III-H poles to match existing line	Use III-H Concrete Poles

¹⁾ To be used when extending or relocating a pole line. For span length details, see table below.

²⁾ To be used when replacing a pole or installing an intermediate pole within an existing pole line.

³⁾ Reference Critical Pole List on pg.3 of 6.

⁴⁾ Use of III-G poles should be limited to existing concrete lateral pole lines whose wire size is less than or equal to #1/0 Aluminum.

Facility	Phases(s)	Wire size	Pole size	Recommended Span Length ⁵ (FPL with 2 attachments – FPL ONLY)		
				105 MPH	130 MPH	145 MPH
Feeder		3#568 ACAR	Class 2	180' - 230'	135' - 200'	100' - 150'
		3#3/0 AAAC	Class 2	180' - 250'	180' - 250'	125' - 250'
Lateral	3 PH	3#1/0 AAAC	Class 2	180' - 250'	180' - 250'	155' - 250'
	2 PH	2#1/0 AAAC	Class 3	180' - 250'	180' - 250'	170' - 250'
	1 PH	1#1/0 AAAC	Class 3	180' - 250'	180' - 250'	180 - 250'

⁵⁾ The lower number equates to the maximum span for FPL primary and 2 foreign attachments. The higher number equates to the maximum span for FPL primary only. Reference the addendum DERM tables when adding additional attachment(s) or equipment. Remember to always contact the Storm Secure regional project manager when working on a Top CIF feeder.

Service / Secondary / Street Light / Outdoor Light Poles

When installing or replacing a secondary, service or street light pole, a minimum Class 4 Wood pole should be used. Specific calculations may require a higher class pole for large Quadruplex wire.

As always, good engineering judgment, safety, reliability, and cost effectiveness should be considered.

In addition to these guidelines, all distribution facilities shall be engineered to meet the minimum requirements set forth in all applicable standards and codes including but not limited to the National Electrical Safety Code (NESC) and Utility Accommodation Guide.

Storm Secure

Distribution Overhead Line Design for Extreme Wind Loading

ADDENDUM TO DISTRIBUTION ENGINEERING REFERENCE MANUAL (DERM)

Introduction

In 2006, FPL introduced the concept of "STORM SECURE". One part of this concept is to harden the electrical system by adopting new standards based on extreme wind velocity criteria. The Florida Public Service Commission and the Florida Administrative Code have adopted the 2007 NESC for the applicable standard of construction.

FPL designs its distribution facilities based on the loading as specified in the 2007 National Electrical Safety Code (NESC) using Grade B Construction. The NESC specifies three weather conditions to consider for calculating loads:

- Rule 250 B. Combined ice and wind loading (FPL current standard construction)
- Rule 250 C. Extreme wind loading
- Rule 250 D. Extreme ice with concurrent wind loading (this is a new loading condition in the 2007 NESC that will not impact FPL).

Prior to the hardening effort, FPL has been designing overhead distribution using the loads calculated under Rule 250 B. This addendum provides the designers the information needed to design projects using Rule 250 C, grade B (extreme wind loading) to calculate the loads, when it is determined that the particular pole line is to be designed to meet extreme wind loading (EWL) requirements. The NESC extreme wind map identifies 7 Basic Wind Speeds throughout Florida. In order to minimize the design effort to accommodate these 7 wind speeds, FPL has created 3 wind regions with designated wind speeds of 105 mph, 130 mph, and 145 mph. The Map shown in Figure 4.2.2-1 identifies the counties within our service territory that fall into the 3 wind regions. Whenever extreme wind designs are deployed, they will be designed to the identified wind speed for the location of the work to be done.

4.2.2 Poles Structures and Guying

A. Poles, General Information

1. Pole Brands

The pole brand includes the pole length & class, the type of treatment, the manufacturer, the date the pole was manufactured and FPL.

Wood Poles –This brand is located at 15' from the bottom of the pole.

Square (cast) Concrete poles – the brand up until 2007 was located 15' from the bottom. New specifications now require the brand to be at 20' from the bottom of the pole.

Distribution Spun Concrete poles – The brand information is on a metal tag that is located 20' from the bottom of the pole.

2. Design Specifications

The NESC specifies 3 Grades of construction: Grade B, Grade C, and Grade N with Grade B being the strongest of the three. These grades of construction are the basis for the required strengths for safety. FPL uses Grade B Construction for all distribution facilities. This means that the calculated loads must be multiplied by "Load Factors" and the calculated or specified strength of structures must be multiplied by "Strength Factors". The Strength multiplied by the Strength Factor (SF) must be equal to, or greater than the Load multiplied by the Load Factor (LF).

Equation 4.2.2-1

$$\text{Strength} \times \text{Strength Factor} \geq \text{Load} \times \text{Load Factor}$$

Table 4.2.2 – 1 below lists the Load Factors and Strength Factors for Grade B Construction from NESC Table 253-1 and Table 261-1A.

Table 4.2.2 - 1 Extreme Wind
 Strength Factors & Load Factors

Strength of	Strength Factor
Wood Poles	0.75
Concrete Poles	1.00
Composite Poles	1.00
Support Hardware	1.00
Guy Wire	0.90
Guy Anchor and Foundation	1.00
	Load Factor
Extreme Wind Loads	1.00

FPL uses the NESC Extreme Wind Loading for its design criteria. As such, identify the wind speed for the job location and determine the load based on the following formula.

Equation 4.2.2-2

$$\text{Load in pounds} = 0.00256 \times (V_{mph})^2 \times k_z \times G_{RF} \times I \times C_f \times A(ft^2)$$

Where,

- 0.00256 - Velocity-Pressure Numerical Coefficient
- V -Velocity of wind in miles per hour (3 second gust)
- k_z -Velocity Pressure Exposure Coefficient
- G_{RF} -Gust Response Factor
- I -Importance Factor, 1.0 for utility structures and their supported facilities.
- C_f - Force Coefficient (Shape Factor)
 For Wood & Spun Concrete Poles = 1.0
 For Square Concrete Poles = 1.6
- A - Projected Wind Area, ft².

The NESC provides formulas for calculating k_z and G_{RF} . However, Tables are also provided and Table 4.2.2-2 below shows the values needed for most distribution structures.


Table 4.2.2-2 Velocity pressure Exposure coefficient (k_z) and Gust Response Factors (G_{RF})

Height (h)	Structure		Equipment		Wire		
	k_z^1	G_{RF}^4	k_z^2	G_{RF}^5	k_z^3	G_{RF}^4 (L ≤ 250 ft)	G_{RF}^4 (250 < L ≤ 500 ft)
≤ 33	0.9	1.02	1.0	1.02	1.0	0.93	0.86
>33 to 50	1	0.97	1.1	0.97	1.1	0.88	0.82
>50 to 80	1.1	0.93	1.2	0.93	1.2	0.86	0.80

1. h for the pole k_z is to be the height of the pole above ground
2. h for the equipment k_z is the height of the center of the area of the equipment above ground
3. h for the wire k_z is the height of the wire above ground
4. h for the G_{RF} is the height above ground for the structure and the wire
5. h for the G_{RF} for the equipment is based on the height of the structure above ground
6. L = design wind span (average of span on both sides of structure)

The wind speeds to be used are shown in Figure 4.2.2 – 1

Figure 4.2.2 –1 Wind Regions by County



3. Wood Pole Strength

The strength of wood poles is specified in the American National Standard – ANSI O5.1-2002. In addition to strength of wood poles, this standard specifies dimensions, shape, sweep spiral grain, knots, and many other characteristics of wood poles.

A change from previous calculations shown in the DERM for allowable pole strength is that the circumference to be used is now considered to be the ground line circumference rather than the “fixity” point circumference. Another change is the strength factor to be used. For extreme wind the strength factor for wood poles is 0.75 (see Table 4.2.2-1)

Example 4.2.2-1:

Determine the pole strength for wind loading on a 45’/2 wood pole that is set 7 feet.

$$\text{Equation 4.2.2-3} \quad M_r = 0.000264fC^3$$

Where

M_r	=	Moment (ultimate or long term bowing) measured in foot-pounds
f	=	Fiber Stress (8000 or 1000 psi for Southern Yellow Pine)
C	=	Circumference at ground Line (in this example circumference = 40.1 inches)
M_r	=	$0.000264 \times (8,000) \times (40.1)^3 = 136,184$ ft.-lbs.

This is the strength for the 45’/2 wood pole. However for design, apply the NESC Strength Factor of 0.75.

The strength of the 45’/2 wood pole = 136,184 x 0.75 = 102,138 ft.-lbs.

4. Concrete Pole Strength

The strength of concrete poles is based on the application of a designated load at a specified location on the pole. This load is measured in KIPS = 1,000 pounds per KIP. A 5 KIP pole is rated based on applying 5,000 pounds of load at two feet below the top of the pole. Most distribution poles are rated by applying the load at two feet down from the top. However, for the type “O”, “S”, and “SU” poles, this load is applied at one foot down from the top. Like wood poles, concrete poles have a continuous rating (loads that are

always on the pole) and a temporary rating (wind loads that come and go). Spun concrete poles (unlike other FPL distribution concrete poles) are designated by their KIP rating rather than a type (i.e., O, S, SU, III, III-G, III- H). Table 4.2.2-3 List the ratings (in KIPS) for the various concrete poles.

Table 4.2.2-3 Concrete Pole Ratings

Pole Type	Temporary Rating	Continuous Rating
O	0.85	0.26
S & SU	0.90	0.30
III	1.30	0.56
III-A	1.30	0.60
III-G	2.40	0.90
III-H	4.20	1.20
12 KIP (square)	8.40	2.40
Spun Concrete		
4.0 KIP	4.00	1.73
4.7 KIP	4.70	2.54
5.0 KIP	5.00	3.03

To calculate the strength of the pole use the following:

For O, S, SU,

$$M_r = \text{Rating (Table 4.2.2-3)} \times (\text{Pole Length} - \text{setting depth} - 1 \text{ foot})$$

Example: 35' Type SU for extreme wind loading

$$M_r = 0.9 \text{ KIPS} \times (35 - 7.5 - 1) = 23,850 \text{ ft-lbs}$$

For III, III-A, III-G, III-H

$$M_r = \text{Rating (Table 4.2.2-3)} \times (\text{Pole Length} - \text{setting depth} - 2 \text{ feet})$$

Example: 50' Type III-H for extreme wind loading

$$M_r = 4.2 \text{ KIPS} \times (50 - 11.5 - 2) = 153,300 \text{ ft-lbs}$$

For Spun Concrete

$$M_r = \text{Rating (Table 4.2.2-3)} \times (\text{Pole Length} - \text{setting depth} - 2 \text{ feet})$$

Example: 50' / 4.7 KIP for extreme wind loading

$$M_r = 4.7 \text{ KIPS} \times (50 - 11 - 2) = 173,900 \text{ ft-lbs}$$

For pre-stressed concrete poles, the NESC extreme wind strength factor = 1.0. The values calculated above will be the correct strength for concrete poles.

B. Wind Loading

1. Wind Loading on poles.

To calculate the wind load on the pole:

- a. Calculate the area of the pole exposed to the wind

$$\text{Equation 4.2.2-4} \quad A = H_1 \left(\frac{a+b}{2} \right) \left(\frac{1}{12} \right)$$

A = projected area above ground line in square feet.
 H₁ = the pole's height above the ground line in feet.

For wood and spun concrete poles,

a = diameter at top of pole in inches.
 b = diameter of pole at ground line in inches.

For square concrete poles, dimensions a and b are the widths of one face at top and ground line respectively.

- b. Calculate the center of the area.

$$\text{Equation 4.2.2-5} \quad H_{CA} = \frac{H_1(b + 2a)}{3(b + a)}$$

H_{CA} is used to calculate the ground line moment due to the wind force.

- c. Calculate the wind force acting on the area (see Equation 4.2.2-2 with explanation of terms)

$$\text{Load in pounds} = 0.00256 \cdot (V_{\text{mph}})^2 \cdot K_z \cdot G_{\text{RF}} \cdot I \cdot C_f \cdot A(\text{ft}^2)$$

Example Calculation for Wood Pole

Pole Length/Class = 45'/2
 Setting depth = 7'
 Wind Region = 145 mph

$$\text{Projected Area } A = H_1(\text{ft.}) \times \frac{1 \text{ ft}}{12 \text{ in}} \times \left[\frac{a + b(\text{inches})}{2} \right]$$

The circumference at the top of a 45' / 2 pole is 25",

$$a = \frac{25''}{\pi} = 7.96''$$

The circumference at 38 ft. below the pole top 40.1", $b = \frac{40.1''}{\pi} = 12.76''$

$$A = \frac{38}{12} \times \left[\frac{7.96 + 12.76}{2} \right] = 32.81 \text{ sq. ft.}$$

$$\text{Height of center of area, } H_{CA} = \frac{H_1(b + 2a)}{3(b + a)} = \frac{38(12.76 + 15.92)}{3(12.76 + 7.96)}$$

$$H_{CA} = \text{Moment Arm} = 17.53 \text{ ft.}$$

Wind Load on Pole =

$$0.00256 \times (145)^2 \times 1.0 \times 0.97 \times 1.0 \times 1.0 \times 32.81 = \mathbf{1713 \text{ lbs}}$$

Where:

k_z is based on $h = 38'$; $k_z = 1.0$

G_{RF} is based on $h = 38'$; $G_{RF} = 0.97$

$C_f = 1.0$ for wood and spun concrete poles

$C_f = 1.6$ for square concrete poles

This load must then be multiplied by the Load Factor, which for extreme wind equals 1.0 and the moment arm to obtain the Ground Line Moment (M_P) of the wind acting on the pole only.

Equation 4.2.2-6

$$M_P = \text{Wind Load} \times \text{Load Factor} \times \text{Moment Arm.}$$

$$M_P = 1713 \text{ lbs} \times 1 \times 17.53 \text{ ft.} = 30,030 \text{ ft. lbs.}$$

The strength of this pole, previously calculated is 102,138 ft.-lbs. The pole itself has used up 29% (30,030/102,138) of its capacity for 145 mph extreme wind. Subtracting the wind load from the strength leaves 72,108 ft.-lbs (102,138 – 30,030) for conductors and other attachments.

Example Calculation for Square Concrete Pole

Pole Length/Class = 50'/III-H
Setting depth = 11.5'
Wind Region = 145 mph

$$\text{Projected Area } A = H_1(\text{ft.}) \times \frac{1 \text{ ft}}{12 \text{ in}} \times \left[\frac{a + b(\text{inches})}{2} \right]$$

From Table H, the width of the pole at the top $a = 9.00''$
The width at ground line, $b = 15.75''$

$$A = \frac{38.5}{12} \times \left[\frac{15.75 + 9.00}{2} \right] = 39.70 \text{ sq. ft.}$$

$$\text{Height of center of area, } H_{CA} = \frac{H_1(b + 2a)}{3(b + a)} = \frac{38.5(15.75 + 18.00)}{3(15.75 + 9.00)}$$

$$H_{CA} = \text{Moment Arm} = 17.5 \text{ ft.}$$

Wind Load on Pole =

$$0.00256 \times (145)^2 \times 1.0 \times 0.97 \times 1.0 \times 1.6 \times 39.7 = 3317 \text{ lbs}$$

Where:

k_z is based on $h = 38.5'$; $k_z = 1.0$

G_{RF} is based on $h = 38.5'$; $G_{RF} = 0.97$

$C_f = 1.0$ for wood and spun concrete poles

$C_f = 1.6$ for square concrete poles

This load must then be multiplied by the Load Factor, which for extreme wind equals 1.0 and the moment arm to obtain the Ground Line Moment (M_P) of the wind acting on the pole only.

$$M_P = \text{Wind Load} \times \text{Load Factor} \times \text{Moment Arm.}$$

$$M_P = 3317 \text{ lbs} \times 1 \times 17.5 \text{ ft.} = 58,040 \text{ ft. lbs.}$$

The strength of this pole, previously calculated is 153,300 ft.-lbs.
The pole itself has used up 38% (58,040/153,300) of its capacity for 145 mph extreme wind. Subtracting the wind load from the strength leaves 95,260 ft-lbs (153,300 – 58,040) for conductors and other attachments.

Example Calculation for Spun Concrete Pole

Pole Length/Class = 50'/4.7 KIP
 Setting depth = 11'
 Wind Region = 145 mph

$$\text{Projected Area } A = H_1 (\text{ft.}) \times \frac{1 \text{ ft}}{12 \text{ inc.}} \times \left[\frac{a + b(\text{inches})}{2} \right]$$

From Table H, the diameter of the pole at the top $a = 9.55''$
 The diameter at ground line, $b = 16.57''$

$$\text{So } A = \frac{39}{12} \times \left[\frac{9.55 + 16.57}{2} \right] = 42.45 \text{ sq. ft.}$$

$$\text{Height of center of area, } H_{CA} = \frac{H_1(b + 2a)}{3(b + a)} = \frac{39(16.57 + 19.1)}{3(16.57 + 9.55)}$$

$$H_{CA} = \text{Moment Arm} = 17.75 \text{ ft.}$$

Wind Load on Pole =

$$0.00256 \times (145)^2 \times 1.0 \times 0.97 \times 1.0 \times 1.0 \times 42.45 = \mathbf{2,216 \text{ lbs}}$$

Where:

k_z is based on $h = 39'$; $k_z = 1.0$

G_{RF} is based on $h = 39'$; $G_{RF} = 0.97$

$C_f = 1.0$ for wood and spun concrete poles

$C_f = 1.6$ for square concrete poles

This load must then be multiplied by the Load Factor, which for extreme wind equals 1.0 and the moment arm to obtain the Ground Line Moment (M_P) of the wind acting on the pole only.

$$M_P = \text{Wind Load} \times \text{Load Factor} \times \text{Moment Arm.}$$

$$M_P = 2,216 \text{ lbs} \times 1 \times 17.75 \text{ ft.} = 39,341 \text{ ft. lbs.}$$

The strength of this pole, previously calculated is 173,900 ft.-lbs. The pole itself has used up 23% (39,341/173,900) of its capacity for 145 mph extreme wind. Subtract the wind load from the strength leaves 134,559 ft.-lbs (173,900 – 39341) for conductors and other attachments.

Table 4.2.2-4 Lists the allowable groundline moments for various pole sizes.

Table 4.2.2-4 Allowable Ground Line Moments

Wood Poles (in earth)				
Pole Size	Setting Depth	Allowable Moment for Attachments at Designated Wind Speeds		
		105 mph	130 mph	145 mph
35/5	6	32178	28738	26324
35/4	6	42429	38656	36007
40/5	6.5	36936	31956	28460
40/4	6.5	48263	42812	38986
40/3	6.5	61567	55646	51489
40/2	6.5	76998	70607	66119
45/3	7	66363	58624	53190
45/2	7	86391	78000	72108
50/2	7	93535	82611	74941
55/2	7.5	99693	86174	76682
60/1	8	131634	113020	99951

Table 4.2.2-4 Allowable Ground Line Moments (cont.)

Square Concrete Poles (in earth)				
Pole Size	Setting Depth	Allowable Moment for Attachments at Designated Wind Speeds		
		105 mph	130 mph	145 mph
35/Type O	7	15426	11417	8602
35/SU	7.5	15323	10778	7588
35/III-G	9	48907	44275	41022
40/III-A	10	23777	17050	12327
40/III-G	9	56781	49950	45154
40/III-H	11.5	96450	88537	82981
40/12 KIP	13	191480	181610	174681
45/III-A	10	24142	14146	7127
45/III-G	9	62676	52592	45511
45/III-H	11.5	110053	98198	89874
45/12 KIP	13.5	222175	208520	198933
50/III-A	10	24111	10635	1173
50/III-G	9.5	67701	54539	45297
50/III-H	11.5	123164	107106	95831
50/12 KIP	13.5	252789	233067	219219
55/III-G	9.5	72176	55004	42947
55/III-H	12	133764	113283	98902
55/12 KIP	14	280155	254873	237121
60/III-H	12	144138	117993	99637
60/12 KIP	14	308835	276454	253719
65/III-H	12	149613	115197	91032

Spun Concrete Poles (in earth)				
Pole Size	Setting Depth	Allowable Moment for Attachments at Designated Wind Speeds		
		105 mph	130 mph	145 mph
50/4.7 KIP	11	153270	142277	134559
55/4.7 KIP	12	167116	153482	143910
60/5.0 KIP	12.5	190953	171477	157803
65/5.0 KIP	13	202928	177845	160233
70/5.0 KIP	13.5	214369	183392	161642

2. Wind Loading on conductors.

The wind loading on conductors is calculated in a similar method to the wind loading on the pole. The load in pounds per conductor uses Equation 4.2.2-2 with the appropriate factors for the attachment heights as shown in Table 4.2.2-2.

To calculate the wind load on the conductor:

- a. Determine the wind region (105 mph, 130 mph, or 145 mph)
- b. Calculate the attachment height to determine the k_z and G_{RF} (Table 4.2.2-2)
- c. The Importance Factor (I) and the Force Coefficient (C_f) are both equal to 1 for conductors.
- d. Calculate the area per foot of conductor
- e. Calculate the wind load per foot of conductor
- f. Calculate the total wind load on the conductor for the length of conductor exposed to the wind (Average of the Spans on either side of the pole).

Example:

Determine the wind load on a 170 foot length [(180'span + 160'span)/2] of 568.3 ACAR conductor that is attached at 30 feet above the ground in the 145 mph wind region.

From Table 4.2.2-2:

$$K_z = 1.0$$

$$G_{RF} = 0.93$$

Calculate the area per foot of conductor
 Diameter = 0.879 inches

For a 1 foot length of conductor:
Projected Area.

$$A = 1(ft.) \times \left[\frac{\text{Conductor Diameter}(inches)}{12(inches / ft)} \right]$$

$$A = 1(ft.) \times \left[\frac{0.879(inches)}{12(inches / ft)} \right]$$

A = 0.073 Square Ft. for each foot of span length

The wind load in pounds per foot of span length (from Equation 4.2.2-2) is

$$\text{Load in pounds} = 0.00256 \times (V_{mph})^2 \times k_z \times G_{RF} \times I \times C_f \times A(ft^2)$$

$$\text{Load in pounds} = 0.00256 \times (145)^2 \times 1 \times .93 \times 1 \times 1 \times .073$$
$$\text{Load} = 3.667 \text{ pounds per foot}$$

$$\begin{aligned} \text{Total Load} &= \text{Length of conductor} \times \text{Load per foot of conductor} \\ &= 170 \times 3.667 \\ \text{Total Load} &= 623.3 \text{ pounds} \end{aligned}$$

This is the load that the wind exerts on the conductor attached at 30 above ground. This load will have to be applied to the pole to determine if the pole has the strength to support the load.

The wind load per foot of conductor for the three wind regions can be found in Table 4.2.2-5, Table 4.2.2- 6 and Table 4.2.2-7.

3. **Wind Loading on equipment.**

The wind loading on equipment is calculated in a similar method to the wind loading on the pole and the conductors. The load in pounds uses Equation 4.2.2-2 with the appropriate factors for the attachment heights a shown in Table 4.2.2-2 and the area of the equipment.

To calculate the wind load on the equipment:

- a. Determine the wind region (105 mph, 130 mph, or 145 mph)
- b. Calculate the attachment height to determine the k_z (Table 4.2.2-2)
(For equipment, use the top mounting hole of the equipment bracket.)
- c. Use the height of the pole above ground to determine G_{RF} (Table 4.2.2-2)
- d. The Importance Factor (I) is equal to 1.
- e. The Force Coefficient (C_f) is equal to 1.0 for cylindrical equipment and 1.6 for rectangular equipment.
- f. Calculate the area of the equipment
- g. Calculate the wind load on the equipment

Example:

Determine the wind load on a 50 kVA transformer mounted at 28 feet on a pole that is 38 feet above the ground in the 145 mph wind region.

From Table 4.2.2-2:

$$K_z = 1.0 \text{ (Equipment } \leq 33' \text{ above ground)}$$

$$G_{RF} = 0.97 \text{ (Equipment based on Pole height } > 33' \text{ to } 50' \text{ above ground)}$$

$$C_f = 1.0$$
$$A = 4.44 \text{ square feet}$$

The wind load in pounds from Equation 4.2.2-2 is

$$\text{Load in pounds} = 0.00256 \times (V_{\text{mph}})^2 \times k_z \times G_{RF} \times I \times C_f \times A(\text{ft}^2)$$

$$\text{Load in pounds} = 0.00256 \times (145)^2 \times 1 \times .97 \times 1 \times 1 \times 4.44$$
$$\text{Load} = 231.8 \text{ pounds}$$

This is the load that the wind exerts on the transformer attached at 28 feet above ground. This load will have to be applied to the pole to determine if the pole has the strength to support the load.

The wind load on equipment for the three wind regions can be found in Table 4.2.2-5 (105 mph), Table 4.2.2- 6 (130 mph) and Table 4.2.2-7 (145 mph).

Table 4.2.2-5 Wind Force on Conductors & Equipment

**Wind Speed = 105 mph
 CONDUCTORS**

Conductor	Diameter	Force in pounds per foot Conductor Height Above Ground		
		≤33'	>33' to 50'	>50' to 80'
568.3 MCM ACAR	0.879	1.923	2.001	2.134
3/0 AAAC	0.502	1.098	1.143	1.218
1/0 AAAC	0.398	0.871	0.906	0.966
#4 AAAC	0.250	0.547	0.569	0.607
3/0 TPX	1.238	2.708	2.819	3.005
1/0 TPX	1.026	2.244	2.336	2.490
6 DPX	0.496	1.085	1.129	1.204
CATV				
Feeder w/1/4"Msgnr	0.750	1.641	1.708	1.820
Trunk w/1/4"Msgnr	1.000	2.187	2.277	2.427
Telephone				
100 pr (24 GA BKMS) Self-Support	0.960	2.100	2.186	2.330
600 pr (24 GA BKMA w/3/8" Msgnr	2.295	5.020	5.225	5.571

**Wind Speed = 105 mph
 EQUIPMENT**

Transformers	Sq. Ft.	Pole Height in same range as Equipment Force in pounds at top mounting Bolt Height Above Ground			Pole height >33' to 50' Equipment Ht ≤33'
		≤33'	>33' to 50'	>50' to 80'	
25	3.75	108.0	112.9	118.1	102.7
50	4.44	127.8	133.7	139.9	121.6
75	4.81	138.5	144.9	151.5	131.7
100	6.55	188.6	197.3	206.3	179.3
167	10.83	311.8	326.1	341.1	296.5
Capacitors					
Switched (1)	19.91	573.2	599.6	627.1	545.1
Fixed (1)	16.89	486.2	508.6	532.0	462.4
Reclosers					
1 phase	4.00	115.2	120.5	126.0	109.5
3 phase (1)	16.89	486.2	508.6	532.0	462.4
Automation Switches					
Joslyn	8.89	255.9	267.7	280.0	243.4
Cooper	10.56	304.0	318.0	332.6	289.1
S&C	15.60	449.1	469.8	491.4	427.1
Riser - PVC U-Guard					
		Force in pounds per foot of riser Height Above Ground			
2" U-Guard	0.19	5.4	5.6	5.9	5.1
5" U-Guard	0.46	12.8	13.8	14.4	13.2

(1) The 1.6 C_f factor for rectangular shape is included in the Area shown for Capacitors and 3 Phase Recloser

Table 4.2.2-6 Wind Force on Conductors & Equipment

Wind Speed = 130 mph
CONDUCTORS

Conductor	Diameter	Force in pounds per foot Conductor Height Above Ground		
		≤33'	>33' to 50'	>50' to 80'
568.3 MCM ACAR	0.879	2.947	3.068	3.270
3/0 AAAC	0.502	1.683	1.752	1.868
1/0 AAAC	0.398	1.334	1.389	1.481
#4 AAAC	0.250	0.838	0.872	0.930
3/0 TPX	1.238	4.151	4.321	4.606
1/0 TPX	1.026	3.440	3.581	3.817
6 DPX	0.496	1.663	1.731	1.845
CATV				
Feeder w/1/4"Msgnr	0.750	2.515	2.617	2.791
Trunk w/1/4"Msgnr	1.000	3.353	3.490	3.721
Telephone				
100 pr (24 GA BKMS) Self-Support	0.960	3.219	3.350	3.572
600 pr (24 GA BKMA w/3/8" Msgnr	2.295	7.695	8.009	8.539

Wind Speed = 130 mph
EQUIPMENT

Transformers	Sq. Ft.	Pole Height in same range as Equipment Force in pounds at top mounting Bolt Height Above Ground			Pole height >33' to 50' Equipment Ht ≤33'
		≤33'	>33' to 50'	>50' to 80'	
25	3.75	165.5	173.1	181.1	157.4
50	4.44	195.9	205.0	214.4	186.3
75	4.81	212.3	222.0	232.2	201.9
100	6.55	289.0	302.4	316.3	274.9
167	10.83	477.9	499.9	522.9	454.5
Capacitors					
Switched (1)	19.91	878.6	919.1	961.3	835.5
Fixed (1)	16.89	745.3	779.7	815.5	708.8
Reclosers					
1 phase	4.00	176.5	184.7	193.1	167.9
3 phase (1)	16.89	745.3	779.7	815.5	708.8
Automation Switches					
Joslyn	8.89	392.3	410.4	429.2	373.1
Cooper	10.56	466.0	487.5	509.9	443.2
S&C	15.60	688.4	720.1	753.2	654.7
Riser - PVC U-Guard					
2" U-Guard	0.19	8.3	8.7	9.1	7.9
5" U-Guard	0.46	20.2	21.2	22.1	19.2

(1) The 1.6 C_r factor for rectangular shape is included in the Area shown for Capacitors and 3 Phase Recloser

Table 4.2.2-7 Wind Force on Conductors & Equipment

Wind Speed = 145 mph
CONDUCTORS

Conductor	Diameter	Force in pounds per foot Conductor Height Above Ground		
		≤33'	>33' to 50'	>50' to 80'
568.3 MCM ACAR	0.879	3.667	3.816	4.069
3/0 AAAC	0.502	2.094	2.180	2.324
1/0 AAAC	0.398	1.660	1.728	1.842
#4 AAAC	0.250	1.043	1.085	1.157
3/0 TPX	1.238	5.164	5.375	5.731
1/0 TPX	1.026	4.280	4.455	4.749
6 DPX	0.496	2.069	2.154	2.296
CATV				
Feeder w/1/4"Msgnr	0.750	3.129	3.256	3.472
Trunk w/1/4"Msgnr	1.000	4.171	4.342	4.629
Telephone				
100 pr (24 GA BKMS) Self-Support	0.960	4.005	4.168	4.444
600 pr (24 GA BKMA w/3/8" Msgnr	2.295	9.573	9.964	10.623

Wind Speed = 145 mph
EQUIPMENT

Transformers	Sq. Ft.	Pole Height in same range as Equipment Force in pounds at top mounting Bolt Height Above Ground			Pole height >33' to 50' Equipment Ht ≤33'
		≤33'	>33' to 50'	>50' to 80'	
25	3.750	205.9	215.4	225.3	195.8
50	4.440	243.8	255.0	266.7	231.8
75	4.810	264.1	276.2	288.9	251.1
100	6.550	359.6	376.2	393.4	342.0
167	10.830	594.6	622.0	650.5	565.4
Capacitors					
Switched (1)	19.910	1093.1	1143.4	1195.9	1039.5
Fixed (1)	16.890	927.3	970.0	1014.5	881.8
Reclosers					
1 phase	4.000	219.6	229.7	240.3	208.8
3 phase (1)	16.890	927.3	970.0	1014.5	881.8
Automation Switches					
Joslyn	8.890	488.1	510.6	534.0	464.1
Cooper	10.560	579.7	606.5	634.3	551.3
S&C	15.600	856.4	895.9	937.1	814.5
Riser - PVC U-Guard					
		Force in pounds per foot of riser Height Above Ground			
2" U-Guard	0.188	10.3	10.8	11.3	9.8
5" U-Guard	0.458	25.2	26.3	27.5	23.9

(1) The 1.6 C_r factor for rectangular shape is included in the Area shown for Capacitors and 3 Phase Recloser

The methodology to determine if a pole has the strength for a specific design or to determine the maximum span distance a specific size pole can support for framing, is shown in the examples below. The calculations are based on using the new tables for extreme wind loading. Note that the ground line is now the point used for the calculations rather than the "fixity" point.

Example:

Conductor: 3-568.3 MCM ACAR and #3/0 AAAC - Neutral

Framing: Modified Vertical and single phase transformer

Transformer: 50 kVA

CATV: Trunk

Telephone: 1-600 pair, 24 gauge, BKMA

Average Span Length = 150 feet

Attachment heights must be calculated using the framing identified and the pole setting depths as shown in table 4.2.2-4.

Case I: Determine if a 45/2 wood pole is strong enough for this design.

Calculate the moments on the pole.

CONDUCTORS		Number of	Wind Load	Avg.	Height	= MOMENT (ft.-lb.)	
	Conductors	x	(Table 4.2.2-7)	Span	Above		
			Per Ft.	Length	Ground		
Primary							
568.3	1	x	3.816	x 150	x 39.00	=	22324
568.3	1	x	3.816	x 150	x 36.60	=	20950
568.3	1	x	3.816	x 150	x 34.60	=	19805
Neut. Sec. St Lt							
3/0	1	x	2.094	x 150	x 29.4	=	9235
CATV - PROPOSED							
Trunk	1	x	4.171	x 150	x 23.6	=	14765
TELEPHONE							
600 pr 24 Ga BKMA	1	x	9.573	x 150	x 22.6	=	32452
TOTAL MOMENT DUE TO CONDUCTOR						=	119531
EQUIPMENT			Wind Load		Height	= MOMENT (ft.-lb.)	
			Force in lbs		Above		
					Ground		
TRANSFORMERS (SEE TABLE FOR INSTRUCTIONS)							
1 Phase	50 kva		231.8	x	29.9	=	6931
TOTAL MOMENT DUE TO EQUIPMENT						=	6931 ft.-lb.
TOTAL ALL MOMENTS						=	126462 ft.-lb.

From Table 4.2.2-4, the allowable moment for attachments to a 45/2 wood pole in a 145 mph wind region is 72,108 ft-lbs. A 45/2 wood pole cannot be used.

Case II: Determine if a 50'/III-H square concrete pole is strong enough for this design

Table 4.2.2-4 shows a revised setting depth for square concrete poles. The new setting depth is generally 5 feet deeper than previous. A 50'/III-H square concrete pole is set 11.5 feet deep.

Re-calculate the moments based on attachment heights.

CONDUCTORS		Number of	Wind Load	Avg.	Height		
		Conductors	Per Ft.	Span	Above		
		x	(Table 4.2.2-7)	Length	Ground	= MOMENT (ft.-lb.)	
		x	x	x	x		
Primary							
568.3	1	x	3.816	x 150	x 39.50	=	22610
568.3	1	x	3.816	x 150	x 37.08	=	21225
568.3	1	x	3.816	x 150	x 35.08	=	20080
Neut. Sec., SLT							
3/0	1	x	2.094	x 150	x 29.92	=	9398
CATV - PROPOSED							
Trunk	1	x	4.171	x 150	x 24.08	=	15066
TELEPHONE							
600 pr 24 Ga BKMA	1	x	9.573	x 150	x 23.08	=	33142
TOTAL MOMENT DUE TO CONDUCTOR						=	121519
EQUIPMENT			Wind Load		Height		
			Force in lbs		Above		
					Ground	= MOMENT (ft.-lb.)	
TRANSFORMERS (SEE TABLE FOR INSTRUCTIONS)							
1 Phase	50 kva		231.8	x	30.42	=	7051
TOTAL MOMENT DUE TO EQUIPMENT						=	7051 ft.-lb.
TOTAL ALL MOMENTS						=	128571 ft.-lb.

From Table 4.2.2-4, the allowable moment for attachments to a 50'/III-H square concrete pole in a 145 mph wind region is 95,831 ft-lbs. A 50'/III-H square concrete pole cannot be used.

Case III: Determine if a 50'4.7 KIP spun concrete pole is strong enough for this design.

Table 4.2.2-4 shows the setting depths for spun concrete poles. A 50'4.7 KIP spun concrete pole is set 11 feet deep.

Re-calculate the moments based on attachment heights.

CONDUCTORS	Number of Conductors	x	Wind Load Per Ft. (Table 4.2.2-7)	x	Avg. Span Length	x	Height Above Ground	=	MOMENT (ft.-lb.)
Primary									
568.3	1	x	3.816	x	150	x	40.00	=	22896
568.3	1	x	3.816	x	150	x	37.58	=	21511
568.3	1	x	3.816	x	150	x	35.58	=	20366
Neut. Sec. St Lt									
3/0	1	x	2.094	x	150	x	30.42	=	9555
CATV - PROPOSED									
Trunk	1	x	4.171	x	150	x	24.58	=	15378
TELEPHONE									
600 pr 24 Ga BKMA	1	x	9.573	x	150	x	23.58	=	33860
TOTAL MOMENT DUE TO CONDUCTOR								=	123566
EQUIPMENT			Wind Load Force in lbs				Height Above Ground	=	MOMENT (ft.-lb.)
TRANSFORMERS	(SEE TABLE FOR INSTRUCTIONS)								
1 Phase	50 kva		231.8		x		30.92	=	7167
TOTAL MOMENT DUE TO EQUIPMENT								=	7167 ft.-lb.
TOTAL ALL MOMENTS								=	130733 ft.-lb.

From Table 4.2.2-4, the allowable moment for attachments to a 50'4.7 KIP spun concrete pole in a 145 mph wind region is 134,559 ft-lbs. A 50'4.7 KIP spun concrete pole can be used.

The maximum span distance for each of the poles above can be determined.

Determine the moment due to 1 foot of conductor moments

Subtract the moment due to the transformer from the total allowable moment

Divide the remaining allowable moment by the total 1 foot conductor moments.

CONDUCTORS		Number of Conductors	x	Wind Load Per Ft. (Table 4.2.2-7)	x	Avg. Span Length	x	Height Above Ground	=	MOMENT (ft.-lb.)
Primary										
568.3	1	x	3.816	x	1	x	39.00	=	149	
568.3	1	x	3.816	x	1	x	36.60	=	140	
568.3	1	x	3.816	x	1	x	34.60	=	132	
Neut. Sec., Still										
3/0	1	x	2.094	x	1	x	29.4	=	62	
CATV - PROPOSED										
Trunk	1	x	4.171	x	1	x	23.6	=	98	
TELEPHONE										
600 pr 24 Ga BKMA	1	x	9.573	x	1	x	22.6	=	218	
									TOTAL MOMENT DUE TO CONDUCTOR	= 797
EQUIPMENT		Wind Load Force in lbs			Height Above Ground			= MOMENT (ft.-lb.)		
TRANSFORMERS (SEE TABLE FOR INSTRUCTIONS)										
1 Phase	50 kva		231.8		x		29.9	=	6931	
									TOTAL MOMENT DUE TO EQUIPMENT	= 6931 ft.-lb.
									TOTAL ALL MOMENTS	= 7728 ft.-lb.

Maximum Allowable moment on 45/2 pole = 72108
 Transformer Moment = 6931
 Available for conductors = 65177
 Conductor Moments per foot of span = 797
 Maximum span distance = 82 ft.

CONDUCTORS		Number of Conductors	x	Wind Load Per Ft. (Table 4.2.2-7)	x	Avg. Span Length	x	Height Above Ground	=	MOMENT (ft.-lb.)
Primary										
568.3	1	x	3.816	x	1	x	39.50	=	151	
568.3	1	x	3.816	x	1	x	37.08	=	141	
568.3	1	x	3.816	x	1	x	35.08	=	134	
Neut. Sec., Still										
3/0	1	x	2.094	x	1	x	29.92	=	63	
CATV - PROPOSED										
Trunk	1	x	4.171	x	1	x	24.08	=	100	
TELEPHONE										
600 pr 24 Ga BKMA	1	x	9.573	x	1	x	23.08	=	221	
									TOTAL MOMENT DUE TO CONDUCTOR	= 810
EQUIPMENT		Wind Load Force in lbs			Height Above Ground			= MOMENT (ft.-lb.)		
TRANSFORMERS (SEE TABLE FOR INSTRUCTIONS)										
1 Phase	50 kva		231.8		x		30.42	=	7051	
									TOTAL MOMENT DUE TO EQUIPMENT	= 7051 ft.-lb.
									TOTAL ALL MOMENTS	= 7861 ft.-lb.

Maximum Allowable moment on 50/III-H pole = 95831
 Transformer Moment = 7051
 Available for conductors = 88780
 Conductor Moments per foot of span = 810
 Maximum span distance = 110 ft.

CONDUCTORS		Number of Conductors	x	Wind Load Per Ft. (Table 4.2.2-7)	x	Avg. Span Length	x	Height Above Ground	=	MOMENT (ft.-lb.)
Primary										
568.3		1	x	3.816	x	1	x	40.00	=	153
568.3		1	x	3.816	x	1	x	37.58	=	143
568.3		1	x	3.816	x	1	x	35.58	=	136
Neut. Sec. St Lt										
3/0		1	x	2.094	x	1	x	30.42	=	64
CATV - PROPOSED										
Trunk		1	x	4.171	x	1	x	24.58	=	103
TELEPHONE										
600 pr 24 Ga BKMA		1	x	9.573	x	1	x	23.58	=	226
TOTAL MOMENT DUE TO CONDUCTOR									=	824
EQUIPMENT				Wind Load Force in lbs				Height Above Ground	=	MOMENT (ft.-lb.)
TRANSFORMERS (SEE TABLE FOR INSTRUCTIONS)										
1 Phase	50 kva			231.8		x		30.92	=	7167
TOTAL MOMENT DUE TO EQUIPMENT									=	7167 ft.-lb.
TOTAL ALL MOMENTS									=	7991 ft.-lb.

Maximum Allowable moment on 50'4.7 KIP po	134559
Transformer Moment	7167
Available for conductors	127392
Conductor Moments per foot of span =	824
Maximum span distance =	155 ft.

Note: In some cases, the limiting factor for maximum span distance is not the wind loading, but the required clearance above the ground and above other conductors or cables. The attachment heights on the pole must be determined for all facilities at the appropriate operating temperatures and sags as defined by the NESC.

C. Storm Guying

One method to overcome the overload on a pole due to transverse wind load is to add storm guys. Storm guys are installed in pairs(back to back) – one on each side of the pole perpendicular to the pole line. These guys should typically be installed 6 inches to 2 feet below the primary attachments.

Calculating the size of the guy wire is very much like calculating a deadend guy.

1. Calculate the transverse wind load on the pole, conductors and all attachments and equipment.
2. The load is then used to size the guy wire based on the load, the attachment height and lead length.
3. A final check should be made to verify that the strength of the pole above the guy attachment is adequate.

Using the example of Case I above for the 45'2 pole, calculate the size of the storm guys and anchors required for extreme wind loading.

1. Transverse wind loads:

Pole	=	Wind load on pole
Primary	=	Wind Load per ft x span length x number of conductors
Neutral	=	Wind Load per ft x span length
CATV	=	Wind Load per ft x span length
Telephone	=	Wind Load per ft x span length
Transformer	=	Wind Load

Load on Pole	=				1713 pounds			
Primary	=	3.816	x	170	x	3	=	1946 pounds
Neutral	=	2.094	x	170	x	1	=	356 pounds
CATV	=	4.171	x	170	x	1	=	709 pounds
Telephone	=	9.573	x	170	x	1	=	1627 pounds
Transformer	=	231.8	x	1			=	232 pounds
								Total Load = 6583 pounds

2. Determine the guy wire size and anchor size required for this installation.

To calculate the tension in the guy wire use the equation below

$$\text{Equation 4.2.2-7} \quad T_{DG} = \frac{T_{TWL}}{L} \times \sqrt{H_G^2 + L^2}$$

Where:

- T_{DG} = Tension in down guy
- T_{TWL} = Transverse Wind Load
- L = The down guy Lead length
- H_G = The attachment Height of the down guy

Use the total transverse wind load for the load to be guyed with the guy attached 6 inches below C phase primary (34.1') and a lead length of 20 feet.

$$T_{DG} = \frac{6583}{20} \sqrt{(34.1)^2 + (20)^2}$$

$$T_{DG} = 13,013 \text{ Pounds}$$

For extreme wind loading, the required strength of the guy wire is equal to the rated breaking strength of the guy wire x 0.9.

Table 4.2.2-11 Storm Guy Strength

Guy Size	Rated Breaking Strength (RBS)	Allowable Guy Tension .9 X RBS
5/16	11200	10080
7/16	20800	18720
9/16	33700	30330

For this example, a 7/16" guy will be installed in each direction perpendicular to the pole line. Use the tension in the down guy to select the appropriate anchor. In this case, a 10" screw anchor will do the job.

3. One final check is to be sure that the pole length above the storm guy attachment has sufficient strength to support the load above it. Basically, this is just like calculating the strength of the total pole but now the "ground line" is at the storm guy attachment height and all of the facilities above this point will create a moment here.

With the top of the pole at 38' and the down guy at 34.1 feet, the length of pole exposed to the wind is now 38-34.1 = 3.9 ft.

Use equation 4.2.2-3 to determine the strength of this section of pole.

The circumference at 3.9 feet down from the top of the pole
 = 26.5 inches

$$M_r = 0.000264 \times (8,000) \times (26.5)^3 \times 0.75 = 29,478 \text{ ft.-lbs.}$$

Use equation 4.2.2-4 to find the area of this section of pole

$$A = 3.9 \left(\frac{25 + 26.5}{2} \right) \left(\frac{1}{12} \right) = 2.66 \text{ sqft}$$

Use equation 4.2.2-5 to find the center of the area of this section of pole

$$\text{Height of center of area, } H_{CA} = \frac{3.9(8.44 + 2(7.96))}{3(8.44 + 7.96)} = 1.93 \text{ ft}$$

Use equation 4.2.2-2 to find the wind load on this section of pole

$$\text{Load in pounds} = 0.00256 \times (145)^2 \times 1.0 \times 0.97 \times 1 \times 1 \times 2.66 = 139 \text{ pounds}$$

Use equation 4.2.2-6 to determine the moment due to the wind load on this section of the pole at the guy attachment point

$$\text{Moment} = 1.93 \times 139 = 269 \text{ ft lbs}$$

Determine the moment created by the wind load on the conductors

Primary	=	3.816	x	170	x	1	x	4.9	=	3179	Ft-Lbs
	=	3.816	x	170	x	1	x	2.5	=	1622	Ft-Lbs
	=	3.816	x	170	x	1	x	0.5	=	324	Ft-Lbs
										5125	Ft-Lbs

$$\text{Total Moment} = 269 + 5125 = 5393 \text{ Ft-Lbs}$$

This load is well under the strength calculated above and the design using storm guys will meet requirements.

4.2.3 Pole Framing

A. *Slack Span Construction*

Slack span construction is employed where it is impractical to follow conventional *guying practices*. The proper application is a pull-off from either a tangent pole or a properly guyed deadend pole to another properly guyed deadend pole. The intent is not to slack span to a stand alone (self-support) pole unless that pole has been properly sized for this application. Improper use of slack span construction can cause a pole to bow or lean which then can cause more slack in the conductors. More slack in the conductors can result in improper clearances and increased potential for conductors to make contact with each other.

The initial sag when installing slack spans limits the per conductor tension to 50 pounds.

Slack Span design criteria:

1. Vertical construction is preferred for two and three phase installations. Maintain 36" separation between phases at the poles.
2. Limit the span lengths to

Table 4.2.2-12 Slack Span Length & Sag

SLACK SPAN		
CONDUCTOR	MAXIMUM LENGTH	INITIAL SAG
568.3 ACAR	50'	3'-7"
3/0 AAAC	75'	2'-9"
1/0 AAAC	95'	2'-10"

3. Use class 2 poles minimum.
4. If crossarm construction is used, use the 9 foot heavy duty wood crossarms or the 8'6" steel crossarm for added horizontal spacing.

B. Targeted Poles

There are many poles in the distribution system identified as Targeted Poles. These poles are deemed critical by virtue of the equipment mounted on them or their importance to maintaining the system. As stated in The Distribution Design Guide "The following list comprises what will be considered targeted poles. When installing and/or replacing an accessible targeted pole, use a III-H concrete pole or a spun concrete pole for spans greater than 300 feet. If the pole is inaccessible, use a Class 2 pole, or consider relocating the equipment to an accessible concrete pole."

Targeted Pole List

"01" Feeder Switch Poles (first pole outside the substation)
Automated Feeder Switches
Interstate/Highway Crossings
Capacitor Banks
Multiple Primary Risers
3 Phase Reclosers
Aerial Auto Transformers
Multiple Circuits
3 phase Transformer Banks (3-100 kVA and larger)
Regulators
Primary Meter

The targeted pole also should meet the design criteria for wind loading as previously shown.

C. Distribution Design Guidelines

The Storm Secure Organization has developed a set of guidelines for Distribution Designers to use when designing or maintaining distribution facilities. The designer can go online to see the most current version.

III. PROCEDURES

III.A. PROCEDURES FOR JOINT USERS

FPL and Incumbent Local Exchange Carriers (ILEC) explore the benefits of joint use and share the cost of pole ownership.

New Construction

1. Before facilities are designed and put into place, the FPL engineer and the ILEC engineer discuss the needs of both companies and the requirements for design by either the detail plans filed with the FPSC or the existing joint use agreement.
2. The joint use agreement for each company dictates which company sets the new pole(s)
3. If FPL is building the pole line, a notice of build is sent by FPL to all CATV companies and telecommunication carriers with attachment agreements in the area.
4. If FPL is building the new pole line CIAC will be collected for the increased size and strength required to accommodate the facilities of all parties requesting attachments.

There are times when the ILEC determines they would like to attach to a pole they previously were not attached to or they wish to modify their facilities, which would in turn increase the loading on a pole

Existing Poles

1. If the ILEC is increasing load on the pole, it is imperative for the ILEC engineer to learn if the pole has been hardened or if the pole now has stronger windloading requirements due to detail plans filed with the FPSC. This is true if the pole is owned by FPL or the ILEC. Discussion with the FPL engineer will help determine the design criteria of the pole.
2. If the new attachment would compromise the loading standard, the ILEC engineer may request make-ready from the FPL engineer to accommodate their attachments. A contribution will be charged in accordance with our agreement.

III.B. PROCEDURES FOR THIRD PARTIES (CATV AND TELECOMMUNICATION CARRIERS (non-ILECs))

- 1) **APPLY** for permit.
 - When making new attachments or overlashing to existing attachments where the resulting bundle is heavier than the existing attachment or has an increased diameter over that of the existing attachment, apply for permit for attachments to FPL poles. Apply for a permit for Non-FPL poles that require FPL make-ready.
 - Remember that permits are not granted for attachments to poles that are exclusively part of an FPL street lighting system.
 - The attachment permit is for CATV cables, wires and supporting hardware only, not for power supplies, amplifiers or similar equipment.
 - Create appropriate permit application package(s):
 - Non-make ready
 - Make ready (requires design, cost approval, invoice, payment, and construction of FPL work order prior to FPL permit approval)
 - Major rebuild or upgrade
 - Review permit application package for accuracy and completeness to avoid rejection.
 - Submit complete permit package.
- 2) **RECEIVE** approved permit. (Exhibit "A")
- 3) **CONSTRUCT** attachments.
 - You must have an approved permit. (Exhibit "A")
 - You must complete construction within 60 days of permit approval (180 days if Major rebuild permit), or permit will automatically expire, and you will need to re-apply.
 - Build facilities as designed in approved permit package.

- Conform to FPL requirements (clearances, tagging, bonding, etc.) and NESC standards.
 - Field review facilities for compliance upon completion of construction.
- 4) NOTIFY of construction completion. (Exhibit "B")**
- Send notice monthly (provided there have been attachments/removals during that month). Remember to include all routine attachments to drop or lift poles.
 - Notice (Exhibit "B") must be sent to permit process contractor (Alpine).
 - Notice (Exhibit "B") must be sent within 30 days after construction of the attachments is complete.

III.C. PROCEDURES FOR GOVERNMENTAL ATTACHMENTS

Attachment Permits are required for:

- New attachments to FPL poles
- Overlashings of existing attachments to FPL poles where the resulting bundle is heavier than the existing attachment or has an increased diameter over that of the existing attachment
- Major rebuilds or upgrades
- Attachments to non-FPL poles that require FPL make-ready

The attachment permit is for Licensee cables, wires and supporting hardware only, not for power supplies, amplifiers or similar equipment.

Wireline attachments are not allowed to poles exclusively a part of an FPL street lighting system.

Permits requiring FPL make-ready will not be approved until FPL design, payment by the Applicant, and construction is completed by FPL.

PERMIT APPLICATION PROCESS

1. Field Survey - Identify ownership and pole size and existing attachments, conductor sizes, and span lengths.
2. Complete the Pole & Midspan Measurement Form
3. Ensure that all minimum clearances will be maintained.
4. Calculate windloading.
5. Complete the "Attachment and Application and Permit Exhibit A".
6. Assemble permit package (which may or may not include request for make ready.
7. Review completed package for accuracy
8. Submit package to FPL for approval
9. Once approved make attachments
10. When complete return Exhibit B to FPL

III.D. PROCEDURES FOR ATTACHMENTS TO TRANSMISSION POLES

Application Requirements

All applications for attachment to transmission poles require complete structural calculations. Applicant shall demonstrate that the poles can withstand the additional proposed mechanical and environmental loads. Calculations shall be provided with GT-STRUDL output forms, with non-linear analysis results, signed and sealed by a Professional Engineer – Structural, licensed in the State of Florida.

Application Costs

The cost associated with reviewing the application calculations will be the responsibility of the applicant. Review of calculations for approval is performed by FPL Transmission at a cost of \$96 per manhour (regardless of final approval or disapproval of the request). A deposit of \$2,000 dollars, payable to FPL, is required for quantities of up to 50 poles.

Application Process

Submit completed application to FPL Representative (same as for distribution attachments). Your representative will review the application for completeness. Completed applications will be forwarded to FPL's Transmission Projects Group for review.

1.0 DESIGN CRITERIA

When more than one code applies, the more stringent criteria shall govern.

1.1 CLEARANCES

Any overhead cable installation shall comply with FPL 2007 NESC Basic Clearances for Overhead Transmission Lines, the National Electric Safety Code (NESC)-2007 or other governmental agency codes.

1.2 DESIGN LOADS

1.2.1 POLE DESIGN

Design loads shall meet the specifications defined in the National Electric Safety Code (NESC)-2007, the American Society of Civil Engineer (ASCE) latest edition "Minimum Design Loads for Buildings and Other Structures" and ASCE Manuals #74, "Guidelines for Electrical Transmission Line Structural Loading".

STEEL TRANSMISSION STRUCTURES

Designs shall meet the specifications defined in the ASCE/SEI 48-05 "Design of Steel Transmission Pole Structures" latest edition, and ASCE Standard latest edition, "Design of Latticed Steel Transmission Structures".

CONCRETE TRANSMISSION POLES

Designs shall meet the specification defined in the ASCE-PCI "Guide for the Design of Prestressed Concrete Pole".

WOOD TRANSMISSION POLES

Designs shall meet the specification defined in the IEEE Standard 751 "Trial-Use Design Guide for Wood Transmission Structures".

1.2.2 WEATHER RELATED LOADS

Transmission poles are required to resist the weather-related loads (Extreme Wind and Ice/Wind). The applied wind load cases that need to be considered for transmission structures from ALL angles are defined as follows:

Under Combined Ice/Wind loads (NESC Section 250 B)
FPL service territory is classified as the "Light Loading District".

Under Extreme Wind Loads (NESC Section 250 C)
ASCE latest edition "Minimum Design Loads for buildings and Other Structures" and ASCE Manuals #74, "Guidelines for Electrical Transmission Line Structural Loading" are the basis of this control criteria.

Under Serviceability Requirements (FPL Policy for Concrete Pole)

45 mph wind load is considered as the minimum wind load applied for this zero-tension condition, which is only applied to prestressed concrete poles. The calculation of the wind pressure also follows the requirements of ASCE latest edition "Minimum Design Loads for Buildings and Other Structures" and ASCE latest edition Manuals #74, "Guidelines for Electrical Transmission Line Structural Loading".

Basic Wind Speeds (ANS/ASCE latest edition). Refer to enclosed drawings showing Basic Wind Speeds(within FPL Service Territory. Map file name: wind_cont_FL-1.g12 created 10-22-02 attached.

1.2.3 OSHA REQUIREMENTS

This project shall be designed to meet all Occupations Safety and Health Administration (OSHA) rules and regulations.

2.0 PERMIT PACKAGE

A permit application shall consist of two (2) complete packages in the following order:


- 1) Payment for Permit (payable to FPL)
- 2) Original, signed Exhibit "A" (front and back)
- 3) Calculations (signed and sealed)
- 4) Field Notes
- 5) Pictures of all affected poles, with corresponding pole identification numbers (photographs or jpeg files)
- 6) Licensee maps (plan/profile) showing route, spans, pole heights, and the Licensee facilities proposed for installation
- 7) Copy of the FPL Primary Map, with the affected area highlighted

3.0 APPROVAL / DISAPPROVAL

Upon review of the permit application, a response stating approval or disapproval will be communicated by the FPL – Transmission Projects Department

FLORIDA WIND ZONES-2002

To Be Used For Transmission Attachment Permits



Docket No. 070301-E1
FPL Storm Hardening Plan
Exhibit MBM-1 Page 187 of 223



BellSouth Telecommunications, Inc.

R. E. Christian, Jr.
State Manager – Joint Use/Right of Way

301 W. Bay Street, 15HH1
Jacksonville, FL 32202
Tel. No. (904) 798-7812
Fax No. (904) 350-2720

Email: earl.christian@bellsouth.com

April 23, 2007

Mr. R. L. Valdez
Senior Regulatory Analyst
Florida Power & Light Company
9250 West Flagler Street
Miami, Florida 33174,

Subject: Florida Power and Light Company (FPL) 2007-2009 Hardening Plans

Dear Mr. Valdez:

In response to your March 22 request for BellSouth Telecommunications, Inc., d/b/a AT&T Florida (AT&T Florida) to review and provide input to FPL's 2007-2009 Hardening Plans, attached is our initial response. Due to the scope of information provided to AT&T Florida and the timeframe in which AT&T Florida had to respond, AT&T Florida reserves its right to supplement this response.

AT&T Florida thanks FPL for the opportunity to review the hardening plans, for the opportunity to meet and discuss the various issues. AT&T Florida looks forward to continuing a dialogue with FPL regarding its hardening efforts so that the most accurate cost information and feedback can be provided to the Florida Public Service Commission prior to its review of the Hardening Plan.

Sincerely,

A handwritten signature in cursive script that reads "Earl Christian".

State Manager – Joint Use/Right of Way

Attachment

BellSouth Telecommunications, Inc. d/b/a AT&T Florida's Initial Response to FPL's Proposed Electric Infrastructure Hardening Plan for 2007 – 2009

BellSouth Telecommunications, Inc. d/b/a AT&T Florida ("AT&T Florida") provides the following initial response to FPL's Electric Infrastructure Hardening Plan forwarded to AT&T Florida on March 22, 2007 ("Hardening Plan"). Due to the scope of information provided to AT&T Florida and the timeframe in which AT&T Florida had to respond, AT&T Florida reserves its right to supplement this response.

FPL's Hardening Plan

FPL plans to harden its infrastructure during 2007 through 2009 through three primary methods by: building to Extreme Wind Loading criteria ("EWL"), engaging in "incremental hardening," and implementing new design guidelines and processes for new construction and major planned work.

2007 Deployment

1. EWL:

In 2007, FPL plans to use EWL to harden twenty-eight (28) Critical Infrastructure Facilities (CIF) which are served by thirty-four (34) primary circuits. The costs that AT&T Florida potentially faces in connection with this aspect of FPL's Hardening Plan can be broken down into the following major categories:

- Costs to transfer facilities from an existing pole to a replacement pole
- Costs to replace cable in instances where FPL moves a pole line such that transfers of existing cable are not feasible
- Contribution costs FPL may seek from AT&T Florida for the replacement poles
- Increased pole rental rates

With regard to the first two items, AT&T Florida cannot accurately estimate costs because AT&T Florida does not know how many of its attachments will be impacted and the type of work that would need to be performed on those attachments. The level of detail regarding the proposed hardening projects that AT&T would need to perform this analysis is not contained in FPL's Hardening Plan. While FPL did provide more detailed information on many of the CIF projects to AT&T Florida on Tuesday, April 17, 2007, AT&T Florida has not had sufficient time to analyze this information before FPL's April 23, 2007 deadline for a response. Accordingly, AT&T Florida reserves its right to supplement this response and to request additional information from FPL if needed.

With this caveat, to facilitate the exchange of information contemplated by Rule 25-6.0342(6), however, AT&T Florida estimates that the transfer of facilities and the replacement of cable owned by AT&T Florida in connection with FPL's proposed hardening of 28 CIFs in 2007 would cost approximately \$4.3 million. In developing this

rough estimate, AT&T Florida assumed that it would have aerial facilities on 18 of the 34 circuits to be hardened, translating into 3,600 spans of AT&T Florida aerial facilities. AT&T Florida further assumed that approximately 20% of the 3,600 spans (720 spans) would involve replacing cable at an estimated cost of \$4,000 per span. AT&T Florida estimated that the remaining 80% (2,880 spans) would involve transfer work at an estimated cost of \$500 per span.

AT&T Florida may face additional costs if FPL seeks contribution toward the cost of new poles. In Section III(A) of its Proposed Hardening Plan entitled "Procedures for Joint Users," FPL states that Contribution In Aid of Construction (CIAC) will be collected "for the increased size and strength required to accommodate the facilities of all parties requesting attachments" and that contribution will be charged in accordance with existing joint use agreements. (*See Hardening Plan* at 47.) In the informational meeting held by FPL on April 12, 2007, FPL indicated that it was still evaluating the contribution issue. Without more specific information on this issue, AT&T Florida remains concerned of the potential for unjustified cost shifting under its existing joint use agreement with FPL.¹ AT&T Florida reserves the right to supplement this response pending further clarification of this issue.

Lastly, hardening of the electric infrastructure will likely result in increased pole rental rates. Because AT&T Florida cannot estimate the potential cost impact of increased rates until rate negotiations are initiated, AT&T Florida reserves the right to supplement its response on this issue.

2. Incremental Hardening

FPL proposes to address thirty-four (34) community projects, which FPL defines as feeders that serve community needs (e.g., grocery stores, gas stations), through incremental hardening. Again, AT&T Florida cannot accurately estimate how many of its attachments will be impacted and the type of work that would need to be performed on those attachments until it receives and analyzes more detailed information on these proposed projects. Assuming that it will have aerial facilities at ten (10) of these sites comprised of ten (10) poles per site, AT&T estimates an additional \$80,000 in cable replacement costs and \$40,000 in transfer costs in connection with FPL's proposed incremental hardening plans for 2007. Again, this is a rough estimate based on limited information.

3. New Design Guidelines

While AT&T Florida has communicated to FPL that AT&T Florida will voluntarily increase the class size of wood poles in its distribution system under certain circumstances, AT&T Florida objects to any references in FPL's *Addendum to FPL's*

¹ The existing joint use agreement between FPL and AT&T Florida addresses the responsibility for pole replacement costs, as well as transfer costs. AT&T Florida will attempt to resolve these issues relative to hardening projects with FPL prior to the Florida Public Service Commission's review of FPL's Hardening Plan so that more accurate cost information can be provided and considered.

Permit Application Process Manuals, Attachment Agreements and Joint Use Agreements that implies that AT&T Florida's poles are governed by FPL's design criteria. Additionally, AT&T Florida would like to have further discussions with FPL regarding how the *Addendum* will impact current joint use operating procedures. AT&T Florida reserves the right to provide further input on the *Addendum* following this dialogue.

2008 & 2009 Deployment

AT&T Florida is not able to estimate the potential cost impact of FPL's Hardening Plan for 2008 and 2009. FPL has not yet identified the locations to be hardened or the method by which the hardening will be accomplished (i.e. EWL vs. incremental hardening). AT&T Florida requests that FPL provide these detailed plans as soon as they are developed so that AT&T Florida can provide the input contemplated by Rule 25-6.0342(6). AT&T Florida reserves the right to comment on these plans once they are finalized.

Benefits of Hardening Plan

The most significant benefit AT&T Florida may recognize from implementation of the Hardening Plan would be from the potential reduction of commercial power outages. As a customer of FPL, AT&T Florida relies on electric service to power its remote terminals. AT&T Florida cannot quantify this potential benefit as it would be difficult to determine how many remote terminals are served by the circuits that will be hardened.

Conclusion

AT&T Florida's input is limited by the scope of the information provided and the timeframe in which AT&T Florida had to respond. AT&T Florida looks forward to continuing a dialogue with FPL regarding its hardening efforts so that the most accurate cost information and feedback can be provided to the Florida Public Service Commission prior to its review of the Hardening Plan.

LAWYERS



Davis Wright Tremaine LLP

ANCHORAGE BELLEVUE LOS ANGELES NEW YORK PORTLAND SAN FRANCISCO SEATTLE SHANGHAI WASHINGTON, D.C.

MARIA BROWNE
DIRECT (202) 973-4281
Maria.Browne@dwt.com

SUITE 200 TEL (202) 973-4200
1919 PENNSYLVANIA AVENUE, N.W. FAX (202) 973-4499
WASHINGTON, D.C. 20006-3402 www.dwt.com

April 23, 2007

Via Electronic and First Class Mail

Bob Valdez
Florida Power & Light Company
Regulatory Affairs Room No. 6047
9250 West Flagler Street
Miami, Florida 33174

Re: FPL 2007-2009 Storm Hardening Plans

Dear Mr. Valdez:

I am writing on behalf of the Florida Cable Telecommunications Association (FCTA) concerning the Florida Power and Light Company Electric Infrastructure Storm Hardening Plan ("Plan") dated March 22, 2007. Florida Administrative Code, Rule 25-6.0342(6) requires pole owning utilities, such as FPL, to seek input from and attempt in good faith to accommodate concerns raised by other entities with existing agreements to share the use of its electric facilities. In your cover letter accompanying the Plan, you asked that FCTA member cable operators provide input concerning the Plan by no later than today, April 23, 2007. In an email dated April 9, 2007, FCTA asked for additional information as well as additional time to review the data and compile cost data for input, but FPL responded that it unable to grant FCTA's request due to the deadline imposed by the Public Service Commission (PSC) of May 7, 2007 for submission of plans to the PSC.

As a preliminary matter, FCTA appreciates the substantial responsibility that FPL has as a pole owner and respects the management decisions FPL has reached in its Plan. The information presented by FPL in the Plan and in additional materials sent via compact disc on April 16, 2007 address substantial portions of FPL's plant to which cable operators are attached and cover a large geographic area. As you know, Comcast is the largest cable operator in FPL's service territory. Comcast has distributed the information to its field representatives in numerous geographic areas for their analysis and review. These representatives have initiated a review of the proposed plans and the impact that such Plan will have on its attachments. However, given



Bob Valdez
Florida Power & Light Company
April 23, 2007
Page 2

the volume of information presented, it will be some time before Comcast will have a true sense of the impact that FPL's Plan will have on its attachments and related activities.

Moreover, while a significant amount of information was included in the plans, additional information was not included that would greatly aid Comcast in providing constructive information to FPL about the costs and benefits of such plans, including the effect on reducing storm restoration costs and customer outages. For example, FPL: provided information only for some example communities not all, only included information about its own attachments to the poles and not those of third party attachers, fails to explain the precise work that will be necessary for third party attachers (i.e., it may state that the pole needs to be replaced but does not further indicate whether the attachments will be transferred to the new pole or re-routed, does not indicate why a particular action is being taken (i.e., whether the pole is being replaced because it is overloaded or rotten), does not indicate the extent to which its storm hardening efforts will delay construction of new third party attachments, and does not give an estimate of the costs for the proposed work or what costs it expects to shift to attaching entities.

We realize that the Plan cannot be extremely detailed as illustrated by the wide ranging estimate of \$40 million to \$70 million in anticipatory hardening related costs that FPL projects for 2007 alone. FPL has stated that it does not yet know what portion of these costs will be billed to cable operators or other third party attachers. We agree that many of the details of costs and benefits of storm hardening must be resolved after the May 7, 2007 filing deadline. However, without this type of information, third party attachers cannot discern the possible cost to them associated with the Plan.

Moreover, as discussed at the meeting held April 13, 2007, third party attachers initially were not consulted in determining what would constitute critical infrastructure and targeted poles. As a result, it does not appear that poles carrying main line cable operator feeders were included. Cable operators now provide life-line services to Florida residents, including valuable communications infrastructure that is relied upon in storm restoration and 911 services. Accordingly, it is possible that certain poles carrying cable facilities should be added to the list of critical infrastructure and targeted poles. FPL stated that it was willing to consider recommendations from cable operators and other third party attachers concerning proposed additions to FPL's list of critical infrastructure and targeted poles. Again, this issue will likely be resolved after the May 7, 2007 filing deadline.

Comcast understands that it may have been difficult for FPL, in the timeframes established by the PSC, to have anticipated and provided all of the detail necessary for third party attachers to give meaningful input. However, given the broad scope of information addressed in the Plan and the limited amount of cost-related detail provided, it would be counter-productive to limit third party input to a one-time response. Instead, FCTA suggests that this plan be only the starting point for discussion between pole owners and third party attachers. FCTA



Bob Valdez
Florida Power & Light Company
April 23, 2007
Page 3

members believe it would be extremely beneficial to all parties to the proceeding and to Florida consumers to hold regularly scheduled workshops to ensure that as specific plans are implemented, third party attachers have an opportunity to participate in the decision making process. Such workshops would also allow third party attachers an opportunity to propose some additional facilities that they believe should be included as critical infrastructure and/or targeted poles. These workshops have worked well in the past to promote good working relationships and good project results, and should be beneficial in working through the storm hardening issues.

While FCTA was not able to provide precise costing data in response to FPL's Plan for the reasons set forth above, FCTA nevertheless has the following comments on the general features of the Plan, which FCTA believes should be treated as initial comments in an ongoing dialogue between cable attachers and FPL.

Electric Infrastructure Storm Hardening Plan

- Page 7, Hardening Existing Facilities. This section explains the process of capturing detailed information at each pole location of a storm hardening project. If the detailed information can be shared with cable operator personnel for the purpose of designing cable operator work associated with the project, much duplication of field work can be eliminated and good results can be expedited.
- Page 7, Examples of Hardening Options: Storm Guying. FCTA agrees that storm guying where practical is a very cost effective means of strengthening poles up to and including extreme wind standards. We also believe that more emphasis on identifying lines or portions of lines which should be strengthened by storm guying will be a good addition to the FPL plan. In addition, the storm guying effects of crossing power and communications lines should be left in the wind loading calculations for poles being hardened. Both crossing lines and lateral pull-off lines whose pull is balanced by down guy wires serve the same purpose as storm guys on existing poles. Ignoring the effects of such lines on wind loading substantially increases the cost of individual projects.
- Some areas of proposed storm hardening of critical infrastructure circuits are shielded to a great extent by tall trees above the height of the distribution lines while others are shielded by tall buildings. The shielding effects of trees and buildings have not been considered by FPL. Clearly, if the trees or buildings do not blow down they shield the line from high winds. If they do blow down they take the storm hardened poles with them. Trees and buildings should be considered, at least in some circumstances. Inclusion of this additional information in the Plan would be helpful.
- It would be very helpful if FPL could provide the number of poles it proposes to change out and the proposed type of replacement pole (i.e., wood, concrete, steel) for each of the categories identified by FPL – i.e., Critical Infrastructure, Community Project, Critical Poles. Gulf Power recently provided this level of detail in its third draft of its Plan at page 10, which is attached hereto for your convenience.



Bob Valdez
Florida Power & Light Company
April 23, 2007
Page 4

- It would be helpful to include in the Plan additional information concerning storm restoration coordination.

FPL Attachment Standards and Procedures Addendum

Section I: Safety

- Page 4. To the extent that FPL adopts requirements they should be reasonable implementations of applicable codes.
- Also on page 4 in the 5th paragraph please explain what is meant by "At no time may the CATV worker encroach upon the electric supply space." It would be best to state that communications workers must at all times comply with applicable NESC and OSHA work rules.
- Also on page 4 in the 6th paragraph concerning RF emitting devices, please provide for at least 48 hours advance notice to the device owner before disconnecting power except in emergencies. Moreover, most wireless (RF emitting) devices attached by cable operators are line powered through the existing cable system and do not require FPL meters. Would this still require a termination switch?

Section II: Standards

- Overlashing a fiber optic cable to an existing cable should not require a permit, notification of FPL only. It is our understanding based upon conversations with FPL that in fact FPL only intends to require approval for overlashing where diameter size of existing facility will be increased. The Plan should so state.
- Page 8, Clearances of communications cables to FPL. At dimension letter B, add an asterisk and refer to NESC Rule 238D Exception which allows reduction of the 12" clearance to 3" if the loop is covered.
- Page 10, Clarification of installation of poles in private easements. If FPL places pole in private easement do third party attachers require a separate easement or is the language of the FPL easement agreement include cable operator?
- At dimension letter F the new requirement in the 2007 NESC is 40". See NESC Rule 239G1. (The change was to Exception 1). The FPL 3" requirement should be referenced for grandfathering of facilities installed prior to 2007.
- At dimension letter K, the 12" separation between cable messengers became effective in NESC 2002 with a requirement for 4" separation between cables in the span under the specified conditions. Please reference NESC Rule 235H 1. and 2.
- At dimension letter L, the recognition of the NESC exception allowing 30" separation is good. Please add reference to NESC Rule 235.2.b.(1)(a). Exception 1. This rule reduces



Bob Valdez
Florida Power & Light Company
April 23, 2007
Page 5

the required clearance between the neutral and cable to 12 inches in the span, not 30.”
The rule also applies to separation between fiber optic cable (supply) and communications cables in the communication space.

- Section II.C. Windload Criteria and Calculations. It would be helpful if this section explained criteria for determining which party is responsible for pole overloading, and how costs for any necessary work to bring pole into compliance will be allocated.
- Section III.B. Procedures for Third Parties (CATV and Telecommunication Carriers). It would be informative if the Addendum included timeframes for the pole makeready process including but not limited to the permit process and completion of work specified by Make Ready engineering approval, so that attachers would have a sense of whether storm hardening activities will impact speed to market.

In addition, there are certain provisions included in the Plan that do not appear to be related to storm hardening but instead appear to be standard terms and conditions of attachment. For example, Section III.B. provides that when overlashing to existing attachments or increasing wire diameter, third parties (CATV and non-ILEC telecommunications carriers) must obtain a permit.¹ Similarly, the same section implies that power supplies, amplifiers and similar equipment will be subject to separate permitting requirements, and thus additional rent. However, permitting is required for rental rate purposes and the rates, terms and conditions of attachment are not before the PSC in this proceeding. Florida Administrative Code, Rule 25-6.0342(8). Accordingly, FCTA believes that these provisions should not be included in the Plan.

FCTA commends FPL on its reliance on the NESC requirements to a great degree for the engineering guidelines for separation between electric and communications attachments. FCTA believes that the suggested changes are consistent with FPL's intentions when these standards were established before recent revisions of the NESC and that most, if not all, the suggestions will be acceptable to FPL. Moreover, FCTA members do see a significant benefit from several of the ten initiatives being deployed by FPL including its three year cycle for vegetation management and eight year inspection plan. Ensuring that wires are not endangered by tree limbs and that poles are not rotten or overloaded, should significantly assist in efforts to prevent storm outages and in storm restoration. Rotten poles in particular are a serious problem in high wind situations because they can cause a cascading effect.

FCTA members would like to work with FPL to ensure that distribution pole infrastructure is hardened to withstand stronger winds and to improve storm restoration. To that end, FCTA members strongly believe that continued open lines of communication and workshops in details of storm hardening plans are provided and input from third parties is solicited extending over the course of the Plan's implementation would significantly contribute

¹ In a subsequent conversation it was explained that in fact permits would only be required where the diameter of wire is increased, as is currently the case.



Bob Valdez
Florida Power & Light Company
April 23, 2007
Page 6

to state's efforts to ensure the availability of power and communications services in extreme weather situations.

Please feel free to contact me if you have any questions or comments related to these initial responsive comments. We look forward to an ongoing dialogue and working together to hardening FPL's infrastructure in a manner that is beneficial to all involved.

Sincerely,

A handwritten signature in cursive script that reads "Maria T. Browne".

Maria T. Browne

ATTACHMENT



Gulf Power Company
 Storm Hardening Plan – DRAFT 4/19/07
 pumping/treatment plants and major sewage treatment plants. The
 planned projects are shown in the table below.

2007 - 2008	District	Critical Load	Total Main Miles	Estimated Number of Pole Changeouts
	Western	Fuel Depot	1.38	46
	Central	Fuel Depot	2.83	100
	Eastern	1-10 Crossings	N.A.	16
TOTAL ALL				162
2008 - 2009	District	Critical Load	Total Main Miles	Estimated Number of Pole Changeouts
	Western	Hospital	3.56	125
	Central	1-10 Crossings	N.A.	14
TOTAL ALL				139
2009 - 2010	District	Critical Load	Total Main Miles	Estimated Number of Pole Changeouts
	Central	Hospital	2.14	75
	Central	Hospital	1.08	38
	Western	1-10 Crossings	N.A.	56
TOTAL ALL				169
Three Year Plan Totals		Company		470

The estimated poles which may be subject to replacement based on the above and possible impact from Joint-Use Assessments are as follows:

Year	Extreme Wind Loading	Joint-Use Assessments	Total Estimated Poles Impacted
2007-2008	162	500	662
2008-2009	139	500	639
2009-2010	169	500	669

9.1.2 Transmission

Gulf Power transmission utilizes overload and strength factors greater than or equal to those required in Section 26 of the National Electric Safety Code. Gulf's loading criteria for new line design is derived from Section 25 of the National Electric Safety Code. These design criteria are used on all new installation and complete rebuild projects throughout the Gulf Power service territory.



Voice | Data | Internet | Wireless | Entertainment

Embarq Corporation
Mailstop: FTLH00201
1311 Blair Stone Road
Tallahassee, FL 32301
FMRARQ.com

May 2, 2007

Mr. Bill Walker
Florida Power & Light Company
215 South Monroe Street, Suite 810
Tallahassee, FL 32301-1859

In RE: Florida Power & Light Storm Hardening Plan

Dear Mr. Valdez:

Embarq has reviewed the Florida Power & Light Electric Infrastructure Storm Hardening Plan dated March 22, 2007 for the years 2007 through 2009 and which was discussed in the April 23, 2007 meeting in Miami. While the plan provided some specifics, e.g. the intent to harden the facilities serving Naples Community Hospital and Lee Memorial Hospital in 2007, most of the plan is non-specific. Therefore, in order to respond regarding the impact of this plan on Embarq, certain assumptions have been made. If additional details are provided regarding the plan, Embarq will review this response and provide a more targeted estimation of the costs and benefits.

Based on the assumption from the plan that FP&L will harden approximately 20% of their poles in the first three years of this plan, Embarq applied that 20% factor times the number of FP&L poles with Embarq attachments in order to arrive at an estimate of the direct and immediate costs to Embarq. Using the formula in the current Joint Use Agreement between FP&L and Embarq and the costs of transferring attachments as well as the costs of existing and new joint use poles, the estimated cost to Embarq is \$13,967,200.00 in years 2007 through 2009 of the plan. If 50% of FP&L's poles are hardened within ten years, the cost to Embarq would be almost \$35,000,000.00 for the ten years (2007 - 2016). Another potential cost which may not be as immediate nor as direct would be increases in pole attachment fees charged by FP&L.

FP&L's Hardening Plan may benefit Embarq by reducing the amount of damage to our facilities, thereby reducing the number of customer outages and reducing the time to restore service. The extent of these benefits will not be known until the next storm and they cannot be readily quantified in dollar savings; however, Embarq does not believe that it is likely these benefits will outweigh the costs.

Sincerely,

Sandra A. Khazraee

cc: Mr. Bob Valdez, FP&L
Mr. Henry Bowlin, Embarq
Mr. Bill Radel, Embarq

Sandra A. Khazraee
REGULATORY MANAGER
LAW AND ETHICS ADVISOR
Voice: (850) 847-0173
Fax: (850) 878-0772

Bob Valdez
05/02/2007 06:13 PM

To: "Dave Bromley" <Dave_Bromley@fpl.com>
cc:
Subject: Fw: Fwd: 2007 Hardening projects

----- Original Message -----

From: "Denise Yoezle" [DYOEZLE@hollywoodfl.org]
Sent: 05/02/2007 04:33 PM
To: Bob Valdez
Subject: Fwd: 2007 Hardening projects

Hi Bob,
Is there another person I can contact for this information?

Denise Yoezle
Operations Manager
Streets & Highways
City of Hollywood
954-967-4526

>>> Denise Yoezle 4/30/2007 9:37 AM >>>

Hi Bob,
I see on your March 22, 2007 correspondence that Memorial Regional Hospital is on the list of 28 Critical Facilities to be hardened. Do you have a schedule for completion of the work at this facility?

Also, of the 34 Community Projects, 11 are located in Broward County. Are any of these located in the City of Hollywood?

We have reviewed the criteria and have no comments, other than to welcome all such efforts for a speedy and effective post-storm recovery.

Regards,

Denise Yoezle
Operations Manager
Streets & Highways

City of Hollywood
954-967-4526



Tony Newbold
04/18/2007 11:27 AM

To: Bob Valdez/RAD/FPL@FPL
cc:
Subject: Fw: Hardening Plans



"Paul W. Milelli"
<pmilelli@psd.co.palm-beac
h.fl.us>
04/11/2007 12:01 PM

To bob_valdex@fpl.com
cc Greg_Cope@fpl.com, Tony_Newbold@fpl.com, "Charles
Tear" <ctear@psd.co.palm-beach.fl.us>
Subject Hardening Plans

Mr. Valdez:

After reviewing the plans provided to Palm Beach County, we offer the following comments:

1. The 2007 Deployment Plan identified four "Acute Care Facilities" in Palm Beach County for "EWL" activities. While we support any activities that will harden the electrical grid leading to all of our facilities, we question how the hospitals were selected, in particular, Good Samaritan Hospital and the Veteran's Administration Hospital.

Good Samaritan Hospital is within the County's Hurricane Vulnerability and Surge Zones and must evacuate in the event of a landfalling hurricane. St. Mary's Hospital (it's sister facility) rests on higher elevation, is one of our County's Trauma Centers, lies outside of the evacuation zones, and is the recipient of Good Samaritan's patients. We would believe that our hospitals outside of the surge and vulnerability zones would take priority over those within the hurricane zones.

The V.A. Hospital, while outside of the surge and vulnerability zones, does not accept patients from the general public. Similarly, we would believe that hospitals serving the general public would take priority.

2. The 2007 Deployment Plan identified ten (10) "Community Projects" for "EWL" activities. While we support any activities that will harden the electrical grid leading to all of our critical infrastructure, we question how FPL selected the listed Feeder's. Of the over 400 Feeders within Palm Beach County serving critical infrastructure, we have identified the top 20% of the feeders for priority restoration immediately following a hurricane. None of the ten feeders identified in the 2007 Deployment Plan is within our top 20%. We have worked with our account executives from FPL to create the list (please see attached) and we would suggest that the Deployment Plan recognize this list as a generator of FPL's Community Project hardening.

The 2007 Deployment Plan speaks to the 2008 and 2009 deployment plans and the critical facilities and community projects selected for upgrading during those years. We would suggest that FPL partner with our County Emergency Management Division staff to review, and possibly modify the "Targeted Facilities" lists for 2008 and 2009.

Again, we support FPL's aggressive hardening plans. We strongly suggest and encourage FPL's consideration of partnering with the County in selecting future feeders and facilities for the electrical grid hardening.

Should you have any questions, please feel free to contact me.

Paul W. Milelli, Director
Department of Public Safety
Palm Beach County
20 South Military Trail
West Palm Beach, FL 33415

561-712-6470 (Office)
561-712-6490 (Fax)



PBTop20PercentFdrs04022007.xls



Barbara Gilbreath
04/30/2007 09:22 AM

To: Bob Valdez/RAD/FPL@FPL
cc: timothy young
Subject: FiberNet Cost Estimates

Bob,

Attached is a summary of costs associated with the hardening of the circuits supplied on the CD. The total cost to FN is estimated at \$15,584.00.

Should you require additional information, please advise.

Barbara Gilbreath
Manager-OSP Engineering and Construction
305-552-2879



FN Cost Summary.x

[FPL FiberNet Cost - 2007 FPL Network Hardening

<u>FPL Circuit Number</u>	<u>FPL FN Cost</u>
404032	\$2,381
803835	\$1,800
804535	\$1,200
101539	\$3,303
501137	\$6,900
	\$15,584

- **Mr. Henry Bowlin**
Process Specialist II
Embarq, Florida, Inc.
MS: LAPKA0241-2191
555 Lake Border Drive
Apopka, Fl 32703-5815

- **Ms. Maria Browne Esquire**
1919 Pennsylvania Ave NW
Suite 200
Washington D.C. 20006

- **Mr. Cody Harrison**
Sabin, Bermant & Gould LLP
Four Times Square
New York, New York 10036

- **Mr. Douglas C. Nelson**
233 Peachtree Street N.E.
Suite 2200
Atlanta, GA. 30303

- **Mr. Christopher McDonald**
Comcast
Direct or State Government Affairs-Florida
300 West Pensacola Street
Tallahassee, Florida 32301

- **Mr. Steve R. Lindsay**
Staff Consultant-Network Engineering
Verizon
8800 Adamo Drive
Mail Code: FLTP0937
Tampa, Fl 33601

- **Mr. R.E. Christian, Jr.**
State Manager-Joint Use/Right of Way
Bell South Telecommunications, Inc.
301 W. Bay Street, 15hh1
Jacksonville, Fl 32202

- **Mr. Gary Cary**
Windstream Florida, Inc.
206 White Ave.
Live Oak, Fl 326064

- **Mr. Jimmy Albritton**
Northeast Florida Telephone Company
130 North 4th Street
Macclenny, Fl 32063-0485

- **Ms. MaryAnn Holt**
Indiantown Telephone Systems
15925 S.W. Warfield Blvd.
Indiantown, Fl 33456

- **Mr. Terry Ray**
Vice President and CFO
ExteNet, System, Inc.
1901 s. Meyers Rd.
Suite 190
Oakbrook Terrace, IL 60181

- **Ms. Carla Hicks**
e.spire/ACSI/Fiberlight
6230 Shiloh Rd. Suite 210
Alpharetta, GA. 30005

- **Mr. John Hunt**
FDN Communications
2301 Lucien Way, Suite 200
Maitland, Fl 32751

- **Mr. Sheldon S. Jordan**
FPL Fibernet LLC
9250 West Flagler Street
Miami, Fl 333174

- **Ms. Kristin Johnson, President**
Hotwire Communications, LLC
300 E. Lancaster Avenue, Suite 208
Wynnewood, PA 19803

- Ms. Tricia Brekenridge
KMC Telecom
994 Explorer Blvd.
Huntsville, Al 35801
- Mr. Steve Mako
Level 3 Communications
2121 West Prospect Rd.
Tamarac, Fl 33309
- Mr. Jay Malinowski
Level 3 Communications
5907 F Hampton Oaks Pkwy
Tampa, Fl 33610
- Pat Fernandez
Level 3 Communications
1800 Pembroke Dr.
Orlando, Fl 32810
- Mr. Michael Hughes
Lightstream Tech
3550 West Waters Ave.
Tampa, fl 33614
- Mr. Virgil Springer
MCI
6929 N. Lakewood Ave.
Tulsa, OK 74117
- Mr. Joe Faber
PT Wireless
444 Hight Street, Suite 400
Palo Alto, CA 94301
- Mr. Gary Hunt
Qwest Communications Corporation
700 West Mineral Avenue
UT H27.19
Littleton, Colorado 80120
- Mr. Ken Kirkland
SETEL
1165 South 6 Street
Macclenny, Fl 32063

- Mr. Paul T. Bradshaw
Sunesys, LLC
202 Titus Av
Warrington, PA 19876
- Mr. Tom Terwilliger
S.F.M. & T., INC.
15398 S.W. 153 St.
Miami, FL 33187
- Mr. Thoomas J. Farrell
TAPCO
23170 Harborview Road
Charlotte Harbor, FL 33980
- TCG South Florida
Attn: V.P. of Operations
1001 West Cypress Creek Rd.
Suite #209
Fort Lauderdale, FL 33309
- Ms. Janet Livengood
Telcov
DDI Plaza Two
500 Thomas Street, Suite 400
Bridgeville, PA 1507-2838
- Ms. Loren Rosenthal
Tier 3 Communications
2235 First Street
Suite 217
Fort Myers, Florida 33901
- Carlie Ancor
U.S. Metropolitan Telecom, LLC
2407 Production Circle
Bonita Springs, FL 34135
- Ms. Leslie Strickland-Corporate Accounting
XO Communications
11111 Sunset Hills Road
Reston, VA 20190

- **City of Cocoa Beach**
Mr. Thiel, I.T. Director
2 South Orlando Avenue
Cocoa Beach, Fl 32931

- **City of Stuart**
Attn: City Clerk
121 S.W. Flagler Avenue
Stuart, Fl 34944

- **City of Miami Beach**
Attn: City Clerk
1700 Convention Center Drive
Miami Beach, Florida 33139

- **Mr. Jack Yaghdjian**
WLRN
172 N.E. 15 Street
Miami, Fl 33132

- **City of South Daytona**
Attn: City Clerk
1672 S. Ridgewood ave.
South Daytona, Fl 32119

- **Collier County**
Attn: Board of Commissioners
3301 E. Tamiami Trail
Naples, Fl 34112

- **Myakka River State Park**
13207 S.R. 72
Sarasota, Fl 34241

- **Sarasota County**
Chairman of Board of Commissioners
1001 Sarasota Center Blvd.
Sarasota, Fl 34240

- **City of Palm Beach Gardens**
Attn: City Clerk
10500 North Military Trail
Palm Beach Gardens, Fl 33410

- **Town of Juno beach**
Attn: City Clerk
340 Ocean Drive
Juno Beach, Fl 33408
- **Village of Wellington**
Attn: City Clerk
14000 Greenbriar Blvd.
Wellington, Fl 33414
- **Seminole County**
Attn: Board of Commissioners
1101 East First Street Sanford, Fl 32771
- **City of Hollywood**
Attn: City Clerk
26000 Hollywood Boulevard
Hollywood, Florida 33020-4807
- **City of Vero Beach**
Attn: City Clerk
1053 20th Place
Vero Beach, Fl 32960
- **Volusia County**
Attn: Board of Commissioners
123 W. Indiana Ave.
Deland, Fl 327320
- **Broward County**
Attn: Board of Commissioners
2300 West Commercial Boulevard
Fort Lauderdale, Florida 33309
- **West Palm Beach**
Attn: Board of Commissioners
200 2nd Street, Fifth Floor
West Palm Beach, Fl 33401
- **City of Boca Raton**
Attn: City Clerk
201 W. Palmetto Park Rd.
Boca Raton, Fl 33432

- **Brevard County**
Attn: Board of Commissioners
2725 Judge Fran Jamieson Way
Suite A-204
Viera, Fl 32940
- **City of Cape Canaveral**
Attn: Cit Clerk
105 Polk Avenue
Cape Canaveral, Fl 32930
- **Charlotte County**
Attn: Board of Commissioners
18500 Murdock Circle
Port Charlotte, Fl 33948
- **Indian River County**
Attn: Board of Commissioners
1028 20th Place
Vero Beach, Fl 32960
- **Manatee County**
Attn: Board of Commissioners
1112 Manatee Avenue West
Bradenton, Fl 34205
- **Martin County**
Attn: Board of Commissioners
2401 SE Monterey Road
Stuart, Fl 34996-3322
- **City of Melbourne**
Attn: City Clerk
900 E. Strawbridge Ave.
Melbourne, Fl 32901
- **Palm Beach County**
Attn: Board of Commissioners
301 N. Olive Avenue
West Palm Beach, Fl 33401

- **City of Port St. Lucie**
City Clerk's Office
121 SW Port St. Lucie Blvd.
1st Floor, Building "A", Room 187
Port St. Lucie, Fl 34984-5099
- **City of Rockledge**
Attn: City Clerk
1600 Huntington Lane
Rockledge, Fl 32955-2660
- **St. Lucie County**
Attn: Board of Commissioners
2300 Virginia Avenue
Fort Pierce, Fl 34982
- **State of Florid, Department of Transportation**
Ms. Ruth Yanks
FDOT Utility Section
3400 W Commercial Blvd
Fort Lauderdale, Fl 33309
- **Town of Lake Park**
Attn: City Clerk
535 Park Avenue
Lake Park, Fl 33403
- **Hendry County**
Attn: Board of Commissioners
25 E. Hickpoochee Ave.
Labelle, Florida 33935
- **City of Deltona**
Attn: City Clerk
2345 Providence Boulevard
Deltona, Fl 32725
- **City of Fort Myers**
City Clerk's Office
2200 Second Street
Fort Myers, Florida 33902

- **City of Lauderdale Lakes**
Attn: City Clerk
4300 NW 36th Street
Lauderdale Lakes, Fl 33319
- **City of Coral Springs**
Attn: City Attorney
9551 W. Sample Road
Coral Springs, Fl 33065
- **City of Boynton Beach**
City Clerk's Office
100 E. Boynton Beach Blvd.
Boynton Beach, Fl 33435-3838
- **City of Delray Beach**
Assistant City Manager
100 NW 1st Ave.
Delray Beach, Fl 33444
- **City of West Melbourne**
City Attorney
2285 Minton Road
West Melbourne, Fl 32904-4928
- **Town of Indialantic by the Sea**
Attn: City Clerk
100 N Andres Avenue
Fort Lauderdale, Fl 33301
- **City of Fort Lauderdale**
Attn: City Clerk
100 N Andrews Avenue
Fort Lauderdale, Fl 33301
- **Columbia County**
Attn: Board of Commissioners
607 NW Quinten St.
Lake City, Fl 32055
- **City of Miami**
Attn: City Clerk
3500 Pan American Drive
Miami, Fl 33133

- **City of Riviera Beach**
Attn: City Clerk
600 West Blue Heron Blvd.
Riviera Beach, Fl 33404
- **City of Pompano Beach**
Attn: City Clerk
100 West Atlantic, Boulevard
Pompano Beach, Florida 33060
- **Mr. Rick Scheller**
Advanced Cable Communications
12409 NW 35 Street
Coral Springs, Fl 33065
- **Mr. Dave Floberg**
Atlantic Broadband
1681 Kennedy Causeway
North Bay Village, Fl 33141
- **Mr. Darrell Larid**
Communication Services
17774 NW US HWY 441
High Springs, Fl 32643
- **Mr. Gary English**
Florida Cable
23505 SR 40
Astor, Fl 32102
- **Nextel South Corp.**
Attn: Legal Services
851 Trafalgar Court suite 300E
Maitland, Florida 32751
- **Mr. Tim Thompson, Regional Vice President**
Nextel South Corp.
Field Engineering and Operations
6575 the Corners Parkway
Norcross, GA 30092
- **Nextel South Corp.**
Attn: Contracts Manager
2001 Edmund Halley Dr.
Reston, VA 20191-3436

- **NEXT G NETWORKS, INC.**
Attn: Contracts Administrator
2216 O'Toole Avenues
San Jose, CA 95131
- **Ms. Rosanne Gervasi Esquire**
Office of the General Counsel
Florida Public Service Commission
2540 Shumard Oak Boulevard
Tallahassee, Florida 32339-0850

2008 and 2009 CIF Projects

Fdr	County	Facility Type	Facility Name
300964	Baker	Acute Care	Ed Fraser Memorial Hospital
201632	Brevard	Acute Care	Palm Bay Community Hospital
200335	Brevard	Acute Care	Parrish Medical Center
203433	Brevard	Acute Care	Sebastian Hospital
203535	Brevard	Acute Care	Wuesthoff Medical Center - Melbourne
200431	Brevard	Acute Care	Wuesthoff Medical Center - Rockledge
203131	Brevard	Acute Care	Wuesthoff Medical Center - Rockledge
703934	Broward	Acute Care	Coral Springs Medical Center
703238	Broward	Acute Care	Florida Medical Center
702435	Broward	Acute Care	Hollywood Medical Center
701934	Broward	Acute Care	Holy Cross Hospital
706366	Broward	Acute Care	Memorial Hospital Miramar
702035	Broward	Acute Care	Memorial Hospital Pembroke
704762	Broward	Acute Care	Memorial Hospital West
706166	Broward	Acute Care	Memorial Hospital West
700231	Broward	Acute Care	Memorial Regional Hospital
701032	Broward	Acute Care	North Broward Medical Center
706531	Broward	Acute Care	North Ridge Medical Center
702236	Broward	Acute Care	Northwest Medical Center
701631	Broward	Acute Care	Plantation General Hospital
704564	Broward	Acute Care	Unviersity Hospital
501538	Charlotte	Acute Care	Charlotte Regional Medical Center
502061	Charlotte	Acute Care	Fawcett Memorial Hospital/Peace River Regional Medical Center
506663	Collier	Acute Care	Cleveland Clinic - Collier County
506762	Collier	Acute Care	Naples Community Hospital
507761	Collier	Acute Care	Physicians Regional Medical Center
301138	Columbia	Acute Care	Lake City Medical Center
808168	Dade	Acute Care	Baptist Health Data Center
804332	Dade	Acute Care	Baptist Hospital
805031	Dade	Acute Care	Doctor's Hospital
803636	Dade	Acute Care	Hialeah Hospital
807432	Dade	Acute Care	Kendall Regional Medical Center
807434	Dade	Acute Care	Kendall Regional Medical Center
801737	Dade	Acute Care	Kindred Hospital
802436	Dade	Acute Care	Larkin Community Hospital
805235	Dade	Acute Care	Mercy Hospital
801732	Dade	Acute Care	Miami Children's Hospital
806931	Dade	Acute Care	Miami Children's Hospital
806935	Dade	Acute Care	Miami Children's Hospital
807039	Dade	Acute Care	Palm Springs General Hospital
800533	Dade	Acute Care	Pan American Hospital
808931	Dade	Acute Care	Westchester General Hospital
501435	De Soto	Acute Care	DeSoto Memorial Hospital
101462	Flagler	Acute Care	Florida Hospital Flagler
405763	Indian River	Acute Care	Sebastian Hospital
506165	Lee	Acute Care	Gulf Coast Hospital
507661	Lee	Acute Care	Health Park Medical Center
501768	Lee	Acute Care	Shell Point Nursing Pavilion
505461	Lee	Acute Care	Southwest Florida Regional Medical Center
404939	Martin	Acute Care	Martin Memorial Hospital South
401138	Martin	Acute Care	Martin Memorial Medical Center
401633	Okeechobee	Acute Care	Raulerson Hospital
402832	Palm Beach	Acute Care	A G Holley State Hospital
403235	Palm Beach	Acute Care	Boca Raton Community Hospital
405337	Palm Beach	Acute Care	Columbia Hospital
409862	Palm Beach	Acute Care	Delray Medical Center
400934	Palm Beach	Acute Care	Glades General Hospital
402836	Palm Beach	Acute Care	JFK Medical Center

2008 and 2009 CIF Projects


Fdr	County	Facility Type	Facility Name
406234	Palm Beach	Acute Care	Jupiter Hospital
401837	Palm Beach	Acute Care	Jupiter Hospital
408961	Palm Beach	Acute Care	Jupiter Hospital
402636	Palm Beach	Acute Care	Palm Beach Gardens Medical Center
407663	Palm Beach	Acute Care	Palms West Hospital
405266	Palm Beach	Acute Care	Wellington Regional Medical Center
409634	Palm Beach	Acute Care	West Boca Medical Center
505165	Sarasota	Acute Care	Doctor's Hospital of Sarasota
500765	Sarasota	Acute Care	Englewood Community Hospital
500333	Sarasota	Acute Care	Venice Regional Medical Center
200131	Seminole	Acute Care	Central Florida Regional Hospital
106232	St Johns	Acute Care	Flagler Hospital
106234	St Johns	Acute Care	Flagler Hospital
300634	Suwannee	Acute Care	Shands at Live Oak
102431	Volusia	Acute Care	Florida Hospital Oceanside
101136	Volusia	Acute Care	Florida Hospital Ormond Memorial
100838	Volusia	Acute Care	Halifax Hospital Port Orange
300961	Baker	Smaller Hospital	NORTHEAST FLA STATE HOSP
203631	Brevard	Smaller Hospital	SEA PINES REHABILITATION HOSPITAL
700233	Broward	Smaller Hospital	KINDRED HOSPITAL - HOLLYWOOD
704135	Broward	Smaller Hospital	KINDRED HOSPITAL - HOLLYWOOD
700135	Broward	Smaller Hospital	KINDRED HOSPITAL - LAS OLAS
700144	Broward	Smaller Hospital	KINDRED HOSPITAL - LAS OLAS
702833	Broward	Smaller Hospital	Memorial Hospital Pembroke Urgent Care Center/Memorial Manor/South Florida State Hospital
702835	Broward	Smaller Hospital	SOUTH FL STATE HOSPITAL
701835	Broward	Smaller Hospital	ST ANTHONY'S REHAB HOSPITAL
704663	Broward	Smaller Hospital	SUNRISE REHABILITATION HOSPITAL
501237	Collier	Smaller Hospital	NAPLES COMMUNITY HOSPITAL
802832	Dade	Smaller Hospital	ST CATHERINE REHABILITATION HOSPITAL
810161	Dade	Smaller Hospital	BAPTIST MEDICAL PLAZA AT DORAL
807037	Dade	Smaller Hospital	CITRUS HEALTH NETWORK/SOUTHERN WINDS HOSPITAL
803545	Dade	Smaller Hospital	JACKSON MEMORIAL MENTAL HEALTH HOSPITAL
805832	Dade	Smaller Hospital	JACKSON SOUTH
804236	Dade	Smaller Hospital	MIAMI CHILDRENS SOUTH DADE
808337	Dade	Smaller Hospital	MIAMI REHABILITATION HOSPITAL
801734	Dade	Smaller Hospital	SOUTH DADE REHABILITATION HOSPITAL
802434	Dade	Smaller Hospital	SOUTH MIAMI HOSPITAL
807032	Dade	Smaller Hospital	SOUTHERN WINDS HOSPITAL
805735	Dade	Smaller Hospital	WESTCHESTER CLINIC
507065	Lee	Smaller Hospital	BONITA COMMUNITY HEALTH CENTER
505462	Lee	Smaller Hospital	SOUTHWEST FLA REG MED CNTR
406532	Palm Beach	Smaller Hospital	JFK HOSPITAL
101135	Volusia	Smaller Hospital	FLORIDA HOSPITAL - ORMOND MEMORIAL
101534	Volusia	Smaller Hospital	HALIFAX HOSPITAL
200336	Brevard	911	BREVARD COUNTY BOARD OF COUNTY COMMISSIONERS
200432	Brevard	911	CITY OF COCOA
201833	Brevard	911	CITY OF COCOA BEACH
202031	Brevard	911	CITY OF INDIAN HARBOUR BEACH
200535	Brevard	911	CITY OF MELBOURNE
204262	Brevard	911	CITY OF PALM BAY
204132	Brevard	911	CITY OF SATELLITE BEACH
203934	Brevard	911	CITY OF TITUSVILLE
203234	Brevard	911	TOWN INDIALANTIC
700737	Broward	911	BCBC#EMS 3679682 C PUBLIC SAFETY BUILDING
707267	Broward	911	CITY OF MIRAMAR
702636	Broward	911	CITY OF POMPANO
702433	Broward	911	MIAMI-DADE CO OCSIS TELE-COMMUNICATION 14
501535	Charlotte	911	CHARLOTTE CO COMM

2008 and 2009 CIF Projects

Docket No. 070301-EI
 2008 and 2009 CIF Projects
 Exhibit MBM-2, Page 3 of 3

Fdr	County	Facility Type	Facility Name
503563	Collier	911	COLLIER CNTY SHERIFF DEPT
306133	Columbia	911	COLUMBIA COUNTY BOARD OF COUNTY COMMISSIONERS
805138	Dade	911	CITY OF MIAMI FIRE-RESCUE STATION #3 - MIAMI 911 ANTENNA & TRANS
805535	Dade	911	HIALEAH CITY OF POLICE DEPT
802533	Dade	911	MIAMI-DADE CO ETSD-PUBLIC SAFETY RADIO SITE 1
805733	Dade	911	MIAMI-DADE CO ETSD-PUBLIC SAFETY RADIO SITE 11/MIAMI-DADE CO GSA ETSD 11
805932	Dade	911	MIAMI-DADE CO ETSD-PUBLIC SAFETY RADIO SITE 14
809666	Dade	911	MIAMI-DADE CO ETSD-PUBLIC SAFETY RADIO SITE 14
810064	Dade	911	MIAMI-DADE CO ETSD-PUBLIC SAFETY RADIO SITE 14
810366	Dade	911	MIAMI-DADE CO ETSD-PUBLIC SAFETY RADIO SITE 14
800440	Dade	911	CORAL GABLES
806534	Dade	911	VILLAGE OF PINECREST - 911 DISPATCH
101461	Flagler	911	FLAGLER COUNTY SHERIFF'S OFFICE
506162	Lee	911	LEE CO COMMISSION
500236	Manatee	911	CITY OF BRADENTON/COUNTY OF MANATEE BCC PROP APPRAISER
401137	Martin	911	MARTIN COUNTY BOARD OF COMMISSIONERS
404938	Martin	911	MARTIN COUNTY BOARD OF COMMISSIONERS
301464	Nassau	911	NASSAU COUNTY SHERIFF DEPARTMENT - NASSAU 911 & SHERIFF
401632	Okeechobee	911	OKEECHOBEE CO BD OF COMM
403034	Palm Beach	911	BD OF PB CO COMM
403031	Palm Beach	911	BD OF PB CO COMM SHERIFF'S DEPT
408031	Palm Beach	911	CITY OF BOCA RATON - BOCA 911,EOC,PHONE TOWERS
401933	Palm Beach	911	CITY OF DELRAY BCH - DELRAY PD/911
405631	Palm Beach	911	CITY OF GREENACRES - 911,EOC,EMS,PD,FD
406236	Palm Beach	911	TOWN OF JUP INLET BCH
402835	Palm Beach	911	TOWN OF MANALAPAN - 911 MANALAPAN/ S PALM BCH
400533	Palm Beach	911	TOWN OF OCEAN RIDGE - 911/PD/EOC/TOWNHALL
405264	Palm Beach	911	VILLAGE OF ROYAL PALM BEACH - 911 DISP, PD, MUN COMPLEX
101635	Putnam	911	PUTNAM COUNTY SHERIFFS DEPT
504135	Sarasota	911	ALLTEL FLORIDA INC - TOWER WEST OF SCT1 SCHOOL
500933	Sarasota	911	COUNTY OF SARASOTA FACILITIES
500763	Sarasota	911	COUNTY OF SARASOTA FACILITIES
500131	Sarasota	911	COUNTY OF SARASOTA FACILITIES
503264	Sarasota	911	COUNTY OF SARASOTA FACILITIES
500133	Sarasota	911	COUNTY OF SARASOTA FACILITIES 0201
505765	Sarasota	911	SPRINTCOM INC
207934	Seminole	911	SEMINOLE COUNTY BOARD OF COUNTY COMMISSIONERS
204636	Seminole	911	SEMINOLE COUNTY BOARD OF COUNTY COMMISSIONERS
207262	Seminole	911	SEMINOLE COUNTY BOARD OF COUNTY COMMISSIONERS
205362	Seminole	911	SEMINOLE COUNTY BOARD OF COUNTY COMMISSIONERS
408461	St Lucie	911	ST LUCIE COUNTY BD OF COUNTY COMM
108262	Volusia	911	COUNTY OF VOLUSIA

Storm Pole Replacements



Davies Consulting, Inc. Benchmark Analysis

- Analysis includes 6 hurricanes and 10 utilities (FPL builds to Grade B – all others build to Grade C)
- Shows pole failure rates and storm strength/category
- Indicates FPL experienced lower pole failure rates vs. others
- Indicates better pole performance - Grade B vs. Grade C