



Dulaney L. O'Roark III  
Vice President & General Counsel, Southeast Region  
Legal Department

5055 North Point Parkway  
Alpharetta, Georgia 30022  
Phone 678-259-1449  
Fax 678-259-1588  
de.oroark@verizon.com

September 7, 2007

Ann Cole, Commission Clerk  
Florida Public Service Commission  
2540 Shumard Oak Boulevard  
Tallahassee, FL 32399-0850

RECEIVED-FPSC  
07 SEP 7 PM 3:14  
COMMISSION CLERK

Re: Docket No. 070297-EI  
Review of 2007 Electric Infrastructure Storm Hardening Plan filed pursuant to Rule 25-6.0342, F.A.C., submitted by Tampa Electric Company

Docket No. 070298-EI  
Review of 2007 Electric Infrastructure Storm Hardening Plan filed pursuant to Rule 25-6.0342, F.A.C., submitted by Progress Energy Florida, Inc.

Docket No. 070299-EI  
Review of 2007 Electric Infrastructure Storm Hardening Plan filed pursuant to Rule 25-6.0342, F.A.C., submitted by Gulf Power Company

Docket No. 070301-EI  
Review of 2007 Electric Infrastructure Storm Hardening Plan filed pursuant to Rule 25-6.0342, F.A.C., submitted by Florida Power & Light Company

Dear Ms. Cole:

CMP 2 Enclosed for filing in the above-referenced matters are an original and 15 copies of the  
COM 5 Direct Testimonies of Dr. Lawrence M. Slavin and Sanford C. Walker on behalf of  
CTR 1 Verizon Florida LLC. Service has been made as indicated on the Certificate of Service.  
If there are any questions regarding this filing, please contact me at (678) 259-1449.

ECR 2 Sincerely,  
GCL 2

OPC             
RCA 1 Dulaney L. O'Roark III *DR*

SCR             
SGA            tas  
SEC            Enclosures  
OTH           

DOCUMENT NUMBER-DATE  
08139 SEP-7 07  
FPSC-COMMISSION CLERK

DOCUMENT NUMBER-DATE  
08138 SEP-7 07  
FPSC-COMMISSION CLERK

**CERTIFICATE OF SERVICE**

I HEREBY CERTIFY that copies of the foregoing were sent via U. S. mail on September 7, 2007 to the parties on the attached list.

Dulaney L. O'Rourke III <sup>pl</sup>

Staff Counsel  
Florida Public Service Commission  
2540 Shumard Oak Boulevard  
Tallahassee, FL 32399-0850

Bill Walker  
Florida Power & Light Company  
215 S. Monroe St., Suite 810  
Tallahassee, FL 32301-1859

John T. Butler  
Florida Power & Light Co.  
700 Universe Boulevard  
Juno Beach, FL 33408-0420

Paul Lewis, Jr.  
Progress Energy Florida Inc.  
106 E. College Avenue, Suite 800  
Tallahassee, FL 32301-7740

John T. Burnett  
Progress Energy Service Co. LLC  
P. O. Box 14042  
St. Petersburg, FL 33733-4042

Lee L. Willis  
James D. Beasley  
Ausley Law Firm  
P. O. Box 391  
Tallahassee, FL 32302

Paula K. Brown  
Tampa Electric Company  
P. O. Box 111  
Tampa, FL 33601-0111

Beth Keating  
Akerman Law Firm  
106 E. College Avenue, Suite 1200  
Tallahassee, FL 32301

J.Meza/E. Edenfield/  
P. Carver/M. Gurdian  
AT&T Florida  
c/o Nancy H. Sims  
150 S. Monroe St., Suite 400  
Tallahassee, FL 32301-1556

Maria T. Browne  
Davis Law Firm  
1919 Pennsylvania Ave., N.W.  
Suite 200  
Washington, DC 20006

Susan S. Masterton  
Embarq Florida Inc.  
Mailstop: FLTLHO0102  
1313 Blair Stone Road  
Tallahassee, FL 32301

Florida Cable Tele. Assn.  
246 E. 6<sup>th</sup> Avenue, Suite 100  
Tallahassee, FL 32303

H. M. Rollins Company, Inc.  
P. O. Box 3471  
Gulfport, MS 39505

Dennis Hayward  
North American Wood Pole Council  
7017 NE Highway 99, Suite 108  
Vancouver, WA 98665

Howard Adams/Peter Dunbar  
Time Warner Telecom  
c/o Pennington Law Firm  
P. O. Box 10095  
Tallahassee, FL 32302-2095

Richard Jackson  
City of Panama City Beach  
110 South Arnold Road  
Panama City Beach, FL 32413

Douglas J. Sale  
Harrison Law Firm  
P. O. Drawer 1579  
Panama City, FL 32402-1579

R. Scheffel Wright/J. LaVia  
Young Law Firm  
225 S. Adams St., Suite 200  
Tallahassee, FL 32301

Mayor Charles Falcone  
Town of Jupiter Island  
P. O. Box 7  
Hobe Sound, FL 33475

Thomas G. Bradford  
Deputy Town Manager  
360 South County Road  
Palm Beach, FL 33480

BEFORE THE FLORIDA PUBLIC SERVICE COMMISSION

In re: Review of 2007 Electric Infrastructure ) Storm Hardening Plan filed pursuant to Rule) 25-6.0342, F.A.C., submitted by Tampa ) Electric Company ) <hr/>	Docket No. 070297-EI
In re: Review of 2007 Electric Infrastructure ) Storm Hardening Plan filed pursuant to Rule) 25-6.0342, F.A.C., submitted by Progress ) Energy Florida, Inc. ) <hr/>	Docket No. 070298-EI
In re: Review of 2007 Electric Infrastructure ) Storm Hardening Plan filed pursuant to Rule) 25-6.0342, F.A.C., submitted by Gulf Power ) Company ) <hr/>	Docket No. 070299-EI
In re: Review of 2007 Electric Infrastructure ) Storm Hardening Plan filed pursuant to Rule) 25-6.0342, F.A.C., submitted by Florida ) Power & Light Company ) <hr/>	Docket No. 070301-EI

DIRECT TESTIMONY OF DR. LAWRENCE M. SLAVIN  
ON BEHALF OF VERIZON FLORIDA LLC

SEPTEMBER 7, 2007

DOCUMENT NUMBER-DATE

08138 SEP-7 5

FPSC-COMMISSION CLERK

1 Q. PLEASE STATE YOUR NAME AND BUSINESS ADDRESS.

2 A. My name is Dr. Lawrence M. Slavin. My business address is 15 Lenape  
3 Avenue, Rockaway, NJ 07866.

4

5 Q. BY WHOM ARE YOU EMPLOYED AND IN WHAT CAPACITY?

6 A. I am employed by Outside Plant Consulting Services, Inc. and am a  
7 Principal of the company.

8

9 Q. PLEASE DESCRIBE YOUR EMPLOYMENT BACKGROUND.

10 A. I started my career at Bell Laboratories, where I worked from 1961 to  
11 1989, primarily in telecommunications product design and development.  
12 At Bell Laboratories, I was selected to be a Distinguished Member of  
13 Technical Staff, an award created to honor those who have sustained a  
14 level of excellence throughout their career. After retiring from Bell Labs  
15 in 1990, I joined Telcordia Technologies (formerly Bellcore) as a  
16 member of its research and professional service organizations, where I  
17 worked during the period 1990-2001. At Telcordia, I served as Director  
18 of the Network Facilities, Components, and Energy Group, responsible  
19 for requirements, testing, and analysis of outside plant media,  
20 components, and powering for telecommunications applications, as well  
21 as related installation and construction guidelines. In 2002, I started a  
22 consulting practice with Outside Plant Consulting Services, Inc.,  
23 focusing on issues related to the communications and power industries.  
24 Exhibit LMS-1 provides more detailed information concerning my  
25 experience in the telecommunications and related utility industries,

1 including my activities in relevant professional organizations, such as  
2 the Executive Subcommittee, Main Committee and several  
3 subcommittees for the National Electric Safety Code ("NESC").  
4

5 **Q. PLEASE SUMMARIZE YOUR INVOLVEMENT WITH THE NESC AS**  
6 **RELEVANT TO THIS PROCEEDING.**

7 A. I have been an active member of NESC Subcommittee 4 (Overhead  
8 Lines – Clearances), Subcommittee 7 (Underground Lines) and  
9 Subcommittee 5 (Overhead Lines – Strength & Loading) since 1998,  
10 and actively participated in the development of the 2002 edition of the  
11 NESC and the recently issued 2007 edition. As a principal member of  
12 these subcommittees, and a representative of the Alliance for  
13 Telecommunications Industry Solutions, I help develop and evaluate  
14 change proposals for upcoming editions of the NESC. In particular,  
15 Subcommittee 5 is responsible for specifying the storm loads and  
16 associated structural strength requirements referenced by Florida Power  
17 & Light Company ("FPL"). I am Chair of Working Group 5.7 (Seminars  
18 and Presentations; Subcommittee 5), and have served on Working  
19 Group 5.2 (Complete Revision of Sections 25 and 26), and on Working  
20 Group 5.8 (Application of Extreme Wind to All Structures). I have also  
21 been Chair of Working Group 4.10 (New Ice Loads and Clearances) of  
22 Subcommittee 4. In addition to my NESC work, I serve on the  
23 Accredited Standards Committee ASC-O5 (responsible for *ANSI O5.1,*  
24 *Wood Poles, Specifications and Dimensions*) and several other industry  
25 related organizations, as listed in Exhibit LMS-1.

1 Q. HAVE YOU BEEN RESPONSIBLE FOR NESC INDUSTRY  
2 INFORMATION SESSIONS RELATING TO UTILITY POLE  
3 STRENGTH AND LOADING?

4 A. Yes. As Chair of Working Group 5.7, I have been responsible for  
5 organizing and coordinating several industry information sessions, as  
6 well as providing some of the associated technical presentations.

7 Among others, these include:

- 8 • *Panel Session: NESC 2007 Panel Session (Strength & Loading)*, IEEE  
9 Power Engineering Society, Towers, Poles & Conductors (TP&C)  
10 Subcommittee Meeting, 2007
- 11 • *Panel Session: Structural Reliability-Based Design of Utility Poles and*  
12 *the National Electrical Safety Code*, 2003 IEEE Transmission &  
13 Distribution Conference and Exposition, 2003
- 14 • *Panel Session on National Electrical Safety Code (NESC), 2002 Edition,*  
15 *ANSI C2*, 2001 IEEE Transmission & Distribution Conference and  
16 Exposition, 2001
- 17 • *Panel Session on Proposed Changes to Strength & Loading*  
18 *Requirements for the 2002 Edition of the National Electrical Safety Code*  
19 *(NESC)*, IEEE Power Engineering Society, Towers, Poles & Conductors  
20 (TP&C) Subcommittee Meeting, 2000

21

22 Q. PLEASE DESCRIBE YOUR EDUCATIONAL BACKGROUND.

23 A. I have received the following college and university degrees:

- 24 • Ph.D. - Mechanical Engineering, New York University, 1969
- 25 • Master of Science - Engineering Mechanics, New York University, 1963

- 1       • Bachelor of Science - Mechanical Engineering, The Cooper Union for  
2       the Advancement of Science & Art, 1961

3

4   **Q.   PLEASE SUMMARIZE YOUR TESTIMONY.**

5   A.   The NESC has been developed by the NESC Committee (a term I use  
6       generically to include the various NESC subcommittees and the Main  
7       Committee), which is a national standards body comprised of  
8       knowledgeable individuals representing utility organizations (including  
9       power, telephone and cable), professional associations, government  
10      organizations, unions and other interested parties, such as consultants,  
11      engineers, and erectors. Throughout most of the United States,  
12      including Florida, the NESC is considered to be authoritative with  
13      respect to basic safety rules for outdoor utility lines, including pole  
14      loading and strength. The NESC specifies that Combined Ice and Wind  
15      District Loading shall be used to determine pole loading and associated  
16      strength for poles not exceeding 60 feet in height, which includes most  
17      distribution poles. The NESC has considered whether extreme wind  
18      loading ("EWL") should be required for poles less than 60 feet in height  
19      and has decided against such a requirement, because the high cost of  
20      attempting to design such poles to withstand EWL does not justify its  
21      benefits. The benefits of EWL are projected to be slight for such cases,  
22      because in most storms involving extreme winds, damage to structures  
23      results primarily from falling trees and branches and flying debris striking  
24      the vulnerable lines, rather than the wind pressure itself imposed on the  
25      structures and lines. Moreover, the attempt to design the shorter



1 structures to EWL can have unintended consequences, such as the  
2 following: (i) longer restoration times because, in spite of the attempt to  
3 design distribution poles to withstand EWL, the significantly greater  
4 number of required poles or stouter poles (or both), may result in longer  
5 restoration times when such poles are nonetheless damaged; (ii) more  
6 (and more serious) traffic accidents because of the greater number  
7 and/or size of poles; and (iii) errors and delays resulting from greater  
8 complexity required to engineer structures for EWL. FPL's arguments  
9 for applying EWL in its service territory have not been presented to, or  
10 accepted by, NESC Subcommittee 5, and, in any case, are based on  
11 limited data that has not been subjected to examination and scrutiny by  
12 the industry. I therefore recommend that FPL's proposal that it apply  
13 EWL to its distribution plant be rejected. If EWL is to be applied at all, it  
14 should be done as a pilot project over a limited time.

15

16 **I. NESC LOADING AND STRENGTH REQUIREMENTS**

17 **A. NESC BACKGROUND**

18 **Q. WHAT IS THE NESC?**

19 A. The NESC is an American National Standards Institute ("ANSI") standard  
20 based on a consensus of those substantially concerned with its scope  
21 and provisions, including the Institute of Electrical and Electronic  
22 Engineers, which also acts as the Secretariat. Other members of the  
23 NESC Committee include organizations representing providers of electric  
24 power or communications service, their suppliers, and other affected or  
25 interested parties, including unions, and consultants, engineers, and

1           erectors. Individual candidates desiring membership for available  
2           positions must submit their credentials for approval by the NESC  
3           Executive Subcommittee. The National Association of Regulatory Utility  
4           Commissioners is represented on several of the NESC subcommittees.  
5           Power companies in Florida, including FPL, are members of  
6           organizations represented on the NESC Main Committee and several  
7           subcommittees, including Subcommittee 5. The NESC includes various  
8           provisions for the safeguarding of persons from hazards from the  
9           installation, operation, and maintenance of electric supply and  
10          communication lines and equipment. The rules contain the basic  
11          provisions that are considered necessary for the safety of employees and  
12          the public.

13

14   **Q.    HOW DO THE POWER AND TELECOMMUNICATIONS INDUSTRIES**  
15   **USE THE NESC WITH RESPECT TO POLE LOADING AND**  
16   **STRENGTH DETERMINATIONS?**

17   A.    Although the NESC does not purport to be a “design specification,” the  
18   basic safety rules provided therein are typically used throughout the  
19   industry as the basis for designing distribution pole lines. Many states  
20   and agencies throughout the United States routinely adopt the latest  
21   edition, or specific editions, of the NESC for application within their  
22   jurisdictions. For example, the 2007 edition is effective in Florida.

23

24   **Q.    THE NAME “NATIONAL ELECTRIC SAFETY CODE” MIGHT**  
25   **SUGGEST THAT THE NESC IS NARROWLY FOCUSED. DOES THE**

1           **NESC SPEAK TO THE STORM-HARDENING ISSUES BEFORE THE**  
2           **COMMISSION IN THIS DOCKET?**

3    A.    Yes. In the NESC, safety issues are generally considered to include  
4           those that would result in damaged poles or downed lines, because  
5           these situations may affect the safety and well being of the public through  
6           associated hazards and loss of essential services. The NESC  
7           Committee therefore weighs the benefits of increasing the number and  
8           size of poles along with the attendant costs and risks, including problems  
9           associated with increased design complexity and possible other issues.

10

11   **Q.    WHAT NESC SECTIONS ADDRESS POLE LOADING AND**  
12   **STRENGTH?**

13   A.    Sections 25 and 26 of the NESC provide the required loadings and  
14           associated strengths of utility poles and other structures. Section 25  
15           specifies the type of storm loads that Grade B or Grade C utility lines  
16           are required to withstand. (“Grades of construction” are discussed  
17           below.) Section 26 specifies the required strengths of the structures  
18           required for the storm loadings specified in Section 25. Two types of  
19           storms are specified in the 2007 edition that are relevant to this  
20           discussion -- (1) Combined Ice and Wind District Loading (Rule 250B)  
21           and (2) EWL (Rule 250C). Combined Ice and Wind District Loading  
22           applies to all Grade B and C poles, including those that do not exceed  
23           60 feet in height (which include distribution poles), while EWL only  
24           applies to those structures that are greater than 60 feet tall, for reasons I  
25           will explain.

1           **B.           NESC SECTION 25: POLE LOADING**

2   **Q.       PLEASE EXPLAIN WHAT IS MEANT BY “LOADING.”**

3   A.       Loading involves the force (generally expressed in pounds) that is  
4           exerted against a structure. The biggest consideration in pole loading is  
5           typically not the weight of the pole or its attachments, but rather the wind  
6           pressure that is applied transversely (horizontally) to the profile of the  
7           pole and attachments. In much the same way that the speed of a sail  
8           boat depends on the speed of the wind and the square footage of the  
9           sail, the load applied to a pole depends on wind speed and the square  
10          footage of the pole and attachments.

11

12   **Q.       PLEASE EXPLAIN GENERALLY HOW DISTRIBUTION POLE**  
13   **LOADING IS CALCULATED UNDER SECTION 25 OF THE NESC.**

14   A.       Loading for Grade B and C distribution poles is determined using Rule  
15           250B, which deals with Combined Ice and Wind District Loading. Rule  
16           250B refers to the Loading District map, NESC Figure 250-1, reproduced  
17           below. The three loading districts in the United States (Heavy, Medium  
18           and Light) specify the amount of radial ice buildup and a concurrent wind  
19           pressure. The Heavy and Medium districts in the north and central  
20           portions of the United States are subject to one-half and one-quarter-inch  
21           radial ice buildup, respectively, on all power and communications wires,  
22           cables, and other conductors, and a concurrent wind pressure  
23           corresponding to approximately 40 m.p.h. (4 p.s.f. wind pressure). The  
24           Light district in the southerly portion of the country, including Florida, is  
25           assumed to experience no ice buildup, but a wind pressure

1 corresponding to approximately 60 m.p.h. (9 p.s.f. wind pressure). The  
2 latter wind speed, although only 50% greater than that assumed in the  
3 rest of the country, corresponds to a wind pressure of more than twice  
4 that in the Heavy or Medium districts, due to the strong dependence of  
5 the wind force on wind speed. (The wind pressure, or force, is  
6 proportional to the square of the wind speed.) The lower pressure in the  
7 Heavy or Medium districts, however, is applied to a greater "sail area"  
8 due to the ice buildup on the conductors (*i.e.*, the cables and wires).  
9 Depending on the conductor diameters, and the ice buildup levels, the  
10 resultant transverse loads in the "Light" district may exceed that in the so-  
11 called "Heavy" or "Medium" areas. In addition, under Rule 250B, a net  
12 design ("safety") factor of approximately 2-to-1 is applied to the common  
13 Grade C wood pole construction, and a net design factor of  
14 approximately 4-to-1 is applied to Grade B wood pole construction,  
15 where required. The design factor is equal to the "load factor" of NESC  
16 Table 253-1 divided by the corresponding "strength factor" of Table 261-  
17 1A. (This description assumes "tangent" pole lines, without significant  
18 corner angles where guys may be required. For such tangent lines, the  
19 transverse wind loads typically represent the critical design condition.)  
20 This procedure results in a reasonably robust design, which experience  
21 has shown to provide reliable, safe service.

22  
23  
24  
25

PART 2. SAFETY RULES FOR OVERHEAD LINES




Fig 250-1  
General Loading Map of United States  
with Respect to Loading of Overhead Lines

1

2 **Q. WHAT IS MEANT BY GRADES OF CONSTRUCTION?**

3 A. Section 24 of the NESC defines three grades of Construction intended  
4 to distinguish between various situations, requiring varying levels of  
5 reliability. In general, these grades depend on the combination of  
6 voltage levels present in the power and communications conductors  
7 supported on the same poles, as well as various details, as specified.  
8 Most distribution poles carrying "primary power" (> 750 volts) at the  
9 upper portion of the pole, and communications cables below, are in the  
10 Grade C category. If the adjacent lines cross railroads tracks or limited  
11 access highways, a greater reliability level is required, corresponding to  
12 Grade B. Most power utility-owned poles are in the Grade C category.

1 The third and lowest grade of construction is Grade N, and applies if the  
2 voltages do not exceed 750 volts. This includes joint-usage poles  
3 supporting only “secondary power” (< 750 volts) or poles supporting only  
4 communications cables. NESC Section 25 (Loadings for Grades B and  
5 C) and most of Section 26 (Rule 261) apply to Grade B or Grade C  
6 construction. The NESC does not provide specific storm loading or  
7 strength requirements for Grade N structures.

8

9 **C. NESC SECTION 26: POLE STRENGTH**

10 **Q. HOW IS POLE STRENGTH CLASSIFIED?**

11 A. Wood pole sizes and strengths are specified in *ANSI O5.1, Wood Poles,*  
12 *Specifications and Dimensions.* ANSI-O5.1 provides a pole  
13 classification system based on the ability of a pole to withstand lateral  
14 loads placed near the top of the pole, in a cantilever situation, such as  
15 may correspond to transverse wind loads on a pole with attachments.  
16 For example, a popular size Class 4 pole would on average withstand a  
17 lateral load of 2,400 pounds applied 2 feet from the tip of the pole. A  
18 Class 3 pole is stronger, and would withstand 3,000 pounds. Within  
19 poles of Class 1-10, lower class number poles correspond to stronger  
20 (*i.e.*, larger diameter) poles. Poles of strength greater than Class 1 are  
21 classified beginning with H1, with strength increasing with the H-  
22 number. Thus, a pole may be described as that supporting a specific  
23 “grade” of construction, corresponding to a level of required reliability  
24 (Grade B or C), or by a “class” size which is selected to match the  
25 strength needed to achieve the required reliability level.

1 **Q. ONCE IT IS ESTABLISHED WHAT LOAD A POLE MUST BEAR,**  
2 **HOW IS POLE STRENGTH DETERMINED?**

3 A. The required strength is determined and calculated based on the  
4 number, size (diameter) and location (height) of the attachments to the  
5 pole, the span length between adjacent poles, and the grade of  
6 construction (via the design factors discussed above).

7

8 **D. APPLICATION OF EXTREME WIND LOADING**

9 **Q. UNDER THE NESC, DOES EWL APPLY TO DISTRIBUTION POLES?**

10 A. No. Under the NESC, EWL applies only to poles greater than 60 feet in  
11 height, which excludes most distribution poles.

12


13 **Q. PLEASE EXPLAIN HOW POLE LOADING IS CALCULATED USING**  
14 **EWL.**

15 A. NESC Rule 250C refers to various wind maps, of which Figure 250-2(d),  
16 including Florida, is reproduced below. The wind speeds correspond to  
17 50-year events, and vary from approximately 95 m.p.h. in the north of the  
18 state to as much as 150 m.p.h. at the southern tip. The minimum 95  
19 m.p.h. speed corresponds to a wind pressure of two and one-half times  
20 that of the 60 m.p.h. wind assumed in the Light loading district. The  
21 maximum 150 m.p.h. speed corresponds to a wind pressure of more than  
22 six times that of the 60 m.p.h. wind. But the corresponding design  
23 factors for Rule 250C are lower than that of Rule 250B, somewhat  
24 reducing the wide divergence in pole strength requirements.  
25 Nonetheless, if EWL were applicable to distribution poles, the impact on



1 pole strength and sizes in Florida, and on utility construction practices  
2 and costs, would be major, as illustrated for the cases described below.

3



4

5

Figure 250-2(d)—Eastern Gulf of Mexico and  
southeastern US hurricane coastline

6

7

8 Q. HAS NESC SUBCOMMITTEE 5 ADDRESSED THE ISSUE OF  
9 WHETHER EWL SHOULD APPLY TO POLES THAT ARE 60 FEET  
10 OR LESS IN HEIGHT?

11 A. Yes. There have been continuing discussions within Subcommittee 5 to  
12 consider eliminating the 60-foot exemption -- so that poles of all heights  
13 would be subject to EWL. Such a revision was discussed with regard to  
14 the 2007 edition but, as had happened previously (such as when the  
15 2002 edition was prepared), the related proposals were rejected. The

1 proposed change that was discussed most seriously would have limited  
2 the effective wind loading to a relatively low level (corresponding to wind  
3 speeds that would cause wind blown debris) and typically would not  
4 have increased the required wind loadings for distribution poles in  
5 Florida. Nonetheless, even this diluted version of an extreme wind  
6 requirement was rejected for incorporation into the NESC.

7

8 **Q. WHY DID THE SUBCOMMITTEE REJECT EWL FOR DISTRIBUTION**  
9 **POLES?**

10 A. The rationale for rejecting consideration of extreme winds for  
11 “distribution” poles (i.e., poles not taller than 60 feet) is that the vast  
12 majority of industry experiences demonstrate that almost all damage to  
13 such poles is caused by trees, tree limbs and flying debris and not by  
14 the wind forces acting directly on the wires and poles. When that is the  
15 case, little is gained by attempting to design such poles to withstand the  
16 direct hurricane wind forces. As stated in the NESC decision to reject  
17 such a change:

18 “Designing structures with heights less than 60 ft for  
19 extreme winds will increase pole strengths for distribution  
20 systems resulting in large increases in cost and design  
21 complexity without commensurate increase in safety.  
22 Safety of employees and the public is provided using the  
23 current NESC loading requirements.”

24 NESC Section 25 does not explicitly use the term “distribution” when  
25 referring to poles not exceeding 60 feet, but has specified the 60-foot

1 threshold to exclude most such poles that would tend to be vulnerable to  
2 the effects of wind-blown debris. In contrast, taller structures, such as  
3 transmission towers, with lines generally above the fray of falling trees,  
4 branches and debris, would benefit from such an application of EWL  
5 requirement.

6

7 **Q. IF EWL WERE APPLIED IN FLORIDA, WOULD THE INCREASED**  
8 **COSTS OF MORE AND STOUTER DISTRIBUTION POLES**  
9 **NECESSARILY PRODUCE ANY SIGNIFICANT BENEFITS FOR**  
10 **FLORIDIANS?**

11 A. No. Because typically most damage to poles during high wind storms  
12 results from trees, branches and flying debris rather than the wind  
13 pressure itself, I would not expect there to be significant benefit to  
14 having more or stouter distribution poles. This is so essentially because  
15 poles, with attached lines spanning the distance to other poles, suffer  
16 disproportionately large exposure and associated effects during  
17 hurricanes as compared to individual structures, including bare poles or  
18 buildings. In most cases the high cost of EWL would not produce  
19 commensurate benefits because even poles that are strengthened to  
20 EWL standards are vulnerable to failure caused by trees, branches and  
21 flying debris. The loads imposed by these objects striking the lines  
22 result in high, unbalanced wire tensions, which impose extremely large  
23 lateral loads on the poles, which is compounded by the domino effect of  
24 damaged individual poles placing increased loads on adjacent poles  
25 along the line.

1 Q. COULD THERE BE ANY NEGATIVE, UNINTENDED  
2 CONSEQUENCES ASSOCIATED WITH EWL?

3 A. Yes. Restoration efforts following a "typical" hurricane event, in which a  
4 combination of a greater number and stouter poles would be damaged  
5 by falling branches and wind-blown debris, would be hampered by the  
6 greater number and larger poles that would have to be replaced. In  
7 addition, the increased number and size of the poles would have a  
8 direct and negative impact on vehicular safety, and conflict with the  
9 objectives of the U.S. Department of Transportation and presumably  
10 that of the DOTs of many states. Still another negative consequence  
11 relates to the engineering support associated with the implementation of  
12 the proposed EWL. The determination of the corresponding wind force  
13 is considerably more complicated than that of the existing transverse  
14 wind force based on the present required Combined Ice and Wind  
15 District Loading. While such calculations are within the capability of  
16 experienced transmission engineers, with civil engineering training, they  
17 are beyond that of most distribution engineers. Although new or  
18 available software packages may alleviate the burden, there will be  
19 inevitable confusion and delays in the design and installation of new  
20 facilities to the detriment of consumers.

21

22 Q. HAS SUBCOMMITTEE 5 DISCUSSED IMPOSING EWL  
23 REQUIREMENTS FOR GRADE N CONSTRUCTION?

24 A. No. To the best of my knowledge, the Subcommittee 5 has never  
25 discussed extending any of the detailed storm loading requirements,

1 including design (load and strength) factors, as specified in Section 25  
2 and Section 26 of the NESC to Grade N applications, which include  
3 communications-only poles or joint-use poles with only secondary power  
4 (< 750 volts). Thus, any proposal to extend Rule 250C to all distribution  
5 poles, regardless of height or grade of construction, would be a major  
6 departure from present considerations in the NESC Committee, or  
7 industry in general.

8

9 **II. ASSESSMENT OF FPL PROPOSAL**

10 **Q. WHAT DOES FPL PROPOSE WITH RESPECT TO EWL?**

11 A. FPL proposes to (i) apply EWL to critical infrastructure, (ii) implement  
12 incremental hardening projects that would strengthen certain existing  
13 infrastructure (but not necessarily applying EWL); and (iii) apply new  
14 design guidelines to new overhead construction, major planned work,  
15 relocation projects and daily work activities, with the intention of moving  
16 FPL's system to EWL gradually over time. FPL states that it plans to  
17 divide its territory into three wind regions, corresponding to extreme  
18 winds of 105, 130 and 145 m.p.h. (except for the southern tip of Florida,  
19 which would be designed for 150 m.p.h.). FPL's proposed design  
20 guidelines call for an increase in pole strength and size (class) in  
21 various scenarios, and for shorter pole spans, which would increase the  
22 number of poles.

23

24 **Q. SHOULD THE COMMISSION ENDORSE FPL'S PROPOSAL TO**  
25 **APPLY EWL TO ITS DISTRIBUTION NETWORK?**

1 A. No. The unlimited application of Rule 250C to all poles would have a  
2 major impact on the cost and operations of the utilities and the third-  
3 party attachers, and would likely have a negative effect on system  
4 restoration efforts and public safety.

5

6 **Q. HOW WOULD FPL'S PLAN AFFECT POLE COSTS?**

7 A. For electric utility-owned joint-use Grade N, Grade B or Grade C pole  
8 applications, the additional pole costs will depend on the extent to which  
9 the proposed extreme wind load would exceed "reasonable" (albeit non-  
10 mandated) Grade N loads, and the already required Combined Ice and  
11 Wind load for Grade B or Grade C applications for poles not exceeding  
12 60 feet in height. Any increased strength requirement leads to stronger  
13 (larger diameter) poles, and/or a greater number of poles (resulting from  
14 shorter span lengths), both of which would obviously be more  
15 expensive.

16


17 **Q. PLEASE ILLUSTRATE THE IMPACT OF MOVING TO EWL ON**  
18 **REQUIRED POLE STRENGTH, ASSUMING POLE ATTACHMENTS**  
19 **AND SPAN LENGTHS REMAIN THE SAME.**

20 A. Figure 1 below illustrates the relative wood pole strength in comparison  
21 to that currently required for a Grade C joint-usage distribution  
22 application; e.g., including primary power (> 750 volts) with  
23 communications cables mounted below the power cables. Assuming  
24 the pole does not exceed 60 feet in height (65 feet in length), such a  
25 pole must be designed to the Combined Ice and Wind Loading. (See

1 NESC Rule 250B, Figure 250-1 and Tables 250-1, 253-1 and 261-1A.)  
2 For present purposes, a tangent line (no corner angles), for which the  
3 design is based on the ability to withstand the transverse wind loading,  
4 and a pole length of 40 feet is assumed. (Pole length and attachment  
5 height has only a minor effect on the results.) Florida, located in the  
6 NESC Light Loading District, corresponds to a wind speed of  
7 approximately 60 m.p.h., but with an additional net design factor of  
8 approximately 2-to-1 for Grade C, and 4-to-1 for Grade B. For Grade N,  
9 a 1-to-1 design factor is assumed. For the proposed application of Rule  
10 250C, I have evaluated wind speeds of 105, 130 and 145 m.p.h.,  
11 representing the regions served by FPL. Consistent with the FPL  
12 Distribution Engineering Reference Manual (DERM) Addendum for  
13 EWL, a Grade B load factor of 1.0 is implemented, rather than the lower  
14 0.75 factor specified in NESC-2007 for typical Grade C construction for  
15 the specified wind speeds.

16  
17  
18  
19  
20  
21  
22  
23  
24  
25

**Relative Distribution Pole Strength  
(NESC-2007, Grade B Extreme Wind Load Factor)**



1  
2  
3  
4  
5  
6  
7  
8  
9  
10  
11  
12  
13  
14  
15

**Figure 1  
FPL Plan Distribution Wood Pole Strength vs. NESC  
Requirements**

The three solid bars to the left side of Figure 1, labeled “N”, “C” and “B,” depict the relative magnitude of the present required pole strength for a Grade N, Grade C, or Grade B application. The three cross-hatched bars to the right depict the relative magnitude of the required pole strength due to extreme wind loads, at the wind speed indicated, should Rule 250C be directly extended to such applications, as proposed by FPL. The results in Figure 1 show that the EWL required pole strength ranges from almost double (105 m.p.h.) to more than three and one half times (145 m.p.h.) that required for the normal Grade C pole strength. For a Grade N pole application, the required strength would increase by




1 a factor ranging from almost four to more than seven. For the less  
2 commonly required Grade B applications, the required strength would  
3 increase by only a few percent for the 105 m.p.h., to double the required  
4 strength at 145 m.p.h. Thus, the EWL requirement as proposed by FPL  
5 would represent a major increase in pole strength requirements, when  
6 considered in comparison to any of the present NESC requirements for  
7 the various grades of construction, including Grade B, which FPL has  
8 apparently been routinely implementing based on Rule 250B (Combined  
9 Ice and Wind Loading Districts).

10

11 **Q. WHAT IS THE IMPACT OF EWL ON REQUIRED WOOD POLE SIZE**  
12 **(CLASS), ASSUMING POLE SPANS STAY THE SAME?**

13 A. Figure 2 illustrates the corresponding wood pole class that would be  
14 required, assuming a Class 4 pole is necessary for the Grade C  
15 application, and the same number of poles (or span length) is  
16 maintained. Similar to Figure 1, the three solid bars to the left side of  
17 Figure 2 depict the representative pole class for a Grade N, Grade C, or  
18 Grade B application. The three cross-hatched bars to the right depict  
19 the required class pole corresponding to the FPL proposed application  
20 of the extreme wind loads. A minimum increase of four class sizes (to  
21 Class H1) would be required for the minimum 105 m.p.h. wind, and as  
22 much as eight class sizes (to Class H5) for the 145 m.p.h. case. A  
23 Class 7 pole would otherwise suffice for the Grade N construction. As  
24 above, the Grade B applications would be affected to a lesser degree,  
25 but the increased size would still be significant, ranging from one to five

1 pole class sizes. The increased pole material costs, including shipping  
 2 and storage, are directly related to the number of poles or pole size  
 3 (class). For larger, stronger poles, increased installation costs for the  
 4 heavier poles may also be expected. Furthermore, the availability of  
 5 such larger size (diameter) wood poles may be an issue.



6  
7  
8  
9

**Figure 2**

**FPL Plan Required Distribution Wood Pole Class vs. NESC  
Requirements**

10

11 **Q. HOW DO YOU EXPLAIN FPL'S TESTIMONY THAT IT ONLY PLANS**  
 12 **TO INCREASE POLE STRENGTH BY ONE POLE CLASS?**

13 **A.** The illustrations above are useful for making an apples-to-apples  
 14 comparison of the increases in pole strength necessary to achieve  
 15 FPL's objectives. Rather than achieving EWL by relying on increased

1 pole strength alone, FPL proposes to use a combination of somewhat  
2 stronger poles and shorter pole-to-pole spans, thus increasing the  
3 number and size of poles and thus significantly increasing costs.  
4 Regardless of whether FPL chooses to use much stronger poles or a  
5 higher number of slightly stronger poles, the result is the same: FPL's  
6 proposed plan would have a major impact on the cost of the distribution  
7 facilities, which, based on reported previous industry experience, would  
8 not provide significant additional protection against storm damage.

9

10 **Q. FPL WITNESS MIRANDA REFERS TO PAST RESISTANCE FROM**  
11 **THE BUILDING INDUSTRY TO THE IMPOSITION OF STRICTER**  
12 **BUILDING CODES FOLLOWING HURRICANE ANDREW, BUT**  
13 **WHICH HAS APPARENTLY RESULTED IN SIGNIFICANT BENEFITS**  
14 **TO HOMES AND BUILDINGS. IS THIS A VALID ANALOGY?**

15 A. No. The primary vulnerability of pole facilities is not due to the poles  
16 themselves, but to the lines and cables extending between poles.  
17 These lines represent a disproportionately large exposure to falling trees  
18 and branches and flying debris that results in high wire tensions that  
19 transfer extremely large unbalanced lateral loads to the pole, which is  
20 compounded by the domino effect of damaged individual poles placing  
21 increased loads on adjacent poles along the line. Thus, poles with  
22 attached lines will experience a disproportionately large load during  
23 hurricanes in comparison to individual structures, including buildings and  
24 bare poles, and generally would not receive a commensurate benefit  
25 associated with the large increase in strength and cost. Furthermore,

1 utility poles and buildings have different physical characteristics, and  
2 cost-effective technologies and methods may be available for hardening  
3 buildings that may not be appropriate for simple pole geometries.  
4 Overall, the decision by the organizations responsible for developing  
5 building standards and codes made the decision appropriate for this  
6 category. The organization responsible for developing standards for the  
7 utility industry -- the NESC Committee -- has decided such a change  
8 would not be of significant benefit.

9

10 **Q. HOW DO YOU RESPOND TO MR. MIRANDA'S TESTIMONY THAT**  
11 **TRANSMISSION LINES WITHSTOOD HURRICANE WILMA**  
12 **HURRICANES BETTER THAN DISTRIBUTION LINES BECAUSE**  
13 **THEY ARE DESIGNED TO WITHSTAND EXTREME WIND?**

14 A. The greater survival rate of transmission structures is to be expected  
15 and has much more to do with their typically greater height than to their  
16 stricter design criteria. Because they are taller and their lines usually  
17 are higher, transmission poles are less vulnerable to falling trees,  
18 branches and wind-blown debris. This consideration is fundamental to  
19 NESC decisions to not require such extreme loadings for the shorter  
20 distribution poles, which would not significantly benefit from the required  
21 increased strength.

22

23 **Q. PLEASE RESPOND TO MR. MIRANDA'S TESTIMONY**  
24 **CONCERNING THE KEMA REPORT.**

25 A. Much of the decision to implement the FPL hardening plan is based on

1 its experiences with Hurricane Wilma, as analyzed and documented in  
2 the January 2006 KEMA report. That report concludes that “wind only”  
3 was the highest contributing factor for pole failures during this storm  
4 event. Performing a forensic analysis is typically a difficult task, due to  
5 the inability to successfully collect information in the midst of the  
6 restoration efforts, combined with the possible lack of immediate  
7 objective information at a later date. One must therefore be cautious in  
8 using the conclusions of such a study, in the absence of an industry  
9 review, as the basis for extensive changes in the distribution plant,  
10 especially when the results would be in conflict with other widely  
11 reported industry experiences. As an example of the difficulties in  
12 attempting to arrive at a unified or consistent explanation of the causes  
13 for damage during Hurricane Wilma, at page 77 the KEMA report states  
14 that:

15 “Compared to other counties, Broward County shows the  
16 highest failure rates . . . . *These findings virtually eliminate*  
17 *the potential Grade C construction as a contributing*  
18 *factor.*”

19 (Emphasis added.) Similarly, at page 80 the report states:

20 “This engineering analysis showed most other relevant  
21 pole break scenarios were of minor importance. Possible  
22 design overload due to double circuits or attachments,  
23 weakening of poles by Hurricane Katrina with Hurricane  
24 Wilma taking them out, *the potential grade C issue* in Palm  
25 Beach County and potential brittleness of CCA poles all

1           have been evaluated *without evidence of substantial*  
2           *contribution to the number of pole breakages.*"

3           (Emphasis added.) Such conclusions would appear to be in conflict  
4           with the "wind only" explanation, because Grade C poles would be  
5           expected to have greater rate of failure than the stronger Grade B  
6           construction otherwise implemented. In any case, ignoring the  
7           inconsistencies and assuming the conclusions about "wind only" are  
8           entirely accurate for this event, it should be concluded that Hurricane  
9           Wilma was a unique storm whose behavior and effects differed from  
10          those more typical extreme wind events in the past, as widely reported  
11          to the NESC Committee. The NESC Committee has many members of  
12          the utility industry from across the country, including the Southeast and  
13          Gulf states, and receives comments from numerous other utilities in  
14          response to recommended change proposals for the NESC. It would  
15          not be reasonable to introduce dramatic design changes to the  
16          distribution plant based on a single storm.

17

18   **Q.   PLEASE ADDRESS MR. MIRANDA'S TESTIMONY CONCERNING**  
19   **THE DAVIES CONSULTING STUDY AND EXHIBIT MBM-3.**

20   A.   Exhibit MBM-3, as provided by FPL, supposedly illustrates that its  
21          network, built to Grade B requirements, fared better than other utilities  
22          that only built to Grade C levels. If accurate, and there were no other  
23          factors involved, this might imply that the extreme wind requirement  
24          would provide additional reliability during hurricanes. Because this  
25          conclusion would be in contradiction to the previously noted experiences

1 of the rest of the industry across the United States, this matter would  
2 require further investigation -- including understanding the relative  
3 exposure and practices of the reporting utilities -- before accepting the  
4 stated implication. Furthermore, as indicated above, the experiences  
5 gained during Hurricane Wilma, as provided in the KEMA report, do not  
6 necessarily support the benefit of Grade B vs. Grade C construction.

7

8 **III. RECOMMENDATION**

9 **Q. WHAT GENERAL APPROACH DO YOU RECOMMEND TO THE**  
10 **COMMISSION CONCERNING EWL?**

11 A. I recommend that the Commission proceed with caution. The NESC is  
12 a well-respected document that is generally recognized as having  
13 served the industry and public well. As I already have noted, the  
14 imposition of an EWL requirement would greatly increase costs, without  
15 delivering significant benefits, and might result in unfortunate unintended  
16 consequences, as sometimes occurs when changing long-standing  
17 practices that have generally been deemed successful. An appropriate  
18 response would attempt to limit the otherwise dramatic impact to as  
19 small a category of facilities as possible, or to reduce the magnitude of  
20 the impact. Thus:

- 21 • Any approval of EWL should be limited to NESC-defined Grade B or  
22 Grade C applications only. Thus, Grade N applications -- which include  
23 joint-use poles with only secondary power (< 750 volts), as well as  
24 several categories of electric-only poles -- should be excluded explicitly  
25 from the proposed application of Rule 250C.

- 1       • The extension of the NESC Rule 250C to distribution poles ( $\leq 60$  feet  
2 tall) in the Grade C category, as defined by the NESC, should use the  
3 load factors provided in the 2007 edition of the NESC. Thus, a load  
4 factor of 0.75 should apply to the hurricane loads of 105, 130 and 145  
5 m.p.h. The resulting required strength would be reduced by 25%  
6 compared to those illustrated in Figure 1.
- 7       • Any approval of EWL should be on a trial basis, initially limited to a  
8 specified geographic area or areas and a defined period (e.g., 1-2  
9 years), to better understand the potential benefits and consequences of  
10 EWL. The application of EWL to certain critical infrastructure may serve  
11 this purpose.

12

13   **Q.    DOES THAT CONCLUDE YOUR TESTIMONY?**

14   **A.    Yes.**

15

16

17

18

19

20

21

22

23

24

25



**About Outside Plant Consulting Services, Inc. (OPCS)**

**(Dr. Lawrence M. Slavin)**

Outside Plant Consulting Services, Inc. (OPCS) was established in 2002 to help meet the needs of the telecommunications and power industries in establishing standards, guidelines and practices for outside plant facilities and products. The OPCS Group provides related support services for field deployment, and product evaluation and analysis. Dr. Lawrence (Larry) M. Slavin, Principal of OPCS, has extensive experience and expertise in such activities, based upon his many years of service at AT&T/Lucent Bell Telephone Laboratories (Distinguished Member of Technical Staff) in telecommunications product design and development, followed by a career at Telcordia Technologies (Bellcore) in its research and professional service organizations.

As Principal Consultant and Manager/Director of the Network Facilities, Components, and Energy Group at Telcordia, Dr. Slavin was responsible for professional services related to the telecommunications industry. These activities included technical leadership in developing installation and construction practices and "generic requirements" documents, introducing new construction methods, and performing analyses on a wide variety of technologies and products (such as poles, duct, wire and cable, electronic equipment cabinets, flywheel energy storage systems and turbine-generators). Throughout his career, he has had a leading role in the evolution of many telecommunications related fields and disciplines -- including aerial and buried plant design and reliability; advanced construction and cable and duct placement techniques; copper pair, coaxial, and fiber-optic technology; flywheel energy storage systems; physical design and development of hardware and electronic and electro-optic systems

(such as the "SLC 96" digital loop carrier); cable media and equipment reliability studies; exploratory fiber-optic hardware development; and systems engineering.

Dr. Slavin is a member of several subcommittees of the National Electrical Safety Code Committee, responsible for specifying safety standards for aerial and buried telecommunications and power facilities in the United States. He is also an active member and participant on the Accredited Standards Committee ASC-O5 ("ANSI-O5") for wood poles and products, as well as on several related committees of the American Society of Civil Engineers. In addition, Dr. Slavin is a Charter Member of the North American Society for Trenchless Technology, has been instrumental in the development of directional drilling standards, and directly supports training activities for the directional drilling industry. He has been instrument in the development and publication of several ASCE manuals for the trenchless installation of buried pipelines. Specific present and recent industry activities are listed below.

**Industry Activities**

- **National Electrical Safety Code Committee**
  - Represents the national telephone industry, via Alliance for Telecommunications Industry Solutions, ATIS
  - Executive Subcommittee
  - Main Committee
  - Subcommittee 4 (Overhead Lines – Clearances)
  - Subcommittee 5 (Overhead Lines – Strength & Loading)
  - Subcommittee 7 (Buried Lines)
- **Accredited Standards Committee ASC-O5**
  - *ANSI O5.1, Wood Poles, Specifications and Dimensions*
  - *ANSI O5.2, Wood Products, Structural Glued Laminated Timber for Utility Structures*
  - *ANSI O5.3, Wood Products, Solid Sawn-Wood Products and Braces*
- **Pole Reliability Based Design (RBD) Committee, ASCE**
  - *Reliability-Based Design of Utility Pole Structures*
- **Distribution Pole Standard Committee, ASCE**
- **Committee F17 on Plastic Piping Systems, ASTM**
  - Subcommittee F17.67 on Trenchless Plastic Pipeline Technology
  - Task Group Leader for development of HDD Standard ASTM F1962
  - *ASTM F1962, Standard Guide for Use of Maxi-Horizontal Directional Drilling for Placement of Polyethylene Pipe or Conduit Under Obstacles, Including River Crossings*

- Trenchless Installation of Pipelines (TIPS) Committee, ASCE
  - *ASCE Manual of Practice for Pipe Bursting Projects*
  - *ASCE Manual of Practice for Pipe Ramming Projects*
- Center for Underground Infrastructure and Research and Education (CUIRE) at the University of Texas, Arlington
  - Industry Advisory Board
- Trenchless Technology Center, Louisiana Tech University
  - Industry Advisory Board
- North American Society for Trenchless Technology (NASTT)
  - Charter Member
  - Chair of Directional Drilling Subcommittee
- Missouri Western State College
  - HDD Steering Committee

