

Susan D. Ritenour
Secretary and Treasurer
and Regulatory Manager

One Energy Place
Pensacola, Florida 32520-0781

Tel 850.444.6231
Fax 850.444.6026
SDRITENO@southernco.com



May 29, 2009

RECEIVED-PPSC
09 JUN - 1 PM 3:44
COMMISSION
CLERK

Ms. Ann Cole, Commission Clerk
Florida Public Service Commission
2540 Shumard Oak Boulevard
Tallahassee FL 32399-0850

Dear Ms. Cole:

RE: Docket No. 080410-EG

Enclosed for official filing in the above referenced docket are an original and fifteen (15) copies of the following:

1. Petition of Gulf Power Company.
2. Prepared direct testimony and exhibit of John N. Floyd.

Also enclosed is a CD containing the Petition in Microsoft Word format as prepared on a Windows NT based computer.

Sincerely,

COM 5
ROR 2
COL 2
SFC
PSP
SIC
SCA
ADM
CLK 1

mv

Enclosures

cc: Beggs and Lane
J. A. Stone, Esq.

DOCUMENT NUMBER-DATE

05415 JUN-1 09

FPSC-COMMISSION CLERK

BEFORE THE FLORIDA PUBLIC SERVICE COMMISSION

IN RE: **Commission Review of Numeric
Conservation Goals for Gulf Power
Company**)
)
)
)

Docket No.: **080410-EG**

CERTIFICATE OF SERVICE

I HEREBY CERTIFY that a true copy of the foregoing was furnished by U. S. mail this 29th day of May, 2009, on the following:

Susan Clark
Radey Law Firm
301 S. Bronough Street, Ste 200
Tallahassee FL 32301

Suzanne Brownless
Suzanne Brownless, PA
1975 Buford Blvd
Tallahassee FL 32308

E. Leon Jacobs, Jr.
c/o Williams & Jacobs, LLC
1720 South Gadsden Street, MS 14, Suit
Tallahassee, FL 32301

Jeremy Susac, Executive Director
Florida Energy & Climate Commission
c/o Governor's Energy office
600 S. Calhoun St, Ste. 251
Tallahassee, FL 32399-0001

Katherine Fleming, Esq
Florida Public Service Commission
2540 Shumard Oak Blvd
Tallahassee, FL 32399-0850

J. R. Kelly, Esq
Stephen Burgess, Esq
Office of the Public Counsel
111 West Madison Street, Rm 812
Tallahassee, FL 32399-1400

Wade Litchfield, Esq
Florida Power & Light Co
215 South Monroe St, Suite 810
Tallahassee, FL 32301

Paul Lewis Jr
Progress Energy Florida, Inc
106 East College Ave, Ste 800
Tallahassee, FL 32301-7740

John T. Burnett, Esq
Progress Energy Service Company, LLC
P.O. Box 14042
St. Petersburg, FL 33733-4042

Paula K. Brown
TECO
PO Box 111
Tampa, FL 33601-0111

John T. English
Florida Public Utilities Co.
PO Box 3395
West Palm Beach, FL 33402-3395

Norman H. Horton Jr Esq
Messer, Caparelo, & Self, PA
PO Box 15579
Tallahassee FL 32317

Susan F. Clark, Esq
Radey, Thomas, Yon, & Clark, PA
301 South Bronough St, Ste 200
Tallahassee FL 32301

James D. Beasley, Esq
Lee L. Willis, Esq
Ausley Law Firm
PO Box 391
Tallahassee FL 32302


Chris Browder
PO Box 3193
Orlando FL 32802-3193

Teala A. Milton
VP Government Relations
21 West Church St, Tower 16
Jacksonville, FL 32202-3158

Jeff Curry
Lakeland Electric Utility Co
501 East Lemon St
Lakeland FL 33801

Mr. Michael Ting
Itron, Inc
Consulting & Analysis Services
1111 Broadway Street, Ste 1800
Oakland, CA 94607

Mr. Richard F. Spelman, President
GDS Associates, Inc
1850 Parkway Place, Ste. 800
Marietta, GA 30067



JEFFREY A. STONE
Florida Bar No. 325953
RUSSELL A. BADDERS
Florida Bar No. 007455
STEVEN R. GRIFFIN
Florida Bar No. 0627569
BEGGS & LANE
P. O. Box 12950
Pensacola FL 32591-2950
(850) 432-2451
Attorneys for Gulf Power Company

BEFORE THE FLORIDA PUBLIC SERVICE COMMISSION

In re: Commission review of numeric conservation goals (Florida Power & Light Company).

Docket No.: 080407-EG

Docket No.: 080408-EG

In re: Commission review of numeric conservation goals (Progress Energy Florida, Inc.).

Docket No.: 080409-EG

Docket No.: 080410-EG

In re: Commission review of numeric conservation goals (Tampa Electric Company).

Docket No.: 080411-EG

Docket No.: 080412-EG

In re: Commission review of numeric conservation goals (Gulf Power Company).

Docket No.: 080413-EG

Filed: June 1, 2009

In re: Commission review of numeric conservation goals (Florida Public Utilities Company).

In re: Commission review of numeric conservation goals (Orlando Utilities Commission)

In re: Commission review of numeric conservation goals (JEA)

**PETITION FOR APPROVAL OF
NUMERIC CONSERVATION GOALS BY GULF POWER COMPANY**

Gulf Power Company ("Gulf Power," "Gulf," or "the Company"), by and through its undersigned attorneys, files this petition with proposed numeric conservation goals and requests that the Florida Public Service Commission ("Commission") accept, approve and adopt Gulf Power's proposed numeric conservation goals as the numeric goals established by the Commission for Gulf Power Company pursuant to section 366.82, Florida Statutes, and Rules 25-17.001 and 25-17.0021, Florida Administrative Code. In support of this petition, the Company states:

DOCUMENT NUMBER: DATE
05415 JUN-18
COMMISSION CLERK

1. Gulf Power is a public utility subject to the jurisdiction of the Commission pursuant to Chapter 366 of the Florida Statutes. Gulf Power's General Offices are located at One Energy Place, Pensacola, Florida 32520.

2. Copies of all notices and pleadings with respect to this petition should be furnished to:

Susan D. Ritenour
Secretary and Treasurer
and Regulatory Manager
Gulf Power Company
One Energy Place
Pensacola, Florida
32520-0780
(850) 444-6231
(850) 444-6026(facsimile)

Jeffery A. Stone, Esq.
Russell A. Badders, Esq.
Steven R. Griffin, Esq.
Beggs & Lane
P.O. Box 12950
Pensacola, Florida
32591-2950
(850) 432-2451
(850) 469-3331(facsimile)

3. The agency affected by this petition is:

Florida Public Service Commission
2540 Shumard Oak Boulevard
Tallahassee, Florida 32399-0850

4. Gulf Power is subject to section 366.82, Florida Statutes, part of the Florida Energy Efficiency and Conservation Act ("FEECA"), which requires the Commission to adopt appropriate goals to increase the efficiency of energy consumption, increase the development of demand side renewable energy systems, reduce and control the growth rates of electric consumption and weather sensitive peak demand, and encourage the development of demand side renewable energy resources.

5. Docket No. 080410-EG is one of seven that has been opened by the Commission to establish numeric conservation goals for each of the seven Florida FEECA utilities pursuant to section 366.82, Florida Statutes, and Rule 25-17.0021, Florida Administrative Code. As a

result of Gulf's evaluations, the Company proposes the following numeric conservation goals which Gulf has determined to be reasonably achievable in the residential, commercial and industrial classes within Gulf Power's service area over a ten-year period.

6. Gulf Power Company's proposed conservation goals for years 2010 through 2019 are set forth below:

Residential

<u>Year</u>	<u>Summer Peak MW Reduction (at Generator)</u>	<u>Winter Peak MW Reduction (at Generator)</u>	<u>Annual GWh Reduction (at Generator)</u>
2010	1.9	1.8	2.0
2011	4.7	4.3	6.0
2012	8.4	7.4	12.3
2013	12.9	11.1	20.5
2014	18.0	15.4	30.3
2015	23.7	20.0	41.3
2016	29.8	25.0	53.2
2017	35.9	30.0	65.3
2018	41.6	34.7	76.5
2019	47.0	39.2	86.8

Commercial/Industrial

<u>Year</u>	<u>Summer Peak MW Reduction (at Generator)</u>	<u>Winter Peak MW Reduction (at Generator)</u>	<u>Annual GWh Reduction (at Generator)</u>
2010	1.2	0.5	2.7
2011	2.8	1.0	7.3
2012	4.7	1.6	13.4
2013	6.9	2.3	20.7
2014	9.3	3.0	28.7
2015	11.8	3.8	37.2
2016	14.4	4.6	46.1
2017	17.0	5.4	55.1
2018	19.5	6.2	63.9
2019	21.9	7.0	72.2

7. The testimony of John N. Floyd, filed contemporaneously with this petition, along with the exhibit and schedules attached thereto, summarizes the Company's ten year projections of the total cost-effective winter and summer peak MW demand reduction and the annual GWh savings which are reasonably achievable through implementation of demand side measures in Gulf Power's service area for the residential, commercial and industrial classes. Gulf Power is also co-sponsoring the testimony and exhibits of Itron, Inc. witness Mike Rufo. Mr. Rufo presents and summarizes the methodology, input data and findings contained in the studies of technical potential and achievable potential for cost-effective energy efficiency and load management for the seven FEECA utilities.

8. As demonstrated by the testimony of witnesses Floyd and Rufo, the Company's

proposed numeric conservation goals for the period 2010 through 2019 are reasonable and are consistent with the requirements of section 366.82, Florida Statutes, and Rule 25-17.0021, Florida Administrative Code.

9. Gulf knows of no material facts in dispute regarding the relief requested herein.

WHEREFORE, Gulf Power Company requests that the Florida Public Service Commission enter an order approving and establishing the Company's proposed numeric conservation goals for the period 2010 through 2019 pursuant to section 366.82, Florida Statutes, and Rule 25-17.0021, Florida Administrative Code, and grant such other relief as is just and reasonable under the facts and law as determined by the Commission.

Respectfully submitted this 29th day of May, 2009.



JEFFREY A. STONE

Florida Bar No. 325953

RUSSELL A. BADDERS

Florida Bar No. 007455

STEVEN R. GRIFFIN

Florida Bar No. 0627569

Beggs & Lane

P. O. Box 12950

Pensacola, FL 32591

(850) 432-2451

Attorneys for Gulf Power Company

BEFORE THE FLORIDA PUBLIC SERVICE COMMISSION

**COMMISSION REVIEW OF NUMERIC
CONSERVATION GOALS**

Docket No. 080410-EG

**PREPARED DIRECT TESTIMONY AND
EXHIBIT OF
JOHN N. FLOYD**

FILED JUNE 1, 2009



DOCUMENT NUMBER-DAT:
05415 JUN-18
FPSC-COMMISSION CLERK

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25

Gulf Power Company
Before the Florida Public Service Commission
Prepared Direct Testimony and Exhibit of
John N. Floyd
Docket No. 080410-EG
Commission Review of Numeric Conservation Goals
June 1, 2009

Q. Will you please state your name, business address, employer and position?

A. My name is John N. Floyd, and my business address is One Energy Place, Pensacola, Florida 32520. I am employed by Gulf Power Company as the Economic Evaluation and Market Reporting Team Leader.

Q. Mr. Floyd, please describe your educational background and business experience.

A. I received a Bachelor Degree in Electrical Engineering from Auburn University in 1985. After serving four years in the U.S. Air Force, I began my career in the electric utility industry at Gulf Power in 1990 and have held various positions within the Company in Power Generation, Metering, Power Delivery Distribution, and Marketing. In my present position, I am responsible for Energy Conservation Cost Recovery (ECCR) filings, economic evaluations, market research, and other marketing services activities.

Q. Have you previously testified before this Commission?

A. Yes.

DOCUMENT NUMBER-DATE
05415 JUN-18
FPSC-COMMISSION CLERK

1 Q. Mr. Floyd, what is the purpose of your testimony?

2 A. The purpose of my testimony is to propose seasonal peak demand and
3 annual energy conservation goals for Gulf Power for the period 2010
4 through 2019.

5

6 Q. Please describe how your testimony is organized.

7 A. My testimony is organized as follows:

8 Section 1: Proposed Goals and Accomplishments

9 Section 2: Overall Process to Develop Goals

10 Section 3: Statutory Adherence

11 Section 4: Additional Supporting Information

12 Section 5: Conclusions

13

14 Q. Have you prepared an exhibit in support of your testimony?

15 A. Yes, I have.

16 Counsel: We ask that Mr. Floyd's exhibit consisting of 11

17 schedules be marked for identification as:

18 Exhibit No. _____ (JNF-1)

19

20 **Section 1: Proposed Goals and Accomplishments**

21 Q. What residential and commercial/industrial goals are appropriate and
22 reasonably achievable for Gulf Power Company for seasonal peak
23 demand and energy conservation for the period 2010 through 2019?

24 A. The Company's proposed seasonal peak demand and annual energy

25

1 conservation goals for the period 2010 through 2019 are contained in
2 Schedule 1 of my exhibit (JNF-1). In total, Gulf is proposing a summer
3 peak demand goal of 68.9 MW, winter peak demand goal of 46.2 MW,
4 and cumulative annual energy conservation goal of 159 GWh. These
5 goals are based upon Gulf's planning process and the results of technical
6 and achievable potential studies conducted by Itron, Inc., Consulting and
7 Analytical Services (Itron). The goals represent the total cost-effective
8 winter and summer peak MW demand reductions and the annual GWh
9 savings at the generator which are reasonably achievable through
10 implementation of demand-side programs in Gulf Power's service area for
11 the residential and commercial/industrial customer classes. The basis for
12 the goals are the MW and GWh associated with estimated maximum
13 adoption of measures that passed both the Rate Impact Measure (RIM)
14 and the Participant's Test (PT) as reflected in the achievable potential
15 results prepared by Itron for Gulf Power.

16

17 Q. How do Gulf Power's proposed Demand-Side Management (DSM) goals
18 for the period of 2010 through 2019 compare to Gulf Power's current DSM
19 goals for the period of 2005 through 2014?

20 A. The cumulative annual energy conservation goals being proposed for the
21 period 2010 through 2019 are higher than the goals currently approved in
22 Commission Order No. PSC-04-0764-PAA-EG. The proposed seasonal
23 peak demand goals are lower than currently approved goals. A
24 comparison of the goals can be found in Schedule 2 of my exhibit.

25

1 Q. Please describe how Gulf Power has endeavored to achieve the
2 objectives of the Florida Energy Efficiency and Conservation Act
3 (FEECA).

4 A. Gulf has a thirty-five year history of promoting energy efficiency and
5 conservation as a way for customers to save money and increase comfort
6 while at the same time reducing the generating capacity required to serve
7 our customer base. This approach began in the 1970's with the
8 introduction of the GoodCents Home program as a way to increase the
9 efficiency of residential energy use by constructing homes with long-term
10 operating cost and comfort in mind. This program not only provided
11 increased comfort and savings to the homeowner, but also provided
12 additional value in the sale and resale of homes meeting this standard.
13 Over the years, the concepts behind this program have been universally
14 adopted in the utility industry and have influenced building code standards
15 as cost-effective means of achieving improvements in energy utilization in
16 both the residential and commercial sectors.

17 Gulf has also been a leader in innovative approaches to DSM.
18 Beginning in the 1990's, Gulf introduced the concept of home energy
19 management combined with variable pricing, including critical peak pricing
20 (CPP). Providing appropriate pricing to reflect changes in the marginal
21 cost of generating electricity during the day allows the customer to be in
22 control of their energy purchases. Coupled with a smart thermostat, this
23 program gives customers the ability to adjust the operation of heating
24 ventilation and cooling (HVAC), water heating, and pool pumps to operate
25 in a manner that is acceptable to their budget and lifestyle while providing

1 benefits in the form of reduced demand during peak periods.
2 Gulf also introduced this variable pricing philosophy in the large
3 commercial/industrial market through a real-time pricing program that has
4 demonstrated significant demand response during peak times while
5 providing increased value to the customers who have the ability to
6 manage their energy consumption.

7 Recognizing a need to explore additional opportunities associated
8 with end-use renewable technologies, Gulf Power, in 2008, received
9 Commission approval of a one year pilot program to evaluate the level of
10 customer interest in and benefits of solar thermal water heating. This
11 program is currently ongoing and will be evaluated at the end of 2009.

12

13 Q. Please describe the progress Gulf has made towards achieving the goals
14 set in Order No. PSC-04-0764-PAA-EG for the period 2005 through
15 2008?

16 A. Schedule 3 of my exhibit provides a summary of Gulf Power's progress
17 toward goal achievement. During this period, Gulf has exceeded the
18 goals for seasonal peak demand reductions and annual energy reductions
19 for the commercial/industrial sector. For the residential sector, however,
20 Gulf has not met its goals for seasonal peak demand reductions and
21 annual energy reductions.

22 Gulf's under-achievement in the residential sector has been
23 primarily due to customer participation in the GoodCents Select program,
24 which has been renamed "Energy Select," being well under projections.
25 Participation projections for this program account for almost 90% of the

1 summer peak demand savings goal and approximately 75% of the annual
2 energy reduction goal. Impacts from the 2004 and 2005 hurricane
3 seasons, growing communication technology incompatibilities due to
4 customer elimination of land line telephone service, delays in
5 development and delivery of hardware from the manufacturer, and
6 resulting suspension of active promotion of the program from August of
7 2007 through March of 2009 have contributed to lower than projected net
8 program participants during this period.

9

10 Q. Does Gulf believe Energy Select can be a viable part of its DSM Plan
11 going forward?

12 A. Yes. Energy Select is Gulf's home energy management with critical peak
13 pricing (CPP) program. The fundamental concepts behind the Energy
14 Select program are sound and do provide dependable demand reductions
15 at peak times as well as high customer satisfaction. In addition, with
16 second generation control units being deployed in 2009 and ongoing
17 deployment of Gulf's automated metering infrastructure (AMI), the
18 opportunity exists to overcome some of the technology barriers that
19 currently limit the program's applicability. Gulf's proposed goals for the
20 period 2010 through 2019 include the achievable potential for Demand
21 Response (DR) associated with this approach to customer-controlled
22 peak demand reductions.

23

24

25

1 **Section 2: Overall Process to Develop DSM Goals**

2 Q. Please provide an overview of the process used to determine the
3 proposed goal levels.

4 A. Gulf Power developed proposed goals based on a progressive process of
5 1) determining the full technical potential for energy efficiency savings; 2)
6 determining the subset of that potential that is cost-effective under both
7 the RIM and Total Resource Cost (TRC) cost-effectiveness screens as
8 compared to Gulf's resource needs from the most recent integrated
9 resource plan; and 3) determining the theoretical achievable potential of
10 energy and demand savings based on modeling of multiple adoption
11 scenarios considering the unique circumstances of our service area,
12 existing programmatic activity, and historical experience.

13 This process was guided by Itron under contract to Florida Power &
14 Light (FP&L) on behalf of the seven Florida utilities subject to
15 requirements of the Florida Energy Efficiency and Conservation Act
16 (FEECA). Itron was assisted in this work by KEMA, Inc., an international
17 energy consulting firm.

18
19 Q. Have there been any changes in Gulf's integrated planning process since
20 the last conservation goals setting process?

21 A. No. Gulf continues to conduct integrated resource planning in conjunction
22 with other Southern electric system operating companies. The
23 Company's planning process evaluates the cost of new generating
24 capacity additions after incorporating the effects of its approved
25 conservation and energy efficiency programs in order to produce an

1 integrated resource plan that meets the needs of our customers in a cost-
2 effective and reliable manner.

3

4 Q, What avoided unit did Gulf use in development of these proposed goals?

5 A. Consistent with Gulf's integrated planning process, the measures
6 evaluated in this process, as well as Gulf Power's purchased power
7 agreement (PPA) with Shell Energy North America (US), L.P. that is
8 currently before this Commission for approval, were evaluated against a
9 2014 combined cycle generating resource need identified in the most
10 recent integrated resource plan for Gulf Power as reflected in Gulf's April
11 2009 Ten-Year Site Plan (TYSP).

12

13 Q. Please describe the collaborative among the utilities and other entities.

14 A. Florida Power & Light (FP&L), Progress Energy Florida (PEF), Tampa
15 Electric Company (TECO), Gulf Power, Jacksonville Electric Authority
16 (JEA), Orlando Utilities Commission (OUC), Florida Public Utilities (FPU),
17 and two non-utility interested parties, the Southern Alliance for Clean
18 Energy (SACE) and the Natural Resources Defense Council (NRDC),
19 hereafter referred to as the collaborative, formed a mutually beneficial
20 working group to progress through the preparation of proposed DSM
21 goals for the period 2010 through 2019.

22 The Commission staff also participated as an observer in this
23 process by attending weekly project status conference calls and
24 coordinating workshop presentations and report submission.

25

1 Q. Why was a collaborative approach utilized?

2 A. The collaborative approach used in this goal setting process had several
3 benefits. First, utilizing a collaborative approach offered an opportunity for
4 consistency across the utilities in development of the Technical Potential
5 Study. The collaborative successfully developed a common scope for the
6 study and jointly selected a consultant, Itron, to conduct the study. This
7 approach also provided an opportunity for each of the participating utilities
8 to gain insight from experiences of the others, which has led to more
9 robust results along each phase of the study. The collaborative also
10 provided a cooperative mechanism for non-utility interested party
11 involvement in preparation of the proposed DSM goals. In this case,
12 SACE and NRDC assisted in development of the project scope, vendor
13 selection, identification of measures to be evaluated, and review of
14 results. The collaborative offered an excellent forum for members to
15 discuss aspects of the studies, make decisions, and generally progress
16 through the goals development process together.

17
18 Q. Please describe the process of how the collaborative selected Itron to be
19 the consulting firm utilized to provide the necessary assistance in the DSM
20 goals setting process.

21 A. First, the collaborative members developed the Scope of Work and
22 request for proposal (RFP) for the Technical Potential Study. Each
23 member submitted names of consultants to be considered. After
24 discussion and review, the collaborative agreed to submit the RFP to
25 eleven potential vendors. Four vendors responded with intent to offer a

1 proposal. Once clarifying questions were answered, three vendors
2 ultimately offered a proposal.

3 The proposals were evaluated by each member of the collaborative
4 independently utilizing a scoring matrix. Once these evaluations were
5 completed, the scores were compiled and averaged such that each utility
6 member and SACE/NRDC had an equal vote in selection of the winning
7 bidder.

8 The Itron/KEMA proposal achieved the best overall score and Itron
9 was subsequently selected to conduct the Technical Potential Study.
10 Itron offered the most thorough proposal for assessing the technical
11 potential by taking a "bottom-up" approach of assessing actual end-use
12 penetrations and opportunities for increased efficiency. The RFP also
13 included provisions for optional tasks to perform the Economic and
14 Achievable Studies once the Technical Potential Study was complete. In
15 January 2009, Itron's contract was modified to include the tasks of
16 Economic and Achievable Studies in support of the FEECA utilities' DSM
17 goal preparation.

18

19 Q. In general, what was the scope of Itron's work in preparation of goals for
20 this filing?

21 A. Itron first developed the total technical potential for energy efficiency in
22 Gulf Power's service area on an end-use measure basis for the residential
23 and commercial/industrial customer classes. Next, after Gulf Power
24 performed cost-effectiveness screening of these measures based on the
25 measure costs and savings estimates provided in the technical potential

1 results, Itron developed estimates of achievable potential on a measure
2 by measure basis for three different incentive scenarios for both a RIM
3 and TRC-based portfolio.

4 Itron also developed methodologies to estimate technical and
5 achievable potential for DR measures and demand-side Solar
6 Photovoltaic (PV) systems.

7

8 Q. How was the comprehensive energy efficiency measure list developed
9 among the collaborative?

10 A. As in the case of previous goals proceedings, the starting point for the
11 measure list to be studied was the Synergistic Resources Corporation
12 (SRC) Electricity Conservation and Energy Efficiency in Florida study
13 commissioned by the Florida Energy Office in 1993. Collaborative
14 members then submitted additional measures for consideration based on
15 existing Commission approved utility programs and other technologies not
16 considered in the 1993 study, nor currently part of any Florida utility DSM
17 program. All proposed measures were reviewed and approved by the
18 collaborative.

19

20 Q. Were there other measures included in the measure list for evaluation that
21 were not identified by the collaborative?

22 A. Yes. Itron proposed additional measures that had been recently analyzed
23 in previous technical potential studies in other jurisdictions. These
24 additions included measures in all residential, commercial, and industrial
25 categories. The study considered 257 unique energy efficient end-use

1 measures, including 61 residential, 78 commercial, and 118 industrial
2 measures. Each measure was evaluated in multiple building-types and
3 against multiple base cases resulting in a total of 2,346 individual energy
4 and demand savings calculations.

5 Itron also evaluated 7 DR and 3 PV measures. In total, the
6 Technical Potential Study included 267 measures, as listed in Schedule 4
7 of my exhibit, in the development of Gulf's proposed goals.

8

9 Q. How were the measure costs and savings for the participant developed?

10 A. The measure costs and savings were initially prepared by Itron for
11 collaborative members' review. This data came from a variety of sources
12 including Florida-specific utility program experience and Florida Solar
13 Energy Center (FSEC) research.

14 Additional information about Itron's sources for this data can be
15 found in Section 3.4 of the Technical Potential for Electric Energy and
16 Peak Demand Savings for Gulf Power Final Report by Itron. A true and
17 correct copy of this report, which was previously filed with the Commission
18 in Docket No. 080410-EG and assigned Document Number 03587-09, is
19 hereby incorporated by reference in my testimony.

20

21 Q. Were natural gas substitution measures considered in the evaluations?

22 A. Yes. In accordance with FPSC Rule 25-17.0021, Gulf Power did consider
23 natural gas water heating measures in both residential and commercial
24 sectors and found them not to be cost-effective. Since Gulf is a summer
25 peaking utility, consideration was not given to natural gas heating

1 substitution measures because they could only reduce winter peak
2 demand.

3

4 Q. Please provide an overview of the process used to determine the full
5 technical potential of energy efficiency measures.

6 A. Once the measure list was finalized, Itron began the process of
7 determining the technical potential associated with these measures by
8 utilizing a "bottom-up" approach. This approach included an assessment
9 of the current penetration of end-use measures in Gulf Power's service
10 area, the number of technically feasible opportunities for implementation
11 of the energy efficient measures, and the resulting energy and demand
12 savings potential. For the commercial sector, KEMA conducted
13 approximately 600 on-site surveys across the state in order to better
14 define building characteristics and baseline end-use equipment
15 saturations. Forty-eight of these surveys were conducted in Gulf Power's
16 service area.

17 In order to account for the overlapping savings of some measures,
18 Itron developed an adoption supply-curve for the entire list of measures
19 based on the participant test results. In other words, measures having
20 higher participant test results were assumed to be adopted before
21 measures of lower participant test results for measures that produced
22 overlapping benefits. For example, a building envelope measure that
23 provides a certain level of energy and demand savings may be adopted
24 before an HVAC measure whose benefits would assume some of those
25 same savings if the building envelope measure had a higher participant

1 test result. The energy and demand benefits for the HVAC measure, in
2 this case, would be adjusted downward in order to avoid double counting.
3 Full details of this process can be found in Section 3 of the Technical
4 Potential for Electric Energy and Peak Demand Savings for Gulf Power
5 Final Report by Itron.

6

7 Q. How was the economic potential for the energy efficiency measures
8 determined?

9 A. Once the technical potential was finalized, Gulf Power began assessing
10 the cost-effectiveness of these measures with their associated adjusted
11 savings benefits and measure costs from the technical potential results.
12 Gulf Power used the avoided cost data associated with its most current
13 integrated resource plan as the basis for these evaluations and
14 subsequent screening using Commission approved cost-effectiveness
15 criteria, namely RIM and TRC. For this screening no administrative costs,
16 program costs, or incentives were included in the RIM and TRC
17 calculations in order to provide the largest set of measures for further
18 consideration.

19 Two sets of economic potential were developed: a set based on
20 measures that passed RIM and a set that passed TRC. Schedule 5 of my
21 exhibit contains the list of the energy efficiency measures included in the
22 economic potential for both the RIM and TRC portfolios.

23

24 Q. Was there additional screening performed on the measure list?

25 A. Yes. This screening included consideration of administrative and program

1 costs in order to ensure any measures passing through for achievable
2 potential modeling would be cost-effective in each of the RIM and TRC
3 portfolios. In addition, measures that had cost/savings combinations that
4 resulted in customer payback of less than two years without any
5 incentives were screened from the final achievable potential analysis.

6 Further screening of the measures was conducted to determine
7 which measures also passed the PT. For measures not initially passing
8 the PT in the RIM portfolio, incentive dollars were applied to increase the
9 PT score to the point the RIM score fell to 1.0. Measures that still did not
10 pass the PT with these maximum incentives were eliminated from further
11 consideration. For the TRC screen, the incentive is not considered in the
12 test so the incentive level was increased to a maximum amount that
13 brought the customer payback to two years. If this incentive level did not
14 bring the PT score to at least 1.0, the measure was eliminated from
15 further consideration.

16

17 Q. At the completion of the screening process, how many measures
18 remained?

19 A. At the completion of the screening process, 143 energy efficiency
20 measures remained and were provided to Itron for achievable potential
21 modeling. Schedule 6 of my exhibit contains the list of measures included
22 in the RIM/PT and TRC/PT achievable potential portfolios.

23

24 Q. How was the achievable potential estimated in this study?

25 A. The achievable potential phase of the energy efficiency study was

1 accomplished by Itron utilizing KEMA's DSM ASSYST model. The
2 achievable potential for energy efficiency measures was estimated by
3 assessing likely market penetration based on trends in customer
4 awareness, measure cost, measure savings, and both energy and non-
5 energy related measure characteristics.

6 As the primary sensitivity to achievable potential, the collaborative
7 agreed to have Itron model adoption estimates for the following incentive
8 scenarios for both the RIM/PT and TRC/PT portfolios:

- 9 a. An incentive of 33% of the incremental cost of the measure
10 (low).
- 11 b. An incentive of 50% of the incremental cost of the measure
12 (medium).
- 13 c. The necessary incentive to bring the customer payback to two
14 years (high).

15 In all cases, the incentive is capped at a maximum value that would
16 produce a two year customer payback or a minimum RIM score of 1.01
17 (as applicable).

18 Itron adjusted the achievable potential to remove effects of
19 "naturally occurring" adoption. In Itron's methodology, naturally occurring
20 adoption includes "free riders" and is an estimate of the amount of energy
21 efficiency projected to occur without further utility program intervention.
22 Additional details about the specific assumptions and variables in the
23 DSM ASSYST model can be found in Mr. Mike Rufo's testimony.

24
25

1 Q. How were Gulf Power's market penetration rates for these DSM goals
2 developed?

3 A. The market penetration rates for Gulf Power were predicted in the DSM
4 ASSYST model based on factors including the level of market awareness
5 created through program marketing, the level of incentive available to the
6 participant, and the overall cost-effectiveness of the measure to the
7 customer.

8 Additional detail about the specific assumptions and variables in
9 the DSM ASSYST model can be found in Mr. Mike Rufo's testimony.

10

11 Q. How were DR measures identified and evaluated for technical and
12 achievable potential?

13 A. Itron used a methodology that made assumptions about three key factors
14 to determine technical potential for DR; the availability of communications
15 networks, the availability and end-use demand reduction capabilities of
16 DR enabling technologies, and the availability of dynamic pricing options.

17 In estimating achievable potential, Itron considered both customer-
18 controlled DR modeled as CPP-type programs and utility-controlled DR
19 modeled as direct load control (DLC). They made a number of
20 assumptions in developing potential adoption scenarios, including full
21 implementation of Advanced Metering Infrastructure (AMI), particularly
22 with regard to CPP programs. Itron did consider Gulf's program
23 experience in refining their CPP assumptions. Ultimately, the achievable
24 potential was projected based on ranges of customer enrollment and
25 represented as a "low enrollment" and "high enrollment" scenario.

1 Additional details about this process can be found in Section 4 of the
2 Technical Potential for Electric Energy and Peak Demand Savings for Gulf
3 Power Final Report by Itron and the testimony of Mr. Mike Rufo.

4
5 Q. How were renewable technologies identified and evaluated?

6 A. Renewable technologies were handled in two ways for the technical and
7 achievable potential studies. First, solar thermal water heating and PV
8 pool pumps were included in the energy efficiency study since they both
9 directly replace specific end-use loads and can be modeled like other
10 efficiency measures.

11 Itron handled rooftop PV using a separate methodology that first
12 estimated the total roof area of residential and commercial buildings plus
13 commercial parking lot shade structures suitable for siting PV systems.
14 Then Itron translated this area into estimates of annual energy and
15 capacity coincident with Gulf Power's summer and winter demand peaks
16 that could be produced by PV. Additional details about this process can
17 be found in Section 5 of the Technical Potential for Electric Energy and
18 Peak Demand Savings for Gulf Power Final Report by Itron and the
19 testimony of Mr. Mike Rufo.

20 Gulf Power conducted cost-effectiveness screening utilizing the
21 measure characteristics provided by Itron and concluded that the rooftop
22 PV measures do not pass the RIM/PT, or the TRC/PT combination of
23 cost-effectiveness tests. Consequently, Itron did not provide achievable
24 potential projections for these measures.

25

1 **Section 3: Statutory Adherence**

2 Q. Has Gulf Power provided an adequate assessment of the full technical
3 potential of all available demand-side conservation and efficiency
4 measures, including demand-side renewable energy systems?

5 A. Yes. Through the collaborative-sponsored study performed by Itron, an
6 adequate assessment of the full technical potential of all available
7 demand-side conservation and energy efficiency measures, including
8 demand-side renewables has been completed. This assessment included
9 the evaluation of 267 individual end-use energy efficiency, demand
10 response, and solar photovoltaic measures.

11

12 Q. Section 366.82(3), Florida Statutes, requires the Commission to evaluate
13 the full technical potential of supply-side conservation and efficiency
14 measures. Does Gulf Power's Technical Potential Study evaluate supply-
15 side conservation and efficiency measures and, if not, why?

16 A. Gulf Power has not conducted an assessment of supply-side conservation
17 and efficiency opportunities in the same manner as the demand-side
18 opportunities have been evaluated. Gulf does recognize that these
19 opportunities may exist and, in fact, considers energy efficiency in
20 selecting supply-side projects in all generation, transmission, and
21 distribution functions. However, the Commission has not developed
22 guidelines for such an evaluation that would provide a methodical
23 approach to identifying, quantifying, and proposing goals for supply-side
24 conservation and efficiency measures. For this reason Gulf Power
25 recommends addressing this portion of the statutory requirements in

1 section 366.82(3), Florida Statutes, in a separate proceeding.

2

3 Q. Has Gulf Power provided an adequate assessment of the achievable
4 potential of all available demand-side conservation and efficiency
5 measures, including demand-side renewable energy systems?

6 A. Yes. Through the collaborative-sponsored study performed by Itron, an
7 adequate assessment of the full achievable potential of demand-side
8 conservation and energy efficiency measures, including demand-side
9 renewables has been completed. This assessment included modeling
10 various projections of achievable potential for energy efficiency measures
11 based on customer incentive levels in both a RIM/PT and TRC/PT
12 portfolio.

13 Itron has also provided estimates of achievable potential for two
14 scenarios of incremental DR: low enrollment and high enrollment. Gulf
15 has included the achievable potential associated with the high enrollment
16 scenario in the Company's proposed goals.

17 All demand-side renewable energy systems were evaluated using
18 the same cost-effectiveness standards as other energy efficiency
19 measures. No renewable measures are cost-effective under these
20 standards and, therefore, none are reflected in the achievable potential
21 results. A summary of the achievable potential results can be found in
22 Schedule 9 of my exhibit.

23

24 Q. Should the Commission establish separate goals for demand-side
25 renewable energy systems?

1 A. No. Separate goals should not be established for demand-side
2 renewables. Instead, demand-side renewables should be evaluated and
3 included in Gulf Power's DSM plan based on the same criteria already
4 established for traditional end-use energy efficiency measures.

5 Gulf is currently evaluating solar thermal water heating through a
6 one-year pilot program approved by this Commission in 2008 and will
7 assess the opportunity for inclusion of this technology in our DSM plan
8 going forward. Gulf also continues to monitor performance and utility
9 system interaction of both small PV and wind generators as part of our
10 evaluation of demand-side renewable energy systems.

11

12 Q. Should the Commission establish additional goals for efficiency
13 improvements in generation, transmission and distribution?

14 A. Not at this time. As stated above, Gulf Power recommends that this matter
15 be considered in a separate proceeding following the conclusion of the
16 current goal-setting process.

17

18 Q. Should the Commission establish separate goals for residential and
19 commercial/industrial customer participation in utility energy audit
20 programs for the period 2010–2019?

21 A. No. Energy audits are an important component of achieving the proposed
22 goals through customer education of both general and program-specific
23 actions customers can take to reduce energy usage and, therefore,
24 should be included as part of the overall DSM goals. Gulf promotes the
25 availability of these audits beyond the minimum requirements of

1 Commission rules and depends on customer response to enhance
2 participation in other programs.

3

4 Q. What cost-effectiveness test should the Commission use to set DSM
5 goals for Gulf Power?

6 A. The Commission should use the combination RIM and PT cost-
7 effectiveness tests to set goals for Gulf Power. This combination of tests
8 provides a reasonable balance between participating and non-
9 participating customer benefits and provides a downward pressure on
10 overall electric rates while still supporting significant conservation activities
11 over the period 2010 through 2019.

12 In fact, utilizing this RIM based portfolio of proposed goals provides
13 more cost-effective achievable conservation than all but the high-incentive
14 TRC based portfolio. The only TRC based portfolio producing a higher
15 level of achievable potential assumes incentives of up to 100% of the
16 incremental cost of measures and would cost Gulf's customers an
17 additional \$209 million over the ten year period, more than double Itron's
18 cost estimate for the RIM based portfolio.

19 Using the combination of RIM and PT cost-effectiveness tests to
20 establish goals for Gulf Power is consistent with the requirements of
21 section 366.82(3), Florida Statutes, to consider impacts to participating
22 customers as well as non-participating customers, together comprising the
23 general body of customers.

24

25

1 Q. Do Gulf Power's proposed DSM goals adequately reflect the costs and
2 benefits to customers participating in the measure?

3 A. Yes. The measures included in development of the goals reflect the costs
4 and benefits to the participating customers. This is done by performing
5 the participant cost test and ensuring that all measures contemplated for
6 inclusion in the goals pass this test.

7

8 Q. Do Gulf Power's proposed DSM goals adequately reflect the costs and
9 benefits to the general body of ratepayers as a whole, including utility
10 incentives and participant contributions?

11 A. Yes. By passing the RIM test, Gulf's proposed goals reflect costs and
12 benefits that minimize overall rate impacts for the general body of
13 customers, whether or not they participate in one of the resulting
14 conservation programs. In addition, by only including measures that also
15 pass PT, these proposed goals adequately consider participant
16 contributions as a component of overall customer impact.

17

18 Q. Do Gulf Power's proposed DSM goals adequately reflect the costs
19 imposed by state and federal regulations on the emission of greenhouse
20 gases?

21 A. Yes. Although there are currently no state or federal regulations
22 governing the emission of greenhouse gases, assumptions for CO₂ cost
23 avoidance have been considered as a benefit in the evaluation of all
24 measures. Specifically, Gulf Power has included a "mid-range" CO₂ cost
25 projection as a component of fuel costs used in the economic screening of

1 measures. This “mid-range” assumption has a nominal value of \$20/ton
2 in 2014 and escalates for future years. This “mid-range” assumption falls
3 within a range of sensitivities Gulf Power has used to model impacts on
4 possible future expansion plans.

5

6 Q. What is Gulf Power’s position relative to the Commission establishing
7 incentives to promote both customer-owned and utility-owned energy
8 efficiency and demand–side renewable energy systems?

9 A. Historically the Commission’s preference for relying on the combination of
10 RIM and PT in the evaluation and approval of utility conservation
11 programs has provided the necessary structure to ensure that the
12 interests of all stakeholders are balanced. In practice, these tests have
13 provided incentives to customers through the payment of rebates, to the
14 utility by balancing the impacts of avoided cost benefits against revenue
15 impacts, and to the general body of customers by preventing cross-
16 subsidization between DSM program participants and non-participants.

17 If, in establishing Gulf Power’s goals, the Commission were to
18 change its policy and establish goals which disturb the appropriate
19 balance between the interests of all stakeholders, Gulf believes that the
20 Commission should consider a utility incentive mechanism as a potential
21 remedy.

22

23 **Section 4: Additional Supporting Information**

24 Q. Please identify the projected technical potential for total energy and peak
25 demand savings for Gulf Power.

1 A. The Itron study breaks technical potential into three categories: energy
2 efficiency, demand response and customer-sited PV. This technical
3 potential represents full implementation of all technically feasible
4 measures without regard to cost, acceptability to customers, or timeframe.
5 The total technical potential for energy efficiency, demand response and
6 PV in Gulf Power's service area is shown in Tables 1, 2 and 3 of Schedule
7 7 of my exhibit.

8 These technical potential estimates are not additive and represent
9 the upper bound of potential from a technical feasibility sense, regardless
10 of cost or acceptability to customers. They do not reflect what is cost-
11 effective or what is achievable in utility-sponsored programs.

12
13 Q. Please identify the projected economic potential for energy and peak
14 demand savings and associated measures for Gulf Power based on both
15 the RIM and TRC cost-effectiveness test.

16 A. The economic potential is the subset of the technical potential that is cost
17 effective under the RIM or TRC cost-effectiveness test. Economic
18 potential is an intermediate step in determining the overall achievable
19 potential for end-use measure savings as discussed previously in my
20 testimony. Like the technical potential results, these numbers reflect full
21 implementation of measures with no time dimension and do not indicate
22 what is achievable in utility-sponsored programs.

23 The economic potential for measures passing the RIM and TRC test is
24 shown in Schedule 8 of my exhibit. As previously stated, the energy
25 efficiency measures that comprise the economic potential for each

1 the RIM and the TRC portfolios are listed in Schedule 5 of my exhibit.

2

3 Q. Please identify the projected achievable potential and associated
4 measures for Gulf Power based on the RIM/PT and TRC/PT cost-
5 effectiveness tests for the period 2010 through 2019.

6 A. Itron has provided projections of achievable potential for three scenarios
7 of customer incentive in both the RIM/PT and TRC/PT portfolios of energy
8 efficiency measures. These results represent a subset of the economic
9 potential that could be achieved over the ten year period 2010 through
10 2019 based on a number of factors discussed previously in my testimony.
11 The achievable potential represents a theoretical value based on the
12 supply-curve implementation of measures and does not necessarily reflect
13 the specific measures that may be feasible in the program design phase
14 of this process. The total achievable potential for each of these three
15 individual scenarios is included in Table 1, Schedule 9 of my exhibit.

16 In addition, Itron provided estimates of achievable potential for DR
17 in both a low enrollment and high enrollment scenario. These values are
18 shown in Table 2, Schedule 9 of my exhibit. As stated previously in my
19 testimony, there is no cost-effective achievable potential associated with
20 the PV measures.

21 As referenced earlier, the energy efficiency measure list for the
22 RIM/PT and TRC/PT achievable potential portfolios is provided in
23 Schedule 6 of my exhibit.

24 Gulf Power's proposed goals are the achievable potential results of
25 the RIM high incentive scenario and the high enrollment scenario for DR

1 as reflected in Schedule 1 of my exhibit.

2

3 Q. For Gulf Power, please describe the sensitivity of the economic potential
4 with regard to high and low capital costs for generation, high fuel and CO₂
5 costs, low fuel and CO₂ costs, and no future CO₂ costs.

6 A. Gulf performed five sensitivities of the economic potential for both TRC
7 and RIM passing measures. The sensitivities are (1) high capital cost,
8 (2) low capital cost, (3) low fuel/low CO₂ cost, (4) high fuel/high CO₂ cost,
9 and (5) no CO₂ cost. These sensitivities were accomplished as
10 adjustments to the avoided cost inputs of the cost-effectiveness
11 screening. It is important to recognize that any of these adjustments may
12 have led to different integrated resource plans as starting points for DSM
13 evaluation and, therefore, should not be considered proxies for the
14 achievable potential results. Similarly, the economic potential represented
15 by these sensitivities is by no means based on the same thorough
16 planning process utilized for the base case results. The results of the
17 sensitivities do show, however, that the baseline case Gulf used in this
18 goal setting process is on the higher-end of the ranges represented.

19 Complete details of the economic potential and associated number
20 of passing measures for each sensitivity are included as Schedule 10 of
21 my exhibit.

22

23 Q. For Gulf Power, what are the 2010-2019 annual bill impacts on residential
24 customers using 1,200 kWh/month with no incremental DSM added?

25 A. Gulf Power estimated the bill impacts for no incremental DSM by

1 calculating the costs associated with supplying the amount of energy and
2 demand defined in the proposed goals with the avoided supply-side unit.
3 This is the amount of increased load Gulf would have if the achievable
4 potential for energy efficiency and demand savings was not met through
5 DSM. This approach is analogous to how the benefits of reducing energy
6 and demand through DSM would be calculated.

7 This method, because it produces capacity and energy related
8 costs over a longer period than the ten year horizon of the proposed DSM
9 goals, can better represent cumulative bill impacts as a net present value
10 (NPV) equivalent. In this case, the NPV bill impact is \$180.32 for a
11 residential customer using 1,200 kWh per month. Calculating this bill
12 impact only during the first ten years does not reflect the substantial
13 capacity and energy costs associated with no DSM in future years. For
14 purposes of comparison, however, the calculated bill impact for each year
15 2010 through 2019 of this no DSM scenario is presented in Schedule 11
16 of my exhibit.

17
18 Q. For Gulf Power, what are the 2010-2019 annual bill impacts on residential
19 customers using 1,200 kWh/month for the projected TRC achievable
20 portfolio, the projected RIM achievable portfolio, and the Company's
21 proposed DSM goals?

22 A. The annual bill impacts for the RIM and TRC achievable portfolios as well
23 as Gulf's proposed goals are calculated by utilizing Itron's estimates of the
24 total costs of achieving the maximum energy and demand savings in each
25 of the RIM and TRC portfolios. Unlike the costs associated with the no

1 DSM case, the costs associated with achieving these energy and demand
2 reductions will conclude at the end of the ten year period 2010 through
3 2019.

4 For comparison to the no DSM estimate of \$180.32, these values
5 can also be represented in a NPV form as \$152.35 for the RIM portfolio
6 and \$282.50 for the TRC portfolio. Since Gulf's proposed goals are
7 equivalent to the RIM portfolio, this calculation demonstrates the bill
8 impact for achievement of these goals is less than the bill impact for no
9 incremental DSM. The annual bill impacts associated with achieving the
10 maximum energy and demand savings in the RIM and TRC portfolios is
11 provided in Schedule 11 of my exhibit.

12
13 **Section 5: Conclusions**

14 Q. How much DSM is reasonably achievable during the 2010-2019 period for
15 Gulf Power?

16 A. Based on Gulf's planning process and the results of Itron's achievable
17 potential projections for energy efficiency and demand response, a
18 cumulative annual total of 159 GWh energy reduction, 69 MW summer
19 peak demand reduction, and 46 MW winter peak demand reduction is
20 reasonably achievable for the period 2010 through 2019. Therefore, Gulf
21 Power is proposing these annual energy and seasonal peak demand
22 reductions as goals for the period 2010 through 2019 as shown in
23 Schedule 1 of my exhibit.

24
25 Q. Has Gulf Power used a sound and reasonable process consistent with

1 Florida's statutory and rule-based requirements to determine its 2010
2 through 2019 DSM goals?

3 A. Yes. Gulf Power has proposed goals based on a full assessment of
4 technical, economic, and achievable potential for demand-side
5 conservation and efficiency measures, including demand-side renewable
6 energy systems in a manner consistent with requirements of section
7 366.82(3), Florida Statutes, and FPSC Rule 25-17.0021.

8

9 Q. Should Gulf Power's proposed 2010-2019 DSM goals be approved?

10 A. Yes.

11

12 Q. Does this conclude your testimony?


13 A. Yes.

AFFIDAVIT

STATE OF FLORIDA)
)
COUNTY OF ESCAMBIA)


Docket No. 080410-EG


Before me the undersigned authority, personally appeared John N. Floyd, who being first duly sworn, deposes, and says that he is the Economic Evaluation and Market Reporting Team Leader in the Marketing Services Department at Gulf Power Company, a Florida corporation, that the foregoing is true and correct to the best of his knowledge, information, and belief. He is personally known to me.



John N. Floyd
Economic Evaluation and Market Reporting
Team Leader

Sworn to and subscribed before me this 29th day of May,
2009.



Notary Public, State of Florida at Large

Proposed Numeric Conservation Goals -- Savings at the Generator

	2010	2011	2012	2013	2014	2015	2016	2017	2018	2019
Residential										
Annual Energy (GWh)	2.0	6.0	12.3	20.5	30.3	41.3	53.2	65.3	76.5	86.8
Summer System Peak (MW)	1.9	4.7	8.4	12.9	18.0	23.7	29.8	35.9	41.6	47.0
Winter System Peak (MW)	1.8	4.3	7.4	11.1	15.4	20.0	25.0	30.0	34.7	39.2
Commercial/Industrial										
Annual Energy (GWh)	2.7	7.3	13.4	20.7	28.7	37.2	46.1	55.1	63.9	72.2
Summer System Peak (MW)	1.2	2.8	4.7	6.9	9.3	11.8	14.4	17.0	19.5	21.9
Winter System Peak (MW)	0.5	1.0	1.6	2.3	3.0	3.8	4.6	5.4	6.2	7.0
Total										
Annual Energy (GWh)	4.7	13.4	25.7	41.2	59.0	78.5	99.3	120.4	140.4	159.0
Summer System Peak (MW)	3.1	7.4	13.1	19.8	27.4	35.5	44.2	52.8	61.1	68.9
Winter System Peak (MW)	2.3	5.3	9.0	13.4	18.4	23.8	29.6	35.4	40.9	46.2

1

Florida Public Service Commission
 Docket No. 080410-EG
 Gulf Power Company
 Witness: John N. Floyd
 Exhibit No. _____ (JNF-1)
 Schedule 1
 Page 1 of 1

GULF POWER COMPANY
Comparison of Current Goals and Proposed Goals
At the Generator

Residential Annual Energy Reduction (GWh)						Residential Summer Peak Reduction (MW)						Residential Winter Peak Reduction (MW)					
Year	Current	Proposed	Difference	% change		Year	Current	Proposed	Difference	% change		Year	Current	Proposed	Difference	% change	
2010	2.7	2.0	(0.7)	-26%		2010	7.2	1.9	(5.3)	-73%		2010	8.8	1.8	(7.0)	-79%	
2011	5.4	6.0	0.6	12%		2011	14.4	4.7	(9.7)	-68%		2011	17.5	4.3	(13.2)	-76%	
2012	8.1	12.3	4.2	52%		2012	21.6	8.4	(13.2)	-61%		2012	26.3	7.4	(18.9)	-72%	
2013	10.8	20.5	9.7	90%		2013	28.7	12.9	(15.8)	-55%		2013	35.0	11.1	(23.9)	-68%	
2014	13.5	30.3	16.8	124%		2014	35.9	18.0	(17.9)	-50%		2014	43.7	15.4	(28.3)	-65%	

Commercial/Industrial Annual Energy Reduction (GWh)						Commercial/Industrial Summer Peak Reduction (MW)						Commercial/Industrial Winter Peak Reduction (MW)					
Year	Current	Proposed	Difference	% change		Year	Current	Proposed	Difference	% change		Year	Current	Proposed	Difference	% change	
2010	2.6	2.7	0.1	5%		2010	1.1	1.2	0.1	6%		2010	0.3	0.5	0.2	50%	
2011	5.2	7.3	2.1	41%		2011	2.2	2.8	0.6	26%		2011	0.7	1.0	0.3	42%	
2012	7.8	13.4	5.6	72%		2012	3.3	4.7	1.4	43%		2012	1.0	1.6	0.6	61%	
2013	10.4	20.7	10.3	99%		2013	4.4	6.9	2.5	58%		2013	1.4	2.3	0.9	64%	
2014	13.0	28.7	15.7	121%		2014	5.5	9.3	3.8	70%		2014	1.7	3.0	1.3	79%	

Total Annual Energy Reduction (GWh)						Total Summer Peak Reduction (MW)						Total Winter Peak Reduction (MW)					
Year	Current	Proposed	Difference	% change		Year	Current	Proposed	Difference	% change		Year	Current	Proposed	Difference	% change	
2010	5.3	4.7	(0.6)	-11%		2010	8.3	3.1	(5.2)	-63%		2010	9.1	2.3	(6.8)	-75%	
2011	10.6	13.4	2.8	26%		2011	16.6	7.4	(9.2)	-55%		2011	18.2	5.3	(12.9)	-71%	
2012	15.9	25.7	9.8	62%		2012	24.9	13.1	(11.8)	-47%		2012	27.3	9.0	(18.3)	-67%	
2013	21.2	41.2	20.0	94%		2013	33.1	19.8	(13.3)	-40%		2013	36.4	13.4	(23.0)	-63%	
2014	26.5	59.0	32.5	123%		2014	41.4	27.4	(14.0)	-34%		2014	45.4	18.4	(27.0)	-59%	

2

**Comparison of Achieved kW and kWh Reductions
With Public Service Commission Established Goals
At the Generator**

Residential									
	GWh Energy Reduction			Summer Peak MW Reduction			Winter Peak MW Reduction		
	Total	Com. Appr.	%	Total	Com. Appr.	%	Total	Com. Appr.	%
	Achieved	Goal	Variance	Achieved	Goal	Variance	Achieved	Goal	Variance
2005	3.48	3.4	2%	3.94	7.8	-49%	4.62	9.5	-51%
2006	4.84	6.7	-28%	6.19	15.5	-60%	7.76	19.0	-59%
2007	6.26	10.1	-38%	8.96	23.3	-62%	11.11	28.5	-61%
2008	6.43	13.4	-52%	8.87	31.0	-71%	10.89	38.0	-71%
2009		16.8			38.8			47.4	
2010		19.5			46.0			56.2	
2011		22.2			53.2			64.9	
2012		24.9			60.4			73.7	
2013		27.6			67.5			82.4	
2014		30.3			74.7			91.1	
Commercial/Industrial									
	GWh Energy Reduction			Summer Peak MW Reduction			Winter Peak MW Reduction		
	Total	Com. Appr.	%	Total	Com. Appr.	%	Total	Com. Appr.	%
	Achieved	Goal	Variance	Achieved	Goal	Variance	Achieved	Goal	Variance
2005	15.79	2.3	587%	14.78	14.1	5%	7.52	6.9	9%
2006	18.46	4.5	310%	23.86	22.9	4%	11.93	11.1	18%
2007	22.12	7.1	212%	30.16	29.3	3%	15.41	14.1	9%
2008	24.32	9.7	151%	31.10	30.4	2%	15.72	14.4	9%
2009		12.3			31.5			14.8	
2010		14.9			32.6			15.1	
2011		17.5			33.7			15.5	
2012		20.1			34.8			15.8	
2013		22.7			35.9			16.2	
2014		25.3			37.0			16.5	
Total									
	GWh Energy Reduction			Summer Peak MW Reduction			Winter Peak MW Reduction		
	Total	Com. Appr.	%	Total	Com. Appr.	%	Total	Com. Appr.	%
	Achieved	Goal	Variance	Achieved	Goal	Variance	Achieved	Goal	Variance
2005	19.27	5.70	238%	18.72	21.90	-15%	12.14	16.40	-26%
2006	23.30	11.20	108%	30.05	38.40	-22%	19.69	30.10	-35%
2007	28.38	17.20	65%	39.12	52.60	-26%	26.52	42.60	-38%
2008	30.75	23.10	33%	39.97	61.40	-35%	26.61	52.40	-49%
2009		29.10			70.30			62.20	
2010		34.40			78.60			71.30	
2011		39.70			86.90			80.40	
2012		45.00			95.20			89.50	
2013		50.30			103.40			98.60	
2014		55.60			111.70			107.60	

Technical Potential Measure List

Residential Energy Efficiency

- 1 13 EER Geothermal Heat Pump
- 2 14 SEER Split-System Air Conditioner
- 3 14 SEER Split-System Heat Pump
- 4 15 SEER Split-System Air Conditioner
- 5 15 SEER Split-System Heat Pump
- 6 17 SEER Split-System Air Conditioner
- 7 17 SEER Split-System Heat Pump
- 8 19 SEER Split-System Air Conditioner
- 9 AC Heat Recovery Units
- 10 AC Maintenance (Indoor Coil Cleaning)
- 11 AC Maintenance (Outdoor Coil Cleaning)
- 12 Attic Venting
- 13 Ceiling R-0 to R-19 Insulation
- 14 Ceiling R-19 to R-38 Insulation
- 15 CFL (18-Watt integral ballast)
- 16 Default Window With Sunscreen
- 17 Double Pane Clear Windows to Double Pane Low-E Windows
- 18 Duct Repair
- 19 Electronically Commutated Motors (ECM) on an Air Handler Unit
- 20 Energy Star CW CEE Tier 1 (MEF=1.8)
- 21 Energy Star CW CEE Tier 2 (MEF=2.0)
- 22 Energy Star CW CEE Tier 3 (MEF=2.2)
- 23 Energy Star Desktop PC
- 24 Energy Star DVD Player
- 25 Energy Star DW (EF=0.68)
- 26 Energy Star Laptop PC
- 27 Energy Star Set-Top Box
- 28 Energy Star TV
- 29 Energy Star TV
- 30 Energy Star VCR
- 31 Faucet Aerators
- 32 HE Freezer
- 33 HE Refrigerator - Energy Star version of above
- 34 HE Room Air Conditioner - EER 11
- 35 HE Room Air Conditioner - EER 12
- 36 HE Water Heater (EF=0.93)
- 37 Heat Pump Water Heater (EF=2.9)
- 38 Heat Trap
- 39 High Efficiency CD (EF=3.01 w/moisture sensor)
- 40 High Efficiency One Speed Pool Pump (1.5 hp)
- 41 HVAC Proper Sizing
- 42 Low Flow Showerhead
- 43 Photocell/timerclock
- 44 Pipe Wrap
- 45 Premium T8, Electronic Ballast
- 46 Proper Refrigerant Charging and Air Flow
- 47 PV-Powered Pool Pumps

4

Technical Potential Measure List

- 48 Radiant Barrier
- 49 Reflective Roof
- 50 Sealed Attic w/Sprayed Foam Insulated Roof Deck
- 51 Single Pane Clear Windows to Double Pane Low-E Windows
- 52 Solar Water Heat
- 53 Two Speed Pool Pump (1.5 hp)
- 54 Variable-Speed Pool Pump (<1 hp)
- 55 Wall 2x4 R-0 to Blow-In R-13 Insulation
- 56 Water Heater Blanket
- 57 Water Heater Temperature Check and Adjustment
- 58 Water Heater Timeclock
- 59 Weather Strip/Caulk w/Blower Door
- 60 Window Film
- 61 Window Tinting

Commercial Energy Efficiency

- 1 Aerosole Duct Sealing
- 2 Air Handler Optimization
- 3 Anti-sweat (humidistat) controls
- 4 Ceiling Insulation
- 5 Centrifugal Chiller, 0.51 kW/ton, 500 tons
- 6 CFL Hardwired, Modular 18W
- 7 CFL Screw-in 18W
- 8 Chiller Tune Up/Diagnostics
- 9 Compressor VSD retrofit
- 10 Continuous Dimming
- 11 Convection Oven
- 12 Cool Roof
- 13 Copier Power Management Enabling
- 14 CRT Monitor Power Management Enabling
- 15 Demand Control Ventilation (DCV)
- 16 Demand controlled circulating systems
- 17 Demand Defrost Electric
- 18 Demand Hot Gas Defrost
- 19 Duct/Pipe Insulation
- 20 DX Coil Cleaning
- 21 DX Packaged System, EER=10.9, 10 tons
- 22 DX Tune Up/ Advanced Diagnostics
- 23 Efficient compressor motor
- 24 Efficient Fryer
- 25 Electronically Commutated Motors (ECM) on an Air Handler Unit
- 26 EMS - Chiller
- 27 EMS Optimization
- 28 Energy Recovery Ventilation (ERV)
- 29 Energy Star or Better Copier
- 30 Energy Star or Better CRT Monitor
- 31 Energy Star or Better LCD Monitor
- 32 Evaporator fan controller for MT walk-ins
- 33 Floating head pressure controls

5

Technical Potential Measure List

- 34 Freezer-Cooler Replacement Gaskets
- 35 Geothermal Heat Pump, EER=13, 10 tons
- 36 Geothermal Heat Pump, EER=13, 10 tons
- 37 HE PTAC, EER=9.6, 1 ton
- 38 Heat Pump Water Heater (air source)
- 39 Heat Recovery Unit
- 40 Heat Trap
- 41 High Bay T5
- 42 High Efficiency Chiller Motors
- 43 High Efficiency Fan Motor, 15hp, 1800rpm, 92.4%
- 44 High Efficiency Water Heater (electric)
- 45 High Pressure Sodium 250W Lamp
- 46 High R-Value Glass Doors
- 47 High-efficiency fan motors
- 48 Hot Water Pipe Insulation
- 49 Hybrid Dessicant-DX System (Trane CDQ)
- 50 LCD Monitor Power Management Enabling
- 51 LED Display Lighting
- 52 LED Exit Sign
- 53 Lighting Control Tuneup
- 54 Multiplex Compressor System
- 55 Night covers for display cases
- 56 Occupancy Sensor
- 57 Occupancy Sensor (hotels)
- 58 Optimize Controls
- 59 Outdoor Lighting Controls (Photocell/Timeclock)
- 60 Oversized Air Cooled Condenser
- 61 Packaged HP System, EER=10.9, 10 tons
- 62 PC Manual Power Management Enabling
- 63 PC Network Power Management Enabling
- 64 Premium T8, Electronic Ballast
- 65 Premium T8, EB, Reflector
- 66 Printer Power Management Enabling
- 67 PSMH, 250 W, electronic ballast
- 68 PSMH, 250W, magnetic ballast
- 69 Refrigeration Commissioning
- 70 Roof Insulation
- 71 Separate Makeup Air / Exhaust Hoods AC
- 72 Solar Water Heater
- 73 Strip curtains for walk-ins
- 74 Thermal Energy Storage (TES)
- 75 Variable Speed Drive Control
- 76 Vending Misers (cooled machines only)
- 77 VSD for Chiller Pumps and Towers
- 78 Window Film (Standard)

6

Technical Potential Measure List

- Industrial Energy Efficiency**
- 1 Aerosole Duct Sealing - Chiller
 - 2 Air conveying systems
 - 3 Bakery - Process
 - 4 Bakery - Process (Mixing) - O&M
 - 5 Centrifugal Chiller, 0.51 kW/ton, 500 tons
 - 6 CFL Hardwired, Modular 18W
 - 7 CFL Screw-in 18W
 - 8 Chiller Tune Up/Diagnostics
 - 9 Clean Room - Controls
 - 10 Clean Room - New Designs
 - 11 Comp Air - ASD (100+ hp)
 - 12 Comp Air - ASD (1-5 hp)
 - 13 Comp Air - ASD (6-100 hp)
 - 14 Comp Air - Motor practices-1 (100+ HP)
 - 15 Comp Air - Motor practices-1 (1-5 HP)
 - 16 Comp Air - Motor practices-1 (6-100 HP)
 - 17 Comp Air - Replace 100+ HP motor
 - 18 Comp Air - Replace 1-5 HP motor
 - 19 Comp Air - Replace 6-100 HP motor
 - 20 Compressed Air - Controls
 - 21 Compressed Air - System Optimization
 - 22 Compressed Air- Sizing
 - 23 Compressed Air-O&M
 - 24 Cool Roof - Chiller
 - 25 Direct drive Extruders
 - 26 Drives - EE motor
 - 27 Drives - Optimization process (M&T)
 - 28 Drives - Process Control
 - 29 Drives - Process Controls (batch + site)
 - 30 Drives - Scheduling
 - 31 Drying (UV/IR)
 - 32 Duct/Pipe Insulation - Chiller
 - 33 DX Coil Cleaning
 - 34 DX Packaged System, EER=10.9, 10 tons
 - 35 DX Tune Up/ Advanced Diagnostics
 - 36 Efficient Curing ovens
 - 37 Efficient desalter
 - 38 Efficient drives
 - 39 Efficient drives - rolling
 - 40 Efficient electric melting
 - 41 Efficient grinding
 - 42 Efficient Machinery
 - 43 Efficient practices printing press
 - 44 Efficient Printing press (fewer cylinders)
 - 45 Efficient processes (welding, etc.)
 - 46 Efficient Refrigeration - Operations
 - 47 EMS - Chiller
 - 48 EMS Optimization - Chiller

Technical Potential Measure List

- 49 Extruders/injection Moulding-multipump
- 50 Fans - ASD (100+ hp)
- 51 Fans - ASD (1-5 hp)
- 52 Fans - ASD (6-100 hp)
- 53 Fans - Controls
- 54 Fans - Motor practices-1 (100+ HP)
- 55 Fans - Motor practices-1 (1-5 HP)
- 56 Fans - Motor practices-1 (6-100 HP)
- 57 Fans - O&M
- 58 Fans - Replace 100+ HP motor
- 59 Fans - Replace 1-5 HP motor
- 60 Fans - Replace 6-100 HP motor
- 61 Fans - System Optimization
- 62 Fans- Improve components
- 63 Gap Forming papermachine
- 64 Geothermal Heat Pump, EER=13, 10 tons
- 65 Heat Pumps - Drying
- 66 Heating - Optimization process (M&T)
- 67 Heating - Process Control
- 68 Heating - Scheduling
- 69 High Bay T5
- 70 High Consistency forming
- 71 High Efficiency Chiller Motors
- 72 Hybrid Dessicant-DX System (Trane CDQ)
- 73 Injection Moulding - Direct drive
- 74 Injection Moulding - Impulse Cooling
- 75 Intelligent extruder (DOE)
- 76 Light cylinders
- 77 Low Pressure Nozzle
- 78 Machinery
- 79 Membranes for wastewater
- 80 Micro Watering System
- 81 Near Net Shape Casting
- 82 New transformers welding
- 83 O&M - Extruders/Injection Moulding
- 84 O&M/drives spinning machines
- 85 Occupancy Sensor
- 86 Optimization control PM
- 87 Optimization Refrigeration
- 88 Optimize Controls
- 89 Optimize drying process
- 90 Other Process Controls (batch + site)
- 91 Power recovery
- 92 Premium T8, Electronic Ballast
- 93 Process control
- 94 Process control
- 95 Process Drives - ASD
- 96 Process optimization
- 97 Pump Retrofit - Irrigation

8

Technical Potential Measure List

- 98 Pumps - ASD (100+ hp)
- 99 Pumps - ASD (1-5 hp)
- 100 Pumps - ASD (6-100 hp)
- 101 Pumps - Controls
- 102 Pumps - Motor practices-1 (100+ HP)
- 103 Pumps - Motor practices-1 (1-5 HP)
- 104 Pumps - Motor practices-1 (6-100 HP)
- 105 Pumps - O&M
- 106 Pumps - Replace 100+ HP motor
- 107 Pumps - Replace 1-5 HP motor
- 108 Pumps - Replace 6-100 HP motor
- 109 Pumps - Sizing
- 110 Pumps - System Optimization
- 111 Refinery Controls
- 112 Replace V-Belts
- 113 Replace V-belts
- 114 Roof Insulation - Chiller
- 115 Thermal Energy Storage (TES) - Chiller
- 116 Top-heating (glass)
- 117 VSD for Chiller Pumps and Towers
- 118 Window Film (Standard) - Chiller

Residential Demand Response

- 1 In home display with peak threshold warning system and pre-set control strategies
- 2 On-Off Switching via low-power wireless communication technology
- 3 Smart Thermostats
- 4 Switch - Cycling Program
- 5 Switch - Shedding Program

Commercial/Industrial Demand Response

- 1 Automated control strategies
- 2 Direct load control system

Residential PhotoVoltaic

- 1 Rooftop solar PV

Commercial PhotoVoltaic

- 1 PV Mounted on Commercial Parking Lot Shade Structures
- 2 Rooftop solar PV

Economic Potential Measure List

RIM Portfolio

Residential Energy Efficiency

- 1 14 SEER Split-System Air Conditioner
- 2 14 SEER Split-System Heat Pump
- 3 15 SEER Split-System Air Conditioner
- 4 15 SEER Split-System Heat Pump
- 5 17 SEER Split-System Air Conditioner
- 6 17 SEER Split-System Heat Pump
- 7 19 SEER Split-System Air Conditioner
- 8 AC Heat Recovery Units
- 9 AC Maintenance (Indoor Coil Cleaning)
- 10 AC Maintenance (Outdoor Coil Cleaning)
- 11 Ceiling R-0 to R-19 Insulation
- 12 Ceiling R-19 to R-38 Insulation
- 13 CFL (18-Watt integral ballast), 0.5 hr/day
- 14 CFL (18-Watt integral ballast), 2.5 hr/day
- 15 CFL (18-Watt integral ballast), 6.0 hr/day
- 16 Default Window With Sunscreen
- 17 Double Pane Clear Windows to Double Pane Low-E Windows
- 18 Duct Repair
- 19 Electronically Commutated Motors (ECM) on an Air Handler Unit
- 20 Energy Star CW CEE Tier 2 (MEF=2.0)
- 21 Energy Star CW CEE Tier 3 (MEF=2.2)
- 22 Energy Star Desktop PC
- 23 Energy Star DVD Player
- 24 Energy Star DW (EF=0.68)
- 25 Energy Star Laptop PC
- 26 Energy Star Set-Top Box
- 27 Energy Star TV
- 28 Energy Star VCR
- 29 Faucet Aerators
- 30 HE Freezer
- 31 HE Refrigerator - Energy Star version of above
- 32 HE Room Air Conditioner - EER 11
- 33 HE Room Air Conditioner - EER 12
- 34 Heat Pump Water Heater (EF=2.9)
- 35 Heat Trap
- 36 High Efficiency CD (EF=3.01 w/moisture sensor)
- 37 High Efficiency One Speed Pool Pump (1.5 hp)
- 38 HVAC Proper Sizing
- 39 HVAC Proper Sizing
- 40 Low Flow Showerhead
- 41 Pipe Wrap

TRC Portfolio

Residential Energy Efficiency

- 14 SEER Split-System Air Conditioner
- AC Heat Recovery Units
- AC Maintenance (Indoor Coil Cleaning)
- AC Maintenance (Outdoor Coil Cleaning)
- Ceiling R-0 to R-19 Insulation
- CFL (18-Watt integral ballast), 0.5 hr/day
- CFL (18-Watt integral ballast), 2.5 hr/day
- CFL (18-Watt integral ballast), 6.0 hr/day
- Default Window With Sunscreen
- Double Pane Clear Windows to Double Pane Low-E Windows
- Duct Repair
- Electronically Commutated Motors (ECM) on an Air Handler Unit
- Energy Star CW CEE Tier 2 (MEF=2.0)
- Energy Star Desktop PC
- Energy Star DVD Player
- Energy Star DW (EF=0.68)
- Energy Star Laptop PC
- Energy Star Set-Top Box
- Energy Star TV
- Energy Star VCR
- Faucet Aerators
- HE Freezer
- HE Refrigerator - Energy Star version of above
- HE Room Air Conditioner - EER 11
- Heat Pump Water Heater (EF=2.9)
- Heat Trap
- High Efficiency CD (EF=3.01 w/moisture sensor)
- High Efficiency One Speed Pool Pump (1.5 hp)
- HVAC Proper Sizing
- HVAC Proper Sizing
- Low Flow Showerhead
- Pipe Wrap
- Proper Refrigerant Charging and Air Flow
- Reflective Roof
- RET 2L4T8, 1EB
- ROB 2L4T8, 1EB
- Two Speed Pool Pump (1.5 hp)
- Variable-Speed Pool Pump (<1 hp)
- Water Heater Blanket
- Water Heater Temperature Check and Adjustment
- Water Heater Timeclock

Economic Potential Measure List

- 42 Proper Refrigerant Charging and Air Flow
- 43 PV-Powered Pool Pumps
- 44 Radiant Barrier
- 45 Reflective Roof
- 46 RET 2L4'T8, 1EB
- 47 ROB 2L4'T8, 1EB
- 48 Sealed Attic w/Sprayed Foam Insulated Roof Deck
- 49 Sealed Attics
- 50 Solar Water Heat
- 51 Two Speed Pool Pump (1.5 hp)
- 52 Variable-Speed Pool Pump (<1 hp)
- 53 Wall 2x4 R-0 to Blow-In R-13 Insulation
- 54 Water Heater Blanket
- 55 Water Heater Temperature Check and Adjustment
- 56 Water Heater Timeclock
- 57 Window Film
- 58 Window Tinting

RIM Portfolio

Commercial Energy Efficiency

- 1 Aerosole Duct Sealing
- 2 Air Handler Optimization
- 3 Anti-sweat (humidistat) controls
- 4 Ceiling Insulation
- 5 Centrifugal Chiller, 0.51 kW/ton, 500 tons
- 6 CFL Hardwired, Modular 18W
- 7 CFL Screw-in 18W
- 8 Chiller Tune Up/Diagnostics
- 9 Compressor VSD retrofit
- 10 Continuous Dimming
- 11 Convection Oven
- 12 Cool Roof - Chiller
- 13 Cool Roof - DX
- 14 Copier Power Management Enabling
- 15 Demand Control Ventilation (DCV)
- 16 Demand controlled circulating systems
- 17 Demand Defrost Electric
- 18 Demand Hot Gas Defrost
- 19 Duct/Pipe Insulation
- 20 DX Coil Cleaning
- 21 DX Packaged System, EER=10.9, 10 tons
- 22 DX Tune Up/ Advanced Diagnostics
- 23 Efficient compressor motor
- 24 Efficient Fryer
- 25 Electronically Commutated Motors (ECM) on an Air Handler Unit
- 26 EMS - Chiller

- Weather Strip/Caulk w/Blower Door
- Window Film
- Window Tinting

TRC Portfolio

Commercial Energy Efficiency

- Aerosole Duct Sealing
- Air Handler Optimization
- Anti-sweat (humidistat) controls
- Ceiling Insulation
- Centrifugal Chiller, 0.51 kW/ton, 500 tons
- CFL Hardwired, Modular 18W
- CFL Screw-in 18W
- Chiller Tune Up/Diagnostics
- Compressor VSD retrofit
- Continuous Dimming
- Cool Roof - Chiller
- Cool Roof - DX
- Copier Power Management Enabling
- Demand controlled circulating systems
- Demand Defrost Electric
- Demand Hot Gas Defrost
- DX Coil Cleaning
- DX Packaged System, EER=10.9, 10 tons
- DX Tune Up/ Advanced Diagnostics
- Efficient compressor motor
- Electronically Commutated Motors (ECM) on an Air Handler Unit
- EMS - Chiller
- EMS Optimization
- Energy Recovery Ventilation (ERV)
- Energy Star or Better Copier
- Energy Star or Better Monitor

Economic Potential Measure List

- 27 EMS Optimization
- 28 Energy Recovery Ventilation (ERV)
- 29 Energy Star or Better Copier
- 30 Energy Star or Better Monitor
- 31 Evaporator fan controller for MT walk-ins
- 32 Floating head pressure controls
- 33 Freezer-Cooler Replacement Gaskets
- 34 Geothermal Heat Pump, EER=13, 10 tons
- 35 HE PTAC, EER=9.6, 1 ton
- 36 Heat Pump Water Heater (air source)
- 37 Heat Recovery Unit
- 38 Heat Trap
- 39 High Bay T5
- 40 High Efficiency Chiller Motors
- 41 High Efficiency Fan Motor, 15hp, 1800rpm, 92.4%
- 42 High Efficiency Water Heater (electric)
- 43 High Pressure Sodium 250W Lamp
- 44 High R-Value Glass Doors
- 45 High-efficiency fan motors
- 46 Hot Water Pipe Insulation
- 47 Hybrid Dessicant-DX System (Trane CDQ)
- 48 LED Display Lighting
- 49 LED Exit Sign
- 50 Lighting Control Tuneup
- 51 Lighting Control Tuneup
- 52 Monitor Power Management Enabling
- 53 Multiplex Compressor System
- 54 Night covers for display cases
- 55 Occupancy Sensor
- 56 Occupancy Sensor (hotels)
- 57 Optimize Controls
- 58 Outdoor Lighting Controls (Photocell/Timeclock)
- 59 Oversized Air Cooled Condenser
- 60 Packaged HP System, EER=10.9, 10 tons
- 61 PC Manual Power Management Enabling
- 62 PC Network Power Management Enabling
- 63 Premium T8, EB, Reflector
- 64 Premium T8, Electronic Ballast
- 65 Printer Power Management Enabling
- 66 PSMH, 250W, magnetic ballast
- 67 Refrigeration Commissioning
- 68 ROB Premium T8, 1EB

- Evaporator fan controller for MT walk-ins
- Floating head pressure controls
- Freezer-Cooler Replacement Gaskets
- Geothermal Heat Pump, EER=13, 10 tons
- HE PTAC, EER=9.6, 1 ton
- Heat Pump Water Heater (air source)
- Heat Recovery Unit
- Heat Trap
- High Bay T5
- High Efficiency Chiller Motors
- High Efficiency Fan Motor, 15hp, 1800rpm, 92.4%
- High Efficiency Water Heater (electric)
- High Pressure Sodium 250W Lamp
- High R-Value Glass Doors
- High-efficiency fan motors
- Hot Water Pipe Insulation
- Hybrid Dessicant-DX System (Trane CDQ)
- LED Display Lighting
- LED Exit Sign
- Lighting Control Tuneup
- Lighting Control Tuneup
- Monitor Power Management Enabling
- Multiplex Compressor System
- Night covers for display cases
- Occupancy Sensor
- Occupancy Sensor (hotels)
- Optimize Controls
- Outdoor Lighting Controls (Photocell/Timeclock)
- Oversized Air Cooled Condenser
- PC Manual Power Management Enabling
- PC Network Power Management Enabling
- Premium T8, EB, Reflector
- Premium T8, Electronic Ballast
- Printer Power Management Enabling
- PSMH, 250W, magnetic ballast
- Refrigeration Commissioning
- ROB Premium T8, 1EB
- ROB Premium T8, EB, Reflector
- Roof Insulation
- Separate Makeup Air / Exhaust Hoods AC
- Strip curtains for walk-ins
- Thermal Energy Storage (TES)

Economic Potential Measure List

- 69 ROB Premium T8, EB, Reflector
- 70 Roof Insulation
- 71 Separate Makeup Air / Exhaust Hoods AC
- 72 Solar Water Heater
- 73 Strip curtains for walk-ins
- 74 Thermal Energy Storage (TES)
- 75 Variable Speed Drive Control
- 76 Vending Misers (cooled machines only)
- 77 VSD for Chiller Pumps and Towers
- 78 Window Film (Standard)

RIM Portfolio

Industrial Energy Efficiency

- 1 Aerosole Duct Sealing
- 2 Aerosole Duct Sealing - Chiller
- 3 Air conveying systems
- 4 Bakery - Process
- 5 Bakery - Process (Mixing) - O&M
- 6 Centrifugal Chiller, 0.51 kW/ton, 500 tons
- 7 CFL Hardwired, Modular 18W
- 8 CFL Screw-in 18W
- 9 Chiller Tune Up/Diagnostics
- 10 Clean Room - Controls
- 11 Clean Room - New Designs
- 12 Comp Air - ASD (100+ hp)
- 13 Comp Air - ASD (1-5 hp)
- 14 Comp Air - ASD (6-100 hp)
- 15 Comp Air - Motor practices-1 (100+ HP)
- 16 Comp Air - Motor practices-1 (1-5 HP)
- 17 Comp Air - Motor practices-1 (6-100 HP)
- 18 Comp Air - Replace 100+ HP motor
- 19 Comp Air - Replace 1-5 HP motor
- 20 Comp Air - Replace 6-100 HP motor
- 21 Compressed Air - Controls
- 22 Compressed Air - System Optimization
- 23 Compressed Air- Sizing
- 24 Compressed Air-O&M
- 25 Cool Roof - Chiller
- 26 Cool Roof - DX
- 27 Direct drive Extruders
- 28 Drives - EE motor
- 29 Drives - Optimization process (M&T)
- 30 Drives - Process Control
- 31 Drives - Process Controls (batch + site)

- Variable Speed Drive Control
- Vending Misers (cooled machines only)
- VSD for Chiller Pumps and Towers
- Window Film (Standard)

TRC Portfolio

Industrial Energy Efficiency

- Aerosole Duct Sealing
- Aerosole Duct Sealing - Chiller
- Air conveying systems
- Bakery - Process
- Bakery - Process (Mixing) - O&M
- Centrifugal Chiller, 0.51 kW/ton, 500 tons
- CFL Hardwired, Modular 18W
- CFL Screw-in 18W
- Chiller Tune Up/Diagnostics
- Clean Room - Controls
- Clean Room - New Designs
- Comp Air - ASD (100+ hp)
- Comp Air - ASD (6-100 hp)
- Comp Air - ASD (6-100 hp)
- Comp Air - Motor practices-1 (100+ HP)
- Comp Air - Motor practices-1 (1-5 HP)
- Comp Air - Motor practices-1 (6-100 HP)
- Comp Air - Replace 100+ HP motor
- Comp Air - Replace 6-100 HP motor
- Compressed Air - Controls
- Compressed Air - System Optimization
- Compressed Air- Sizing
- Compressed Air-O&M
- Cool Roof - Chiller
- Cool Roof - DX
- Direct drive Extruders
- Drives - EE motor
- Drives - Optimization process (M&T)
- Drives - Process Control
- Drives - Process Controls (batch + site)
- Drives - Scheduling

Economic Potential Measure List

- 32 Drives - Scheduling
- 33 Drying (UV/IR)
- 34 Duct/Pipe Insulation
- 35 Duct/Pipe Insulation - Chiller
- 36 DX Coil Cleaning
- 37 DX Packaged System, EER=10.9, 10 tons
- 38 DX Tune Up/ Advanced Diagnostics
- 39 Efficient Curing ovens
- 40 Efficient desalter
- 41 Efficient drives
- 42 Efficient drives - rolling
- 43 Efficient electric melting
- 44 Efficient grinding
- 45 Efficient Machinery
- 46 Efficient practices printing press
- 47 Efficient Printing press (fewer cylinders)
- 48 Efficient processes (welding, etc.)
- 49 Efficient Refrigeration - Operations
- 50 EMS - Chiller
- 51 EMS Optimization - Chiller
- 52 Extruders/injection Moulding-multipump
- 53 Fans - ASD (100+ hp)
- 54 Fans - ASD (1-5 hp)
- 55 Fans - ASD (6-100 hp)
- 56 Fans - Controls
- 57 Fans - Motor practices-1 (100+ HP)
- 58 Fans - Motor practices-1 (1-5 HP)
- 59 Fans - Motor practices-1 (6-100 HP)
- 60 Fans - O&M
- 61 Fans - Replace 100+ HP motor
- 62 Fans - Replace 1-5 HP motor
- 63 Fans - Replace 6-100 HP motor
- 64 Fans - System Optimization
- 65 Fans- Improve components
- 66 Gap Forming papermachine
- 67 Geothermal Heat Pump, EER=13, 10 tons
- 68 Heat Pumps - Drying
- 69 Heating - Optimization process (M&T)
- 70 Heating - Process Control
- 71 Heating - Scheduling
- 72 High Bay T5
- 73 High Consistency forming
- 74 High Efficiency Chiller Motors
- 75 Hybrid Dessicant-DX System (Trane CDQ)

- Drying (UV/IR)
- DX Coil Cleaning
- DX Packaged System, EER=10.9, 10 tons
- DX Tune Up/ Advanced Diagnostics
- Efficient Curing ovens
- Efficient desalter
- Efficient drives
- Efficient drives - rolling
- Efficient electric melting
- Efficient grinding
- Efficient Machinery
- Efficient practices printing press
- Efficient Printing press (fewer cylinders)
- Efficient processes (welding, etc.)
- Efficient Refrigeration - Operations
- EMS - Chiller
- EMS Optimization - Chiller
- Extruders/injection Moulding-multipump
- Fans - ASD (100+ hp)
- Fans - ASD (6-100 hp)
- Fans - Controls
- Fans - Motor practices-1 (100+ HP)
- Fans - Motor practices-1 (1-5 HP)
- Fans - Motor practices-1 (6-100 HP)
- Fans - O&M
- Fans - Replace 100+ HP motor
- Fans - Replace 6-100 HP motor
- Fans - System Optimization
- Fans- Improve components
- Gap Forming papermachine
- Heat Pumps - Drying
- Heating - Optimization process (M&T)
- Heating - Process Control
- Heating - Scheduling
- High Bay T5
- High Consistency forming
- High Efficiency Chiller Motors
- Hybrid Dessicant-DX System (Trane CDQ)
- Injection Moulding - Direct drive
- Injection Moulding - Impulse Cooling
- Intelligent extruder (DOE)
- Light cylinders
- Machinery
- Membranes for wastewater

Economic Potential Measure List

- | | | |
|-----|---------------------------------------|---------------------------------------|
| 76 | Injection Moulding - Direct drive | Near Net Shape Casting |
| 77 | Injection Moulding - Impulse Cooling | New transformers welding |
| 78 | Intelligent extruder (DOE) | O&M - Extruders/Injection Moulding |
| 79 | Light cylinders | O&M/drives spinning machines |
| 80 | Machinery | Occupancy Sensor |
| 81 | Membranes for wastewater | Optimization control PM |
| 82 | Near Net Shape Casting | Optimization Refrigeration |
| 83 | New transformers welding | Optimize Controls |
| 84 | O&M - Extruders/Injection Moulding | Optimize drying process |
| 85 | O&M/drives spinning machines | Other Process Controls (batch + site) |
| 86 | Occupancy Sensor | Power recovery |
| 87 | Optimization control PM | Premium T8, Electronic Ballast |
| 88 | Optimization Refrigeration | Process control |
| 89 | Optimize Controls | Process Drives - ASD |
| 90 | Optimize drying process | Process optimization |
| 91 | Other Process Controls (batch + site) | Pumps - ASD (100+ hp) |
| 92 | Power recovery | Pumps - ASD (6-100 hp) |
| 93 | Premium T8, Electronic Ballast | Pumps - Controls |
| 94 | Process control | Pumps - Motor practices-1 (100+ HP) |
| 95 | Process Drives - ASD | Pumps - Motor practices-1 (1-5 HP) |
| 96 | Process optimization | Pumps - Motor practices-1 (6-100 HP) |
| 97 | Pumps - ASD (100+ hp) | Pumps - O&M |
| 98 | Pumps - ASD (1-5 hp) | Pumps - Replace 100+ HP motor |
| 99 | Pumps - ASD (6-100 hp) | Pumps - Replace 6-100 HP motor |
| 100 | Pumps - Controls | Pumps - Sizing |
| 101 | Pumps - Motor practices-1 (100+ HP) | Pumps - System Optimization |
| 102 | Pumps - Motor practices-1 (1-5 HP) | Refinery Controls |
| 103 | Pumps - Motor practices-1 (6-100 HP) | Replace V-belts |
| 104 | Pumps - O&M | Roof Insulation |
| 105 | Pumps - Replace 100+ HP motor | Roof Insulation - Chiller |
| 106 | Pumps - Replace 1-5 HP motor | Top-heating (glass) |
| 107 | Pumps - Replace 6-100 HP motor | VSD for Chiller Pumps and Towers |
| 108 | Pumps - Sizing | Window Film (Standard) |
| 109 | Pumps - System Optimization | Window Film (Standard) - Chiller |
| 110 | Refinery Controls | |
| 111 | Replace V-belts | |
| 112 | Roof Insulation | |
| 113 | Roof Insulation - Chiller | |
| 114 | Top-heating (glass) | |
| 115 | VSD for Chiller Pumps and Towers | |
| 116 | Window Film (Standard) | |
| 117 | Window Film (Standard) - Chiller | |

Achievable Potential Measure List

16

RIM Portfolio

Residential Energy Efficiency

- 1 14 SEER Split-System Air Conditioner
- 2 AC Maintenance (Indoor Coil Cleaning)
- 3 AC Maintenance (Outdoor Coil Cleaning)
- 4 Ceiling R-0 to R-19 Insulation
- 5 Default Window With Sunscreen
- 6 Double Pane Clear Windows to Double Pane Low-E Windows
- 7 Duct Repair
- 8 Electronically Commutated Motors (ECM) on an Air Handler Unit
- 9 Energy Star CW CEE Tier 2 (MEF=2.0)
- 10 HE Refrigerator - Energy Star version of above
- 11 HE Room Air Conditioner - EER 11
- 12 Heat Pump Water Heater (EF=2.9)
- 13 High Efficiency CD (EF=3.01 w/moisture sensor)
- 14 Proper Refrigerant Charging and Air Flow
- 15 Reflective Roof
- 16 Variable-Speed Pool Pump (<1 hp)
- 17 Window Film
- 18 Window Tinting
- 19
- 20
- 21
- 22
- 23
- 24

RIM Portfolio

Commercial Energy Efficiency

- 1 Air Handler Optimization
- 2 Ceiling Insulation
- 3 Centrifugal Chiller, 0.51 kW/ton, 500 tons
- 4 CFL Hardwired, Modular 18W
- 5 Chiller Tune Up/Diagnostics
- 6 Compressor VSD retrofit
- 7 Continuous Dimming
- 8 Cool Roof - Chiller
- 9 Cool Roof - DX
- 10 Copier Power Management Enabling
- 11 Demand controlled circulating systems
- 12 DX Packaged System, EER=10.9, 10 tons
- 13 DX Tune Up/ Advanced Diagnostics
- 14 Electronically Commutated Motors (ECM) on an Air Handler Unit

TRC Portfolio

Residential Energy Efficiency

- 14 SEER Split-System Air Conditioner
- AC Maintenance (Indoor Coil Cleaning)
- AC Maintenance (Outdoor Coil Cleaning)
- Ceiling R-0 to R-19 Insulation
- CFL (18-Watt integral ballast), 0.5 hr/day
- Default Window With Sunscreen
- Double Pane Clear Windows to Double Pane Low-E Windows
- Duct Repair
- Electronically Commutated Motors (ECM) on an Air Handler Unit
- Energy Star CW CEE Tier 2 (MEF=2.0)
- Faucet Aerators
- HE Freezer
- HE Refrigerator - Energy Star version of above
- HE Room Air Conditioner - EER 11
- Heat Pump Water Heater (EF=2.9)
- High Efficiency CD (EF=3.01 w/moisture sensor)
- Low Flow Showerhead
- Proper Refrigerant Charging and Air Flow
- Reflective Roof
- Variable-Speed Pool Pump (<1 hp)
- Water Heater Timeclock
- Weather Strip/Caulk w/Blower Door
- Window Film
- Window Tinting

TRC Portfolio

Commercial Energy Efficiency

- Air Handler Optimization
- Ceiling Insulation
- Centrifugal Chiller, 0.51 kW/ton, 500 tons
- CFL Hardwired, Modular 18W
- Chiller Tune Up/Diagnostics
- Compressor VSD retrofit
- Continuous Dimming
- Cool Roof - Chiller
- Cool Roof - DX
- Copier Power Management Enabling
- Demand controlled circulating systems
- DX Packaged System, EER=10.9, 10 tons
- DX Tune Up/ Advanced Diagnostics
- Electronically Commutated Motors (ECM) on an Air Handler Unit

Florida Public Service Commission
Docket No. 080410-EG
Gulf Power Company
Witness: John N. Floyd
Exhibit No. _____ (JNF-1)
Schedule 6
Page 1 of 4

Achievable Potential Measure List

- 15 EMS - Chiller
- 16 EMS Optimization
- 17 Energy Recovery Ventilation (ERV)
- 18 Evaporator fan controller for MT walk-ins
- 19 Geothermal Heat Pump, EER=13, 10 tons
- 20 HE PTAC, EER=9.6, 1 ton
- 21 Heat Pump Water Heater (air source)
- 22 Heat Recovery Unit
- 23 High Efficiency Chiller Motors
- 24 High Efficiency Fan Motor, 15hp, 1800rpm, 92.4%
- 25 High Efficiency Water Heater (electric)
- 26 High Pressure Sodium 250W Lamp
- 27 High R-Value Glass Doors
- 28 High-efficiency fan motors
- 29 Hybrid Dessicant-DX System (Trane CDQ)
- 30 LED Display Lighting
- 31 LED Exit Sign
- 32 Lighting Control Tuneup
- 33 Multiplex Compressor System
- 34 Occupancy Sensor
- 35 Occupancy Sensor (hotels)
- 36 Optimize Controls
- 37 Outdoor Lighting Controls (Photocell/Timeclock)
- 38 Oversized Air Cooled Condenser
- 39 Premium T8, EB, Reflector
- 40 ROB Premium T8, 1EB
- 41 ROB Premium T8, EB, Reflector
- 42 Roof Insulation
- 43 Variable Speed Drive Control
- 44 VSD for Chiller Pumps and Towers
- 45 Window Film (Standard)
- 46

- EMS - Chiller
- EMS Optimization
- Energy Recovery Ventilation (ERV)
- Evaporator fan controller for MT walk-ins
- Geothermal Heat Pump, EER=13, 10 tons
- HE PTAC, EER=9.6, 1 ton
- Heat Pump Water Heater (air source)
- Heat Recovery Unit
- High Efficiency Chiller Motors
- High Efficiency Fan Motor, 15hp, 1800rpm, 92.4%
- High Efficiency Water Heater (electric)
- High Pressure Sodium 250W Lamp
- High R-Value Glass Doors
- High-efficiency fan motors
- Hot Water Pipe Insulation
- Hybrid Dessicant-DX System (Trane CDQ)
- LED Display Lighting
- LED Exit Sign
- Lighting Control Tuneup
- Multiplex Compressor System
- Occupancy Sensor
- Occupancy Sensor (hotels)
- Optimize Controls
- Outdoor Lighting Controls (Photocell/Timeclock)
- Oversized Air Cooled Condenser
- Premium T8, EB, Reflector
- ROB Premium T8, 1EB
- ROB Premium T8, EB, Reflector
- Roof Insulation
- Variable Speed Drive Control
- VSD for Chiller Pumps and Towers
- Window Film (Standard)

Achievable Potential Measure List

RIM Portfolio

Industrial Energy Efficiency

- 1 CFL Hardwired, Modular 18W
- 2 Chiller Tune Up/Diagnostics
- 3 Clean Room - Controls
- 4 Clean Room - New Designs
- 5 Comp Air - Motor practices-1 (1-5 HP)
- 6 Comp Air - Motor practices-1 (6-100 HP)
- 7 Comp Air - Replace 100+ HP motor
- 8 Comp Air - Replace 6-100 HP motor
- 9 Compressed Air - Controls
- 10 Cool Roof - Chiller
- 11 Cool Roof - DX
- 12 Direct drive Extruders
- 13 Drives - EE motor
- 14 Drives - Process Control
- 15 Drives - Process Controls (batch + site)
- 16 Drying (UV/IR)
- 17 DX Tune Up/ Advanced Diagnostics
- 18 Efficient Curing ovens
- 19 Efficient desalter
- 20 Efficient drives
- 21 Efficient drives - rolling
- 22 Efficient electric melting
- 23 Efficient grinding
- 24 Efficient Machinery
- 25 Efficient Printing press (fewer cylinders)
- 26 Efficient processes (welding, etc.)
- 27 EMS - Chiller
- 28 EMS Optimization - Chiller
- 29 Extruders/injection Moulding-multipump
- 30 Fans - Controls
- 31 Fans - Motor practices-1 (1-5 HP)
- 32 Fans - Motor practices-1 (6-100 HP)
- 33 Fans - Replace 100+ HP motor
- 34 Fans - Replace 6-100 HP motor
- 35 Fans - System Optimization
- 36 Heat Pumps - Drying
- 37 Heating - Process Control
- 38 High Efficiency Chiller Motors
- 39 Hybrid Dessicant-DX System (Trane CDQ)
- 40 Injection Moulding - Direct drive
- 41 Injection Moulding - Impulse Cooling
- 42 Light cylinders
- 43 Machinery

TRC Portfolio

Industrial Energy Efficiency

- Centrifugal Chiller, 0.51 kW/ton, 500 tons
- CFL Hardwired, Modular 18W
- Chiller Tune Up/Diagnostics
- Clean Room - Controls
- Clean Room - New Designs
- Comp Air - Motor practices-1 (100+ HP)
- Comp Air - Motor practices-1 (1-5 HP)
- Comp Air - Motor practices-1 (6-100 HP)
- Comp Air - Replace 100+ HP motor
- Comp Air - Replace 6-100 HP motor
- Compressed Air - Controls
- Cool Roof - Chiller
- Cool Roof - DX
- Direct drive Extruders
- Drives - EE motor
- Drives - Process Control
- Drives - Process Controls (batch + site)
- Drives - Scheduling
- Drying (UV/IR)
- DX Packaged System, EER=10.9, 10 tons
- DX Tune Up/ Advanced Diagnostics
- Efficient Curing ovens
- Efficient desalter
- Efficient drives
- Efficient drives - rolling
- Efficient electric melting
- Efficient grinding
- Efficient Machinery
- Efficient Printing press (fewer cylinders)
- Efficient processes (welding, etc.)
- EMS - Chiller
- EMS Optimization - Chiller
- Extruders/injection Moulding-multipump
- Fans - Controls
- Fans - Motor practices-1 (100+ HP)
- Fans - Motor practices-1 (1-5 HP)
- Fans - Motor practices-1 (6-100 HP)
- Fans - Replace 100+ HP motor
- Fans - Replace 6-100 HP motor
- Fans - System Optimization
- Heat Pumps - Drying
- Heating - Process Control
- Heating - Scheduling

Achievable Potential Measure List

- 44 Membranes for wastewater
- 45 New transformers welding
- 46 O&M/drives spinning machines
- 47 Occupancy Sensor
- 48 Optimization control PM
- 49 Optimization Refrigeration
- 50 Optimize drying process
- 51 Other Process Controls (batch + site)
- 52 Process control
- 53 Process optimization
- 54 Pumps - Motor practices-1 (1-5 HP)
- 55 Pumps - Motor practices-1 (6-100 HP)
- 56 Pumps - Replace 100+ HP motor
- 57 Pumps - Replace 6-100 HP motor
- 58 Pumps - System Optimization
- 59 Roof Insulation
- 60 Roof Insulation - Chiller
- 61 VSD for Chiller Pumps and Towers
- 62 Window Film (Standard)
- 63 Window Film (Standard) - Chiller
- 64
- 65
- 66
- 67
- 68
- 69
- 70
- 71
- 72
- 73

- High Efficiency Chiller Motors
- Hybrid Dessicant-DX System (Trane CDQ)
- Injection Moulding - Direct drive
- Injection Moulding - Impulse Cooling
- Intelligent extruder (DOE)
- Light cylinders
- Machinery
- Membranes for wastewater
- New transformers welding
- O&M/drives spinning machines
- Occupancy Sensor
- Optimization control PM
- Optimization Refrigeration
- Optimize drying process
- Other Process Controls (batch + site)
- Power recovery
- Power recovery
- Process optimization
- Pumps - Motor practices-1 (100+ HP)
- Pumps - Motor practices-1 (1-5 HP)
- Pumps - Motor practices-1 (6-100 HP)
- Pumps - Replace 100+ HP motor
- Pumps - Replace 6-100 HP motor
- Pumps - System Optimization
- Refinery Controls
- Roof Insulation
- Roof Insulation - Chiller
- VSD for Chiller Pumps and Towers
- Window Film (Standard)
- Window Film (Standard) - Chiller

**Table 1
Summary of Energy Efficiency Technical Potential Results**

	Annual Energy (GWh)	Summer System Peak (MW)	Winter System Peak (MW)
Residential	1,968	534	341
Commercial/Industrial	1,377	264	155
Total	3,345	798	496

**Table 2
Summary of Demand Response Technical Potential Results**

	Annual Energy (GWh)	Summer System Peak (MW)	Winter System Peak (MW)
Residential	N/A	198	209
Commercial/Industrial	N/A	98	41
Total	N/A	296	250

**Table 3
Summary of Solar Photovoltaic Technical Potential Results**

	Annual Energy (GWh)	Summer System Peak (MW)	Winter System Peak (MW)
Residential	2,509	911	166
Commercial/Industrial	1,429	541	69
Total	3,938	1,452	235

Florida Public Service Commission
 Docket No. 080410-EG
 Gulf Power Company
 Witness: John N. Floyd
 Exhibit No. _____ (JNF-1)
 Schedule 7
 Page 1 of 1

Summary of Energy Efficiency Economic Potential Results

	Annual Energy (GWh)		Summer System Peak (MW)		Winter System Peak (MW)	
	RIM	TRC	RIM	TRC	RIM	TRC
Residential	2,331	1,716	672	443	397	185
Commercial/Industrial	1,462	1,367	282	252	155	112
Total	3,793	3,083	954	695	552	297

Florida Public Service Commission
 Docket No. 080410-EG
 Gulf Power Company
 Witness: John N. Floyd
 Exhibit No. _____ (JNF-1)
 Schedule 8
 Page 1 of 1

**Table 1
Summary of Energy Efficiency Achievable Potential Results**

	Annual Energy (GWh)		Summer System Peak (MW)		Winter System Peak (MW)	
	RIM	TRC	RIM	TRC	RIM	TRC
Residential						
Low Incentive (33%)	45	59	16	17	4	5
Mid Incentive (50%)	58	78	22	24	6	9
High Incentive (maximum or 2 yr payback)	87	154	36	52	26	48
Commercial/Industrial						
Low Incentive (33%)	39	42	7	7	2	2
Mid Incentive (50%)	52	61	11	11	2	3
High Incentive (maximum or 2 yr payback)	72	98	16	19	4	6
Total						
Low Incentive (33%)	85	101	23	24	5	7
Mid Incentive (50%)	110	139	32	35	9	12
High Incentive (maximum or 2 yr payback)	159	252	52	71	30	54

**Table 2
Summary of Demand Response Achievable Potential Results**

	Annual Energy (GWh)	Summer System Peak (MW)	Winter System Peak (MW)
	Residential		
High Enrollment	N/A	11	13
Low Enrollment	N/A	7	8
Commercial/Industrial			
High Enrollment	N/A	6	3
Low Enrollment	N/A	7	2
Total			
High Enrollment	N/A	17	17
Low Enrollment	N/A	14	10

22

Florida Public Service Commission
Docket No. 080410-EG
Gulf Power Company
Witness: John N. Floyd
Exhibit No. _____ (JNF-1)
Schedule 9
Page 1 of 1

Summary of the Economic Potential Sensitivity Results

	# of Passing Measures		Annual Energy (GWh)		Summer System Peak (MW)		Winter System Peak (MW)	
	RIM	TRC	RIM	TRC	RIM	TRC	RIM	TRC
Residential								
Base	58	44	2,331	1,716	443	386	397	185
Low Capital	57	43	2,331	1,685	440	386	397	178
High Capital	57	43	2,331	1,716	443	386	397	185
\$0 Carbon	31	40	1,434	1,565	413	385	250	173
Low Fuel/Carbon	27	37	1,236	1,396	392	370	229	144
High Fuel/Carbon	58	44	2,339	1,743	447	386	397	190
Commercial/Industrial								
Base	195	181	1,462	1,367	252	228	155	112
Low Capital	194	180	1,462	1,367	252	228	155	112
High Capital	194	180	1,462	1,371	255	228	155	115
\$0 Carbon	137	179	1,072	1,319	244	228	120	107
Low Fuel/Carbon	98	177	581	1,314	242	228	89	106
High Fuel/Carbon	195	183	1,477	1,376	256	228	157	116
Total								
Base	253	225	3,793	3,083	695	614	552	297
Low Capital	251	223	3,793	3,052	692	614	552	290
High Capital	251	223	3,793	3,087	698	614	552	300
\$0 Carbon	168	219	2,506	2,884	657	613	370	280
Low Fuel/Carbon	125	214	1,817	2,710	634	598	318	250
High Fuel/Carbon	253	227	3,816	3,119	703	614	554	306

23

Florida Public Service Commission
Docket No. 080410-EG
Gulf Power Company
Witness: John N. Floyd
Exhibit No. _____ (JNF-1)
Schedule 10
Page 1 of 1

		Annual Bill Impact for 1,200 kWh/Month Residential Customer										
		NPV	2010	2011	2012	2013	2014	2015	2016	2017	2018	2019
No DSM		\$ 180.32	\$ 0.47	\$ 1.75	\$ 3.22	\$ 5.23	\$ 9.97	\$ 14.16	\$ 17.80	\$ 21.21	\$ 24.48	\$ 27.63
RIM Portfolio/Proposed Goals		\$ 152.35	\$ 6.25	\$ 11.05	\$ 16.27	\$ 20.49	\$ 24.01	\$ 26.87	\$ 28.99	\$ 29.52	\$ 28.32	\$ 27.08
TRC Portfolio		\$ 282.50	\$ 7.36	\$ 13.52	\$ 21.22	\$ 29.79	\$ 39.56	\$ 51.08	\$ 63.44	\$ 71.31	\$ 78.31	\$ 84.76