

Woodland Dr

Spanish Oaks Blvd

Forest Ln


Belcener Rd

Winding Oaks Dr




Forest View Dr

Rain Gauge
Treatment Plant



MH 15



Data Summary Report

Custom
Utilities, Inc.
MH 15

10/04/2015 12:00 AM - 10/10/2015 12:00 AM

Flow Summary

Maximum (gpm): 69.07 10/05/2015 06:00 AM
Minimum (gpm): 6.92 10/09/2015 02:00 AM
Average (gpm): 26.44
Total (gal): 228,440.0

Date	Maximum (gpm)	Maximum Time	Minimum (gpm)	Minimum Time	Average (gpm)	Total (gal)
10/04/2015 12:00 AM	61.67	10:15	16.66	02:00	36.39	52,403.7
10/05/2015 12:00 AM	69.07	06:00	13.14	01:00	32.40	46,655.6
10/06/2015 12:00 AM	46.85	20:00	10.38	23:45	25.01	36,007.7
10/07/2015 12:00 AM	53.60	06:00	7.84	01:15	23.31	33,573.1
10/08/2015 12:00 AM	49.54	06:30	7.68	01:15	21.83	31,436.6
10/09/2015 12:00 AM	37.03	07:15	6.92	02:00	19.70	28,363.3

Data Summary Report

Custom
Utilities, Inc.
MH 15

10/04/2015 12:00 AM - 10/10/2015 12:00 AM

Level Summary

Maximum (in): 4.18 10/04/2015 10:15 AM
Minimum (in): 1.26 10/08/2015 12:45 AM
Average (in): 2.37

Date	Maximum (in)	Maximum Time	Minimum (in)	Minimum Time	Average (in)
10/04/2015 12:00 AM	4.18	10:15	2.16	23:30	3.05
10/05/2015 12:00 AM	3.92	06:00	1.92	23:45	2.68
10/06/2015 12:00 AM	3.10	07:00	1.50	23:45	2.22
10/07/2015 12:00 AM	3.20	06:00	1.29	01:30	2.08
10/08/2015 12:00 AM	3.05	18:00	1.26	00:45	2.10
10/09/2015 12:00 AM	2.97	07:15	1.27	01:15	2.10

Data Summary Report

Custom
Utilities, Inc.
MH 15

10/11/2015 12:00 AM - 10/24/2015 11:15 AM

Flow Summary

Maximum (gpm): 123.65 10/14/2015 10:00 AM
Minimum (gpm): 0.00 10/19/2015 12:15 AM
Average (gpm): 18.95
Total (gal): 367,552.4

Date	Maximum (gpm)	Maximum Time	Minimum (gpm)	Minimum Time	Average (gpm)	Total (gal)
10/11/2015 12:00 AM	45.32	11:15	6.14	03:00	23.15	33,339.3
10/12/2015 12:00 AM	43.09	19:30	8.14	00:15	22.16	31,903.5
10/13/2015 12:00 AM	54.25	06:15	6.43	01:00	23.15	33,339.7
10/14/2015 12:00 AM	123.65	10:00	6.81	01:45	23.18	33,379.7
10/15/2015 12:00 AM	49.32	19:30	5.77	03:15	22.26	32,054.9
10/16/2015 12:00 AM	50.46	19:15	6.86	01:00	23.71	34,140.0
10/17/2015 12:00 AM	60.34	08:00	7.03	01:30	26.13	37,629.0
10/18/2015 12:00 AM	49.04	08:30	5.80	23:45	20.24	29,140.5
10/19/2015 12:00 AM	31.64	11:30	0.00	00:15	13.95	20,089.7
10/20/2015 12:00 AM	31.65	08:30	0.00	00:00	12.00	17,276.3
10/21/2015 12:00 AM	28.76	19:00	0.00	00:00	12.17	17,528.8
10/22/2015 12:00 AM	35.45	05:30	0.00	00:00	13.10	18,858.5
10/23/2015 12:00 AM	27.33	17:30	0.00	00:15	14.16	20,392.3
10/24/2015 12:00 AM	39.67	08:00	0.00	00:30	12.56	8,480.3

Data Summary Report

Custom
Utilities, Inc.
MH 15


10/11/2015 12:00 AM - 10/24/2015 11:15 AM

Level Summary


Maximum (in): 4.36 10/14/2015 10:00 AM
Minimum (in): 0.37 10/21/2015 03:45 AM
Average (in): 1.67

Date	Maximum (in)	Maximum Time	Minimum (in)	Minimum Time	Average (in)
10/11/2015 12:00 AM	3.14	18:30	1.40	04:00	2.21
10/12/2015 12:00 AM	3.00	19:30	1.50	01:45	2.19
10/13/2015 12:00 AM	3.41	06:15	1.33	01:00	2.19
10/14/2015 12:00 AM	4.36	10:00	1.36	23:30	2.06
10/15/2015 12:00 AM	2.94	19:30	0.99	03:15	1.84
10/16/2015 12:00 AM	2.88	19:15	1.09	01:15	1.93
10/17/2015 12:00 AM	3.46	19:00	1.05	04:00	2.12
10/18/2015 12:00 AM	3.62	08:30	0.88	23:45	1.67
10/19/2015 12:00 AM	1.73	11:30	0.55	23:45	1.21
10/20/2015 12:00 AM	1.72	05:45	0.44	01:00	1.11
10/21/2015 12:00 AM	1.70	06:00	0.37	03:45	1.10
10/22/2015 12:00 AM	1.82	05:30	0.49	04:30	1.15
10/23/2015 12:00 AM	1.68	05:30	0.43	01:45	1.19
10/24/2015 12:00 AM	1.91	08:00	0.51	01:15	1.08

Rain Gauge Treatment Plant



MH 15



Data Summary Report

Custom
Utilities, Inc.
MH 15

10/25/2015 12:00 AM - 10/31/2015 12:00 AM

Flow Summary

Maximum (gpm): 39.86 10/26/2015 07:45 AM
Minimum (gpm): 0.00 10/25/2015 12:00 AM
Average (gpm): 13.94
Total (gal): 120,444.0

Date	Maximum (gpm)	Maximum Time	Minimum (gpm)	Minimum Time	Average (gpm)	Total (gal)
10/25/2015 12:00 AM	35.19	12:00	0.00	00:00	16.34	23,530.9
10/26/2015 12:00 AM	39.86	07:45	0.00	00:15	13.87	19,977.5
10/27/2015 12:00 AM	29.20	19:15	0.00	00:00	13.54	19,492.9
10/28/2015 12:00 AM	34.03	06:00	0.00	00:00	13.53	19,477.3
10/29/2015 12:00 AM	32.79	18:30	0.00	00:00	13.00	18,713.8
10/30/2015 12:00 AM	30.95	08:15	0.00	00:15	13.37	19,251.6

Data Summary Report

Custom
Utilities, Inc.
MH 15

10/25/2015 12:00 AM - 10/31/2015 12:00 AM

Level Summary

Maximum (in): 1.88 10/28/2015 06:00 AM
Minimum (in): 0.42 10/25/2015 04:00 AM
Average (in): 1.19

Date	Maximum (in)	Maximum Time	Minimum (in)	Minimum Time	Average (in)
10/25/2015 12:00 AM	1.80	19:00	0.42	04:00	1.24
10/26/2015 12:00 AM	1.87	07:45	0.44	01:00	1.19
10/27/2015 12:00 AM	1.77	17:15	0.50	04:00	1.19
10/28/2015 12:00 AM	1.88	06:00	0.48	00:45	1.19
10/29/2015 12:00 AM	1.80	05:30	0.51	03:00	1.16
10/30/2015 12:00 AM	1.77	08:15	0.56	00:15	1.18

Data Summary Report

Custom
Utilities, Inc.
MH 15

11/01/2015 12:00 AM - 11/07/2015 12:00 AM

Flow Summary

Maximum (gpm): 41.96 11/01/2015 06:45 PM
Minimum (gpm): 0.00 11/01/2015 12:00 AM
Average (gpm): 14.36
Total (gal): 124,097.6

Date	Maximum (gpm)	Maximum Time	Minimum (gpm)	Minimum Time	Average (gpm)	Total (gal)
11/01/2015 12:00 AM	41.96	18:45	0.00	00:00	13.69	19,711.7
11/02/2015 12:00 AM	41.18	19:45	0.00	00:15	14.33	20,633.9
11/03/2015 12:00 AM	33.59	18:45	0.00	00:45	14.19	20,439.3
11/04/2015 12:00 AM	34.15	06:45	0.00	00:30	14.01	20,176.6
11/05/2015 12:00 AM	33.47	08:15	0.00	00:30	13.92	20,041.9
11/06/2015 12:00 AM	40.70	19:15	0.00	00:30	16.04	23,094.2

Data Summary Report

Custom
Utilities, Inc.
MH 15

11/01/2015 12:00 AM - 11/07/2015 12:00 AM

Level Summary


Maximum (in): 2.08 11/02/2015 07:45 PM
Minimum (in): 0.51 11/01/2015 05:15 AM
Average (in): 1.29

Date	Maximum (in)	Maximum Time	Minimum (in)	Minimum Time	Average (in)
11/01/2015 12:00 AM	2.03	18:45	0.51	05:15	1.25
11/02/2015 12:00 AM	2.08	19:45	0.58	04:30	1.27
11/03/2015 12:00 AM	1.87	07:30	0.61	04:30	1.28
11/04/2015 12:00 AM	1.87	06:45	0.59	04:45	1.26
11/05/2015 12:00 AM	1.87	08:15	0.56	04:45	1.28
11/06/2015 12:00 AM	2.00	19:15	0.58	02:15	1.37

Rain Gauge Treatment Plant



MH 15



Data Summary Report

Custom
Utilities, Inc.
MH 15

11/08/2015 12:00 AM - 12/05/2015 12:00 AM

Flow Summary

Maximum (gpm): 57.16 11/22/2015 10:45 AM
Minimum (gpm): 0.00 11/08/2015 01:15 AM
Average (gpm): 22.64
Total (gal): 880,381.1

Date	Maximum (gpm)	Maximum Time	Minimum (gpm)	Minimum Time	Average (gpm)	Total (gal)
11/08/2015 12:00 AM	44.30	14:45	0.00	01:15	18.25	26,281.1
11/09/2015 12:00 AM	38.38	17:15	0.00	01:15	18.27	26,308.3
11/10/2015 12:00 AM	42.12	08:30	0.00	04:00	18.74	26,991.8
11/11/2015 12:00 AM	40.60	07:30	5.27	04:15	19.86	28,605.0
11/12/2015 12:00 AM	49.98	08:00	5.46	01:30	20.83	29,997.0
11/13/2015 12:00 AM	38.01	19:15	3.84	04:30	17.44	25,113.5
11/14/2015 12:00 AM	44.65	15:15	4.27	05:00	20.46	29,467.1
11/15/2015 12:00 AM	50.92	15:00	3.44	04:45	22.40	32,254.9
11/16/2015 12:00 AM	45.06	07:30	8.36	03:15	24.31	35,008.8
11/17/2015 12:00 AM	46.36	20:15	4.29	05:15	23.51	33,851.0
11/18/2015 12:00 AM	51.61	07:45	5.19	05:00	23.97	34,522.8
11/19/2015 12:00 AM	46.92	19:30	6.90	05:00	26.81	38,606.3
11/20/2015 12:00 AM	52.03	08:00	12.92	05:00	27.51	39,612.8
11/21/2015 12:00 AM	55.94	14:45	12.50	02:30	28.69	41,310.1
11/22/2015 12:00 AM	57.16	10:45	7.55	05:15	28.49	41,019.2
11/23/2015 12:00 AM	44.17	07:45	5.96	04:30	23.44	33,753.4
11/24/2015 12:00 AM	56.51	18:45	0.00	05:00	22.15	31,889.4
11/25/2015 12:00 AM	48.81	19:45	4.31	04:00	23.25	33,482.4
11/26/2015 12:00 AM	52.35	11:45	4.43	04:30	24.84	35,770.6
11/27/2015 12:00 AM	52.21	19:30	5.09	05:00	22.90	32,980.1
11/28/2015 12:00 AM	46.26	15:30	4.99	02:45	20.95	30,161.7
11/29/2015 12:00 AM	49.21	19:00	4.87	05:15	24.98	35,969.8
11/30/2015 12:00 AM	52.16	19:00	5.05	02:30	23.18	33,382.5
12/01/2015 12:00 AM	44.40	06:15	8.96	03:45	22.27	32,071.9
12/02/2015 12:00 AM	51.76	06:30	5.54	04:15	22.40	32,260.6
12/03/2015 12:00 AM	49.57	19:15	4.15	02:45	21.85	31,463.9
12/04/2015 12:00 AM	43.17	06:30	4.01	04:15	19.61	28,244.9

Data Summary Report

Custom
Utilities, Inc.
MH 15

11/08/2015 12:00 AM - 12/05/2015 12:00 AM

Flow Summary

Maximum (gpm): 57.16 11/22/2015 10:45 AM
Minimum (gpm): 0.00 11/08/2015 01:15 AM
Average (gpm): 22.64
Total (gal): 880,381.1

Date	Maximum (gpm)	Maximum Time	Minimum (gpm)	Minimum Time	Average (gpm)	Total (gal)
11/08/2015 12:00 AM	44.30	14:45	0.00	01:15	18.25	26,281.1
11/09/2015 12:00 AM	38.38	17:15	0.00	01:15	18.27	26,308.3
11/10/2015 12:00 AM	42.12	08:30	0.00	04:00	18.74	26,991.8
11/11/2015 12:00 AM	40.60	07:30	5.27	04:15	19.86	28,605.0
11/12/2015 12:00 AM	49.98	08:00	5.46	01:30	20.83	29,997.0
11/13/2015 12:00 AM	38.01	19:15	3.84	04:30	17.44	25,113.5
11/14/2015 12:00 AM	44.65	15:15	4.27	05:00	20.46	29,467.1
11/15/2015 12:00 AM	50.92	15:00	3.44	04:45	22.40	32,254.9
11/16/2015 12:00 AM	45.06	07:30	8.36	03:15	24.31	35,008.8
11/17/2015 12:00 AM	46.36	20:15	4.29	05:15	23.51	33,851.0
11/18/2015 12:00 AM	51.61	07:45	5.19	05:00	23.97	34,522.8
11/19/2015 12:00 AM	46.92	19:30	6.90	05:00	26.81	38,606.3
11/20/2015 12:00 AM	52.03	08:00	12.92	05:00	27.51	39,612.8
11/21/2015 12:00 AM	55.94	14:45	12.50	02:30	28.69	41,310.1
11/22/2015 12:00 AM	57.16	10:45	7.55	05:15	28.49	41,019.2
11/23/2015 12:00 AM	44.17	07:45	5.96	04:30	23.44	33,753.4
11/24/2015 12:00 AM	56.51	18:45	0.00	05:00	22.15	31,889.4
11/25/2015 12:00 AM	48.81	19:45	4.31	04:00	23.25	33,482.4
11/26/2015 12:00 AM	52.35	11:45	4.43	04:30	24.84	35,770.6
11/27/2015 12:00 AM	52.21	19:30	5.09	05:00	22.90	32,980.1
11/28/2015 12:00 AM	46.26	15:30	4.99	02:45	20.95	30,161.7
11/29/2015 12:00 AM	49.21	19:00	4.87	05:15	24.98	35,969.8
11/30/2015 12:00 AM	52.16	19:00	5.05	02:30	23.18	33,382.5
12/01/2015 12:00 AM	44.40	06:15	8.96	03:45	22.27	32,071.9
12/02/2015 12:00 AM	51.76	06:30	5.54	04:15	22.40	32,260.6
12/03/2015 12:00 AM	49.57	19:15	4.15	02:45	21.85	31,463.9
12/04/2015 12:00 AM	43.17	06:30	4.01	04:15	19.61	28,244.9

Data Summary Report

Custom
Utilities, Inc.
MH 15

12/06/2015 12:00 AM - 12/17/2015 12:00 AM

Flow Summary

Maximum (gpm): 66.18 12/14/2015 06:45 AM
Minimum (gpm): 4.81 12/12/2015 05:30 AM
Average (gpm): 26.30
Total (gal): 416,657.6

Date	Maximum (gpm)	Maximum Time	Minimum (gpm)	Minimum Time	Average (gpm)	Total (gal)
12/06/2015 12:00 AM	57.56	19:15	9.00	05:15	28.50	41,039.1
12/07/2015 12:00 AM	54.28	20:00	6.42	02:30	24.30	34,989.6
12/08/2015 12:00 AM	51.59	17:45	4.91	04:30	25.50	36,715.8
12/09/2015 12:00 AM	50.98	12:45	8.63	02:30	25.05	36,071.6
12/10/2015 12:00 AM	51.73	20:00	8.22	04:00	24.66	35,511.7
12/11/2015 12:00 AM	42.01	06:30	7.25	05:00	23.43	33,740.4
12/12/2015 12:00 AM	54.90	10:45	4.81	05:30	24.81	35,727.4
12/13/2015 12:00 AM	64.55	19:15	10.69	05:45	33.19	47,795.9
12/14/2015 12:00 AM	66.18	06:45	13.28	04:15	29.59	42,610.8
12/15/2015 12:00 AM	61.29	14:15	6.55	02:30	25.41	36,590.6
12/16/2015 12:00 AM	51.32	18:45	5.32	04:30	24.91	35,864.6

Data Summary Report

Custom
Utilities, Inc.
MH 15


12/06/2015 12:00 AM - 12/17/2015 12:00 AM

Level Summary


Maximum (in): 2.92 12/13/2015 07:15 PM
Minimum (in): 0.89 12/12/2015 05:30 AM
Average (in): 1.83

Date	Maximum (in)	Maximum Time	Minimum (in)	Minimum Time	Average (in)
12/06/2015 12:00 AM	2.62	19:15	1.18	05:15	1.85
12/07/2015 12:00 AM	2.50	06:45	1.15	02:30	1.81
12/08/2015 12:00 AM	2.78	17:45	1.08	04:45	1.81
12/09/2015 12:00 AM	2.56	12:45	1.24	04:00	1.81
12/10/2015 12:00 AM	2.59	19:30	1.17	05:00	1.78
12/11/2015 12:00 AM	2.28	06:30	1.11	08:30	1.71
12/12/2015 12:00 AM	2.37	09:15	0.89	05:30	1.68
12/13/2015 12:00 AM	2.92	19:15	1.25	06:00	1.98
12/14/2015 12:00 AM	2.92	06:45	1.53	04:00	1.99
12/15/2015 12:00 AM	2.84	14:15	1.21	03:45	1.87
12/16/2015 12:00 AM	2.63	20:00	1.01	04:45	1.85


Rain Gauge Treatment Plant




MH 15




Rain Gauge Treatment Plant



MH 15



Rain Gauge Treatment Plant



Data Summary Report

Custom
Utilities, Inc.
MH 15

01/14/2016 12:00 AM - 01/17/2016 11:00 AM

Flow Summary

Maximum (gpm): 63.13 01/16/2016 08:45 PM
Minimum (gpm): 0.00 01/15/2016 10:15 AM
Average (gpm): 19.94
Total (gal): 99,313.5

Date	Maximum (gpm)	Maximum Time	Minimum (gpm)	Minimum Time	Average (gpm)	Total (gal)
01/14/2016 12:00 AM	53.07	19:30	3.39	04:30	19.19	27,637.1
01/15/2016 12:00 AM	44.04	07:30	0.00	10:15	20.37	29,328.1
01/16/2016 12:00 AM	63.13	20:45	5.63	06:30	22.12	31,855.7
01/17/2016 12:00 AM	33.34	00:15	7.28	06:15	15.90	10,492.6

Data Summary Report

Custom
Utilities, Inc.
MH 15

01/14/2016 12:00 AM - 01/17/2016 11:00 AM

Level Summary

Maximum (in): 3.25 01/16/2016 08:45 PM
Minimum (in): 0.45 01/15/2016 10:15 AM
Average (in): 1.67

Date	Maximum (in)	Maximum Time	Minimum (in)	Minimum Time	Average (in)
01/14/2016 12:00 AM	2.84	20:00	0.84	05:30	1.61
01/15/2016 12:00 AM	2.50	06:45	0.45	10:15	1.74
01/16/2016 12:00 AM	3.25	20:45	1.02	07:30	1.72
01/17/2016 12:00 AM	2.06	00:15	1.15	07:30	1.55

RAIN EVENT

NOV. 8

Data Summary Report

Custom
Utilities, Inc.
MH 15

12/18/2015 12:00 AM - 12/22/2015 12:00 AM

Flow Summary

Maximum (gpm): 60.57 12/21/2015 01:45 PM
Minimum (gpm): 0.00 12/20/2015 05:45 AM
Average (gpm): 23.13
Total (gal): 133,223.8

Date	Maximum (gpm)	Maximum Time	Minimum (gpm)	Minimum Time	Average (gpm)	Total (gal)
12/18/2015 12:00 AM	45.78	16:00	5.79	04:00	22.76	32,778.9
12/19/2015 12:00 AM	41.27	10:45	4.69	04:45	21.54	31,013.7
12/20/2015 12:00 AM	46.64	14:30	0.00	05:45	23.41	33,710.6
12/21/2015 12:00 AM	60.57	13:45	4.76	05:15	24.81	35,720.7

Data Summary Report

Custom
Utilities, Inc.
MH 15


12/18/2015 12:00 AM - 12/22/2015 12:00 AM

Level Summary

Maximum (in): 2.89 12/21/2015 01:45 PM
Minimum (in): 0.82 12/20/2015 05:45 AM
Average (in): 1.67

Date	Maximum (in)	Maximum Time	Minimum (in)	Minimum Time	Average (in)
12/18/2015 12:00 AM	2.34	06:30	0.89	03:15	1.64
12/19/2015 12:00 AM	2.39	10:45	0.91	04:45	1.59
12/20/2015 12:00 AM	2.81	13:00	0.82	05:45	1.67
12/21/2015 12:00 AM	2.89	13:45	1.02	03:30	1.77

MH 15



Data Summary Report

Custom
Utilities, Inc.
MH 15

11/08/2015 07:00 AM - 11/09/2015 01:00 AM

Level Summary

Maximum (in): 2.10 11/08/2015 02:45 PM
Minimum (in): 0.83 11/09/2015 01:00 AM
Average (in): 1.64

Date	Maximum (in)	Maximum Time	Minimum (in)	Minimum Time	Average (in)
11/08/2015 07:00 AM	1.50	07:45	1.09	07:00	1.30
11/08/2015 08:00 AM	1.76	08:30	1.60	08:00	1.69
11/08/2015 09:00 AM	1.71	09:00	1.67	09:30	1.69
11/08/2015 10:00 AM	2.06	10:30	1.73	10:00	1.87
11/08/2015 11:00 AM	1.97	11:45	1.73	11:15	1.83
11/08/2015 12:00 PM	1.95	12:00	1.62	12:45	1.75
11/08/2015 01:00 PM	2.07	13:00	1.63	13:15	1.79
11/08/2015 02:00 PM	2.10	14:45	1.58	14:15	1.80
11/08/2015 03:00 PM	1.96	15:30	1.64	15:45	1.84
11/08/2015 04:00 PM	1.62	16:00	1.36	16:15	1.53
11/08/2015 05:00 PM	1.81	17:00	1.62	17:15	1.71
11/08/2015 06:00 PM	1.90	18:15	1.71	18:00	1.80
11/08/2015 07:00 PM	2.03	19:30	1.81	19:00	1.91
11/08/2015 08:00 PM	1.83	20:30	1.68	20:00	1.75
11/08/2015 09:00 PM	1.67	21:15	1.48	21:00	1.59
11/08/2015 10:00 PM	1.58	22:30	1.29	22:45	1.44
11/08/2015 11:00 PM	1.41	23:30	0.98	23:00	1.20
11/09/2015 12:00 AM	1.13	00:00	0.83	01:00	1.00

Data Summary Report

Custom
Utilities, Inc.
MH 15

11/08/2015 07:00 AM - 11/09/2015 01:00 AM

Flow Summary

Maximum (gpm): 44.30 11/08/2015 02:45 PM
Minimum (gpm): 4.66 11/09/2015 01:00 AM
Average (gpm): 23.11
Total (gal): 24,955.2

Date	Maximum (gpm)	Maximum Time	Minimum (gpm)	Minimum Time	Average (gpm)	Total (gal)
11/08/2015 07:00 AM	17.84	07:45	8.86	07:00	13.51	810.7
11/08/2015 08:00 AM	28.39	08:30	20.64	08:00	23.89	1,433.4
11/08/2015 09:00 AM	23.94	09:45	21.66	09:30	22.53	1,351.9
11/08/2015 10:00 AM	37.64	10:30	24.21	10:00	30.21	1,812.8
11/08/2015 11:00 AM	37.08	11:45	26.35	11:00	30.16	1,809.3
11/08/2015 12:00 PM	33.11	12:00	20.92	12:45	26.60	1,596.0
11/08/2015 01:00 PM	34.58	13:00	21.63	13:15	26.42	1,585.4
11/08/2015 02:00 PM	44.30	14:45	20.29	14:15	30.28	1,816.8
11/08/2015 03:00 PM	36.73	15:30	20.82	15:45	29.99	1,799.3
11/08/2015 04:00 PM	20.79	16:45	15.01	16:15	18.65	1,119.0
11/08/2015 05:00 PM	26.57	17:00	19.10	17:15	23.62	1,416.9
11/08/2015 06:00 PM	34.00	18:15	24.64	18:30	28.92	1,735.2
11/08/2015 07:00 PM	33.22	19:15	30.35	19:00	31.61	1,896.8
11/08/2015 08:00 PM	27.39	20:45	22.65	20:00	25.08	1,505.0
11/08/2015 09:00 PM	21.86	21:15	16.68	21:00	20.13	1,207.6
11/08/2015 10:00 PM	18.49	22:30	12.96	22:45	16.08	964.8
11/08/2015 11:00 PM	15.98	23:30	7.29	23:15	11.22	673.0
11/09/2015 12:00 AM	8.98	00:00	4.66	01:00	7.02	421.3