

COMMISSIONERS:  
ART GRAHAM, CHAIRMAN  
JULIE I. BROWN  
DONALD J. POLMANN  
GARY F. CLARK  
ANDREW GILES FAY

STATE OF FLORIDA



DIVISION OF ENGINEERING  
TOM BALLINGER  
DIRECTOR  
(850) 413-6910

# Public Service Commission

April 15, 2019

Mr. Joel T. Baker  
Florida Power & Light Company  
700 Universe Boulevard  
Juno Beach, FL 33408  
Joel.Baker@fpl.com

## STAFF'S SECOND DATA REQUEST VIA EMAIL & US MAIL

**Re: Docket No. 20190082-EQ - Petition for approval of renewable energy tariff and standard offer contract, by Florida Power & Light Company.**

Dear Mr. Baker:

Please provide responses to the following questions by May 6, 2019.

1. Please explain why Florida Power & Light Company (FPL or Utility) is planning to construct a 1,886 megawatt (MW) combined cycle unit in 2026, when FPL's projected capacity need in 2026 is only 106 MW per Schedule 7.1 of the Utility's Ten-Year Site Plan. As part of this response, detail what alternatives, if any, FPL considered and provide analysis demonstrating that the 2026 unit was the most economic decision.
2. Please indicate whether or not building the 1,886 MW combined cycle unit can be delayed with purchased power contracts. If not, please explain.

Please file all responses electronically via the Commission's website at [www.floridapsc.com](http://www.floridapsc.com) by selecting the Clerk's Office tab and Electronic Filing Web Form. If you have any questions, please contact me by phone at (850) 413-6592 or by email at [tthomps@psc.state.fl.us](mailto:tthomps@psc.state.fl.us).

Sincerely,

A handwritten signature in blue ink that reads "Takira Thompson".

Takira Thompson  
Engineering Specialist  
Division of Engineering

TTT/jp

cc: Office of Commission Clerk (Docket No. 20190082-EQ)