# AUSLEY MCMULLEN

ATTORNEYS AND COUNSELORS AT LAW

123 SOUTH CALHOUN STREET
P.O. BOX 391 (ZIP 32302)
TALLAHASSEE, FLORIDA 32301
(850) 224-9115 FAX (850) 222-7560

April 26, 2021

# **ELECTRONIC FILING**

Mr. Adam J. Teitzman, Commission Clerk Office of Commission Clerk Florida Public Service Commission 2540 Shumard Oak Boulevard Tallahassee, Florida 32399-0850

Re: Fuel and Purchased Power Cost Recovery Clause with Generating Performance

Incentive Factor; FPSC Docket No. 20210001-EI

Dear Mr. Teitzman:

Attached for filing in the above docket are Tampa Electric Company's GPIF Actual Unit Performance Data Schedules for the month of March 2021.

Thank you for your assistance in connection with this matter.

Sincerely,

James D. Beasley

JDB/ne Attachment

cc: All parties of record (w/attachment)

# **CERTIFICATE OF SERVICE**

I HEREBY CERTIFY that a true and correct copy of the foregoing Schedules, filed on behalf of Tampa Electric Company, has been furnished by electronic mail on this 26th day of April 2021 to the following:

Ms. Suzanne Brownless
Office of the General Counsel
Florida Public Service Commission
2540 Shumard Oak Boulevard
Tallahassee, FL 32399-0850
<a href="mailto:sbrownle@psc.state.fl.us">sbrownle@psc.state.fl.us</a>

Ms. Patricia A. Christensen Associate Public Counsel Office of Public Counsel 111 West Madison Street – Room 812 Tallahassee, FL 32399-1400 christensen.patty@leg.state.fl.us

Ms. Dianne M. Triplett
Duke Energy Florida
299 First Avenue North
St. Petersburg, FL 33701
Dianne.triplett@duke-energy.com
FLRegulatoryLegal@duke-energy.com

Mr. Matthew R. Bernier Senior Counsel Duke Energy Florida 106 East College Avenue, Suite 800 Tallahassee, FL 32301-7740 Matthew.bernier@duke-energy.com

Mr. Jon C Moyle, Jr. Moyle Law Firm 118 North Gadsden Street Tallahassee, FL 32301 jmoyle@moylelaw.com mqualls@moylelaw.com

Mr. Steven R. Griffin Beggs & Lane P.O. Box 12950 Pensacola FL 32591 srg@beggslane.com Ms. Beth Keating Gunster, Yoakley & Stewart, P.A. 215 S. Monroe St., Suite 601 Tallahassee, FL 32301 bkeating@gunster.com

Maria Moncada
David M. Lee
Florida Power & Light Company
700 Universe Boulevard
Juno Beach, FL 33408-0420
maria.moncada@fpl.com
david.lee@fpl.com

Mr. Kenneth Hoffman Vice President, Regulatory Relations Florida Power & Light Company 215 South Monroe Street, Suite 810 Tallahassee, FL 32301-1859 ken.hoffman@fpl.com

Mr. Mike Cassel Regulatory and Governmental Affairs Florida Public Utilities Company Florida Division of Chesapeake Utilities Corp. 1750 SW 14th Street, Suite 200 Fernandina Beach, FL 32034 mcassel@fpuc.com

Mr. Russell A. Badders
Vice President & Associate General Counsel
Gulf Power Company
One Energy Place
Pensacola FL 32520
russell.badders@nexteranergy.com

Mr. Robert Scheffel Wright
Mr. John T. LaVia, III
Gardner, Bist, Wiener, Wadsworth,
Bowden, Bush, Dee, LaVia & Wright, P.A.
1300 Thomaswood Drive
Tallahassee, FL 32308
Schef@gbwlegal.com
Jlavia@gbwlegal.com

Mr. James W. Brew
Ms. Laura W. Baker
Stone Mattheis Xenopoulos & Brew, PC
1025 Thomas Jefferson Street, NW
Eighth Floor, West Tower
Washington, D.C. 20007-5201
jbrew@smxblaw.com
lwb@smxblaw.com

ATTORNEY

### ACTUAL UNIT PERFORMANCE DATA

| PLANT/UNIT                                   |         | MONTH OF: | MONTH OF:      | MONTH OF: | MONTH OF: | MONTH OF: | MONTH OF: | MONTH OF: | MONTH OF: | MONTH OF: | MONTH OF: | MONTH OF: | MONTH OF: | PERIOD    |
|--|---------|-----------|----------------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| BAYSIDE 1                                    |         | Jan-21    | Feb-21         | Mar-21    | Apr-21    | May-21    | Jun-21    | Jul-21    | Aug-21    | Sep-21    | Oct-21    | Nov-21    | Dec-21    | 2021      |
| Equivalent Availability Factor (%)           | EAF     | 81.0      | 97.3           | 71.0      |           |           |           |           |           |           |           |           |           | 84.9      |
|  |         |           |                |           |           |           |           |           |           |           |           |           |           |           |
| 2. Period Hours                              | PH      | 744.0     | 672.0          | 743.0     |           |           |           |           |           |           |           |           |           | 2,159.0   |
| 3. Service Hours                             | SH      | 2.9       | 659.1          | 596.1     |           |           |           |           |           |           |           |           |           | 1,258.1   |
| 4. Reserve Shutdown Hours                    | RSH     | 599.3     | 0.0            | 0.0       |           |           |           |           |           |           |           |           |           | 599.3     |
| 5. Unavailable Hours                         | UH      | 141.7     | 12.9           | 148.0     |           |           |           |           |           |           |           |           |           | 302.6     |
| 6. Planned Outage Hours                      | РОН     | 0.0       | 0.0            | 79.9      |           |           |           |           |           |           |           |           |           | 79.9      |
| 7. Forced Outage Hours                       | FOH     | 0.8       | 7.9            | 68.1      |           |           |           |           |           |           |           |           |           | 76.8      |
| 8. Maintenance Outage Hours                  | МОН     | 141.0     | 5.0            | 0.0       |           |           |           |           |           |           |           |           |           | 146.0     |
| 9a. Partial Planned Outage Hours             | РРОН    | 0.0       | 0.0            | 0.0       |           |           |           |           |           |           |           |           |           | 0.0       |
| 9b. Load Reduction Partial Planned (MW)      | LRPP    | 0.0       | 0.0            | 0.0       |           |           |           |           |           |           |           |           |           | 0.0       |
| 10a. Partial Forced Outage Hours             | PFOH    | 0.0       | 9.0            | 66.6      |           |           |           |           |           |           |           |           |           | 75.6      |
| 10b. Load Reduction Partial Forced (MW)      | LRPF    | 0.0       | 79.0           | 79.0      |           |           |           |           |           |           |           |           |           | 79.0      |
| 11a. Partial Maintenance Outage Hours        | РМОН    | 0.0       | 6.6            | 60.4      |           |           |           |           |           |           |           |           |           | 67.0      |
| 11b. Load Reduction Partial Maintenance (MW) | LRPM    | 0.0       | 79.0           | 185.3     |           |           |           |           |           |           |           |           |           | 174.8     |
| 12. Net Summer Continuous Rating (MW)        | NSC     | 701.0     | 701.0          | 701.0     |           |           |           |           |           |           |           |           |           | 701.0     |
| 13. Operating British Thermal Units (GBTU)   | OPR BTU | 0.0       | 2,629.4        | 2,086.8   |           |           |           |           |           |           |           |           |           | 4,716.1   |
| 14. Net Generation (MWH)                     | NETGEN  | 0.0       | 356,616.9      | 281,193.7 |           |           |           |           |           |           |           |           |           | 637,810.6 |
| 15. Avg. Net Operating Heat Rate (BTU/KWH)   | ANOHR   | 0.0       | 7,373.0        | 7,421.0   |           |           |           |           |           |           |           |           |           | 7,394.2   |
| 16. Net Output Factor (%)                    | NOF     | 0.0       | 67.5           | 49.0      |           |           |           |           |           |           |           |           |           | 64.0      |
| 17. Net Period Continuous Rating (MW)        | NPC     | 792.0     | 792.0          | 792.0     |           |           |           |           |           |           |           |           |           | 792.0     |
| 18. Avg. Net Operating Heat Rate Equation    |         | ANOHR = N | NOF (-2.852) + | 7,630     |           |           |           |           |           |           |           |           |           |           |

### ACTUAL UNIT PERFORMANCE DATA

|   | PLANT/UNIT                                   |         | MONTH OF: | MONTH OF:     | MONTH OF: | MONTH OF: | MONTH OF: | MONTH OF: | MONTH OF: | MONTH OF: | MONTH OF: | MONTH OF: | MONTH OF: | MONTH OF: | PERIOD      |
|---|--|---------|-----------|---------------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|-------------|
|   | BAYSIDE 2                                    |         | Jan-21    | Feb-21        | Mar-21    | Apr-21    | May-21    | Jun-21    | Jul-21    | Aug-21    | Sep-21    | Oct-21    | Nov-21    | Dec-21    | 2021        |
|   | 1. Equivalent Availability Factor (%)        | EAF     | 98.4      | 99.6          | 97.3      |           |           |           |           |           |           |           |           |           | 98.8        |
|   | 2. Period Hours                              | PH      | 744.0     | 672.0         | 743.0     |           |           |           |           |           |           |           |           |           | 2,159.0     |
|   | 3. Service Hours                             | SH      | 736.7     | 670.2         | 729.7     |           |           |           |           |           |           |           |           |           | 2,136.6     |
|   | 4. Reserve Shutdown Hours                    | RSH     | 0.0       | 0.0           | 0.0       |           |           |           |           |           |           |           |           |           | 0.0         |
|   | 5. Unavailable Hours                         | UH      | 7.3       | 1.8           | 14.3      |           |           |           |           |           |           |           |           |           | 23.4        |
|   | 6. Planned Outage Hours                      | РОН     | 0.0       | 0.0           | 0.0       |           |           |           |           |           |           |           |           |           | 0.0         |
|   | 7. Forced Outage Hours                       | FOH     | 0.0       | 1.8           | 0.0       |           |           |           |           |           |           |           |           |           | 1.8         |
|   | 8. Maintenance Outage Hours                  | мон     | 7.3       | 0.0           | 14.3      |           |           |           |           |           |           |           |           |           | 21.6        |
|   | 9a. Partial Planned Outage Hours             | РРОН    | 0.0       | 0.0           | 0.0       |           |           |           |           |           |           |           |           |           | 0.0         |
| , | 9b. Load Reduction Partial Planned (MW)      | LRPP    | 0.0       | 0.0           | 0.0       |           |           |           |           |           |           |           |           |           | 0.0         |
|   | 10a. Partial Forced Outage Hours             | PFOH    | 0.0       | 3.2           | 0.0       |           |           |           |           |           |           |           |           |           | 3.2         |
|   | 10b. Load Reduction Partial Forced (MW)      | LRPF    | 0.0       | 77.0          | 0.0       |           |           |           |           |           |           |           |           |           | 77.0        |
|   | 11a. Partial Maintenance Outage Hours        | РМОН    | 19.8      | 0.0           | 24.6      |           |           |           |           |           |           |           |           |           | 44.4        |
|   | 11b. Load Reduction Partial Maintenance (MW) | LRPM    | 77.0      | 0.0           | 77.0      |           |           |           |           |           |           |           |           |           | 77.0        |
|   | 12. Net Summer Continuous Rating (MW)        | NSC     | 929.0     | 929.0         | 929.0     |           |           |           |           |           |           |           |           |           | 929.0       |
|   | 13. Operating British Thermal Units (GBTU)   | OPR BTU | 2,941.7   | 3,623.8       | 3,326.4   |           |           |           |           |           |           |           |           |           | 9,891.8     |
|   | 14. Net Generation (MWH)                     | NETGEN  | 394,036.0 | 493,064.0     | 449,494.3 |           |           |           |           |           |           |           |           |           | 1,336,594.3 |
|   | 15. Avg. Net Operating Heat Rate (BTU/KWH)   | ANOHR   | 7,466.0   | 7,349.0       | 7,400.0   |           |           |           |           |           |           |           |           |           | 7,400.8     |
|   | 16. Net Output Factor (%)                    | NOF     | 50.6      | 70.1          | 57.8      |           |           |           |           |           |           |           |           |           | 59.7        |
|   | 17. Net Period Continuous Rating (MW)        | NPC     | 1,047.0   | 1,047.0       | 1,047.0   |           |           |           |           |           |           |           |           |           | 1,047.0     |
|   | 18. Avg. Net Operating Heat Rate Equation    |         | ANOHR = N | OF (-6.673) + | 7,965     |           |           |           |           |           |           |           |           |           |             |
|   |  |         |           |               |           |           |           |           |           |           |           |           |           |           |             |



### ACTUAL UNIT PERFORMANCE DATA

| PLANT/UNIT                                    |         | MONTH OF: | MONTH OF:       | MONTH OF: | MONTH OF: | MONTH OF: | MONTH OF: | MONTH OF: | MONTH OF: | MONTH OF: | MONTH OF: | MONTH OF: | MONTH OF: | PERIOD    |
|---|---------|-----------|-----------------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| BIG BEND 4                                    |         | Jan-21    | Feb-21          | Mar-21    | Apr-21    | May-21    | Jun-21    | Jul-21    | Aug-21    | Sep-21    | Oct-21    | Nov-21    | Dec-21    | 2021      |
| 1. Facility leads Applicability, Factors (60) | FAF     | 60.1      | 00.4            | 06.5      |           |           |           |           |           |           |           |           |           | 01.1      |
| Equivalent Availability Factor (%)            | EAF     | 60.1      | 98.4            | 86.5      |           |           |           |           |           |           |           |           |           | 81.1      |
| 2. Period Hours                               | PH      | 744.0     | 672.0           | 743.0     |           |           |           |           |           |           |           |           |           | 2,159.0   |
| 3. Service Hours                              | SH      | 534.6     | 653.4           | 642.5     |           |           |           |           |           |           |           |           |           | 1,830.5   |
| 4. Reserve Shutdown Hours                     | RSH     | 104.6     | 18.6            | 1.0       |           |           |           |           |           |           |           |           |           | 124.2     |
| 5. Unavailable Hours                          | UH      | 104.8     | 0.0             | 100.5     |           |           |           |           |           |           |           |           |           | 205.3     |
| 6. Planned Outage Hours                       | РОН     | 0.0       | 0.0             | 96.2      |           |           |           |           |           |           |           |           |           | 96.2      |
| 7. Forced Outage Hours                        | FOH     | 4.3       | 0.0             | 4.3       |           |           |           |           |           |           |           |           |           | 8.6       |
| 8. Maintenance Outage Hours                   | мон     | 100.5     | 0.0             | 0.0       |           |           |           |           |           |           |           |           |           | 100.5     |
| 9a. Partial Planned Outage Hours              | РРОН    | 0.0       | 0.0             | 0.0       |           |           |           |           |           |           |           |           |           | 0.0       |
| 9b. Load Reduction Partial Planned (MW)       | LRPP    | 0.0       | 0.0             | 0.0       |           |           |           |           |           |           |           |           |           | 0.0       |
| 10a. Partial Forced Outage Hours              | PFOH    | 336.1     | 24.1            | 0.0       |           |           |           |           |           |           |           |           |           | 360.2     |
| 10b. Load Reduction Partial Forced (MW)       | LRPF    | 246.5     | 190.0           | 0.0       |           |           |           |           |           |           |           |           |           | 242.7     |
| 11a. Partial Maintenance Outage Hours         | РМОН    | 0.0       | 0.0             | 0.0       |           |           |           |           |           |           |           |           |           | 0.0       |
| 11b. Load Reduction Partial Maintenance (MW)  | LRPM    | 0.0       | 0.0             | 0.0       |           |           |           |           |           |           |           |           |           | 0.0       |
| 12. Net Summer Continuous Rating (MW)         | NSC     | 347.0     | 347.0           | 347.0     |           |           |           |           |           |           |           |           |           | 347.0     |
| 13. Operating British Thermal Units (GBTU)    | OPR BTU | 1,135.4   | 2,224.0         | 1,699.2   |           |           |           |           |           |           |           |           |           | 5,058.6   |
| 14. Net Generation (MWH)                      | NETGEN  | 114,956.0 | 212,466.0       | 159,431.0 |           |           |           |           |           |           |           |           |           | 486,853.0 |
| 15. Avg. Net Operating Heat Rate (BTU/KWH)    | ANOHR   | 9,877.0   | 10,468.0        | 10,658.0  |           |           |           |           |           |           |           |           |           | 10,390.5  |
| 16. Net Output Factor (%)                     | NOF     | 49.8      | 75.3            | 57.4      |           |           |           |           |           |           |           |           |           | 61.6      |
| 17. Net Period Continuous Rating (MW)         | NPC     | 432.0     | 432.0           | 432.0     |           |           |           |           |           |           |           |           |           | 432.0     |
| 18. Avg. Net Operating Heat Rate Equation     |         | ANOHR = N | IOF (-5.6236) + | 11,149    |           |           |           |           |           |           |           |           |           |           |



### ACTUAL UNIT PERFORMANCE DATA

| PLANT/UNIT                                   |         | MONTH OF: | MONTH OF:      | MONTH OF: | MONTH OF: | MONTH OF: | MONTH OF: | MONTH OF: | MONTH OF: | MONTH OF: | MONTH OF: | MONTH OF: | MONTH OF: | PERIOD   |
|--|---------|-----------|----------------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|----------|
| POLK 1                                       |         | Jan-21    | Feb-21         | Mar-21    | Apr-21    | May-21    | Jun-21    | Jul-21    | Aug-21    | Sep-21    | Oct-21    | Nov-21    | Dec-21    | 2021     |
| Equivalent Availability Factor (%)           | EAF     | 73.4      | 99.9           | 91.9      |           |           |           |           |           |           |           |           |           | 88.0     |
| 2. Period Hours                              | PH      | 744.0     | 672.0          | 743.0     |           |           |           |           |           |           |           |           |           | 2,159.0  |
| 3. Service Hours                             | SH      | 73.3      | 63.4           | 343.5     |           |           |           |           |           |           |           |           |           | 480.2    |
| 4. Reserve Shutdown Hours                    | RSH     | 472.9     | 608.0          | 385.5     |           |           |           |           |           |           |           |           |           | 1,466.4  |
| 5. Unavailable Hours                         | UH      | 197.9     | 0.6            | 15.0      |           |           |           |           |           |           |           |           |           | 213.5    |
| 6. Planned Outage Hours                      | РОН     | 0.0       | 0.0            | 0.0       |           |           |           |           |           |           |           |           |           | 0.0      |
| 7. Forced Outage Hours                       | FOH     | 197.9     | 0.6            | 15.0      |           |           |           |           |           |           |           |           |           | 213.5    |
| 8. Maintenance Outage Hours                  | МОН     | 0.0       | 0.0            | 0.0       |           |           |           |           |           |           |           |           |           | 0.0      |
| 9a. Partial Planned Outage Hours             | РРОН    | 0.0       | 0.0            | 0.0       |           |           |           |           |           |           |           |           |           | 0.0      |
| 9b. Load Reduction Partial Planned (MW)      | LRPP    | 0.0       | 0.0            | 0.0       |           |           |           |           |           |           |           |           |           | 0.0      |
| 10a. Partial Forced Outage Hours             | PFOH    | 0.0       | 0.0            | 135.6     |           |           |           |           |           |           |           |           |           | 135.6    |
| 10b. Load Reduction Partial Forced (MW)      | LRPF    | 0.0       | 0.0            | 77.0      |           |           |           |           |           |           |           |           |           | 77.0     |
| 11a. Partial Maintenance Outage Hours        | РМОН    | 0.0       | 0.0            | 0.0       |           |           |           |           |           |           |           |           |           | 0.0      |
| 11b. Load Reduction Partial Maintenance (MW) | LRPM    | 0.0       | 0.0            | 0.0       |           |           |           |           |           |           |           |           |           | 0.0      |
| 12. Net Summer Continuous Rating (MW)        | NSC     | 210.0     | 210.0          | 210.0     |           |           |           |           |           |           |           |           |           | 210.0    |
| 13. Operating British Thermal Units (GBTU)   | OPR BTU | 82.2      | 88.1           | 437.0     |           |           |           |           |           |           |           |           |           | 607.4    |
| 14. Net Generation (MWH)                     | NETGEN  | 7,975.0   | 7,431.0        | 47,770.0  |           |           |           |           |           |           |           |           |           | 63,176.0 |
| 15. Avg. Net Operating Heat Rate (BTU/KWH)   | ANOHR   | 10,308.0  | 11,856.0       | 9,149.0   |           |           |           |           |           |           |           |           |           | 9,613.9  |
| 16. Net Output Factor (%)                    | NOF     | 47.3      | 50.9           | 60.5      |           |           |           |           |           |           |           |           |           | 57.2     |
| 17. Net Period Continuous Rating (MW)        | NPC     | 230.0     | 230.0          | 230.0     |           |           |           |           |           |           |           |           |           | 230.0    |
| 18. Avg. Net Operating Heat Rate Equation    |         | ANOHR = N | IOF (-7.778) + | 10,842    |           |           |           |           |           |           |           |           |           |          |



# ACTUAL UNIT PERFORMANCE DATA

| PLANT/UNIT                                   |         | MONTH OF: | MONTH OF:     | MONTH OF: | MONTH OF: | MONTH OF: | MONTH OF: | MONTH OF: | MONTH OF: | MONTH OF:       | MONTH OF: | MONTH OF: | MONTH OF: | PERIOD    |  |
|--|---------|-----------|---------------|-----------|-----------|-----------|-----------|-----------|-----------|-----------------|-----------|-----------|-----------|-----------|--|
| POLK 2                                       |         | Jan-21    | Feb-21        | Mar-21    | Apr-21    | May-21    | Jun-21    | Jul-21    | Aug-21    | Sep-21          | Oct-21    | Nov-21    | Dec-21    | 2021      |  |
| 101.2  |         | Juli 21   | 100 21        | 14101 21  | Apr 22    | May 21    | Jun 21    | Jul 21    | Aug 21    | 30 <b>p 2</b> 1 | 00.21     | 1400 21   | 500 21    | 2021      |  |
| 1. Equivalent Availability Factor (%)        | EAF     | 99.8      | 85.6          | 76.9      |           |           |           |           |           |                 |           |           |           | 88.1      |  |
| 2. Period Hours                              | PH      | 744.0     | 672.0         | 743.0     |           |           |           |           |           |                 |           |           |           | 2,159.0   |  |
| 3. Service Hours                             | SH      | 741.3     | 43.1          | 446.6     |           |           |           |           |           |                 |           |           |           | 1,231.0   |  |
| 4. Reserve Shutdown Hours                    | RSH     | 1.3       | 532.1         | 146.0     |           |           |           |           |           |                 |           |           |           | 679.4     |  |
| 5. Unavailable Hours                         | UH      | 1.4       | 96.8          | 151.4     |           |           |           |           |           |                 |           |           |           | 249.6     |  |
| 6. Planned Outage Hours                      | РОН     | 1.1       | 86.4          | 143.2     |           |           |           |           |           |                 |           |           |           | 230.7     |  |
| 7. Forced Outage Hours                       | FOH     | 0.3       | 0.0           | 8.2       |           |           |           |           |           |                 |           |           |           | 8.5       |  |
| 8. Maintenance Outage Hours                  | МОН     | 0.0       | 10.4          | 0.0       |           |           |           |           |           |                 |           |           |           | 10.4      |  |
| 9a. Partial Planned Outage Hours             | РРОН    | 0.0       | 0.0           | 0.0       |           |           |           |           |           |                 |           |           |           | 0.0       |  |
| 9b. Load Reduction Partial Planned (MW)      | LRPP    | 0.0       | 0.0           | 0.0       |           |           |           |           |           |                 |           |           |           | 0.0       |  |
| 10a. Partial Forced Outage Hours             | PFOH    | 0.4       | 0.0           | 0.0       |           |           |           |           |           |                 |           |           |           | 0.4       |  |
| 10b. Load Reduction Partial Forced (MW)      | LRPF    | 124.8     | 0.0           | 0.0       |           |           |           |           |           |                 |           |           |           | 124.8     |  |
| 11a. Partial Maintenance Outage Hours        | РМОН    | 0.0       | 0.0           | 77.7      |           |           |           |           |           |                 |           |           |           | 77.7      |  |
| 11b. Load Reduction Partial Maintenance (MW) | LRPM    | 0.0       | 0.0           | 125.0     |           |           |           |           |           |                 |           |           |           | 125.0     |  |
| 12. Net Summer Continuous Rating (MW)        | NSC     | 1,061.0   | 1,061.0       | 1,061.0   |           |           |           |           |           |                 |           |           |           | 1,061.0   |  |
| 13. Operating British Thermal Units (GBTU)   | OPR BTU | 3,751.0   | 185.9         | 2,381.5   |           |           |           |           |           |                 |           |           |           | 6,318.5   |  |
| 14. Net Generation (MWH)                     | NETGEN  | 538,346.0 | 13,910.0      | 317,805.0 |           |           |           |           |           |                 |           |           |           | 870,061.0 |  |
| 15. Avg. Net Operating Heat Rate (BTU/KWH)   | ANOHR   | 6,968.0   | 13,368.0      | 7,494.0   |           |           |           |           |           |                 |           |           |           | 7,262.2   |  |
| 16. Net Output Factor (%)                    | NOF     | 60.5      | 26.9          | 59.3      |           |           |           |           |           |                 |           |           |           | 58.9      |  |
| 17. Net Period Continuous Rating (MW)        | NPC     | 1,200.0   | 1,200.0       | 1,200.0   |           |           |           |           |           |                 |           |           |           | 1,200.0   |  |
| 18. Avg. Net Operating Heat Rate Equation    |         | ANOHR = N | NOF (-53.862) | + 11,266  |           |           |           |           |           |                 |           |           |           |           |  |



| Unit E    | vent Number Event Type                   | Event Begin Date Ev | ent Begin Time E | vent End Date Ev | ent End Time Ev | ent Duration Cause Cod | e Cause Code Description     | Narrative   | Net Available Capacity Net Dependable Capacity |
|-----------|--|---------------------|------------------|------------------|-----------------|------------------------|------------------------------|---|--|
| BS CT1(A) | 11 Planned Outage                        | 3/14/2021           | 23:55:00         | 3/21/2021        | 23:00:00        | 167.08 5002            | Inlet air filters            | Planned outage to perform EBI inspection on 1A CT, and Inlet filter replacements.     | 183  |
| BS CT1(A) | 12 Unplanned (Forced) Outage - Immediate | e 3/21/2021         | 23:00:00         | 3/31/2021        | 23:59:00        | 241 5082               | High pressure blades/buckets | Planned outage forced to extend due to damaged (cracked) buckets found during boresco | op 183   |

9

| Unit Eve  | nt Number Event Type                    | Event Begin Date Eve | ent Begin Time E | vent End Date Ev | ent End Time Ev | ent Duration Cause Code | Cause Code Description | Narrative   | Net Available Capacity Net Dependable Capacity |
|-----------|---|----------------------|------------------|------------------|-----------------|-------------------------|------------------------|---|--|
| BS CT1(B) | 12 Reserve Shutdown                     | 3/5/2021             | 23:16:00         | 3/6/2021         | 8:27:00         | 9.18                    |                        | Reserve Shutdown  | 183  |
| BS CT1(B) | 13 Planned Outage                       | 3/13/2021            | 0:29:00          | 3/20/2021        | 12:00:00        | 178.52 5002             | Inlet air filters      | Planned EBI for 1B CT, Inlet air filters also changed during this time.             | 183  |
| BS CT1(B) | 14 Unplanned (Forced) Outage - Immediat | e 3/20/2021          | 12:00:00         | 3/21/2021        | 13:50:00        | 25.83                   |                        | 1C moved from a Planned Outage to Forced Outage when we were attempting to close in | 0 183  |
| BS CT1(B) | 15 Reserve Shutdown                     | 3/21/2021            | 13:50:00         | 3/21/2021        | 15:02:00        | 1.2                     |                        | Reserve Shutdown  | 183  |
| BS CT1(B) | 16 Reserve Shutdown                     | 3/30/2021            | 1:24:00          | 3/30/2021        | 11:21:00        | 9.95                    |                        | Reserve Shutdown  | 183  |

| Unit    | Event Number | Event Type                            | Event Regin Date Eve   | ont Pogin Timo E | wont End Data E   | ant End Time Eu  | vent Duration Cause Code | Cause Code Description | Narrative  | Net Available Capacity Net Dependable Capacity  |
|---------|--------------|---------------------------------------|------------------------|------------------|-------------------|------------------|--------------------------|------------------------|--|---|
| UIII    | LVEHI NUMBER | Event Type                            | LVEIIL BEGIII Date LVE | ent begin mine L | venit Liiu Date L | vent thu nine tv | rent Duration Cause Code | Cause Code Description | inditative   | Net Available Capacity Net Depelluable Capacity |
| BS CT1( | C) 25 F      | Reserve Shutdown                      | 3/7/2021               | 8:41:00          | 3/7/2021          | 17:15:00         | 8.57                     |                        | Reserve Shutdown   | 183   |
| BS CT1( | C) 26 F      | Reserve Shutdown                      | 3/10/2021              | 23:32:00         | 3/11/2021         | 6:30:00          | 6.97                     |                        | Reserve Shutdown   | 183   |
| BS CT1( | C) 27 F      | Reserve Shutdown                      | 3/12/2021              | 0:14:00          | 3/12/2021         | 2:28:00          | 2.23                     |                        | Reserve Shutdown   | 183   |
| BS CT1( | C) 28 L      | Unplanned (Forced) Outage - Immediate | 3/20/2021              | 23:35:00         | 3/21/2021         | 2:00:00          | 2.42 5120                | Hydraulic oil system   | 1C tripped offline due to momentary dip in trip oil pressure, causing gas valves to cl | 183   |
| BS CT1( | C) 29 F      | Reserve Shutdown                      | 3/21/2021              | 2:00:00          | 3/21/2021         | 4:30:00          | 2.5                      |                        | Reserve Shutdown   | 183   |
| BS CT1( | C) 30 L      | Unplanned (Forced) Outage - Immediate | 3/21/2021              | 4:30:00          | 3/21/2021         | 14:26:00         | 9.93                     |                        | 1C CT was made unavailable due to 1B CT's forced outage repairing pole top switches or | n 183   |
| BS CT1( | C) 31 F      | Reserve Shutdown                      | 3/21/2021              | 14:26:00         | 3/24/2021         | 16:35:00         | 74.15                    |                        | Reserve Shutdown   | 183   |
| BS CT1( | C) 32 F      | Reserve Shutdown                      | 3/25/2021              | 0:04:00          | 3/25/2021         | 13:58:00         | 13.9                     |                        | Reserve Shutdown   | 183   |
| BS CT1( | C) 33 F      | Reserve Shutdown                      | 3/26/2021              | 0:30:00          | 3/26/2021         | 12:06:00         | 11.6                     |                        | Reserve Shutdown   | 183   |
| BS CT1( | C) 34 F      | Reserve Shutdown                      | 3/26/2021              | 21:59:00         | 3/27/2021         | 11:38:00         | 13.65                    |                        | Reserve Shutdown   | 183   |
| BS CT1( | C) 35 F      | Reserve Shutdown                      | 3/29/2021              | 1:39:00          | 3/29/2021         | 16:20:00         | 14.68                    |                        | Reserve Shutdown   | 183   |

| Unit Event I | Number Event Type                          | Event Begin Date Eve | ent Begin Time E | vent End Date E | vent End Time Eve | ent Duration Cause Code | Cause Code Description                                   | Narrative   | Net Available Capacity Net Dep | pendable Capacity |
|--------------|--|----------------------|------------------|-----------------|-------------------|-------------------------|--|---|--------------------------------|-------------------|
| BS ST 1      | 6 Maintenance Derating                     | 3/13/2021            | 0:29:00          | 3/20/2021       | 12:00:00          | 178.52 3999             | Other miscellaneous balance of plant problems Planned I  | EBI for 1B CT, Inlet air filters also changed during this time.               | 164                            | 243               |
| BS ST 1      | 7 Maintenance Derating                     | 3/14/2021            | 23:55:00         | 3/20/2021       | 12:00:00          | 132.08 3999             | Other miscellaneous balance of plant problems Planned of | outage to perform EBI inspection on 1A CT, and Inlet filter replacements.     | 85                             | 243               |
| BS ST 1      | 8 Maintenance Derating                     | 3/20/2021            | 12:00:00         | 3/20/2021       | 23:38:00          | 11.63 3999              | Other miscellaneous balance of plant problems Planned of | outage to perform EBI inspection on 1A CT, and Inlet filter replacements.     | 160                            | 243               |
| BS ST 1      | 9 Unplanned (Forced) Outage - Immediate    | 3/20/2021            | 23:38:00         | 3/21/2021       | 2:00:00           | 2.37 3999               | Other miscellaneous balance of plant problems ST 1 tripp | ped offline when 1C CT/HRSG tripped offline, this is because 1C CT was the on |                                | 243               |
| BS ST 1      | 10 Reserve Shutdown                        | 3/21/2021            | 2:00:00          | 3/21/2021       | 4:30:00           | 2.5                     | Reserve S  | Shutdown  |                                | 243               |
| BS ST 1      | 11 Unplanned (Forced) Outage - Immediate   | 3/21/2021            | 4:30:00          | 3/21/2021       | 13:50:00          | 9.33 3999               | Other miscellaneous balance of plant problems With 1A i  | in planned outage, and 1B and 1C in forced outages, we had no Steam Supply t  | 0                              | 243               |
| BS ST 1      | 12 Reserve Shutdown                        | 3/21/2021            | 13:50:00         | 3/21/2021       | 17:27:00          | 3.62                    | Reserve S  | Shutdown  |                                | 243               |
| BS ST 1      | 13 Maintenance Derating                    | 3/21/2021            | 17:27:00         | 3/21/2021       | 23:00:00          | 5.55 3999               | Other miscellaneous balance of plant problems 1A Bores   | cope Inspection   | 164                            | 243               |
| BS ST 1      | 14 Unplanned (Forced) Derating - Immediate | e 3/21/2021          | 23:00:00         | 3/31/2021       | 0:00:00           | 217 3999                | Other miscellaneous balance of plant problems 1A entere  | ed into a forced outage to facilitate the repair of 3rd Stage Buckets.        | 164                            | 243               |



| Unit E    | vent Number Event Type | Event Begin Date Ev | vent Begin Time E | vent End Date Ev | ent End Time Eve | ent Duration Cause Code | Cause Code Description | Narrative                | Net Available Capacity Net Dependable Capacity |
|-----------|------------------------|---------------------|-------------------|------------------|------------------|-------------------------|------------------------|--------------------------|--|
| BS CT2(A) | 9 Reserve Shutdown     | 3/3/2021            | 22:25:00          | 3/4/2021         | 16:24:00         | 17.98                   |                        | Reserve Shutdown         | 183  |
| BS CT2(A) | 10 Reserve Shutdown    | 3/7/2021            | 23:25:00          | 3/8/2021         | 7:28:00          | 8.05                    |                        | Reserve Shutdown         | 183  |
| BS CT2(A) | 11 Maintenance Outage  | e 3/8/2021          | 7:28:00           | 3/11/2021        | 17:15:00         | 81.78 5272              | Borescope inspection   | 2A EBI Inspection needed | 183  |
| BS CT2(A) | 12 Reserve Shutdown    | 3/11/2021           | 17:15:00          | 3/11/2021        | 18:38:00         | 1.38                    |                        | Reserve Shutdown         | 183  |
| BS CT2(A) | 13 Reserve Shutdown    | 3/24/2021           | 9:40:00           | 3/25/2021        | 5:30:00          | 19.83                   |                        | Reserve Shutdown         | 183  |
| BS CT2(A) | 14 Reserve Shutdown    | 3/26/2021           | 23:18:00          | 3/27/2021        | 12:44:00         | 13.43                   |                        | Reserve Shutdown         | 183  |

| Unit      | Event Number Event Type | Event Begin Date E | vent Begin Time E | vent End Date E | vent End Time Ev | ent Duration Cause | Code Cause Code Description Narrative | Net Available Capacity Net Dependable Capacity |
|-----------|-------------------------|--------------------|-------------------|-----------------|------------------|--------------------|---------------------------------------|--|
| BS CT2(B) | 6 Reserve Shutdowr      | 3/14/2021          | 22:35:00          | 3/14/2021       | 23:20:00         | 0.75               | Reserve Shutdown                      | 183  |
| BS CT2(B) | 7 Reserve Shutdowr      | 3/20/2021          | 0:16:00           | 3/20/2021       | 16:52:00         | 16.6               | Reserve Shutdown                      | 183  |
| BS CT2(B) | 8 Reserve Shutdowr      | 3/22/2021          | 23:51:00          | 3/23/2021       | 17:13:00         | 17.37              | Reserve Shutdown                      | 183  |
| BS CT2(B) | 9 Reserve Shutdowr      | 3/28/2021          | 2:23:00           | 3/28/2021       | 10:54:00         | 8.52               | Reserve Shutdown                      | 183  |

Tampa Electric Company
Outage Listing
March 2021

| Unit Ev   | ent Number Event Type Ev | vent Begin Date Even | nt Begin Time Ev | vent End Date Ev | ent End Time Eve | ent Duration Cause C | Code Cause Code Description | Narrative | Net Available Capacity Net Dependable Capacity |
|-----------|--------------------------|----------------------|------------------|------------------|------------------|----------------------|-----------------------------|-----------|--|
| BS CT2(C) | 34 Reserve Shutdown      | 3/11/2021            | 23:24:00         | 3/12/2021        | 10:52:00         | 11.47                | Reserve Shutdown            |           | 183  |
| BS CT2(C) | 35 Reserve Shutdown      | 3/14/2021            | 0:50:00          | 3/14/2021        | 12:55:00         | 12.08                | Reserve Shutdown            |           | 183  |
| BS CT2(C) | 36 Reserve Shutdown      | 3/14/2021            | 21:54:00         | 3/15/2021        | 16:33:00         | 18.65                | Reserve Shutdown            |           | 183  |
| BS CT2(C) | 37 Reserve Shutdown      | 3/16/2021            | 23:16:00         | 3/17/2021        | 12:42:00         | 13.43                | Reserve Shutdown            |           | 183  |
| BS CT2(C) | 38 Reserve Shutdown      | 3/17/2021            | 23:15:00         | 3/18/2021        | 6:16:00          | 7.02                 | Reserve Shutdown            |           | 183  |
| BS CT2(C) | 39 Reserve Shutdown      | 3/19/2021            | 0:00:00          | 3/19/2021        | 6:42:00          | 6.7                  | Reserve Shutdown            |           | 183  |
| BS CT2(C) | 40 Reserve Shutdown      | 3/19/2021            | 21:32:00         | 3/23/2021        | 5:40:00          | 80.13                | Reserve Shutdown            |           | 183  |
| BS CT2(C) | 41 Reserve Shutdown      | 3/23/2021            | 23:42:00         | 3/25/2021        | 16:20:00         | 40.63                | Reserve Shutdown            |           | 183  |
| BS CT2(C) | 42 Reserve Shutdown      | 3/27/2021            | 1:49:00          | 3/27/2021        | 15:14:00         | 13.42                | Reserve Shutdown            |           | 183  |
| BS CT2(C) | 43 Reserve Shutdown      | 3/28/2021            | 0:36:00          | 3/28/2021        | 10:11:00         | 9.58                 | Reserve Shutdown            |           | 183  |
| BS CT2(C) | 44 Reserve Shutdown      | 3/29/2021            | 0:17:00          | 3/29/2021        | 7:53:00          | 7.6                  | Reserve Shutdown            |           | 183  |
| BS CT2(C) | 45 Reserve Shutdown      | 3/30/2021            | 0:11:00          | 3/30/2021        | 12:06:00         | 11.92                | Reserve Shutdown            |           | 183  |

Tampa Electric Company
Outage Listing
March 2021

| Unit E    | Event Number Event Type | Event Begin Date Eve | ent Begin Time Ev | vent End Date Ev | ent End Time Ev | ent Duration Cau | ise Code Cause Code Description | Narrative Net Available Capacity Net Dependable Capacity |
|-----------|-------------------------|----------------------|-------------------|------------------|-----------------|------------------|---------------------------------|--|
| BS CT2(D) | 21 Reserve Shutdown     | 3/6/2021             | 23:56:00          | 3/7/2021         | 16:11:00        | 16.25            | Reserve Shutdown                | 183  |
| BS CT2(D) | 22 Reserve Shutdown     | 3/10/2021            | 0:18:00           | 3/10/2021        | 7:16:00         | 6.97             | Reserve Shutdown                | 183  |
| BS CT2(D) | 23 Reserve Shutdown     | 3/13/2021            | 7:58:00           | 3/13/2021        | 14:59:00        | 7.02             | Reserve Shutdown                | 183  |
| BS CT2(D) | 24 Reserve Shutdown     | 3/14/2021            | 20:22:00          | 3/15/2021        | 7:32:00         | 11.17            | Reserve Shutdown                | 183  |
| BS CT2(D) | 25 Reserve Shutdown     | 3/15/2021            | 22:46:00          | 3/16/2021        | 12:32:00        | 13.77            | Reserve Shutdown                | 183  |
| BS CT2(D) | 26 Reserve Shutdown     | 3/16/2021            | 23:56:00          | 3/17/2021        | 14:59:00        | 15.05            | Reserve Shutdown                | 183  |
| BS CT2(D) | 27 Reserve Shutdown     | 3/18/2021            | 1:09:00           | 3/18/2021        | 9:29:00         | 8.33             | Reserve Shutdown                | 183  |
| BS CT2(D) | 28 Reserve Shutdown     | 3/19/2021            | 1:18:00           | 3/24/2021        | 14:29:00        | 133.18           | Reserve Shutdown                | 183  |
| BS CT2(D) | 29 Reserve Shutdown     | 3/24/2021            | 22:29:00          | 3/25/2021        | 13:33:00        | 15.07            | Reserve Shutdown                | 183  |
| BS CT2(D) | 30 Reserve Shutdown     | 3/25/2021            | 21:34:00          | 3/26/2021        | 13:37:00        | 16.05            | Reserve Shutdown                | 183  |
| BS CT2(D) | 31 Reserve Shutdown     | 3/27/2021            | 22:28:00          | 3/28/2021        | 9:37:00         | 11.15            | Reserve Shutdown                | 183  |
| BS CT2(D) | 32 Reserve Shutdown     | 3/28/2021            | 23:20:00          | 3/29/2021        | 6:21:00         | 7.02             | Reserve Shutdown                | 183  |
| BS CT2(D) | 33 Reserve Shutdown     | 3/29/2021            | 22:43:00          | 3/30/2021        | 5:55:00         | 7.2              | Reserve Shutdown                | 183  |
| BS CT2(D) | 34 Reserve Shutdown     | 3/30/2021            | 23:17:00          | 3/31/2021        | 14:43:00        | 15.43            | Reserve Shutdown                | 183  |
| BS CT2(D) | 35 Reserve Shutdown     | 3/31/2021            | 23:28:00          | 3/31/2021        | 23:59:00        | 0.53             | Reserve Shutdown                | 183  |

| Unit Event Nur | mber Event Type       | Event Begin Date Ev | ent Begin Time E | vent End Date E | vent End Time Ev | ent Duration Cause Code | Cause Code Description                            | Narrative            | Net Available CapacityNet Dep | endable Capacity |
|----------------|-----------------------|---------------------|------------------|-----------------|------------------|-------------------------|---|----------------------|-------------------------------|------------------|
| BS ST 2        | 4 Maintenance Deratir | ոչ 3/8/2021         | 7:28:00          | 3/11/2021       | 17:15:00         | 81.78 3999              | Other miscellaneous balance of plant problem 2A E | BI Inspection needed | 238                           | 315              |

| Unit       | Event<br>Number | Event Type                          | Event Begin<br>Date | Event Begin<br>Time | Event End<br>Date | Event End Time | Event<br>Duration | Cause<br>Code | Cause Code Description                     | Narrative  | Net Available<br>Capacity | Net Dependable<br>Capacity |
|------------|-----------------|-------------------------------------|---------------------|---------------------|-------------------|----------------|-------------------|---------------|--|--|---------------------------|----------------------------|
| Big Bend 4 | 8 Uni           | planned (Forced) Outage - Immediate | 3/27/2021           | 15:54:00            | 3/27/202          | 1 19:18:00     | 3.4               | 8260          | Scrubber booster I.D. fan (fan specific to | th D Booster fan tripped on high vibration limits, causing a unit trip.                |                           | 432                        |
| Big Bend 4 | 9 Uni           | planned (Forced) Outage - Immediate | 3/27/2021           | 19:28:00            | 3/27/202          | 1 20:23:00     | 0.92              | 4250          | Other low pressure turbine problems        | Turbine exhaust hood temperature exceeded limits, causing a unit trip.                 |                           | 432                        |
| Big Bend 4 | 10 Plan         | nned Outage                         | 3/27/2021           | 23:50:00            | 3/31/202          | 1 23:59:00     | 96.17             | 1035          | Platen superheater                         | Planned outage. Boiler tube inspections.https://portal.spsinc.com/Home/Index/?primaryi |                           | 432                        |

| Unit Event | Number Event Type                          | Event Begin Date Eve | nt Begin Time E | vent End Date E | vent End Time Eve | ent Duration Cause Code | Cause Code Description | Narrative   | Net Available Capacity Net Dependable Capacity |
|------------|--|----------------------|-----------------|-----------------|-------------------|-------------------------|------------------------|---|--|
| Polk 1     | 8 Reserve Shutdown                         | 3/3/2021             | 0:11:00         | 3/14/2021       | 9:28:00           | 272.28                  |                        | Reserve Shutdown  | 180  |
| Polk 1     | 9 Unplanned (Forced) Outage - Immediate    | 3/14/2021            | 9:53:00         | 3/15/2021       | 0:00:00           | 14.12 0775              | Economizer piping      | Forced outage just after startup, due to LP Economizer tube leak                      | 180  |
| Polk 1     | 10 Reserve Shutdown                        | 3/15/2021            | 0:00:00         | 3/19/2021       | 15:59:00          | 111.98                  |                        | Reserve Shutdown  | 180  |
| Polk 1     | 11 Unplanned (Forced) Outage - Immediate   | 3/25/2021            | 7:17:00         | 3/25/2021       | 8:23:00           | 1.1 5042                | Fuel nozzles           | Unit tripped on flame instability flameout while increasing load from minimum to base | 180  |
| Polk 1     | 12 Unplanned (Forced) Derating - Immediate | 3/25/2021            | 8:23:00         | 3/31/2021       | 0:00:00           | 135.62 5042             | Fuel nozzles           | Unit tripped on flame instability/flameout while increasing load from minimum to base | 110 180  |

| Unit      | Event Number Event Type                  | Event Begin Date Ev | ent Begin Time E | vent End Date Ev | vent End Time Ever | nt Duration Cause Code | Cause Code Description Narrative   | Net Available Capacity Net Dependable Capacity |
|-----------|--|---------------------|------------------|------------------|--------------------|------------------------|--|--|
| Polk 1 ST | 9 Reserve Shutdown                       | 3/3/2021            | 0:00:00          | 3/14/2021        | 9:53:00            | 272.88                 | Reserve Shutdown   | 50   |
| Polk 1 ST | 10 Unplanned (Forced) Outage - Immediat  | e 3/14/2021         | 9:53:00          | 3/15/2021        | 0:00:00            | 14.12 3999             | Other miscellaneous balance of plant problems Forced outage just after startup, due to LP Economizer tube leak                   | 50   |
| Polk 1 ST | 11 Reserve Shutdown                      | 3/15/2021           | 0:00:00          | 3/19/2021        | 18:09:00           | 114.15                 | Reserve Shutdown   | 50   |
| Polk 1 ST | 12 Reserve Shutdown                      | 3/19/2021           | 18:11:00         | 3/19/2021        | 19:17:00           | 1.1                    | Reserve Shutdown   | 50   |
| Polk 1 ST | 13 Reserve Shutdown                      | 3/25/2021           | 7:20:00          | 3/25/2021        | 9:31:00            | 2.18                   |  | 50   |
| Polk 1 ST | 14 Unplanned (Forced) Derating - Immedia | ate 3/25/2021       | 8:23:00          | 3/31/2021        | 0:00:00            | 135.62 3999            | Other miscellaneous balance of plant problems Unit tripped on flame instability/flameout while increasing load from minimum to b | ase 43 50                                      |

| Unit Event N | umber Event Type                         | Event Begin Date Eve | nt Begin Time E | vent End Date Ev | ent End Time Ev | ent Duration Cause Code | e Cause Code Description | Narrative  | Net Available Capacity Net Dependable Capacity |
|--------------|--|----------------------|-----------------|------------------|-----------------|-------------------------|--------------------------|--|--|
| Polk 2       | 41 Reserve Shutdown                      | 3/1/2021             | 0:00:00         | 3/1/2021         | 10:26:00        | 10.43                   |                          | Reserve Shutdown   | 180  |
| Polk 2       | 42 Reserve Shutdown                      | 3/2/2021             | 0:16:00         | 3/2/2021         | 10:01:00        | 9.75                    |                          | Reserve Shutdown   | 180  |
| Polk 2       | 43 Reserve Shutdown                      | 3/2/2021             | 22:10:00        | 3/9/2021         | 17:56:00        | 163.77                  |                          | Reserve Shutdown   | 180  |
| Polk 2       | 44 Reserve Shutdown                      | 3/9/2021             | 21:55:00        | 3/12/2021        | 2:29:00         | 52.57                   |                          | Reserve Shutdown   | 180  |
| Polk 2       | 45 Unplanned (Forced) Outage - Immediate | 3/12/2021            | 12:14:00        | 3/12/2021        | 13:01:00        | 0.78 9590               | Miscellaneous regulatory | While Starting #2 Steam Turbine, permitted run time at low CT load (with excess emissi | 180  |
| Polk 2       | 46 Reserve Shutdown                      | 3/12/2021            | 23:39:00        | 3/13/2021        | 0:57:00         | 1.3                     |                          | Reserve Shutdown   | 180  |
| Polk 2       | 47 Reserve Shutdown                      | 3/13/2021            | 23:21:00        | 3/14/2021        | 12:30:00        | 12.15                   |                          | Reserve Shutdown   | 180  |
| Polk 2       | 48 Reserve Shutdown                      | 3/15/2021            | 0:43:00         | 3/15/2021        | 13:12:00        | 12.48                   |                          | Reserve Shutdown   | 180  |
| Polk 2       | 49 Reserve Shutdown                      | 3/16/2021            | 0:29:00         | 3/16/2021        | 12:09:00        | 11.67                   |                          | Reserve Shutdown   | 180  |
| Polk 2       | 50 Reserve Shutdown                      | 3/23/2021            | 22:23:00        | 3/24/2021        | 13:41:00        | 15.3                    |                          | Reserve Shutdown   | 180  |
| Polk 2       | 51 Reserve Shutdown                      | 3/25/2021            | 1:16:00         | 3/25/2021        | 11:48:00        | 10.53                   |                          | Reserve Shutdown   | 180  |
| Polk 2       | 52 Reserve Shutdown                      | 3/31/2021            | 0:27:00         | 3/31/2021        | 10:34:00        | 10.12                   |                          | Reserve Shutdown   | 180  |

| Unit     | Event Number | Event Type                        | Event Begin Date | Event Begin Time Ev | vent End Date | Event End Time Eve | ent Duration Cause Code | Cause Code Description                  | Narrative   | Net Available Capacity Net Dependable Capacity |
|----------|--------------|-----------------------------------|------------------|---------------------|---------------|--------------------|-------------------------|---|---|--|
| Polk 2 S | T 2 Plann    | ned Outage                        | 3/1/2021         | 0:00:00             | 3/12/2021     | 12:13:00           | 276.22 4260             | Main stop valves                        | STG2 Minor inspection of Turbine Stop and Control Valves and bearings. More specifica         | 480  |
| Polk 2 S | T 2 Plann    | ned Outage                        | 3/1/2021         | 0:00:00             | 3/1/2021      | 0:00:00            | 0 4260                  | Main stop valves                        | STG2 Minor inspection of Turbine Stop and Control Valves and bearings. More specifica         | 480  |
| Polk 2 S | T 3 Unpla    | anned (Forced) Outage - Immediate | e 3/12/2021      | 12:14:00            | 3/13/2021     | 3:27:00            | 15.22 3999              | Other miscellaneous balance of plant pr | roblems CTG2 caused Forced Outage. CTG2 had run to support the STG2 startup, for the number o | 480  |
| Polk 2 S | T 4 Unpla    | anned (Forced) Outage - Immediate | e 3/13/2021      | 3:47:00             | 3/13/2021     | 4:08:00            | 0.35 4260               | Main stop valves                        | HRSG2. Improper operation of the steam dump valves during STG2 start-up caused STG2 to        | r 480  |
| Polk 2 S | T 5 Unpla    | anned (Forced) Outage - Immediate | e 3/13/2021      | 12:49:00            | 3/13/2021     | 17:28:00           | 4.65 4260               | Main stop valves                        | HRSG2 Hot Reheat Valve went shut during bringing GTG4 on line. When the valve went shu        | u 480  |
| Polk 2 S | T 6 Main     | tenance Derating                  | 3/22/2021        | 21:40:00            | 3/31/2021     | 0:00:00            | 194.33 3999             | Other miscellaneous balance of plant pr | roblems Unit 4 CT off line for planned maintenance  | 355 480  |

| Unit Even | it Number Event Type Ev | ent Begin Date Eve | nt Begin Time Ev | ent End Date Ev | ent End Time Eve | ent Duration Cause | e Code Cause Code Description Narra | tive Net Available Capacity Net Dependable Capacity |
|-----------|-------------------------|--------------------|------------------|-----------------|------------------|--------------------|-------------------------------------|---|
| Polk 3    | 30 Reserve Shutdown     | 3/1/2021           | 0:00:00          | 3/1/2021        | 12:09:00         | 12.15              | Reserve Shutdown                    | 180   |
| Polk 3    | 31 Reserve Shutdown     | 3/1/2021           | 22:36:00         | 3/2/2021        | 10:48:00         | 12.2               | Reserve Shutdown                    | 180   |
| Polk 3    | 32 Reserve Shutdown     | 3/2/2021           | 21:37:00         | 3/8/2021        | 17:46:00         | 140.15             | Reserve Shutdown                    | 180   |
| Polk 3    | 33 Reserve Shutdown     | 3/8/2021           | 22:53:00         | 3/9/2021        | 17:38:00         | 18.75              | Reserve Shutdown                    | 180   |
| Polk 3    | 34 Reserve Shutdown     | 3/9/2021           | 20:46:00         | 3/11/2021       | 16:41:00         | 43.92              | Reserve Shutdown                    | 180   |
| Polk 3    | 35 Reserve Shutdown     | 3/11/2021          | 20:42:00         | 3/12/2021       | 16:30:00         | 19.8               | Reserve Shutdown                    | 180   |
| Polk 3    | 36 Reserve Shutdown     | 3/12/2021          | 22:15:00         | 3/13/2021       | 15:41:00         | 17.43              | Reserve Shutdown                    | 180   |
| Polk 3    | 37 Reserve Shutdown     | 3/13/2021          | 21:26:00         | 3/14/2021       | 15:07:00         | 16.68              | Reserve Shutdown                    | 180   |
| Polk 3    | 38 Reserve Shutdown     | 3/18/2021          | 0:33:00          | 3/18/2021       | 12:21:00         | 11.8               | Reserve Shutdown                    | 180   |
| Polk 3    | 39 Reserve Shutdown     | 3/26/2021          | 0:16:00          | 3/26/2021       | 9:56:00          | 9.67               | Reserve Shutdown                    | 180   |

| Unit Event | Number Event Type Eve | ent Begin Date Eve | ent Begin Time E | vent End Date Ev | ent End Time Eve | ent Duration Cause Cod | e Cause Code Description | Narrative  | Net Available CapacityNet Dependable Capacity |
|------------|-----------------------|--------------------|------------------|------------------|------------------|------------------------|--------------------------|--|---|
| Polk 4     | 19 Reserve Shutdown   | 3/1/2021           | 0:00:00          | 3/1/2021         | 14:01:00         | 14.02                  |                          | Reserve Shutdown   | 180   |
| Polk 4     | 20 Reserve Shutdown   | 3/1/2021           | 21:18:00         | 3/2/2021         | 13:35:00         | 16.28                  |                          | Reserve Shutdown   | 180   |
| Polk 4     | 21 Reserve Shutdown   | 3/2/2021           | 20:00:00         | 3/8/2021         | 6:19:00          | 130.32                 |                          | Reserve Shutdown   | 180   |
| Polk 4     | 22 Reserve Shutdown   | 3/8/2021           | 9:15:00          | 3/12/2021        | 17:22:00         | 104.12                 |                          | Reserve Shutdown   | 180   |
| Polk 4     | 23 Reserve Shutdown   | 3/12/2021          | 19:54:00         | 3/13/2021        | 10:52:00         | 14.97                  |                          | Reserve Shutdown   | 180   |
| Polk 4     | 24 Planned Outage     | 3/22/2021          | 21:51:00         | 3/31/2021        | 23:59:00         | 218.15 5270            | Hot end inspection       | Scheduled outage for CT hot gas path inspection and generator inspection | 180   |

| Unit Event | Number Event Type Ev | ent Begin Date Eve | ent Begin Time Ev | vent End Date Ev | ent End Time Eve | ent Duration Cau | ise Code Cause Code Description | Narrative | Net Available Capacity Net Dependable Capacity |
|------------|----------------------|--------------------|-------------------|------------------|------------------|------------------|---------------------------------|-----------|--|
| Polk 5     | 19 Reserve Shutdown  | 3/1/2021           | 0:00:00           | 3/1/2021         | 12:37:00         | 12.62            | Reserve Shutdown                |           | 180  |
| Polk 5     | 20 Reserve Shutdown  | 3/1/2021           | 21:52:00          | 3/2/2021         | 11:52:00         | 14               | Reserve Shutdown                |           | 180  |
| Polk 5     | 21 Reserve Shutdown  | 3/2/2021           | 20:49:00          | 3/3/2021         | 16:51:00         | 20.03            | Reserve Shutdown                |           | 180  |
| Polk 5     | 22 Reserve Shutdown  | 3/3/2021           | 20:54:00          | 3/8/2021         | 4:24:00          | 103.5            | Reserve Shutdown                |           | 180  |
| Polk 5     | 23 Reserve Shutdown  | 3/8/2021           | 8:21:00           | 3/9/2021         | 5:39:00          | 21.3             | Reserve Shutdown                |           | 180  |
| Polk 5     | 24 Reserve Shutdown  | 3/9/2021           | 8:40:00           | 3/10/2021        | 17:28:00         | 32.8             | Reserve Shutdown                |           | 180  |
| Polk 5     | 25 Reserve Shutdown  | 3/10/2021          | 22:10:00          | 3/12/2021        | 14:21:00         | 40.18            | Reserve Shutdown                |           | 180  |
| Polk 5     | 26 Reserve Shutdown  | 3/12/2021          | 20:55:00          | 3/13/2021        | 12:55:00         | 16               | Reserve Shutdown                |           | 180  |
| Polk 5     | 27 Reserve Shutdown  | 3/13/2021          | 20:22:00          | 3/14/2021        | 15:49:00         | 18.45            | Reserve Shutdown                |           | 180  |
| Polk 5     | 28 Reserve Shutdown  | 3/18/2021          | 22:27:00          | 3/22/2021        | 12:06:00         | 85.65            | Reserve Shutdown                |           | 180  |
| Polk 5     | 29 Reserve Shutdown  | 3/27/2021          | 0:26:00           | 3/27/2021        | 7:33:00          | 7.12             | Reserve Shutdown                |           | 180  |