

FILED 3/31/2025 DOCUMENT NO. 02385-2025 FPSC - COMMISSION CLERK 123 South Calhoun Street

Attorneys and Counselors at Law 123 South Calhoun Street P.O. Box 391 32302 Tallahassee, FL 32301

P: (850) 224-9115 F: (850) 222-7560

ausley.com

March 31, 2025

# VIA: ELECTRONIC FILING

Mr. Adam J. Teitzman Commission Clerk Florida Public Service Commission 2540 Shumard Oak Boulevard Tallahassee, Florida 32399-0850

# Re: Tampa Electric Company's Petition for Approval of 2026-2035 Storm Protection Plan Dkt. No.: 20250016-EI

Dear Mr. Teitzman:

Attached for filing in the above docket on behalf of Tampa Electric Company are revised Bates Pages 74, 98, 101-104, 114, 205, and 207 in the Direct Testimony of Kevin Palladino and Exhibit KEP-1 (DN 00267-2025) and Bates Page 37 in the Direct Testimony of Jason D. DeStigter (DN 00268-2025). A description of these changes is included below:

- (1) Tampa Electric is revising Bates Pages 74, 98, 205, and 207 in Mr. Palladino's testimony and Bates Page 37 in Mr. DeStigter's testimony to remove references to the term "prudent" in response to objections raised by the Office of Public Counsel; and
- (2) Tampa Electric is revising Bates Pages 101-104 and 114 to provide revised estimated customer counts for projects planned in the first year of the company's 2026-2035 Storm Protection Plan in response to issues raised by the Office of Public Counsel.

Thank you for your assistance in connection with this matter.

Sincerely,

holiden n. Mean

Malcolm N. Means

MNM/bml Attachment cc: Walt Trierweiler, Office of Public Counsel TECO Regulatory

TAMPA ELECTRIC COMPANY DOCKET NO. 20250016-EI EXHIBIT NO. KEP-1 WITNESS: PALLADINO PAGE 54 OF 58 FILED: 01/15/2025 REVISED: 03/31/2025

## 5.4 Storm Protection Plan Program Budget Levels

Based on the experience from the two previous SPPs, Tampa Electric is able to provide more consistent annual targets for the SPP which results in a more consistent overall budget. For example:

- Distribution Lateral Undergrounding targets are between 65 to 85 miles converted annually
- Distribution Overhead Feeder Hardening targets are between 20 to 30 circuits completed
- Transmission Asset Upgrade circuits range from 10 to 15
- Vegetation Management targets are also consistent with the fouryear goal of around 1,500 distribution miles.
  - o 500 700 miles of Supplemental Distribution
  - o 700 1,000 miles of Mid-Cycle Distribution
  - o Around 500 miles of annual Transmission

As such, Tampa Electric strives to obtain these targets each year to harden our electric system in a focused, structured, and prudent thoughtful manner.

## 6. Storm Protection Plan Estimated Rate Impacts

Tampa Electric prepared estimated rate impacts for 2026, 2027, and 2028 of the proposed SPP.

Each year's costs derive from the Programs described in this SPP. For each Program, the capital-related costs, depreciation and return, and O&M costs are combined into a revenue requirement. For each year, the SPP Programs were itemized and identified as to whether they are substation, transmission, or distribution costs.

Tampa Electric applied the methodology that was established by the Commission in the company's most recent base rate proceeding to

TAMPA ELECTRIC COMPANY DOCKET NO. 20250016-EI EXHIBIT NO. KEP-1 WITNESS: PALLADINO APPENDIX B PAGE 17 OF 18 FILED: 01/15/2025 REVISED: 03/31/2025

resistance of control cabinets and related equipment. Prudent <u>Carefully considered</u> modifications will be made. Consideration will be given to whether there will be load to be served in the area of the substation immediately after a storm and if any load can be served from adjacent substations that are outside the flooded area.

### 5.1.5 Other

When transformers are added to an existing substation or a transformer is upgraded, if needed, existing fences are removed, and new fences are installed to meet or exceed current NESC wind and height standards. At the same time, animal protection covers are installed on all 13kV bushings, lightning arrestors, switches and leads. This helps prevent damage from debris that gets inside the substation.

#### 5.2 Construction Standards

Tampa Electric uses galvanized tubular steel structures in new distribution substations. The tallest structure is approximately 24 feet above grade, with most of the structures and equipment being below 17 feet. Distribution feeder circuits are designed to exit the substation via underground cables installed inside a six-inch conduit.

In 230kV substations and 69kV switching stations, control buildings are used to house protection relays, communication equipment, Remote Terminal Unit ("RTU") monitoring equipment and substation battery systems. Previous construction methods used concrete block construction with poured concrete columns and concrete roof panels, which are designed to withstand winds of 120 mph without any damage to the building or the equipment housed inside. Control buildings currently being installed are prefabricated metal buildings designed for 150 mph wind loading. Tampa Electric installs eight-foot-tall perimeter chain link fences designed to 120 mph or walls designed to 125 mph. This

Specific Project Detail
OH to UG Length Converted (miles)
1.53
1.31
0.71
0.62
1.26
1.40
2.18
0.87
2.55
1.18
0.99
0.61
0.44
0.38
0.16
0.54
0.98
0.22
3.26
0.67
0.21
1.16
0.34
0.00
20.00
0.27
1.07
0.64
0.73
0.39
0.42
1.13
1.23
α α

TAMPA ELECTRIC COMPANY DOCKET NO. 20250016-EI EXHIBIT NO. KEP-1 WITNESS: PALLADINO APPENDIX C PAGE 2 OF 5 FILED: 01/15/2025 REVISED: 03/31/2025

Tampa	Electric'	s Distribut	ion Lateral	Undergro	ounding	- Year	2026 Det	tails		
		Specific Project Detail		Custome:	rs		Project	Constr	ruction	Project
Project ID	Circuit No.	OH to UG Length Converted (miles)	Residential	Small C&I	Large C&I	Total	Start Qtr	Start Qtr	End Qtr	Cost in 2026
LUG CSA 13837.91812632	13837	0.41	160	16	5	182	Q2 - 2026	Q2 - 2027	Q3 - 2027	\$501,425
LUG WSA 13082.60073788	13082	0.85	40	4	1	46	Q2 - 2026	Q2 - 2027	Q3 - 2027	\$1,100,883
LUG CSA 13093.60029776	13093	0.46	56	6	2	64	Q2 - 2026	Q2 - 2027	Q3 - 2027	\$593,778
LUG WSA 13754.90847913	13754	0.34	54	5	2	61	Q2 - 2026	Q2 - 2027	Q3 - 2027	\$408,728
LUG WSA 13078.10127937	13078	1.60	50	5	2	57	Q2 - 2026	Q2 - 2027	Q3 - 2027	\$2,078,209
LUG ESA 13127.90334707	13127	0.36	136	14	5	154	Q2 - 2026	Q2 - 2027	Q3 - 2027	\$486,818
LUG WSA 13072.10165789	13072	0.48	28	3	1	32	Q2 - 2026	Q2 - 2027	Q3 - 2027	\$624,000
LUG WSA 13217.92097014	13217	0.63	16	2	1	18	Q2 - 2026	Q2 - 2027	Q3 - 2027	\$820,263
LUG WSA 13611.10092875	13611	0.67	107	11	4	122	Q2 - 2026	Q2 - 2027	Q3 - 2027	\$872,016
LUG ESA 13906.92282884	13906	0.10	26	3	1	29	Q2 - 2026	Q2 - 2027	Q3 - 2027	\$128,864
LUG CSA 13748.60111391	13748	0.73	70	7	2	80	Q2 - 2026	Q2 - 2027	Q3 - 2027	\$891,363
LUG DCA 13330.92197131	13330	1.17	67	7	2	76	Q2 - 2026	Q2 - 2027	Q3 - 2027	\$1,521,000
LUG WSA 13510.10218987	13510	0.15	193	20	7	219	Q2 - 2026	Q2 - 2027	Q3 - 2027	\$195,000
LUG WSA 13191.10173522	13191	0.50	33	3	1	37	Q2 - 2026	Q2 - 2027	Q3 - 2027	\$650,553
LUG WSA 13063.10124545	13063	0.51	41	4	1	47	Q2 - 2026	Q2 - 2027	Q3 - 2027	\$693,497
LUG CSA 13218.60318065	13218	0.50	116	12	4	132	Q2 - 2026	Q2 - 2027	Q3 - 2027	\$614,067
LUG WSA 13740.60614298	13740	1.01	29	3	1	33	Q2 - 2026	Q2 - 2027	Q3 - 2027	\$1,308,221
LUG ESA 13509.10501141	13509	0.16	13	1	0	15	Q2 - 2026	Q2 - 2027	Q3 - 2027	\$220,909
LUG CSA 13091.10163224	13091	0.76	50	5	2	57	Q2 - 2026	Q2 - 2027	Q3 - 2027	\$931,180
LUG PCA 13390.92605381	13390	0.34	118	12	4	134	Q2 - 2026	Q2 - 2027	Q3 - 2027	\$444,600
LUG PCA 13805.10916743	13805	0.48	7	1	0	8	Q2 - 2026	Q2 - 2027	Q3 - 2027	\$625,300
LUG WSA 13112.92890357	13112	1.23	49	5	2	56	Q2 - 2026	Q2 - 2027	Q3 - 2027	\$1,594,716
LUG CSA 13043.10093646	13043	0.56	44	5	2	50	Q2 - 2026	Q2 - 2027	Q3 - 2027	\$678,264
LUG WSA 13206.10167762	13206	0.55	25	3	1	28	Q2 - 2026	Q2 - 2027	Q3 - 2027	\$720,318
LUG SHA 13780.10723993	13780	0.27	89	9	3	101	Q2 - 2026	Q2 - 2027	Q3 - 2027	\$364,602
LUG ESA 13326.10477228	13326	2.48	26	3	1	29	Q2 - 2026	Q2 - 2027	Q3 - 2027	\$3,226,600
LUG WSA 13219.60518342	13219	0.47	15	2	1	17	Q2 - 2026	Q2 - 2027	Q3 - 2027	\$611,010
LUG ESA 13793.92685255	13793	0.19	26	3	1	30	Q2 - 2026	Q2 - 2027	Q3 - 2027	\$256,449
LUG CSA 13093.60031511	13093	0.80	26	3	1	29	Q2 - 2026	Q2 - 2027	Q3 - 2027	\$1,040,000
LUG WSA 13483.60393455	13483	2.87	490	50	17	557	Q3 - 2026	Q3 - 2027	Q4 - 2027	\$3,727,623
LUG WSA 13865.60305740	13865	0.14	37	4	1	42	Q3 - 2026	Q3 - 2027	Q4 - 2027	\$181,951
LUG ESA 13502.10497396	13502	0.30	63	6	2	72	Q3 - 2026	Q3 - 2027	Q4 - 2027	\$398,864
LUG WSA 13162.94434120	13162	0.60	60	6	2	68	Q3 - 2026	Q3 - 2027	Q4 - 2027	\$780,000
LUG CSA 13175.60060554	13175	1.23	18	2	1	20	Q3 - 2026	Q3 - 2027	Q4 - 2027	\$1,599,000
LUG WSA 13112.92874488	13112	0.35	35	4	1	40	Q3 - 2026	Q3 - 2027	Q4 - 2027	\$478,534
LUG ESA 13878.10105726	13878	0.54	122	13	4	139	Q3 - 2026	Q3 - 2027	Q4 - 2027	\$729,205
LUG CSA 14012.92299193	14012	0.62	260	27	9	296	Q3 - 2026	Q3 - 2027	Q4 - 2027	\$756,677
LUG ESA 13231.10868121	13231	0.27	22	2	1	25	Q3 - 2026	Q3 - 2027	Q4 - 2027	\$368,693
LUG CSA 13829.10425054	13829	0.24	48	5	2	55	Q3 - 2026	Q3 - 2027	Q4 - 2027	\$245,791
LUG WSA 13624.10274748	13624	0.28	22	2	1	25	Q3 - 2026	Q3 - 2027	Q4 - 2027	\$363,409
LUG WSA 13167.92398222	13167	0.37	11	1	0	13	Q3 - 2026	Q3 - 2027	Q4 - 2027	\$481,000

Tampa	Electric'	s Distribut	ion Lateral	Undergro	ounding	- Year	2026 Det	ails		
		Specific Project Detail		Custome	rs		Construction Project Proj			Project
Project ID	Circuit No.	OH to UG Length Converted (miles)	Residential	Small C&I	Large C&I	Total	Start Qtr	Start Qtr	End Qtr	Cost in 2026
LUG ESA 13039.92496615	13039	1.45	60	6	2	68	03 - 2026	03 - 2027	Q4 - 2027	\$1,882,400
LUG PCA 13723.60422059	13723	0.91	55	6	2	63	03 - 2026	03 - 2027	Q4 - 2027	\$1,110,200
LUG WSA 13738.90267141	13738	0.22	277	28	9	315	03 - 2026	Q3 - 2027	Q4 - 2027	\$286,000
LUG WSA 13082.60073803	13082	0.22	29	3	1	33	Q3 - 2026	Q3 - 2027	Q4 - 2027	\$286,000
LUG SHA 13899.60005952	13899	0.91	73	7	2	83	Q3 - 2026	Q3 - 2027	Q4 - 2027	\$1,184,300
LUG CSA 13036.10143568	13036	0.66	47	5	2	53	Q3 - 2026	Q3 - 2027	Q4 - 2027	\$809,428
LUG WSA 13072.10165803	13072	0.52	10	1	0	11	Q3 - 2026	Q3 - 2027	Q4 - 2027	\$639,863
LUG ESA 13795.90398961	13795	0.51	20	2	1	23	Q3 - 2026	Q3 - 2027	Q4 - 2027	\$664,300
LUG WSA 13198.10051863	13198	0.42	59	6	2	67	Q3 - 2026	Q3 - 2027	Q4 - 2027	\$567,000
LUG SHA 13900.91863298	13900	0.27	151	15	5	172	Q3 - 2026	Q3 - 2027	Q4 - 2027	\$359,744
LUG WSA 13217.10247858	13217	0.83	30	3	1	34	Q3 - 2026	Q3 - 2027	Q4 - 2027	\$1,078,313
LUG WSA 13219.92527637	13219	1.58	36	4	1	41	03 - 2026	Q3 - 2027	Q4 - 2027	\$2,054,000
LUG CSA 13832.91532289	13832	0.74	31	3	1	35	03 - 2026	Q3 - 2027	Q4 - 2027	\$962,000
LUG WSA 13068.10688316	13068	0.62	14	1	0	16	03 - 2026	03 - 2027	Q4 - 2027	\$806,000
LUG WSA 13060.92907479	13060	0.46	258	26	9	293	03 - 2026	03 - 2027	Q4 - 2027	\$598,000
LUG WSA 13167.10160212	13167	0.24	48	5	2	55	Q3 - 2026	Q3 - 2027	Q4 - 2027	\$311,723
LUG WSA 13081.60008652	13081	0.08	27	3	1	31	03 - 2026	03 - 2027	Q4 - 2027	\$111,477
LUG WSA 13164.10158932	13164	1.62	153	16	5	174	03 - 2026	03 - 2027	Q4 - 2027	\$2,106,000
LUG WSA 13201.91868130	13201	0.59	112	11	4	127	03 - 2026	03 - 2027	Q4 - 2027	\$771,440
LUG WSA 13016.92132257	13016	0.19	54	5	2	61	03 - 2026	03 - 2027	Q4 - 2027	\$240,530
LUG WSA 13756.10589590	13756	0.59	27	3	1	31	03 - 2026	03 - 2027	04 - 2027	\$767,000
LUG WSA 13622.60048809	13622	0.73	5	1	0	6	04 - 2026	04 - 2027	Q4 - 2027	\$985,500
LUG WSA 13219.90098743	13218	0.77	108	11	4	123	04 - 2026	04 - 2027	Q4 - 2027	\$939,400
LUG WSA 13621.91418404	13621	0.42	11	1	0	12	04 - 2026	04 - 2027	04 - 2027	\$546.000
LUG WSA 13740.90487798	13740	2.09	49	5	2	56	04 - 2026	04 - 2027	04 - 2027	\$2.717.000
LUG CSA 13034.10142238	13034	0.64	16	2	1	18	04 - 2026	04 - 2027	Q4 - 2027	\$840,708
LUG WSA 13065.92238609	13065	0.45	24	2	1	27	04 - 2026	04 - 2027	Q4 - 2027	\$611,987
LUG WSA 13078.90444684	13078	1.26	31	3	1	35	04 - 2026	04 - 2027	Q4 - 2027	\$1,638,000
LUG WSA 13194.10286125	13194	1.68	54	5	2	61	04 - 2026	Q4 - 2027	Q4 - 2027	\$2,266,112
LUG CSA 13417.92035203	13417	0.60	30	3	1	34	04 - 2026	Q4 - 2027	Q4 - 2027	\$732,000
LUG WSA 13737.10007252	13737	0.46	4	0	0	5	04 - 2026	04 - 2027	Q4 - 2027	\$598,000
LUG ESA 13878.10105728	13878	0.23	23	2	1	26	Q4 - 2026	Q4 - 2027	Q4 - 2027	\$313,210
LUG WSA 13754.90423524	13754	0.54	35	4	1	40	Q4 - 2026	Q4 - 2027	Q4 - 2027	\$657,007
LUG CSA 14012.91181114	14012	0.65	17	2	1	19	Q4 - 2026	Q4 - 2027	Q4 - 2027	\$787,963
LUG WSA 13198.94019819	13198	0.23	47	5	2	53	Q4 - 2026	Q4 - 2027	Q4 - 2027	\$299,000
LUG CSA 13036.10143504	13036	0.75	4	0	0	4	Q4 - 2026	Q4 - 2027	Q4 - 2027	\$918,443
LUG WSA 13754.90915815	13754	0.91	12	1	0	14	Q4 - 2026	Q4 - 2027	Q4 - 2027	\$1,110,200
LUG WSA 13208.90152415	13208	0.17	26	3	1	29	Q4 - 2026	Q4 - 2027	Q4 - 2027	\$229,500
LUG ESA 13686.93697046	13686	0.40	26	3	1	29	Q4 - 2026	Q4 - 2027	Q4 - 2027	\$544,347
LUG WSA 13080	13080	7.25	1091	43	7	1,141	Q4 - 2026	Q4 - 2027	Q4 - 2027	\$2,614,095
LUG WHA 13371	13371	6.79	417	33	5	455	Q4 - 2026	Q4 - 2027	Q4 - 2027	\$2,426,907

TAMPA ELECTRIC COMPANY DOCKET NO. 20250016-EI EXHIBIT NO. KEP-1 WITNESS: PALLADINO APPENDIX C PAGE 5 OF 5 FILED: 01/15/2025 REVISED: 03/31/2025

Tampa	Electric'	s Distribut.	ion Lateral U	Jndergro	guibnu	- Үеаг	2026 De	tails			
		Specific Project Detail		Customer	» «		Proie C	Cons	truct	ion	Droiant Droiant
Project ID	Circuit No.	OH to UG Length Converted (miles)	Residential	Small C&I	Large C&I	Total	start Qtr	Start Qtr		End Qtr	cost in 2026
LUG WSA 13162	13162	2.71	213	128	33	374	Q4 - 2026	04 - 202	27 Q4	- 2027	\$1,004,493
LUG PCA 13125	13125	3.83	404	24	12	440	Q4 - 2026	04 - 202	27 Q4	- 2027	\$827,292
LUG CSA 13051	13051	0.88	69	30	£	104	Q4 - 2026	Q4 - 202	27 Q4	- 2027	\$328,788
LUG CSA 13093	13093	3.17	629	39	T	669	Q4 - 2026	Q4 - 202	27 Q4	- 2027	\$1,150,150
LUG ESA 13228	13228	2.79	103	98	31	232	Q4 - 2026	Q4 - 202	27 Q4	- 2027	\$1,014,796
LUG WSA 13140	13140	1.86	202	51	13	266	Q4 - 2026	Q4 - 202	27 Q4	- 2027	\$688,416
LUG WSA 13165	13165	0.54	53	27	10	90	Q4 - 2026	Q4 - 202	27 Q4	- 2027	\$193,578
LUG WSA 13164	13164	1.77	273	7	0	280	Q4 - 2026	Q4 - 202	27 Q4	- 2027	\$646,555
LUG WHA 13288	13288	0.54	41	29	10	80	Q4 - 2026	Q4 - 202	27 Q4	- 2027	\$197,491
LUG WSA 13638	13638	0.98	44	19	5	68	Q4 - 2026	Q4 - 202	27 Q4	- 2027	\$306,430
LUG WSA 13738	13738	0.60	32	8	L	4.7	Q4 - 2026	Q4 - 202	27 Q4	- 2027	\$224,055
LUG WSA 13141	13141	0.74	227	17	3	247	Q4 - 2026	Q4 - 202	27 Q4	- 2027	\$281,797

TAMPA ELECTRIC COMPANY DOCKET NO. 20250016-EI EXHIBIT NO. KEP-1 WITNESS: PALLADINO APPENDIX H PAGE 2 OF 2 FILED: 01/15/2025 REVISED: 03/31/2025

		Froject Cost in 2026	\$174,000	
Tampa Electric's Distribution Storm Surge Hardening - Year 2026 Details	ruction	End Month	Dec-27	
	Const	Start Month	Jan-27	
		Project Start Month	Jan-26	
		Customers		
		Total	27,318	
	s	Large C&I	859	
	Customers	Small C&I	2,405	
		Residential	24,054	
		Structure Count	174	
		Circuit No.	Multiple	
		Project ID	SSH-TBD300	

TAMPA ELECTRIC COMPANY DOCKET NO. 20250016-EI EXHIBIT NO. KEP-1 WITNESS: PALLADINO APPENDIX J PAGE 7 OF 34 FILED: 01/15/2025 REVISED: 03/31/2025

## 3 Vegetation Management Program Initiatives

TECO and Accenture analyzed the initiatives described in **Table 3-1** to determine an optimal blend of VM activity to reduce vegetation-related outages during extreme weather events while continuing to minimize day-to-day vegetation-related outages.

Initiative	Name	Description	Modeling Methodology
Initiative 1	Distribution VM	Trim an equivalent of 25% of	Target 25% of the miles in each of TECO's 7
	Four-Year Cycle	TECO s overhead lines (~1,534	service areas annually. Due to the nature of
		miles) annually.	the algorithm and available targeting data,
			targeting is based on SAIDI performance in
			regular weather (i.e., blue sky).
Initiative 2	Supplemental	Trim an additional 400 – 700	Six different approaches were evaluated –
	<b>Distribution VM</b>	targeted miles annually with a	400, 450, 500, 550, 600, and 700 miles.
		view to mitigating outage risk	Targeting criteria is identical to Initiative 1.
		on those circuits most	
		susceptible to storm damage	
Initiative 3	Mid-Cycle	Perform mid-cycle inspections	- The VMOT analysis assumes that a
	Distribution VM	on circuits, prescribing	percentage of circuit's adjacent trees will be
		additional VM as needed.	prescribed for trimming or removal
		Periodicity is based on the	(percentage varies based on circuit cycle
		following criteria:	periodicity; see section 8.3.3 for details on
		- Circuits with a trim	criteria).
		periodicity of every 4 or more	- As VMOT works with miles of circuit rather
		years: two years after trim	than individual trees, this is modeled as a
			percentage of the circuit's miles re-setting to
		- Circuits with a trim	trimmed in that year, while the remainder of
		periodicity of every 3 years:	the circuit continues to age. Within the
		two years after trim, skipping	model, the costs associated with day-to-day
		every other mid-cycle	restoration, major event restoration, and
			corrective maintenance costs are re-
		- Circuits with a trim	calculated to reflect the new trim-age profile
		periodicity of every 2 years:	of the circuit.
		one year after trim, skipping	
		every other mid-cycle	

## Table 3-1: Vegetation Management Initiatives

Initiative 2 (Supplemental Distribution VM) seeks to reduce tree-caused outages by reducing the proximity between tree limbs and lines, as well as reducing trees' sail area which would otherwise cause them to sway or break as wind speed increases.

Initiative 3 (Mid-Cycle Distribution VM) focuses on the same proximity and sail area reduction efforts as Initiative 2 but is primarily intended to address hazard trees and fast-growing tree species which may encroach on lines despite recurring VM cycle activity.

TAMPA ELECTRIC COMPANY DOCKET NO. 20250016-EI EXHIBIT NO. KEP-1 WITNESS: PALLADINO APPENDIX J PAGE 9 OF 34 FILED: 01/15/2025 REVISED: 03/31/2025

## 5 VM Activity Distribution Across Service Areas

For Initiative 1 (Distribution VM Four-Year Cycle), each service area is allotted one-quarter of its mileage every year, amounting to 1,534 miles across TECO's entire service territory. Central, for example, accounts for roughly 16.5% of TECO's overhead miles, and is allotted 16.5% of the annual 1,534-mile target as depicted in **Table 5-1**.

Service Area	Annual Mileage Target	Percentage
Central	253	16.5%
Dade City	92	6.0%
Eastern	209	13.6%
Plant City	306	20.0%
South Hillsborough	179	11.6%
Western	265	17.3%
Winter Haven	229	14.9%
TECO (Overall)	1,534	100.0%

For the mileage addressed via Initiative 2 (Supplemental Distribution VM), one quarter of the prescribed supplemental miles are allocated across the service areas in the same proportions as Initiative 1. The remainder of the miles are directed where they will deliver the greatest benefit in terms of reliability improvement per dollar spent, as determined by VMOT. To describe this in practical terms, for a strategy in which 400 miles of supplemental distribution VM are prescribed, 100 miles would be assigned across the service areas in accordance with the percentages outlined in the above table, with the remaining 300 miles directed to the areas where it would deliver the greatest benefit.

As covered in the **Vegetation Management Program Initiatives** section, Initiative 3 (Mid-Cycle Distribution VM) focuses on the same proximity and sail area reduction efforts as Initiative 2 but is primarily intended to address hazard trees and fast-growing tree species which may encroach on lines despite recurring VM cycle activity. **Table 3-1** shows how the annual inspection mileage for Initiative 3 is estimated on an annual basis.

# 6 VM Program Evaluation

TECO utilized VMOT to compare the projected impact of several SPP approaches by evaluating vegetation-related blue and gray sky reliability against relevant costs. TECO examined the resource implications of each approach and the relative reliability improvements for the additional dollars spent to determine the best strategy moving forward. To ensure that all model outputs were based on the most recent data available, TECO engaged Accenture to refresh the VMOT configuration and the various assumptions built into the VMOT Storm Report. The configuration refresh process and associated

vegetation density, asset condition, wind zone, and 1 flood modeling. With this basis, hardening investment 2 3 identification and prioritization provides a robust assessment to focus investment on the portions of the 4 5 system that are more likely to fail in the major storm. 6 7 Drives PrudencyReasonableness: The assessment and modeling approach drives prudency reasonableness for 8 the Storm Protection Plan in that the business case 9 allows Tampa Electric to invest in the portions of 10 11 the system that provide the model value to customers. Balanced: Since storm events cannot be fullv 12 eliminated, the diversification of hardening measures 13 14 allows Tampa Electric to provide a higher level of system resilience for customers. 15 16 What conclusions can be made from the results of the 17 0. resilience analysis? 18 19 20 Α. The conclusions of Tampa Electric's Storm Protection plan evaluated within the Storm Resilience Model are: 21 The overall investment level of \$1.62 billion for 22 23 Tampa Electric's Storm Protection Plan is reasonable and provides customers with maximum benefits. The 24 25 projects selected have favorable project economics