

Ausley, McMullen, McGehee, Carothers & Proctor

Attorneys at Law

Washington Square Building

227 S. Calhoun Street - 32301

P. O. Box 391 - 32302

Tallahassee, Florida

Telephone 904 224-0115

Telescopier 904 222-7560 Main Building

Telescopier 904 222-7130 Real Estate

Telescopier 904 222-7952 Utilities

January 18, 1994

HAND DELIVERED

Jenn Johnson Hert
Kenneth R. Hart
David J. Hull
E. Martin McGehee (Retired)
Carolyn D. Olive
R. Stan Peeler
Robert A. Pierce
H. Palmer Proctor
M. Julian Proctor, Jr.
Steven P. Seymore
William M. Smith
Deborah J. Stephens
James Harold Thompson
J. Jeffry Wahien
Emily S. Waugh
C. Gary Williams
Lee L. Willis

Charles S. Ausley (1907-1972)
John C. Ausley (1912-1980)
D. Fred McMullen (1904-1980)
Gerald T. Hert (1948-1991)
DuBoose Ausley
Margaret B. Ausley
James D. Beasley
Michael P. Brynere
C. Graham Carothers
Kevin J. Carroll
Robert N. Clarke, Jr.
J. Marshall Conard
Timothy B. Elliott
Stephen C. Emmanuel
John P. Fons
Van P. Geeker
Michael J. Glazer
Carla A. Green

Mr. Steve C. Tribble, Director
Division of Records and Reporting
Florida Public Service Commission
101 East Gaines Street
Tallahassee, Florida 32399-0850

Re: Fuel and Purchased Power Cost Recovery Clause
with Generating Performance Incentive Factor;
FPSC Docket No. 940001-EI


Dear Mr. Tribble:

Enclosed for filing in the above docket, on behalf of Tampa Electric Company, are fifteen (15) copies of Prepared Direct Testimony and Exhibits (GAK-2) and (GAK-3) of Mr. George A. Keselowsky regarding Tampa Electric's Generating Performance Incentive Factor for the period April 1994 through September 1994.

Please acknowledge receipt and filing of the above by stamping the duplicate copy of this letter and returning same to this writer.

Thank you for your assistance in connection with this matter.

Sincerely,



James D. Beasley

JDB/pp
encls.

cc: All Parties of Record (w/encls.)

DOCUMENT NUMBER-DATE

00520 JAN 18 8

FPSC-RECORDS/REPORTING

Ausley, McMullen, McGehee, Carothers & Proctor

Mr. Steve C. Tribble
January 18, 1994
Page 2

CERTIFICATE OF SERVICE

I HEREBY CERTIFY that a true copy of the foregoing testimony and exhibits, filed on behalf of Tampa Electric Company, has been furnished by U. S. Mail on this 18th day of January, 1994 to the following:

Ms. Martha C. Brown*
Staff Counsel
Division of Legal Services
Florida Public Service Commission
101 East Gaines Street
Tallahassee, FL 32399-0863

Mr. James A. McGee
Senior Counsel
Florida Power Corporation
Post Office Box 14042
St. Petersburg, FL 33733

Mr. Joseph A. McGlothlin
Ms. Vicki Gordon Kaufman
McWhirter, Reeves, McGlothlin
Davidson & Bakas
315 South Calhoun St., Suite 716
Tallahassee, FL 32301

Mr. Jack Shreve
Office of Public Counsel
Room 812
111 West Madison Street
Tallahassee, FL 32399-1400

Mr. Matthew M. Childs
Steel Hector & Davis
601 First Florida Bank Building
Tallahassee, FL 32301

Mr. John W. McWhirter
McWhirter, Reeves, McGlothlin
Davidson & Bakas
Post Office Box 3350
Tampa, FL 33601-3350

Mr. Robert Goldman
Messer, Vickers, Caparello,
Madsen, Lewis, Goldman & Metz
Post Office Box 1876
Tallahassee, FL 32301-1876

Mr. B. Kenneth Gatlin
Gatlin, Woods, Carlson & Cowdery
1709-D Mahan Drive
Tallahassee, FL 32308

Mr. Jeffrey Stone
Beggs & Lane
Post Office Box 12950
Pensacola, FL 32576

Mr. Richard A. Zambo
Richard A. Zambo, P.A.
598 S.W. Hidden River Avenue
Palm City, FL 34990

Mr. Earle H. O'Donnell
Ms. Zori G. Ferkin
Dewey Ballantine
1775 Pennsylvania Avenue, N.W.
Washington, D. C. 20006-4605

Mr. David M. Kleppinger
Post Office Box 1166
Harrisburg, PA 17108-1166

Ms. Suzanne Brownless
Suzanne Brownless, P.A.
1546 Blair Stone Pines Drive
Tallahassee, Fl 32301


ATTORNEY

*By hand delivery

1 DOCKET NO. 940001-E
2 TAMPA ELECTRIC COMPANY
3 SUBMITTED FOR FILING 1/18/94
4 (PROJECTION)

5

6

7 BEFORE THE FLORIDA PUBLIC SERVICE COMMISSION
8 PREPARED DIRECT TESTIMONY
9 OF
10 GEORGE A. KESELOWSKY

- 11
- 12
- 13 Q. Will you please state your name, business address, and employer?
- 14
- 15 A. My name is George A. Keselowsky and my business address is Post Office Box
16 111, Tampa, Florida 33601. I am employed by Tampa Electric Company.
- 17
- 18 Q. Please furnish us with a brief outline of your educational background and business
19 experience.
- 20
- 21 A. I graduated in 1972 from the University of South Florida with a Bachelor of
22 Science Degree in Mechanical Engineering. I have been employed by Tampa
23 Electric Company in various engineering positions since that time. My current
24 position is that of Senior Consulting Engineer - Production Engineering.
- 25

1 Q. What are your current responsibilities?

2
3 A. I am responsible for testing and reporting unit performance, and the compilation
4 and reporting of generation statistics.

5
6 Q. What is the purpose of your testimony?

7
8 A. My testimony presents Tampa Electric Company's methodology for determining
9 the various factors required to compute the Generating Performance Incentive
10 Factor (GPIF) as ordered by this Commission.

11
12 Q. Have you prepared an exhibit showing the various elements of the derivation of
13 Tampa Electric Company's GPIF formula?

14
15 A. Yes, I have prepared, under my direction and supervision, an exhibit entitled
16 "Tampa Electric Company, Generating Performance Incentive Factor" April 1994
17 - September 1994, consisting of 35 pages filed with the Commission on January
18 18, 1994. (Have identified as Exhibit GAK-2). The data prepared within this
19 exhibit is consistent with the GPIF Implementation Manual previously approved
20 by this Commission.

21
22 Q. Which generating units on Tampa Electric Company's system are included in the
23 determination of your GPIF?

24
25 A. Six of our coal-fired units are included. These are: Gannon Station Units 5 and

1 6; and Big Bend Station Units 1, 2, 3, and 4.

2

3 Q. Will you describe how Tampa Electric Company evolved the various factors
4 associated with the GPIF as ordered by this Commission?

5

6 A. Yes. First, the two factors to be used, as set forth by the Commission Staff, are
7 unit availability and station heat rate.

8

9 Q. Please continue.

10

11 A. A target was established for equivalent availability for each unit considered for
12 this period. Heat rate targets were also established for each unit. A range of
13 potential improvement and degradation was determined for each of these
14 parameters.

15

16 Q. Would you describe how the target values for unit availability were determined?

17

18 A. Yes I will. The Planned Outage Factor (POF) and the Equivalent Unplanned
19 Outage Factor (EUOF) were subtracted from 100% to determine the target
20 equivalent availability. The factors for each of the 6 units included within the
21 GPIF are shown on page 5 of my exhibit. For example, the projected EUOF for
22 Gannon Unit Five is 12.9%. The Planned Outage Factor for this same unit

23

24

25

1 during this period is 4.4%. Therefore, the target equivalent availability for this
2 unit equals:

3

4 $100\% - [(12.9\% + 4.4\%)] = 82.7\%$

5

6 This is shown on page 4, column 3 of my exhibit.

7

8 Q. How was the potential for unit availability improvement determined?

9

10 A. Maximum equivalent availability is arrived at using the following formula.

11 Equivalent Availability Maximum

12 $EAF_{max} = 100\% - [0.8(EUOF_T) + 0.95(POF_T)]$

13

14 The factors included in the above equations are the same factors that determine
15 target equivalent availability. To attain the maximum incentive points, a 20%
16 reduction in Forced Outage and Maintenance Outage Factors (EUOF), plus a 5%
17 reduction in the Planned Outage Factor (POF) will be necessary. Continuing with
18 our example on Gannon Unit Five:

19

20 $EAF_{max} = 100\% - [0.8(12.9\%) + 0.95(4.4\%)] = 85.5\%$

21

22 This is shown on page 4, column 4 of my exhibit.

- 1 Q. How was the potential for unit availability degradation determined?
- 2
- 3 A. The potential for unit availability degradation is significantly greater than is the
- 4 potential for unit availability improvement. This concept was discussed
- 5 extensively and approved in earlier hearings before this Commission. Tampa
- 6 Electric Company's approach to incorporating this skewed effect into the unit
- 7 availability tables is to use a potential degradation range equal to twice the
- 8 potential improvement. Consequently, minimum equivalent availability is arrived
- 9 at via the following formula:
- 10
- 11 Equivalent Availability Minimum
- 12 $EAF_{MIN} = 100\% - [1.4(EUOF_T) + 1.10(POF_T)]$
- 13
- 14 Again, continuing with our example of Gannon Unit Five,
- 15
- 16 $EAF_{MIN} = 100\% - [1.4(12.9\%) + 1.1(4.4\%)] = 77.1\%$
- 17
- 18 Equivalent availability MAX and MIN for the other five units is computed in a
- 19 similar manner.
- 20
- 21 Q. How do you arrive at the Planned Outage, Maintenance Outage and Forced
- 22 Outage Factors?
- 23
- 24 A. Our planned outages for this period are shown on page 19 of my exhibit. A
- 25 Critical Path Method (C.P.M.) for each outage greater than two weeks which.

1 affects GPIF is included in my exhibit. For example, Big Bend Unit 1 is
2 scheduled for a major unit inspection from April 9 to June 3, 1994. There are
3 1344 planned outage hours scheduled for the summer 1994 period, and a total of
4 4391 hours during this 6 month period. Consequently, the Planned Outage Factor
5 for Unit 2 at Big Bend is $1344/4391 \times 100\%$ or 30.6%. This factor is shown on
6 pages 5 and 15 of my exhibit. Big Bend Units 2, 3 and 4, as well as Gannon
7 Unit 6 have planned outage factors of zero. Gannon Unit 5 has a planned outage
8 factor of 4.4%.

9

10 Q. How did you arrive at the Forced Outage and Maintenance Outage Factors on
11 each unit?

12

13 A. Graphs of both of these factors (adjusted for planned outages) vs. time are
14 prepared. Both monthly data and 12 month moving average data are recorded.
15 For each unit the most current, September 1993, 12 month ending value was used
16 as a basis for the projection. This value was adjusted up or down by analyzing
17 trends and causes for recent forced and maintenance outages. All projected
18 factors are based upon historical unit performance, engineering judgment, time
19 since last planned outage, and equipment performance resulting in a forced or
20 maintenance outage. These target factors are additive and result in a EUOF of
21 12.9% for Gannon Unit Five. The Equivalent Unplanned Outage Factor (EUOF)

22

23

24

25

1 for Gannon Unit Five is verified by the data shown on page 13, lines 3, 5, 10 and
2 11 of my exhibit and calculated using the formula:

3

4
$$\text{EUOF} = \frac{\text{FOH} + \text{EPOH} + \text{MOH} + \text{EMOH}}{\text{Period Hours}} \times 100$$

5 or

6

7
$$\text{EUOF} = \frac{(462 + 105)}{4391} \times 100 = 12.9\%$$

8

9 Relative to Gannon Unit Five, the EUOF of 12.9% forms the basis of our
10 Equivalent Availability target development as shown on sheets 4 and 5 of my
11 exhibit.

12

13 Q. Please continue with your review of the remaining units.

14

15 Big Bend Unit One

16 A. The projected EUOF for this unit is 10.8% during this period. This unit will
17 have a planned outage this period and the Planned Outage Factor is 30.6%. This
18 results in a target equivalent availability of 58.6% for the period.

19

20 Big Bend Unit Two

21 The projected EUOF for this unit is 12.4%. This unit will not have a planned
22 outage during this period and the Planned Outage Factor is 0.0%. Therefore, the
23 target equivalent availability for this unit is 87.6%.

Big Bend Unit Three

The projected EUOF for this unit is 16.5% during this period. This unit will not have a planned outage this period and the Planned Outage Factor is 0.0%. Therefore, the target equivalent availability for this unit is 83.5%.

Big Bend Unit Four

The projected EUOF for this unit is 11.9%. This unit will not have a planned outage during this period and the Planned Outage Factor is 0.0%. This results in a target equivalent availability of 88.1% for the period.

Garrison Unit Five

The projected EUOF for this unit is 12.9%. This unit will have a planned outage during this period and the Planned Outage Factor is 4.4%. Therefore, the target equivalent availability for this unit is 82.7%.

Gannon Unit Six

The projected EUOF for this unit is 16.9 %. This unit will not have a planned outage during this period and the Planned Outage Factor is 0.0 %. Therefore, the target equivalent availability for this unit is 83.1 %.

21 Q. Would you summarize your testimony regarding Equivalent Availability Factor
22 (EAF), Equivalent Unplanned Outage Factor (EUOF) and Equivalent Unplanned
23 Outage Rate (EUOR)?

25 A. Yes I will. Please note on page 5 that the GPIF system weighted Equivalent

1 Availability Factor (EAF) equals 80.4 %. This target compares very favorably to
2 previous GPIF periods. It exceeds three of the five previous periods, and is in
3 fact, better than or equal to four of the five previous periods. It also exceeds the
4 five period average EAF. These targets represent an outstanding level of
5 performance for our system.

6

7 Q. As you graph and monitor Forced and Maintenance Outage Factors, why are they
8 adjusted for planned outage hours?

9

10 A. This adjustment makes these factors more accurate and comparable. Obviously,
11 a unit in a planned outage stage or reserve shutdown stage will not incur a forced
12 or maintenance outage. Since our units are usually base loaded, reserve shutdown
13 is generally not a factor. To demonstrate the effects of a planned outage, note the
14 EUOR and EUOF for Gannon Unit Five on page 13. During the months of May
15 through September, EUOF and EUOR are equal. This is due to the fact that no
16 planned outages are scheduled during these months. During the month of April,
17 EUOR exceeds EUOF. The reason for this difference is the scheduling of a
18 planned outage. The adjusted factors apply to the period hours after planned
19 outage hours have been extracted.

20

21 Q. Does this mean that both rate and factor data are used in calculated data?

22

23 A. Yes it does. Rates provide a proper and accurate method of arriving at the unit
24 parameters. These are then converted to factors since they are directly additive.
25 That is, the Forced Outage Factor + Maintenance Outage Factor + Planned

1 Outage Factor + Equivalent Availability = 100%. Since factors are additive,
2 they are easier to work with and to understand.

3

4 Q. You previously stated that you had developed a CPM for your unit outages. How
5 do you use the CPM in conjunction with your planned outages?

6

7 A. The CPM's included in this exhibit are preliminary and include only the major
8 work activities we expect to accomplish during the planned outage. Planned
9 outages are very complex and are anticipated months in advance. The actual
10 CPM's utilized in the execution of the planned outage are detailed for all major
11 and minor work activities.

12

13 Since it is important to the company and beneficial to our Customers to control
14 outage length, we have implemented a computerized outage management system.
15 Essentially, this tool enables management to monitor outage progress, measure
16 activity results against previously established milestones, and verify timely
17 execution of all critical path events. This results in the shortest outage time
18 possible and the maximum utilization of all resources. Any reduction in planned
19 outage length directly improves unit equivalent availability.

20

21 Q. Has Tampa Electric Company prepared the necessary heat rate data required for
22 the determination of the Generating Performance Incentive Factor?

23

24 A. Yes. Target heat rates as well as ranges of potential operation have been
25 developed as required.

- 1 Q. On what basis were the heat rate targets determined?
- 2
- 3 A. Average net operating heat rates are determined and reported on a unit basis.
- 4 Therefore, all heat rate data pertaining to the GPIF is calculated on this basis.
- 5
- 6 Q. How were these targets determined?
- 7
- 8 A. Net heat rate data for the three most recent summer periods, along with the
- 9 PROMOD III program, formed the basis of our target development. Projections
- 10 of unit performance were made with the aid of PROMOD III. The historical data
- 11 and the target values are analyzed to assure applicability to current conditions of
- 12 operation. This provides assurance that any periods of abnormal operations, or
- 13 equipment modifications having material effect on heat rate can be taken into
- 14 consideration.
- 15
- 16 Q. Were any such circumstances of abnormal operation a consideration in your target
- 17 setting procedure?
- 18
- 19 A. No. All data points were used in target determination and formed a valid body
- 20 of data.
- 21
- 22 Q. Have you developed the heat rate targets in accordance with GPIF guidelines?
- 23
- 24 A. Yes.
- 25

1 Q. How were the ranges of heat rate improvement and heat rate degradation
2 determined?

3

4 A. The ranges were determined through analysis of historical net heat rate and net
5 output factor data. This is the same data from which the net heat rate vs. net
6 output factor curves have been developed for each station. This information is
7 shown on pages 27 through 32 of my exhibit.

8

9 Q. Would you elaborate on the analysis used in the determination of the ranges?

10

11 A. The net heat rate vs. net output factor curves are the results of a first order curve
12 fit to historical data. The standard error of the estimate of this data was
13 determined, and a factor was applied to produce a band of potential improvement
14 and degradation. Both the curve fit and the standard error of the estimate were
15 performed by computer program for each station. These curves are also used in
16 post period adjustments to actual heat rates to account for unanticipated changes
17 in unit dispatch.

18

19 Q. Can you summarize your heat rate projection for the summer 1994 period?

20

21 A. Yes. The heat rate target for Big Bend Unit 1 is 10,062 Btu/Net kwh. The range
22 about this value, to allow for potential improvement or degradation, is
23 ± 342 Btu/Net kwh. The heat rate target for Big Bend Unit 2 is 10,069 Btu/Net
24 kwh with a range of ± 313 Btu/Net kwh. The heat rate target for Big Bend
25 Unit 3 is 9,676 Btu/Net kwh, with a range of ± 285 Btu/Net kwh. The heat rate

1 target for Big Bend Unit 4 is 10,114 Btu/Net kwh with a range of \pm 269 Btu/Net
2 kwh. The heat rate target for Gannon Unit 5 is 10,408 Btu/Net kwh with a range
3 of \pm 344 Btu/Net kwh. The heat rate target for Gannon Unit 6 is 10,454 Btu/Net
4 kwh with a range of \pm 403 Btu/Net kwh. A zone of tolerance of \pm 75 Btu/Net
5 kwh is included within the range for each target. This is shown on page 4, and
6 pages 7 through 12 of my exhibit.

7
8 Q. Do you feel that the heat rate targets and ranges in your projection meet the
9 criteria of the GPIF and the philosophy of this Commission?

10
11 A. Yes I do.

12
13 Q. After determining the target values and ranges for average net operating heat rate
14 and equivalent availability, what is the next step in the GPIF?

15
16 A. The next step is to calculate the savings and weighting factor to be used for both
17 average net operating heat rate and equivalent availability. This is shown on pages
18 7 through 12. Our PROMOD III cost simulation model was used to calculate the
19 total system fuel cost if all units operated at target heat rate and target availability
20 for the period. This total system fuel cost of \$140,166,300 is shown on page 6
21 column 2.

22
23 The PROMOD III output was then used to calculate total system fuel cost with
24 each unit individually operating at maximum improvement in equivalent
25 availability and each station operating at maximum improvement in average net

1 operating heat rate. The respective savings are shown on page 6 column 4. After
2 all the individual savings are calculated, column 4 is totaled: \$6,536,200 reflects
3 the savings if all units operated at maximum improvement. A weighting factor
4 for each parameter is then calculated by dividing individual savings by the total.
5 For Big Bend Unit Two, the weighting factor for equivalent availability is 8.77%
6 as shown in the right hand column on page 6. Pages 7 thru 12 show the point
7 table, the Fuel Savings/(Loss), and the equivalent availability or heat rate value.
8 The individual weighting factor is also shown. For example, on Big Bend Unit
9 Two, page 10, if the unit operates at 90.1% equivalent availability, fuel savings
10 would equal \$573,000 and 10 equivalent availability points would be awarded.

11

12 The Generating Performance Incentive Factor Reward/Penalty Table on page 2
13 is a summary of the tables on pages 7 through 12. The left hand column of this
14 document shows the Tampa Electric Company's incentive points. The center
15 column shows the total fuel savings and is the same amount as shown on page 6,
16 column 4, \$6,536,200. The right hand column of page 2 is the estimated reward
17 or penalty based upon performance. The maximum amount of penalty or reward
18 is \$1,802,513. The calculation of this amount is detailed on page 3.

19

20 Q. How were the maximum allowed incentive dollars determined?

21

22 A. Referring to my exhibit on page 3, line 8, the estimated average common equity
23 for the period April - September 1994 is shown to be \$888,262,571. This
24 produces the maximum allowed jurisdictional incentive dollars of \$1,802,513
25 shown on line 15.

1 Q. Is there any other constraint set forth by this Commission regarding the magnitude
2 of incentive dollars?

3

4 A. Yes. Incentive dollars are not to exceed fifty percent of fuel savings. Page 2 of
5 my exhibit demonstrates that this constraint is met.

6

7 Q. Do you wish to summarize your testimony on the GPIF?

8

9 A. Yes. To the best of my knowledge and understanding, Tampa Electric Company
10 has fully complied with the Commission's directions, philosophy, and
11 methodology in our determination of Generating Performance Incentive Factor.
12 The GPIF for Tampa Electric Company is expressed by the following formula for
13 calculating Generating Performance Incentive Points (GPIP):

14
$$\begin{aligned} \text{GPIP} = & (0.0231 \text{ EAP}_{\text{GNS}} + 0.0858 \text{ EAP}_{\text{GN6}} \\ & + 0.0891 \text{ EAP}_{\text{BB1}} + 0.0877 \text{ EAP}_{\text{BB2}} \\ & + 0.1242 \text{ EAP}_{\text{BB3}} + 0.0859 \text{ EAP}_{\text{BB4}} \\ & + 0.0547 \text{ HRP}_{\text{GNS}} + 0.0986 \text{ HRP}_{\text{GN6}} \\ & + 0.0738 \text{ HRP}_{\text{BB1}} + 0.0969 \text{ HRP}_{\text{BB2}} \\ & + 0.0913 \text{ HRP}_{\text{BB3}} + 0.0889 \text{ HRP}_{\text{BB4}}) \end{aligned}$$

20 Where:

21 GPIP = Generating performance incentive points.

22 EAP = Equivalent availability points awarded/deducted for
23 Units 5 and 6 at Gannon and Units 1, 2, 3 and 4 at Big Bend.

24 HRP = Average net heat rate points awarded/deducted for Units 5
25 and 6 at Gannon and Units 1, 2, 3 and 4 at Big Bend.

1 Q. Have you prepared a document summarizing the GPIF targets for the April
2 - September 1994 period?

3

4 A. Yes. The availability and heat rate targets for each unit are listed on attachment
5 "A" to this testimony entitled "Tampa Electric Company GPIF Targets, April 1,
6 1994 - September 30, 1994".

7

8 Q. Do you wish to sponsor an exhibit consisting of estimated unit performance data
9 supporting the fuel adjustment?

10

11 A. Yes I do. (Have identified as Exhibit GAK-3).

12

13 Q. Briefly describe this exhibit.

14

15 A. This exhibit consists of 23 pages. This data is Tampa Electric Company's
16 estimate of the Unit Performance Data and Unit Outage Data for the April
17 - September 1994 period.

18

19 Q. Does this conclude your testimony?

20

21 A. Yes.

ATTACHMENT "A"
January 18, 1994

TAMPA ELECTRIC COMPANY
GPIF TARGETS
April 1, 1994 - September 30, 1994

Unit	Availability			Heat Rate
	EAF	POF	EUOF	
Gannon 5	82.7	4.4	12.9 ¹	10,408 ¹
Gannon 6	83.1	0	16.9 ²	10,454 ²
Big Bend 1	58.6	30.6	10.8 ³	10,062 ³
Big Bend 2	87.6	0	12.4 ⁴	10,069 ⁴
Big Bend 3	83.5	0	16.5 ⁵	9,676 ⁵
Big Bend 4	88.1	0	11.9 ⁶	10,114 ⁶

¹ Original Sheet 6.401.94E, Pg. 13

² Original Sheet 6.401.94E, Pg. 14

³ Original Sheet 6.401.94E, Pg. 15

⁴ Original Sheet 6.401.94E, Pg. 16

⁵ Original Sheet 6.401.94E, Pg. 17

⁶ Original Sheet 6.401.94E, Pg. 18

EXHIBIT NO. _____
DOCKET NO. 940001-EI
TAMPA ELECTRIC COMPANY
(GAK-2)
PAGE 1 OF 35

TAMPA ELECTRIC COMPANY
GENERATING PERFORMANCE INCENTIVE FACTOR
APRIL 1994 - SEPTEMBER 1994
TABLE OF CONTENTS

<u>SCHEDULE</u>	<u>PAGE</u>
GPIF REWARD/PENALTY TABLE ESTIMATED	2
GPIF CALCULATIONS OF MAXIMUM ALLOWED INCENTIVE DOLLARS	3
GPIF TARGET AND RANGE SUMMARY	4
COMPARISON GPIF TARGETS VS PRIOR PERIODS ACTUAL PERFORMANCE	5
GPIF HEAT RATE SUMMARY	5
DERIVATION OF WEIGHTING FACTORS	6
GENERATING PERFORMANCE INCENTIVE POINT TABLES	7-12
ESTIMATED UNIT PERFORMANCE DATA	13-18
PLANNED OUTAGE SCHEDULE	19
CRITICAL PATH METHOD DIAGRAMS	20
TAMPA ELECTRIC COMPANY FORCED OUTAGE AND MAINTENANCE OUTAGE FACTOR GRAPHS	21-26
NET HEAT RATE VS NET OUTPUT FACTOR GRAPHS	27-32
GENERATING UNITS IN GPIF (TABLE 4.2 IN MANUAL)	33
UNIT RATINGS AS OF APRIL 1, 1994	34
PROJECTED PERCENT GENERATION BY UNIT	35

TAMPA ELECTRIC COMPANY
GENERATING PERFORMANCE INCENTIVE POINTS TABLE
REWARD/PENALTY TABLE - ESTIMATED
APRIL 1994 - SEPTEMBER 1994

GENERATING PERFORMANCE INCENTIVE POINTS (GPIP)	FUEL SAVINGS/(LOSS) (\$000)	GENERATING PERFORMANCE INCENTIVE FACTOR (\$000)
+10	6,536.2	1,802.5
+9	5,882.6	1,622.3
+8	5,229.0	1,442.0
+7	4,575.3	1,261.8
+6	3,921.7	1,081.5
+5	3,268.1	901.3
+4	2,614.5	721.0
+3	1,960.9	540.8
+2	1,307.2	360.5
+1	653.6	180.3
0	0.0	0.0
-1	(930.6)	(180.3)
-2	(1,861.2)	(360.5)
-3	(2,791.8)	(540.8)
-4	(3,722.4)	(721.0)
-5	(4,653.0)	(901.3)
-6	(5,583.5)	(1,081.5)
-7	(6,514.1)	(1,261.8)
-8	(7,444.7)	(1,442.0)
-9	(8,375.3)	(1,622.3)
-10	(9,305.9)	(1,802.5)

**TAMPA ELECTRIC COMPANY
GENERATING PERFORMANCE INCENTIVE FACTOR
CALCULATION OF MAXIMUM ALLOWED INCENTIVE DOLLARS
ESTIMATED
APRIL 1994 - SEPTEMBER 1994**

Line 1	Beginning of period balance of common equity End of month common equity:		\$890,332,000
Line 2	Month of	April	\$860,519,000
Line 3	Month of	May	\$868,658,000
Line 4	Month of	June	\$876,874,000
Line 5	Month of	July	\$898,625,000
Line 6	Month of	August	\$907,125,000
Line 7	Month of	September	\$915,705,000
Line 8	(summation of line 1 through 7 divided by 7)		\$888,262,571
Line 9	25 Basis points		0.0025
Line 10	Revenue expansion factor		61.3738%
Line 11	Maximum allowed incentive Dollars (Line 8 times 9 divided by line 10 times 0.5)		\$1,809,124
Line 12	Jurisdictional Sales		7,249,171 MWH
Line 13	Total Sales		7,275,757 MWH
Line 14	Jurisdictional Separation Factor (Line 12 divided by line 13)		99.63%
Line 15	Maximum Allowed Jurisdictional Incentive Dollars (Line 11 times Line 14)		\$1,802,513

TAMPA ELECTRIC COMPANY

GPIF TARGET AND RANGE SUMMARY

APRIL 1994 - SEPTEMBER 1994

EQUIVALENT AVAILABILITY

PLANT/UNIT	WEIGHTING FACTOR (%)	BAF TARGET (%)	BAF MAX. (%)	RANGE MIN. (%)	MAX. FUEL SAVINGS (\$000)	MAX. FUEL LOSS (\$000)
GANNON 5	2.31%	82.7	85.5	77.7	150.9	(424.9)
GANNON 6	8.58%	83.1	86.5	76.3	560.8	(843.3)
BIG BEND 1	8.91%	88.6	92.3	81.2	582.3	(1,165.1)
BIG BEND 2	8.77%	87.6	90.1	82.6	573.0	(926.3)
BIG BEND 3	12.42%	83.5	86.8	76.9	811.8	(1,501.0)
BIG BEND 4	<u>8.59%</u>	88.1	90.5	83.3	<u>561.3</u>	<u>(1,149.2)</u>
GPIF SYSTEM	49.58%				3,240.1	(6,009.5)

AVERAGE NET OPERATING HEAT RATE
FOR
GPIF COAL GENERATING UNITS

PLANT/UNIT	WEIGHTING FACTOR (%)	ANOHR Btu/kwh	TARGET NOP	ANOHR TARGET RANGE MIN.	ANOHR TARGET RANGE MAX.	MAX. FUEL SAVINGS SL (\$000)	MAX. FUEL LOSS (\$000)
GANNON 5	5.47%	10408	69.9	10064	10752	357.3	(357.3)
GANNON 6	9.86%	10454	65.9	10051	10857	644.3	(644.3)
BIG BEND 1	7.38%	10062	90.2	9720	10404	482.1	(482.1)
BIG BEND 2	9.69%	10069	87.5	9756	10382	633.1	(633.1)
BIG BEND 3	9.13%	9676	87.7	9391	9961	597.0	(597.0)
BIG BEND 4	<u>8.89%</u>	10114	87.6	9845	10383	<u>582.3</u>	<u>(582.3)</u>
GPIF SYSTEM	50.42%					3,296.1	(3,296.1)

TAMPA ELECTRIC COMPANY
COMPARISON OF GPF TARGETS VS. PRIOR PERIOD ACTUAL PERFORMANCE

AVAILABILITY

PLANT/UNIT	TARGET WEIGHTING FACTOR	NORMALIZED WEIGHTING FACTOR	TARGET PERIOD APR '91 - SEP '91			ACTUAL PERFORMANCE APR '91 - SEP '91			ACTUAL PERFORMANCE OCT '91 - MAR '92			ACTUAL PERFORMANCE APR '92 - SEP '92			ACTUAL PERFORMANCE OCT '92 - MAR '93			ACTUAL PERFORMANCE APR '93 - SEP '93		
			POW	BLDG	BARL	POW	BLDG	BARL	POW	BLDG	BARL	POW	BLDG	BARL	POW	BLDG	BARL			
BIG BEND 1	8.81%	18.0	30.6	10.8	16.6	0.0	14.2	14.2	8.8	18.6	21.4	20.0	11.6	14.6	0.0	8.6	7.1	0.0	13.2	13.2
BIG BEND 2	8.77%	17.7	0.0	12.4	12.4	0.0	8.0	8.0	2.8	10.4	10.8	0.0	11.7	11.7	22.2	6.6	6.6	0.0	22.2	22.2
BIG BEND 3	12.42%	25.1	0.0	16.6	16.6	11.8	12.8	14.6	18.7	18.1	22.5	0.0	11.0	11.0	2.8	14.1	14.6	18.6	11.8	14.0
BIG BEND 4	8.69%	17.3	0.0	11.8	11.8	0.0	18.8	18.8	0.0	8.8	8.8	0.0	11.8	11.8	21.8	10.7	18.8	0.0	7.8	7.9
GANNON 5	2.31%	4.7	4.4	12.8	13.5	28.8	10.8	18.8	0.0	8.8	8.8	0.0	10.8	10.8	0.0	12.0	12.0	30.1	9.3	15.3
GANNON 6	0.47%	17.1	0.0	18.2	18.2	14.8	11.2	19.2	22.1	8.2	8.2	8.8	14.2	18.2	0.0	22.1	22.1	8.8	18.2	12.7
GPF SYSTEM WEIGHTED AVG.		100.0	8.7	13.8	14.7	7.4	13.2	14.4	12.1	12.6	14.8	3.7	12.1	12.6	9.0	12.2	13.2	6.2	13.4	14.3
GPF SYSTEM WEIGHTED EQUIVALENT AVAILABILITY			89.4			78.2			78.2			84.2			78.2			80.4		
6 PERIOD AVERAGE			6 PERIOD AVERAGE			6 PERIOD AVERAGE			6 PERIOD AVERAGE			6 PERIOD AVERAGE			6 PERIOD AVERAGE					
			FAC			FAC			FAC			FAC			FAC					
			7.8			12.7			13.8			78.6								

AVERAGE NET OPERATING HEAT RATE (MMBtu/MMB)

PLANT/UNIT	TARGET WEIGHTING FACTOR	NORMALIZED WEIGHTING FACTOR	HEAT RATE TARGET	ADJUSTED PRIOR HEAT RATE APR '91 - SEP '91		ADJUSTED PRIOR HEAT RATE APR '91 - SEP '92		ADJUSTED PRIOR HEAT RATE APR '92 - SEP '93		
				MMBtu/MMB	MMBtu/MMB	MMBtu/MMB	MMBtu/MMB	MMBtu/MMB	MMBtu/MMB	
GANNON 5	8.47%	10.8	10408	10477		10453		10287		
GANNON 6	0.86%	19.6	10454	10687		10415		10813		
BIG BEND 1	7.36%	14.6	10082	10140		10180		9980		
BIG BEND 2	0.69%	19.2	10089	10030		10078		10080		
BIG BEND 3	0.13%	18.1	9978	9730		9643		9854		
BIG BEND 4	0.47%	17.8	10114	10152		10552		10199		
GPF SYSTEM WEIGHTED AVERAGE H.R. (MMB/MMB)			10117		10177		10113		10060	

**TAMPA ELECTRIC COMPANY
DERIVATION OF WEIGHTING FACTORS
APRIL 1994 - SEPTEMBER 1994
PRODUCTION COSTING SIMULATION
FUEL COST (\$000)**

<u>UNIT PERFORMANCE INDICATOR</u>	<u>AT TARGET</u>	<u>IMPROVEMENT</u>	<u>SAVINGS</u>	<u>WEIGHTING FACTOR (% OF SAVINGS)</u>
	<u>(1)</u>	<u>(2)</u>	<u>(3)</u>	

EQUIVALENT AVAILABILITY

EA ₁ , GANNON 5	140166.3	140015.4	150.9	2.31%
EA ₂ , GANNON 6	140166.3	139605.5	560.8	8.58%
EA ₃ , BIG BEND 1	140166.3	139584.0	582.3	8.91%
EA ₄ , BIG BEND 2	140166.3	139593.3	573.0	8.77%
EA ₅ , BIG BEND 3	140166.3	139354.5	811.8	12.42%
EA ₆ , BIG BEND 4	140166.3	139605.0	561.3	8.59%

HEAT RATE

AHR ₁ , GANNON 5	140166.3	139809.0	357.3	5.47%
AHR ₂ , GANNON 6	140166.3	139522.0	644.3	9.86%
AHR ₃ , BIG BEND 1	140166.3	139684.2	482.1	7.38%
AHR ₄ , BIG BEND 2	140166.3	139533.2	633.1	9.69%
AHR ₅ , BIG BEND 3	140166.3	139569.3	597.0	9.13%
AHR ₆ , BIG BEND 4	140166.3	139584.0	582.3	8.89%
			6536.2	100.00%

TOTAL SAVINGS

(1) Fuel adjustment Base Case - All unit performance indicators at target.

(2) All other unit performance indicators at target.

(3) Expressed in replacement energy cost.

TAMPA ELECTRIC COMPANY
 GENERATING PERFORMANCE INCENTIVE POINTS TABLE
 APRIL 1994 - SEPTEMBER 1994
 GANNON 8

EQUIVALENT AVAILABILITY POINTS	FUEL SAVINGS/(LOSS) (\$x1000)	ADJUSTED ACTUAL EQUIVALENT AVAILABILITY	AVERAGE HEAT RATE POINTS	FUEL SAVINGS/(LOSS) (\$x1000)	ADJUSTED ACTUAL AVERAGE HEAT RATE
+10	131.9	85.5	+10	357.3	10464
+9	135.8	85.2	+9	328	10091
+8	120.7	84.9	+8	285.8	10118
+7	105.6	84.7	+7	250.1	10145
+6	90.5	84.4	+6	214.4	10172
+5	75.5	84.1	+5	178.7	10199
+4	60.4	83.8	+4	142.9	10225
+3	45.3	83.5	+3	107.2	10252
+2	30.2	83.3	+2	71.5	10279
+1	15.1	83.0	+1	35.7	10306
				0.0	10333
0	0.0	82.7	0	0.0	10408
				0.0	10483
-1	(42.5)	82.1	-1	(35.7)	10510
-2	(85.0)	81.6	-2	(71.5)	10537
-3	(127.5)	81.0	-3	(107.2)	10564
-4	(170.0)	80.5	-4	(142.9)	10591
-5	(212.5)	79.9	-5	(178.7)	10618
-6	(254.9)	79.3	-6	(214.4)	10644
-7	(297.4)	78.8	-7	(250.1)	10671
-8	(339.9)	78.2	-8	(285.8)	10698
-9	(382.4)	77.7	-9	(321.6)	10725
-10	(424.9)	77.1	-10	(357.3)	10752

Weighting Factor = 2.31%

Weighting Factor = 5.47%

TAMPA ELECTRIC COMPANY
GENERATING PERFORMANCE INCENTIVE POINTS TABLE
APRIL 1994 - SEPTEMBER 1994
GANNON 6

EQUIVALENT AVAILABILITY POINTS	FUEL SAVINGS/(LOSS) (\$/1000)	ADJUSTED ACTUAL EQUIVALENT AVAILABILITY	AVERAGE HEAT RATE POINTS	FUEL SAVINGS/(LOSS) (\$/1000)	ADJUSTED ACTUAL AVERAGE HEAT RATE
+10	560.8	86.5	+10	644.3	10051
+9	504.7	86.2	+9	579.9	10084
+8	448.6	85.8	+8	515.4	10117
+7	392.6	85.5	+7	451.0	10149
+6	336.5	85.1	+6	386.6	10182
+5	280.4	84.8	+5	322.2	10215
+4	224.3	84.5	+4	257.7	10248
+3	168.2	84.1	+3	193.3	10281
+2	112.2	83.8	+2	128.9	10313
+1	56.1	83.4	+1	64.4	10346
				0.0	10379
0	0.0	83.1	0	0.0	10454
				0.0	10529
-1	(84.3)	82.4	-1	(64.4)	10562
-2	(168.7)	81.7	-2	(128.9)	10595
-3	(253.0)	81.1	-3	(193.3)	10627
-4	(337.3)	80.4	-4	(257.7)	10660
-5	(421.7)	79.7	-5	(322.2)	10693
-6	(506.0)	79.0	-6	(386.6)	10726
-7	(590.3)	78.3	-7	(451.0)	10759
-8	(674.6)	77.7	-8	(515.4)	10791
-9	(759.0)	77.0	-9	(579.9)	10824
-10	(843.3)	76.3	-10	(644.3)	10857

Weighting Factor = 8.58%

Weighting Factor = 9.86%

TAMPA ELECTRIC COMPANY
GENERATING PERFORMANCE INCENTIVE POINTS TABLE
APRIL 1994 - SEPTEMBER 1994
BIG BEND 1

EQUIVALENT AVAILABILITY POINTS	FUEL SAVINGS/(LOSS) (\$x1000)	ADJUSTED ACTUAL EQUIVALENT AVAILABILITY	AVERAGE HEAT RATE POINTS	FUEL SAVINGS/(LOSS) (\$x1000)	ADJUSTED ACTUAL AVERAGE HEAT RATE
+10	582.3	62.3	+10	482.1	9720
+9	524.1	61.9	+9	433.9	9747
+8	465.8	61.6	+8	385.7	9773
+7	407.6	61.2	+7	337.5	9800
+6	349.4	60.8	+6	289.3	9827
+5	291.2	60.4	+5	241.1	9854
+4	232.9	60.1	+4	192.8	9880
+3	174.7	59.7	+3	144.6	9907
+2	116.5	59.3	+2	96.4	9934
+1	58.2	59.0	+1	48.2	9960
				0.0	9987
0	0.0	58.6	0	0.0	10042
				0.0	10137
-1	(116.5)	57.9	-1	(48.2)	10164
-2	(233.0)	57.1	-2	(96.4)	10190
-3	(349.5)	56.4	-3	(144.6)	10217
-4	(466.0)	55.6	-4	(192.8)	10244
-5	(582.6)	54.9	-5	(241.1)	10271
-6	(699.1)	54.2	-6	(289.3)	10297
-7	(815.6)	53.4	-7	(337.5)	10324
-8	(932.1)	52.7	-8	(385.7)	10351
-9	(1,048.6)	51.9	-9	(433.9)	10377
-10	(1,165.1)	51.2	-10	(482.1)	10404

Weighting Factor = 8.91%

Weighting Factor = 7.38%

TAMPA ELECTRIC COMPANY
GENERATING PERFORMANCE INCENTIVE POINTS TABLE
APRIL 1994 - SEPTEMBER 1994
BIG BEND 2

EQUIVALENT AVAILABILITY POINTS	FUEL SAVINGS/(LOSS) (\\$x1000)	ADJUSTED ACTUAL EQUIVALENT AVAILABILITY	AVERAGE HEAT RATE POINTS	FUEL SAVINGS/(LOSS) (\\$x1000)	ADJUSTED ACTUAL AVERAGE HEAT RATE
+10					
+9	573.0	89.1	+10		
+8	513.7	89.9	+9	633.1	9756
+7	458.4	89.6	+8	569.8	9780
+6	401.1	89.4	+7	506.5	9804
+5	343.8	89.1	+6	443.2	9827
+4	286.5	88.9	+5	379.9	9851
+3	229.2	88.6	+4	316.6	9875
+2	171.9	88.4	+3	253.2	
+1	114.6	88.1	+2	189.9	9999
0	57.3	87.9	+1	126.6	9923
	0.0	87.6	0	63.3	9946
-1				0.0	9970
-2	(92.6)			0.0	9994
-3	(185.3)	87.1		0.0	10069
-4	(277.9)	86.6	-1	0.0	10144
-5	(370.5)	86.1	-2	(63.3)	10168
-6	(463.2)	85.6	-3	(126.6)	10192
-7	(555.8)	85.1	-4	(189.9)	10215
-8	(648.4)	84.6	-5	(253.2)	10239
-9	(741.0)	84.1	-6	(316.6)	10263
-10	(833.7)	83.6	-7	(379.9)	10287
	(926.3)	83.1	-8	(443.2)	10311
		82.6	-9	(506.5)	10334
			-10	(569.8)	10358
				(633.1)	10382
Weighting Factor =		8.77%	Weighting Factor =		9.69%

TAMPA ELECTRIC COMPANY
 GENERATING PERFORMANCE INCENTIVE POINTS TABLE
 APRIL 1994 - SEPTEMBER 1994
 BIG BEND 3

EQUIVALENT AVAILABILITY POINTS	FUEL SAVINGS/(LOSS) ($\$ \times 1000$)	ADJUSTED ACTUAL EQUIVALENT AVAILABILITY	AVERAGE HEAT RATE POINTS	FUEL SAVINGS/(LOSS) ($\$ \times 1000$)	ADJUSTED ACTUAL AVERAGE HEAT RATE
+10	811.6	86.8	+10	597.0	9991
+9	730.6	86.5	+9	537.3	9412
+8	649.4	86.1	+8	477.6	9433
+7	568.3	85.8	+7	417.9	9454
+6	487.1	85.5	+6	358.2	9475
+5	405.9	85.2	+5	298.5	9496
+4	324.7	84.8	+4	238.8	9517
+3	243.5	84.5	+3	179.1	9538
+2	162.4	84.2	+2	119.4	9559
+1	81.2	83.8	+1	59.7	9580
				0.0	9601
0	0.0	83.5	0	0.0	9626
				0.0	9751
-1	(150.1)	82.8	-1	(59.7)	9772
-2	(300.2)	82.2	-2	(119.4)	9793
-3	(450.3)	81.5	-3	(179.1)	9814
-4	(600.4)	80.9	-4	(238.8)	9835
-5	(750.5)	80.2	-5	(298.5)	9856
-6	(900.6)	79.5	-6	(358.2)	9877
-7	(1,050.7)	78.9	-7	(417.9)	9898
-8	(1,200.8)	78.2	-8	(477.6)	9919
-9	(1,350.9)	77.6	-9	(537.3)	9940
-10	(1,501.0)	76.9	-10	(597.0)	9961

Weighting Factor = 12.42%

Weighting Factor = 9.13%

TAMPA ELECTRIC COMPANY
GENERATING PERFORMANCE INCENTIVE POINTS TABLE
APRIL 1994 - SEPTEMBER 1994
BIG BEND 4

<u>EQUIVALENT AVAILABILITY POINTS</u>	<u>FUEL SAVINGS/(LOSS) (\$x1000)</u>	<u>ADJUSTED ACTUAL EQUIVALENT AVAILABILITY</u>	<u>AVERAGE HEAT RATE POINTS</u>	<u>FUEL SAVINGS/(LOSS) (\$x1000)</u>	<u>ADJUSTED ACTUAL AVERAGE HEAT RATE</u>
+10	561.3	90.5	+10	582.3	9845
+9	505.2	90.3	+9	524.1	9844
+8	449.0	90.0	+8	465.8	9844
+7	392.9	89.8	+7	407.6	9843
+6	336.8	89.5	+6	349.4	9823
+5	280.7	89.3	+5	291.2	9942
+4	224.5	89.1	+4	232.9	9961
+3	168.4	88.8	+3	174.7	9981
+2	112.3	88.6	+2	116.5	10000
+1	56.1	88.3	+1	58.2	10020
				0.0	10039
0	0.0	88.1	0	0.0	10114
				0.0	10189
-1	(114.9)	87.6	-1	(58.2)	10208
-2	(229.8)	87.1	-2	(116.5)	10228
-3	(344.8)	86.7	-3	(174.7)	10247
-4	(459.7)	86.2	-4	(232.9)	10267
-5	(574.6)	85.7	-5	(291.2)	10286
-6	(689.5)	85.2	-6	(349.4)	10305
-7	(804.4)	84.7	-7	(407.6)	10325
-8	(919.4)	84.3	-8	(465.8)	10344
-9	(1,034.3)	83.8	-9	(524.1)	10364
-10	(1,149.2)	83.3	-10	(582.3)	10383

Weighting Factor = 8.59%

Weighting Factor = 8.89%

TAMPA ELECTRIC COMPANY
 ESTIMATED UNIT PERFORMANCE DATA
 APRIL 1994 - SEPTEMBER 1994

PLANT/UNIT GANNON 5	MONTH OF:						PERIOD SUMMER 1994
	APR 94	MAY 94	JUN 94	JUL 94	AUG 94	SEP 94	
1. EAF (%)	83.4	86.4	86.5	86.4	86.4	86.7	82.7
2. POF (%)	26.7	0.0	0.0	0.0	0.0	0.0	4.4
3. EUOF (%)	9.9	13.6	13.5	13.6	13.6	13.3	12.9
4. EUOR (%)	13.5	13.6	13.5	13.6	13.6	13.3	13.5
5. PH	719	744	720	744	744	720	4391
6. SH	492	693	671	693	693	671	3913
7. RSH	0	0	0	0	0	0	0
8. LH	227	51	49	51	51	49	478
9. POH	192	0	0	0	0	0	192
10. FOH & EFOH	58	62	79	62	62	79	462
11. MOH & EMOH	13	19	18	19	19	17	105
12. OPER BTU (GBTU)	762,577	1202,002	1129,671	1149,535	1143,942	1074,211	6462,541
13. NET GEN (MWH)	743,99	117,250	108,789	109,110	108,494	102,930	620,912
14. ANOHR (BTU/KWH)	10282	10252	10384	10538	10544	10436	10408
15. NOF (%)	86.6	74.5	71.4	69.4	69.0	67.6	69.9
16. NSC (MW)	227	227	227	227	227	227	227

17. ANOHR EQUATION: $\text{ANOHR} = \text{NOF} (-19.6360) + 11780.7$

FILED:
 SUSPENDED:
 EFFECTIVE: 4/01/94
 DOCKET NO. : 940001-EI

TAMPA ELECTRIC COMPANY
ESTIMATED UNIT PERFORMANCE DATA
APRIL 1994 - SEPTEMBER 1994

PLANT/UNIT GANNON 6	MONTH OP:	PERIOD					
	APR 94	MAY 94	JUN 94	JUL 94	AUG 94	SEP 94	SUMMER 1994
1. EAF (%)	83.0	83.2	83.1	83.2	83.2	82.9	83.1
2. POF (%)	0.0	0.0	0.0	0.0	0.0	0.0	0.0
3. EUOF (%)	17.0	16.8	16.9	16.8	16.8	17.1	16.9
4. EUOR (%)	17.0	16.8	16.9	16.8	16.8	17.1	16.9
5. PH	719	744	720	744	744	720	4391
6. SH	653	675	653	675	675	656	3987
7. RSH	0	0	0	0	0	0	0
8. UH	68	69	67	69	69	64	404
9. POH	0	0	0	0	0	0	0
10. FOH & EFOH	100	103	100	103	103	101	610
11. MOH & EMOH	22	22	22	22	22	22	132
12. OPER BTU (GBTU)	1506.731	1796.295	1869.392	1898.997	1685.116	1587.655	9944.166
13. NET GEN (MWH)	144975	173845	180091	161022	159775	151503	951211
14. ANOHR (BTU/KWH)	10407	10333	10428	10539	10547	10479	10454
15. NOF (%)	61.3	71.1	67.7	65.9	65.4	63.8	65.9
16. NSC (MW)	362	362	362	362	362	362	362

17. ANOHR EQUATION:
$$\text{ANOHR} = \text{NOF} (-13.1800) + 11322.8$$

FILED:
SUSPENDED:
EFFECTIVE: 4/01/94
DOCKET NO. : 940001-EI

TAMPA ELECTRIC COMPANY
 ESTIMATED UNIT PERFORMANCE DATA
 APRIL 1994 - SEPTEMBER 1994

PLANT/UNIT BIG BEND 1	MONTH OF: APR 94	MONTH OF: MAY 94	MONTH OF: JUN 94	MONTH OF: JUL 94	MONTH OF: AUG 94	MONTH OF: SEP 94	PERIOD SUMMER 1994
1. EAF (%)	22.4	0.0	76.0	84.4	84.4	84.4	58.6
2. POF (%)	73.4	100.0	10.0	0.0	0.0	0.0	30.6
3. EUOF (%)	4.2	0.0	14.0	15.6	15.6	15.6	10.8
4. EUOR (%)	15.7	0.0	15.6	15.6	15.6	15.6	15.6
5. PH	719	744	720	744	744	720	4391
6. SH	174	0	586	674	674	656	2764
7. RSH	0	0	0	0	0	0	0
8. UH	545	744	134	70	70	64	1627
9. POH	528	744	72	0	0	0	1344
10. FOH & EFOH	21	0	72	83	83	79	338
11. MOH & EMOH	9	0	29	33	33	33	137
12. OPER BTU (GBTU)	640,448	0.000	2156,446	2492,636	2488,339	2382,917	10160,786
13. NET GEN (MWH)	64796	0	214896	246520	246093	237515	1009822
14. ANOHR (BTU/KWH)	9884	0	10035	10111	10111	10033	10062
15. NOF (%)	91.9	0.0	90.5	90.3	90.2	89.4	90.2
16. NSC (MW)	405	405	405	405	405	405	405
17. ANOHR EQUATION:	ANOHR = NOF (-13.9140) + 11317.0						

FILED:
 SUSPENDED:
 EFFECTIVE: 4/01/94
 DOCKET NO: 940001 - EI

**TAMPA ELECTRIC COMPANY
ESTIMATED UNIT PERFORMANCE DATA
APRIL 1994 - SEPTEMBER 1994**

PLANT/UNIT BIG HEND 2	MONTH OF:						PERIOD SUMMER 1994
	APR 94	MAY 94	JUN 94	JUL 94	AUG 94	SEP 94	
1. EAF (%)	87.8	87.8	87.8	87.8	87.8	87.4	87.8
2. POF (%)	0.0	0.0	0.0	0.0	0.0	0.0	0.0
3. EUOF (%)	12.4	12.4	12.4	12.4	12.4	12.6	12.4
4. EUOR (%)	12.4	12.4	12.4	12.4	12.4	12.6	12.4
5. PH	719	744	720	744	744	720	4391
6. SH	664	686	664	686	686	668	4054
7. RSH	0	0	0	0	0	0	0
8. UH	55	58	56	58	58	52	337
9. PDH	0	0	0	0	0	0	0
10. FOH & EFOH	68	68	68	68	68	68	404
11. MOH & EMOH	23	24	23	24	24	23	141
12. OPER BTU (GBTU)	2425.433	2530.729	2389.224	2440.293	2426.286	2327.822	14535.587
13. NET GEN (MWH)	243525	253473	236053	240900	239599	230019	1443839
14. ANOHR (BTU/KWH)	9960	9984	10098	10130	10135	10116	10069
15. NOF (%)	90.3	91.0	97.8	86.5	86.0	84.8	87.7
16. NSC (MW)	406	406	406	406	406	406	406

17. ANOHR EQUATION: $ANOHR = NOF (-7.3385) + 10712.3$

FILED:
SUSPENDED:
EFFECTIVE: 4/01/94
DOCKET NO. : 9401001-E

**TAMPA ELECTRIC COMPANY
ESTIMATED UNIT PERFORMANCE DATA
APRIL 1994 - SEPTEMBER 1994**

PLANT/UNIT BIG BEND 3	MONTH OF:						PERIOD SUMMER 1994
	APR 94	MAY 94	JUN 94	JUL 94	AUG 94	SEP 94	
1. EAF (%)	83.5	83.5	83.5	83.5	83.5	83.3	83.5
2. POF (%)	0.0	0.0	0.0	0.0	0.0	0.0	0.0
3. EUOF (%)	16.4	16.5	16.4	16.5	16.5	16.7	16.5
4. EUOR (%)	16.4	16.5	16.4	16.5	16.5	16.7	16.5
5. PH	718	744	720	744	744	720	691
6. SH	642	671	649	671	671	654	665
7. RSH	0	0	0	0	0	0	0
8. UH	70	73	71	73	73	66	426
9. POH	0	0	0	0	0	0	0
10. FOH & EFOH	78	81	78	81	81	80	479
11. MOH & EMOH	40	42	40	42	42	40	246
12. OPER BTU (GBTU)	2368.973	2489.357	2391.827	2442.866	2438.653	2359.087	14468.763
13. NET GEN (MWH)	245572	256809	246771	252635	251990	243536	1497315
14. ANOHR (BTU/KWH)	9647	9693	9692	9670	9670	9687	9676
15. NOF (%)	89.0	89.0	88.4	87.8	87.3	86.6	87.8
16. NSC (MW)	430	430	430	430	430	430	430

17. ANOHR EQUATION: $ANOHR = NOF (-7.1595) + 10305.1$

FILED:
SUSPENDED:
EFFECTIVE: 4/01/94
DOCKET NO. : 940001-EI

**TAMPA ELECTRIC COMPANY
ESTIMATED UNIT PERFORMANCE DATA
APRIL 1994 - SEPTEMBER 1994**

PLANT/UNIT BIG BEND 4	MONTH OF:						PERIOD SUMMER 1994
	APR 94	MAY 94	JUN 94	JUL 94	AUG 94	SEP 94	
1. EAF (%)	88.2	88.0	88.2	88.0	88.0	88.2	88.1
2. POF (%)	0.0	0.0	0.0	0.0	0.0	0.0	0.0
3. EUOF (%)	11.8	12.0	11.8	12.0	12.0	11.8	11.9
4. EUOR (%)	11.8	12.0	11.8	12.0	12.0	11.8	11.9
5. PH	719	744	720	744	744	720	4391
6. SH	671	693	671	693	693	674	4095
7. RSH	0	0	0	0	0	0	0
8. UH	48	51	49	51	51	46	296
9. POH	0	0	0	0	0	0	0
10. FOH & EFOH	68	71	68	71	71	68	417
11. MOH & EMOH	17	18	17	18	18	17	105
12. OPER BTU (GBTU)	2649.522	2765.023	2631.096	2692.830	2682.801	2581.462	16002.734
13. NET GEN (MWH)	265591	274984	259634	264041	263045	254772	1562247
14. ANOHR (BTU/KWH)	9976	10056	10126	10196	10199	10132	10114
15. NOF (%)	89.8	90.0	87.8	86.4	86.1	85.7	87.6
16. NSC (MW)	441	441	441	441	441	441	441


17. ANOHR EQUATION: $ANOHR = NOF (-12.333) + 11194.3$

FILED:
SUSPENDED:
EFFECTIVE: 4/01/94
DOCKET NO. : 940001-EI

TAMPA ELECTRIC COMPANY
PLANNED OUTAGE SCHEDULE (ESTIMATED)
GPIF UNITS
APRIL 1994 - SEPTEMBER 1994


<u>PLANT/UNIT</u>	<u>PLANNED OUTAGE DATES</u>	<u>OUTAGE REASONS</u>
• + GANNON 5	MAR 26 - APR 08	FUEL SYSTEM CLEAN-UP
BIG BEND 1	APR 09 - JUN 03	PENTHOUSE PRESSURIZATION REPLACE HIGH TEMP. REHEATER REPLACE PULV. SH/THROAT LINERS REPLACE BURNER PANELS BOILER CHEMICAL CLEANING REPLACE LOWER WATER WALL TUBES L.P. TURBINE MODIFICATION PRECIP. OUTLET DUCT REPLACEMENT GENERATOR STEP-UP TRANS. MODIFICA' INSP. GOV. VVS/INT/RHT/THRTL. VVS

- OUTAGE START-END DATE OUT OF GPIF PERIOD
- + CPM'S WERE NOT INCLUDED FOR THESE UNITS, OUTAGES ARE LESS THAN 2 WEEKS




TAMPA ELECTRIC COMPANY
BIG BEND UNIT NO. 1
PLANNED DUTAGE 1994
PRELIMINARY CPM
11/11/93


TAMPA ELECTRIC CO.
GANNON UNIT #5
EFOF (ADJUSTED FOR PLANNED OUTAGE HOURS)




TAMPA ELECTRIC CO.
GANNON UNIT #5
EMOF (ADJUSTED FOR PLANNED OUTAGE HOURS)




TAMPA ELECTRIC CO.
GANNON UNIT #6
EFOF (ADJUSTED FOR PLANNED OUTAGE HOURS)




TAMPA ELECTRIC CO.
GANNON UNIT #6
EMOF (ADJUSTED FOR PLANNED OUTAGE HOURS)




TAMPA ELECTRIC CO.
BIG BEND UNIT #1
EFOF (ADJUSTED FOR PLANNED OUTAGE HOURS)




TAMPA ELECTRIC CO.
BIG BEND UNIT #1
EMOF (ADJUSTED FOR PLANNED OUTAGE HOURS)




TAMPA ELECTRIC CO.
BIG BEND UNIT #2
EFOF (ADJUSTED FOR PLANNED OUTAGE HOURS)




TAMPA ELECTRIC CO.
BIG BEND UNIT #2
EMOF (ADJUSTED FOR PLANNED OUTAGE HOURS)




TAMPA ELECTRIC CO.
BIG BEND UNIT #3
EFOF (ADJUSTED FOR PLANNED OUTAGE HOURS)




TAMPA ELECTRIC CO.
BIG BEND UNIT #3
EMOF (ADJUSTED FOR PLANNED OUTAGE HOURS)




TAMPA ELECTRIC CO.
BIG BEND UNIT #4
EEOF (ADJUSTED FOR PLANNED OUTAGE HOURS)



TAMPA ELECTRIC CO.
BIG BEND UNIT #4
EMOF (ADJUSTED FOR PLANNED OUTAGE HOURS)




TAMPA ELECTRIC COMPANY
 HEAT RATE VS. NET OUTPUT FACTOR
 GANNON 5, SUMMER 1994



TARGET NET HEAT RATE: 10408
 TARGET NET OUTPUT FACTOR: 69.9


100E 27 OF 35

TAMPA ELECTRIC COMPANY
 HEAT RATE VS. NET OUTPUT FACTOR
 GANNON 6, SUMMER 1994




TARGET NET HEAT RATE: 10454
 TARGET NET OUTPUT FACTOR: 65.9

TAMPA ELECTRIC COMPANY
 HEAT RATE VS. NET OUTPUT FACTOR
 BIG BEND 1, SUMMER 1994




TARGET NET HEAT RATE: 10062
 TARGET NET OUTPUT FACTOR: 90.2

TAMPA ELECTRIC COMPANY
HEAT RATE VS. NET OUTPUT FACTOR
BIG BEND 2, SUMMER 1994




TARGET NET HEAT RATE: 10069
TARGET NET OUTPUT FACTOR: 87.7

TAMPA ELECTRIC COMPANY
 HEAT RATE VS. NET OUTPUT FACTOR
 BIG BEND 3, SUMMER 1994



TARGET NET HEAT RATE: 9676
 TARGET NET OUTPUT FACTOR: 87.8

TAMPA ELECTRIC COMPANY
 HEAT RATE VS. NET OUTPUT FACTOR
 BIG BEND 4, SUMMER 1994



TARGET NET HEAT RATE: 10114
 TARGET NET OUTPUT FACTOR: 87.6

TAMPA ELECTRIC COMPANY
TABLE 4.2
GENERATING UNITS IN GPIF
APRIL 1994 - SEPTEMBER 1994

<u>UNIT</u>	<u>MDC</u> <u>GROSS (MW)</u>	<u>NDC</u> <u>NET (MW)</u>
GANNON 5	240	227
GANNON 6	375	362
BIG BEND 1	420	405
BIG BEND 2	420	406
BIG BEND 3	445	430
BIG BEND 4	<u>475</u>	<u>441</u>
TOTAL	2375	2271
SYSTEM TOTAL	3410	3262
% OF SYSTEM TOTAL	69.65%	69.62%

TAMPA ELECTRIC COMPANY
UNIT RATINGS
APRIL 1994 - SEPTEMBER 1994

UNIT	MDC GROSS (MW)	NDC NET (MW)
HOOKERS POINT 1	33	32
HOOKERS POINT 2	33	32
HOOKERS POINT 3	33	32
HOOKERS POINT 4	43	41
HOOKERS POINT 5	<u>70</u>	<u>67</u>
HOOKERS TOTAL.	212	204
GANNON 1	125	119
GANNON 2	125	119
GANNON 3	165	155
GANNON 4	200	189
GANNON 5	240	227
GANNON 6	<u>375</u>	<u>362</u>
GANNON TOTAL	1230	1171
BIG BEND 1	420	405
BIG BEND 2	420	406
BIG BEND 3	445	430
BIG BEND 4	<u>475</u>	<u>441</u>
BIG BEND TOTAL	1760	1682
GANNON C.T.	15	15
BIG BEND C.T. 1	15	15
BIG BEND C.T. 2	65	65
BIG BEND C.T. 3	<u>65</u>	<u>65</u>
C.T. TOTAL	160	160
PHILLIPS 1	18	17
PHILLIPS 2	18	17
DINNER LAKE	<u>12</u>	<u>11</u>
SEBRING TOTAL	<u>46</u>	<u>45</u>
SYSTEM TOTAL	3410	3262

TAMPA ELECTRIC COMPANY
 PERCENT GENERATION BY UNIT
 APRIL 1984 - SEPTEMBER 1984

STATION	UNIT	NET OUTPUT MWH	% OF PROJECTED OUTPUT	% CUMULATIVE PROJECTED OUTPUT
BIG BEND	4	1582247	18.55%	18.55%
BIG BEND	3	1497315	17.66%	64.88%
BIG BEND	2	1443630	16.92%	35.47%
BIG BEND	1	1009822	11.84%	47.31%
GANNON	6	851211	11.18%	76.01%
GANNON	5	620912	7.20%	83.29%
GANNON	3	387310	4.86%	87.95%
GANNON	4	309519	3.63%	91.58%
GANNON	1	278101	3.28%	94.84%
GANNON	2	215372	2.52%	97.36%
HOOKERS POINT	5	68571	0.77%	98.13%
HOOKERS POINT	4	42459	0.60%	98.63%
HOOKERS POINT	2	28812	0.34%	98.97%
HOOKERS POINT	3	24680	0.29%	99.79%
HOOKERS POINT	1	18466	0.22%	99.50%
PHILLIPS	2	17166	0.20%	99.28%
PHILLIPS	1	8959	0.11%	99.08%
BIG BEND CT	2	7198	0.08%	99.96%
BIG BEND CT	3	5300	0.06%	99.90%
DINNER LAKE		4416	0.05%	99.84%
GANNON CT		968	0.01%	99.99%
BIG BEND CT	1	891	0.01%	100.00%
<hr/>				
TOTAL GENERATION		8530330.0	100.00%	

GENERATION BY COAL UNITS: 8505448 MWH

% GENERATION BY COAL UNITS: 97.36%

GENERATION BY OIL UNITS: 224882 MWH

% GENERATION BY OIL UNITS: 2.64%

GENERATION BY GPIF UNITS: 7105140 MWH

% GENERATION BY GPIF UNITS 63.29%

EXHIBIT NO. _____
DOCKET NO. 940001-EI
TAMPA ELECTRIC COMPANY
(GAK-3)
PAGE 1 OF 23

TAMPA ELECTRIC COMPANY
GENERATING PERFORMANCE INCENTIVE FACTOR
APRIL 1994 - SEPTEMBER 1994
TABLE OF CONTENTS

<u>SCHEDULE</u>	<u>PAGE</u>
BIG BEND 1 - ESTIMATED UNIT PERFORMANCE DATA	2
BIG BEND 2 - ESTIMATED UNIT PERFORMANCE DATA	3
BIG BEND 3 - ESTIMATED UNIT PERFORMANCE DATA	4
BIG BEND 4 - ESTIMATED UNIT PERFORMANCE DATA	5
GANNON 1 - ESTIMATED UNIT PERFORMANCE DATA	6
GANNON 2 - ESTIMATED UNIT PERFORMANCE DATA	7
GANNON 3 - ESTIMATED UNIT PERFORMANCE DATA	8
GANNON 4 - ESTIMATED UNIT PERFORMANCE DATA	9
GANNON 5 - ESTIMATED UNIT PERFORMANCE DATA	10
GANNON 6 - ESTIMATED UNIT PERFORMANCE DATA	11
HOOKERS POINT 1 - ESTIMATED UNIT PERFORMANCE DATA	12
HOOKERS POINT 2 - ESTIMATED UNIT PERFORMANCE DATA	13
HOOKERS POINT 3 - ESTIMATED UNIT PERFORMANCE DATA	14
HOOKERS POINT 4 - ESTIMATED UNIT PERFORMANCE DATA	15
HOOKERS POINT 5 - ESTIMATED UNIT PERFORMANCE DATA	16
GANNON CT1 - ESTIMATED UNIT PERFORMANCE DATA	17
BIG BEND CT1 - ESTIMATED UNIT PERFORMANCE DATA	18
BIG BEND CT2 - ESTIMATED UNIT PERFORMANCE DATA	19
BIG BEND CT3 - ESTIMATED UNIT PERFORMANCE DATA	20
PHILLIPS 1 - ESTIMATED UNIT PERFORMANCE DATA	21
PHILLIPS 2 - ESTIMATED UNIT PERFORMANCE DATA	22
DINNER LAKE - ESTIMATED UNIT PERFORMANCE DATA	23

TAMPA ELECTRIC COMPANY
 ESTIMATED UNIT PERFORMANCE DATA
 APRIL 1994 - SEPTEMBER 1994

PLANT/UNIT BIG BEND 1	MONTH OF: APR 94	MONTH OF: MAY 94	MONTH OF: JUN 94	MONTH OF: JUL 94	MONTH OF: AUG 94	MONTH OF: SEP 94	PERIOD SUMMER 1994
1. EAF (%)	22.4	0.0	78.0	64.4	84.4	84.4	58.6
2. POF (%)	73.4	100.0	10.0	0.0	0.0	0.0	30.6
3. EUOF (%)	4.2	0.0	14.0	15.6	15.6	15.6	10.8
4. EUOR (%)	15.7	0.0	15.6	15.6	15.6	15.6	15.6
5. PH	719	744	720	744	744	720	4391
6. SH	174	0	586	674	674	656	2764
7. RSH	0	0	0	0	0	0	0
8. UH	545	744	134	70	70	64	1627
9. POH	528	744	72	0	0	0	1344
10. FOH & EFOH	21	0	72	53	83	79	336
11. MOH & EMOH	9	0	29	33	33	33	137
12. OPER BTU (GBTU)	640,448	0,000	2156,446	2492,636	2486,539	2382,917	10160,786
13. NET GEN (MWH)	61796	0	214696	246520	246093	237515	1009822
14. ANOHR (BTU/KWH)	9884	0	10035	10111	10111	10033	10062
15. NOF (%)	91.9	0.0	90.5	90.3	90.2	89.4	90.2
16. NSC (MW)	405	405	405	405	405	405	405

17. ANOHR EQUATION:

$$\text{ANOHR} = \text{NOF} (-13.9140) + 11317.0$$

FILED:
 SUSPENDED:
 EFFECTIVE: 4/01/94
 DOCKET NO: 940001-E

**TAMPA ELECTRIC COMPANY
ESTIMATED UNIT PERFORMANCE DATA
APRIL 1994 - SEPTEMBER 1994**

PLANT/UNIT BIG BEND 2	MONTH OP:						PERIOD SUMMER 1994
	APR 94	MAY 94	JUN 94	JUL 94	AUG 94	SEP 94	
1. EAF (%)	87.8	87.8	87.8	87.8	87.8	87.4	87.8
2. PDF (%)	0.0	0.0	0.0	0.0	0.0	0.0	0.0
3. EUOF (%)	12.4	12.4	12.4	12.4	12.4	12.6	12.4
4. EUOR (%)	12.4	12.4	12.4	12.4	12.4	12.6	12.4
5. PH	719	744	720	744	744	720	4991
6. BH	664	666	664	666	666	668	4054
7. RSH	0	0	0	0	0	0	0
8. UH	55	58	58	58	58	52	537
9. POH	0	0	0	0	0	0	0
10. FOH & EFOH	68	68	68	68	68	68	404
11. MOH & EMOH	23	24	23	24	24	23	141
12. OPER BTU (GBTU)	2425.433	2530.729	2583.224	2440.293	2428.286	2327.522	14535.587
13. NET GEN (MWH)	243525	253473	238053	240800	239599	230069	144339
14. ANOHR (BTU/KWH)	9960	9964	10098	10130	10135	10116	10069
15. NOF (%)	90.3	91.0	87.8	86.5	86.0	84.8	87.7
16. NSC (MW)	406	406	406	406	406	406	406

17. ANOHR EQUATION: $ANOHR = NOF (-7.3385) + 10712.3$

FILED:
SUSPENDED:
EFFECTIVE: 4/01/94
DOCKET NO. : 940001-EI

**TAMPA ELECTRIC COMPANY
ESTIMATED UNIT PERFORMANCE DATA
APRIL 1994 - SEPTEMBER 1994**

PLANT/UNIT BIG BEND 3	MONTH OF:						PERIOD SUMMER 1994
	APR 94	MAY 94	JUN 94	JUL 94	AUG 94	SEP 94	
1. EAF (%)	83.6	83.5	83.6	83.5	83.5	83.3	83.5
2. POF (%)	0.0	0.0	0.0	0.0	0.0	0.0	0.0
3. EUOF (%)	16.4	16.5	16.4	16.5	16.5	16.7	16.5
4. EUOR (%)	16.4	16.5	16.4	16.5	16.5	16.7	16.5
5. PH	719	744	720	744	744	720	4991
6. SH	649	671	649	671	671	654	3965
7. RSH	0	0	0	0	0	0	0
8. UH	70	73	71	73	73	66	426
9. POH	0	0	0	0	0	0	0
10. FOH & EFOH	78	81	78	81	81	80	479
11. MOH & EMOH	40	42	40	42	42	40	246
12. OPER BTU (GBTU)	2368.973	2489.357	2391.827	2442.866	2436.653	2359.087	14488.783
13. NET GEN (MWH)	245572	256809	246771	252635	251990	243598	1497315
14. ANOHR (BTU/KWH)	9647	9693	9692	9670	9670	9687	9676
15. NOF (%)	88.0	89.0	88.4	87.6	87.3	86.6	87.8
16. NSC (MW)	430	430	430	430	430	430	430

17. ANOHR EQUATION:
$$\text{ANOHR} = \text{NOF} (-7.1595) + 10305.1$$

FILED:
SUSPENDED:
EFFECTIVE: 4/01/94
DOCKET NO. : 940001-EI

TAMPA ELECTRIC COMPANY
ESTIMATED UNIT PERFORMANCE DATA
APRIL 1994 - SEPTEMBER 1994

PLANT/UNIT BIG BEND 4	MONTH OF:						PERIOD SUMMER 1994
	APR 94	MAY 94	JUN 94	JUL 94	AUG 94	SEP 94	
1. EAF (%)	88.2	88.0	88.2	88.0	88.0	88.2	88.1
2. POF (%)	0.0	0.0	0.0	0.0	0.0	0.0	0.0
3. EUOF (%)	11.8	12.0	11.8	12.0	12.0	11.8	11.9
4. EUOR (%)	11.8	12.0	11.6	12.0	12.0	11.8	11.9
5. PH	719	744	720	744	744	720	4391
6. SH	671	683	671	693	653	674	4095
7. RSH	0	0	0	0	0	0	0
8. UH	48	51	49	51	51	48	296
9. POH	0	0	0	0	0	0	0
10. FOH & EFOH	68	71	68	71	71	68	417
11. MOH & EMOH	17	18	17	18	18	17	105
12. OPER BTU (GBTU)	2649.522	2765.023	2631.098	2692.630	2682.801	2681.462	16002.734
13. NET GEN (MWH)	265591	274984	259834	264041	263045	254772	1582247
14. ANOHR (BTU/KWH)	9976	10056	10126	10199	10199	10132	10114
15. NOF (%)	89.8	90.0	87.8	86.4	86.1	85.7	87.6
16. NSC (MW)	441	441	441	441	441	441	441

17. ANOHR EQUATION: ANOHR = NOF (-12.3330) + 11194.3

FILED:
SUSPENDED:
EFFECTIVE: 4/01/94
DOCKET NO. : 940001-EI

TAMPA ELECTRIC COMPANY
 ESTIMATED UNIT PERFORMANCE DATA
 APRIL 1994 - SEPTEMBER 1994

PLANT/UNIT GANNON 1	MONTH OP: APR94	MONTH OP: MAY94	MONTH OP: JUN94	MONTH OP: JUL94	MONTH OP: AUG94	MONTH OP: SEP94	PERIOD SUMMER 1994
1. EAF (%)	90.7	96.0	95.3	95.3	92.9	94.0	93.9
2. POF (%)	3.3	0.0	0.0	0.0	0.0	0.0	0.5
3. EUOF (%)	6.0	5.0	4.7	4.7	7.1	6.0	5.8
4. EUOR (%)	7.0	7.2	7.1	7.1	7.1	7.0	7.1
5. PH	719	744	720	744	744	720	4391
6. SH	501	495	482	478	717	593	3336
7. RSH	63	230	241	249	0	106	909
8. UH	45	19	17	17	27	21	146
9. POH	24	0	0	0	0	0	24
10. FOH & EFOH	27	23	21	22	33	27	153
11. MOH & EMOH	16	14	13	13	20	16	92
12. OPER BTU (GBTU)	479,689	522,596	489,982	493,060	631,534	517,297	3113,938
13. NET GEN (MWH)	42957	47349	42328	44070	55471	45928	278101
14. ANOMR (BTU/KWH)	11168	11033	11104	11168	11385	11263	11197
15. NOF (%)	61.1	60.4	77.0	77.5	65.0	65.1	70.1
16. NSC (MW)	119	119	119	119	119	119	119

FILED:
 SUSPENDED:
 EFFECTIVE: 4/01/94
 DOCKET NO. : 940001-E

TAMPA ELECTRIC COMPANY
 ESTIMATED UNIT PERFORMANCE DATA
 APRIL 1994 - SEPTEMBER 1994

PLANT/UNIT GANNON 2	MONTH OF: APR94	MONTH OF: MAY94	MONTH OF: JUN94	MONTH OF: JUL94	MONTH OF: AUG94	MONTH OF: SEP94	PERIOD SUMMER 1994
1. EAF (%)	77.3	66.4	89.4	89.5	84.3	90.3	82.8
2. POF (%)	10.0	22.6	0.0	0.0	0.0	0.0	5.5
3. EUOF (%)	12.7	11.0	10.6	10.5	15.7	9.7	11.7
4. EUOR (%)	15.9	15.8	15.9	15.8	15.8	15.9	15.9
5. PH	719	744	720	743	744	720	4391
6. SH	502	454	418	432	649	386	2841
7. RSH	74	58	243	251	4	279	809
8. UH	143	232	59	61	91	53	641
9. POH	72	168	0	0	0	0	240
10. FOH & EFOH	60	54	50	51	77	46	338
11. MOH & EMOH	31	26	26	27	40	24	176
12. OPER BTU (3BTU)	361,575	408,679	401,484	401,149	528,669	353,625	2462,181
13. NET GEN (MWH)	32515	36577	35583	34764	44839	31074	213371
14. ANOHR (BTU/KWH)	11336	11173	11283	11523	11790	11880	11432
15. NOF (%)	54.4	67.7	71.5	67.7	58.1	67.6	63.7
16. NSC (MW)	119	119	119	119	119	119	119

FILED:
 SUSPENDED:
 EFFECTIVE: 4/01/94
 DOCKET NO. : 940001-EI

**TAMPA ELECTRIC COMPANY
ESTIMATED UNIT PERFORMANCE DATA
APRIL 1994 - SEPTEMBER 1994**

PLANT/UNIT GANNON 3	MONTH OF:						PERIOD SUMMER 1994
	APR94	MAY94	JUN94	JUL94	AUG94	SEP94	
1. EAF (%)	92.5	92.5	93.2	92.5	92.5	92.5	92.5
2. POF (%)	0.0	0.0	0.0	0.0	0.0	0.0	0.0
3. EUOF (%)	7.5	7.5	6.8	7.5	7.5	7.5	7.4
4. EUOR (%)	7.5	7.5	7.6	7.5	7.5	7.5	7.5
5. PH	719	744	720	744	744	720	4391
6. SH	667	689	594	689	689	667	3995
7. RSH	-1	0	76	0	0	0	77
8. UH	53	55	48	55	55	53	319
9. POH	0	0	0	0	0	0	0
10. FCH & EFOH	38	39	34	39	39	38	227
11. MOH & EMCH	16	17	15	17	17	16	96
12. OPER BTU (GBTU)	666,369	813,306	703,346	778,605	777,108	714,200	4455,554
13. NET GEN (MWH)	59942	73608	63203	68823	68609	63125	397310
14. ANOHR (BTU/KWH)	11151	11040	11129	11313	11327	11314	11214
15. NOF (%)	68.0	68.9	68.5	64.4	64.2	51.1	64.2
16. NSC (MW)	155	155	155	155	155	155	155

FILED:
SUSPENDED:
EFFECTIVE: 4/01/94
DOCKET NO. : 940001-EI

**TAMPA ELECTRIC COMPANY
ESTIMATED UNIT PERFORMANCE DATA
APRIL 1994 - SEPTEMBER 1994**

PLANT/UNIT GANNON 4	MONTH OF:						PERIOD SUMMER 1994
	APR94	MAY94	JUN94	JUL94	AUG94	SEP94	
1. EAF (%)	86.4	86.8	86.4	86.6	83.5	0.0	63.3
2. POF (%)	0.0	0.0	0.0	0.0	81.3	100.0	26.8
3. EUOF (%)	13.8	13.4	13.8	13.4	5.2	0.0	9.9
4. EUOR (%)	13.8	13.5	13.8	13.5	13.8	0.0	13.8
5. PH	719	744	720	744	744	720	4391
6. SH	652	674	652	674	281	0	2913
7. RSH	1	3	2	3	1	0	10
8. UH	68	67	68	67	482	720	1468
9. POH	0	0	0	0	456	720	1176
10. FOH & EFOH	89	71	69	71	26	0	306
11. MOH & EMOH	29	29	29	29	11	0	127
12. OPER BTU (GBTU)	635,749	614,620	761,870	793,794	312,299	0,000	3306,332
13. NET GEN (MWH)	59019	77067	70294	73975	29164	0	308519
14. ANOHR (BTU/KWH)	10772	10570	10696	10731	10706	0	10689
15. NOF (%)	47.9	60.5	57.0	58.1	59.1	0.0	56.2
16. NSC (MW)	169	169	169	169	169	169	169

FILED:
SUSPENDED:
EFFECTIVE: 4/01/94
DOCKET NO. : 040001--EI

TAMPA ELECTRIC COMPANY
 ESTIMATED UNIT PERFORMANCE DATA
 APRIL 1994 - SEPTEMBER 1994

PLANT/UNIT GANNON 5	MONTH OP:	PERIOD SUMMER 1994					
	APR 94	MAY 94	JUN 94	JUL 94	AUG 94	SEP 94	
1. EAF (%)	63.4	26.4	86.5	86.4	86.4	86.7	82.7
2. POF (%)	28.7	0.0	0.0	0.0	0.0	0.0	4.4
3. EUOF (%)	9.9	13.6	13.5	13.6	13.6	13.3	12.9
4. EUOR (%)	13.5	13.6	13.5	13.6	13.6	13.3	13.5
5. PH	719	744	720	744	744	720	4991
6. SH	492	693	671	693	693	671	3913
7. RSH	0	0	0	0	0	0	0
8. LH	227	51	49	51	51	49	478
9. POH	192	0	0	0	0	0	192
10. FOH & EFOH	58	82	79	82	82	79	462
11. MOH & EMOH	13	19	18	19	19	17.	105
12. OPER BTU (GBTU)	762,577	1202,002	1129,671	1149,638	1143,942	1074,211	6462,541
13. NET GEN (MWH)	74330	117250	106789	109110	106404	102930	620912
14. ANOHR (BTU/RWH)	10282	10252	10384	10538	10544	10436	10408
15. NOF (%)	66.6	74.5	71.4	69.4	69.0	67.8	69.9
16. NBC (MW)	227	227	227	227	227	227	227

17. ANOHR EQUATION: $ANOHR = NOF (-19.0860) + 11780.7$

FILED:
 SUSPENDED:
 EFFECTIVE: 4/01/94
 DOCKET NO. : 940001-EI

**TAMPA ELECTRIC COMPANY
ESTIMATED UNIT PERFORMANCE DATA
APRIL 1994 - SEPTEMBER 1994**

PLANT/UNIT GANNON 6	MONTH OF:						PERIOD SUMMER 1994
	APR 94	MAY 94	JUN 94	JUL 94	AUG 94	SEP 94	
1. EAF (%)	83.0	83.2	83.1	83.2	83.2	82.9	83.1
2. POF (%)	0.0	0.0	0.0	0.0	0.0	0.0	0.0
3. EUOF (%)	17.0	16.8	16.9	16.6	16.8	17.1	16.9
4. EUOA (%)	17.0	16.8	16.9	16.6	16.8	17.1	16.9
5. PH	719	744	720	744	744	720	4391
6. SH	653	675	653	675	675	656	3967
7. RSH	0	0	0	0	0	0	0
8. UH	66	69	67	69	69	64	404
9. POH	0	0	0	0	0	0	0
10. FOH & EFOH	100	103	100	103	103	101	510
11. MOH & EMOH	22	22	22	22	22	22	132
12. OPER BTU (GBTU)	1506.731	1796.295	1669.392	1696.997	1685.116	1587.655	9944.186
13. NET GEN (MWH)	144975	173845	160091	161022	159775	151503	951211
14. ANOHR (BTU/KWH)	10407	10333	10428	10539	10547	10479	10454
15. NOF (%)	61.3	71.1	67.7	65.9	65.4	63.8	65.8
16. NSC (MW)	362	362	362	362	362	362	362

17. ANOHR EQUATION: $\text{ANOHR} = \text{NOF} (-13.1600) + 11322.6$

FILED:
SUSPENDED:
EFFECTIVE: 4/01/94
DOCKET NO. : 940001-EI

TAMPA ELECTRIC COMPANY
ESTIMATED UNIT PERFORMANCE DATA
APRIL 1994 - SEPTEMBER 1994

PLANT/UNIT HOOKERS POINT 1	MONTH OF:						PERIOD SUMMER 1994
	APR94	MAY94	JUN94	JUL94	AUG94	SEPT94	
1. EAF (%)	99.6	92.6	92.5	25.1	77.8	92.4	79.8
2. POF (%)	0.0	0.0	0.0	74.2	15.1	0.0	15.3
3. EUOF (%)	0.4	7.4	7.5	0.7	6.0	7.6	4.8
4. EUOR (%)	13.6	15.0	14.9	16.1	14.7	15.1	14.6
5. PH	719	744	720	744	744	720	4591
6. SH	19	311	308	26	262	310	1230
7. RSH	697	378	358	161	317	355	2206
8. UH	3	55	54	557	165	55	890
9. FOH	0	0	0	552	120	0	672
10. FOH & EFOH	3	47	46	4	39	47	186
11. MOH & EMOH	0	8	8	1	6	8	31
12. OPER BTU (GBTU)	8,486	58,771	73,483	12,273	77,541	79,952	310,616
13. NET GEN (MWH)	567	3261	4323	805	4714	4796	18466
14. AHOMR (BTU/ROWH)	14966	18022	16998	15246	16470	16673	16821
15. NCF (%)	93.3	32.8	43.9	96.8	56.2	48.3	46.7
16. NSC (MW)	32	32	32	32	32	32	32

FILED:
SUSPENDED:
EFFECTIVE: 4/01/94
DOCKET NO. : 940001-EI

**TAMPA ELECTRIC COMPANY
ESTIMATED UNIT PERFORMANCE DATA
APRIL 1994 - SEPTEMBER 1994**

PLANT/UNIT HOOKERS POINT 2	MONTH OF:					MONTH OF: SEP94	PERIOD SUMMER 1994
	APR94	MAY94	JUN94	JUL94	AUG94		
1. EAF (%)	48.0	96.2	96.1	96.1	96.8	96.1	88.2
2. POF (%)	50.1	0.0	0.0	0.0	0.0	0.0	8.2
3. EUOF (%)	1.9	3.8	3.9	3.9	4.2	3.9	3.6
4. EUOR (%)	7.7	7.4	7.5	7.5	7.5	7.4	7.5
5. PH	719	744	720	744	744	720	4391
6. SH	167	350	346	360	380	350	1943
7. RSH	178	366	346	355	333	342	1920
8. UH	374	28	28	29	31	26	518
9. POH	360	0	0	0	0	0	360
10. FOH & EFOH	5	10	10	10	11	10	102
11. MOH & EMCH	9	16	16	19	20	16	405.944
12. OPER BTU (GBTU)	25,048	53,473	70,480	79,650	99,000	78,213	21812
13. NET GEN (MWH)	1758	3738	5002	5630	7085	5569	14096
14. ANOHR (BTU/KWH)	14167	14305	14060	14144	13973	13924	14096
15. NOF (%)	33.1	33.4	45.2	48.9	58.3	49.9	46.1
16. NSC (MW)	32	32	32	32	32	32	32

FILED:
SUSPENDED:
EFFECTIVE: 4/01/94
DOCKET NO. : 940001-EI

TAMPA ELECTRIC COMPANY
ESTIMATED UNIT PERFORMANCE DATA
APRIL 1994 - SEPTEMBER 1994

PLANT/UNIT HOOKERS POINT 3	MONTH OF:						PERIOD SUMMER 1994
	APR94	MAY94	JUN94	JUL94	AUG94	SEP94	
1. EAF (%)	97.2	97.3	90.7	10.9	71.2	97.2	78.6
2. POF (%)	0.0	0.0	0.0	67.1	25.8	0.0	19.1
3. EUOF (%)	2.8	2.7	0.3	2.0	3.0	2.6	2.3
4. EUOR (%)	5.8	5.5	5.1	5.4	5.5	5.5	5.5
5. PH	719	744	720	744	744	720	4561
6. SH	335	345	37	261	375	345	1676
7. RSH	364	379	681	-180	155	345	1754
8. UH	20	20	2	663	214	20	939
9. POH	0	0	0	648	192	0	640
10. FOH & EFOH	13	13	1	10	14	13	64
11. MOH & EMCH	7	7	1	5	8	7	35
12. OPER BTU (GBTU)	63,831	65,063	8,822	67,079	111,068	90,927	409,790
13. NET GEN (MW)	3665	3901	533	4002	6849	6630	24580
14. ANOHR (BTU/MWH)	17416	17448	16552	16761	16217	16150	16672
15. NOF (%)	34.2	35.3	45.0	47.9	57.1	51.0	45.2
16. NSC (MW)	32	32	32	32	32	32	32

FILED:
SUSPENDED:
EFFECTIVE: 4/01/94
DOCKET NO. : 940001-EI

**TAMPA ELECTRIC COMPANY
ESTIMATED UNIT PERFORMANCE DATA
APRIL 1994 - SEPTEMBER 1994**

PLANT/UNIT HOOKERS POINT 4	MONTH OF: APR94	MONTH OF: MAY94	MONTH OF: JUN94	MONTH OF: JUL94	MONTH OF: AUG94	MONTH OF: SEP94	PERIOD SUMMER 1994
1. EAF (%)	96.2	96.2	96.1	96.2	74.5	96.1	92.5
2. POF (%)	0.0	0.0	0.0	0.0	22.6	0.0	3.8
3. EUOF (%)	3.8	3.8	3.9	3.8	3.1	3.9	3.7
4. EUOR (%)	7.5	7.6	7.3	7.3	7.3	7.5	7.4
5. PH	719	744	720	744	744	720	4391
6. SH	333	342	353	355	290	344	2017
7. RSH	359	374	339	361	263	348	2044
8. UH	27	28	28	28	191	28	330
9. POH	0	0	0	0	168	0	168
10. FOH & EFON	18	19	19	19	16	19	110
11. MOH & EMCH	9	9	9	9	7	9	52
12. OPER BTU (GJ/TU)	79,909	84,613	105,009	112,774	104,984	111,642	601,931
13. NET GEN (MWH)	5555	5827	7551	7914	7622	7990	42459
14. ANOHR (BTU/KWH)	14385	14521	14117	14250	13957	13973	14177
15. NOF (%)	40.7	41.6	52.9	54.4	66.3	56.7	51.3
16. NSC (MW)	41	41	41	41	41	41	.41

FILED:
SUSPENDED:
EFFECTIVE: 4/1/94
DOCKET NO. : 940001-E

**TAMPA ELECTRIC COMPANY
ESTIMATED UNIT PERFORMANCE DATA
APRIL 1994 - SEPTEMBER 1994**

PLANT/UNIT HOOKERS POINT 5	MONTH OF:						PERIOD SUMMER 1994
	APR94	MAY94	JUN94	JUL94	AUG94	SEP94	
1. EAF (%)	89.4	83.5	83.3	83.1	82.4	83.2	83.1
2. POF (%)	0.0	0.0	0.0	0.0	0.0	0.0	0.0
3. EUOF (%)	16.6	16.5	16.7	16.9	17.6	16.8	16.9
4. EUOR (%)	28.3	28.3	28.2	28.3	28.3	28.1	28.3
5. PH	719	744	720	744	744	720	4391
6. SH	302	312	305	319	332	309	1879
7. RSH	296	309	295	299	281	290	1772
8. UH	119	123	120	126	131	121	740
9. POH	0	0	0	0	0	0	0
10. FOH & EFOH	48	50	46	51	53	49	299
11. MOH & EMOH	71	73	72	75	78	72	441
12. OPER BTU (GSTU)	127,776	136,705	155,796	171,467	197,417	169,778	958,939
13. NET GEN (MWH)	8302	8869	10626	11795	14074	11905	65571
14. ANOHR (BTU/KWH)	15391	15414	14662	14537	14027	14261	14624
15. NOF (%)	41.0	42.4	52.0	55.2	63.3	57.5	52.1
16. NSC (MW)	67	67	67	67	67	67	67

FILED:
SUSPENDED:
EFFECTIVE: 4/01/94
DOCKET NO. : 940001-EI

TAMPA ELECTRIC COMPANY
 ESTIMATED UNIT PERFORMANCE DATA
 APRIL 1994 - SEPTEMBER 1994

PLANT/UNIT GANNON CT 1	MONTH OP: APR94	MONTH OP: MAY94	MONTH OP: JUN94	MONTH OP: JUL94	MONTH OP: AUG94	MONTH OP: SEPT94	PERIOD SUMMER 1994
1. EAF (%)	89.0	99.5	99.5	99.3	98.8	99.3	91.6
2. POF (%)	46.7	0.0	0.0	0.0	0.0	0.0	7.7
3. EUOF (%)	0.3	0.4	0.7	0.7	1.2	0.7	0.7
4. EUOR (%)	40.0	27.3	31.3	27.8	30.0	33.3	30.5
5. PH	719	744	720	744	744	720	4391
6. SH	5	8	11	13	21	10	66
7. RSH	378	733	704	728	714	705	3960
8. UH	338	3	5	5	0	5	365
9. POH	336	0	0	0	0	0	336
10. FOH & EFOH	1	2	3	3	5	3	17
11. MOH & EMOH	1	1	2	2	4	2.	12
12. OPER BTU (GBTU)	0.938	2,269	2,876	3,442	5,854	2,827	18,206
13. NET GEN (MWH)	50	121	153	183	311	150	968
14. ANOHR (BTU/KWH)	18760	18762	18797	18809	18823	18847	18808
15. NOF (%)	111.1	100.8	92.7	93.8	98.7	100.0	97.8
16. NSC (MW)	15	15	15	15	15	15	15

FILED:
 SUSPENDED:
 EFFECTIVE: 4/01/94
 DOCKET NO. : 940001-EI

TAMPA ELECTRIC COMPANY
ESTIMATED UNIT PERFORMANCE DATA
APRIL 1994 - SEPTEMBER 1994

PLANT/UNIT REG BEND CT 1	MONTH OF:						PERIOD SUMMER 1994
	APR94	MAY94	JUN94	JUL94	AUG94	SEP94	
1. EAF (%)	90.6	90.6	83.1	90.3	90.6	90.3	91.7
2. POF (%)	0.0	0.0	46.7	0.0	0.0	0.0	7.7
3. EUOF (%)	0.4	0.4	0.3	0.7	1.2	0.7	0.8
4. EUOR (%)	33.3	27.3	20.6	29.4	31.0	33.3	30.7
5. PH	719	744	720	744	744	720	4391
6. SH	6	8	5	12	20	10	61
7. RSH	710	733	377	727	715	705	3957
8. UH	3	3	338	5	9	5	363
9. POH	0	0	336	0	0	0	336
10. FOH & EFOH	2	2	1	3	5	3	16
11. MOH & EMOH	1	1	1	2	4	2	11
12. OPER BTU (GBTU)	1,672	2,132	1,469	3,258	5,570	2,670	16,771
13. NET GEN (MWH)	89	113	78	173	296	142	891
14. ANOHR (BTU/KWH)	18787	18867	18833	18832	18816	18803	18823
15. NOF (%)	96.9	94.2	104.0	96.1	96.7	94.7	97.4
16. NSC (MW)	15	15	15	15	15	15	15

FILED:
SUSPENDED:
EFFECTIVE: 4/01/94
DOCKET NO. : 940001-EI

TAMPA ELECTRIC COMPANY
ESTIMATED UNIT PERFORMANCE DATA
APRIL 1994 - SEPTEMBER 1994

PLANT/UNIT BIG BEND CT 2	MONTH OF:						MONTH OF: SEP 94	PERIOD WINTER 1994
	APR 94	MAY 94	JUN 94	JUL 94	AUG 94			
1. EAF (%)	99.4	99.2	98.9	98.9	98.1	98.9	98.9	98.9
2. POF (%)	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
3. BUOF (%)	0.6	0.8	1.1	1.1	1.9	1.1	1.1	1.1
4. EUOR (%)	23.5	28.6	28.6	25.8	27.5	28.6	27.3	
5. PH	719	744	720	744	744	720	4391	
6. SH	13	15	20	23	37	20	128	
7. RSH	702	723	692	713	693	692	4215	
8. UH	4	6	8	8	14	8	48	
9. POH	0	0	0	0	0	0	0	
10. FOH & EFOH	2	3	4	4	7	4	24	
11. MOH & EMOH	2	3	4	4	7	4	24	
12. OPER BTU (GBTI)	11,443	13,162	17,949	21,202	34,348	17,777	115,881	
13. NET GEN (MWH)	708	815	1115	1318	2139	1103	7198	
14. ANOHR (BTU/KW)	16162	16150	16098	16086	16058	16117	16099	
15. NOF (%)	83.8	83.6	85.8	88.2	88.9	84.8	86.5	
16. NSC (MW)	65	65	65	65	65	65	65	

FILED:
SUSPENDED:
EFFECTIVE: 4/01/94
DOCKET NO: 940001-EI

TAMPA ELECTRIC COMPANY
ESTIMATED UNIT PERFORMANCE DATA
APRIL 1994 - SEPTEMBER 1994

PLANT/UNIT BIG BEND CT 3	MONTH OF: APR94	MONTH OF: MAY94	MONTH OF: JUN94	MONTH OF: JUL94	MONTH OF: AUG94	MONTH OF: SEP94	PERIOD SUMMER 1994
1. EAF (%)	99.4	54.6	99.2	99.2	98.7	99.2	91.5
2. POF (%)	0.0	45.2	0.0	0.0	0.0	0.0	7.7
3. EUOF (%)	0.8	0.3	0.8	0.8	1.3	0.8	0.8
4. EUOR (%)	28.6	25.0	27.3	25.0	25.0	28.6	26.4
5. PH	719	744	720	744	744	720	4391
6. SH	10	6	16	18	30	15	95
7. RSH	705	400	696	720	704	690	3926
8. LH	4	538	6	6	10	6	370
9. POH	0	536	0	0	0	0	336
10. FOH & EFOH	2	1	3	3	5	3	17
11. MOH & EMOH	2	1	3	3	5	3	17
12. OPER BTU (GBTU)	8.724	5.854	14.039	16.723	27.703	13.842	88.885
13. NET GEN (MWH)	539	367	871	1038	1723	858	5396
14. ANOHR (BTU/KWH)	16186	15951	16116	16111	16078	16133	16102
15. NOF (%)	82.9	94.1	83.8	88.7	88.4	88.0	87.4
16. NSC (MW)	65	65	65	65	65	65	65

FILED:
SUSPENDED:
EFFECTIVE: 4/01/94
DOCKET NO. : 940001-EI

TAMPA ELECTRIC COMPANY
ESTIMATED UNIT PERFORMANCE DATA
APRIL 1994 - SEPTEMBER 1994

PLANT/UNIT PHILLIPS 1	MONTH OF: APR94	MONTH OF: MAY94	MONTH OF: JUN94	MONTH OF: JUL94	MONTH OF: AUG94	MONTH OF: SEPT94	PERIOD SUMMER 1994
1. EAF (%)	98.6	98.4	98.3	24.6	79.4	95.7	81.9
2. POF (%)	0.0	0.0	0.0	74.2	16.1	0.0	15.3
3. EUOF (%)	1.4	1.8	3.8	1.2	4.4	4.3	2.8
4. EUOR (%)	18.5	18.2	18.5	18.8	18.5	18.3	18.5
5. FH	719	744	720	744	744	720	4991
6. SH	44	54	119	39	145	138	559
7. RSH	668	678	574	144	446	551	3068
8. UH	10	12	27	561	153	31	794
9. POH	0	0	0	552	120	0	872
10. FOH & EFOH	3	4	9	3	11	10	40
11. MOH & EMOH	7	8	18	6	22	21	82
12. OPER BTU/(MMBTU)	6,809	8,522	18,839	6,207	23,189	21,999	85,624
13. MFT GEN (MMBTU)	721	891	1970	650	2428	2290	8959
14. ANOHR (BTU/100W)	9569	9565	9563	9549	9551	9555	9557
15. MOF (%)	98.4	97.1	97.4	98.0	98.5	98.0	97.8
16. MSC (MM)	17	17	17	17	17	17	17

FILED:
SUSPENDED:
EFFECTIVE: 4/01/93
DOCKET NO.: 930001-EI

**TAMPA ELECTRIC COMPANY
ESTIMATED UNIT PERFORMANCE DATA
APRIL 1994 - SEPTEMBER 1994**

PLANT/UNIT PHILLIPS 2	MONTH OF:	PERIOD					
	APR94	MAY94	JUN94	JUL94	AUG94	SEP94	SUMMER 1994
1. EAF (%)	95.7	95.8	93.9	96.0	96.0	93.8	95.1
2. POF (%)	0.0	0.0	0.0	0.0	0.0	0.0	0.0
3. EUOF (%)	4.3	4.2	6.7	4.0	4.0	6.3	4.9
4. EUOR (%)	18.3	18.3	18.2	18.2	18.2	18.3	18.3
5. PH	719	744	720	744	744	720	4391
6. SH	138	138	216	135	135	201	963
7. RSH	550	575	456	579	579	474	3213
8. UH	31	31	48	30	30	45	215
9. POH	0	0	0	0	0	0	0
10. FOH & EFOH	10	10	16	10	10	15	71
11. MOH & EMOH	21	21	32	20	20	30	144
12. OPER BTU (GJ/TD)	23,341	24,622	38,798	24,103	23,411	35,989	170,254
13. NET GEN (MWtD)	2326	2491	3924	2439	2346	3640	17166
14. ANOHR (BTU/MWH)	10035	9884	9887	9882	9979	9887	9919
15. NOF (%)	93.6	100.3	100.9	100.4	96.5	100.6	99.0
16. NSC (MW)	18	18	18	18	18	18	18

FILED:
SUSPENDED:
EFFECTIVE: 4/01/93
DOCKET NO. : 930001-EI

**TAMPA ELECTRIC COMPANY
ESTIMATED UNIT PERFORMANCE DATA
APRIL 1994 - SEPTEMBER 1994**

PLANT/UNIT DINNER LAKE	MONTH OF:						PERIOD SUMMER 1994
	APR94	MAY94	JUN94	JUL94	AUG94	SEP94	
1. EAF (%)	99.3	99.3	97.5	96.8	95.3	96.7	97.5
2. POF (%)	0.0	0.0	0.0	0.0	0.0	0.0	0.0
3. EUOF (%)	0.7	0.7	2.5	3.2	4.7	3.3	2.5
4. EUOR (%)	20.0	20.0	21.2	21.6	21.5	21.6	21.4
5. PH	719	744	720	744	744	720	4391
6. SH	20	20	67	87	128	66	408
7. RSH	694	719	635	633	601	610	3972
8. UH	5	5	18	24	35	24	111
9. POH	0	0	0	0	0	0	0
10. FOH & EFOH	2	2	6	11	16	11	50
11. MOH & EMOH	3	3	10	13	19	13	61
12. OPER BTU (GBTU)	3,031	3,050	10,185	13,188	19,373	13,015	81,840
13. NET GEN (MMWH)	216	218	727	942	1384	929	4416
14. ANOHR (BTU/MMWH)	14032	13991	14010	13998	13998	14010	14004
15. NOF (%)	98.2	99.1	98.6	98.4	98.3	98.2	98.4
16. NSC (MW)	11	11	11	11	11	11	11

FILED:
SUSPENDED:
EFFECTIVE: 4/01/94
DOCKET NO. : 940001-EI