

ORIGINAL

Wootens

Docket No. 060368-WS

Application to Increase Rates and Charges
For a "Class A" Utility
In

Florida

VOLUME 6

Book 7

Set 56 of 57

Containing
Additional Engineering Requirements

Monthly Operating Reports

CMP _____

COM _____

CTR _____

ECR 1 _____

GCL _____

OPC _____

RCA _____

SCR _____

SGA _____

SEC _____

OTH _____

Aqua Utilities Florida, Inc.

DOCUMENT NUMBER-DATE

00886 JAN 26 8

FPSC-COMMISSION CLERK

Aqua Utilities Florida, Inc. Monthly Operating Reports

Wootens

	Tab Number	Page Number
Year: 2004		
January	1	3
February	2	5
March	3	7
April	4	9
May	5	11
June	6	13
July	7	14
August	8	16
September	9	18
October	10	20
November	11	22
December	12	24
Year: 2005		
January	1	26
February	2	28
March	3	30
April	4	32
May	5	34
June	6	36
July	7	38
August	8	40
September	9	42
October	10	44
November	11	46
December	12	48

MONTHLY OPERATION REPORT FOR PWSs TREATING RAW GROUND WATER OR PURCHASED FINISHED WATER



See Pages 4 for Instructions.

I. General Information for the Month/Year of: January, 2004

A. Public Water System (PWS) Information

PWS Name:	Wootens			PWS Identification Number:	2541280
PWS Type:	<input checked="" type="checkbox"/> Community	<input type="checkbox"/> Non-Transient Non-Community	<input type="checkbox"/> Transient Non-Community	<input type="checkbox"/> Consecutive	
Number of Service Connections at End of Month:	24			Total Population Served at End of Month:	60
PWS Owner:	Florida Water Services				
Contact Person:	Craig Anderson			Contact Person's Title:	VP Environmental Services
Contact Person's Mailing Address:	P.O. Box 609520	City:	Orlando	State:	Florida
Contact Person's Telephone Number:	(407) 598-4199			Contact Person's Fax Number:	(407) 598-4217
Contact Person's E-Mail Address:	craiga@florida-water.com				

B. Water Treatment Plant Information

Plant Name:	Wootens			Plant Telephone Number:	904-329-1122
Plant Address:	Hess Road			City:	Georgetown
Type of Water Treatment by Plant:	<input checked="" type="checkbox"/> Raw Ground Water	<input type="checkbox"/> Purchased Finished Water		State:	Florida
Permitted Maximum Day Operating Capacity of Plant, gallons per day:	60,000			Zip Code:	32139
Plant Category (per subsection 62-699.310(4), F.A.C.):	V			Plant Class (per subsection 62-699.310(4), F.A.C.):	D

Licensed Operators	Name	License Class	License Number	Day(s) / Shift(s) Worked
Lead/Chief Operator:	Paul Thompson	A	7251	Days 1st Shift
Other Operators:	Donald Holcomb	A	5091	Days 1st Shift

II. Certification by Lead/Chief Operator

I, the undersigned water treatment plant operator licensed in Florida, am the lead/chief operator of the water treatment plant identified in part I of this report. I certify that the information provided in this report is true and accurate to the best of my knowledge and belief. I certify that all drinking water treatment chemicals used at this plant conform to NSF International Standard 60 or other applicable standards referenced in subsection 62-555.320(3), F.A.C. I also certify that the following additional operations records for this plant were prepared each day that a licensed operator staffed or visited this plant during the month indicated above: (1) records of amounts of chemicals used and chemical feed rates; and (2) if applicable, appropriate treatment process performance records. Furthermore, I agree to provide these additional operations records to the PWS owner so the PWS owner can retain them, together with copies of this report, at a convenient location for at least ten years.

_____ Signature and Date	Paul Thompson _____ Printed or Typed Name	A-7251 _____ License Number
-----------------------------	---	-----------------------------------

MONTHLY OPERATION REPORT FOR PW'Ss TREATING RAW GROUND WATER OR PURCHASED FINISHED WATER

PWS Identification Number: 2541280 Plant Name: Wootens

III. Daily Data for the Month/Year of: January, 2004

Means of Achieving Four-Log Virus Inactivation/Removal: Free Chlorine Chlorine Dioxide Ozone Combined Chlorine (Chloramines)
 Ultraviolet Radiation Other (Describe):

Type of Disinfectant Residual Maintained in Distribution System: Free Chlorine Combined Chlorine (Chloramines) Chlorine Dioxide

Day of the Month	Days Plant Staffed or Visited by Operator (Place "X")	Hours plant in Operation	Net Quantity of Finished Water Produced, gal	CT Calculations, or UV Dose, to Demostate Four-Log Virus Inactivation, if Applicable*										Lowest Residual Disinfectant Concentration at Remote Point in Distribution System, mg/L	Emergency or Abnormal Operating Conditions: Repair or Maintenance Work that Involves Taking Water System Components Out of Operation	
				CT Calculations					UV Dose							
				Peak Flow Rate, gpd	Lowest Residual Disinfectant Concentration (C) Before or at First Customer During Peak Flow, mg/L	Disinfectant Contact Time (T) at C Measurement Point During Peak Flow, minutes	Lowest CT Provided Before or at First Customer During Peak Flow, mg-min/L	Temp of Water, °C	pH of Water, if Applicable	Minimum CT Required, mg-min/L	Lowest Operating UV Dose, mW-sec/cm ²	Minimum UV Dose Required, mW-sec/cm ²				
1	X	24.0	1,940		1.2										0.7	
2	X	24.0	2,880		1.5										0.6	
3		24.0	2,523													
4		24.0	2,523													
5	X	24.0	2,523		1.8										0.7	
6	X	24.0	2,190		2.3										1.0	
7	X	24.0	1,460		1.7										0.8	
8	X	24.0	2,900		1.4										0.5	
9	X	24.0	1,440		1.6										0.6	
10		24.0	2,723													
11		24.0	2,723													
12	X	24.0	2,723		1.8										0.8	
13	X	24.0	2,570		2.5										1.2	
14	X	24.0	2,770		1.6										0.7	
15	X	24.0	1,170		2.8										1.2	
16	X	24.0	2,620		2.6										1.0	
17		24.0	2,447													
18		24.0	2,447													
19	X	24.0	2,447		3.0										1.3	
20	X	24.0	3,560		2.5										1.1	
21	X	24.0	2,580		2.8										1.0	
22	X	24.0	2,360		3.0										1.6	
23	X	24.0	1,930		2.5										1.2	
24		24.0	2,480													
25		24.0	2,480													
26	X	24.0	2,480		2.5										1.0	
27	X	24.0	1,510		2.9										1.1	
28	X	24.0	2,560		3.0										1.3	
29	X	24.0	1,930		3.0										1.0	
30	X	24.0	1,390		2.8										0.9	
31		24.0														
Total			70,280													
Average			2,267													
Maximum			3,560													

* Refer to the instructions for this report to determine which plants must provide this information.

MONTHLY OPERATION REPORT FOR PW'Ss TREATING RAW GROUND WATER OR PURCHASED FINISHED WATER

PWS Identification Number: 2541280 Plant Name: Wootens

III. Daily Data for the Month/Year of: February, 2004

Means of Achieving Four-Log Virus Inactivation/Removal: Free Chlorine Chlorine Dioxide Ozone Combined Chlorine (Chloramines)
 Ultraviolet Radiation Other (Describe):

Type of Disinfectant Residual Maintained in Distribution System: Free Chlorine Combined Chlorine (Chloramines) Chlorine Dioxide

Day of the Month	Days Plant Staffed or Visited by Operator (Place "X")	Hours plant in Operation	Net Quantity of Finished Water Produced, gal.	CT Calculations, or UV Dose, to Demostate Four-Log Virus Inactivation, if Applicable*										Emergency or Abnormal Operating Conditions; Repair or Maintenance Work that Involves Taking Water System Components Out of Operation	
				CT Calculations					UV Dose						
				Peak Flow Rate, gpd.	Lowest Residual Disinfectant Concentration (C) Before or at First Customer During Peak Flow; mg/L.	Disinfectant Contact Time (T) at C Measurement Point During Peak Flow, minutes	Lowest CT Provided Before or at First Customer During Peak Flow, mg-min/L.	Temp of Water, °C	pH of Water, if Applicable	Minimum CT Required, mg-min/L.	Lowest Operating UV Dose, mW-sec/cm ² .	Minimum UV Dose Required, mW-sec/cm ² .	Lowest Residual Disinfectant Concentration at Remote Point in Distribution System, mg/L.		
1		24.0	3,780												
2	X	24.0	3,780		2.8									1.1	
3	X	24.0	2,860		3.0									1.5	
4	X	24.0	2,890		2.9									1.1	
5	X	24.0	2,390		3.0									1.4	
6	X	24.0	2,470		3.0									1.0	
7		24.0	2,910												
8		24.0	2,910												
9	X	24.0	2,910		2.8									1.1	
10	X	24.0	3,240		3.5									1.6	
11	X	24.0	2,200		2.8									1.0	
12	X	24.0	2,540		2.8									1.1	
13	X	24.0	2,280		3.0									1.0	
14		24.0	2,570												
15		24.0	2,570												
16	X	24.0	2,570		2.8									0.9	
17	X	24.0	2,850		3.0									1.1	
18	X	24.0	2,760		3.1									1.0	
19	X	24.0	2,500		2.3									0.7	
20	X	24.0	2,580		2.7									1.0	
21		24.0	2,400												
22		24.0	2,400												
23	X	24.0	2,400		2.9									1.1	
24	X	24.0	3,030		2.7									1.0	
25	X	24.0	2,130		3.0									1.1	
26	X	24.0	1,980		3.2									1.3	
27	X	24.0	2,120		3.0									1.0	
28		24.0													
29		24.0													
Total			72,020												
Average			2,483												
Maximum			3,780												

* Refer to the instructions for this report to determine which plants must provide this information.

MONTHLY OPERATION REPORT FOR PW'Ss TREATING RAW GROUND WATER OR PURCHASED FINISHED WATER

PWS Identification Number: 2541280 Plant Name: Wootens

III. Daily Data for the Month/Year of: March, 2004

Means of Achieving Four-Log Virus Inactivation/Removal: Free Chlorine Chlorine Dioxide Ozone Combined Chlorine (Chloramines)
 Ultraviolet Radiation Other (Describe):

Type of Disinfectant Residual Maintained in Distribution System: Free Chlorine Combined Chlorine (Chloramines) Chlorine Dioxide

Day of the Month	Days Plant Staffed or Visited by Operator (Place "X")	Hours plant in Operation	Net Quantity of Finished Water Produced, gal.	CT Calculations, or UV Dose, to Demostate Four-Log Virus Inactivation, if Applicable*										Lowest Residual Disinfectant Concentration at Remote Point in Distribution System, mg/L	Emergency or Abnormal Operating Conditions; Repair or Maintenance Work that Involves Taking Water System Components Out of Operation
				CT Calculations					UV Dose						
				Peak Flow Rate, gpd.	Lowest Residual Disinfectant Concentration (C) Before or at First Customer During Peak Flow, mg/L	Disinfectant Contact Time (T) at C Measurement Point During Peak Flow, minutes	Lowest CT Provided Before or at First Customer During Peak Flow, mg-min/L	Temp of Water, °C	pH of Water, if Applicable	Minimum CT Required, mg-min/L	Lowest Operating UV Dose, mW-sec/cm ²	Minimum UV Dose Required, mW-sec/cm ²			
1	X	24.0	10,810		3.0									1.4	
2	X	24.0	1,540		2.7									1.2	
3	X	24.0	2,170		1.0									0.5	
4	X	24.0	1,680		1.7									0.8	
5	X	24.0	2,700		2.8									1.0	
6		24.0	2,523												
7		24.0	2,523												
8	X	24.0	2,523		3.0									1.0	
9	X	24.0	3,850		3.2									1.8	
10	X	24.0	2,030		2.8									1.4	
11	X	24.0	1,760		3.1									1.1	
12	X	24.0	2,760		3.0									1.0	
13		24.0	2,780												
14		24.0	2,780												
15	X	24.0	2,780		2.8									1.2	
16	X	24.0	1,910		3.0									1.4	
17	X	24.0	1,820		3.0									1.0	
18	X	24.0	2,080		2.8									1.1	
19	X	24.0	3,990		3.0									1.2	
20		24.0	3,597												
21		24.0	3,597												
22	X	24.0	3,597		3.2									1.0	
23	X	24.0	3,920		3.0									1.2	
24	X	24.0	2,680		2.8									1.2	
25	X	24.0	3,420		2.8									1.1	
26	X	24.0	4,200		3.2									1.2	
27		24.0	4,130												
28		24.0	4,130												
29	X	24.0	4,130		3.0									1.3	
30	X	24.0	3,940		3.0									1.2	
31	X	24.0	3,660		2.8									1.2	
Total			100,010												
Average			3,226												
Maximum			10,810												

* Refer to the instructions for this report to determine which plants must provide this information.

MONTHLY OPERATION REPORT FOR PW'Ss TREATING RAW GROUND WATER OR PURCHASED FINISHED WATER

PWS Identification Number: 2541280 Plant Name: Wootens

III. Daily Data for the Month/Year of: April, 2004

Means of Achieving Four-Log Virus Inactivation/Removal: Free Chlorine Chlorine Dioxide Ozone Combined Chlorine (Chloramines)
 Ultraviolet Radiation Other (Describe):

Type of Disinfectant Residual Maintained in Distribution System: Free Chlorine Combined Chlorine (Chloramines) Chlorine Dioxide

Day of the Month	Days Plant Staffed or Visited by Operator (Place "X")	Hours plant in Operation	Net Quantity of Finished Water Produced, gal.	CT Calculations, or UV Dose, to Demstrate Four-Log Virus Inactivation, if Applicable*										Lowest Residual Disinfectant Concentration at Remote Point in Distribution System, mg/L	Emergency or Abnormal Operating Conditions; Repair or Maintenance Work that Involves Taking Water System Components Out of Operation	
				CT Calculations					UV Dose							
				Peak Flow Rate, gpd.	Lowest Residual Disinfectant Concentration (C) Before or at First Customer During Peak Flow, mg/L	Disinfectant Contact Time (T) at C Measurement Point During Peak Flow, minutes	Lowest CT Provided Before or at First Customer During Peak Flow, mg-min/L	Temp of Water, °C	pH of Water, if Applicable	Minimum CT Required, mg-min/L	Lowest Operating UV Dose, mW-sec/cm ²	Minimum UV Dose Required, mW-sec/cm ²				
1	X	24.0	3,680		3.0										1.3	
2	X	24.0	3,040		3.2										1.2	
3		24.0	2,927													
4		24.0	2,927													
5	X	24.0	2,927		3.0										1.2	
6	X	24.0	3,250		3.0										1.6	
7	X	24.0	3,780		2.8										1.5	
8	X	24.0	3,180		3.2										1.9	
9	X	24.0	2,720		3.0										1.6	
10		24.0	2,553													
11		24.0	2,553													
12	X	24.0	2,553		2.8										1.5	
13	X	24.0	2,080		2.5										1.2	
14	X	24.0	2,880		3.0										1.4	
15	X	24.0	3,290		3.2										1.6	
16	X	24.0	4,310		3.2										1.5	
17		24.0	3,447													
18		24.0	3,447													
19	X	24.0	3,447		3.5										1.3	
20	X	24.0	3,410		3.0										1.1	
21	X	24.0	6,190		3.2										1.3	
22	X	24.0	3,480		3.0										1.2	
23	X	24.0	4,950		3.5										1.4	
24		24.0	4,833													
25		24.0	4,833													
26	X	24.0	4,833		3.0										1.2	
27	X	24.0	2,580		3.0										1.1	
28	X	24.0	2,980		2.8										1.0	
29	X	24.0	2,380		3.0										1.2	
30	X	24.0	3,230		3.0										1.0	
Total			102,690													
Average			3,423													
Maximum			6,190													

* Refer to the instructions for this report to determine which plants must provide this information.

MONTHLY OPERATION REPORT FOR PW'Ss TREATING RAW GROUND WATER OR PURCHASED FINISHED WATER

PWS Identification Number: 2541280 Plant Name: Wootens

III. Daily Data for the Month/Year of: May, 2004

Means of Achieving Four-Log Virus Inactivation/Removal: Free Chlorine Chlorine Dioxide Ozone Combined Chlorine (Chloramines)
 Ultraviolet Radiation Other (Describe):

Type of Disinfectant Residual Maintained in Distribution System: Free Chlorine Combined Chlorine (Chloramines) Chlorine Dioxide

Day of the Month	Days Plant Staffed or Visited by Operator (Place "X")	Hours plant in Operation	Net Quantity of Finished Water Produced, gal.	CT Calculations, or UV Dose, to Demostate Four-Log Virus Inactivation, if Applicable*										Emergency or Abnormal Operating Conditions; Repair or Maintenance Work that Involves Taking Water System Components Out of Operation	
				CT Calculations					UV Dose						
				Peak Flow Rate, gpd.	Lowest Residual Disinfectant Concentration (C) Before or at First Customer During Peak Flow, mg/L	Disinfectant Contact Time (T) at C Measurement Point During Peak Flow, minutes	Lowest CT Provided Before or at First Customer During Peak Flow, mg-min/L	Temp of Water, °C	pH of Water, if Applicable	Minimum CT Required, mg-min/L	Lowest Operating UV Dose, mW-sec/cm ²	Minimum UV Dose Required, mW-sec/cm ²	Lowest Residual Disinfectant Concentration at Remote Point in Distribution System, mg/L		
1		24.0	3,087												
2		24.0	3,087												
3	X	24.0	3,087		2.6									1.0	
4	X	24.0	1,110		2.5									0.8	
5	X	24.0	4,180		2.6									1.0	
6	X	24.0	2,680		3.0									1.1	
7	X	24.0	2,750		3.0									1.0	
8		24.0	3,140												
9		24.0	3,140												
10	X	24.0	3,140		2.8									1.0	
11	X	24.0	3,050		2.6									0.7	
12	X	24.0	2,070		3.0									1.0	
13	X	24.0	2,800		3.5									1.2	
14	X	24.0	2,120		3.0									0.9	
15		24.0	2,450												
16		24.0	2,450												
17	X	24.0	2,450		2.5									0.8	
18	X	24.0	1,930		3.0									1.0	
19	X	24.0	1,480		2.7									1.0	
20	X	24.0	2,730		2.8									1.0	
21	X	24.0	2,400		3.0									1.1	
22		24.0	3,350												
23		24.0	3,350												
24	X	24.0	3,350		2.8									1.0	
25	X	24.0	2,600		3.0									1.2	
26	X	24.0	2,650		2.5									1.0	
27	X	24.0	2,720		2.5									1.0	
28	X	24.0	3,350		2.8									1.0	
29		24.0	5,093												
30		24.0	5,093												
31	X	24.0	5,093		2.4									1.0	
Total			91,980												
Average			2,967												
Maximum			5,093												

* Refer to the instructions for this report to determine which plants must provide this information.

Docket No. 060368-WS

**Application to Increase Rates and Charges
For a "Class A" Utility**

In

Florida

Report Missing:

Monthly Operating Report

Wootens

June 2004

Aqua Utilities Florida, Inc.

MONTHLY OPERATION REPORT FOR PWSs TREATING RAW GROUND WATER OR PURCHASED FINISHED WATER



See Pages 4 for Instructions.

I. General Information for the Month/Year of: July, 2004

A. Public Water System (PWS) Information

PWS Name: Wootens		PWS Identification Number: 2541280	
PWS Type: <input checked="" type="checkbox"/> Community <input type="checkbox"/> Non-Transient Non-Community <input type="checkbox"/> Transient Non-Community		<input type="checkbox"/> Consecutive	
Number of Service Connections at End of Month: 24		Total Population Served at End of Month: 60	
PWS Owner: Aqua Utilities Florida			
Contact Person: Mike Fitzgerald		Contact Person's Title: Area Manager	
Contact Person's Mailing Address: 1343 NE 17th Road		City: Ocala	State: Florida
Contact Person's Telephone Number: (352) 732-6027		Contact Person's Fax Number: (352) 732-3213	
Contact Person's E-Mail Address: mvfitzgerald@aquaaamerica.com			

B. Water Treatment Plant Information

Plant Name: Wootens		Plant Telephone Number: 904-329-1122	
Plant Address: Hess Road		City: Georgetown	State: Florida
Type of Water Treatment by Plant: <input checked="" type="checkbox"/> Raw Ground Water <input type="checkbox"/> Purchased Finished Water			
Permitted Maximum Day Operating Capacity of Plant, gallons per day: 60,000			
Plant Category (per subsection 62-699.310(4), F.A.C.): V		Plant Class (per subsection 62-699.310(4), F.A.C.): D	
Licensed Operators	Name	License Class	License Number
Lead/Chief Operator	Mark March	C	8287
Other Operators	Paul Thompson	A	7251
			Days 1st Shift

II. Certification by Lead/Chief Operator

I, the undersigned water treatment plant operator licensed in Florida, am the lead/chief operator of the water treatment plant identified in part I of this report. I certify that the information provided in this report is true and accurate to the best of my knowledge and belief. I certify that all drinking water treatment chemicals used at this plant conform to NSF International Standard 60 or other applicable standards referenced in subsection 62-555.320(3), F.A.C. I also certify that the following additional operations records for this plant were prepared each day that a licensed operator staffed or visited this plant during the month indicated above: (1) records of amounts of chemicals used and chemical feed rates; and (2) if applicable, appropriate treatment process performance records. Furthermore, I agree to provide these additional operations records to the PWS owner so the PWS owner can retain them, together with copies of this report, at a convenient location for at least ten years.

Signature and Date	Mark March Printed or Typed Name	C-8287 License Number
--------------------	-------------------------------------	--------------------------

MONTHLY OPERATION REPORT FOR PW'Ss TREATING RAW GROUND WATER OR PURCHASED FINISHED WATER

PWS Identification Number: 2541280 Plant Name: Wootens

III. Daily Data for the Month/Year of: July, 2004

Means of Achieving Four-Log Virus Inactivation/Removal: Free Chlorine Chlorine Dioxide Ozone Combined Chlorine (Chloramines)
 Ultraviolet Radiation Other (Describe):

Type of Disinfectant Residual Maintained in Distribution System: Free Chlorine Combined Chlorine (Chloramines) Chlorine Dioxide

Day of the Month	Days Plant Staffed or Visited by Operator (Place "X")	Hours plant in Operation	Net Quantity of Finished Water Produced, gal.	CT Calculations, or UV Dose, to Demostate Four-Log Virus Inactivation, if Applicable*								Lowest Residual Disinfectant Concentration at Remote Point in Distribution System, mg/L	Emergency or Abnormal Operating Conditions; Repair or Maintenance Work that Involves Taking Water System Components Out of Operation	
				CT Calculations				UV Dose						
				Peak Flow Rate, gpd.	Lowest Residual Disinfectant Concentration (C) Before or at First Customer During Peak Flow, mg/L	Disinfectant Contact Time (T) at C Measurement Point During Peak Flow, minutes	Lowest CT Provided Before or at First Customer During Peak Flow, mg-min/L	Temp of Water, °C	pH of Water, if Applicable	Minimum CT Required, mg-min/L	Lowest Operating UV Dose, mW-sec/cm ²			Minimum UV Dose Required, mW-sec/cm ²
1	X	24.0	3,890		1.8								0.5	
2	X	24.0	4,890		2.8								0.9	
3		24.0	4,917											
4		24.0	4,917											
5	X	24.0	4,917		1.4								0.6	
6	X	24.0	4,640		1.6								0.6	
7	X	24.0	2,800		0.4								0.7	
8	X	24.0	2,790		2.8								1.0	
9	X	24.0	2,230		3.0								1.2	
10		24.0	3,733											
11		24.0	3,733											
12	X	24.0	3,733		2.6								1.0	
13	X	24.0	2,510		2.4								0.6	
14	X	24.0	2,190		2.8								1.4	
15	X	24.0	2,480		1.5								0.7	
16	X	24.0	2,140		2.4								1.1	
17		24.0	2,063											
18		24.0	2,063											
19	X	24.0	2,063		3.0								1.4	
20	X	24.0	2,500		2.8								1.4	
21	X	24.0	2,880		3.0								1.4	
22	X	24.0	2,700		3.0								1.3	
23	X	24.0	1,420		3.0								1.4	
24		24.0	2,957											
25		24.0	2,957											
26	X	24.0	2,957		3.0								1.3	
27	X	24.0	2,030		2.6								0.9	
28	X	24.0	2,000		2.5								1.0	
29	X	24.0	1,940		2.2								0.8	
30	X	24.0	2,890		3.0								1.2	
31		24.0	2,390											
Total			92,320											
Average			2,978											
Maximum			4,917											

* Refer to the instructions for this report to determine which plants must provide this information.

MONTHLY OPERATION REPORT FOR PWSs TREATING RAW GROUND WATER OR PURCHASED FINISHED WATER



See Pages 4 for Instructions.

I. General Information for the Month/Year of: August, 2004

A. Public Water System (PWS) Information

PWS Name:	Wootens			PWS Identification Number:	2541280
PWS Type:	<input checked="" type="checkbox"/> Community	<input type="checkbox"/> Non-Transient Non-Community	<input type="checkbox"/> Transient Non-Community	<input type="checkbox"/> Consecutive	
Number of Service Connections at End of Month:	24			Total Population Served at End of Month:	60
PWS Owner:	Aqua Utilities Florida				
Contact Person:	Mike Fitzgerald			Contact Person's Title:	Area Manager
Contact Person's Mailing Address:	1343 NE 17th Road	City:	Ocala	State:	Florida
Contact Person's Telephone Number:	(352) 732-6027			Contact Person's Fax Number:	(352) 732-3213
Contact Person's E-Mail Address:	mvfitzgerald@aquaaamerica.com				

B. Water Treatment Plant Information

Plant Name:	Wootens			Plant Telephone Number:	904-329-1122
Plant Address:	Hess Road		City:	Georgetown	State: Florida
Type of Water Treatment by Plant:	<input checked="" type="checkbox"/> Raw Ground Water	<input type="checkbox"/> Purchased Finished Water			
Permitted Maximum Day Operating Capacity of Plant, gallons per day:	60,000				
Plant Category (per subsection 62-699.310(4), F.A.C.):	V			Plant Class (per subsection 62-699.310(4), F.A.C.):	
				D	
Licensed Operators	Name	License Class	License Number	Day(s) / Shift(s) Worked	
Lead/Chief Operator:	Mark March	C	8287		
Other Operators:	Paul Thompson	A	7251	Days 1st Shift	

II. Certification by Lead/Chief Operator

I, the undersigned water treatment plant operator licensed in Florida, am the lead/chief operator of the water treatment plant identified in part I of this report. I certify that the information provided in this report is true and accurate to the best of my knowledge and belief. I certify that all drinking water treatment chemicals used at this plant conform to NSF International Standard 60 or other applicable standards referenced in subsection 62-555.320(3), F.A.C. I also certify that the following additional operations records for this plant were prepared each day that a licensed operator staffed or visited this plant during the month indicated above: (1) records of amounts of chemicals used and chemical feed rates; and (2) if applicable, appropriate treatment process performance records. Furthermore, I agree to provide these additional operations records to the PWS owner so the PWS owner can retain them, together with copies of this report, at a convenient location for at least ten years.

Signature and Date	Mark March	C-8287
	Printed or Typed Name	License Number

MONTHLY OPERATION REPORT FOR PW'Ss TREATING RAW GROUND WATER OR PURCHASED FINISHED WATER

PWS Identification Number: 2541280 Plant Name: Wootens

III. Daily Data for the Month/Year of: August, 2004

Means of Achieving Four-Log Virus Inactivation/Removal: Free Chlorine Chlorine Dioxide Ozone Combined Chlorine (Chloramines)
 Ultraviolet Radiation Other (Describe):

Type of Disinfectant Residual Maintained in Distribution System: Free Chlorine Combined Chlorine (Chloramines) Chlorine Dioxide

Day of the Month	Days Plant Staffed or Visited by Operator (Place "X")	Hours plant in Operation	Net Quantity of Finished Water Produced, gal.	CT Calculations, or UV Dose, to Demostate Four-Log Virus Inactivation, if Applicable*								Lowest Residual Disinfectant Concentration at Remote Point in Distribution System, mg/L	Emergency or Abnormal Operating Conditions, Repair or Maintenance Work that Involves Taking Water System Components Out of Operation
				CT Calculations				UV Dose					
				Peak Flow Rate, gpd.	Lowest Residual Disinfectant Concentration (C) Before or at First Customer During Peak Flow, mg/L	Disinfectant Contact Time (T) at C Measurement Point During Peak Flow, minutes	Lowest CT Provided Before or at First Customer During Peak Flow, mg-min/L	Minimum CT Required, mg-min/L	Temp of Water, °C	pH of Water, if Applicable	Lowest Operating UV Dose, mW-sec/cm ²		
1		24.0	3,750										
2	X	24.0	3,750		3.0							1.6	
3	X	24.0	2,090		1.9							0.7	
4	X	24.0	1,710		3.0							1.4	
5	X	24.0	1,900		2.8							1.1	
6	X	24.0	1,670		2.4							1.1	
7		24.0	2,110										
8		24.0	2,110										
9	X	24.0	2,110		2.8							1.2	
10	X	24.0	2,230		2.2							1.0	
11	X	24.0	1,630		2.8							1.2	
12	X	24.0	2,050		2.2							1.0	
13	X	24.0	2,520		2.5							1.1	
14		24.0	2,083										
15		24.0	2,083										
16	X	24.0	2,083		2.8							1.0	
17	X	24.0	1,730		2.5							1.0	
18	X	24.0	1,580		2.2							1.0	
19	X	24.0	1,630		1.5							0.9	
20	X	24.0	1,820		2.3							1.1	
21		24.0	2,067										
22		24.0	2,067										
23	X	24.0	2,067		2.4							1.1	
24	X	24.0	1,890		1.4							0.5	
25	X	24.0	1,310		2.0							0.8	
26	X	24.0	2,550		2.5							1.1	
27	X	24.0	2,780		2.8							1.2	
28		24.0	2,390										
29		24.0	2,390										
30	X	24.0	2,390		2.8							1.2	
31	X	24.0	1,800		2.2							0.9	
Total			66,340										
Average			2,140										
Maximum			3,750										

* Refer to the instructions for this report to determine which plants must provide this information.

MONTHLY OPERATION REPORT FOR PWSs TREATING RAW GROUND WATER OR PURCHASED FINISHED WATER



See Pages 4 for Instructions.

I. General Information for the Month/Year of:	September, 2004
--	-----------------

A. Public Water System (PWS) Information

PWS Name: Wootens	PWS Identification Number: 2541280		
PWS Type: <input checked="" type="checkbox"/> Community <input type="checkbox"/> Non-Transient Non-Community <input type="checkbox"/> Transient Non-Community <input type="checkbox"/> Consecutive			
Number of Service Connections at End of Month: 24	Total Population Served at End of Month: 60		
PWS Owner: Aqua Utilities Florida			
Contact Person: Mike Fitzgerald	Contact Person's Title: Area Manager		
Contact Person's Mailing Address: 1343 NE 17th Road	City: Ocala	State: Florida	Zip Code: 34472
Contact Person's Telephone Number: (352) 732-6027	Contact Person's Fax Number: (352) 732-3213		
Contact Person's E-Mail Address: mvfitzgerald@aquaamerica.com			

B. Water Treatment Plant Information

Plant Name: Wootens	Plant Telephone Number: 904-329-1122		
Plant Address: Hess Road	City: Georgetown	State: Florida	Zip Code: 32139
Type of Water Treatment by Plant: <input checked="" type="checkbox"/> Raw Ground Water <input type="checkbox"/> Purchased Finished Water			
Permitted Maximum Day Operating Capacity of Plant, gallons per day: 60,000			
Plant Category (per subsection 62-699.310(4), F.A.C.): V	Plant Class (per subsection 62-699.310(4), F.A.C.): D		
Licensed Operators	Name	License Class	License Number
Lead/Chief Operator:	Mark March	C	8287
Other Operators:	Paul Thompson	A	7251
			Days 1st Shift

II. Certification by Lead/Chief Operator

I, the undersigned water treatment plant operator licensed in Florida, am the lead/chief operator of the water treatment plant identified in part I of this report. I certify that the information provided in this report is true and accurate to the best of my knowledge and belief. I certify that all drinking water treatment chemicals used at this plant conform to NSF International Standard 60 or other applicable standards referenced in subsection 62-555.320(3), F.A.C. I also certify that the following additional operations records for this plant were prepared each day that a licensed operator staffed or visited this plant during the month indicated above: (1) records of amounts of chemicals used and chemical feed rates; and (2) if applicable, appropriate treatment process performance records. Furthermore, I agree to provide these additional operations records to the PWS owner so the PWS owner can retain them, together with copies of this report, at a convenient location for at least ten years.

Signature and Date

Mark March

Printed or Typed Name

C-8287

License Number

MONTHLY OPERATION REPORT FOR PW'Ss TREATING RAW GROUND WATER OR PURCHASED FINISHED WATER

PWS Identification Number: 2541280 Plant Name: Wootens

III. Daily Data for the Month/Year of: September, 2004

Means of Achieving Four-Log Virus Inactivation/Removal: Free Chlorine Chlorine Dioxide Ozone Combined Chlorine (Chloramines)
 Ultraviolet Radiation Other (Describe):

Type of Disinfectant Residual Maintained in Distribution System: Free Chlorine Combined Chlorine (Chloramines) Chlorine Dioxide

Day of the Month	Days Plant Staffed or Visited by Operator (Place "X")	Hours plant in Operation	Net Quantity of Finished Water Produced, gal.	CT Calculations, or UV Dose, to Demostate Four-Log Virus Inactivation, if Applicable*										Lowest Residual Disinfectant Concentration at Remote Point in Distribution System, mg/L	Emergency or Abnormal Operating Conditions; Repair or Maintenance Work that Involves Taking Water System Components Out of Operation
				CT Calculations					UV Dose						
				Peak Flow Rate, gpd.	Lowest Residual Disinfectant Concentration (C) Before or at First Customer During Peak Flow, mg/L	Disinfectant Contact Time (T) at C Measurement Point During Peak Flow, minutes	Lowest CT Provided Before or at First Customer During Peak Flow, mg-min/L	Temp of Water, °C	pH of Water, if Applicable	Minimum CT Required, mg-min/L	Lowest Operating UV Dose, mW-sec/cm ²	Minimum UV Dose Required, mW-sec/cm ²			
1	X	24.0	800		2.1									1.2	
2	X	24.0	3,040		2.2									0.8	
3	X	24.0	7,230		0.5									0.4	
4		24.0	1,240												
5		24.0	1,240												
6	X	24.0	1,240												
7	X	24.0													
8	X	24.0													
9	X	24.0	1,680		3.5+									2.3	
10	X	24.0	2,290		0.8									0.4	
11		24.0	2,093												
12		24.0	2,093												
13	X	24.0	2,093		3.5									1.4	
14	X	24.0	1,010		2.7									1.3	
15	X	24.0	1,680		2.8									1.6	
16	X	24.0	890		3.0									1.6	
17	X	24.0	3,540		2.8									1.6	
18		24.0	2,657												
19		24.0	2,657												
20	X	24.0	2,657		2.7									1.6	
21	X	24.0	1,730		2.8									1.6	
22	X	24.0	2,590		3.0									1.6	
23	X	24.0	2,310		3.0									1.2	
24	X	24.0	2,290		3.5									1.6	
25		24.0	3,100												
26		24.0	3,100												
27	X	24.0	3,100		3.0									2.0	
28	X	24.0	1,450		3.2									2.0	
29	X	24.0	3,190		2.5									1.4	
30	X	24.0	3,770		3.5									1.8	
31		24.0													
Total			66,760												
Average			2,154												
Maximum			7,230												

* Refer to the instructions for this report to determine which plants must provide this information.

MONTHLY OPERATION REPORT FOR PWSs TREATING RAW GROUND WATER OR PURCHASED FINISHED WATER



See Pages 4 for Instructions.

I. General Information for the Month/Year of:	October, 2004
--	---------------

A. Public Water System (PWS) Information

PWS Name: Wootens	PWS Identification Number: 2541280		
PWS Type: <input checked="" type="checkbox"/> Community <input type="checkbox"/> Non-Transient Non-Community <input type="checkbox"/> Transient Non-Community <input type="checkbox"/> Consecutive			
Number of Service Connections at End of Month: 24	Total Population Served at End of Month: 60		
PWS Owner: Aqua Utilities Florida			
Contact Person: Mike Fitzgerald	Contact Person's Title: Area Manager		
Contact Person's Mailing Address: 1343 NE 17th Road	City: Ocala	State: Florida	Zip Code: 34472
Contact Person's Telephone Number: (352) 732-6027	Contact Person's Fax Number: (352) 732-3213		
Contact Person's E-Mail Address: mvfitzgerald@aquaamerica.com			

B. Water Treatment Plant Information

Plant Name: Wootens	Plant Telephone Number: 904-329-1122		
Plant Address: Hess Road	City: Georgetown	State: Florida	Zip Code: 32139
Type of Water Treatment by Plant: <input checked="" type="checkbox"/> Raw Ground Water <input type="checkbox"/> Purchased Finished Water			
Permitted Maximum Day Operating Capacity of Plant, gallons per day: 60,000			
Plant Category (per subsection 62-699.310(4), F.A.C.): V	Plant Class (per subsection 62-699.310(4), F.A.C.): D		
Licensed Operators:	Name	License Class	License Number
Lead/Chief Operator:	Mark March	C	8287
Other Operators:	Paul Thompson	A	7251
			Days 1st Shift

II. Certification by Lead/Chief Operator

I, the undersigned water treatment plant operator licensed in Florida, am the lead/chief operator of the water treatment plant identified in part I of this report. I certify that the information provided in this report is true and accurate to the best of my knowledge and belief. I certify that all drinking water treatment chemicals used at this plant conform to NSF International Standard 60 or other applicable standards referenced in subsection 62-555.320(3), F.A.C. I also certify that the following additional operations records for this plant were prepared each day that a licensed operator staffed or visited this plant during the month indicated above: (1) records of amounts of chemicals used and chemical feed rates; and (2) if applicable, appropriate treatment process performance records. Furthermore, I agree to provide these additional operations records to the PWS owner so the PWS owner can retain them, together with copies of this report, at a convenient location for at least ten years.

_____ Signature and Date	Mark March Printed or Typed Name	C-8287 License Number
-----------------------------	-------------------------------------	--------------------------

MONTHLY OPERATION REPORT FOR PW'SS TREATING RAW GROUND WATER OR PURCHASED FINISHED WATER

PWS Identification Number: 2541280 Plant Name: Woolens

III. Daily Data for the Month/year of: October, 2004

Means of Achieving Four-Log Virus Inactivation/Removal: Free Chlorine Chlorine Dioxide Ozone Combined Chlorine (Chloramines) Ultraviolet Radiation

Type of Disinfectant Residual Maintained in Distribution System: Free Chlorine Combined Chlorine (Chloramines) Chlorine Dioxide

Days Plant Started or Visited by Operator (Place "X")	Hours Plant in Operation	Net Quantity of Finished Water Produced, gal	Peak Flow Rate, gpd	Lowest Residual Disinfectant Concentration (C) Before or at First Customer Measurement (T) at C	Disinfectant Provided Before or at Customer Peak Flow, mg/L	Temp of Water, °C if Applicable	pH of Water, if Applicable	Minimum CT Required, mg·min/L	Lowest UV Dose Required, mW·sec/cm ²	Minimum UV Dose Provided, mW·sec/cm ²	Lowest Residual Disinfectant Concentration at Remote Point in Distribution System, mg/L	Emergency or Abnormal Operating Conditions: Repair or Maintenance Work that Involves Taking Water System Components Out of Operation	CT Calculations, or UV Dose, to Demostate Four-Log Virus Inactivation, if Applicable*		CT Calculations		UV Dose	
													Lowest Residual Disinfectant Concentration (C) Before or at First Customer Measurement (T) at C	Disinfectant Provided Before or at Customer Peak Flow, mg/L	Temp of Water, °C if Applicable	pH of Water, if Applicable	Minimum CT Required, mg·min/L	Lowest UV Dose Required, mW·sec/cm ²
1	X	24.0	3,770	3.5							1.8							
2		24.0	3,657	3.57														
3		24.0	3,657	3.57														
4	X	24.0	3,657	3.57							1.8							
5	X	24.0	1,300	3.0							1.6							
6	X	24.0	2,090	3.5							1.8							
7	X	24.0	2,430	3.5							1.9							
8	X	24.0	4,370	3.5							1.6							
9		24.0	2,747															
10		24.0	2,747															
11	X	24.0	2,747	3.5							1.6							
12	X	24.0	1,670	3.5							1.6							
13	X	24.0	2,190	3.5							1.6							
14	X	24.0	1,880	3.5							1.6							
15	X	24.0	2,830	3.5							1.6							
16		24.0	2,170															
17		24.0	2,170															
18	X	24.0	2,170	3.5							1.0							
19	X	24.0	3,910	3.5							1.3							
20	X	24.0	1,460	2.6							1.3							
21	X	24.0	3,880	3.5							1.3							
22	X	24.0	2,680	3.5							1.3							
23		24.0	2,023															
24		24.0	2,023															
25	X	24.0	2,023	3.5							1.2							
26	X	24.0	2,970	3.1							1.2							
27	X	24.0	1,240	3.5							1.2							
28	X	24.0	1,770	3.5							1.2							
29	X	24.0	2,200	3.0							1.2							
30	X	24.0	3,480	3.0							1.2							
31		24.0	1,753															
Total		79,663																
Average		2,570																
Maximum		4,370																

* Refer to the instructions for this report to determine which plants must provide this information

MONTHLY OPERATION REPORT FOR PWSs TREATING RAW GROUND WATER OR PURCHASED FINISHED WATER



See Pages 4 for Instructions.

I. General Information for the Month/Year of: November, 2004

A. Public Water System (PWS) Information

PWS Name: Wootens		PWS Identification Number: 2541280	
PWS Type: <input checked="" type="checkbox"/> Community <input type="checkbox"/> Non-Transient Non-Community <input type="checkbox"/> Transient Non-Community <input type="checkbox"/> Consecutive			
Number of Service Connections at End of Month: 24		Total Population Served at End of Month: 60	
PWS Owner: Aqua Utilities Florida			
Contact Person: Brian Heath		Contact Person's Title: Area Manager	
Contact Person's Mailing Address: 1343 NE 17th Road		City: Ocala	State: Florida
Contact Person's Telephone Number: (352) 732-6027		Contact Person's Fax Number: (352) 732-3213	
Contact Person's E-Mail Address: beheath@aquamerica.com			

B. Water Treatment Plant Information

Plant Name: Wootens		Plant Telephone Number: 904-329-1122	
Plant Address: Hess Road		City: Georgetown	State: Florida
Type of Water Treatment by Plant: <input checked="" type="checkbox"/> Raw Ground Water <input type="checkbox"/> Purchased Finished Water			
Permitted Maximum Day Operating Capacity of Plant, gallons per day: 60,000			
Plant Category (per subsection 62-699.310(4), F.A.C.): V		Plant Class (per subsection 62-699.310(4), F.A.C.): D	
Licensed Operators	Name	License Class	License Number
Lead/Chief Operator:	Mark March	C	8287
Other Operators:	Paul Thompson	A	7251

II. Certification by Lead/Chief Operator

I, the undersigned water treatment plant operator licensed in Florida, am the lead/chief operator of the water treatment plant identified in part I of this report. I certify that the information provided in this report is true and accurate to the best of my knowledge and belief. I certify that all drinking water treatment chemicals used at this plant conform to NSF International Standard 60 or other applicable standards referenced in subsection 62-555.320(3), F.A.C. I also certify that the following additional operations records for this plant were prepared each day that a licensed operator staffed or visited this plant during the month indicated above: (1) records of amounts of chemicals used and chemical feed rates; and (2) if applicable, appropriate treatment process performance records. Furthermore, I agree to provide these additional operations records to the PWS owner so the PWS owner can retain them, together with copies of this report, at a convenient location for at least ten years.

Signature and Date	Mark March Printed or Typed Name	C-8287 License Number
--------------------	-------------------------------------	--------------------------

MONTHLY OPERATION REPORT FOR PW'Ss TREATING RAW GROUND WATER OR PURCHASED FINISHED WATER

PWS Identification Number: 2541280 Plant Name: Wootens

III. Daily Data for the Month/Year of: November, 2004

Means of Achieving Four-Log Virus Inactivation/Removal: Free Chlorine Chlorine Dioxide Ozone Combined Chlorine (Chloramines)
 Ultraviolet Radiation Other (Describe):

Type of Disinfectant Residual Maintained in Distribution System: Free Chlorine Combined Chlorine (Chloramines) Chlorine Dioxide

Day of the Month	Days Plant Staffed or Visited by Operator (Place "X")	Hours plant in Operation	Net Quantity of Finished Water Produced, gal.	CT Calculations, or UV Dose, to Demostate Four-Log Virus Inactivation, if Applicable*										Emergency or Abnormal Operating Conditions; Repair or Maintenance Work that Involves Taking Water System Components Out of Operation.	
				CT Calculations					UV Dose						
				Peak Flow Rate, gpd.	Lowest Residual Disinfectant Concentration (C) Before or at First Customer During Peak Flow, mg/L	Disinfectant Contact Time (T) at C Measurement Point During Peak Flow, minutes	Lowest CT Provided Before or at First Customer During Peak Flow, mg-min/L	Temp of Water, °C	pH of Water, if Applicable	Minimum CT Required, mg-min/L	Lowest Operating UV Dose, mW-sec/cm ²	Minimum UV Dose Required, mW-sec/cm ²	Lowest Residual Disinfectant Concentration at Remote Point in Distribution System, mg/L		
1	X	24.0	5,260		2.8									1.2	
2	X	24.0	1,780		2.5									1.2	
3	X	24.0	5,490		2.7									1.2	
4	X	24.0	3,500		2.6									1.0	
5	X	24.0	2,690		3.0									1.2	
6		24.0	4,203												
7		24.0	4,203												
8	X	24.0	4,203		2.4									1.0	
9	X	24.0	1,690		2.8									1.6	
10	X	24.0	2,300		3.5									1.6	
11	X	24.0	2,210		3.5									1.2	
12	X	24.0	2,030		3.0									1.0	
13		24.0	2,087												
14		24.0	2,087												
15	X	24.0	2,087		3.5									0.8	
16	X	24.0	1,620		3.5									10.0	
17	X	24.0	3,210		3.5									0.6	
18	X	24.0	2,200		3.0									0.9	
19	X	24.0	1,930		3.0									0.8	
20		24.0	2,295												
21	X	24.0	2,295		3.5									0.8	
22	X	24.0	2,200		2.8									0.6	
23	X	24.0	2,190		3.0									1.0	
24	X	24.0	2,460		2.8									0.6	
25		24.0	2,345												
26	X	24.0	2,345		3.5									0.6	
27		24.0	2,803												
28		24.0	2,803												
29	X	24.0	2,803		3.5									0.6	
30	X	24.0	1,670		3.5									0.7	
31		24.0													
Total			80,990												
Average			2,613												
Maximum			5,490												

* Refer to the instructions for this report to determine which plants must provide this information.

MONTHLY OPERATION REPORT FOR PW'SS TREATING RAW GROUND WATER OR PURCHASED FINISHED WATER

PWS Identification Number: 2541280 Plant Name: Woolens

III. Daily Data for the Month/Year of: December, 2004

Means of Achieving Four-Log Virus Inactivation/Removal: Free Chlorine Chlorine Dioxide Ozone Combined Chlorine (Chloramines)

Type of Disinfectant Residual Maintained in Distribution System: Free Chlorine Combined Chlorine (Chloramines) Chlorine Dioxide

Days Plant Started or Visited by Operator (Place "X")

Day of the Month	Hours plant in Operation	Net Quantity of Finished Water Produced, gal.	Peak Flow Rate, gpd.	Lowest Residual Disinfectant Concentration (C) at C	Disinfectant Contact Time	Lowest CT Before or at Customer	Flow, mg-min/L During Peak	Temp of Water, °C if Applicable	pH of Water, if Applicable	Minimum CT Required, mg-min/L	Lowest UV Dose, mW-sec/cm ²	Minimum UV Dose, mW-sec/cm ²	Remote Point in Distribution System, mg/L	Emergency or Abnormal Operating Conditions: Repair or Maintenance Work that Involves Taking Water System Components Out of Operation
1	X	2,690	24.0	3.5										
2	X	2,160	24.0	3.5										
3	X	2,610	24.0	3.5										
4		2,013	24.0											
5		2,013	24.0											
6	X	2,013	24.0	2.7										
7	X	2,040	24.0	3.0										
8	X	2,020	24.0	3.5										
9	X	1,600	24.0	2.8										
10	X	1,380	24.0	3.5										
11		2,360	24.0											
12		2,360	24.0											
13	X	2,360	24.0	3.5										
14	X	830	24.0	2.5										
15	X	1,820	24.0	2.8										
16	X	3,460	24.0	2.0										
17	X	2,460	24.0	2.6										
18		2,440	24.0											
19		2,440	24.0											
20	X	2,440	24.0	2.8										
21	X	1,730	24.0	3.0										
22	X	2,870	24.0	3.5										
23	X	1,130	24.0	3.0										
24	X	1,610	24.0	3.5										
25		2,103	24.0											
26		2,103	24.0											
27	X	2,103	24.0	3.5										
28	X	1,560	24.0	2.5										
29	X	2,710	24.0	3.5										
30	X	2,800	24.0	3.5										
31	X	2,450	24.0	3.5										
Total		66,680												
Average		2,151												
Maximum		3,460												

* Refer to the instructions for this report to determine which plants must provide this information.

MONTHLY OPERATION REPORT FOR PW'Ss TREATING RAW GROUND WATER OR PURCHASED FINISHED WATER

PWS Identification Number: 2541280 Plant Name: Wootens

III. Daily Data for the Month/Year of: January, 2005

Means of Achieving Four-Log Virus Inactivation/Removal: Free Chlorine Chlorine Dioxide Ozone Combined Chlorine (Chloramines)
 Ultraviolet Radiation Other (Describe):

Type of Disinfectant Residual Maintained in Distribution System: Free Chlorine Combined Chlorine (Chloramines) Chlorine Dioxide

Day of the Month	Days Plant Staffed or Visited by Operator (Place "X")	Hours plant in Operation	Net Quantity of Finished Water Produced, gal.	CT Calculations, or UV Dose, to Demostate Four-Log Virus Inactivation, if Applicable*								Lowest Residual Disinfectant Concentration at Remote Point in Distribution System, mg/L	Emergency or Abnormal Operating Conditions; Repair or Maintenance Work that Involves Taking Water System Components Out of Operation	
				CT Calculations				UV Dose						
				Peak Flow Rate, gpd.	Lowest Residual Disinfectant Concentration (C) Before or at First Customer During Peak Flow, mg/L	Disinfectant Contact Time (T) at C Measurement Point During Peak Flow, minutes	Lowest CT Provided Before or at First Customer During Peak Flow, mg-min/L	Temp of Water, °C	pH of Water, if Applicable	Minimum CT Required, mg-min/L	Lowest Operating UV Dose, mW-sec/cm ²			Minimum UV Dose Required, mW-sec/cm ²
1			24.0	3,407										
2			24.0	3,407										
3	X		24.0	3,407		2.9							1.0	
4	X		24.0	2,600		2.8							1.1	
5	X		24.0	3,470		2.8							1.0	
6	X		24.0	2,890		3.5							1.2	
7	X		24.0	2,890		3.0							1.0	
8			24.0	2,990										
9			24.0	2,990										
10	X		24.0	2,990		3.2							1.0	
11	X		24.0	1,060		2.8							1.0	
12	X		24.0	3,480		2.8							0.8	
13	X		24.0	3,210	2.2+								0.8	
14	X		24.0	8,240		2.0							0.7	
15			24.0	323										
16			24.0	323										
17	X		24.0	323		2.0							0.9	
18	X		24.0	2,410		2.8							1.0	
19	X		24.0	2,850		2.8							1.0	
20	X		24.0	2,650		2.4							0.8	
21	X		24.0	2,700		2.8							0.8	
22			24.0	2,917										
23			24.0	2,917										
24	X		24.0	2,917		3.5							0.7	
25	X		24.0	1,940		3.5							0.9	
26	X		24.0	4,960		1.6							0.7	
27	X		24.0	1,980		2.5							0.7	
28	X		24.0	1,620		2.5							0.7	
29			24.0	2,100										
30			24.0	2,100										
31	X		24.0	2,100		2.8							1.2	
Total				84,160										
Average				2,715										
Maximum				8,240										

* Refer to the instructions for this report to determine which plants must provide this information.

MONTHLY OPERATION REPORT FOR PW'Ss TREATING RAW GROUND WATER OR PURCHASED FINISHED WATER

PWS Identification Number: 2541280 Plant Name: Wootens

III. Daily Data for the Month/Year of: February, 2005

Means of Achieving Four-Log Virus Inactivation/Removal: Free Chlorine Chlorine Dioxide Ozone Combined Chlorine (Chloramines)
 Ultraviolet Radiation Other (Describe):

Type of Disinfectant Residual Maintained in Distribution System: Free Chlorine Combined Chlorine (Chloramines) Chlorine Dioxide

Day of the Month	Days Plant Staffed or Visited by Operator (Place "X")	Hours plant in Operation	Net Quantity of Finished Water Produced, gal.	CT Calculations, or UV Dose, to Demostate Four-Log Virus Inactivation, if Applicable*										Emergency or Abnormal Operating Conditions; Repair or Maintenance Work that Involves Taking Water System Components Out of Operation	
				CT Calculations					UV Dose						
				Peak Flow Rate, gpd.	Lowest Residual Disinfectant Concentration (C) Before or at First Customer During Peak Flow, mg/L	Disinfectant Contact Time (T) at C Measurement Point During Peak Flow, minutes	Lowest CT Provided Before or at First Customer During Peak Flow, mg-min/L	Temp of Water, °C	pH of Water, if Applicable	Minimum CT Required, mg-min/L	Lowest Operating UV Dose, mW-sec/cm ²	Minimum UV Dose Required, mW-sec/cm ²	Lowest Residual Disinfectant Concentration at Remote Point in Distribution System, mg/L		
1	X	24.0	1,710		3.0										1.2
2	X	24.0	2,670		2.8										1.0
3	X	24.0	2,140		3.0										1.3
4	X	24.0	2,660		2.2										1.0
5		24.0	3,313												
6		24.0	3,313												
7	X	24.0	3,313		2.6										1.0
8	X	24.0	1,630		2.4										1.0
9	X	24.0	3,650		2.5										1.0
10	X	24.0	1,670		2.2										1.2
11		24.0	3,165												
12	X	24.0	3,165		2.7										1.0
13		24.0	3,210												
14	X	24.0	3,210		2.7										1.0
15	X	24.0	2,280		2.5										0.8
16	X	24.0	3,560		2.5										1.0
17	X	24.0	1,540		2.5										0.9
18	X	24.0	4,010		2.8										1.0
19		24.0	2,483												
20		24.0	2,483												
21	X	24.0	2,483		2.5										0.8
22	X	24.0	1,890		2.3										0.7
23	X	24.0	2,400		2.8										1.0
24	X	24.0	3,930		2.9										1.0
25	X	24.0	3,620		2.8										1.0
26		24.0	2,860												
27		24.0	2,860												
28	X	24.0	2,860		2.8										1.2
29		24.0													
30		24.0													
31		24.0													
Total			78,080												
Average			2,519												
Maximum			4,010												

* Refer to the instructions for this report to determine which plants must provide this information.

MONTHLY OPERATION REPORT FOR PW'Ss TREATING RAW GROUND WATER OR PURCHASED FINISHED WATER

PWS Identification Number: 2541280 Plant Name: Wootens

III. Daily Data for the Month/Year of: March, 2005

Means of Achieving Four-Log Virus Inactivation/Removal: Free Chlorine Chlorine Dioxide Ozone Combined Chlorine (Chloramines)
 Ultraviolet Radiation Other (Describe):

Type of Disinfectant Residual Maintained in Distribution System: Free Chlorine Combined Chlorine (Chloramines) Chlorine Dioxide

Day of the Month	Days Plant Staffed or Visited by Operator (Place "X")	Hours plant in Operation	Net Quantity of Finished Water Produced, gal.	CT Calculations, or UV Dose, to Demostate Four-Log Virus Inactivation, if Applicable*										Emergency or Abnormal Operating Conditions; Repair or Maintenance Work that Involves Taking Water System Components Out of Operation	
				CT Calculations					UV Dose						
				Peak Flow Rate, gpd.	Lowest Residual Disinfectant Concentration (C) Before or at First Customer During Peak Flow, mg/L	Disinfectant Contact Time (T) at C Measurement Point During Peak Flow, minutes	Lowest CT Provided Before or at First Customer During Peak Flow, mg-min/L	Temp of Water, °C	pH of Water, if Applicable	Minimum CT Required, mg-min/L	Lowest Operating UV Dose, mW-sec/cm ²	Minimum UV Dose Required, mW-sec/cm ²	Lowest Residual Disinfectant Concentration at Remote Point in Distribution System, mg/L		
1	X	24.0	2,090		2.5										1.0
2	X	24.0	2,280		2.6										1.1
3	X	24.0	1,760		2.5										0.8
4	X	24.0	4,150		2.8										1.0
5		24.0	2,367												
6		24.0	2,367												
7	X	24.0	2,367		2.9										1.0
8	X	24.0	1,020		2.5										0.9
9	X	24.0	2,440		2.8										1.0
10	X	24.0	1,290		2.9										1.0
11	X	24.0	3,810		2.8										1.0
12		24.0	2,530												
13		24.0	2,530												
14	X	24.0	2,530		2.8										1.0
15	X	24.0	2,550		2.9										1.0
16	X	24.0	1,650		2.5										0.9
17	X	24.0	1,060		2.1										0.7
18	X	24.0	2,270		2.3										1.0
19		24.0	2,133												
20		24.0	2,133												
21	X	24.0	2,133		2.5										1.2
22	X	24.0	2,490		2.1										0.9
23	X	24.0	3,790		2.8										1.2
24	X	24.0	3,360		2.6										1.0
25	X	24.0	3,090		2.2										0.9
26		24.0	2,657												
27		24.0	2,657												
28	X	24.0	2,657		2.2										1.0
29	X	24.0	1,570		1.8										0.9
30	X	24.0	3,380		2.5										1.2
31	X	24.0	2,770		2.8										1.0

Total	75,880
Average	2,448
Maximum	4,150

* Refer to the instructions for this report to determine which plants must provide this information.

MONTHLY OPERATION REPORT FOR PWSs TREATING RAW GROUND WATER OR PURCHASED FINISHED WATER



See Pages 4 for Instructions.

I. General Information for the Month/Year of: April, 2005

A. Public Water System (PWS) Information

PWS Name:	Wootens			PWS Identification Number:	2541280
PWS Type:	<input checked="" type="checkbox"/> Community	<input type="checkbox"/> Non-Transient Non-Community	<input type="checkbox"/> Transient Non-Community	<input type="checkbox"/> Consecutive	
Number of Service Connections at End of Month:	29			Total Population Served at End of Month:	87
PWS Owner:	Aqua Utilities Florida				
Contact Person:	Brian Heath			Contact Person's Title:	Area Manager
Contact Person's Mailing Address:	PO Box 490310	City:	Leesburg	State:	Florida
Contact Person's Telephone Number:	(352) 787-098	Zip Code:	34749		
Contact Person's E-Mail Address:	beheath@aquaamerica.com				

B. Water Treatment Plant Information

Plant Name:	Wootens			Plant Telephone Number:	(352) 787-0980	
Plant Address:	Hess Road			City:	Georgetown	
Type of Water Treatment by Plant:	<input checked="" type="checkbox"/> Raw Ground Water	<input type="checkbox"/> Purchased Finished Water	State:	Florida		
Permitted Maximum Day Operating Capacity of Plant, gallons per day:	60,000					
Plant Category (per subsection 62-699.310(4), F.A.C.):	V			Plant Class (per subsection 62-699.310(4), F.A.C.):	D	
Licensed Operators	Name	License Class	License Number	Day(s) / Shift(s) Worked		
Lead/Chief Operator:	Larry White	C	7082	Days 1st Shift		
Other Operators:	Paul Thompson	A	7251	Days 1st Shift		

II. Certification by Lead/Chief Operator

I, the undersigned water treatment plant operator licensed in Florida, am the lead/chief operator of the water treatment plant identified in part I of this report. I certify that the information provided in this report is true and accurate to the best of my knowledge and belief. I certify that all drinking water treatment chemicals used at this plant conform to NSF International Standard 60 or other applicable standards referenced in subsection 62-555.320(3), F.A.C. I also certify that the following additional operations records for this plant were prepared each day that a licensed operator staffed or visited this plant during the month indicated above: (1) records of amounts of chemicals used and chemical feed rates; and (2) if applicable, appropriate treatment process performance records. Furthermore, I agree to provide these additional operations records to the PWS owner so the PWS owner can retain them, together with copies of this report, at a convenient location for at least ten years.

_____ Signature and Date	Larry White _____ Printed or Typed Name	C7082 _____ License Number
-----------------------------	---	----------------------------------

MONTHLY OPERATION REPORT FOR PW'Ss TREATING RAW GROUND WATER OR PURCHASED FINISHED WATER

PWS Identification Number: 2541280 Plant Name: Wootens

III. Daily Data for the Month/Year of: April, 2005

Means of Achieving Four-Log Virus Inactivation/Removal: Free Chlorine Chlorine Dioxide Ozone Combined Chlorine (Chloramines)
 Ultraviolet Radiation Other (Describe):

Type of Disinfectant Residual Maintained in Distribution System: Free Chlorine Combined Chlorine (Chloramines) Chlorine Dioxide

Day of the Month	Days Plant Staffed or Visited by Operator (Place "X")	Hours plant in Operation	Net Quantity of Finished Water Produced, gal.	CT Calculations, or UV Dose, to Demostate Four-Log Virus Inactivation, if Applicable*										Lowest Residual Disinfectant Concentration at Remote Point in Distribution System, mg/L	Emergency or Abnormal Operating Conditions; Repair or Maintenance Work that Involves Taking Water System Components Out of Operation	
				CT Calculations					UV Dose							
				Peak Flow Rate, gpd.	Lowest Residual Disinfectant Concentration (C) Before or at First Customer During Peak Flow, mg/L	Disinfectant Contact Time (T) at C Measurement Point During Peak Flow, minutes	Lowest CT Provided Before or at First Customer During Peak Flow, mg-min/L	Temp of Water, °C	pH of Water, if Applicable	Minimum CT Required, mg-min/L	Lowest Operating UV Dose, mW-sec/cm ²	Minimum UV Dose Required, mW-sec/cm ²				
1	X	24.0	3,350		2.6										1.1	
2		24.0	2,377													
3		24.0	2,377													
4	X	24.0	2,377		2.0										0.9	
5	X	24.0	2,410		1.9										1.0	
6	X	24.0	2,130		1.7										0.9	
7	X	24.0	2,940		2.1										1.0	
8	X	24.0	1,880		1.8										0.7	
9		24.0	8,007													
10		24.0	8,007													
11	X	24.0	8,007		1.6										0.8	
12	X	24.0	16,410		1.5										0.5	
13	X	24.0	15,750		1.0										0.4	
14	X	24.0	2,300		2.8										2.1	
15	X	24.0	2,090		2.9										2.4	
16		24.0	2,193													
17		24.0	2,193													
18	X	24.0	2,193		2.3										1.9	
19	X	24.0	3,680		2.4										2.0	
20	X	24.0	2,590		1.9										1.2	
21	X	24.0	2,550		1.4										0.9	
22	X	24.0	4,600		2.2										1.2	
23		24.0	2,507													
24		24.0	2,507													
25	X	24.0	2,507		1.9										1.1	
26	X	24.0	3,700		1.6										0.8	
27	X	24.0	2,280		2.0										0.9	
28	X	24.0	1,610		1.9										1.0	
29	X	24.0	2,460		2.1										1.0	
30		24.0	1,843													
31		24.0														
Total			119,823													
Average			3,865													
Maximum			16,410													

* Refer to the instructions for this report to determine which plants must provide this information.

MONTHLY OPERATION REPORT FOR PWSs TREATING RAW GROUND WATER OR PURCHASED FINISHED WATER



See Pages 4 for Instructions.

I. General Information for the Month/Year of: May, 2005

A. Public Water System (PWS) Information

PWS Name:	Wootens			PWS Identification Number:	2541280	
PWS Type:	<input checked="" type="checkbox"/> Community	<input type="checkbox"/> Non-Transient Non-Community	<input type="checkbox"/> Transient Non-Community	<input type="checkbox"/> Consecutive		
Number of Service Connections at End of Month:	29			Total Population Served at End of Month:	87	
PWS Owner:	Aqua Utilities Florida					
Contact Person:	Brian Heath			Contact Person's Title:	Area Manager	
Contact Person's Mailing Address:	PO Box 490310		City:	Leesburg	State:	Florida
Contact Person's Telephone Number:	(352) 787-098		Contact Person's Fax Number:	(352) 787-6333		
Contact Person's E-Mail Address:	beheath@aquamerica.com					

B. Water Treatment Plant Information

Plant Name:	Wootens			Plant Telephone Number:	(352) 787-0980	
Plant Address:	Hess Road		City:	Georgetown	State:	Florida
Type of Water Treatment by Plant:	<input checked="" type="checkbox"/> Raw Ground Water	<input type="checkbox"/> Purchased Finished Water				
Permitted Maximum Day Operating Capacity of Plant, gallons per day:	60,000					
Plant Category (per subsection 62-699.310(4), F.A.C.):	V			Plant Class (per subsection 62-699.310(4), F.A.C.):	D	
Licensed Operators:	Name	License Class	License Number	Day(s) / Shift(s) Worked		
Lead/Chief Operator:	Paul Thompson	A	7251	Days 1st Shift		
Other Operators:						

II Certification by Lead/Chief Operator

I, the undersigned water treatment plant operator licensed in Florida, am the lead/chief operator of the water treatment plant identified in part I of this report. I certify that the information provided in this report is true and accurate to the best of my knowledge and belief. I certify that all drinking water treatment chemicals used at this plant conform to NSF International Standard 60 or other applicable standards referenced in subsection 62-555.320(3), F.A.C. I also certify that the following additional operations records for this plant were prepared each day that a licensed operator staffed or visited this plant during the month indicated above: (1) records of amounts of chemicals used and chemical feed rates; and (2) if applicable, appropriate treatment process performance records. Furthermore, I agree to provide these additional operations records to the PWS owner so the PWS owner can retain them, together with copies of this report, at a convenient location for at least ten years.

Signature and Date	<u>Paul Thompson</u>	<u>A7251</u>
	Printed or Typed Name	License Number

MONTHLY OPERATION REPORT FOR PWSs TREATING RAW GROUND WATER OR PURCHASED FINISHED WATER

PWS Identification Number: 2541280 Plant Name: Woolens May, 2005

Means of Achieving Four-Log Virus Inactivation/Removal: Free Chlorine Chlorine Dioxide Ozone Combined Chlorine (Chloramines) Ultraviolet Radiation
 Type of Disinfectant Residual Maintained in Distribution System: Free Chlorine Combined Chlorine (Chloramines) Chlorine Dioxide

Days Plant Staffed or Visited by Operator (Place "X")	Hours plant in Operation	Net Quantity of Finished Water Produced, gal	Peak Flow Rate, gpd	Lowest Residual Disinfectant Concentration (C) Before or at First Customer During Peak Flow, mg/L	Disinfectant (D) at C Measurement Point During Peak Flow, minutes	Lowest CT Provided Before or at First Customer During Peak Flow, min/L	Temp of Water, °C if Applicable	pH of Water, if Applicable	Minimum CT Required, mg·min/L	Operating UV Dose, mW-sec/cm ²	Lowest UV Dose Required, mW-sec/cm ²	Emergency or Abnormal Operating Conditions: Repair or Maintenance Work that Involves Taking Water System Components Out of Operation	CT Calculations, or UV Dose, to Demostate Four-Log Virus Inactivation, if Applicable*	
													UV Dose	CT Calculations
1		24.0	2,765	2.3									1.8	
2	X	24.0	2,765	2.3									1.6	
3	X	24.0	2,270	2.3									1.4	
4	X	24.0	2,800	1.4									1.1	
5	X	24.0	1,910	1.3									0.8	
6	X	24.0	2,220	1.2									0.9	
7		24.0	1,870											
8		24.0	1,870											
9	X	24.0	1,870	1.0									0.8	
10	X	24.0	2,070	1.4									1.1	
11	X	24.0	2,480	1.2									0.9	
12	X	24.0	2,640	1.3									1.1	
13	X	24.0	1,730	1.6									0.7	
14		24.0	2,783											
15		24.0	2,783											
16	X	24.0	2,783	1.7									1.3	
17	X	24.0	1,600	1.6									0.6	
18	X	24.0	1,730	1.4									1.0	
19	X	24.0	2,390	1.6									1.2	
20	X	24.0	3,220	2.0									1.5	
21		24.0	2,467											
22		24.0	2,467											
23	X	24.0	2,467	1.8									1.3	
24	X	24.0	2,160	1.8									1.4	
25	X	24.0	2,240	1.9									1.5	
26	X	24.0	2,900	1.7									1.2	
27	X	24.0	2,590	1.7									1.2	
28		24.0	3,360											
29		24.0	3,360											
30	X	24.0	3,360	1.8									1.0	
31	X	24.0	3,560	1.5										
Total		77,480												
Average		2,499												
Maximum		3,560												

* Refer to the instructions for this report to determine which plants must provide this information.

MONTHLY OPERATION REPORT FOR PWSs TREATING RAW GROUND WATER OR PURCHASED FINISHED WATER



See Pages 4 for Instructions.

I. General Information for the Month/Year of: June, 2005

A. Public Water System (PWS) Information

PWS Name: Wootens		PWS Identification Number: 2541280	
PWS Type: <input checked="" type="checkbox"/> Community <input type="checkbox"/> Non-Transient Non-Community <input type="checkbox"/> Transient Non-Community <input type="checkbox"/> Consecutive			
Number of Service Connections at End of Month: 29		Total Population Served at End of Month: 87	
PWS Owner: Aqua Utilities Florida			
Contact Person: Brian Heath		Contact Person's Title: Area Manager	
Contact Person's Mailing Address: PO Box 490310		City: Leesburg	State: Florida
		Zip Code: 34749	
Contact Person's Telephone Number: (352) 787-098		Contact Person's Fax Number: (352) 787-6333	
Contact Person's E-Mail Address: beheath@aquamerica.com			

B. Water Treatment Plant Information

Plant Name: Wootens		Plant Telephone Number: (352) 787-0980	
Plant Address: Hess Road		City: Georgetown	State: Florida
		Zip Code: 32139	
Type of Water Treatment by Plant: <input checked="" type="checkbox"/> Raw Ground Water <input type="checkbox"/> Purchased Finished Water			
Permitted Maximum Day Operating Capacity of Plant, gallons per day: 60,000			
Plant Category (per subsection 62-699.310(4), F.A.C.): V		Plant Class (per subsection 62-699.310(4), F.A.C.): D	

Licensed Operators	Name	License Class	License Number	Day(s) / Shift(s) Worked
Lead/Chief Operator:	Larry White	C	7082	Days 1st Shift
Other Operators:	Paul Thompson	A	7251	Days 1st Shift

II. Certification by Lead/Chief Operator

I, the undersigned water treatment plant operator licensed in Florida, am the lead/chief operator of the water treatment plant identified in part I of this report. I certify that the information provided in this report is true and accurate to the best of my knowledge and belief. I certify that all drinking water treatment chemicals used at this plant conform to NSF International Standard 60 or other applicable standards referenced in subsection 62-555.320(3), F.A.C. I also certify that the following additional operations records for this plant were prepared each day that a licensed operator staffed or visited this plant during the month indicated above: (1) records of amounts of chemicals used and chemical feed rates; and (2) if applicable, appropriate treatment process performance records. Furthermore, I agree to provide these additional operations records to the PWS owner so the PWS owner can retain them, together with copies of this report, at a convenient location for at least ten years.

Signature and Date	Larry White Printed or Typed Name	C7082 License Number
--------------------	--------------------------------------	-------------------------

MONTHLY OPERATION REPORT FOR PW'Ss TREATING RAW GROUND WATER OR PURCHASED FINISHED WATER

PWS Identification Number: 2541280 Plant Name: Wootens

III. Daily Data for the Month/Year of: June, 2005

Means of Achieving Four-Log Virus Inactivation/Removal: Free Chlorine Chlorine Dioxide Ozone Combined Chlorine (Chloramines)
 Ultraviolet Radiation Other (Describe):

Type of Disinfectant Residual Maintained in Distribution System: Free Chlorine Combined Chlorine (Chloramines) Chlorine Dioxide

Day of the Month	Days Plant Staffed or Visited by Operator (Place "X")	Hours plant in Operation	Net Quantity of Finished Water Produced, gal.	CT Calculations, or UV Dose, to Demostate Four-Log Virus Inactivation, if Applicable*								Lowest Residual Disinfectant Concentration at Remote Point in Distribution System, mg/L	Emergency or Abnormal Operating Conditions, Repair or Maintenance Work that Involves Taking Water System Components Out of Operation	
				CT Calculations				UV Dose						
				Peak Flow Rate, gpd.	Lowest Residual Disinfectant Concentration (C) Before or at First Customer During Peak Flow, mg/L	Disinfectant Contact Time (T) at C Measurement Point During Peak Flow, minutes	Lowest CT Provided Before or at First Customer During Peak Flow, mg-min/L	Temp of Water, °C	pH of Water, if Applicable	Minimum CT Required, mg-min/L	Lowest Operating UV Dose, mW-sec/cm ²			Minimum UV Dose Required, mW-sec/cm ²
1	X	24.0	1,250		1.3								1.1	
2	X	24.0	3,770		1.6								1.3	
3	X	24.0	2,900		1.4								1.0	
4		24.0	2,317											
5		24.0	2,317											
6	X	24.0	2,317		1.3								0.8	
7	X	24.0	2,590		2.0								1.6	
8	X	24.0	940		1.6								1.4	
9	X	24.0	2,210		1.5								0.9	
10	X	24.0	1,800		1.4								1.0	
11		24.0	2,317											
12		24.0	2,317											
13	X	24.0	2,317		1.5								1.2	
14	X	24.0	2,050		1.8								1.5	
15	X	24.0	2,190		2.0								1.7	
16	X	24.0	2,800		1.4								1.6	
17	X	24.0	890		1.5								1.3	
18		24.0	2,523											
19		24.0	2,523											
20	X	24.0	2,523		1.6								1.4	
21	X	24.0	2,000		1.8								1.5	
22	X	24.0	1,500		1.5								1.2	
23	X	24.0	2,380		1.5								1.3	
24	X	24.0	2,720		2.0								1.6	
25		24.0	3,677											
26		24.0	3,677											
27	X	24.0	3,677		1.2								0.6	
28	X	24.0	2,110		1.4								1.1	
29	X	24.0	2,370		1.8								1.4	
30	X	24.0	3,670		1.6								1.2	
31		24.0												
Total			72,640											
Average			2,343											
Maximum			3,770											

* Refer to the instructions for this report to determine which plants must provide this information.

MONTHLY OPERATION REPORT FOR PW'Ss TREATING RAW GROUND WATER OR PURCHASED FINISHED WATER

PWS Identification Number: 2541280 Plant Name: Wootens

III. Daily Data for the Month/Year of: July, 2005

Means of Achieving Four-Log Virus Inactivation/Removal: Free Chlorine Chlorine Dioxide Ozone Combined Chlorine (Chloramines)
 Ultraviolet Radiation Other (Describe):

Type of Disinfectant Residual Maintained in Distribution System: Free Chlorine Combined Chlorine (Chloramines) Chlorine Dioxide

Day of the Month	Days Plant Staffed or Visited by Operator (Place "X")	Hours plant in Operation	Net Quantity of Finished Water Produced, gal.	CT Calculations, or UV Dose, to Demostate Four-Log Virus Inactivation, if Applicable*										Lowest Residual Disinfectant Concentration at Remote Point in Distribution System, mg/L	Emergency or Abnormal Operating Conditions; Repair or Maintenance Work that Involves Taking Water System Components Out of Operation
				CT Calculations					UV Dose						
				Peak Flow Rate, gpd.	Lowest Residual Disinfectant Concentration (C) Before or at First Customer During Peak Flow, mg/L	Disinfectant Contact Time (T) at C Measurement Point During Peak Flow, minutes	Lowest CT Provided Before or at First Customer During Peak Flow, mg-min/L	Temp of Water, °C	pH of Water, if Applicable	Minimum CT Required, mg-min/L	Lowest Operating UV Dose, mW-sec/cm ²	Minimum UV Dose Required, mW-sec/cm ²			
1	X	24.0	2,800		2.1									1.7	
2		24.0	3,620												
3		24.0	3,620												
4	X	24.0	3,620		2.0									1.5	
5	X	24.0	3,990		1.8									1.3	
6	X	24.0	2,490		1.5									1.2	
7	X	24.0	2,950		1.6									1.2	
8	X	24.0	2,530		1.5									1.0	
9		24.0	2,497												
10		24.0	2,497												
11	X	24.0	2,497		1.4									0.8	
12	X	24.0	2,720		1.5									0.6	
13	X	24.0	2,050		2.5									1.3	
14	X	24.0	2,040		2.2									1.2	
15	X	24.0	3,460		2.3									1.0	
16		24.0	2,883												
17		24.0	2,883												
18	X	24.0	2,883		2.1									1.2	
19	X	24.0	2,310		1.7									1.0	
20	X	24.0	3,830		2.2									1.3	
21	X	24.0	4,420		2.1									1.3	
22	X	24.0	3,190		2.1									1.2	
23		24.0	2,867												
24		24.0	2,867												
25	X	24.0	2,867		2.3									1.4	
26	X	24.0	2,790		2.2									1.5	
27	X	24.0	2,260		2.0									1.0	
28	X	24.0	5,850		2.1									1.1	
29	X	24.0	8,960		1.7									1.0	
30		24.0	3,220												
31		24.0	3,220												
Total			100,680												
Average			3,248												
Maximum			8,960												

* Refer to the instructions for this report to determine which plants must provide this information.

MONTHLY OPERATION REPORT FOR PW'Ss TREATING RAW GROUND WATER OR PURCHASED FINISHED WATER

PWS Identification Number: 2541280 Plant Name: Wootens

III. Daily Data for the Month/Year of: August, 2005

Means of Achieving Four-Log Virus Inactivation/Removal: Free Chlorine Chlorine Dioxide Ozone Combined Chlorine (Chloramines)
 Ultraviolet Radiation Other (Describe):

Type of Disinfectant Residual Maintained in Distribution System: Free Chlorine Combined Chlorine (Chloramines) Chlorine Dioxide

Day of the Month	Days Plant Staffed or Visited by Operator (Place "X")	Hours plant in Operation	Net Quantity of Finished Water Produced, gal.	CT Calculations, or UV Dose, to Demostate Four-Log Virus Inactivation, if Applicable*								Lowest Residual Disinfectant Concentration at Remote Point in Distribution System, mg/L	Emergency or Abnormal Operating Conditions, Repair or Maintenance Work that Involves Taking Water System Components Out of Operation	
				CT Calculations				UV Dose						
				Peak Flow Rate, gpd.	Lowest Residual Disinfectant Concentration (C) Before or at First Customer During Peak Flow, mg/L	Disinfectant Contact Time (T) at C Measurement Point During Peak Flow, minutes	Lowest CT Provided Before or at First Customer During Peak Flow, mg-min/L	Temp of Water, °C if Applicable	pH of Water	Minimum CT Required, mg-min/L	Lowest Operating UV Dose, mW-sec/cm ²			Minimum UV Dose Required, mW-sec/cm ²
1	X	24.0	4,830		2.5								1.7	
2	X	24.0	2,850		2.0								1.3	
3	X	24.0	2,090		1.9								1.0	
4	X	24.0	2,270		1.8								0.8	
5	X	24.0	1,750		1.6								0.7	
6		24.0	3,170											
7		24.0	3,170											
8	X	24.0	3,170		2.0								1.0	
9	X	24.0	3,230		2.0								1.3	
10	X	24.0	1,540		1.9								1.2	
11	X	24.0	2,980		1.8								1.0	
12	X	24.0	3,530		2.0								1.2	
13		24.0	3,183											
14		24.0	3,183											
15	X	24.0	3,183		1.8								1.1	
16	X	24.0	3,060		1.9								1.1	
17	X	24.0	4,530		1.5								0.9	
18	X	24.0	2,390		2.2								1.0	
19	X	24.0	6,370		1.6								0.8	
20		24.0	3,107											
21		24.0	3,107											
22	X	24.0	3,107		2.3								1.2	
23	X	24.0	4,360		1.9								1.0	
24	X	24.0	2,790		2.0								1.2	
25	X	24.0	2,310		1.9								1.1	
26	X	24.0	4,700		1.8								1.0	
27		24.0	3,050											
28		24.0	3,050											
29	X	24.0	3,050		2.2								1.3	
30	X	24.0	3,490		1.7								1.2	
31	X	24.0	2,750		1.9								1.1	
Total			99,350											
Average			3,205											
Maximum			6,370											

* Refer to the instructions for this report to determine which plants must provide this information.

MONTHLY OPERATION REPORT FOR PW'Ss TREATING RAW GROUND WATER OR PURCHASED FINISHED WATER

PWS Identification Number: 2541280 Plant Name: Wootens

III. Daily Data for the Month/Year of: September, 2005

Means of Achieving Four-Log Virus Inactivation/Removal: Free Chlorine Chlorine Dioxide Ozone Combined Chlorine (Chloramines)
 Ultraviolet Radiation Other (Describe):

Type of Disinfectant Residual Maintained in Distribution System: Free Chlorine Combined Chlorine (Chloramines) Chlorine Dioxide

Day of the Month	Days Plant Staffed or Visited by Operator (Place "X")	Hours plant in Operation	Net Quantity of Finished Water Produced, gal	CT Calculations, or UV Dose, to Demostate Four-Log Virus Inactivation, if Applicable*								Lowest Residual Disinfectant Concentration at Remote Point in Distribution System, mg/L	Emergency or Abnormal Operating Conditions, Repair or Maintenance Work that Involves Taking Water System Components Out of Operation	
				CT Calculations				UV Dose						
				Peak Flow Rate, gpd	Lowest Residual Disinfectant Concentration (C) Before or at First Customer During Peak Flow, mg/L	Disinfectant Contact Time (T) at C Measurement Point During Peak Flow, minutes	Lowest CT Provided Before or at First Customer During Peak Flow, mg-min/L	Minimum CT Required, mg-min/L	Lowest Operating UV Dose, mW-sec/cm ²	Minimum UV Dose Required, mW-sec/cm ²	Temp of Water, °C if Applicable			pH of Water, if Applicable
1	X	24.0	3,900		1.7								1.1	
2	X	24.0	3,540		2.1								1.0	
3		24.0	3,603											
4		24.0	3,603											
5	X	24.0	3,603		2.0								1.1	
6	X	24.0	4,870		1.9								1.0	
7	X	24.0	3,730		2.1								1.2	
8	X	24.0	3,410		2.1								1.3	
9	X	24.0	2,840		2.0								1.2	
10		24.0	3,247											
11		24.0	3,247											
12	X	24.0	3,247		1.8								0.9	
13	X	24.0	2,450		1.9								1.0	
14	X	24.0	2,170		1.8								0.8	
15	X	24.0	1,760		1.2								0.9	
16	X	24.0	2,370		2.1								1.6	
17		24.0	2,573											
18		24.0	2,573											
19	X	24.0	2,573		2.0								1.5	
20	X	24.0	2,210		1.9								1.3	
21	X	24.0	2,140		2.1								1.6	
22	X	24.0	1,500		2.0								1.4	
23	X	24.0	2,150		2.0								1.2	
24		24.0	2,307											
25		24.0	2,307											
26	X	24.0	2,307		2.6								2.0	
27	X	24.0	1,300		1.0								0.5	
28	X	24.0	1,620		0.8								0.7	
29	X	24.0	2,400		1.2								0.7	
30	X	24.0	2,330		1.4								1.1	
31		24.0												
Total			81,880											
Average			2,641											
Maximum			4,870											

* Refer to the instructions for this report to determine which plants must provide this information.

MONTHLY OPERATION REPORT FOR PWSs TREATING RAW GROUND WATER OR PURCHASED FINISHED WATER



See Pages 4 for Instructions.

I. General Information for the Month/Year of: October, 2005

A. Public Water System (PWS) Information

PWS Name: Wootens		PWS Identification Number: 2541280	
PWS Type: <input checked="" type="checkbox"/> Community <input type="checkbox"/> Non-Transient Non-Community <input type="checkbox"/> Transient Non-Community <input type="checkbox"/> Consecutive			
Number of Service Connections at End of Month: 29		Total Population Served at End of Month: 87	
PWS Owner: Aqua Utilities Florida			
Contact Person: Brian Heath		Contact Person's Title: Area Manager	
Contact Person's Mailing Address: PO Box 490310		City: Leesburg	State: Florida
Contact Person's Telephone Number: (352) 787-098		Zip Code: 34749	
Contact Person's E-Mail Address: beheath@aquamerica.com		Contact Person's Fax Number: (352) 787-6333	

B. Water Treatment Plant Information

Plant Name: Wootens		Plant Telephone Number: (352) 787-0980	
Plant Address: Hess Road		City: Georgetown	State: Florida
Type of Water Treatment by Plant: <input checked="" type="checkbox"/> Raw Ground Water <input type="checkbox"/> Purchased Finished Water		Zip Code: 32139	
Permitted Maximum Day Operating Capacity of Plant, gallons per day: 60,000			
Plant Category (per subsection 62-699.310(4), F.A.C.): V		Plant Class (per subsection 62-699.310(4), F.A.C.): D	
Licensed Operators	Name	License Class	License Number
Lead/Chief Operator:	Paul Thompson	A	7251
Other Operators:	Larry White	C	7082
	David Haring	C	14091

II. Certification by Lead/Chief Operator

I, the undersigned water treatment plant operator licensed in Florida, am the lead/chief operator of the water treatment plant identified in part I of this report. I certify that the information provided in this report is true and accurate to the best of my knowledge and belief. I certify that all drinking water treatment chemicals used at this plant conform to NSF International Standard 60 or other applicable standards referenced in subsection 62-555.320(3), F.A.C. I also certify that the following additional operations records for this plant were prepared each day that a licensed operator staffed or visited this plant during the month indicated above: (1) records of amounts of chemicals used and chemical feed rates; and (2) if applicable, appropriate treatment process performance records. Furthermore, I agree to provide these additional operations records to the PWS owner so the PWS owner can retain them, together with copies of this report, at a convenient location for at least ten years.

Signature and Date	Paul Thompson Printed or Typed Name	A7251 License Number
--------------------	--	-------------------------

MONTHLY OPERATION REPORT FOR PW'Ss TREATING RAW GROUND WATER OR PURCHASED FINISHED WATER

PWS Identification Number: 2541280 Plant Name: Wootens

III. Daily Data for the Month/Year of: October, 2005

Means of Achieving Four-Log Virus Inactivation/Removal: Free Chlorine Chlorine Dioxide Ozone Combined Chlorine (Chloramines)
 Ultraviolet Radiation Other (Describe):

Type of Disinfectant Residual Maintained in Distribution System: Free Chlorine Combined Chlorine (Chloramines) Chlorine Dioxide

Day of the Month	Days Plant Staffed or Visited by Operator (Place "X")	Hours plant in Operation	Net Quantity of Finished Water Produced, gal.	CT Calculations, or UV Dose, to Demostate Four-Log Virus Inactivation, if Applicable*								Lowest Residual Disinfectant Concentration at Remote Point in Distribution System, mg/L	Emergency or Abnormal Operating Conditions; Repair or Maintenance Work that Involves Taking Water System Components Out of Operation
				CT Calculations				UV Dose					
				Peak Flow Rate, gpd.	Lowest Residual Disinfectant Concentration (C) Before or at First Customer During Peak Flow, mg/L	Disinfectant Contact Time (T) at C Measurement Point During Peak Flow, minutes	Lowest CT Provided Before or at First Customer During Peak Flow, mg-min/L	Temp of Water, °C	pH of Water, if Applicable	Minimum CT Required, mg-min/L	Lowest Operating UV Dose, mW-sec/cm ²		
1		24.0	4,843										
2		24.0	4,843										
3	X	24.0	4,843		0.6								
4	X	24.0	2,110		1.4							0.3	
5	X	24.0	2,400		1.2							0.7	
6	X	24.0	1,590		1.2							0.4	
7	X	24.0	4,310		1.0							0.5	
8		24.0	2,143										
9		24.0	2,143										
10	X	24.0	2,143		1.6							0.6	
11	X	24.0	1,500		2.4							1.6	
12	X	24.0	2,500		2.1							1.2	
13	X	24.0	1,330		1.5							0.5	
14	X	24.0	2,950		1.5							0.5	
15		24.0	2,993										
16		24.0	2,993										
17	X	24.0	2,993		2.0							0.8	
18	X	24.0	1,200		1.7							0.6	
19	X	24.0	2,850		1.4							0.5	
20	X	24.0	2,000		1.7							0.8	
21	X	24.0	2,580		2.7							1.8	
22		24.0	2,077										
23		24.0	2,077										
24	X	24.0	2,077		1.5							0.7	
25	X	24.0	1,280		1.8							0.7	
26	X	24.0	2,000		1.3							0.5	
27	X	24.0	1,650		1.5							0.6	
28	X	24.0	2,930		1.3							0.6	
29		24.0	2,587										
30		24.0	2,587										
31	X	24.0	2,587		1.0							0.4	
Total			79,110										
Average			2,552										
Maximum			4,843										

* Refer to the instructions for this report to determine which plants must provide this information.

MONTHLY OPERATION REPORT FOR PWSs TREATING RAW GROUND WATER OR PURCHASED FINISHED WATER



See Pages 4 for Instructions.

I. General Information for the Month/Year of:	November, 2005
--	----------------

A. Public Water System (PWS) Information

PWS Name: Wootens		PWS Identification Number: 2541280	
PWS Type: <input checked="" type="checkbox"/> Community <input type="checkbox"/> Non-Transient Non-Community <input type="checkbox"/> Transient Non-Community <input type="checkbox"/> Consecutive			
Number of Service Connections at End of Month: 29		Total Population Served at End of Month: 87	
PWS Owner: Aqua Utilities Florida			
Contact Person: Brian Heath		Contact Person's Title: Area Manager	
Contact Person's Mailing Address: PO Box 490310		City: Leesburg	State: Florida
Contact Person's Telephone Number: (352) 787-098		Zip Code: 34749	
Contact Person's E-Mail Address: <u>beheath@aquaamerica.com</u>		Contact Person's Fax Number: (352) 787-6333	

B. Water Treatment Plant Information

Plant Name: Wootens		Plant Telephone Number: (352) 787-0980	
Plant Address: Hess Road		City: Georgetown	State: Florida
Type of Water Treatment by Plant: <input checked="" type="checkbox"/> Raw Ground Water <input type="checkbox"/> Purchased Finished Water		Zip Code: 32139	
Permitted Maximum Day Operating Capacity of Plant, gallons per day: 60,000			
Plant Category (per subsection 62-699.310(4), F.A.C.): V		Plant Class (per subsection 62-699.310(4), F.A.C.): D	
Licensed Operators	Name	License Class	License Number / Day(s) / Shift(s) Worked
Lead/Chief Operator:	Paul Thompson	A	7251 / Days 1st Shift
Other Operators:	Larry White	C	7082 / Days 1st Shift
	David Haring	C	14091 / Days 1st Shift

II. Certification by Lead/Chief Operator

I, the undersigned water treatment plant operator licensed in Florida, am the lead/chief operator of the water treatment plant identified in part I of this report. I certify that the information provided in this report is true and accurate to the best of my knowledge and belief. I certify that all drinking water treatment chemicals used at this plant conform to NSF International Standard 60 or other applicable standards referenced in subsection 62-555.320(3), F.A.C. I also certify that the following additional operations records for this plant were prepared each day that a licensed operator staffed or visited this plant during the month indicated above: (1) records of amounts of chemicals used and chemical feed rates; and (2) if applicable, appropriate treatment process performance records. Furthermore, I agree to provide these additional operations records to the PWS owner so the PWS owner can retain them, together with copies of this report, at a convenient location for at least ten years.

Signature and Date	Paul Thompson Printed or Typed Name	A7251 License Number
--------------------	--	-------------------------

MONTHLY OPERATION REPORT FOR PW'Ss TREATING RAW GROUND WATER OR PURCHASED FINISHED WATER

PWS Identification Number: 2541280 Plant Name: Wootens

III. Daily Data for the Month/Year of: November, 2005

Means of Achieving Four-Log Virus Inactivation/Removal: Free Chlorine Chlorine Dioxide Ozone Combined Chlorine (Chloramines)
 Ultraviolet Radiation Other (Describe):

Type of Disinfectant Residual Maintained in Distribution System: Free Chlorine Combined Chlorine (Chloramines) Chlorine Dioxide

Day of the Month	Days Plant Staffed or Visited by Operator (Place "X")	Hours plant in Operation	Net Quantity of Finished Water Produced, gal.	CT Calculations, or UV Dose, to Demostate Four-Log Virus Inactivation, if Applicable*								Lowest Residual Disinfectant Concentration at Remote Point in Distribution System, mg/L	Emergency or Abnormal Operating Conditions, Repair or Maintenance Work that Involves Taking Water System Components Out of Operation	
				CT Calculations				UV Dose						
				Peak Flow Rate, gpd	Lowest Residual Disinfectant Concentration (C) Before or at First Customer During Peak Flow, mg/L	Disinfectant Contact Time (T) at C Measurement Point During Peak Flow, minutes	Lowest CT Provided Before or at First Customer During Peak Flow, mg-min/L	Temp of Water, °C	pH of Water, if Applicable	Minimum CT Required, mg-min/L	Lowest Operating UV Dose, mW-sec/cm ²			Minimum UV Dose Required, mW-sec/cm ²
1	X	24.0	2,970		1.0								0.4	
2	X	24.0	1,800		1.0								0.4	
3	X	24.0	1,990		1.0								0.4	
4	X	24.0	2,780		1.0								0.4	
5		24.0	2,440											
6		24.0	2,440											
7	X	24.0	2,440		1.0								0.3	
8	X	24.0	2,250		1.2								0.2	
9	X	24.0	2,250		1.4								0.3	
10	X	24.0	3,770		1.2								0.3	
11	X	24.0	3,380		1.4								0.3	
12		24.0	2,330											
13		24.0	2,330											
14	X	24.0	2,330		1.4								0.3	
15	X	24.0	1,240		1.6								0.4	
16	X	24.0	2,030		1.5								0.3	
17	X	24.0	1,410		1.5								0.4	
18	X	24.0	3,720		1.6								0.4	
19		24.0	2,100											
20		24.0	2,100											
21	X	24.0	2,100		2.5								1.0	
22	X	24.0	2,620		2.4								1.0	
23	X	24.0	2,720		1.7								0.7	
24	X	24.0	2,730		1.8								0.6	
25	X	24.0	2,960		2.0								0.6	
26		24.0	3,430											
27		24.0	3,430											
28	X	24.0	3,430		2.0								0.6	
29	X	24.0	1,510		1.5								0.3	
30	X	24.0	3,110		1.3								0.3	
31		24.0												
Total			76,140											
Average			2,456											
Maximum			3,770											

* Refer to the instructions for this report to determine which plants must provide this information.

MONTHLY OPERATION REPORT FOR PW'SS TREATING RAW GROUND WATER OR PURCHASED FINISHED WATER

PWS Identification Number: 2541280 Plant Name: Wootens

III. Daily Data for the Month/year of: December, 2005

Means of Achieving Four-Log Virus Inactivation/Removal: Free Chlorine Chlorine Dioxide Ozone Combined Chlorine (Chloramines) Ultraviolet Radiation Other (Describe):

Type of Disinfectant Residual Maintained in Distribution System: Free Chlorine Combined Chlorine (Chloramines) Chlorine Dioxide

Days Plant Started or Visited by Operator (Place "X")	Hours plant in Operation	Net Quantity of Finished Water Produced, gal.	Peak Flow Rate, gpd.	Lowest Residual Disinfectant Concentration (C) Before or at First Measurement (T) at C	Disinfectant Contact Time Before or at First Customer During Peak Flow, minutes	Temp of Water, °C If Applicable	pH of Water	Minimum CT Required, mg·min/L	Lowest Operating UV Dose, mW·sec/cm ²	Required UV Dose, mW·sec/cm ²	Lowest Residual Disinfectant Concentration at Remote Point in Distribution System, mg/L	CT Calculations, or UV Dose, to Demostate Four-Log Virus Inactivation, if Applicable*	
												UV Dose	UV Dose
1	X	24.0	1,360	1.7							0.4		
2	X	24.0	3,240	1.5							0.4		
3		24.0	2,783										
4		24.0	2,783										
5	X	24.0	2,783	2.0							0.6		
6	X	24.0	2,080	2.0							0.8		
7	X	24.0	2,530	2.0							1.0		
8	X	24.0	2,150	1.8							0.4		
9	X	24.0	2,290	1.8							0.4		
10		24.0	2,340										
11		24.0	2,340										
12	X	24.0	2,340	1.7							0.3		
13	X	24.0	2,010	1.4							0.3		
14	X	24.0	1,920	1.4							0.3		
15	X	24.0	1,810	1.7							0.3		
16	X	24.0	3,380	1.5							0.3		
17		24.0	2,277										
18		24.0	2,277										
19	X	24.0	2,277	1.4							0.3		
20	X	24.0	1,670	1.4							0.3		
21	X	24.0	2,870	1.5							0.3		
22	X	24.0	2,560	1.5							0.3		
23	X	24.0	2,030	1.7							0.3		
24		24.0	2,253										
25		24.0	2,253										
26	X	24.0	2,253	1.7							0.3		
27	X	24.0	3,620	1.7							0.3		
28	X	24.0	3,500	1.5							0.3		
29	X	24.0	2,760	1.7							0.3		
30	X	24.0	3,240	1.5							0.3		
31		24.0	3,256										
Total			77,236										
Average			2,491										
Maximum			3,620										

* Refer to the instructions for this report to determine which plants must provide this information.