

090000-01

GOLD COAST UTILITY CORP.

P.O. Box 9076 • Lakeshore, Florida 33854 • (863) 696-0504 • Fax (863) 696-0504 • e-mail: lwuco@gsu.com

DISTRIBUTION CENTER
09 JUN 25 AM 7:19

DATE: June 23, 2009

PRECAUTIONARY BOIL WATER NOTICE

TO: ALL RESIDENTS OF THE NALCREST, LAKESHORE AREA COMMUNITIES INCLUDING GRANADA CONDOS, WALDEN SHORES MHP, AND VILLAGE GREEN APTS.

A LOSS OF WATER PRESSURE was EXPERIENCED ON **June 22** (from 10:15pm to 11:00pm). The cause of this problem was the loss of power to a control circuit at the water plant. We are working expeditiously to ensure this event does not reoccur.

RECEIVED-FPSC
09 JUN 25 AM 10:46
COMMISSION CLERK

AS A PRECAUTION, WE ADVISE THAT ALL WATER USED FOR DRINKING OR COOKING BE BOILED. A ROLLING BOIL OF ONE MINUTE IS SUFFICIENT. AS AN ALTERNATIVE BOTTLED WATER MAY BE USED. THIS "PRECAUTIONARY BOIL WATER NOTICE" WILL REMAIN IN EFFECT UNTIL A BACTERIOLOGICAL SURVEY SHOWS THAT THE WATER IS SAFE TO DRINK.

RESIDENTS WILL BE NOTIFIED WHEN TESTING IS COMPLETE AND BOIL WATER NOTICE IS RESCINDED.

ANY QUESTIONS OR CONCERNS SHOULD BE DIRECTED TO ME AT 696-0504.

Nathan Eckstein
Facility Supervisor
GOLD COAST UTILITY CORP.

CC: FILE
POLK COUNTY HEALTH UNIT – ENVIRONMENTAL SECTION

DOCUMENT NUMBER-DATE

06349 JUN 25 8

FPSC-COMMISSION CLERK