

7855 126TH AVENUE NORTH LARGO, FL 33773

Telephone: 727-536-9979

Bill To:

UTILITIES, INC.

ATTENTION: ACCOUNTS PAYABLE 2335 SANDERS ROAD

NORTHBROOK, IL 60062

## **Invoice 85972**

Date 03/02/15

**Customer U100** 

Batcl		
Doc_	669764	

Ship To:

LAKE PLACID WTP 2165 SOUTH US-27

2165 SOUTH US-27 LAKE PLACID, FL 33852

PO# !	8081		Order Number BU#242100		Terms Net 30 Day	s ·	
Reg.	Quantity Ship	B.O.	Item Number	Description	Tax	Unit Price	Amoun
1	1	0	SERVICE	Service Call ANNUAL	N	426.00	426.00
3	3	0	ssc	Gallon of Oil	Y	0.00	0.00
				REC MAR 1	<b>CEIVED</b> 1 2 2015		
NAN 45KW	S/N K980	822198 AN	NUAL GENERATO	DR SERVICE; MIKE WIL	SON		
UNTIL PAID	FOR IN F	ULL.		AMOUNT POWER, INC. N PAST DUE AMOUNTS.	NonTaxable Subtotal Taxable Subtotal Tax (7.000%) Total Invoice		426.00 0.00 0.00 426.00



Customer Number: U100 Address: UTILLTIES, INC.
ATTENTION: ACCOUNTS PAYABLE
2335 SANDERS ROAD
NORTHEROOK, IL 60062


Work Order #: 58276 Call Received By: ALLY Mileage: 126.31

Generator Set Package Specifications
Make: ONAN Model: 45GGFC
AMPs: Voltage: 480

Model: CSG-649I-6005-A Bat Volt: 12

AMPs: Voltage: 480
Spec No: 99767B
Engine Specifications
Make: FORD Model: CSG-648
Bat Size: C27
Engine Generator End Specifications
Gen Make:
Automatic Transfer Switch
ATS Make: CNAN Model: OT225
Service Call:
\*\*\*CALL: IN ADVANCE TO MEET TECH ON SITE\*\*\*

727-536-9979



Problem LAKE PLACID WTP Location: 2165 SOUTH US-27 LAKE PLACID, FL 33852

Product #: 1018 Mgmt Phone:-Mgmt Contact: NANCY

Preventive Maintenance NFPA 110, Table A-6-3.1 (a)

Ser No: K980822198 Hertz: 60

Ser No: 27465-0-04-98 Bat Qty: 1

Ser No:

Ser No: K980824185

Call Date: 01/13/2015 Location Phone: 407-468-3268 Location Contact: MIKE WILSON

Kw: 45 Phase: 3

Fuel Type: PROPANE Engine Specs: NP14837

Gen Spec:

ATS Spec: 14959K

	tions: VI:V	isual Inspections CL: Clean CH: Cha	nge K:Check R:	Record T: Test	
Fuel System		System Operation		Lubrication System	
Day Tank Float Switch (VI,T)	X	Amps: Phase 1		Crankcase Breather (CK, CL)	Х
Day Tank Level (VI,CK)	NA	Amps: Phase 2		Crankcase Oil Level (CK, CL)	Х
Fuel Filters (CH)		Amps: Phase 3		Governor Oil (VI, CK)	
Hoses and Connections (VI)	Х	Battery Charger Alternator (VI,R) AVI	DC 13.9	Governor Oil (CH)	
Main Supply Tank Level (VI,R)	65%	Building Load Test (T)		Hose Piping and Pittings (VI, CK)	Х
Main Supply Tank Level 2		Coolant System Leaks (VI)	X	Oil Change (CH)	X
Main Supply Tank Level 3		Exhaust Opacity (VI)	X	Oil Filters (CH)	X
Piping/Tubing (VI)	X	Exhaust System Leaks (VI)	X	Oil Sample	
Strainers or Traps (CL)	X	Exhaust Wet Stacking (VI)	Х	Generator	
Solenoid Valve Operation (VI,T)	X	Fuel System Leaks (VI)	Х	Bearings (VI)	Х
Supply or Transfer Pump (VI,T)	X	Governor Operation (VI,CK)	X	Brushes, Slip-Rings, Commutator (VI, CK, CL	
Tank Vents and Overflow (CK,T)	X	Loaded Hertz. (CK,R)		Diodes,Surge Supprsr,Heat Sink (VI,CL)	'x
Water in System (VI,T)	X	Loaded Voltage (CK,R)		Flexplate (VI)	X
System Summary		Manual Start (T)	X	Fuse, Circuit Breaker (VI,CL_T)	X
All System Breakers Closed	X	Oil Pressure (VI,R)	46	General Appearance	Х
Unit Left in Auto	X	Oil System Leaks (VI)	X	Mounting Hardware (VI,CK)	Х
Cooling System		Pre-Alarm System (T)	X	Stator, Rotor, Excitor (VI)	Х
Antifreeze Protection Freeze Point (T)	-23	Proper Air Flow (VI)	X	Voltage Regulator (VI,CL)	Х
Belt Condition and Tension (VI,CK)	Х	Shutdown System (T)		Wiring and Connections (VI,CK)	Х
Coolant Appearance (VI)	X	Unloaded Hertz. (CK,R)	60,2	Intake System	
Coolant Filter (CH)		Unloaded Voltage (CK,R) VAC	493	Air Filter (VI)	Х
Coolant Level (VI,CK)	Χ.	Unusual Vibrations/Noise (VI,CK)	X	Air Filter Replaced	
Condition of Radiator Exterior (VI,CL)	Х	Water Temperature (VI,R)	173	Air Filter Serviced	
Hoses and Connections (VI,CK)	X	Exhaust System		Hoses and Clamps (VI,CK)	Х
Inhibitor Protection (T)	X	Drain Condensate (CK)	X	PVC/Breather (VI,CK)	X
Jacket Water Heater (CK)	X	Flexible Connector (VI)	X	PVC/Breather Replaced	
Louvers and Ducts (VI,T)	Х	Insulation (VI,CK)	X	PVC/Breather Serviced	
Pressure Test Cap and System (T)	Х	Rain Cap or Metered Section (VI)	X	Turbo Charger (VI,CK)	X
Water Pump (VI)	Х	Silencer and Piping Condition (VI)	X	Prime Mover	
Battery System		Supports (VI,CK)	X	Carburator Adjustments(CK)	X
Battery Charger Float Operation (VI,R)	13.3	A.T.S.		General Appearence (VI, CL)	Х
Battery Charger Equalize Operatn. (CK,i		Cabintet Lamps (VI)	X	Governor Link Binding(VI, CK, Lube)	Х
Battery Age (VI,R)	Not Dated		X	Tune Up (spark ignited engine) (CH)	
Clean and Tighten Terminals (VI,CK)	X	Control Wiring/Connections (VI,CK)	X	Vibration Damper (VI)	Х
Electrolyte Level (CK)	X	Exercisor Clock (VI,R)	Tues @ 2:00 PM	Vibration Isolation Mounts (VI)	X
Load Test (T,R)	Pass	General Appearance (VI,CL)	X	Wiring and Connections (VI, CK)	Х
Specific Gravity/State of Charge (T)	>75%	Inphase/Program Transition	X	Ancillary Equipment	
		Main Contacts (VI)	X	Annunciator (VI)	
		Power Monitors (VI)	X	Generator Enclosure (VI) Lube Hinges	Х
		Time Delay Operations min.	_		
		Time Delay Operations sec.	0		

TYPEOF SERVICE: ANNUAL UNIT HOURS: 1096.5 DATE OF SERVICE: 02/24/2015
Comments: called Mike and scheduled to meet with someone at the unit @ 2:30. Arrived on site and checked the gates and they are all locked still. After waiting for 15 minutes, I called Mike and he apologizes and calls me back to tell me that someone will be out there right away. Otto arrives at 3:15 and opens the gates for me. I then perform the annual service. Annual inspection completed. Pumped out approx 3 gallons of oil, changed oil fifter and pumped in approx 3 gallons of new oil. All fluids are full and batteries, hoses, belts, and filters are all in good, serviceable condition. Unit starts without hesitation and runs up to temp without issue and all readings are normal. Power readings were taken from ATS which is in good condition. Unit shutdown, placed in auto with the breaker closed and the enclosure panels latched shut. After loading everything into the truck, I closed the ATS garage door and the gates and locked them.