

**City of Chattahoochee**  
**Report to the Florida Public Service Commission Pursuant to**  
**Rule 25-6.0343, F.A.C.**  
**Calendar Year 2015**

**1) Introduction**

- a) Name of city/utility  
City of Chattahoochee
  
- b) Address, street, city, zip  
P.O. Box 188  
115 Lincoln Drive  
Chattahoochee, FL 32324
  
- c) Contact information: Name, title, phone, fax, email  
Jimmy Cain  
Electric Distribution Forman  
Office: 850-663-4475  
Cell: 850-567-5167  
Fax: 850-663-4233  
E-Mail: jimmycain@fairpoint.net

**2) Number of meters served in calendar year 2015**

1156

**3) Standards of Construction**

**a) National Electric Safety Code Compliance**

Construction standards, policies, guidelines, practices, and procedures at the City of Chattahoochee comply with the National Electrical Safety Code (ANSI C-2).

**b) Extreme Wind Loading Standards**

Construction standards, policies, guidelines, practices, and procedures at the City of Chattahoochee are guided by extreme wind loading standards specified by figure 250-2 (d) of the 2002 edition of the N.E.S.C for new construction, rebuilding, or relocation of existing facilities, assigned on or after December 10, 2006.

**c) Flooding and Storm Surges**

The City of Chattahoochee is a non-coastal utility, therefore, storm surge/flooding is not an issue.

**d) Safe and Efficient Access of New and Replacement Distribution Facilities**

Electrical construction standards, policies, guidelines, practices, and procedures at the City of Chattahoochee provide for placement of new and replacement distribution facilities so as to facilitate safe and efficient access for installation and maintenance.

**e) Attachments by Others**

The pole attachment agreement between the City of Chattahoochee and third party affiliates include language, which specifies that the affiliate, not the City of Chattahoochee, has the burden of assessing pole strength and safety before they attach to the pole. The city or its designee shall have the right to inspect any time all construction work performed.

**4. Facility Inspections**

**a) Describe the utility's policies, guidelines, practices, and procedures for inspecting transmission and distribution lines, poles, and structures including, but not limited to, pole inspection cycles and pole selection process.**

A complete inspection is performed on the City of Chattahoochee's distribution system every three years. The inspection involves excavation around the base of the pole, sounding with a hammer (to determine if there is a hollow forming), and probing with a steel rod to determine depth of rot. A visual examination of the pole hardware, insulators, guys, and anchorage points are also made during this time.

**b) Describe the number and percentage of transmission and distribution inspections planned and completed for 2015.**

All 1,957 distribution poles were inspected in January of 2015. The City of Chattahoochee has no transmission facilities.

- c) Describe the number and percentage of transmission poles and structures and distribution poles failing inspection in 2015 and the reason for the failure.**

In the 2015 inspection 60 distribution poles, or 3% inspected were found to be defective. Ground line and pole top decay were the major causes.

- d) Describe the number and percentage of transmission poles and structures and distribution poles, by pole type and class of structure, replaced or for which remediation was taken after inspection in 2015, including a description of the remediation taken.**

33-(55% of poles failing inspection) class 6 - 30'  
11-(18% of poles failing inspection) class 6 – 35'  
16-(27% of poles failing inspection) class 4 – 40'

During 2015 we replaced, 18- 30'poles, 6-35'poles,15-40'poles and 1-45'pole. The remaining 20 defective poles will be worked on through out 2016.

## **5. Vegetation Management**

- a) Describe the utility's policies, guidelines, practices, and procedures for vegetation management, including programs addressing appropriate planting, landscaping, and problem tree removal practices for vegetation management outside of road right-of-ways or easements, and an explanation as to why the utility believes its vegetation management practices are sufficient.**

The City of Chattahoochee trims the distribution system on an annual basis. By trimming annually this decreases the man hours taken to perform this task when it is let go for too long. It also decreases the anxiety of home owners by not butchering trees that are extremely overgrown. This also cuts down on animal outages (mainly squirrels) by limiting their pathways to poles and conductors. All dead and severely leaning trees that pose a threat to lines are removed to prevent contact and damage.

- b) Describe the quantity, level, and scope of vegetation management planned and completed for transmission and distribution facilities in 2015.**

The Public Utility Research Center has held two management workshops in 2007 and 2009. Through F.E.M.A. the City of Chattahoochee has a copy of their reports and will use the

information to continually improve vegetation management practices. We will participate in future best practice workshops if there is interest.

## **6. Storm Hardening Research**

The City of Chattahoochee is a member of the Florida Municipal Electric Association (FMEA), which is participating with all of Florida's electric utilities in storm hardening research through the Public Utility Research Center at the University of Florida. Under separate cover, FMEA is providing the FPSC with a report of research activities. For further information, contact Barry Moline, Executive Director, FMEA, 850-224-3314, ext.1, or [bmoline@publicpower.com](mailto:bmoline@publicpower.com).