

City Hall 510 N. Baker St. Mount Dora, FL 32757

Office of the City Manager 352-735-7126 Fax: 352-735-4801

Finance Department 352-735-7118 Fax: 352-735-1406

Human Resources 352-735-7106 Fax: 352-735-9457

Planning and Development 352-735-7112 Fax: 352-735-7191

City Hall Annex 900 N. Donnelly St. Mount Dora, FL 32757

Parks and Recreation 352-735-7183 Fax: 352-735-3681

Public Safety Complex 1300 N. Donnelly St. Mount Dora, FL 32757

Police Department 352-735-7130 Fax: 352-383-4623

Fire Department 352-735-7140 Fax: 352-383-0881

 Public Works Complex

 1250 N. Highland St.

 Mount Dora, FL 32757

 352-735-7151

 Alt. Tel: 352-735-7105

 Fax: 352-735-1539

 Alt. Fax: 352-735-2892

W. T. Bland Public Library 1995 N. Donnelly St. Mount Dora, FL 32757 352-735-7180 Fax: 352-735-0074

Website: www.cityofmountdora.com VIA EMAIL (pbuys@psc.state.fl.us)

February 28, 2025

Penelope Buys Florida Public Service Commission 2540 Shumard Oak Boulevard Tallahassee, FL 32399-0850 Email: pbuys@psc.state.fl.us

Subject: Storm Hardening Report for City of Mount Dora, pursuant to Rule 25-6.0343, FAC

Dear Ms. Buys:

Pursuant to Rule 25-6.0343, Florida Administrative Code, attached is the Storm Hardening Report for 2024 for the City of Mount Dora.

The City is submitting this report to you via email and electronically through the PSC Clerk's office as well.

https://secure.floridapsc.com/ClerkOffice/EfilingPublic

Please verify receipt of this report by an email response to me at my email address shown below.

Submitted on behalf of:

Steven G. Langley Electric Utility Director

Please contact me if you have any questions.

Wayne R. Zimmerman

Deputy Electric Director 900 North Donnelly Street Mount Dora, FL 32757 <u>zimmermanw@ci.mount-dora.fl.us</u> Office: (352) 735-7151 extension 1818 Cell: (352) 630-9487

City of Mount Dora Report to the Florida Public Service Commission Pursuant to Rule 25-6.0343, F.A.C. Calendar Year 2024

1) Introduction

- a) City of Mount Dora
- b) 900 North Donnelly Street Mount Dora, FL 32757
- c) Contact information: Name, title, phone, fax, email

Mr. Steve Langley Electric Utility Director Phone: (352) 735-7155, ex 1815 Fax: (352) 735-1539 Email: langleys@cityofmountdora.com

2) Number of meters served in calendar year 2024

The City of Mount Dora has approximately 6313 customers.

3) Standards of Construction

a) National Electric Safety Code Compliance

Construction standards, policies, guidelines, practices, and procedures at the City of Mount Dora comply with the National Electrical Safety Code (NESC), (ANSI C-2). For electrical facilities constructed on or after January 1, 2017, the 2017 NESC applies. The edition of the NESC in effect at the time of the facility's initial construction governs electrical facilities constructed prior to January 1, 2017.

b) Extreme Wind Loading Standards

Construction standards, policies, guidelines, practices, and procedures at the City of Mount Dora are guided by the extreme wind loading standards as specified by <u>http://windspeed.atcouncil.org/</u> as recommended by the NESC for:

- a) New construction.
- b) Major planned work, including expansion, rebuild, or relocation of existing facilities, assigned on or after December 10, 2006.
- c) Targeted critical infrastructure facilities and major thoroughfares.

c) Flooding and Storm Surges

The City of Mount Dora is in the process of evaluating our standards, policies, guidelines, practices and procedures that address the effects of flooding and storm surges on underground facilities and supporting overhead facilities. Through the Florida Municipal Electric Association, The City of Mount Dora participates in the Public Utility Research Center's (PURC) study on the conversion of overhead electric facilities to underground and the effectiveness of undergrounding facilities in preventing storm damage and outages. We continue to evaluate and address the effects of flooding and storm surge but we feel that it is important to wait for the results of this research to justify the effort and cost of converting overhead to underground. The City is a non-coastal utility, however recognizes many of the Lakes and Drainage within our service territory have potential within these issues.

d) Safe and Efficient Access of New and Replacement Distribution Facilities

Electrical construction standards, policies, guidelines, practices, and procedures at the City of Mount Dora_provide for placement of new and replacement distribution facilities so as to facilitate safe and efficient access for installation and maintenance. Wherever new facilities are placed (i.e. front, back or side of property), all facilities are installed so that City's facilities are accessible by its crews and vehicles to ensure proper maintenance/repair is performed as expeditiously and safely as possible. The City decides on a case-by-case basis whether existing facilities need to be relocated. If it is determined that facilities need to be relocated, they will be placed in the safest, most accessible area available.

e. Attachments by Others

Electrical construction standards, policies, guidelines, practices, and procedures at the City of Mount Dora include written safety, pole reliability, and designate compliance to pole loading capacity, and engineering standards and procedures for attachments by others to the utility's electric transmission and distribution poles. We inspect these attachments on an 8 year cycle.

4. Facility Inspections

a) Describe the utility's policies, guidelines, practices, and procedures for inspecting transmission and distribution lines, poles, and structures including, but not limited to, pole inspection cycles and pole selection process.

The City electric system consists of distribution lines, poles, and structures – it owns no transmission facilities. Since its service territory is relatively small, the Electric Department has been able to make visual inspections of its six distribution feeders on an annual basis. Wood poles are visually inspected for cracks and a sounding technique is used to determine potential wood rot. On December 5, 2017, the City engaged a contractor to inspect and treat all wood poles in the electric service territory. This project was completed in 2019 and the City used the inspection results to establish a replacement priority. The City also makes comprehensive field inspections of its distribution lines, poles, and structures. The program consists of an annual field inspection of all six of the City's six distribution feeders, documented with a field report that identifies the following situations:

- 1. Pole Maintenance Items
- 2. Vegetation Maintenance
- 3. Transformer Maintenance
- 4. CATV Joint Use Attachment
- 5. Communications Joint Use Attachment

Once the field inspection reports have been completed, City staff goes back to each pole and makes the identified repairs. The City typically schedules the annual field inspections during the first quarter to enable a majority of repairs to be completed before hurricane season. If a third-party pole attachment appears damaged or does not meet NESC clearance requirements, the City notifies the respective party in writing.

To supplement the annual field inspections, the City makes additional inspections before the arrival of adverse weather events, such as hurricanes and tropical storms. The prestorm inspections utilize the same inspection form as the annual field inspection. Some of the City's distribution lines are attached to 69 kV transmission poles owned by Duke Energy. Any observed problems with the transmission poles are reported directly to Duke Energy. The City utilizes a GIS mapping system for its electric distribution system. The GIS system is now being used to map and manage all of the City's distribution facilities including wood and concrete poles, attached hardware, pole attachments by other entities, and underground electrical facilities.

The City also makes comprehensive field inspections of its distribution lines, poles, and structures. The program consists of an annual field inspection of all six of the City's six distribution feeders, documented with a field report that identifies and reports resolution to any anomalies detected.

The City completed its annual field inspections of its six distribution system during 2024. The City owns no transmission facilities so no inspections were made.

c) Describe the number and percentage of transmission poles and structures and distribution poles failing inspection in 2024 and the reason for the failure.

Pole inspections are conducted by the City on an eight (8) year cycle. The past inspection during 2017 all poles were inspected with corrective measures being complete. The next inspection is planned in 2025.

d) Describe the number and percentage of transmission poles and structures and distribution poles, by pole type and class of structure, replaced or for which remediation was taken after inspection in 2024, including a description of the remediation taken.

The City remediated all of the issues identified in the annual field inspection and has replaced installed additional poles shown in the data below.

The City attaches its distribution circuits to certain Duke Energy 69 kV transmission poles that are within the City's electric service area. Of the 90 transmission poles, 34 are wood. Duke Energy has an on-going program of replacing its older wood poles with steel poles. While these transmission poles are not owned by the City, the pole replacement program improves the ability of the City's distribution system to better withstand storm events since its distribution circuits attach to the poles. Moreover, hardening the two Duke Energy 69 kV transmission circuits that feed the Mount Dora Substation improves overall reliability.

	Number of Poles				Wood Pole	Added	Removed	Number of Poles	
		at 1/0	1/22		Replacements	FUIES	FUIES	at 12/3	0/2024
	Original	Inventory	Revised	% of					% of
Description	Count	Adjustment ⁽¹⁾	Count	Total Poles	Count	Count	Count	Count	Total Poles
Wood Poles									
25 foot	143	0	143	4.9%				143	4.9%
30 foot	638	0	638	21.9%		2		640	21.8%
35 foot	39	0	39	1.3%				39	1.3%
40 foot	443	0	443	15.2%		3		446	15.2%
45 foot	453	0	453	15.5%		5		458	15.6%
50/55 foot	0	0	0	0.0%				0	0.0%
Duke Energy Transmission ⁽²⁾	34	0	34	1.2%				34	1.2%
Total Wood Poles	1,750	0	1,750	60.0%	0	10	0	1,760	59.9%
Concrete/Fiberalass/Steel Poles									
30 foot	469	0	469	40.1%		1		470	39.9%
35 foot	0	0	0	0.0%				0	0.0%
40 foot	229	0	229	19.6%		6		235	19.9%
45 foot	387	0	387	33.1%		3		390	33.1%
50/55 foot	28	0	28	2 4%				28	2 4%
Duke Energy Transmission ⁽²⁾	56	0	56	4.8%				56	4.7%
Total Concrete/Fiber/Steel	1,169	0	1,169	40.0%	0	10	0	1,179	40.1%
									100.001
Lotal Dalaa:	2 0 1 0		2 0 1 0	100 00/	· · · · ·	20		2 0 2 0	100 00/

The following table lists all wood poles that were replaced / installed with concrete, fiberglass, or steel poles in 2024:

5. Vegetation Management

a) Describe the utility's policies, guidelines, practices, and procedures for vegetation management, including programs addressing appropriate planting, landscaping, and problem tree removal practices for vegetation management outside of road right-ofways or easements, and an explanation as to why the utility believes its vegetation management practices are sufficient.

The City's Electric Division trims trees on a 24 month cycle using an outside contractor. This contractor focuses on clearing vegetation that could adversely impact the reliability of the City's electric distribution system and to insure compliance with the NESC. In addition to the contractor crew, the City employs one two-man crew that is continuously trimming trees and reducing vegetative growth throughout other parts of the City. In some situations, the City crew assists the contractor crew in trimming or removing large trees.

The City routinely removes limbs from trees located outside road right-of-ways or easements that could create clearance problems for its overhead distribution circuits. The City has also removed entire trees in such locations if those trees threaten overhead distribution circuits (usually dead trees in danger of falling).

The City believes that its vegetation management practices result in high reliability because it trims trees on a 24 month cycle, which is much more frequent than the practices of other Florida electric utilities. The City owns no transmission facilities.

b) Describe the quantity, level, and scope of vegetation management planned and completed for transmission and distribution facilities in 2024.

The City Electric Division trimmed approximately 20 miles of distribution lines in maintaining a 24 month cycle for Circuits M598, M593 and M593. The City utilized an outside contractor to trim these three circuits. The City also removed limbs from trees located outside road right-of-ways or easements that could create clearance problems for its overhead distribution circuits. The City owns no transmission facilities

6. Storm Hardening Research

The City of Mount Dora is a member of the Florida Municipal Electric Association (FMEA), which is participating with all of Florida's electric utilities in storm hardening research through the Public Utility Research Center at the University of Florida. Under separate cover, FMEA will provide the FPSC with a report of research activities. For further information, contact Amy Zubaly, Executive Director, FMEA, 850-224-3314, ext. 1001, or <u>azubaly@flpublicpower.com</u>.