



Building Community®

# TEN YEAR SITE PLAN

---

April 2019

## Table of Contents

Introduction .....	1
1. Description of Existing Facilities .....	2
1.1 Power Supply System Description .....	2
1.1.1 System Summary .....	2
1.1.2 Purchased Power .....	4
1.2 Transmission and Distribution .....	8
1.2.1 Transmission and Interconnections .....	8
1.2.2 Transmission System Considerations .....	8
1.2.3 Transmission Service Requirements .....	9
1.2.4 Distribution .....	9
1.3 Demand Side Management .....	10
1.3.1 Interruptible Load .....	10
1.3.2 Demand-Side Management Programs .....	10
1.4 Clean Power and Renewable Energy .....	12
2. Forecast of Electric Power Demand and Energy Consumption .....	19
2.1 Peak Demand Forecast .....	19
2.2 Energy Forecast .....	19
2.3 Plug-in Electric Vehicle Peak Demand and Energy .....	22
3. Forecast of Facilities Requirements .....	29
3.1 Future Resource Needs .....	29
3.1.1 Integrated Resource Planning Study .....	29
3.1.2 Capacity Needs .....	29
3.2 Resource Plan .....	31
4. Other Planning Assumptions and Information .....	40
4.1 Fuel Price Forecast .....	40
4.2 Economic Parameters .....	41
4.2.1 Inflation and Escalation Rates .....	41
4.2.2 Municipal Bond Interest Rate .....	41
4.2.3 Present Worth Discount Rate .....	41
4.2.4 Interest During Construction Interest Rate .....	41
4.2.5 Levelized Fixed Charge Rate .....	41
5. Environmental and Land Use Information .....	43

## List of Tables and Figures

Table 1: JEA Purchased Power Schedule .....	6
Table 2: DSM Portfolio .....	11
Table 3: DSM Programs.....	11
Figure 1: Summer Peak Demand History & Forecast.....	20
Figure 2: Winter Peak Demand History & Forecast .....	21
Figure 3: Net Energy for Load History & Forecast .....	21
Figure 4: Plug-in Electric Vehicles Daily Charge Pattern .....	22
Table 4a: Resource Needs After Committed Units - Summer.....	29
Table 4b: Resource Needs After Committed Units - Winter.....	30
Table 5: Resource Plan.....	31

## List of Schedules

Schedule 1: Existing Generating Facilities .....	7
Schedule 2.1: History and Forecast of Energy Consumption and Number of Customers .....	23
Schedule 2.2: History and Forecast of Energy Consumption and Number of Customers .....	24
Schedule 3.1: History and Forecast of Summer Peak Demand.....	25
Schedule 3.2: History and Forecast of Winter Peak Demand .....	26
Schedule 3.3: History and Forecast of Annual Net Energy For Load.....	27
Schedule 4: Previous Year Actual and Two Year Forecast of Peak Demand and Net Energy for Load By Month .....	28
Schedule 5: Fuel Requirements .....	32
Schedule 6.1: Energy Sources (GWh) .....	33
Schedule 6.2: Energy Sources (Percent) .....	34
Schedule 7.1: Summer Forecast of Capacity, Demand, and Scheduled Maintenance at Time of Peak .....	35
Schedule 7.2: Winter Forecast of Capacity, Demand, and Scheduled Maintenance at Time of Peak .....	36
Schedule 8: Planned and Prospective Generating Facility Additions and Changes.....	37
Schedule 9: Status Report and Specifications of Proposed Generating Facilities.....	38
Schedule 10: Status Report and Specification of Proposed Directly Associated Transmission Lines.....	39

## List of Abbreviations

### Type of Generation Units

CA	Combined Cycle – Steam Turbine Portion, Waste Heat Boiler (only)
CC	Combined Cycle
CT	Combined Cycle – Combustion Turbine Portion
GT	Combustion Turbine
FC	Fluidized Bed Combustion
IC	Internal Combustion
ST	Steam Turbine, Boiler, Non-Nuclear

### Status of Generation Units

FC	Existing generator planned for conversion to another fuel or energy source
M	Generating unit put in deactivated shutdown status
P	Planned, not under construction
RT	Existing generator scheduled to be retired
RP	Proposed for repowering or life extension
TS	Construction complete, not yet in commercial operation
U	Under construction, less than 50% complete
V	Under construction, more than 50% complete

### Types of Fuel

BIT	Bituminous Coal
DFO	No. 2 Fuel Oil
RFO	No. 6 Fuel Oil
MTE	Methane
NG	Natural Gas
SUB	Sub-bituminous Coal
PC	Petroleum Coke
WH	Waste Heat

### Fuel Transportation Methods

PL	Pipeline
RR	Railroad
TK	Truck
WA	Water

## **Introduction**

---

The Florida Public Service Commission (FPSC) is responsible for ensuring that Florida's electric utilities plan, develop, and maintain a coordinated electric power grid throughout the state. The FPSC must also ensure that electric system reliability and integrity is maintained, that adequate electricity at a reasonable cost is provided, and that plant additions are cost-effective. In order to carry out these responsibilities, the FPSC must have information sufficient to assure that an adequate, reliable, and cost-effective supply of electricity is planned and provided.

The Ten-Year Site Plan (TYSP) provides information and data that will facilitate the FPSC's review. This TYSP provides information related to JEA's power supply strategy to adequately meet the forecasted needs of our customers for the planning period from January 1, 2019 to December 31, 2028. This power supply strategy maintains a balance of reliability, environmental stewardship, and low cost to the consumers.

## 1. Description of Existing Facilities

---

### 1.1 Power Supply System Description

#### 1.1.1 System Summary

JEA is the eighth largest municipally owned electric utility in the United States in terms of number of customers. JEA's electric service area covers most of Duval County and portions of Clay and St. Johns Counties. JEA's service area covers approximately 900 square miles and serves more than 450,000 customers.

As of January 1, 2019, JEA consists of three financially separate entities: the JEA Electric System; the St Johns River Power Park bulk power system; and the Robert W. Scherer bulk power system. St Johns River Power Park is in the process of being decommissioned. The total projected net capability of JEA's generation system is 3,105 MW for winter and 2,771 MW for summer. Details of the existing facilities are displayed in TYSP Schedule 1.

##### 1.1.1.1 The JEA Electric System

The JEA Electric System consists of generating facilities located on four plant sites within the City of Jacksonville (The City); the J. Dillon Kennedy Generating Station (Kennedy), the Northside Generating Station (Northside), the Brandy Branch Generating Station (Brandy Branch), and the Greenland Energy Center (GEC).

Collectively, these plants consist of two dual-fired (petroleum coke/coal) Circulating Fluidized Bed (CFB) steam turbine-generator units (Northside steam Units 1 and 2); one dual-fired (oil/gas) steam turbine-generator unit (Northside steam Unit 3); seven dual-fired (gas/diesel) combustion turbine-generator units (Kennedy GT7 and GT8, GEC GT1 and GT2 and Brandy Branch GT1, CT2, and CT3); four diesel-fired combustion turbine-generator units (Northside GTs 3, 4, 5, and 6); and one combined cycle heat recovery steam generator unit (Brandy Branch steam Unit 4).

JEA is currently upgrading Brandy Branch units CT2 and CT3. The upgrade involves the addition of General Electric's Advanced Gas Path (AGP) and 7FA.05 compressor modifications to the existing Brandy Branch CT2 and CT3 7FA.03 units. The upgrade is expected to yield an additional 84 MW of summer capacity and 33 MW of winter capacity via efficiency improvements as displayed in schedule 8. The upgrade is expected to be a minor source permit modification. Implementation is currently underway.

### **1.1.1.2 The Bulk Power Systems**

#### **1.1.1.2.1 St. John's River Power Park**

The St. Johns River Power Park (SJRPP) was jointly owned by JEA (80 percent) and Florida Power and Light (20 percent). SJRPP consisted of two nominal 638 MW bituminous coal fired units located north of the Northside Generating Station in Jacksonville, Florida. Unit 1 began commercial operation in March 1987 and Unit 2 followed in May 1988.

Although JEA was the majority owner of SJRPP, both owners were entitled to 50 percent of the output of SJRPP. Since Florida Power and Light (FPL) ownership was only 20 percent, JEA sold, and FPL purchased, on a "take-or-pay" basis, 37.5 percent of JEA's 80 percent share of the generating capacity and related energy of SJRPP. Contractually, the sale would have continued until the earlier of the Joint Ownership Agreement expiration in October 2021 or the realization of the sale limit which was expected to occur June 2019.

JEA and FPL obtained all required approvals, including those of the JEA Board, FPL's Board, and the Florida PSC, and definitive agreements for cessation of commercial operations and decommissioning of the Power Park were executed, including an Asset Transfer and Contract Termination Agreement dated as of May 17, 2017. .

JEA completed the Regulated Material Study and Environmental Site Assessments on August 25, 2017. FPL obtained Florida PSC Final Order approval on October 16, 2017. JEA's Procurement Awards Committee approved a Demolition and Soil Remediation contract on November 16, 2017. The plant closure was executed on January 5, 2018. The total demolition and the soil and groundwater remediation is scheduled to be complete in 2019. At that time final closing will occur and all land and real assets will be transferred to JEA.

#### **1.1.1.2.2 Robert W. Scherer Generating Station**

Robert W. Scherer Unit 4 is a coal-fired generating unit with a net output of 846 MW located in Monroe County, Georgia. Scherer Unit 4 is one of four coal-fired steam units located at the 12,000-acre site near the Ocmulgee River approximately three miles east of Forsyth, Georgia. JEA and FPL purchased an undivided interest of this unit from Georgia Power Company. JEA has 23.6 percent (200 net MW) and FPL 76.36 percent ownership interest in Unit 4.

In addition to the purchase of undivided ownership interests in Scherer Unit 4, under the Scherer Unit 4 Purchase Agreement, JEA and FPL also purchased proportionate undivided ownership interests in (i) certain common facilities shared by Units 3 and 4 at Plant Scherer, (ii) certain common facilities shared by Units 1, 2, 3 and 4 at Plant Scherer and (iii) an associated coal stockpile. Under a separate agreement, JEA also purchased a proportionate undivided ownership interest in substation and switchyard facilities. JEA has firm transmission service for delivering the energy output from this unit to JEA's system.

### **1.1.2 Purchased Power**

#### **1.1.2.1 Trail Ridge Landfill**

In 2006, JEA entered into a purchase power agreement (PPA) with Trail Ridge Energy, LLC (TRE) to purchase energy and environmental attributes from up to 9 net MW of firm renewable generation capacity utilizing the methane gas from the City's Trail Ridge landfill located in western Duval County (the "Phase One Purchase"). The facility is one of the largest landfill gas-to-energy facilities in the Southeast. The TRE gas-to-energy facility began commercial operation December 6, 2008.

JEA and TRE executed an amendment to this purchase power agreement on March 9, 2011 that included additional capacity. The "Phase Two Purchase" amendment included up to 9 additional net MW. Landfill Energy Systems (LES) developed the Sarasota County Landfill in Nokomis, Florida (up to 6 net MW) to serve part of this Phase Two agreement. This portion of the Phase Two purchase began February 2015.

#### **1.1.2.2 Southern Company**

JEA entered into a purchase power agreement with Southern Power to purchase 200 MW of firm capacity and associated energy from January 1, 2018 – December 31, 2019. The purchase is unit contingent on one of 2, Southern Power owned, natural gas fired combined cycle units at the Hal B Wansley plant, Wansley Unit 7. The plant is located in northeastern Heard County between the cities of Franklin and Carrollton in Georgia.

#### **1.1.2.3 Jacksonville Solar**

In May 2009, JEA entered into a purchase power agreement with Jacksonville Solar, LLC (Jax Solar) to receive up to 12 MW (AC rating) of as-available renewable energy from the solar plant located in western Duval County. The Jacksonville Solar facility consists of approximately 200,000 photovoltaic panels on a 100-acre site and was forecasted to produce an average of 22,340 megawatt-hours (MWh) of electricity per year. The Jacksonville Solar plant began commercial operation at full designed capacity September 30, 2010. Jax Solar generated 17,670 MWh in calendar year 2018.

#### **1.1.2.4 Solar Purchase Power Agreements**

In 2014, JEA's Board approved a Solar Photovoltaic Initiative that supports up to 38 additional MW (AC). JEA issued Solar PV RFPs in December 2014 and April 2015 to solicit PPA proposals to satisfy the adopted 2014 Solar PV Policy. JEA awarded a total of 31.5 MW of solar PV power purchase contracts with terms of 20-25 years to various vendors. Of the awarded contracts, only seven agreements have been finalized for a total of 27 MW. Only one of these solar facilities remain to be completed by close of 1<sup>st</sup> quarter of 2019.

In October 2017, the JEA Board approved a further solar expansion consisting of five-50 MWAC solar facilities to be constructed on JEA-owned property. These projects, totaling 250 MWAC, will



be structured as PPAs. Request for Qualifications to select the vendors was issued and a vendor short list was announced in November 2017. The RFP for the facilities was released to the short listed vendors on January 2, 2018. JEA received and evaluated 50 proposals that conformed to the requirements of the RFP. April 26, 2018, JEA awarded the contracts EDF Renewables Distributed Solutions. JEA negotiated and executed the contracts 1<sup>st</sup> quarter of 2019. JEA will purchase the produced energy and the associated environmental attributes from each facility: Beaver Street Solar Center, Cecil Commerce Solar Center, Deep Creek Solar Center, Forest Trail Solar Center, and Westlake Solar Center. The facilities are tentatively scheduled for completion by the end of 2022.

#### **1.1.2.5 Nuclear Generation**

JEA's Board had established targets to acquire 10 percent of JEA's energy requirements from nuclear sources by 2018 and up to 30 percent by 2030. In March 2008, the JEA Board of Directors approved the pursuit of nuclear energy partnerships as part of a strategy for greater regulatory and fuel diversification. In October, 2017, the JEA Board modified this goal by adopting an Energy Mix Policy, which allows the 30 percent target to be met by any carbon-free or carbon-neutral generation. Meeting these targets will result in a smaller carbon footprint for JEA's customers.

In June 2008, JEA entered into a 20-year purchase power agreement (PPA) with the Municipal Electric Authority of Georgia (MEAG) for a portion of MEAG's entitlement to Vogtle Units 3 and 4. These two new nuclear units are under construction at the existing Plant Vogtle location in Burke County, GA. Under this PPA, JEA is entitled to a total of 206 MW of firm capacity from these units. After accounting for transmission losses, JEA is anticipating to receive a total of 200 MW of net firm capacity from these units. The current schedule makes available to JEA 100 net MW of capacity beginning November 2021 from Unit 3 and an additional 100 net MW beginning November 2022 from Unit 4. Table 1 lists JEA's current purchased power contracts.

#### **1.1.2.6 Cogeneration**

Cogeneration facilities help meet the energy needs of JEA's system on an as-available, non-firm basis. Since these facilities are considered energy only resources, they are not forecasted to contribute firm capacity to JEA's reserve margin requirements.

Currently, JEA has contracts with one customer-owned qualifying facility (QF), as defined in the Public Utilities Regulatory Policy Act of 1978. Anheuser Busch has a total installed summer rated capacity of 8 MW and winter rated capacity of 9 MW.

**Table 1: JEA Purchased Power Schedule**

<b>Contract</b>		<b>Start Date</b>	<b>End Date</b>	<b>MW <sup>(1)</sup></b>	<b>Product Type</b>
<b>LES Trail Ridge</b>	<b>I</b>	12/06/08	12/31/26	9	Annual
	<b>II</b>	02/01/14	12/31/26	6	Annual
<b>MEAG Plant Vogtle</b>	<b>Unit 3</b>	06/01/19	06/01/39	100	Annual
	<b>Unit 4</b>	06/01/20	06/01/40	100	Annual
<b>Jacksonville Solar</b>		09/30/10	09/30/40	12	Annual
<b>NW Jacksonville Solar</b>		05/30/17	05/30/42	7	Annual
<b>Old Plank Road Solar</b>		10/13/17	10/13/37	3	Annual
<b>Starratt Solar</b>		12/20/17	12/20/37	5	Annual
<b>Blair Site Solar</b>		01/23/18	01/23/38	4	Annual
<b>Simmons Road Solar</b>		01/17/18	01/17/38	2	Annual
<b>Old Kings Solar</b>		10/15/18	10/15/38	1	Annual
<b>SunPort Solar</b>		10/01/19	10/01/39	5	Annual
<b>Cecil Commerce Solar<sup>(2)</sup></b>		02/01/21	02/01/45	50	Annual
<b>Forest Trail Solar <sup>(2)</sup></b>		05/01/21	05/01/46	50	Annual
<b>Deep Creek Solar <sup>(2)</sup></b>		08/01/21	08/01/46	50	Annual
<b>Westlake Solar<sup>(2)</sup></b>		10/01/21	10/01/46	50	Annual
<b>Beaver Street Solar<sup>(2)</sup></b>		01/01/22	01/01/47	50	Annual

<sup>(1)</sup> Capacity level may vary over contract term. All capacities are listed in MWAC.

<sup>(2)</sup> Dates are tentative.

## Schedule 1: Existing Generating Facilities

(1)	(2)	(3)	(4)	(5)	(6)	(7)	(8)	(9)	(10)	(11)	(12)	(13)	(14)	(15)
Plant Name	Unit Number	Location	Unit Type	Fuel Type		Fuel Transport		Commercial In-Service	Expected Retirement	Gen Max Nameplate (b)	Net MW Capability		Ownership	Status
				Primary	Alt.	Primary	Alt.	Mo/Year	Mo/Year	kW	Summer	Winter		
Kennedy										<u>407,600</u>	<u>300</u>	<u>382</u>		
	7	12-031	GT	NG	DFO	PL	WA	06/2000	(a)	203,800	150	191	Utility	
	8	12-031	GT	NG	DFO	PL	WA	06/2009	(a)	203,800	150	191	Utility	
Northside										<u>1,512,100</u>	<u>1,322</u>	<u>1,356</u>		
	1	12-031	ST	PC	BIT	WA	RR	05/2003	(a)	350,000	293	293	Utility	
	2	12-031	ST	PC	BIT	WA	RR	04/2003	(a)	350,000	293	293	Utility	
	3	12-031	ST	NG	RFO	PL	WA	07/1977	(a)	563,700	524	524	Utility	
	33-36	12-031	GT	DFO		WA,TK		01/1975	(a)	248,400	212	246	Utility	
Brandy Branch										<u>879,800</u>	<u>651</u>	<u>786</u>		
	1	12-031	GT	NG	DFO	PL	TK	05/2001	(a)	203,800	150	191	Utility	
	2	12-031	CT	NG		PL	TK	05/2001	(a)	203,800	150	186	Utility	
	3	12-031	CT	NG		PL	TK	10/2001	(a)	203,800	150	186	Utility	
	4	12-031	CA	WH				01/2005	(a)	268,400	201	223	Utility	
Greenland Energy Center										<u>407,600</u>	<u>300</u>	<u>382</u>		
	1	12-031	GT	NG	DFO	PL	TK	06/2011	(a)	203,800	150	191	Utility	
	2	12-031	GT	NG	DFO	PL	TK	06/2011	(a)	203,800	150	191	Utility	
Scherer														
	4	13-207	ST	BIT		RR		02/1989	(a)	990,000	198	198	Joint	(c)
JEA System Total											2,771	3,105		(d)

**Notes:**

- (a) Units expected to be maintained throughout the TYSP period.
- (b) Generator Max Nameplate is total unit not ownership.
- (c) Net capability reflects JEA's 23.64% ownership in Scherer 4.
- (d) Numbers may not add due to rounding.

## **1.2 Transmission and Distribution**

### **1.2.1 Transmission and Interconnections**

JEA's transmission system consists of 744 circuit-miles of bulk power transmission facilities operating at four voltage levels: 69 kV, 138 kV, 230 kV, and 500 kV.

The 500 kV transmission lines are jointly owned by JEA and FPL, completing the path from FPL's Duval substation (west of JEA's system) to the north to interconnect with the Georgia Integrated Transmission System (ITS). Along with JEA and FPL, Duke Energy Florida and the City of Tallahassee each own transmission interconnections with the Georgia ITS. JEA's import capacity is 1,228 MW over the 500 kV transmission lines through Duval substation.

The 230 kV and 138 kV transmission systems provide a backbone around JEA's service territory, with one river crossing in the north and no river crossings in the south, leaving an open loop. The 69 kV transmission system extends from JEA's core urban load center to the northwest, northeast, east, and southwest; covering the area not covered by the 230 kV and 138 kV transmission backbone.

JEA owns and operates a total of four 230 kV transmission interconnections at FPL's Duval substation in Duval County. In addition, JEA has one 230 kV transmission interconnection which terminates at Beaches Energy Services' Sampson substation (FPL metered) in St. Johns County. JEA's ownership of this interconnection ends at State Road 210 which is located just north of the Sampson substation. JEA also has one 230 kV transmission interconnection terminating at Seminole Electric Cooperative Incorporated's (SECI) Black Creek substation in Clay County. JEA's ownership of this interconnection ends at the Duval County – Clay County line.

JEA has one 138 kV tie-line owned by Beaches Energy Services terminating at JEA's Neptune substation. The 138 kV circuit breaker at Neptune substation is owned and maintained by JEA, and the 138 kV transmission line fed by the circuit breaker is owned and operated by Beaches Energy Services. JEA also owns and operates a 138 kV transmission loop that extends from the 138 kV backbone north to JEA's Nassau substation. This substation serves as a 138 kV transmission interconnection point for FPL's O'Neil substation and Florida Public Utilities Company's (FPU) Step Down substation. JEA's ownership of these two 138 kV interconnections end at the first transmission structure outside of the Nassau substation.

### **1.2.2 Transmission System Considerations**

JEA continues to evaluate and upgrade the bulk power transmission system as necessary to provide reliable electric service to its customers. In compliance with North American Electric Reliability Corporation (NERC) and Florida Reliability Coordinating Council's (FRCC) standards, JEA continually assesses the needs and options for increasing the capability of the transmission system.

JEA performs system assessments using JEA's published Transmission Planning Process in conjunction with and as an integral part of the FRCC's published Regional Transmission Planning Process. FRCC's published Regional Transmission Planning Process facilitates coordinated planning by all transmission providers, owners, and stakeholders within the FRCC Region.

FRCC's members include investor owned utilities, municipal utilities, power marketers, and independent power producers. The FRCC Board of Directors has the responsibility to ensure that the FRCC Regional Transmission Planning Process is fully implemented. The FRCC Planning Committee, which includes representation by all FRCC members, directs the FRCC Transmission Technical Subcommittee in conjunction with the FRCC Staff to conduct the necessary studies to fully implement the FRCC Regional Transmission Planning Process. The FRCC Regional Transmission Planning Process meets the principles of the Federal Energy Regulatory Commission (FERC) Final Rule in Docket No. RM05-35-000 for: (1) coordination, (2) openness, (3) transparency, (4) information exchange, (5) comparability, (6) dispute resolution, (7) regional coordination, (8) economic planning studies, and (9) cost allocation for new projects.

### **1.2.3 Transmission Service Requirements**

JEA also engages in market transmission service obligations via the Open Access Same-time Information System (OASIS) where daily, weekly, monthly, and annual firm and non-firm transmission requests are submitted by potential transmission service subscribers.

The following two existing transmission service contracts are set to expire in the near future:

- The contract for the delivery of backup, non-firm, as-available service to Beaches Energy Services will expire at the end of November of this year.
- FPL purchased Cedar Bay plant and retired the generation in December 2016. The transmission service for the delivery of Cedar Bay generation has been converted to JEA's Open Access Transmission service, and will remain with FPL through 2024.

### **1.2.4 Distribution**

The JEA distribution system operates at three primary voltage levels (4.16 kV, 13.2 kV, and 26.4 kV). The 4.16kV system serves a permanently defined area in older residential neighborhoods. The 13kV system serves a permanently defined area in the urban downtown area. These two distribution systems serve any new customers that are located within their defined areas, but there are no plans to expand these two systems beyond their present boundaries. The 26.4 kV system serves approximately 86 percent of JEA's load, including 75 percent of the 4.16 kV substations. The current standard is to expand the 26.4kV system as required to serve all new distribution loads, except loads that are within the boundaries of the 4.16kV or 13.2kV systems. JEA has approximately 6600 miles of distribution circuits of which more than half is underground

## **1.3 Demand Side Management**

### **1.3.1 Interruptible Load**

JEA currently offers Interruptible and Curtailable Service to eligible industrial class customers with peak demands of 750 kW or higher. Customers who subscribe to the Interruptible Service are subject to interruption of their full nominated load during times of system emergencies, including supply shortages. Customers who subscribe to the Curtailable Service may elect to voluntarily curtail portions of their nominated load based on economic incentives. For the purposes of JEA's planning reserve requirements, only customer load nominated for Interruptible Service is treated as non-firm. This non-firm load reduces the need for capacity planning reserves to meet peak demands. JEA forecasts 105 MW of interruptible peak load for the summer and 102 MW for the winter which remain constant throughout the study period. For 2019, the interruptible load represents 3.9 percent of the forecasted total peak demand in the winter and 4.3 percent of the forecasted total peak demand in the summer.

### **1.3.2 Demand-Side Management Programs**

JEA continues to pursue a greater implementation of demand-side management programs where economically beneficial and continues to meet JEA's Florida Energy Efficiency and Conservation Act (FEECA) goals. JEA's demand-side management programs focus on improving the efficiency of customer end uses as well as improving the system load factor. To encourage efficient customer usage, JEA offers customers both education and economic incentives on more efficient end use technologies. For load factor improvement, JEA has implemented a Demand Rate Pilot program with the intent of reducing peaks for residential customers.

Electrification programs include on-road and off-road vehicles, floor scrubbers, forklifts, cranes and other industrial process technologies. JEA's forecast of annual incremental demand and energy reductions due to its current DSM energy efficiency programs is shown in Table 2. The Demand Rate Pilot program is still in development, and as such impacts are not reflected in Table 2. JEA's current and planned DSM programs are summarized by commercial and residential programs in Table 3.

**Table 2: DSM Portfolio – Energy Efficiency Programs**

<b>ANNUAL INCREMENTAL</b>		<b>2019</b>	<b>2020</b>	<b>2021</b>	<b>2022</b>	<b>2023</b>	<b>2024</b>	<b>2025</b>	<b>2026</b>	<b>2027</b>	<b>2028</b>
<b>Annual</b>	Residential	12.8	12.8	12.8	12.8	12.8	12.8	12.8	12.8	12.8	12.8
<b>Energy</b>	Commercial	13.0	13.0	13.0	13.0	13.0	13.0	13.0	13.0	13.0	13.0
<b>(GWh)</b>	<b>Total</b>	<b>25.7</b>	<b>25.7</b>	<b>25.7</b>	<b>25.7</b>	<b>25.7</b>	<b>25.7</b>	<b>25.7</b>	<b>25.7</b>	<b>25.7</b>	<b>25.7</b>
<b>Summer</b>	Residential	2.4	2.4	2.4	2.4	2.4	2.4	2.4	2.4	2.4	2.4
<b>Peak</b>	Commercial	1.6	1.6	1.6	1.6	1.6	1.6	1.6	1.6	1.6	1.6
<b>(MW)</b>	<b>Total</b>	<b>4.0</b>	<b>4.0</b>	<b>4.0</b>	<b>4.0</b>	<b>4.0</b>	<b>4.0</b>	<b>4.0</b>	<b>4.0</b>	<b>4.0</b>	<b>4.0</b>
<b>Winter</b>	Residential	1.9	1.9	1.9	1.9	1.9	1.9	1.9	1.9	1.9	1.9
<b>Peak</b>	Commercial	1.2	1.2	1.2	1.2	1.2	1.2	1.2	1.2	1.2	1.2
<b>(MW)</b>	<b>Total</b>	<b>3.1</b>	<b>3.1</b>	<b>3.1</b>	<b>3.1</b>	<b>3.1</b>	<b>3.1</b>	<b>3.1</b>	<b>3.1</b>	<b>3.1</b>	<b>3.1</b>

**Table 3: DSM Programs**

<b>Commercial Programs</b>	<b>Residential Programs</b>
Commercial Energy Assessment Program	Residential Energy Assessment Program
Commercial Energy Efficient Products	Residential Energy Efficient Products
Commercial Prescriptive Program	Residential New Build
Custom Commercial Program	Residential Solar Water Heating
Commercial Solar Net Metering	Residential Solar Net Metering
Small Business Direct Install Program	Neighborhood Efficiency Program
Off-Road Electrification	Residential Efficiency Upgrade
	Electric Vehicles
	Demand Rate Pilot

## **1.4 Clean Power and Renewable Energy**

JEA continues to investigate economic opportunities to incorporate clean power and renewable energy into JEA's power supply portfolio. To that end, JEA has implemented several clean power and renewable energy initiatives and continues to evaluate potential new initiatives.

### **1.4.1 Clean Power Program**

From 1999 - 2014, JEA worked with the Sierra Club of Northeast Florida (Sierra Club), the American Lung Association (ALA), and local environmental groups through routine Clean Power Program meetings, as established in JEA's "Clean Power Action Plan" as a means of providing guidance and recommendations to JEA in the development and implementation of the Clean Power Programs.

Since the conclusion of this program, JEA has continued to make considerable progress related to clean power initiatives. This progress includes installation of clean power systems, unit efficiency improvements, solar purchase power agreements, legislative and public education activities, and research and development of clean power technologies.

### **1.4.2 Renewable Energy**

In 2005, JEA received a Sierra Club Clean Power Award for its voluntary commitment to increasing the use of solar, wind and other renewable or green power sources. Since that time, JEA has implemented new renewable energy projects and continues to explore additional opportunities to increase its utilization of renewable energy. JEA issued several Requests for Proposals (RFPs) for solar energy that resulted in new resources for JEA's portfolio. As discussed below, JEA's existing renewable energy sources include installation of solar photovoltaic (PV), solar thermal, and landfill gas capacity.

#### **1.4.2.1 Solar and the Solar Incentive**

JEA has installed 35 solar PV systems, totaling 222 kW, on public high schools in Duval County, as well as many of JEA's facilities, and the Jacksonville International Airport. To further promote the acceptance and installation of solar energy systems, JEA implemented the Solar Incentive Program in early 2002. This program provided rebates for the installation of solar thermal systems.

In addition to the solar thermal system incentive program, JEA established a residential net metering program to encourage the use of customer-sited solar PV systems. The policy has since evolved with several revisions:



- 2009: Tier 1 & 2 Net Metering policy launched to include all customer-owned renewable generation systems less than or equal to 100 kW
- 2011: Tier 3 Net Metering policy established for customer-owned renewable generation systems greater than 100 kW up to 2 MW
- 2014: Policy updated to define Tier 1 as 10 kW or less, Tier 2 as greater than 10 kW – 100 kW, and Tier 3 as greater than 100 kW – 2 MW. This policy was capped at 10 MW for total generation. All customer-owned generation in excess of 2 MW would be addressed in JEA's Distributed Generation Policy.
- October 2017: JEA Board approved the consolidation of the Net Metering and Distributed Generation Policies into a single, comprehensive Distributed Generation Policy.
- April 1, 2018: The comprehensive Distributed Generation (DG) Policy qualifies renewable and non-renewable customer-owned generation systems under the following ranges:
  - DG-1 – Less than or equal to 2 MW
  - DG-2D – Over 2 MW with distribution level connection
  - DG-2T – Over 2 MW with transmission level connection

This DG policy will act in concert with the JEA Battery Incentive Program (see Section 1.4.3.3 Energy Storage) and allows existing customers the option to be grandfathered under the 2014 Net Metering Policy for a period of 20 years.

JEA signed a purchase power agreement with Jacksonville Solar, LLC in May 2009 to provide energy from a 12 MWAC rated solar farm, which began operation in summer 2010 (see Section 1.1.2.3 Jacksonville Solar).

In December 2014, a Solar Policy was approved by the JEA Board, setting forth the goal of an additional 38 MW of solar photovoltaic (PV) power via power purchase contracts by the end of 2016. JEA issued three Solar PV RFPs and received a total of 73 bids. In 2015, JEA awarded a total of 31.5 MW of solar PV power purchase contracts with terms of 20 to 25 years to various vendors. One PPA for 5 MW on land owned by the U.S. Navy was awarded to Hecate Energy, LLC in 2016 because JEA and the Navy were unable to agree on the lease. A 4.5 MW award to SunEdison Utility Solutions, LLC was cancelled due to failure of the contractor to secure site control. The following are the seven PPAs that were finalized for a total of 27 MW in JEA's service territory of which JEA pays only for the energy produced by the facilities:

- 25-year PPA with Northwest Jacksonville Solar Partners, LLC for the produced energy, as well as the associated environmental attributes from a 7 MWAC facility, which consists of 28,000 single-axis tracking photovoltaic panels on a vendor-leased site, owned by American Electric Power (AEP). The facility became operational on May 30, 2017.

- 20-year PPA with Old Plank Road Solar Farm, LLC for the produced energy, as well as the associated environmental attributes from a 3-MWAC solar farm, Old Plank Road Solar. The facility, which consists of 12,800 single-axis tracking photovoltaic panels on a vendor-leased 40-acre site, is owned by Southeast Solar Farm Fund, a partnership between PEC Velo & Cox Communications. The site attained commercial operation on October 13, 2017.
- 20-year PPA with C2 Starratt Solar, LLC for the produced energy, as well as the associated environmental attributes from a 5- MWAC solar farm, Starratt Solar. The facility, on a vendor-leased site, is owned by C2 Starratt Solar, LLC and was constructed by Inman Solar, Incorporated. The site attained commercial operation on December 20, 2017.
- 20-year PPA with Inman Solar Holdings 2, LLC for the produced energy, as well as the associated environmental attributes from a 2 MWAC solar farm, Simmons Solar. The facility, on a vendor-leased site, is owned by Inman Solar Holdings 2, LLC and was constructed by Inman Solar, Inc. The site attained commercial operation on January 17, 2018.
- 20-year PPA with Hecate Energy Blair Road, LLC for the produced energy, as well as the associated environmental attributes from a 4 MWAC solar farm, Blair Road. The facility, on a vendor-leased site, is owned by Hecate Energy Blair Road, LLC and was constructed by Hecate Energy, LLC. The site attained commercial operation on January 23, 2018.
- 20-year PPA with JAX Solar Developers, a wholly-owned subsidiary of Mirasol Fafco Solar, Inc. for the produced energy, as well as the associated environmental attributes from a 1 MWAC solar farm, Old Kings Rd Solar. The facility is owned by EcoPower Development, LLC and was constructed by Mirasol Fafco Solar, Inc. The site attained commercial operation on October 15, 2018.
- 20-year PPA with National Solar, LLC for a 5 MWAC solar PV and 4 MWh battery storage system. The site, labeled SunPort Solar, is scheduled for commercial operation 4th quarter 2019.

In October 2017, the JEA Board approved a further solar expansion consisting of five-50 MWAC solar facilities to be constructed on JEA-owned property. These projects, totaling 250 MWAC, are structured as PPAs. Request for Qualifications to select the vendors was issued and a vendor short list was announced in November 2017. The RFP for the facilities was released to the short listed vendors on January 2, 2018. JEA received and evaluated 50 proposals that conformed to the requirements of the RFP. Near the end of April 2018, JEA awarded the contracts to EDF Renewables Distributed Solutions. JEA and EDF executed the contracts during the 1<sup>st</sup> quarter of 2019. JEA will purchase the produced energy, as well as the associated environmental attributes from each facility: Beaver Street Solar Center, Cecil Commerce Solar Center, Deep Creek Solar

Center, Forest Trail Solar Center, and Westlake Solar Center. The facilities are tentatively scheduled for completion by the end of 2022.

#### **1.4.2.2 Landfill Gas and Biogas**

JEA owned three internal combustion engine generators located at the Girvin Road landfill. This facility was placed into service in July 1997, and has been fueled by the methane gas produced by the landfill. The facility originally had four generators, with an aggregate net capacity of 3 MW. Since that time, gas generation has declined and one generator was removed and placed into service at the Buckman Wastewater Treatment facility and Girvin was decommissioned in 2014.

The JEA's Buckman Wastewater Treatment Plant previously dewatered and incinerated the sludge from the treatment process and disposed of the ash in a landfill. The current facility manages the sludge using three anaerobic digesters and one sludge dryer to produce a pelletized fertilizer product. The methane gas from the digesters can be used as a fuel for the sludge dryer and for the on-site 800 kW generator.

JEA signed a Power Purchase Agreement with Trail Ridge Energy, LLC (TRE) in 2006 (Phase One) for 9 net MW of the gas-to-energy facility at the Trail Ridge Landfill in Duval County. In 2011, JEA executed an amendment to the Power Purchase Agreement (Phase Two) to purchase 9 additional MW from a gas-to-energy facility. LES has developed the Sarasota County Landfill in Nokomis, Florida (up to 6 net MW) to serve part of this Phase Two agreement. This portion of the Phase Two purchase began February 2015 (see Section 1.1.2.1 Trail Ridge Landfill).

#### **1.4.2.3 Wind**

As part of its ongoing effort to utilize more sources of renewable energy, in 2004 JEA entered into a 20-year agreement with Nebraska Public Power District (NPPD) to participate in a wind generation project located in Ainsworth, Nebraska. JEA's participation in NPPD's wind generation project allows JEA to receive environmental credits (green tags) associated with this green power project. Under the wind generation agreement, JEA purchases 10 MW of capacity from NPPD's wind generation facility. In turn, NPPD buys back the energy at specified on and off peak charges.

JEA has sold environmental credits for specified periods from this project thereby reducing but not eliminating JEA's net cost for this resource for that period. With the expansion of JEA's renewable portfolio within the State of Florida, additional landfill gas generation and new solar facilities, JEA and NPPD agreed to terminate the contract effective December 31, 2019.

#### **1.4.2.4 Biomass**

In 2008, to obtain cost-effective biomass generation, JEA completed a detailed feasibility study of both self-build stand-alone biomass units and the co-firing of biomass in Northside 1 and 2.

The JEA self-build projects would not have been eligible for the federal tax credits afforded to developers. The co-firing alternative for Northside 1 and 2 considered potential reliability issues associated with both of those units. Even though the price of petroleum coke has been volatile in recent past, petroleum coke prices are still forecasted to be lower than the cost of biomass on an as-fired basis. In addition, JEA conducted an analytical evaluation of specific biomass fuel types to determine the possibility of conducting a co-firing test in Northside 1 or 2.

In 2011, JEA co-fired biomass in the Northside Units 1 and 2, utilizing wood chips from JEA tree trimming activities as a biomass energy source. Northside 1 and 2 produced a total of 2,154 MWh of energy from wood chips during 2011 and 2012. At that time, JEA received bids from local sources to provide sized biomass for potential use for Northside Units 1 and 2. Currently, no biomass is being co-fired in Northside Units 1 and 2.

### **1.4.3 Research Efforts**

Many of Florida's renewable resources such as offshore wind, tidal, and energy crops require additional research and development before they can be implemented as large-scale power generating technologies. JEA's renewable energy research efforts have focused on the development of these technologies through a partnership with the University of North Florida's (UNF) Engineering Department. In the past, UNF and JEA have worked on the following projects:

- JEA with UNF, worked to quantify the winter peak reductions of solar hot water systems.
- UNF, in association with the University of Florida, evaluated the effect of biodiesel fuel in a utility-scale combustion turbine. Biodiesel has been extensively tested on diesel engines, but combustion turbine testing has been very limited.
- UNF evaluated the tidal hydro-electric potential for North Florida, particularly in the Intracoastal Waterway, where small proto-type turbines have been tested.
- JEA, UNF, and other Florida municipal utilities partnered on a grant proposal to the Florida Department of Environmental Protection to evaluate the potential for offshore wind development in Florida.
- JEA provided solar PV equipment to UNF for installation of a solar system at the UNF Engineering Building to be used for student education.
- JEA developed a 15 acre biomass energy farm where the energy yields of various hardwoods and grasses were evaluated over a 3 year period.
- JEA participated in the research of a high temperature solar collector that has the potential for application to electric generation or air conditioning.

Through Florida State University (FSU), JEA participated in The Sunshine State Solar Grid Initiative (SUNGRIN) which was a five-year project (2010-2015) funded under the DOE Solar Energy Technologies Program (SETP), Systems Integration (SI) Subprogram, High Penetration Solar Deployment Projects. The goal of the SUNGRIN project, which started in spring 2010, was to gain significant insight into effects of high-penetration levels of solar PV systems in the power grid, through simulation-assisted research and development involving a technically varied and geographically dispersed set of real-world test cases within the Florida grid. JEA provided FSU with data from the output of Jacksonville Solar project.

In addition to these projects, in 2016 JEA pledged its support to the proposed 3-year Florida Alliance for Accelerating Solar and Storage Technology Readiness (FAASSTeR) project. The program, as led by Nhu Energy, Inc. and Florida Municipal Electric Association (FMEA), with partial funding from the DOE, seeks to grow solar capacity in FMEA member utilities to over 10% by 2024, and provide increased value in terms of cost of service, electric infrastructure reliability, security, and resilience, and environmental and broader economic benefits. With assistance from the National Renewable Energy Laboratory (NREL) and Lawrence Berkeley National Laboratory (LBNL), studies on cost and performance of solar and solar plus storage applications were conducted. As the program enters its final year, JEA is identifying potential strategies to apply study results in our solar and storage efforts.

#### **1.4.3.1 Generation Efficiency and New Natural Gas Generation**

In the late 1990's, JEA began to modernize its natural gas/oil fleet of generating units by replacing inefficient steam units and inefficient combustion turbine units with more efficient natural gas fired combustion turbines and combined cycle units. The retirement of units and their replacement with an efficient combined cycle unit and efficient simple cycle combustion turbines at Brandy Branch, Kennedy, and Greenland Energy Center significantly reduced CO2 emissions.

#### **1.4.3.2 Renewable Energy Credits**

JEA makes all environmental attributes from renewable facilities available to sell in order to lower rates for JEA customers. JEA has sold environmental credits for specified periods. In 2019, JEA will certify approximately 20,000 Solar RECs under the Green-e certification structure and track and deliver approximately 46,000 landfill gas REC through the North America Renewables (NAR) registry.

#### **1.4.3.3 Energy Storage**

JEA continues its efforts to demonstrate its commitment to energy efficiency and environmental improvement by researching energy storage applications and methods to efficiently incorporate storage technologies into the JEA system.

JEA will welcome a 4 MWh battery storage system to the grid 4th quarter 2019. The system will firm and smooth the PV output of the 5 MWAC SunPort Solar PV project. This will be the first utility scale storage system of its kind on the JEA system.

JEA commenced its Battery Incentive Program April 1, 2018 to provide a financial incentive towards the cost of an energy storage system, subject to lawfully appropriated funds. The Program, meant to be used in concert with the 2018 Distributed Generation Policy, facilitates customers in being efficient energy users. Customers who elect to collect the rebate will be able to offset electricity consumption from JEA, up to the limits of their storage devices. Funds allotted to each customer under the Program is subject to review and change, to optimize adoption. Since its inception, more than 25 applications have been submitted for residential storage systems.

## **2. Forecast of Electric Power Demand and Energy Consumption**

---

Annually, JEA develops forecasts of seasonal peaks demand, net energy for load (NEL), interruptible customer demand, demand-side management (DSM), and the impact of plug-in electric vehicles (PEVs). JEA removes from the total load forecast all seasonal, coincidental non-firm sources and adds sources of additional demand to derive a firm load forecast.

JEA uses National Oceanic and Atmospheric Administration (NOAA) Weather Station - Jacksonville International Airport for the weather parameters, Moody's Analytics (Moody) economic parameters for Duval County, JEA's Data Warehouse to determine the total number of Residential accounts and CBRE Jacksonville for Commercial and Industrial total inventory square footages. JEA develops its annual forecast using SAS and Microsoft Office Excel.

JEA's Fiscal Year 2019 baseline forecast uses 10-years of historical data. Using the shorter periods allows JEA to capture the more recent trends in customer behavior, energy efficiency and conservation, where these trends are captured in the actual data and used to forecast projections.

### **2.1 Peak Demand Forecast**

JEA normalizes historical seasonal peaks using historical maximum and minimum temperatures, 24°F is used as the normal temperature for the winter peak and 97°F for the normal summer peak demands. JEA develops the seasonal peak forecasts using multiple regression analysis of normalized historical seasonal peaks, normalized historical and forecasted residential, commercial and industrial energy for Winter/Summer peak months, heating degrees for the 72 hours leading to winter peak and cooling degrees for the 48 hours leading to summer peak. JEA's forecasted Average Annual Growth Rate (AAGR) for total peak demand during the TYSP period is 0.55 percent for summer and 0.75 percent for winter.

### **2.2 Energy Forecast**

JEA begins this forecast process by weather normalizing energy for each customer class. JEA uses NOAA Weather Station - Jacksonville International Airport for historical weather data. JEA develops the normal weather using 10-year historical average heating/cooling degree days and maximum/minimum temperatures. Normal months, with heating/cooling degree days and maximum/minimum temperatures that are closest to the averages, are then selected. JEA updates its normal weather every 5 years or more frequently, if needed.

The residential energy forecast was developed using multiple regression analysis of weather normalized historical residential energy, Total Population, Median Household Income, Total Housing Starts from Moody's Analytics, JEA's total residential accounts and JEA's residential electric rate.


The commercial energy forecast was developed using multiple regression analysis of weather normalized historical commercial energy, commercial inventory square footage, total commercial employment, gross product and JEA's commercial electric rate.

The industrial energy forecast was developed using multiple regression analysis of weather normalized historical industrial energy, total industrial employment, proprietors' profit and total retail sales product for existing industrial accounts. JEA then layers in the estimated energy for new industrial customers on the forecasted industrial energy.



The lighting energy forecast was developed using the historical actual energy, number of luminaries and JEA's estimated High Pressure Sodium (HPS) to Light-Emitting Diode (LED) street light conversion schedule. The LEDs are estimated to use 45% less energy than the HPS street lights. JEA developed the forecasted number of luminaries using regression analysis of the number of JEA customers. The forecasted lighting energy was calculated using the forecasted number of luminaries, applied with the remaining HPS to LED street light conversions with all new street light additions as LED only.

JEA's forecasted AAGR for net energy for load during the TYSP period is 0.57 percent.

**Figure 1: Summer Peak Demand History & Forecast**





**Figure 2: Winter Peak Demand History & Forecast****Figure 3: Net Energy for Load History & Forecast**

## 2.3 Plug-in Electric Vehicle Peak Demand and Energy


The PEVs demand and energy forecasts are developed using the historical number of PEVs in Duval County obtained from Florida Department of Highway Safety and Motor Vehicles (DHSMV) and the historical number of vehicles in Duval County from the U.S. Census Bureau.

JEA forecasted the numbers of vehicles in Duval County using multiple regression analysis of historical and forecasted Duval Population, Median Household Income and Number of Households from Moody's Analytics. The forecasted number of PEVs is modeled using multiple regression analysis of the number of vehicles and the average motor gasoline price from the U.S. Energy Information Administration (EIA) Annual Energy Outlook (AEO).

The usable battery capacity (70% of battery capacity) per vehicle was determined based on the current plug-in vehicle models in Duval County, such as BMW, General Motors' Chevrolet and Cadillac, Honda, Fisker, Ford, Mitsubishi, Nissan, Porsche, Tesla, Toyota and Volvo. The average usable battery capacity per PEV is calculated using the average usable battery capacity of each vehicle brand and then assumes the annual growth of usable battery capacity per PEV by using historical 5 years average growth of 0.69 kWh. Similarly, the peak capacity is determined based on the average on-board charging rate of each vehicle brand and the forecast peak capacity per PEV grows by 0.28 kW per year.

JEA developed the PEVs daily charge pattern based on the U.S. Census 2013 American Community Survey (ACS-13) for time of arrival to work and travel time to work for Duval County. The baseline forecast assumed that charging will be once every two days and uncontrolled; charging starts immediately upon arriving home.

**Figure 4: PEVs Daily Charge Pattern**



The PEVs peak demand forecast is developed using the on-board charge rate for each model, the PEVs daily charge pattern and the total number of PEVs each year. The PEV energy forecast is developed simply by summing the hourly peak demand for each year.

JEA's forecasted AAGRs for PEV winter and summer coincidental peak demand and total energy are 23 percent during the TYSP period.

**Schedule 2.1:** History and Forecast of Energy Consumption and Number of Customers by Class

(1)	(2)	(3)	(4)	(5)	(6)	(7)	(8)	(9)	(10)
Year	Rural and Residential			Commercial			Industrial		
	GWH Sales	Average Number of Customers	Average kWh/ Customer	GWH Sales	Average Number of Customers	Average kWh/ Customer	GWH Sales	Average Number of Customers	Average kWh/ Customer
2009	5,319	368,111	14,448	4,024	45,748	87,957	2,836	226	12,549,465
2010	5,747	369,051	15,572	4,071	46,192	88,137	2,913	223	13,057,475
2011	5,237	369,761	14,163	3,927	46,605	84,255	2,889	215	13,434,073
2012	4,880	372,430	13,102	3,852	47,127	81,735	2,809	218	12,875,696
2013	4,852	377,326	12,860	3,777	47,691	79,204	2,804	219	12,795,722
2014	5,162	383,998	13,443	3,882	49,364	78,642	2,785	215	12,984,365
2015	5,197	391,219	13,285	4,001	50,821	78,733	2,806	207	13,531,924
2016	5,351	398,387	13,431	4,064	51,441	78,994	2,692	202	13,322,934
2017	5,199	404,806	12,842	4,011	51,970	77,176	2,777	202	13,717,349
2018	5,460	412,070	13,251	4,042	52,525	76,954	2,765	196	14,081,384
2019	5,273	418,407	12,602	4,117	53,462	77,002	2,858	197	14,508,854
2020	5,305	424,939	12,484	4,143	54,101	76,585	2,866	197	14,547,396
2021	5,331	431,420	12,356	4,178	54,735	76,327	2,869	197	14,564,867
2022	5,363	437,973	12,245	4,210	55,360	76,051	2,874	197	14,588,164
2023	5,400	444,544	12,147	4,240	55,976	75,754	2,875	197	14,595,252
2024	5,434	450,901	12,050	4,267	56,587	75,411	2,873	197	14,582,096
2025	5,472	457,010	11,973	4,294	57,194	75,069	2,869	197	14,560,917
2026	5,518	462,846	11,922	4,320	57,796	74,739	2,869	197	14,562,319
2027	5,571	468,446	11,892	4,345	58,394	74,414	2,873	197	14,582,416
2028	5,631	473,963	11,881	4,371	58,988	74,105	2,874	197	14,589,885

**Schedule 2.2:** History and Forecast of Energy Consumption and Number of Customers by Class

Year	(11)	(12)	(13)	(14)	(15)	(16)	(17)	(18)
	Street & Highway Lighting	Other Sales to Ultimate Customers	Total Sales to Ultimate Customers	Sales For Resale	Utility Use & Losses	Net Energy For Load	Other Customers	Total Number of Customers
	GWH	GWH	GWH	GWH	GWH	GWH	(Avg. Number)	
2009	120	0	12,299	591	265	13,155	2	414,086
2010	122	0	12,853	766	227	13,846	2	415,468
2011	123	0	12,176	500	304	12,980	2	416,583
2012	123	0	11,663	423	325	12,411	2	419,777
2013	122	0	11,556	395	335	12,286	2	425,238
2014	105	0	11,934	472	252	12,658	2	433,578
2015	87	0	12,091	392	385	12,868	2	442,249
2016	77	0	12,184	490	263	12,937	2	450,032
2017	63	0	12,050	288	334	12,672	2	456,981
2018	59	0	12,326	82	405	12,813	1	464,793
2019	53	0	12,301	42	353	12,696	1	472,067
2020	52	0	12,366	42	356	12,765	1	479,238
2021	51	0	12,429	43	360	12,832	1	486,353
2022	52	0	12,499	43	365	12,907	1	493,531
2023	53	0	12,568	43	370	12,982	1	500,719
2024	53	0	12,627	43	378	13,048	1	507,686
2025	54	0	12,688	44	388	13,120	1	514,402
2026	55	0	12,761	44	394	13,199	1	520,840
2027	56	0	12,844	44	393	13,282	1	527,039
2028	56	0	12,933	44	389	13,366	1	533,149

Schedule 3.1: History and Forecast of Summer Peak Demand

(1)	(2)	(3)	(4)	(5)	(6)	(7)	(8)	(9)	(10)	(11)		(12)	
Calendar Year	Total Demand	Interruptible Load	PEV	Load Management		QF Load Served By QF Generation	Cumulative Conservation		Net Firm Peak Demand	Time Of Peak			
				Residential	Comm/Indu		Residential	Comm/Indu		Month	Day	H.E.	Temp
2009	2,754	0	0	0	0	0	0	0	2,754	6	22	1600	98
2010	2,817	0	0	0	0	0	0	0	2,817	6	18	1700	102
2011	2,756	0	0	0	0	0	0	0	2,756	8	11	1700	98
2012	2,616	0	0	0	0	0	0	0	2,616	7	25	1700	95
2013	2,596	0	0	0	0	0	0	0	2,596	8	14	1600	93
2014	2,646	0	0	0	0	0	0	0	2,646	8	22	1600	99
2015	2,683	0	0	0	0	0	0	0	2,683	6	17	1600	97
2016	2,763	0	0	0	0	0	0	0	2,763	7	7	1700	98
2017	2,682	0	0	0	0	0	0	0	2,682	8	16	1700	96
2018	2,557	0	0	0	0	0	0	0	2,557	8	8	1500	90
2019	2,454	105	1	0	0	0	2	2	2,556	---	---	---	---
2020	2,468	105	2	0	0	0	5	3	2,567	---	---	---	---
2021	2,482	105	2	0	0	0	7	5	2,577	---	---	---	---
2022	2,497	105	2	0	0	0	10	6	2,588	---	---	---	---
2023	2,512	105	3	0	0	0	12	8	2,600	---	---	---	---
2024	2,525	105	4	0	0	0	14	10	2,610	---	---	---	---
2025	2,537	105	4	0	0	0	17	11	2,619	---	---	---	---
2026	2,548	105	5	0	0	0	19	13	2,627	---	---	---	---
2027	2,562	105	6	0	0	0	22	14	2,637	---	---	---	---
2028	2,577	105	7	0	0	0	24	16	2,649	---	---	---	---

**Note:** All projections coincident at time of peak.

Schedule 3.2: History and Forecast of Winter Peak Demand

(1)	(2)	(3)	(4)	(5)	(6)	(7)	(8)	(9)	(10)	(11)		(12)	
Calendar Year	Total Demand	Interruptible Load	PEV	Load Management		QF Load Served By QF Generation	Cumulative Conservation		Net Firm Peak Demand	Time Of Peak			
				Residential	Comm/Indu		Residential	Comm/Indu		Month	Day	H.E.	Temp
2009	3,064	0	0	0	0	0	0	0	3,064	2	6	800	23
2010	3,224	0	0	0	0	0	0	0	3,224	1	11	800	20
2011	3,062	0	0	0	0	0	0	0	3,062	1	14	800	23
2012	2,665	0	0	0	0	0	0	0	2,665	1	4	800	22
2013	2,559	0	0	0	0	0	0	0	2,559	2	18	800	24
2014	2,823	0	0	0	0	0	0	0	2,823	1	7	800	22
2015	2,863	0	0	0	0	0	0	0	2,863	2	20	800	24
2016	2,674	0	0	0	0	0	0	0	2,674	1	20	800	28
2017	2,480	0	0	0	0	0	0	0	2,480	1	9	800	30
2018	3,080	0	0	0	0	0	0	0	3,080	1	8	800	26
2019	2,615	102	0	0	0	0	2	1	2,715	---	---	---	---
2020	2,639	102	0	0	0	0	4	2	2,735	---	---	---	---
2021	2,659	102	0	0	0	0	6	4	2,752	---	---	---	---
2022	2,678	102	1	0	0	0	8	5	2,768	---	---	---	---
2023	2,700	102	1	0	0	0	10	6	2,787	---	---	---	---
2024	2,718	102	1	0	0	0	11	7	2,802	---	---	---	---
2025	2,735	102	1	0	0	0	13	8	2,816	---	---	---	---
2026	2,753	102	1	0	0	0	15	10	2,832	---	---	---	---
2027	2,773	102	2	0	0	0	17	11	2,849	---	---	---	---
2028	2,796	102	2	0	0	0	19	12	2,869	---	---	---	---

**Note:** All projections coincident at time of peak.

**Schedule 3.3:** History and Forecast of Annual Net Energy For Load

(1)	(2)	(3)		(4)	(5)	(6)	(7)	(8)	(9)	(10)
Calendar Year	Total Energy for Load	Interruptible Load	PEV	Load Management		QF Load Served By QF Generation	Cumulative Conservation		Net Energy for Load	Load Factor
				Residential	Comm/Indu		Residential	Comm/Indu		
2009	13,155	0	0	0	0	0	0	0	13,155	49%
2010	13,846	0	0	0	0	0	0	0	13,846	49%
2011	12,980	0	0	0	0	0	0	0	12,980	48%
2012	12,411	0	0	0	0	0	0	0	12,411	53%
2013	12,286	0	0	0	0	0	0	0	12,286	54%
2014	12,658	0	0	0	0	0	0	0	12,658	51%
2015	12,868	0	0	0	0	0	0	0	12,868	51%
2016	12,937	0	0	0	0	0	0	0	12,937	53%
2017	12,672	0	0	0	0	0	0	0	12,672	54%
2018	12,813	0	0	0	0	0	0	0	12,813	47%
2019	12,716	0	6	0	0	0	13	13	12,696	53%
2020	12,809	0	8	0	0	0	26	26	12,765	53%
2021	12,899	0	10	0	0	0	38	39	12,832	53%
2022	12,997	0	12	0	0	0	51	52	12,907	53%
2023	13,095	0	15	0	0	0	64	65	12,982	53%
2024	13,184	0	19	0	0	0	77	78	13,048	53%
2025	13,278	0	23	0	0	0	90	91	13,120	53%
2026	13,378	0	28	0	0	0	102	104	13,199	53%
2027	13,481	0	33	0	0	0	115	117	13,282	53%
2028	13,585	0	39	0	0	0	128	130	13,366	53%

**Schedule 4:** Previous Year Actual and Two Year Forecast of Peak Demand and Net Energy for Load By Month

(1)	(2)	(3)	(2)	(3)	(4)	(5)	(6)	(7)
	Actual	2018	Forecast	2019	Forecast	2020	Forecast	2021
Month	Peak Demand (MW)	Net Energy For load (GWH)	Peak Demand (MW)	Net Energy For load (GWH)	Peak Demand (MW)	Net Energy For load (GWH)	Peak Demand (MW)	Net Energy For load (GWH)
January	3,080	1,220	2,715	1,036	2,735	1,042	2,752	1,047
February	1,956	832	2,463	899	2,481	904	2,497	908
March	2,000	899	1,917	940	1,932	945	1,944	950
April	1,819	881	1,908	920	1,916	925	1,924	930
May	2,242	1,060	2,290	1,085	2,299	1,091	2,308	1,097
June	2,511	1,186	2,411	1,179	2,421	1,185	2,431	1,191
July	2,535	1,226	2,517	1,282	2,528	1,289	2,538	1,295
August	2,557	1,284	2,556	1,263	2,567	1,270	2,577	1,277
September	2,556	1,257	2,359	1,135	2,369	1,141	2,379	1,147
October	2,354	1,076	2,167	1,019	2,184	1,024	2,197	1,030
November	2,144	921	2,080	934	2,096	939	2,109	944
December	2,367	971	2,252	1,004	2,269	1,009	2,283	1,015
Annual Peak and Total Energy	3,080	12,813	2,715	12,696	2,735	12,765	2,752	12,832



### 3. Forecast of Facilities Requirements

#### 3.1 Future Resource Needs

##### 3.1.1 Integrated Resource Planning Study

JEA began an IRP process in 2018 that was not complete as of the filing of this TYSP. This IRP is expected to be completed in draft form by summer 2019.

##### 3.1.2 Capacity Needs

JEA evaluates future supply capacity needs for the electric system based on peak demand and energy forecasts, existing supply resources and contracts, transmission considerations, existing unit capacity changes, and future committed resources as well as other planning assumptions.

The base capacity plan includes the addition of the purchased power agreement with MEAG for the Vogtle Units 3 and 4 and the purchased power agreement with Southern Power for combined cycle energy and capacity from Wansley. With these baseline assumptions, seasonal capacity purchases are needed in 2020 and 2021, see Table 4.

**Table 4a: Resource Needs after Committed Units - Summer**

Summer										
Year	Installed Capacity	Firm Capacity		QF	Available Capacity	Firm Peak Demand	Reserve Margin Before Maintenance		Reserve Margin After Maintenance	
		Import	Export				MW	Percent	MW	Percent
	MW	MW	MW	MW	MW	MW	MW	Percent	MW	Percent
2019	2,855	215	0	0	3,070	2,556	514	20%	514	20%
2020	2,855	15	0	0	2,870	2,567	304	12%	304	12%
2021	2,855	15	0	0	2,870	2,577	293	11%	293	11%
2022	2,855	115	0	0	2,970	2,588	382	15%	382	15%
2023	2,855	215	0	0	3,070	2,600	470	18%	470	18%
2024	2,855	215	0	0	3,070	2,610	460	18%	460	18%
2025	2,855	215	0	0	3,070	2,619	451	17%	451	17%
2026	2,855	215	0	0	3,070	2,627	443	17%	443	17%
2027	2,855	200	0	0	3,055	2,637	418	16%	418	16%
2028	2,855	200	0	0	3,055	2,649	406	15%	406	15%

**Table 4b:** Resource Needs after Committed Units - Winter

Winter										
Year	Installed Capacity	Firm Capacity		QF	Available Capacity	Firm Peak Demand	Reserve Margin Before Maintenance		Reserve Margin After Maintenance	
		Import	Export							
	MW	MW	MW	MW	MW	MW	MW	Percent	MW	Percent
2018/19	3,105	215	0	0	3,320	2,715	605	22%	605	22%
2019/20	3,138	15	0	0	3,153	2,735	417	15%	417	15%
2020/21	3,138	15	0	0	3,153	2,752	400	15%	400	15%
2021/22	3,138	115	0	0	3,253	2,768	484	17%	484	17%
2022/23	3,138	215	0	0	3,353	2,787	566	20%	566	20%
2023/24	3,138	215	0	0	3,353	2,802	550	20%	550	20%
2024/25	3,138	215	0	0	3,353	2,816	536	19%	536	19%
2025/26	3,138	215	0	0	3,353	2,832	521	18%	521	18%
2026/27	3,138	200	0	0	3,338	2,849	488	17%	488	17%
2027/28	3,138	200	0	0	3,338	2,869	468	16%	468	16%

**Note:** Committed capacity additions include Wansley in 2019 only and Vogtle Units 3 & 4 in November 2021 & 2022

JEA's Planning Reserve Policy defines the planning reserve requirements that are used to develop the resource portfolio through the Integrated Resource Planning process. These guidelines set forth the planning criteria relative to the planning reserve levels and the constraints of the resource portfolio.

JEA's system capacity is planned with a targeted 15 percent generation reserve level for forecasted wholesale and retail firm customer coincident one-hour peak demand, for both winter and summer seasons. This reserve level has been determined to be adequate to meet and exceed the industry standard Loss of Load Probability of 0.1 days per year. This level has been used by the Florida Public Service Commission (FPSC) for municipalities in the consideration of need for additional generation additions.

To meet these Planning Reserve Policy requirements, JEA will acquire the needed capacity and associated energy as identified in Table 4, for those years where the reserve margin is below 15 percent. JEA's Planning Reserve Policy establishes a guideline that provides an allowance to meet the 15 percent reserve margin with up to 3 percent of forecasted firm peak demand in any season from purchases acquired in the operating horizon. Where JEA's seasonal needs are greater than 3% of firm peak demand, TEA will acquire short-term seasonal market purchases for JEA no later than the season prior to the need. TEA actively trades energy with a large number of counterparties throughout the United States, and is generally able to acquire capacity and energy from other market participants when any of its members require additional resources.

### 3.2 Resource Plan

To develop the resource plan outlined in this TYSP submittal, JEA included a review of existing electric supply resources, forecasts of customer energy requirements and peak demands, forecasts of fuel prices and fuel availability, committed unit additions, existing capacity changes and annual and seasonal capacity purchase additions. All these factors considered collectively provide JEA with sufficient capacity to cover customer demand and reserves during this ten-year period. Table 5 presents the ten-year resource plan, which meets JEA's strategic goals. TYSP Schedules 5-10 provide further detail on this plan.

**Table 5:** Resource Plan

Year	Description
2019	SOCO Annual Contact (200 MW) <sup>(1)</sup>
	Brandy Branch CC Upgrade (84 MW Summer/ 33 MW Winter)
2020	TEA Purchase (100 MW Summer)
2021	MEAG Plant Vogtle 3 Purchase (100 MW) <sup>(2)</sup>
	TEA Purchase (25 MW Winter/100 MW Summer)
2022	MEAG Plant Vogtle 4 Purchase (100 MW) <sup>(2)</sup>
	TEA Purchase (25 MW Summer)
2023	
2024	
2025	
2026	
2027	Trail Ridge Contract Expires (-15 MW)
2028	

**Notes:**

<sup>(1)</sup> SOCO Annual purchase ends on 12/31/2019

<sup>(2)</sup> After accounting for transmission losses, JEA expects to receive 100 MW November 2021 and 100 MW November 2022 for a total of 200 MW of net firm capacity from the Vogtle units under construction.

<sup>(3)</sup> PEV addition of 1.85 MW Winter and 7.42 MW Summer by 2028.

<sup>(4)</sup> Cumulative DSM addition of 31 MW Winter and 40 MW Summer at time of peak by 2028.

## Schedule 5: Fuel Requirements

	(1)	(2)	(3)	(4)	(5)	(6)	(7)	(8)	(9)	(10)	(11)	(12)	(13)	(14)	(15)
	Fuel	Type	Units	Actual											
				2017	2018	2019	2020	2021	2022	2023	2024	2025	2026	2027	2028
(1)	<b>NUCLEAR</b>														
	<b>TOTAL</b>	<b>TRILLION BTU</b>		<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>
(2)	<b>COAL</b>														
	<b>TOTAL</b>	<b>1000 TON</b>		<b>2,568</b>	<b>1,733</b>	<b>2,181</b>	<b>1,953</b>	<b>1,953</b>	<b>1,992</b>	<b>1,685</b>	<b>1,777</b>	<b>1,821</b>	<b>1,814</b>	<b>1,791</b>	<b>2,064</b>
(3)	<b>RESIDUAL</b>														
	STEAM	1000 BBL		1	40	0	0	0	0	0	0	0	0	0	0
(4)	CC	1000 BBL		0	0	0	0	0	0	0	0	0	0	0	0
(5)	CT/GT	1000 BBL		0	0	0	0	0	0	0	0	0	0	0	0
(6)	<b>TOTAL</b>	<b>1000 BBL</b>		<b>1</b>	<b>40</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>
(7)	<b>DISTILLATE</b>														
	STEAM	1000 BBL		0.3	0.6	2.2	2.1	1.7	1.9	1.6	1.9	1.4	1.5	3.0	1.9
(8)	CC	1000 BBL		0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
(9)	CT/GT	1000 BBL		3.6	20.0	1.7	24.2	2.8	1.6	1.9	1.1	1.3	1.4	4.7	2.8
(10)	<b>TOTAL</b>	<b>1000 BBL</b>		<b>4</b>	<b>21</b>	<b>4</b>	<b>26</b>	<b>4</b>	<b>3</b>	<b>3</b>	<b>3</b>	<b>3</b>	<b>3</b>	<b>8</b>	<b>5</b>
(12)	<b>NATURAL GAS</b>														
	STEAM	1000 MCF		13,891	18,802	17,923	20,000	18,406	18,407	15,522	15,804	15,787	15,804	17,474	16,490
(13)	CC	1000 MCF		26,817	27,847	24,169	31,035	30,534	26,630	29,191	29,643	28,446	29,411	29,591	26,470
(14)	CT/GT	1000 MCF		3,864	6,248	3,814	5,042	3,584	4,364	3,698	3,099	3,378	2,931	3,908	5,425
(15)	<b>TOTAL</b>	<b>1000 MCF</b>		<b>44,572</b>	<b>52,897</b>	<b>45,906</b>	<b>56,077</b>	<b>52,523</b>	<b>49,401</b>	<b>48,411</b>	<b>48,546</b>	<b>47,611</b>	<b>48,146</b>	<b>50,973</b>	<b>48,385</b>
(16)	<b>OTHER (SPECIFY)</b>														
	<b>TOTAL</b>	<b>TRILLION BTU</b>		<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>

**Note:** Coal includes JEA's share of Scherer 4 and Northside Coal and Petroleum Coke.

Schedule 6.1: Energy Sources (GWh)

	(1)	(2)	(3)	(4)	(5)	(6)	(7)	(8)	(9)	(10)	(11)	(12)	(13)	(14)	(15)
	Fuel	Type	Units	Actual		2019	2020	2021	2022	2023	2024	2025	2026	2027	2028
				2017	2018										
(1)	Firm Inter-Region Intchg. <sup>(a)</sup>		GWH	1,439	2,485	1,588	318	442	1,047	1,672	1,619	1,611	1,668	1,613	1,615
(2)	NUCLEAR		GWH	0	0	0	0	0	0	0	0	0	0	0	0
(3)	COAL <sup>(b)</sup>		GWH	5,377	3,558	4,959	4,539	4,619	4,638	4,076	4,160	4,397	4,327	4,298	4,808
(4)		STEAM		0	24	0	0	0	0	0	0	0	0	0	0
(5)		CC		0	0	0	0	0	0	0	0	0	0	0	0
(6)		CT		0	0	0	0	0	0	0	0	0	0	0	0
(7)		RESIDUAL		TOTAL	GWH	0	24	0	0	0	0	0	0	0	0
(8)		STEAM		0	0	0	0	0	0	0	0	0	0	0	0
(9)		CC		0	0	0	0	0	0	0	0	0	0	0	0
(10)		CT		1	6	1	10	1	1	1	0	1	1	2	1
(11)	DISTILLATE	TOTAL	GWH	1	6	1	10	1	1	1	0	1	1	2	1
(12)	NATURAL GAS	STEAM		1,355	1,833	1,768	1,967	1,790	1,795	1,479	1,490	1,507	1,491	1,665	1,591
(13)		CC		4,012	4,152	3,819	4,912	4,832	4,207	4,602	4,682	4,490	4,641	4,672	4,179
(14)		CT		376	605	350	471	333	406	343	288	311	269	363	505
(15)		TOTAL		GWH	5,743	6,590	5,938	7,350	6,954	6,408	6,424	6,460	6,307	6,402	6,700
(16)	NUG		GWH	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
(17)	RENEWABLES	HYDRO LANDFILL GAS SOLAR		0	0	0	0	0	0	0	0	0	0	0	0
(18)				81	91	130	130	130	130	130	130	130	130	0	0
(19)				30	58	81	418	685	683	680	679	674	672	669	668
(20)				TOTAL	GWH	111	149	211	548	815	813	810	809	804	802
(21)	OTHER (SPECIFY)		GWH	0	0	0	0	0	0	0	0	0	0	0	0
(22)	NET ENERGY FOR LOAD <sup>(c)</sup>		GWH	12,672	12,813	12,696	12,765	12,832	12,907	12,982	13,048	13,120	13,199	13,282	13,366

**Note:** (a) Firm Inter-Regional Interchange includes Seasonal and Annual PPAs starting in 2018 and Nuclear PPA from MEAG starting in 2021.

(b) Coal includes JEA's share of Scherer 4, and Northside Coal and Petroleum Coke.

(c) May not add due to rounding.

Schedule 6.2: Energy Sources (Percent)

	(1)	(2)	(3)	(4)	(5)	(6)	(7)	(8)	(9)	(10)	(11)	(12)	(13)	(14)	(15)
	Fuel	Type	Units	Actual		2019	2020	2021	2022	2023	2024	2025	2026	2027	2028
				2017	2018										
(1)	Firm Inter-Region Intchg. <sup>(a)</sup>		%	11.4	19.4	12.5	2.5	3.4	8.1	12.9	12.4	12.3	12.6	12.1	12.1
(2)	NUCLEAR		%	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
(3)	COAL <sup>(b)</sup>		%	42.4	27.8	39.1	35.6	36.0	35.9	31.4	31.9	33.5	32.8	32.4	36.0
(4)		STEAM		0.0	0.2	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
(5)		CC		0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
(6)		CT		0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
(7)	RESIDUAL	TOTAL	%	0.0	0.2	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
(8)		STEAM		0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
(9)		CC		0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
(10)		CT		0.0	0.1	0.0	0.1	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
(11)	DISTILLATE	TOTAL	%	0.0	0.1	0.0	0.1	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
(12)		STEAM		10.7	14.3	13.9	15.4	13.9	13.9	11.4	11.4	11.5	11.3	12.5	11.9
(13)		CC		31.7	32.4	30.1	38.5	37.7	32.6	35.4	35.9	34.2	35.2	35.2	31.3
(14)		CT		3.0	4.7	2.8	3.7	2.6	3.1	2.6	2.2	2.4	2.0	2.7	3.8
(15)	NATURAL GAS	TOTAL	%	45.3	51.4	46.8	57.6	54.2	49.7	49.5	49.5	48.1	48.5	50.4	46.9
(16)	NUG		%	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
(17)	RENEWABLES	HYDRO		0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
(18)		LANDFILL GAS		0.6	0.7	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	0.0	0.0
(19)		SOLAR		0.2	0.5	0.6	3.3	5.3	5.3	5.2	5.2	5.1	5.1	5.0	5.0
(20)		TOTAL	%	0.9	1.2	1.7	4.3	6.4	6.3	6.2	6.2	6.1	6.1	5.0	5.0
(21)	OTHER (SPECIFY)		%	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
(22)	NET ENERGY FOR LOAD <sup>(c)</sup>		%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%

**Note:** <sup>(a)</sup> Firm Inter-Regional Interchange includes Seasonal and Annual PPAs starting in 2018 and Nuclear PPA from MEAG starting in 2021.

<sup>(b)</sup> Coal includes JEA's share of Scherer 4, and Northside Coal and Petroleum Coke.

<sup>(c)</sup> May not add due to rounding.

<sup>(d)</sup> JEA sells environmental credits for specified periods.

**Schedule 7.1:** Summer Forecast of Capacity, Demand, and Scheduled Maintenance  
at Time of Peak

Year	Installed Capacity	Firm Capacity		QF	Available Capacity	Firm Peak Demand	Reserve Margin Before Maintenance		Scheduled Maintenance	Reserve Margin After Maintenance	
		Import	Export								
	MW	MW	MW	MW	MW	MW	MW	Percent	MW	MW	Percent
2019	2,855	215	0	0	3,070	2,556	514	20%	0	514	20%
2020	2,855	115	0	0	2,970	2,567	404	16%	0	404	16%
2021	2,855	115	0	0	2,970	2,577	393	15%	0	393	15%
2022	2,855	140	0	0	2,995	2,588	407	16%	0	407	16%
2023	2,855	215	0	0	3,070	2,600	470	18%	0	470	18%
2024	2,855	215	0	0	3,070	2,610	460	18%	0	460	18%
2025	2,855	215	0	0	3,070	2,619	451	17%	0	451	17%
2026	2,855	215	0	0	3,070	2,627	443	17%	0	443	17%
2027	2,855	200	0	0	3,055	2,637	418	16%	0	418	16%
2028	2,855	200	0	0	3,055	2,649	406	15%	0	406	15%

**Schedule 7.2: Winter Forecast of Capacity, Demand, and Scheduled Maintenance**  
at Time of Peak

Year	Installed Capacity	Firm Capacity		QF	Available Capacity	Firm Peak Demand	Reserve Margin Before Maintenance		Scheduled Maintenance	Reserve Margin After Maintenance	
		Import	Export								
	MW	MW	MW	MW	MW	MW	MW	Percent	MW	MW	Percent
2019	3,105	215	0	0	3,320	2,715	605	22%	0	605	22%
2020	3,138	15	0	0	3,153	2,735	417	15%	0	417	15%
2021	3,138	40	0	0	3,178	2,752	425	15%	0	425	15%
2022	3,138	115	0	0	3,253	2,768	484	17%	0	484	17%
2023	3,138	215	0	0	3,353	2,787	566	20%	0	566	20%
2024	3,138	215	0	0	3,353	2,802	550	20%	0	550	20%
2025	3,138	215	0	0	3,353	2,816	536	19%	0	536	19%
2026	3,138	215	0	0	3,353	2,832	521	18%	0	521	18%
2027	3,138	200	0	0	3,338	2,849	488	17%	0	488	17%
2028	3,138	200	0	0	3,338	2,869	468	16%	0	468	16%



**Schedule 8:** Planned and Prospective Generating Facility Additions and Changes

Planned and Prospective Generating Facility and Purchased Power Additions and Changes														
(1)	(2)	(3)	(4)	(5)	(6)	(7)	(8)	(9)	(10)	(11)	(12)	(13)	(14)	(15)
Plant Name	Unit No.	Location	Unit Type	Fuel Type		Fuel Transport		Construction Start Date	Commercial/ In-Service or Change Date	Expected Retirement/ Shutdown Date	Gen Max Nameplate	Net Capability		Status
				Primary	Alternate	Primary	Alternate					Summer	Winter	
											kW	MW	MW	
Brandy Branch CT	2	12-031	CT	NG		PL		Feb-19	Apr-19	(a)	203800	42	16.5	In Progress
Brandy Branch CT	3	12-031	CT	NG	DFO	PL	TK	Mar-19	May-19	(a)	203800	42	16.5	In Progress

**Notes:**

(a) Units expected to be maintained throughout the TYSP period.

**Schedule 9: Status Report and Specifications of Proposed Generating Facilities***(2018 Dollars)*

<b>1</b>	<b>Plant Name and Unit Number:</b>	None to Report
<b>2</b>	<b>Capacity:</b>	
<b>3</b>	Summer MW	
<b>4</b>	Winter MW	
<b>5</b>	<b>Technology Type:</b>	
<b>6</b>	<b>Anticipated Construction Timing:</b>	
<b>7</b>	Field Construction Start-date:	
<b>8</b>	Commercial In-Service date:	
<b>9</b>	<b>Fuel:</b>	
<b>10</b>	Primary	
<b>11</b>	Alternate	
<b>12</b>	<b>Air Pollution Control Strategy:</b>	
<b>13</b>	<b>Cooling Method:</b>	
<b>14</b>	<b>Total Site Area:</b>	
<b>15</b>	<b>Construction Status:</b>	
<b>16</b>	<b>Certification Status:</b>	
<b>17</b>	<b>Status with Federal Agencies:</b>	
<b>18</b>	<b>Projected Unit Performance Data:</b>	
<b>19</b>	Planned Outage Factor (POF):	
<b>20</b>	Forced Outage Factor (FOF):	
<b>21</b>	Equivalent Availability Factor (EAF):	
<b>22</b>	Resulting Capacity Factor (%):	
<b>23</b>	Average Net Operating Heat Rate (ANOHR):	
<b>24</b>	<b>Projected Unit Financial Data:</b>	
<b>25</b>	Book Life:	
<b>26</b>	Total Installed Cost (In-Service year \$/kW):	
<b>27</b>	Direct Construction Cost (\$/kW):	
<b>28</b>	AFUDC Amount (\$/kW):	
<b>29</b>	Escalation (\$/kW):	
<b>30</b>	Fixed O&M (\$/kW-yr):	
<b>31</b>	Variable O&M (\$/MWh):	

**Schedule 10:** Status Report and Specification of Proposed Directly Associated Transmission Lines

1	Point of Origin and Termination	None To Report
2	Number of Lines	
3	Right of Way	
4	Line Length	
5	Voltage	
6	Anticipated Construction Time	
7	Anticipated Capital Investment	
8	Substations	
9	Participation with Other Utilities	

## 4. Other Planning Assumptions and Information

---

### 4.1 Fuel Price Forecast

JEA uses a diverse mix of fuels in its generating units. The fuel price projections include natural gas, coal, petroleum coke, uranium, residual fuel oil and diesel fuel.

The fuel price projections used in this forecast were developed based on long-term price forecasts from the Annual Energy Outlook 2018 (AEO2018) issued by the U.S. Energy Information Administration (EIA). The AEO2018, presents projections of energy supply, demand, and prices through 2050. AEO2018 projections are based on results from the EIA's National Energy Modeling System (NEMS). NEMS is a computer based energy-economy modeling system of U.S. energy markets. NEMS projects the production, imports, conversion, consumption, and prices of energy, subject to a variety of assumptions related to macroeconomic and financial factors, world energy markets, resource availability and costs, behavioral and technological choice criteria, technology characteristics, and demographics.

Scherer 4 burns Powder River Basin (PRB) coal. Projections of the commodity price for PRB coal are based on existing coal contracts through 2022 and then escalated using AEO2018 projections for PRB coal. The transportation component of the delivered price projection was derived from existing contracts and escalated by an inflation rate of 2.0% thereafter. The inflation rate of 2.0% originates from the AEO2018.

Northside units 1 and 2 currently burn a blend of petroleum coke and coal. These units are projected to burn 60 percent petroleum coke and 40 percent coal during the forecast period. The Northside coal price projections are based on short-term NYMEX API2 Argus-McCloskey coal futures and then escalated using AEO2018 projections for Central Appalachian coal. Current freight rates for 2019 waterborne delivery of Colombian coal were escalated using the AEO2018 inflation rate to project transportation costs beyond 2019. A three year historical petroleum coke to coal price ratio applied to the delivered Northside coal price projections was used to derive the petroleum coke price.

JEA currently operates eight units utilizing natural gas as a primary fuel. These units are GEC GT1 and GT2, Brandy Branch GT1, CT2 and CT3, Northside 3, and Kennedy GT7 and GT8. The natural gas price projection was based on the current short-term NYMEX strip and then escalated using AEO2018 Henry Hub price forecast. The transportation costs are a combination of historical Florida city gate market costs on Florida Gas Transmission and local distribution fees.

The 1970's-vintage combustion turbine units at Northside Generating Station (GT3, GT4, GT5, and GT6) burn diesel fuel as the primary fuel type. Five JEA units utilize diesel fuel as an alternative to natural gas: Kennedy GT7 and GT8, GEC GT1 and GT2, and Brandy Branch GT1. Projections for the price of diesel fuel are based on short-term NYMEX ultra-low sulfur diesel futures pricing and then escalated using AEO2018 projections for ultra-low sulfur diesel.

JEA has a purchase power agreement with MEAG for 200MW from Vogtle Units 3 and 4 currently under construction in Georgia with planned in-service dates of 2021 and 2022. The fuel price forecast accounts for the costs of mine-mouth uranium, enrichment and fabrication.

## **4.2 Economic Parameters**

This section presents the parameters and methodology used for economic evaluations as part of JEA's least-cost expansion plan to satisfy forecast capacity requirements throughout the TYSP period.

### **4.2.1 Inflation and Escalation Rates**

The general inflation rate, construction cost escalation rate, fixed O&M escalation rate, and nonfuel variable O&M escalation rate are each assumed to be 2.0 percent.

### **4.2.2 Municipal Bond Interest Rate**

JEA performs sensitivity assessments of project cost to test the robustness of JEA's resource plan. Project cost includes forecast of direct cost of construction, indirect cost, and financing cost. Financing cost includes the forecast of long term tax exempt municipal bond rates, issuance cost, and insurance cost. For JEA's plan development, the long term tax exempt municipal bond rate is assumed to be 4.50 percent. This rate is based on JEA's judgment and expectation that the long term financial markets will return to historical stable behavior under more stable economic conditions.

### **4.2.3 Present Worth Discount Rate**

The present worth discount rate is assumed to be equal to the tax exempt municipal bond interest rate of 4.50 percent.

### **4.2.4 Interest During Construction Interest Rate**

The interest during construction rate, or IDC, is assumed to be 4.50 percent.

### **4.2.5 Levelized Fixed Charge Rate**

The fixed charge rate (FCR) represents the sum of a project's fixed charges as a percent of the initial investment cost. When the FCR is applied to the initial investment, the product equals the revenue requirements needed to offset the fixed charges during a given year. A separate FCR can be calculated and applied to each year of an economic analysis, but it is common practice to use a single, levelized FCR (LFCR) that has the same present value as the year-by-year fixed charge rate.

Different generating technologies are assumed to have different economic lives and therefore different financing terms. Simple cycle combustion turbines are assumed to have a 20 year

financing term; while natural gas fired combined cycle units are assumed to be financed over 25 years. Given the various economic lives and corresponding financing terms, different LFCRs were developed.

All LFCR calculations assume the 4.50 percent tax exempt municipal bond interest rate, a 1.00 percent bond issuance fee, and a 0.50 percent annual property insurance cost. The resulting 20 year fixed charge rate is 8.265 percent and the 25 year fixed charge rate is 7.312 percent.

## **5. Environmental and Land Use Information**

---

JEA does not have any capacity build projects underway or planned for the term of this Ten Year Site Plan. Therefore, there are no potential sites in which to report environmental and land use information.