



April 1, 2022

Office of Commission Clerk
Florida Public Service Commission
2540 Shumard Oak Boulevard
Tallahassee, Florida 32399-0850
Attn: Adam Teitzman

Re: 2022 Ten Year Site Plan

Dear Mr. Teitzman,

Pursuant to Section 186.801, Florida Statutes and Rules 25-22.070-072 of Florida Administrative Code, Lakeland Electric submits its 2022 Ten Year Site Plan via the Commissions electronic platform.

If you have questions please contact me at 863-834-6595.

Sincerely,

/s/Cynthia Clemmons

Cynthia Clemmons
City of Lakeland
Manager of Legislative and Regulatory Relations
Lakeland Electric
863-834-6595 Work
Cindy.Clemmons@LakelandElectric.com
501 E Lemon St.
Lakeland, Florida 33801

Enclosure

Intentionally Blank

Lakeland Electric

Ten-Year Site Plan 2022-2031

April 2022

Submitted to:

Florida Public Service Commission



Intentionally Blank

Table of Contents

1.0 Introduction.....	1-1
1.1 General Description of the Utility.....	1-1
1.2 Forecast of Electrical Demand and Energy	1-2
1.3 Energy Conservation & Management Programs	1-2
1.4 Forecasting Methods and Procedures	1-3
1.5 Forecast of New Capacity Requirements.....	1-3
1.6 Environmental and Land Use Information	1-4
1.7 Ten-Year Site Plan Schedules.....	1-4
 2.0 General Description of the Utility.....	 2-1
2.1 City of Lakeland Historical Background	2-1
2.1.1 Generation.....	2-1
2.1.2 Transmission	2-3
2.2 General Description: Lakeland Electric.....	2-5
2.2.1 Existing Generating Units.....	2-5
2.2.2 Capacity and Power Sales Contracts.....	2-7
2.2.3 Capacity and Power Purchase Contracts.....	2-7
2.2.4 Planned Unit Retirements	2-7
2.2.5 Load and Electrical Characteristics	2-7
2.3 Service Area.....	2-8
Table 2-1 Existing Generation Facilities	2-9
Table 2-1a Existing Generation Facilities.....	2-10
Figure 2-1 Service Territory Map	2-11
 3.0 Forecast of Electric Demand and Energy	 3-1
3.1 Service Territory Population Forecast	3-3
3.2 Account Forecasts.....	3-4
3.2.1 Residential Accounts	3-4
3.2.2 Commercial Accounts.....	3-4
3.2.3 Industrial Accounts	3-4
3.2.4 Other Accounts	3-5
3.2.5 Total Accounts Forecast	3-5
3.3 Energy Sales Forecast.....	3-5
3.3.1 Residential Energy Sales Forecast.....	3-6
3.3.2 Commercial Energy Sales.....	3-8
3.3.3 Industrial Energy Sales.....	3-10

Table of Contents (Continued)

3.3.4 Other Sales Forecast	3-10
3.3.5 Total Sales Forecast	3-11
3.4 Net Energy for Load Forecast.....	3-11
3.5 Peak Demand Forecast.....	3-11
3.6 Hourly Load Forecast	3-12
3.7 Sensitivities Cases.....	3-12
3.7.1 High & Low Load Forecast Scenarios.....	3-12
4.0 Energy Conservation & Management Programs	4-1
4.1 Conservation Programs 2021	4-1
4.2 Solar Program Activities.....	4-2
4.2.1 Utility Interactive Net Metered Photovoltaic Systems	4-2
4.2.2 Utility Scale Solar PV Program	4-2
4.2.3 Utility Solar Water Heating Program	4-3
4.2.4 Renewable Energy Credit Trading.....	4-4
5.0 Forecasting Method and Procedures.....	5-1
5.1 Integrated Resource Plan	5-1
5.2 Florida Municipal Power Pool	5-1
5.3 Economic Parameters.....	5-2
5.3.1 Inflation Rate	5-2
5.3.2 Bond Interest Rate.....	5-2
5.3.3 Present Worth Discount Rate.....	5-2
5.3.4 Interest During Construction.....	5-2
5.3.5 Fixed Charge Rate.....	5-2
5.4 Fuel Parameters.....	5-3
5.4.1 Natural Gas	5-3
5.4.2 Coal	5-6
5.4.3 Fuel Oil	5-7
5.4.4 Fuel Price Projections	5-7
5.4.5 Fuel Forecast Sensitivities	5-9

Table of Contents (Continued)

6.0 Forecast of New Capacity Requirements.....	6-1
6.1 Assessment of the Need for Capacity and Energy.....	6-1
6.1.1 Load Forecast.....	6-1
6.1.2 Reserve Requirements	6-1
6.1.3 Existing Generation and Retirements	6-2
6.2 Seasonal Capacity and Reserve Margins.....	6-3
6.3 Energy Resources and Analysis	6-3
6.4 Summary Study Results	6-4
Table 6-1 Projected Reliability Levels - Winter	6-5
Table 6-2 Projected Reliability Levels - Summer.....	6-5
Table 6-3 Energy Resources Mix	6-6
7.0 Environmental and Land Use Information	7-1
Table 7-1 Emission Control Options in Major LE Units.....	7-2
Figure 7-1 McIntosh Plant Topographic Map	7-3
Figure 7-2 City of Lakeland Zoning Map.....	7-4
Figure 7-3 McIntosh Solar Plant Site - Topological Map.....	7-5
Figure 7-4 Site Location - McIntosh Solar	7-6
Figure 7-5 Site Location of 120 MW RICE Engines.....	7-7
Figure 7-6 Site Location of 120 MW RICE Engines in McIntosh Plant	7-8
8.0 Ten -Year Site Plan Schedules.....	8-1
Table 8-1 Schedule 1.0 Existing Generation	8-2
Table 8-1a Schedule 1.0 Existing Generation.....	8-3
Table 8-2 Schedule 2.1 Energy Consumption & Number of Customers.....	8-4
Table 8-3 Schedule 2.2 Energy Consumption & Number of Customers.....	8-5
Table 8-4 Schedule 2.3 Energy Consumption & Number of Customers.....	8-6
Table 8-5 Schedule 3.1 Summer Peak Demand Base Case	8-7
Table 8-5a Schedule 3.1a Summer Peak Demand Low Case	8-8
Table 8-5b Schedule 3.1b Summer Peak Demand High Case.....	8-9
Table 8-6 Schedule 3.2 Winter Peak Demand Base Case	8-10
Table 8-6a Schedule 3.2a Winter Peak Demand Low Case	8-11
Table 8-6b Schedule 3.2b Winter Peak Demand High Case	8-12

Table 8-7 Schedule 3.3 Annual Net Energy for Load Base Case.....	8-13
Table 8-7a Schedule 3.3a Annual Net Energy for Load Low Case.....	8-14
Table 8-7b Schedule 3.3b Annual Net Energy for Load High Case.....	8-15
Table 8-8 Schedule 4 Peak Demand and Net Energy by Month	8-16
Table 8-9 Schedule 5 Fuel Requirements	8-17
Table 8-10 Schedule 6.1 Energy Sources (GWhs)	8-18
Table 8-11 Schedule 6.2 Energy Sources (%)	8-19
Table 8-12 Schedule 7.1 Capacity, Demand, at Summer Peak	8-20
Table 8-13 Schedule 7.2 Capacity, Demand, at Winter Peak.....	8-21
Table 8-14 Schedule 8.0 Planned & Prospective Generation	8-22
Table 8-15 Schedule 9.1 Status Report of Approved Generation.....	8-23
Table 8-15 Schedule 9.2 Status Report of Approved Generation.....	8-24
Table 8-16 Schedule 9.2 Status Report of Proposed Transmission	8-25
8.1 List of Abbreviations and Descriptions	8-26

1.0 Introduction [SECTION 1]

This report contains the 2022 Lakeland Electric (LE) Ten-Year Site Plan (TYSP) pursuant to Florida Statutes and as adopted by Order No. PSC-97-1373-FOF-EU on October 30, 1997. The TYSP is a comprehensive plan how LE can provide low cost, reliable, and clean energy to its customers to foster economic development in Lakeland for the next 10 years. TYSPs are non-binding in Florida, but they do provide state, regional, and local agencies a notice of proposed plants and transmission facilities in near future.

The TYSP 2022 is divided into the following eight sections:

- Section 1: Introduction
- Section 2: General Description of Utility
- Section 3: Forecast of Electric Demand and Energy
- Section 4: Energy Conservation & Management Programs
- Section 5: Forecasting Methods and Procedures
- Section 6: Forecast of New Capacity Requirements
- Section 7: Environmental and Land Use Information
- Section 8 Ten-Year Site Plan Schedules

The contents of each section are summarized in the remainder of this Introduction.

1.1 General Description of the Utility [SECTION 2]

Section 2 of the TYSP discusses a historical overview of Lakeland Electric's system and a description of the existing power generating and transmission system. This section includes tables which show the source of the utility's current 715 MW of net winter generating capacity and 647 MW of net summer generating capacity (as of the end of year 2021). To increase grid reliability and energy supply, LE plans to add 120 MW of gas based modular generating units by the end of 2023. This will bring LE's total amount of net installed capacity of 835 MW and 780 MW in winter and summer. This action will help to accelerate the deployment of additional 50 MW of solar energy in near future.

1.2 Forecast of Electric Demand and Energy [SECTION 3]

Section 3 of the TYSP provides a summary of Lakeland's electric load and energy forecast. LE uses statistical and mathematical models that link electricity usage to several key input parameters such as region's economic activity, population growth, demographic data, and energy efficiency characteristics on electrical appliances. Forecasts included in this section are on population, customer classes, energy sales, net energy requirement, and system peak demand in an hourly basis in its service territory. In addition, sensitivity cases on high and low cases are developed on energy sales to customers, system net energy and peak load requirements for LE's customers.

1.3 Energy Conservation & Management Programs [SECTION 4]

Section 4 provides the description of the existing energy conservation & management programs as adopted by Lakeland Electric. Additional details regarding Lakeland Electric's energy conservation & management programs are on file with the Florida Public Service Commission (FPSC).

Lakeland Electric's existing energy conservation and management programs include the following programs which promote cost-effective measures for both electric demand and energy savings, especially during peak hours:

- Residential Programs:
 - Insulation rebate
 - Energy Savings Kits
 - HVAC Maintenance Incentive
 - Heat Pump Rebates
 - LED Lighting
 - On-Line Energy Audit
 - Energy Star Appliance Rebate
- Commercial Programs:
 - Conservation Rebate
 - Commercial Lighting Rebate
- Transportation Programs:

– Rebate on Electric Vehicle Purchase

Section 4 also contains discussions on Lakeland Electric’s solar programs. While these types of programs are not traditionally thought of as DSM, they have the same effect of conserving energy normally generated by fossil fuels as DSM programs do by virtue of their avoidance of fossil fuels through the use of renewable energy. Lakeland Electric has capacity to generate more than 14 MW of power from solar, enough to supply power for more than 7,000 households during a sunny day in the summer. Lakeland Electric is determined to continuously increase the solar power for its customers with additional utility scale solar and customer’s roof top solar.

1.4 Forecasting Methods and Procedures [SECTION 5]

Forecasting long-term electric load and energy is the first step in planning future generation. Based on future energy requirements, Lakeland Electric coordinates and manages its existing resources to meet the future energy requirements at the lowest cost possible for its customers.

Section 5 summarizes the Integrated Resource Planning process utilized by Lakeland Electric and explains Lakeland Electric’s participation in the Florida Municipal Power Pool (FMPP).

While Section 3 discusses the forecast, methods used for the TYSP, Section 5 outlines the economic and fuel assumptions applied to planning capacity and energy in the future.

1.5 Forecast of New Capacity Requirements [SECTION 6]

Section 6 describes the process Lakeland Electric uses to assess the need for additional capacity to serve Lakeland Electric’s customers. This section concludes by stating that Lakeland Electric plan to keep Reserve Margins at or greater than 15% during the current ten-year planning period and complies with the Florida Reliability Coordinating Council’s (FRCC) minimum reserve margin criteria for the FRCC Region.

1.6 Environmental and Land Use Information [SECTION 7]

Section 7 addresses environmental and land use issues related to Lakeland Electric's recently planned 120 MW new Reciprocating Internal Combustion Engines (RICE) to be available in early 2024 at Lakeland Electric's McIntosh Power Plant (see Table 7-1). This section also provides Table 7-2 which summarizes different control strategies adopted to comply with various environmental emissions for existing major generating units. Also analyzed are the issues related to land use air permits to build 16 MW of solar generation in the McIntosh Power Plant site.

1.7 Ten-Year Site Plan Schedules [SECTION 8]

Section 8 presents the schedules of new generation and any retirements including any power purchase necessary required by the Florida Public Service Commission (FPSC) for the TYSP.

Tables 8-1 and 8-1a summarize the detailed information on existing generating units owned by Lakeland Electric. Tables 8-2 through 8-5 provide information by customer class. Tables 8-2 through 8-8 provide demand and energy history and forecasts. Table 8-9 provides a history and forecast of fuel requirements by fuel type. Tables 8-10 and 8-11 provide a history and forecast of energy produced by fuel type. Tables 8-12 and 8-13 provide comparisons of Lakeland Electric resources to Lakeland Electric demand. These tables demonstrate that Lakeland Electric's expected Reserve Margin exceeds 15% in each year in winter during this planning period. However, LE may need to have some capacity purchase necessary to meet the reserve margin of 15% in summer. Tables 8-14 provides information related to Lakeland Electric's planned new generating units and any changes/modifications on existing units.

2.0 General Description of the Utility

2.1 City of Lakeland: Historical Background

2.1.1 Generation

The City of Lakeland was incorporated on January 1, 1885, when 27 citizens approved and signed the city charter. Shortly thereafter, the original light plant was built by Lakeland Light and Power Company at the corner of Cedar Street and Massachusetts Avenue. This plant had an original capacity of 50 kW. On May 26, 1891, plant manager Harry Sloan threw the switch to light Lakeland by electricity for the first time with five arc lamps. Incandescent lights were first installed in 1903.

Public power in Lakeland was established in 1904, when foresighted citizens and municipal officials purchased the small private 50 kW electric light plant from owner Bruce Neff for \$7,500. The need for an expansion led to the construction of a new power plant on the north side of Lake Mirror in 1916. The initial capacity of the Lake Mirror Power Plant was 500 kW. The plant was expanded three times. The first expansion occurred in 1922 with the addition of 2,500 kW; in 1925, 5,000 kW additional capacity was added, followed by another 5,000 kW in 1938. With the final expansion, the removal of the initial 500 kW unit was required to make room for the addition of the 5,000 kW generating unit, resulting in a total peak plant capacity of 12,500 kW.

As the community continued to grow, the need for a new power plant emerged and the Charles Larsen Memorial Power Plant was constructed on the south-east shore of Lake Parker in 1949. The initial capacity of the Larsen Plant Steam was Unit No. 4 (20,000kW) and it was completed in 1950. The first addition to the Larsen Plant was Steam Unit No. 5 (1956) which had a capacity of 25,000 kW. In 1959, Steam Unit No. 6 was added and increased the plant capacity by another 25,000 kW. Three gas turbines, each with a nominal rating of 11,250 kW, were installed as peaking units in 1962. In 1966, a third steam unit capacity addition was made to the Larsen Plant. This was Steam Unit No.7 having a nominal 44,000 kW capacity and an estimated cost of \$9.6 million. This brought the total Larsen Plant nameplate capacity up to a nominal 147,750 kW.

In the meantime, the Lake Mirror Plant, with its old and obsolete equipment, became relatively inefficient and hence was no longer in active use. It was kept in cold standby and then retired in 1971.

As the city continued to grow during the late 1960's, the demand for power and energy grew at a rapid rate, making evident the need for a new power plant site. A site was purchased on the north

side of Lake Parker and construction commenced during 1970. Initially, two diesel units with a peaking capacity of a nominal rating 2,500 kW each were placed into commercial operation in 1970.

Steam Unit No. 1, with a nominal rating of 90 MW, was put into commercial operation in February 1971, for a total cost of \$15.22 million. In June of 1976, Steam Unit No. 2 was placed into commercial operation, with a nominal rated capacity of 115 MW and at a cost of \$25.77 million. This addition increased the total capacity of the Lakeland system to approximately 360 MW. At this time, the new plant site on the north shore of Lake Parker was renamed the C. D. McIntosh, Jr. Power Plant in recognition of the former Electric and Water Department Director.

On January 2, 1979, construction was started on McIntosh Unit No. 3, a nominal 334 MW coal fired steam generating unit which became commercial on September 1, 1982. The unit was designed to use low sulfur oil as an alternate fuel, but this feature was later decommissioned. McIntosh Unit No. 3 was later modified so that its nominal gross output was increased to 365 MW. The unit used a minimal amount of natural gas for flame stabilization during startups. The plant utilized sewage effluent for cooling tower makeup water. This unit was jointly owned with the Orlando Utilities Commission (OUC) which has a 40 percent undivided interest in the unit.

Larsen Unit No. 8, a natural gas fired combined cycle unit 8 has a nameplate generating capacity of 131.5 MW at present. Larsen Unit No. 8 began its simple cycle operation in July 1992, and combined cycle operation in November of that year. A new fogger system is planned for summer operations in 2022, which will provide an additional 3 MWs of summer capacity. A new Peak Fire controls system is planned to be commissioned by the end of 2022, which will add 3 MWs of year-round capacity.

In 1994, Lakeland made the decision to retire the first unit at the Larsen Plant, Steam Unit No. 4. This unit, put in service in 1950 with a capacity of 20 MW, had reached the end of its economic life. In March of 1997, Lakeland retired Larsen Unit No. 6, a 25 MW oil fired unit that was also nearing the end of its economic life. In October of 2004, Lakeland retired Larsen Unit 7, a 50 MW oil fired steam unit.

In 1999, the construction of McIntosh Unit No. 5, a simple cycle, natural gas fired combustion turbine was completed, having a summer nominal capacity of 225 MW. The unit was released for commercial operation in May 2001. Beginning in September 2001, the unit underwent conversion to a combined cycle unit through the addition of a nominal 120 MW steam turbine generator. Construction was completed in spring 2002 with the unit being declared commercial in May 2002. The resulting combined cycle gross capacity of the unit is 345 MW summer and 360 MW winter. In December of 2020, Unit No. 5 went through a major outage to install “NextGen Hardware” that

increased the capacity of the combined cycle to 339 MW (net 332 MW) in summer and 385 MW (net 378 MW in winter. Addition of Steam Power Augmentation (SPAG) increased the capacity to 349 MW (net 342 MW) in summer and 395 MW (net 388 MW) in winter. The final capacity was made achievable to 360 MW in summer and 405 MW in winter with SPAG and Flex Fire combined.

During the summer of 2001, Lakeland took its first step into the world of distributed generation with the groundbreaking of its Winston Peaking Station. The Winston Peaking Station consists of 20 quick start reciprocating internal combustion engines each driving a 2.5 MW electric generator. This provides Lakeland with 50 MW of peaking capacity that can be started and put online at full load in ten minutes. The Station went in commercial operation in December 2001.

McIntosh Gas Turbine No. 2 at the McIntosh Plant was online on June 22, 2022. This unit has gross ratings of 125 (120) MW in winter (summer). McIntosh Unit No. 3 (a coal unit) was retired from its operations on April 4, 2021. This unit had been in operation since 1982. The decision to retire this unit was made possible due to significant savings realized on fuel and operation cost compared to energy from natural gas-based generation. While ensuring that LE's capability grow and changes with time to supply low cost and environmentally friendly electricity to its customers, LE decided to build six(6) new small modular reciprocating internal combustion engines (RICE) in McIntosh power plant. Each unit will be capable of producing 20 MWs in less than 10-minutes for a total of 120 MWs in total. This enhanced flexibility of these units will help to firm up the energy variability of solar units being planned in Lakeland's territory in the near future. This plant is expected to be commercially available for operations by the 1st Quarter of 2024. At the same time, LE is expected to operate more than 50 MW of solar generating units by 2025.

2.1.2 Transmission

The first phase of the Lakeland 69 kV transmission system was placed in operation in 1961 with a step-down transformer at the Lake Mirror Plant to feed the 4 kV bus, nine 4 kV feeders, and a new substation in the southwest section of the town with two step-down transformers feeding four 12 kV feeders.

In 1966, a 69 kV line was completed from the North west substation to the Southwest substation, completing the loop around the town. At the same time, the old tie to Bartow was reinsulated for a 69 kV line and went into operation, feeding a new step-down substation in Highland City with four 12 kV feeders. In addition, a 69 kV line was completed from Larsen Plant around the South east section of the town to the Southwest substation. By 1972, 20 sections of 69 kV lines, feeding a total of nine step-down substations, with a total of 41 distribution feeders, were completed and placed

in service. By the fall of 1996, all the original 4 kV equipment and feeders had been replaced and/or upgraded to 12 kV service. By 1998, 29 sections of 69 kV lines were in service feeding 20 distribution substations.

As the Lakeland system continued to grow, the need for additional and larger transmission facilities grew as well. In 1981, Lakeland's first 230 kV facilities went into service to accommodate Lakeland's McIntosh Unit No. 3 and to tie Lakeland into the State transmission grid at the 230 kV

level. A 230 kV line was built from McIntosh Plant to Lakeland's West substation. A 230/69 kV autotransformer was installed at each of those substations to tie the 69 kV and 230 kV transmission systems together. In 1988, a second 230 kV line was constructed from the McIntosh Plant to Lakeland's Eaton Park substation along with a 230/69 kV autotransformer at Eaton Park. That line was the next phase of the long-range goal to electrically circle the Lakeland service territory with 230 kV transmission to serve as the primary backbone of the system.

In 1999, Lakeland added a generation unit at its McIntosh Power Plant that resulted in a new 230/69/12kV substation being built and energized in March of that year. The Tenoroc substation replaced the switching station called North McIntosh. In addition to Tenoroc, another new 230/69/12kV substation was built. The substation, Interstate, went into operation in June of 1999 and is connected by what was the McIntosh West 230 kV line. This station was built to address concerns on load growth in the areas adjacent to the I-4 corridor which were causing problems at both the 69kV and distribution levels in this area.

In 2001, Lakeland began its next phase of its 230kV transmission system with the construction of the Crews Lake 230/69kV substation. The substation was completed and placed in service in 2001. This project includes two 230kV ties and one 69kV tie with Tampa Electric Company (TECO), a 150MVA 230/69kV autotransformer and a 230kV line from Lakeland's Eaton Park 230kV substation to the Crews Lake substation.

Early transmission interconnections with other systems included a 69 kV tie at Larsen Plant with TECO, was established in mid-1960s. A second tie with TECO was later established at Lakeland's Highland City substation. A 115 kV tie was established in the 1970s with Progress Energy of Florida (PEF), now Duke Energy Florida (DEF) and Lakeland's West substation and was subsequently upgraded and replaced with the current two 230 kV lines to PEF in 1981. At the same time, Lakeland was interconnected with the OUC at Lakeland's McIntosh Power Plant. In August 1987, the 69 kV TECO tie at Larsen Power Plant was taken out of service and a new 69 kV TECO tie was put in service connecting Lakeland's Orangedale substation to TECO's Polk City substation. In mid-1994, a new

69 kV line was energized connecting Larsen Plant to the Ridge Generating Station (Ridge), an independent power producer. Lakeland had a 30-year firm power-wheeling contract with Ridge to wheel up to 40 MW of their power to DEF. In early 1996, a new substation, East, was installed in the Larsen Plant to the Ridge 69 kV transmission line. However, as of January 31, 2019, Ridge Generating Station was permanently shut down. As a result, the 69 kV East to Ridge tie line is no longer in use. Later in 1996, the third tie line to TECO was built from East to TECO's Gapway substation. As mentioned above, in August of 2001, Lakeland completed two 230 kV ties and one 69 kV tie with TECO at Lakeland's Crews Lake substation. The multiple 230 kV interconnection configuration of Lakeland is also tied into the bulk transmission grid and provides access to the 500 kV transmission network via DEF, providing greater reliability. At present, Lakeland has a total of about 128 miles of 69 kV and 28 miles of 230 kV transmission lines in service along with six 150 MVA 230/69 kV autotransformers. In 2020, Lakeland added a 150 MVA 69/13.8 KV auto transformer to connect the recently installed McIntosh Gas Turbine No. 2 into the Distribution System. In order to accommodate the rising electric demand in the northern part of the service area, LE is building a brand new 69 KV sub-station in Bridgewater.

2.2 General Description: Lakeland Electric

2.2.1 Existing Generating Units

This section provides additional detail on Lakeland Electric's existing generating plants. Lakeland Electric's existing generating units are located at two different plant sites: Charles Larsen Memorial (Larsen) and C.D. McIntosh Jr. (McIntosh). Both plant sites are located at Lake Parker in Polk County, Florida. The two plants have multiple units with different technologies and fuel types. Table 2-1 provides technical and other general characteristics of all Lakeland Electric generating units.

The Larsen site is located on the south east shore of Lake Parker in Lakeland. The site has three units. Larsen Unit 8 (CC) has a net winter (summer) capacity of 121 MW (106 MW). The Unit's combustion turbine has a net winter (summer) rating of 93 MW (78 MW).

Larsen Units 2 and 3, General Electric combustion turbines, have a combined net winter (summer) rating of 27 MW (19 MW). The units burn natural gas as the primary fuel with diesel as the backup. These two units are temporarily out of service for major maintenance.

Historically, Larsen Unit No. 5 consisted of a boiler for steam generation and steam turbine generator to convert the steam to electrical power. When the boiler began to show signs of degradation beyond economical repair, a gas turbine with a heat recovery steam generator, Larsen Unit No. 8, was

added to the facility. This allowed the gas turbine (Larsen Unit No. 8) to generate electricity and the waste heat from the gas turbine to repower the former Larsen Unit No. 5 steam turbine in a combined cycle configuration.

The McIntosh site is located in the City of Lakeland along the northeastern shore of Lake Parker and encompasses 513 acres. Electricity generated by the McIntosh units is stepped up in voltage by generator step-up transformers to 69 kV and 230 kV for transmission via the power grid. The McIntosh site currently includes six (6) units in commercial operation having a total net winter (summer) rating of 715 MW (647 MW).

McIntosh Gas Turbine 1 consists of a General Electric combustion turbine with a net winter (summer) output rating of 19 MW (17 MW). Whereas Gas Turbine No. 2 has a total net winter (summer) capacity of 122 MW (117 MW) and was installed in the summer of 2020.

McIntosh Unit No. 3 - a net 342 MW size pulverized coal fired steam unit was owned 60 percent by Lakeland Electric and 40 percent by the OUC. Unit 3 was retired on April 4, 2021. The decommissioning of this unit along with previously retired units 1 and 2 at Macintosh Plant is scheduled to take place by 2024. Two small internal combustion engines with a net output of 2.5 MW each are also located at the McIntosh site, and will remain at the site.

McIntosh Unit No. 5, a Siemens 501G combined cycle unit, was initially built and operated as a simple cycle combustion turbine that was placed into commercial operation in May 2001. The unit was taken out of service for conversion to combined cycle starting in mid-September 2001 and was returned to commercial service in May 2002 as a combined cycle unit with a net winter (summer) rating of 354 MW (338 MW). The unit is equipped with Selective Catalytic Reduction (SCR) for NO_x control. In December of 2020, Unit 5 went through a major outage, with Siemens' Next Gen Hardware, that increased the capacity of the combined cycle to 339 MW (net 332 MW) summer and 385 MW (net 378 MW) winter; the capacity with Steam Power Augmentation (SPAG) to 349 MW (net 342 MW) in summer and 395 MW (net 378 MW) in winter; and capacity with SPAG and Flex Fire to 359 MW (net 352 MW) summer and 405 MW (net 398 MW) winter.

Lakeland Electric constructed 50 MW peaking units adjacent to its Winston Substation in 2001. The purpose of the peaking plant is to provide additional quick start generation capability for Lakeland's changing system demand and during the times of high demand assuring extra reliability in Lakeland's System operation. The Winston station consists of twenty (20) cylinder RICE engines producing 2.5 MW of generation each. Altogether, the 20 diesel engines provide 50 MW of installed Capacity. The units are currently fueled by #2 fuel oil but have the capability to burn a mix of 5% by #2 oil and 95% natural gas. Lakeland Electric currently does not have natural gas service to the site.

The plant has remote start/run capability for extreme emergencies at times when the plant is unmanned. The station does not use open cooling towers. This results in minimal water or wastewater requirements.

The engines are equipped with hospital grade noise suppression equipment on the exhausts. Emission control is achieved by Selective Catalytic Reduction (SCR) using 19% aqueous ammonia. The SCR system will allow the plant to operate within the Minor New Source levels permitted by the Florida Department of Environmental Protection (DEP).

Winston Peaking Station (WPS) was constructed adjacent to Lakeland's Winston Distribution Load Substation. Power generated at WPS goes directly into Winston Substation at 12.47 kV distribution level of the substation and has sufficient capacity to serve the substation loads. Winston Substation serves several of Lakeland Electric's largest and most critical accounts. Should the Winston Substation lose all three 69 kV circuits to the substation, the WPS can be online and serving load within ten minutes. In addition to increasing the substation's reliability, this arrangement allows Lakeland to delay the installation of a third 69kV to 12.47kV transformer by several years and contributes to lowering loads on Lakeland's transmission system.

2.2.2 Capacity and Power Purchase Contracts

After the retirement of coal unit No. 3 on April 4, 2021, Lakeland Electric entered a firm long-term power purchase contract that started from April 1, 2021 and is expected to retire in late 2023 or early 2024 when new RICE engines becomes available. Lakeland Electric anticipates having capacity and energy contracts with neighboring utilities and other pool members on an as needed basis when the major units are on planned/forced outages. LE is negotiating for a long-term power purchase agreement (PPA) with Florida Renewable Partners for a 16 MW solar farm being built in McIntosh Plant site.

2.2.4 Planned Unit Retirements

Lakeland Electric recently retired its McIntosh Unit No. 3 – a coal-fired steam unit on April 4, 2021. As an enhanced fleet modernization effort, Lakeland Electric will evaluate the performance of existing older peaking units and examine how LE can meet future power demand in a more innovative and reliable way. This may require retiring some older and less-efficient gas or oil units.

2.2.5 *Planned Unit Additions*

Lakeland Electric has planned to add a combination of solar (16 MW) and the six (6) modular size (20 MW each, 120 MW total) reciprocating internal combustion engines (RICE) expected to be operational in 2024 to maintain the resource adequacy and flexibility in Lakeland System. In addition, plans for adding more solar is under study to explore the best options to meet LE customer's future need.

2.3 Service Area

Lakeland Electric's electric service area is shown on Figure 2-1 and is entirely located in Polk County. Lakeland Electric serves approximately 246 square miles, with approximately 174 square miles outside of Lakeland's city limits.

**Lakeland Electric
2022 Ten-Year Site Plan**

General Description of the Utility


Table 2-1 Lakeland Electric Existing Generating Facilities													
				Fuel ⁴		Fuel Transport ⁵						Net Capability ²	
Plant Name	Unit No.	Location	Unit Type ³	Pri	Alt	Pri	Alt	Alt Fuel Days Use ¹	Commercial In-Service Month/Year	Expected Retirement Month/Year	Gen. Max. Nameplate kW	Summer MW	Winter MW
Charles Larsen Memorial	GT2*	16-17/28S/24E	GT	NG	DFO	PL	TK	NR	11/62	Unknown	11,250	10	14
	GT3*		GT	NG	DFO	PL	TK	NR	12/62	Unknown	11,250	9	13
	8		CA	WH	---	---			04/56	Unknown	30,000	28	28
	8		CT	NG	DFO	PL	TK	NR	07/92	Unknown	101,520	78	93
Plant Total												106	121
¹ LAK doesnot maintain records of the days the alternative fuel was used. ² Net Normal, * Long term scheduled maintenance													
² Net Normal													
Source: Lakeland Energy Supply Unit Rating Group													
³ Unit Type				⁴ Fuel Type					⁵ Fuel Transportation Method				
CA Combined Cycle Steam Part				DFO Distillate Fuel Oil					PL Pipeline				
CT Combined Cycle Combustion Turbine				RFO Residual Fuel Oil					TK Truck				
GT Combustion Gas Turbine				BIT Bituminous Coal					RR Railroad				
ST Steam Turbine				WH Waste Heat					NG Natural Gas				

**Lakeland Electric
2022 Ten-Year Site Plan**

General Description of the Utility

Table 2-2 Lakeland Electric Existing Generating Facilities													
				Fuel ⁴		Fuel Transport ⁵						Net Capability	
Plant Name	Unit No.	Location	Unit Type ³	Pri	Alt	Pri	Alt	Alt Fuel Days Use ²	Commercial In-Service Month/Year	Expected Retirement Month/Year	Gen. Max. Nameplate kW	Summer MW	Winter MW
Winston Peaking Station	1-20	21/28S/23E	IC	DFO	---	TK	---	NR	12/01	Unknown	2,500 each	50	50
Plant Total												50	50
C.D. McIntosh, Jr.	D1	4-5/28S/24E	IC	DFO	---	TK	---	NR	01/70	Unknown	2,600	2.5	2.5
	D2		IC	DFO	---	TK	---	NR	01/70	Unknown	2,600	2.5	2.5
	GT1		GT	NG	DFO	PL	TK	NR	05/73	Unknown	26,640	17	19
	GT2		GT	NG	DFO	PL	TK	NR	06/20	Unknown	130,050	117	122
	5		CT	NG	---	PL	---	NR	05/01	Unknown	292,950	234	280
	5		CA	WH	---	---	---	NR	05/02	Unknown	135,000	118	118
Plant Total												491	544
System Total												647	715
¹ Lakeland's 60 percent portion of joint ownership with Orlando Utilities Commission.													
² Lakeland does not maintain records of the number of days that alternate fuel is used.													
³ Unit Type				⁴ Fuel Type					⁵ Fuel Transportation Method				
CA Combined Cycle Steam Part				DFO Distillate Fuel Oil					PL Pipeline				
CT Combined Cycle Combustion Turbine				RFO Residual Fuel Oil					TK Truck				
GT Combustion Gas Turbine				BIT Bituminous Coal					RR Railroad				
ST Steam Turbine				WH Waste Heat					NG Natural Gas				

Lakeland Electric Service Area



Page intentionally left Blank

3.0 Forecast of Electric Demand and Energy

Annually, Lakeland Electric (LE) develops a detailed short-term (1 year) electric load and energy forecast for budget purposes and short-term operational studies. An annual long-term forecast is developed for the Utility's long-term planning studies (i.e., TYSP).

Sales and customer forecasts of monthly data are prepared by rate classification. Separate forecast models are developed for inside and outside the City of Lakeland corporate limits for the Residential, Commercial, Industrial and Other (municipal departments and outdoor lighting) rate classifications. Monthly forecasts are summarized annually using fiscal period ending September 30th for the short-term budget forecast and by calendar year for long-term studies and reporting.

Lakeland Electric uses MetrixND, an advanced statistical forecasting software tool, developed by Itron, to assist with the development of LE's number of customers, energy and demand forecasts. Lakeland Electric uses MetrixLT, another Itron software tool, which integrates with MetrixND to develop the long-term system hourly load forecast.

The modeling techniques used to generate the forecasts include multiple regression, study of historical relationships and growth rates, trend analysis, and exponential smoothing. Lakeland Electric utilizes Itron's Statistically Adjusted End-Use (SAE) econometric modeling approach for the residential and commercial sectors. The SAE approach is designed to capture the impact of changing end-use saturation and efficiency trends, by building type, as well as economic conditions on long-term residential and commercial energy sales and demand.

Many variables are evaluated for the development of the forecasts. The variables that have proven to be significant and are included in the forecasts are weather, gross regional product, disposable personal income per household, persons per household, number of households, local population, electricity price, building type, appliance saturation and efficiency. Binary variables are used to explain outliers in historical billing discrepancies, trend shifts, monthly seasonality, rate migration between classes and other issues that could affect the accuracy of forecast models.

Weather variables

Heating and cooling degree days are weather variables that attempt to explain a customer's usage behavior as influenced by either hot or cold weather. Heating Degree Days (HDD) occur when the average daily temperature is less than Lakeland Electric's established base temperature of 65 degrees Fahrenheit. Cooling Degree Days (CDD) occur when the average daily temperature is greater than 65 degrees. The formulas used to determine the number of degree days are:

$$HDD = \text{Base Temperature (65)} - \text{Average Daily Temperature}$$

$$CDD = \text{Average Daily Temperature} - \text{Base Temperature (65)}$$

These HDD and CDD variables are used in the forecasting process to correlate electric consumption with weather. The HDD and CDD variables are weighted to capture the impacts of weather on revenue from monthly billed consumption.

Lakeland Electric uses weather data from its own weather stations, which are strategically placed throughout the electric service territory to provide the best estimate of overall temperature for the Lakeland Electric service area.

The most recent 20 years of historical normal weather is used as an input into the sales forecast models.

Normal peak-producing weather is also developed using historical 20-years weather. A weighted average of temperatures on both the day of historical monthly peak and day prior to peak is used to create the HDD and CDD variables.

Economic and demographic variables

The economic and demographic projections used in the forecasts are purchased from Moody's Analytics.

Price variables

A real price forecast by month and rate class is created based on Lakeland Electric historical price data, projections from the Lakeland Electric Rates and Fuel teams, the U.S. Energy Information Administration (EIA) Annual Energy Outlook (AEO) forecasted price of electricity, historical and projected Net Energy for Load, and the projected Consumer Price Index. The 12-month moving average of projected real price of electricity is the price variable used in the sales and demand SAE models.

Structural Indices

The end-use saturation and efficiency indices used in the models are purchased from Itron. Itron's Energy Forecasting Group (EFG) offers end-use data services and forecasting support. EFG's projections are based on data derived from the EIA's AEO forecast for the South Atlantic Census Division. Itron is also contracted to further calibrate the indices based on Lakeland Electric's service area using average square feet by building type for the Commercial Sector and average use by dwelling type for the Residential Sector.

Lakeland Electric reviews the forecasts for reasonableness, compares projections to historical patterns, and modifies the results as needed using informed judgment.

Historical monthly data is available and is analyzed for the 20-year period. Careful evaluation of the data and model statistics is performed; this often results in most models being developed using less than a 10-year estimation period.

Lakeland Electric currently does not have any specific energy savings goals through Demand Side Management (DSM) programs; therefore, Lakeland Electric does not assume any deductions in peak load for the forecast period.

3.1 Service Territory Population Forecast

Electric Service Territory Population Estimate

Lakeland Electric's service area encompasses approximately 246 square miles, approximately 171 square miles of which are outside the City of Lakeland's corporate limits. The estimated electric service territory population for Lakeland Electric in 2021 was 299,557 persons.

Population Forecast

Lakeland Electric's service territory population is projected to increase at an estimated 1.12% average annual growth rate (AAGR) for years 2022 – 2031.

Polk County's population (Lakeland / Winter Haven MSA) is expected to grow at 1.28% AAGR for the same 10-year period. Historically, Polk County's population has grown faster than LE's service territory population.

3.2 Accounts Forecast

Lakeland Electric forecasts the number of monthly electric accounts for the following categories and subcategories:

- Residential, Inside and Outside City Limits
- Commercial, Inside and Outside City Limits
- Industrial, Inside and Outside City Limits
- Other, Inside and Outside City Limits

3.2.1 Residential Accounts

A regression model is used to develop the Residential account forecast using monthly customer data. Total Residential accounts are projected as a function of number of households in the Lakeland / Winter Haven Metropolitan Statistical Area (MSA). Binary variables are used to explain outliers in historical billing data and to account for seasonality.

3.2.2 Commercial Accounts

Commercial accounts consist of the General Service (GS), General Service Business Demand (GSBD) and General Service Demand (GSD) rate classes.

Due in large part to energy efficiency, Lakeland Electric is experiencing a long-term trend of General Service Large Demand (GSLD) customers migrating to Commercial rate classes. For this reason, a regression model combining both Commercial and GSLD rate classes is being used. The number of Commercial and GSLD accounts is projected as a function of the moving average of projected residential accounts.

A ratio of the Commercial and GSLD rate classes is then applied to generate the Commercial and GSLD account forecasts.

3.2.3 Industrial Accounts

Industrial accounts consist of General Service Large Demand (GSLD), Interruptible (INT) and Extra-Large Demand Customer (ELDC) rate classes.

The GSLD rate class consists of customers with a billing demand greater than 500 kW, at least three times, over the past 12 months. As noted in section 3.2.2, the GSLD account forecast is a ratio of the combined Commercial and GSLD account forecast.

The INT rate class consists of customers with a billing demand greater than 1000 kW, at least three times, over the past 12 months.

The ELDC rate class consists of customers with a billing demand greater than 5000 kW at least three times over the past 12 months.

Projections for INT and ELDC accounts are modeled independently of MetrixND. Special consideration is given to account for new major commercial and industrial development projects that may impact future demand and energy requirements.

3.2.4 Other Accounts

The Other account category consists of Municipal, Electric and Water Department accounts within the City of Lakeland, as well as private area lighting and roadway lighting.

Historical data for these classes is inconsistent and difficult to model. Therefore, account projections for this category are based on time trends and historical growth rates. Lakeland Electric also takes into consideration any future projects and potential developments. These forecasts are developed outside of MetrixND.

3.2.5 Total Accounts Forecast

The Total Account Forecast for Lakeland Electric is the sum of all the individual forecasts mentioned above.

3.3 Energy Sales Forecast

Lakeland Electric's Energy Sales Forecast is the sum of the following forecasts:

- Residential, Inside and Outside City Limits
- Commercial, Inside and Outside City Limits
- Industrial, Inside and Outside City Limits
- Other, Inside and Outside City Limits

3.3.1 Residential Energy Sales Forecast

The Residential energy sales forecast is developed using the Statistically Adjusted End-Use (SAE) econometric modeling approach.

The residential sales models are estimated with historical monthly energy sales data. They are average use models based on the following equation:

$$AvgUse_{y,m} = b_0 + b_1 XCool_{y,m} + b_2 XHeat_{y,m} + b_3 XOther_{y,m} + \varepsilon_{y,m}$$

Where $XCool_{y,m}$, $XHeat_{y,m}$ and $XOther_{y,m}$ are explanatory variables constructed from weather data, end use equipment efficiency and saturation trends, economic and demographic data, dwelling type (single family, multi family or mobile home) and square footage.

For example, $XCool$ incorporates cooling equipment saturation levels, cooling equipment efficiency, thermal efficiency, thermal integrity and square footage by dwelling type, household income, persons per household, price of electricity and CDDs.

This cooling variable is represented by the product of an end use equipment index and a monthly usage multiplier.

That is,

$$XCool_{y,m} = CoolIndex_y \times CoolUse_{y,m}$$

Where

$XCool_{y,m}$ is the estimated cooling energy use in year (y) and month (m)

$CoolIndex_y$ is the annual index of cooling equipment

$CoolUse_{y,m}$ is the monthly usage multiplier

The $CoolIndex_{y,m}$ is calculated as follows:

$$CoolIndex_y = Structural Index_y \times \sum_{Type} Weight^{Type} \times \frac{\left(\frac{Saturation_y^{Type}}{Efficiency_y^{Type}} \right)}{\left(\frac{Saturation_Y^{Type}}{Efficiency_Y^{Type}} \right)}$$

Where

The *StructuralIndex* is constructed by combining the EIA's building shell efficiency index trends with surface area estimates, indexed to the base year value:

$$StructuralIndex_y = \frac{BuildingShellEfficiencyIndex_y \times SurfaceArea_y}{BuildingShellEfficiencyIndex_Y \times SurfaceArea_Y}$$

Type is the cooling equipment type (Room Air Conditioning, Central Air Conditioning, Air Source Heat Pump, Ground Source Heat pump). Currently, the base year *Y* in the EFG residential end use energy projections is 2015.

CoolUse_{y,m} is defined as follows:

$$CoolUse_{y,m} = \left(\frac{CDD_{y,m}}{CDD_Y} \right) \times \left(\frac{HHSIZE_{y,m}}{HHSIZE_Y} \right)^\alpha \times \left(\frac{HHIncome_{y,m}}{HHIncome_Y} \right)^\beta \times \left(\frac{Price_{y,m}}{Price_Y} \right)^\gamma$$

Where

HHSIZE is average household size (persons per household)

HHIncome is average income per household

α , β , γ are the elasticities

Y is the Base Year

The *XHeat* variable is constructed in the same manner as the *XCool* variable, with cooling equipment replaced by heating equipment and CDDs replaced by HDDs. The heating equipment types used to construct the *XHeat* variable are furnace, air-source heat pump, ground-source heat pump, secondary heating and furnace fans.

The corresponding *HeatUse_{y,m}* variable is defined as follows:

$$HeatUse_{y,m} = \left(\frac{HDD_{y,m}}{HDD_Y} \right) \times \left(\frac{HHSIZE_{y,m}}{HHSIZE_Y} \right)^\alpha \times \left(\frac{HHIncome_{y,m}}{HHIncome_Y} \right)^\beta \times \left(\frac{Price_{y,m}}{Price_Y} \right)^\gamma$$

The *XOther* variable includes the equipment types that are not influenced by weather and constitute the base load portion of residential energy consumption. The equipment types included are electric water heating, electric cooking, refrigerator,

freezer, dishwasher, electric clothes washer, electric clothes dryer, television, lighting and miscellaneous electric appliances.

The corresponding $OtherUse_{y,m}$ variable is defined as follows:

$$OtherUse_{y,m} = \left(\frac{BDays_{y,m}}{30.44} \right) \times \left(\frac{HHSize_{y,m}}{HHSize_Y} \right)^{\alpha} \times \left(\frac{HHIncome_{y,m}}{HHIncome_Y} \right)^{\beta} \times \left(\frac{Price_{y,m}}{Price_Y} \right)^{\gamma}$$

Instead of a weather variable, the OtherUse formula contains a BDays variable, which represents the number of billing days in year (y) and month (m). These values are normalized by 30.44, the average number of days in a month.

The equation used to develop the total residential energy sales forecast is:

$$ResidentialSales_{y,m} = ResidentialCustomer_{y,m} \times AverageUsePerCustomer_{y,m}$$

3.3.2 Commercial Energy Sales

As mentioned in section 3.2.2, there is an increase in rate migration between the GSLD and Commercial rate classes due to energy efficiency. Therefore, a combined Commercial and GSLD energy sales model is generated. This model is developed using the SAE modeling approach for Commercial building types using EFG projections derived from EIA data. The Commercial sales model is driven by Gross Regional Product, price of electricity, number of households, weather, commercial building type, appliance saturations and efficiencies. Binary variables are used to help explain fluctuations in historical billing data due to rate migrations, billing discrepancies, seasonality and other factors that may affect the accuracy of the forecast models.

The Commercial SAE model framework defines energy use in a year as the sum of energy used by the heating equipment, cooling equipment and other equipment. The formal model equation is:

$$USE_{y,m} = b_0 + b_1 \times XCool_{y,m} + b_2 \times XHeat_{y,m} + b_3 \times XOther_{y,m} + \epsilon_{y,m}$$

Where $XCool_{y,m}$, $XHeat_{y,m}$ and $XOther_{y,m}$ are explanatory variables constructed from weather data, end use equipment efficiency and saturation trends, economic projections, commercial building type and square footage.

The $XCool_{y,m}$ variable is the amount of energy used by cooling systems and is defined as:

$$XCool_{y,m} = CoolIndex_y \times CoolUse_{y,m}$$

Where

$XCool_{y,m}$ is the estimated cooling energy use in year (y) and month (m)

$CoolIndex_y$ is the annual index of cooling equipment

$CoolUse_{y,m}$ is the monthly usage multiplier

The cooling equipment index depends on equipment saturation levels ($CoolShare$) normalized by operating efficiency levels ($Efficiency$):

$$CoolIndex_y = CoolSales_y \times \frac{\left(\frac{CoolShare_y}{Efficiency_y} \right)}{\left(\frac{CoolShare_y}{Efficiency_y} \right)}$$

Base year cooling sales are defined as:

$$CoolSales_y = \left(\frac{kWh}{Sqft} \right)_{Cooling} \times \left(\frac{CommercialSales_y}{\sum_e kWh/Sqft_e} \right)$$

Base-year cooling sales are the product of the average space cooling intensity value and the ratio of the total commercial sales in the base year over the sum of the end use intensity values.

The monthly Commercial $CoolUse$ variable is computed as:

$$CoolUse_{y,m} = \left(\frac{CDD_{y,m}}{CDD_y} \right) \times \left(\frac{EconVar_{y,m}}{EconVar_y} \right)^\alpha \times \left(\frac{Price_{y,m}}{Price_y} \right)^\beta$$

Where

$EconVar$ is a function of Household growth and Gross Regional Product

α, β are elasticities

The *XHeat* variable has the same structure as the *XCool* variable, with cooling equipment replaced by heating equipment, and CDDs replaced by HDDs. The corresponding monthly *HeatUse_{y,m}* variable is defined as:

$$HeatUse_{y,m} = \left(\frac{HDD_{y,m}}{HDD_Y} \right) \times \left(\frac{EconVar_{y,m}}{EconVar_Y} \right)^\alpha \times \left(\frac{Price_{y,m}}{Price_Y} \right)^\beta$$

The *XOther* variable is also similar in structure to the *XCool* variable, and replaces cooling equipment with other equipment (ventilation, electric water heating, cooking equipment, refrigeration, lighting, office equipment and miscellaneous equipment). Instead of a weather variable there is a *BDays* variable, which represents the number billing days in year (y) and month (m), normalized by 30.44 days (the average number of billing days in a month.)

The corresponding *OtherUse_{y,m}* variable is defined as:

$$OtherUse_{y,m} = \left(\frac{BDays_{y,m}}{30.44} \right) \times \left(\frac{EconVar_{y,m}}{EconVar_Y} \right)^\alpha \times \left(\frac{Price_{y,m}}{Price_Y} \right)^\beta$$

3.3.3 Industrial Energy Sales

While the GSLD demand and energy sales are forecast in combination with Commercial energy sales, the remainder of the Industrial class – the INT and ELDC rate classes - are modeled independently of the SAE methodology. Each INT and ELDC customer is evaluated individually to account for their expected future energy and demand consumption, using average historical growth rates, monthly demand and expected future changes to load based on information provided by various sources, including account managers, LE engineering, local news and informed judgement.

3.3.4 Other Sales Forecast

The Other energy sales forecast consists of sales for the City's Municipal, Electric and Water Departments, private area lighting, roadway lighting and unmetered street

lighting rate classes. Models are difficult to develop for these rate classes due to the large fluctuations in the historical billing data. Therefore, the projections for this category are based on historical trends and growth rates. Special consideration is given to account for new projects and potential developments.

3.3.5 Total Sales Forecast

The results of the energy sales forecasts for all revenue classes are added together to create a total sales forecast.

Lakeland Electric currently does not have any energy efficiency goals, therefore LE does not assume any deductions in peak load for the forecast period.

3.4 Net Energy for Load Forecast

A loss factor of approximately 2.6% is applied through 2031 to convert total energy sales to Net Energy for Load (NEL). The loss factor is developed using a historical average of the estimated amount of energy lost during the generation, transmission and distribution while delivering energy to the customers. The actual loss factor in 2021 was 2.9% for Lakeland Electric System.

3.5 Peak Demand Forecast

A regression model is estimated in MetrixND to forecast monthly peaks. The model is developed using Itron's SAE modeling approach to ensure that end-use appliance saturations and efficiencies that may affect peak are being accounted for. The models are driven by monthly energy coefficients and normal peak-producing weather conditions.

The winter peak forecast is developed under the assumption that its occurrence will be on a January weekday. Historical winter peaks have occurred between the months of December to March, between the hours of 7 a.m. and 9 a.m. Temperatures at time of winter peaks range from 19° F to 51° F.

The summer peak forecast is developed under the assumption that its occurrence will be on a July weekday. Historical summer peaks have occurred between the months of

June to September, on weekdays, and between the hours of 3 p.m. and 6 p.m. Temperatures at time of summer peaks range from 90° F to 101° F.

3.6 Hourly Load Forecast

Twenty-four hourly regression models are developed in MetrixND to generate the 20-year hourly load shape. Each of these models relates weather and calendar conditions (day-of-week, month, holidays, seasonal periods, etc.) to load. The uncalibrated hourly load shape is then scaled to the energy forecast and the peak forecast using MetrixLT. The result is an hourly load shape that is calibrated to the system energy and system peak forecasts produced using MetrixND.

3.7 Sensitivity Cases

3.7.1 High & Low Load Forecast Scenarios

A forecast is generated based on the projections of its drivers and assumptions at the time of forecast development. This base forecast (50/50) is intended to represent the forecast that is “most likely” to occur.

There may be some conditions arising that may cause variation from what is expected in the base forecast. For these reasons, high and low case scenario forecasts are developed for customers, energy sales, system net energy for load and peaks. The high and low forecasts are based on variations of the primary drivers including population and economic growth.

Model Evaluation and Statistics

The results of the Electric Load and Energy Forecast are reviewed by an outside consultant. Itron is contracted to review all sales, customer, peak and energy forecast models for reasonableness and statistical significance. Itron also evaluates and reviews all key forecast assumptions.

Additionally, the MetrixND software is used to calculate statistical tests for determining a significant model, including Adjusted R-Squared, Durbin-Watson Statistic,

F-Statistic, Probability (F-Statistic), Mean Absolute Deviation (MAD) and Mean Absolute Percentage Error (MAPE).

Intentionally left Blank

4.0 Energy Conservation and Management Programs

Lakeland Electric is committed to the efficient use of electric energy and provide cost effective energy conservation and demand reduction programs for all its consumers. Lakeland Electric is not subject to the Florida Energy Efficiency and Conservation Act (FEECA) rules but has in place several Energy Conservation & Management Programs and remains committed to utilize cost effective conservation and Management Programs that will benefit its customers. Presented in this section are the currently active energy efficiency programs from Lakeland Electric.

4.1 Conservation Programs 2022

In keeping with Lakeland Electric's plan to promote retail energy conservation programs, the utility is continuing the following activities during 2022:

Residential

- Insulation rebate - \$200 rebate for adding attic insulation to achieve R30 total. Certificate issued to resident at energy audit/visit and redeemed to Insulation Contractor. Can be homeowner installed.
- Energy Saving Kits – giveaway at audits contains weather-stripping, outlet gaskets, low flow showerhead, LED, etc.
- HVAC Maintenance Incentive - \$50 rebate for residential customers that have A/C maintenance done.
- Heat Pump Rebate - \$300 rebate for installing a SEER 15 or higher heat pump
- LED Lighting – giveaway at audits, up to 3 per residence
- On-line Energy Audit
- Energy Star Appliance Rebates

Commercial

- Conservation Rebate – rebate of \$150/kW for GSLD, Contract, and Interruptible customers that make energy efficiency improvements. Promoted by Account Executives.
- Commercial Lighting – rebate of \$150/kW reduced per customer for energy efficient lighting upgrades.

Transportation

- New Electric Vehicle – rebate of \$1000
- Used Electric Vehicle – rebate of \$500
- Electric Charging Station – rebate of \$100

Estimated Demand and Energy Savings for FY 2021

- 2.0 MW demand reduction and over 3,500 MWhs

4.2 Solar Program Activities

Lakeland Electric considers solar photovoltaic (PV) system as distributed generators irrespective of their connection to the grid. Solar being available during the daytime, it contributes to reduce system peak demand/energy avoiding the generation/purchase at higher cost. This helps to reduce the average cost of electricity to LE Customers.

4.2.1 Utility Interactive Net Metered Photovoltaic Systems

As of December 2021, there were approximately 730 PV residential customers in the Lakeland Electric service territory. These PV systems have about 5,200 kW of installed capacity. Lakeland Electric has allowed the interconnection of these systems in a “net meter” fashion.

4.2.2 Utility Scale Solar PV Program

During November 2007, Lakeland Electric issued a Request for Proposal seeking an investor to purchase and install investor owned PV systems totaling 24 MW on customer owned sites as well as City of Lakeland properties. During December 2007, a successful bidder was identified, and installation of the following PV systems began:

- Lakeland Electric’s first Solar Energy Purchase Agreement (SEPA) was signed on July 21, 2009 for an investor-owned 250 kW PV system for a twenty-year commitment. The roof top system began commercial operation at the RP Funding Center on April 4, 2010.
- Phase I solar array was installed at the Lakeland Linder Airport with a SEPA that was initiated on November 9, 2010. This 2.25 MW PV system began operation on December 22, 2011, for a twenty-five-year term.

- Phase II of the Lakeland Linder Airport site is located off Hamilton Road and began shortly after Phase I. The SEPA for Phase II was initiated on December 9, 2010. Phase II is a 2.75 MW PV system that began operation on September 16, 2012, for a twenty-five-year term.
- Phase III is the most recent solar array added to the Lakeland Linder Airport site and is located off Medulla Road. Lakeland Electric entered a SEPA on March 2, 2015, for 3.15 MW PV. This solar array operation began on December 21, 2016, for a twenty-five-years term.
- Lakeland entered a SEPA with a solar vendor on November 25, 2013, for a 6.0 MW PV system located adjacent to the Sutton substation. The facility is commonly referred to as Bird blue or by the road intersection Bellavista/Sutton. It began generating power on July 6, 2015
- Lakeland is in the final negotiation on PPA for a new solar farm (16 MW) to be built by Florida Renewable Partners. This solar farm will be built on the east side of McIntosh Power Plant. The solar farm will be available for production by the end of 2023.
- In addition to the 16 MW from the new solar farm being built, Lakeland Electric is actively looking for an additional of 30 MW or more from solar in its territory.

In total, Lakeland Electric has 14.4 MW of solar capacity and has the potential to produce approximately 2% of the average daytime system-wide summer load. At present, total production is approximately 25,000 MWhs annually.

4.2.3 Utility Solar Water Heating Program

During November 2007, LE issued a RFP for the expansion of its Residential Solar Water Heating Program. In this solicitation, Lakeland sought the services of a venture capital investor who would purchase, install, own, operate and maintain 3,000 – 10,000 solar water heaters on LE customers' residences in return for a revenue sharing agreement. LE would provide customer service and marketing support, along with meter reading, billing and collections. During December 2007, a successful bidder was identified and notified. In August 2009, LE approved a contract with the vendor with plans to resume

installations of solar water heaters. Annual projected energy savings from this project will range between 7,500 and 25,000 MWh. These solar generators will also produce Renewable Energy Credits that will contribute toward Florida's expected mandate for renewable energy as a part of the utility's energy portfolio.

During the summer of 2010, the "Solar for Lakeland" program began installing residential solar water heaters. Under this expanded program, the solar thermal energy was sold for the fixed monthly amount of \$34.95. All solar heating systems continued to be metered for customers' verification of solar operation and for tracking green credits for the utility. Through the end of 2017, there were 259 solar heaters installed in Lakeland residences. The water heaters are currently being installed by the vendors for the residential customers in Lakeland.

4.2.4 Renewable Energy Credit Trading

Lakeland Electric's Renewable Energy Credits (REC) are produced from its five solar energy purchases made through PPAs that have a combined name plate capacity of 14.4 MW.

In January of 2019, Lakeland Electric set up an account with the North American Renewable Registry to start trading its solar RECs classified as Green-e-Eligible. A REC is created for every (1) Megawatt-hour of renewable electricity generated and delivered to the utility grid.

The utility's 2022 fiscal year forecast for RECS is about 21,000 in total and a REC can sell for \$1.55 to \$6.53 in the state of Florida.

5.0 Forecasting Method and Procedures

This section describes Lakeland’s long-term Integrated Resource Planning (IRP) process in which economic and fuel parameters are the major drivers to develop a long-term plan that helps to develop a portfolio that focuses on a best forward path for Lakeland Electric. This chapter also explains the position of Lakeland Electric in economy energy purchase and sales from Florida Municipal Power Pool (FMPP). Also explained are fuel supply arrangement and fuel price projections to be used in the long-term resource planning process.

5.1 Integrated Resource Plan

In addition to the Ten -Year Site Plan process, Lakeland Electric utilizes an IRP process for meeting 10 to 20 years of forecasted energy demand plus reserve capacity through a combination of supply and demand-side resources along with economy energy purchase from the Florida Municipal Power Pool (FMPP) while meeting the objectives of environmental responsibility, reliability and affordability for its customers. The IRP evaluates the risks and uncertainties related to regulation, marketplace and technologies based on known information and assumptions.

5.2 Florida Municipal Power Pool

Lakeland Electric is a member of the FMPP with the Orlando Utilities Commission (OUC) and the Florida Municipal Power Agency (FMPA). These three utilities operate as a single Balancing Authority (BA). All FMPP generating units are committed and dispatched together ensuring economic dispatch and reliability to the entire FMPP BA.

The FMPP is not a capacity pool meaning that each member must plan for and maintain sufficient capacity to meet their own individual electric demand and operating reserve obligations. Lakeland, therefore, must ultimately plan to meet its own load and reserve requirements as reflected in this document. Each member participates in a day ahead market in purchases or sales activities and all units are dispatched in an economic

order. The FMPP provides an opportunity for members to purchase economy energy when available from other members.

5.3 Economic Parameters

Subsections of 5.3 present the assumed values adopted for economic parameters used in Lakeland Electric's planning process. The assumptions stated in this section are applied consistently throughout this document.

5.3.1 Inflation Rate

The general inflation rate applied is assumed to be 6.5% in 2022, 3.5% in 2023 and 2.5% thereafter based on Moody's CPI forecast as of December 2021.

5.3.2 Bond Interest Rate

Consistent with the traditional tax-exempt financing approach used by Lakeland, the self-owned supply-side alternatives assume 100 percent debt financing. Lakeland's long-term tax-exempt bond interest rate is assumed to be 4.0 percent.

5.3.3 Present Worth Discount Rate

The present worth discount rate used in the analysis is set equal to Lakeland's assumed bond interest rate of 4.0 percent.

5.3.4 Interest During Construction

During construction of the plant, progress payments will be made to the EPC contractor and interest charges will accrue on loan draw downs. The interest during construction rate is assumed to be 4.0 percent.

5.3.5 Fixed Charge Rate

The fixed charge rate is the sum of the project fixed charges as a percent of the project's total initial capital cost. When the fixed charge rate is applied to the initial investment, the product equals the revenue requirements needed to offset fixed costs for a

given year. A separate fixed charge rate can be calculated and applied to each year of an economic analysis, but it is most common to use a Levelized Fixed Charge Rate that has the same present value as the year by year fixed charged rates. Included in the fixed charged rate calculation is an assumed 0.7 percent issuance fee, a 0.0 percent annual insurance cost, and there is no 6 months' debt reserve for Lakeland.

5.4 Fuel Parameters

Subsections of 5.4 below outline the basic fuel assumptions and fuel delivery arrangement for Lakeland.

5.4.1 Natural Gas

Natural gas is a colorless, odorless fuel that burns cleaner than many other traditional fossil fuels. Natural gas can be used for heating, cooling, and production of electricity and other industrial uses.

Natural gas is found in the Earth's crust. Once the gas is brought to the surface, it is refined to remove impurities such as water, sand and other gases. The natural gas is then transported through pipelines and delivered to the customer either directly from the pipeline or through a distribution company or utility.

5.4.1.1 Natural Gas Supply and Availability

Significant natural gas reserves exist, both in the United States and throughout the North American mainland and coastal regions. Natural gas reserves are mostly dependent on domestic production. Production of natural gas from the Marcellus and Haynesville areas has increased due to advanced drilling technology which has lowered cost contributing to increased supply which reduces price volatility seen in recent years. During 2021, natural gas trading has averaged around \$3.316 per MMBtu and the five-year NYMEX Henry Hub Natural Gas forward curve is projected to continue to average around \$3.615 per MMBtu.

5.4.1.2 Natural Gas Transportation

There are now three transportation companies serving Peninsular Florida. Florida Gas Transmission Company (FGT), Sabal Trail Transmission, and Gulfstream Natural Gas System (GNGS). Lakeland Electric has interconnections and service agreements with GNGS and FGT to provide diversification and flexibility in gas delivery.

5.4.1.2.1 Florida Gas Transmission Company

FGT is an open access interstate pipeline company transporting natural gas for third parties through its 5,000 miles pipeline system extending from South Texas to Miami, Florida.

The FGT pipeline system accesses a diversity of natural gas supply regions, including:

- Anadarko Basin (Texas, Oklahoma, and Kansas)
- Arkona Basin (Oklahoma and Arkansas)
- Texas and Louisiana Gulf Areas (Gulf of Mexico)
- Black Warrior Basin (Mississippi and Alabama)
- Louisiana – Mississippi – Alabama Salt Basin

FGT's total receipt point capacity is in excess of 3.0 billion cubic feet per day and includes connections with 12 intrastate pipelines to facilitate transfers of natural gas into its pipeline system. FGT reports a current delivery capability to Peninsular Florida of approximately 3.1 billion cubic feet per day. Lakeland Electric currently has in excess of 28,000 MMBtu/day of firm transportation with FGT for natural gas delivery to its generation facilities.

5.4.1.2.2 Florida Gas Transmission market area pipeline system

The FGT multiple pipeline system corridor enters the Florida Panhandle in northern Escambia County and runs easterly to a point in southwestern Clay County, where the pipeline corridor turns southerly to pass west of the Orlando area. The mainline corridor

then turns to the southeast to a point in southern Brevard County, where it turns south generally paralleling Interstate Highway 95 to the Miami area. A major lateral line (the St. Petersburg Lateral) extends from a junction point in southern Orange County westerly to terminate in the Tampa, St Petersburg and Sarasota area. A major loop corridor (the West Leg Pipeline) branches from the mainline corridor in southeastern Suwannee County to run southward through western Peninsular Florida to connect to the St. Petersburg Lateral system in northeastern Hillsborough County. Each of the above major corridors include stretches of multiple pipelines (loops) to provide flow redundancy and transport capability. Numerous lateral pipelines extend from the major corridors to serve major local distribution systems and industrial/utility customers.

FGT's Phase VIII Expansion Project came into full operation April 1, 2011. It consists of approximately 483.2 miles of multi diameter pipeline in Alabama, Mississippi and Florida with approximately 365.8 miles built parallel to existing pipelines. The project added 213,600 horsepower (HP) of additional mainline compression. One new compressor station was built in Highlands County, Florida. The project provides an annual average of 820,000 MMBtu/day of additional firm transportation capacity.

5.4.1.2.3 Gulfstream pipeline

The Gulfstream pipeline is a 744 mile pipeline originating in the Mobile Bay region and crossing the Gulf of Mexico to a landfall in Manatee County (south Tampa Bay). The pipeline supplies Florida with up to 1.1 billion cubic feet of gas per day serving existing and prospective electric generation and industrial projects in southern Florida. Phase I of the pipeline is complete and ends in Polk County, Florida. The pipeline extends to Florida Power & Light's Martin Plant. Construction for the Gulfstream pipeline began in 2001 and it was placed in service in May 2002. Phase II was completed in 2005. Lakeland Electric added an additional 10,000 MMBtus/day of Gulfstream Pipeline capacity during 2017, for a total of 50,000 MMBtus/day.

5.4.1.2.4 Sabal Trail Transmission

The Sabal Trail pipeline is a 515 miles interstate pipeline originating in Central Alabama and terminating in Central Florida. The pipeline's Phase 1 facilities began commercial service July 3, 2017. The Phase 1 capacity of the pipeline is 830,000 Dth/day. Lakeland Electric is not currently a customer of Sabal Trail Transmission.

5.4.1.2.5 Transcontinental Gas Pipeline (TRANSCO)

The Transco Pipeline is a 10,000-mile interstate pipeline extending from south Texas to New York City. Lakeland Electric acquired 5,800 MMBtus/day beginning January 26, 2022 as a risk mitigation strategy to flow additional natural gas to both FGT and Gulfstream pipelines.

5.4.2 Coal

While coal has been a long standing and reliable fuel used primarily for electric generation, many utilities are ceasing coal operations for a variety of reasons including environmental concerns, efficiency, and primarily economics. Lakeland Electric retired its coal unit in April 2021. Lakeland Electric's McIntosh Unit No. 3 was a 365 MW coal burning plant placed into service in the early 1980's. Lakeland Electric is planning to replace this coal unit with a combination of solar and gas based modular RICE units starting from 2024.

5.4.2.1 Coal Supply and Availability

In the past, Lakeland Electric had coal contracts to serve the fuel requirements for the McIntosh Unit 3 coal generation facility. Since the plant was retired for its operation in 2021, the contract with CSX had been terminated.

5.4.3 Fuel Oil

5.4.3.1 Fuel Oil supply and Availability

Lakeland Electric obtains all fuel oil through spot market purchases and has no long-term contracts. This strategy provides the lowest cost for fuel oil consistent with usage, current price stabilization and on-site storage. Lakeland Electric's Fuels Section continually monitors the cost effectiveness of spot market purchasing.

5.4.3.2 Fuel Oil Transportation

Although Lakeland Electric is not a large consumer of fuel oils, a small amount is consumed during operations for backup fuel and diesel unit operations. Fuel oil is transported to Lakeland by truck.

5.4.4 Fuel Price Projections

This section presents the long-term price projections for natural gas and fuel oil. The fuel price forecast for solid fuel oil and natural gas is prepared by Lakeland Electric's Fuels Department. The natural gas forecast uses a blended average from a consultant forecast and the New York Mercantile Exchange (NYMEX) natural gas forward curve along with transport rate, usage and fuel to provide a total delivered price. The oil prices use the ten-year NYMEX crude oil forward curve. The diesel oil forecast is, with respect to the percentage of growth, based off the Energy Information Administration's Annual Energy Outlook 2021.

5.4.4.1 Natural Gas Price Forecast

The price forecast for natural gas is based on historical prices and future expectations for the market. The forecast takes into account the spot purchases of gas to meet its needs along with its risk management holdings intended to reduce price volatility.

To address the historic volatility of the natural gas market, Lakeland Electric initiated a formal fuel hedging program in 2003. The Energy Authority (TEA), a company located in Jacksonville, FL, is Lakeland Electric's consultant assisting in the administration and adjustment of policies and procedures, as well as the oversight of the program.

Lakeland Electric purchases "seasonal" gas to supplement the base requirement and purchases "as needed" daily gas, known commonly as "spot gas", to round out its supply needs.

Natural gas transportation from FGT is currently supplied under two rates in FGT's tariff; FTS-1 and FTS-3. Rates in FTS-1 are based on FGT's Phase II, III, IV, V, VI and VII, expansion. Rates in FTS-3 are based on the Phase VIII expansion, which went in service April 1, 2011¹. Lakeland has diversified its capacity with 60% Gulfstream, 34% FGT and 6% Transco. The FTS usage and fuel rates for FGT, Gulfstream and Transco listed below are effective from December 1, 2021.

Table 5-1 Natural Gas Tariff Transportation Rates						
Rates And Surcharges	Rate Schedules					
	FGT FTS-1 w/surcharges (cents/DTH)*	FGT FTS-2 w/surcharges (cents/DTH)*	**FGT FTS-3 w/surcharges (cents/DTH)*	FGT ITS-1	Gulfstream FTS-1	Gulfstream FTS-6%
Reservation Usage	53.18 4.15	63.18 4.15	132.99 2.82	96.57 0.00	55.763 0.0213	70.41 0.0068
Total	57.33	67.33	135.81	96.57	55.7813	70.4168
Fuel Charge	2.78%	2.78%	2.78%	2.78%	1.85%	1.85%
* A DTH is equivalent to 1 MMBtu or 1 MCF ** Lakeland does not currently subscribe to any FTS-3 Capacity						

The average transportation rate of \$0.59/MMBtu will be added for purposes of projecting delivered gas prices for existing gas units in Lakeland. This average rate is

¹ Lakeland does not currently subscribe to any FTS-3 capacity.

realized through a current mix of FGT, Gulfstream and Transco, including consideration of Lakeland Electric's ability to relinquish its FTS, Gulfstream and Transco transportation or acquire other firm and interruptible gas transportation on the market. The delivered natural gas price is projected to be very volatile during the next twelve months due to events in Russia, low storage projections and the end of withdrawal season. The long-term average price is forecasted to remain around \$3.615 during the next five years. The average delivered gas price forecast in Lakeland will be around \$4.808/MMBtu for the year 2022, which is above the last five-year average.

5.4.4.3 Fuel Oil Price Forecast

Changes in production levels and methods are placing oil prices at a lower level in the world market. Lakeland adjusts its oil price forecast to reflect current market pricing and what the anticipated future price may be.

5.4.5 Fuel Forecast Sensitivities

Lakeland Electric is not conducting any specific forecasted fuel price sensitivity analysis at this moment.

This page intentionally left blank.

6.0 Forecast of New Capacity Requirements

6.1 Assessment of the Need for Capacity/Energy

This section describes the process Lakeland Electric uses to assess the need for capacity under the principle of resource adequacy to serve Lakeland Electric's customers reliably in the future. The need for future capacity is based on Lakeland Electric's long-term load forecast, Florida Reliability Coordinating Council (FRCC) and FMPP's reserve margin requirements, and existing generation capacity of Lakeland Electric. In order to serve the customers in its territory, LE needs to have enough resources to meet the peak hour demand in any day throughout the year.

6.1.1 Load Forecast

The load forecast described in Section 3.0 is used to determine the need for capacity. The total electricity sales and peak hour demand forecast for this TYSP were developed based on future economic expectation and future population. LE generates a range of load forecasts (i.e., base-expected, high and low) to ensure that LE's plan is flexible enough to meet all scenarios. A summary of the annual peak load forecast for winter and summer for base case (i.e., reference) scenario are presented in Tables 6-1 and 6-2.

6.1.2 Reserve Requirements

Prudent utility planning requires that utilities secure firm generating resources over and above the expected peak system demand to account for unanticipated demand levels and supply changes. This additional capacity (i.e., reserve capacity) should be large enough to cover the loss of any unit in the system and be able to respond adequately to cover the moment to moment change in system load. Total reserves should also be able to cover uncertainties such as planned outage, interruption on transmission system due to planned maintenance or weather events and load forecasting error. Several methods of estimating the appropriate level of reserve capacity are used. A commonly used approach is the reserve margin method, which is calculated as follows:

$$\frac{\text{System net capacity} - \text{System net peak demand}}{\text{System net peak demand}}$$

Lakeland Electric looked at probabilistic approaches to determine its reliability needs in the past. The study has looked at reliability indices such as Loss of Load Probability (LOLP) and Expected Unserved Energy (EUE). Lakeland Electric has found that due to the strength of its transmission system, and interconnection with neighboring utilities, operation within FMPP, LOLP and EUE values were so small in the past that reserve margin-based reliability measures would be enough at this time. Moreover, FRCC performs LOLP analysis every two years and the reliability standards are adequate to operate the system reliably.

6.1.3 Existing Energy Supply

Availability factor on Generating Units is reviewed annually and is found to be within industry standards for the types of units that Lakeland Electric has in its fleet, indicating adequate and prudent maintenance is taking place.

Lakeland Electric added Gas Turbine No. 2 in 2020 and retired its McIntosh Unit No 3 in April 2021. Lakeland plans to add 16 MW of solar at McIntosh Plant to be available for generation in early 2024. LE is using a wide variety of resources (own and purchase) to meet the load and reserve obligations. LE uses a production cost model – PCI GenTrader - to obtain an optimal capacity plan to meet its energy need with minimal unserved energy over the next 10 years. Table 6-1 shows the combination of purchase and LE owned resources for existing and planned capacity requirements. In addition, LE has secured firm Power Purchases necessary to meet load and reserve obligations until new resources are installed and operational. In 2024, 120 MW (6 units) of additional capacity will be available and will replace the existing long-term power purchase contract. These new generating units are highly reliable, efficient, flexible, and cost effective. The high flexibility and modularity of these Reciprocating Internal Combustion Engines (RICE) can provide a low-cost energy solution to Lakeland supporting an optimized transition to

additional solar energy in its energy portfolio. Lakeland plans to add more than 50 MW of solar in the future. These new engines can quickly ramp up and down as needed to balance the variable nature of solar resources. This will help to improve the reliability in Lakeland System.

6.2 Seasonal Capacity and Reserve Margins

As discussed in Section 6.1.2 above, by comparing Lakeland Electric's load forecast plus reserves with firm supply, the Reserve Margins can be identified. Since electric supply and demand differ in summer and winter, planning based on seasonal reserve margin is a key. This TYSP study also considers capabilities and performance of solar resources in both summer and winter. Lakeland Electric's Reserve Margins presented in Tables 6-1 and 6-2 are at or higher than 15% in both seasons.

Tables 6-1 and 6-2 indicate that using the base winter forecast, Lakeland Electric's Reserve Margins are greater than 15% in summer season during the current ten-year planning period. This complies with the Frock's minimum reserve margin criteria to meet the reliability requirements. Whereas, LE's winter reserve margins fall slightly below 15% without external power purchases/repair of existing out of service gas turbines or building any new resources. This is because Lakeland's winter peak load variability is more unpredictable and higher than summer.

Solar resources – unlike traditional dispatchable generators – are highly variable resources that depend on the time of the day, season and weather conditions. Hence, solar firm capacity is considered only 50% of the installed capacity during summer and 0% in winter in this study – which aligns the industry standard for planning purpose

As Lakeland Electric's needs and fleet of resources continue to change through time, reserve margin levels will be reviewed and adjusted as appropriate.

6.3 Energy Resources and Analysis

Tables 6.1 - 6.3 summarize the process Lakeland Electric uses to find the target for capacity and energy mix that is based on ten-year production cost analysis. This process involves selecting appropriate types of committed and planned resources to meet the future needs of LE customers. This combination of resources is represented as a portfolio for Lakeland Electric under the base case assumptions and production cost analysis. The GenTrader software model provides the optimal energy generation from Lakeland units along with economy purchase from the FMPP members when Lakeland units are economically dispatched with the other Pool members. This portfolio is decided based on optimal optimization of cost, risk, and environmental factors. As can be seen in Table 6.3, natural gas-fired resources are dominant in LE's future energy mix as more than 90% of energy comes from these resources. Solar mix is still low until 2024, but it increases in 4% range after 2024 when new solar units are added in the portfolio. Lakeland expects to have 5-10% of energy purchases from the combination of economy purchases from the FMPP members and fixed contract energy purchases from bilateral agreement with the OUC until new resources are built. When LE's RICE engines and solar resources become available in 2024, LE becomes a net seller and a buyer based upon relative dispatch costs of LE units compared to the other units in FMPP.

6.4 Summery - Study Results

Table 6-1 and 6.2 presents the schedules of new resources and anticipated future purchases in addition to the existing resources and power purchases. The planned portfolio provides adequate resource adequacy (i.e., reserve margin) during the summer based on existing and planned supply and demand. Since Lakeland anticipates more than 5% of installed capacity coming from solar by 2025, there is a need of about 15 MW of capacity which may either come from purchases or additional capacity from repairs on out of service gas turbine units in 2028 and later. This is because the capacity contribution from solar in meeting winter peak loads in the winter month's morning hours is assumed negligible. Table 6-3 presents the energy mix scenario for Lakeland Electric. LE starts to be more self-

enough in terms of energy after 2024 when LE's new resources are installed in 2024 and the firm power purchase agreement with the OUC expires.

Table 6-1 Projected Reliability Levels - Winter / Base Case										
Year	Net Generating Capacity MW	Net System Purchases MW	Net System Sales MW	Net System Capacity MW	System Peak Demand		Reserve Margin		Excess(Deficit) to Maintain 15% Reserve Margin	
					Before Interruptible and Load Management	After Interruptible and Load Management	Before Interruptible and Load Management	After Interruptible and Load Management	Before Interruptible and Load Management	After Interruptible and Load Management
					MW	MW	%	%	MW	MW
2021/22	709	125	0	834	677	677	23%	23%	55	55
2022/23	709	125	0	834	682	682	22%	22%	50	50
2023/24	809	0	0	809	689	689	17%	17%	17	17
2024/25	809	0	0	809	691	691	17%	17%	14	14
2025/26	809	0	0	809	695	695	16%	16%	10	10
2026/27	809	0	0	809	699	699	16%	16%	5	5
2027/28	809	15	0	824	706	706	17%	17%	12	12
2028/29	809	15	0	824	708	708	16%	16%	10	10
2029/30	809	15	0	824	711	711	16%	16%	6	6
2030/31	809	15	0	824	714	714	15%	15%	3	3

Table 6-2 Projected Reliability Levels - Summer / Base Case										
Year	Net Generating Capacity MW	Net System Purchases MW	Net System Sales MW	Net System Capacity MW	System Peak Demand		Reserve Margin		Excess(Deficit) to Maintain 15% Reserve Margin	
					Before Interruptible and Load Management	After Interruptible and Load Management	Before Interruptible and Load Management	After Interruptible and Load Management	Before Interruptible and Load Management	After Interruptible and Load Management
					MW	MW	%	%	MW	MW
2021	665	132	0	797	656	656	21%	21%	43	43
2022	665	132	0	797	661	661	21%	21%	37	37
2023	665	132	0	797	663	663	20%	20%	35	35
2024	765	32	0	797	668	668	19%	19%	29	29
2025	765	32	0	797	671	671	19%	19%	25	25
2026	765	32	0	797	674	674	18%	18%	22	22
2027	765	32	0	797	678	678	18%	18%	17	17
2028	765	32	0	797	683	683	17%	17%	12	12
2029	765	32	0	797	687	687	16%	16%	7	7
2030	765	32	0	797	691	691	15%	15%	2	2

Table 6.3: Energy Resource Mix													
Energy Source	Type	Units	Calendar Year										
			2021-Actual	2022	2023	2024	2025	2026	2027	2028	2029	2030	2031
Coal		%	13.1%	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%
Distillate	Steam	%	0.00%	0.00%	0.00%	0.00%	0.00%	0.00%	0.00%	0.00%	0.00%	0.00%	0.00%
	CC	%	0.00%	0.00%	0.00%	0.00%	0.00%	0.00%	0.00%	0.00%	0.00%	0.00%	0.00%
	CT	%	0.00%	0.12%	0.15%	0.09%	0.09%	0.03%	0.00%	0.00%	0.00%	0.00%	0.00%
	Total	%	0.00%	0.12%	0.15%	0.09%	0.09%	0.03%	0.00%	0.00%	0.00%	0.00%	0.00%
Natural Gas	Steam	%	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
	CC	%	66.4%	89.0%	91.7%	73.5%	88.7%	90.9%	88.3%	85.8%	86.2%	85.2%	81.9%
	CT	%	0.5%	1.8%	2.8%	7.4%	8.9%	7.7%	8.2%	6.1%	8.4%	7.9%	5.5%
	Total	%	66.8%	90.8%	94.5%	80.9%	97.6%	98.6%	96.5%	91.9%	94.5%	93.0%	87.3%
Solar		%	0.8%	0.7%	0.7%	1.9%	4.6%	4.6%	4.6%	4.5%	4.4%	4.4%	4.4%
Other (Specify) ¹		%	19.2%	8.4%	4.7%	17.1%	-2.3%	-3.3%	-1.1%	3.6%	1.0%	2.6%	8.3%
Net Energy for Load		%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%
¹ Other = Purchase													

7.0 Environmental and Land Use Information

As discussed in Section 6, Lakeland Electric added a new 125 MW McIntosh Gas Turbine No. 2 in 2020 and retired its coal unit (219 MW – LE’s net share) at Lakeland Electric’s McIntosh Power Plant. LE is replacing its retired coal unit by a combination of 120 MW RICE engines and solar by 2024. LE has been issued a construction permit for those Engines to be built at McIntosh plant site (Figure 7-5 and 7-6). LE anticipates purchasing 16 MW of solar through PPA beginning from 2024. The facility for solar will be located at LE’s McIntosh Power Plant site (See Figures 7-2 and 7-3) and air permitting process is underway for construction. To achieve LE’s overall mission to provide affordable energy and environmental stewardship, LE has adopted different measures to maintain the environmental footprint of the new generating units, including air emissions, water, waste and land use impacts within the state and federal standard.

Per the Ten-Year Site Plan definitions (rule 25-22-072), “Preferred Sites” include sites where a utility has taken action to site a new generation. “Preferred Site” information of the Plant site for planned units is presented from Figures 7-1 – 7.5.

Table 7-1 summarizes different control strategies adopted to comply with various environmental emission regulations in LE’s existing major generating units. The air pollution control technologies installed at those generating units meet all the state and federal regulations for all pollutants.

[See Table 7-1 on next page]

Table 7-1: Emission Control Options in Major LE Units

Table 7-1 Lakeland Electric Existing Generating Facilities Environmental Emissions and Control Strategies for Major Existing Generating Units								
Plant Name	Unit (Type)	Fuel		Air Pollutants and Control Strategies				Cooling Type
		Primary	Alt.	PM	SO2	Nox	CO	
Charles Larsen Memorial	8 (CC)	NG	DFO	None	LS	LNB	None	OTF
						WI		
C.D. McIntosh, Jr.	GT2 (GT)	NG	DFO	None	LS	WI	None	N/A
	5 (CC)	NG	N/A	None	LS	LNB	OC	WCTM
						SCR		
Winston	1-20 (IC)	DFO	N/A	None	LS	OFA	OC	N/A
PM Particulate matter OTF Once-through flow FGD Flue gas desulfurization SO2 Sulfur dioxide FGR Flue gas recirculation OFA Overfire air NOX Nitrogen oxides IC Internal combustion SCR Selective catalytic reduction CO Carbon monoxide NG Natural Gas N/A Not Applicable LS Low sulfur fuel WCTM Water cooling tower mechanical OC Oxidation catalyst LNB Low Nox burners ESP Electrostatic precipitator DFO Distillate Fuel oil WI Water injections CC Combined Cycle Alt Alternated GT Gas Turbine								
Source: Lakeland Environmental Staff								

Figure 7-1: C.D. McIntosh Power Plant Topographic Map




Figure 7-2: City of Lakeland – Zoning Map




Figure 7-3: McIntosh Solar Plant Site – Topological map




Figure 7-4: Site Location – McIntosh Solar



Figure 7-5: Site Location of 120 MW RICE Engines in McIntosh Plant





Figure 7-6: Site Location of 120 MW RICE Engines in McIntosh Plant



8.0 Ten-Year Site Plan Schedules

This section presents all the schedules as required by the Ten-Year Site Plan for the Florida Public Service Commission.

Tables 8-1 and 8-1a provide LE's existing unit characteristics.

Tables 8-2 through 8-5 provide information on energy usage characteristics by customer class in the past and the future.

Tables 8-2 through 8-8 provide history and forecast on LE's electric demand and energy.

Table 8-9 provides a history and forecast of fuel requirements by fuel type.

Tables 8-10 and 8-11 provide a history and forecast of energy produced by fuel type.

Tables 8-12 and 8-13 provide comparisons of Lakeland Electric resources to Lakeland Electric demand. This table demonstrates that Lakeland Electric's Reserve Margin forecast will be maintained at 15% or higher each year in this Ten-Year-Site Plan period.

Tables 8-14 provides information related to changes in the status of Lakeland Electric's existing and future units.

Tables 8-15 and 8-16 present the major technical and cost characteristics of new units to be installed at McIntosh Plant including solar.

Table 8-1 Lakeland Electric Existing Generating Facilities													
				Fuel ⁴		Fuel Transport ⁵						Net Capability ²	
Plant Name	Unit No.	Location	Unit Type ³	Pri	Alt	Pri	Alt	Alt Fuel Days Use ¹	Commercial In-Service Month/Year	Expected Retirement Month/Year	Gen. Max. Nameplate kW	Summer MW	Winter MW
Charles Larsen Memorial	GT2*	16-17/28S/24E	GT	NG	DFO	PL	TK	NR	11/62	Unknown	11,250	10	14
	GT3*		GT	NG	DFO	PL	TK	NR	12/62	Unknown	11,250	9	13
	8		CA	WH	---	---			04/56	Unknown	30,000	28	28
	8		CT	NG	DFO	PL	TK	NR	07/92	Unknown	101,520	78	93
Plant Total												106	121
¹ LAK doesnot maintain records of the days the alternative fuel was used. , ² Net Normal, * Long termscheduled maintenance - not included in available capacity.													
² Net Normal													
Source: Lakeland Energy Supply Unit Rating Group													
³ Unit Type				⁴ Fuel Type				⁵ Fuel Transportation Method					
CA Combined Cycle Steam Part				DFO Distillate Fuel Oil				PL Pipeline					
CT Combined Cycle Combustion Turbine				RFO Residual Fuel Oil				TK Truck					
GT Combustion Gas Turbine				BIT Bituminous Coal				RR Railroad					
ST Steam Turbine				WH Waste Heat				NG Natural Gas					

Table 8-1a													
Schedule 1.0: Existing Generating Facilities as of December 31, 2021													
				Fuel ⁴		Fuel Transport ⁵						Net Capability	
Plant Name	Unit No.	Location	Unit Type ³	Pri	Alt	Pri	Alt	Alt Fuel Days Use ²	Commercial In-Service Month/Year	Expected Retirement Month/Year	Gen. Max. Nameplate kW	Summer MW	Winter MW
Winston Peaking Station	1-20	21/28S/23E	IC	DFO	---	TK	---	---	12/01	Unknown	2,500 each	50	50
Plant Total												50	50
C.D. McIntosh, Jr.	D1	4-5/28S/24E	IC	DFO	---	TK	---	---	01/70	Unknown	2,600	2.5	2.5
	D2		IC	DFO	---	TK	---	---	01/70	Unknown	2,600	2.5	2.5
	GT1		GT	NG	DFO	PL	TK	---	05/73	Unknown	26,640	17	19
	GT2		GT	NG	RFO	PL	TK	---	06/20	Unknown	130,050	117	122
	3 ³		ST	BIT	---	RR	TK	---	09/82	Apr-21	219,000	205	205
	5		CT	NG	---	PL	---	---	05/01	Unknown	292,950	234	280
	5		CA	WH	---	---	---	---	05/02	Unknown	135,000	118	118
Plant Total												491	544
System Total												647	715
³ Lakeland's 60 percent portion of joint ownership with Orlando Utilities Commission.Retired in 2021.													
² Lakeland does not maintain records of the number of days that alternate fuel is used.													
³ Unit Type				⁴ Fuel Type					⁵ Fuel Transportation Method				
CA Combined Cycle Steam Part				DFO Distillate Fuel Oil					PL Pipeline				
CT Combined Cycle Combustion Turbine				RFO Residual Fuel Oil					TK Truck				
GT Combustion Gas Turbine				BIT Bituminous Coal					RR Railroad				
ST Steam Turbine				WH Waste Heat									
				NG Natural Gas									

Table 8-2								
Schedule 2.1: History and Forecast of Energy Consumption and Number of Customers by Customer Class								
(1)	(2)	(3)	(4)	(5)	(6)	(7)	(8)	(9)
Year	Rural & Residential					Commercial		
	Population	Members per Household	GWh	Average No. of Customers	Average kWh Consumption per Customer	GWh	Average No. of Customers	Average kWh Consumption per Customer
2012	262,288	2.59	1,343	101,252	13,264	727	11,765	61,793
2013	264,023	2.59	1,368	101,968	13,416	742	11,864	62,542
2014	271,379	2.63	1,400	103,099	13,579	752	12,022	62,552
2015	274,861	2.63	1,468	104,581	14,037	789	12,157	64,901
2016	279,331	2.64	1,473	105,932	13,905	795	12,225	65,031
2017	283,626	2.63	1,460	107,703	13,556	803	12,372	64,905
2018	288,157	2.64	1,524	109,043	13,976	813	12,543	64,817
2019	292,465	2.65	1,540	110,403	13,949	806	12,687	63,530
2020	295,899	2.64	1,612	112,175	14,370	789	12,889	61,215
2021	299,557	2.61	1,597	114,683	13,925	832	13,219	62,940
Forecast								
2022	302,985	2.66	1,568	115,191	13,612	817	13,227	61,768
2023	306,431	2.65	1,577	116,617	13,523	828	13,371	61,925
2024	309,771	2.65	1,592	118,056	13,485	836	13,518	61,843
2025	313,112	2.66	1,608	119,539	13,452	845	13,670	61,814
2026	316,542	2.66	1,624	121,024	13,419	852	13,824	61,632
2027	320,106	2.66	1,640	122,484	13,390	861	13,977	61,601
2028	323,774	2.66	1,658	123,927	13,379	870	14,128	61,580
2029	327,489	2.67	1,678	125,361	13,385	880	14,277	61,638
2030	331,200	2.67	1,696	126,764	13,379	889	14,425	61,629
2031	334,867	2.67	1,716	128,100	13,396	898	14,567	61,646

Table 8-3 Schedule 2.2: History and Forecast of Energy Consumption and Number of Customers by Customer Class							
(1)	(2)	(3)	(4)	(5)	(6)	(7)	(8)
Year	Industrial			Railroads and Railways	Street & Highway Lighting GWh	Other Sales to Public Authorities GWh	Total Sales to Ultimate Consumers GWh
	GWh	Average No. of Customers	Average kWh Consumption per Customer				
2012	579	81	7,148,148	0	33	70	2,751
2013	618	79	7,822,785	0	33	70	2,831
2014	649	77	8,428,571	0	33	70	2,903
2015	670	76	8,815,789	0	34	73	3,034
2016	655	74	8,851,351	0	34	73	3,030
2017	648	72	9,000,000	0	35	72	3,018
2018	676	74	9,135,135	0	35	70	3,118
2019	667	76	8,776,316	0	35	69	3,117
2020	660	75	8,800,000	0	35	68	3,163
2021	679	71	9,563,380	0	35	67	3,210
Forecast							
2022	667	77	8,662,338	0	35	67	3,154
2023	673	77	8,740,260	0	35	67	3,180
2024	678	78	8,692,308	0	35	67	3,208
2025	681	79	8,620,253	0	35	67	3,236
2026	685	80	8,562,500	0	35	67	3,263
2027	690	81	8,518,519	0	35	67	3,293
2028	695	82	8,475,610	0	35	67	3,325
2029	700	83	8,433,735	0	35	67	3,360
2030	704	84	8,380,952	0	35	67	3,391
2031	709	85	8,341,176	0	35	67	3,425

Table 8-4					
Schedule 2.3: History and Forecast of Energy Consumption and Number of Customers by Customer Class					
(1)	(2)	(3)	(4)	(5)	(6)
Year	Wholesale Purchases for Resale GWh	Wholesale Sales for Resale GWh	Net Energy for Load GWh	Other Customers (Average No.)	Total No. of Customers
2012	0	0	2,873	8,953	122,050
2013	0	0	2,919	8,892	122,803
2014	0	0	3,006	8,820	124,019
2015	0	0	3,126	8,860	125,674
2016	0	0	3,109	8,921	127,152
2017	0	0	3,086	8,966	129,113
2018	0	0	3,180	8,997	130,658
2019	0	0	3,189	9,051	132,217
2020	0	0	3,273	9,182	134,320
2021	65	0	3,305	9,189	137,162
Forecast					
2022	65	0	3,238	9,196	137,691
2023	65	0	3,264	9,248	139,313
2024	0	0	3,292	9,300	140,952
2025	0	0	3,321	9,353	142,641
2026	0	0	3,349	9,406	144,334
2027	0	0	3,379	9,460	146,002
2028	0	0	3,412	9,514	147,650
2029	0	0	3,448	9,569	149,289
2030	0	0	3,481	9,624	150,896
2031	0	0	3,516	9,679	152,431

Table 8-5 Schedule 3.1: History and Forecast of Summer Peak Demand Base Case (MW)									
(1)	(2)	(3)	(4)	(5)	(6)	(7)	(8)	(9)	(10)
Year	Total	Wholesale	Retail	Interrupt.	Residential		Commercial/Industrial		Net Firm Demand
					Load Management	Conservation	Load Management	Conservation	
2012	590	0	590	0	0	0	0	0	590
2013	602	0	602	0	0	0	0	0	602
2014	627	0	627	0	0	0	0	0	627
2015	632	0	632	0	0	0	0	0	632
2016	649	0	649	0	0	0	0	0	649
2017	644	0	644	0	0	0	0	0	644
2018	639	0	639	0	0	0	0	0	639
2019	667	0	667	0	0	0	0	0	667
2020	678	0	678	0	0	0	0	0	678
2021	692	0	692	0	0	0	0	0	692
Forecast									
2022	660	0	660	0	0	0	0	0	660
2023	662	0	662	0	0	0	0	0	662
2024	667	0	667	0	0	0	0	0	667
2025	671	0	671	0	0	0	0	0	671
2026	677	0	677	0	0	0	0	0	677
2027	682	0	682	0	0	0	0	0	682
2028	687	0	687	0	0	0	0	0	687
2029	694	0	694	0	0	0	0	0	694
2030	702	0	702	0	0	0	0	0	702
2031	707	0	707	0	0	0	0	0	707

Table 8-5a Schedule 3.1a: History and Forecast of Summer Peak Demand Low Case (MW)									
(1)	(2)	(3)	(4)	(5)	(6)	(7)	(8)	(9)	(10)
Year	Total	Wholesale	Retail	Interrupt.	Residential		Commercial/Industrial		Net Firm Demand
					Load Management	Conservation	Load Management	Conservation	
2012	590	0	590	0	0	0	0	0	590
2013	602	0	602	0	0	0	0	0	602
2014	627	0	627	0	0	0	0	0	627
2015	632	0	632	0	0	0	0	0	632
2016	649	0	649	0	0	0	0	0	649
2017	644	0	644	0	0	0	0	0	644
2018	639	0	639	0	0	0	0	0	639
2019	667	0	667	0	0	0	0	0	667
2020	678	0	678	0	0	0	0	0	678
2021	692	0	692	0	0	0	0	0	692
Forecast									
2022	656	0	656	0	0	0	0	0	656
2023	659	0	659	0	0	0	0	0	659
2024	663	0	663	0	0	0	0	0	663
2025	667	0	667	0	0	0	0	0	667
2026	673	0	673	0	0	0	0	0	673
2027	678	0	678	0	0	0	0	0	678
2028	683	0	683	0	0	0	0	0	683
2029	690	0	690	0	0	0	0	0	690
2030	697	0	697	0	0	0	0	0	697
2031	703	0	703	0	0	0	0	0	703

Table 8-5b									
Schedule 3.1b: History and Forecast of Summer Peak Demand High Case (MW)									
(1)	(2)	(3)	(4)	(5)	(6)	(7)	(8)	(9)	(10)
Year	Total	Wholesale	Retail	Interrupt.	Residential		Commercial/Industrial		Net Firm Demand
					Load Management	Conservation	Load Management	Conservation	
2012	590	0	590	0	0	0	0	0	590
2013	602	0	602	0	0	0	0	0	602
2014	627	0	627	0	0	0	0	0	627
2015	632	0	632	0	0	0	0	0	632
2016	649	0	649	0	0	0	0	0	649
2017	644	0	644	0	0	0	0	0	644
2018	639	0	639	0	0	0	0	0	639
2019	667	0	667	0	0	0	0	0	667
2020	678	0	678	0	0	0	0	0	678
2021	692	0	692	0	0	0	0	0	692
Forecast									
2022	664	0	664	0	0	0	0	0	664
2023	666	0	666	0	0	0	0	0	666
2024	671	0	671	0	0	0	0	0	671
2025	675	0	675	0	0	0	0	0	675
2026	681	0	681	0	0	0	0	0	681
2027	686	0	686	0	0	0	0	0	686
2028	692	0	692	0	0	0	0	0	692
2029	698	0	698	0	0	0	0	0	698
2030	706	0	706	0	0	0	0	0	706
2031	712	0	712	0	0	0	0	0	712

Table 8-6 Schedule 3.2: History and Forecast of Winter Peak Demand Base Case (MW)									
(1)	(2)	(3)	(4)	(5)	(6)	(7)	(8)	(9)	(10)
Year	Total	Wholesale	Retail	Interrupt.	Residential		Comm./Ind.		Net Firm Demand
					Load Management	Conservation	Load Management	Conservation	
2012/13	549	0	549	0	0	0	0	0	549
2013/14	577	0	577	0	0	0	0	0	577
2014/15	653	0	653	0	0	0	0	0	653
2015/16	583	0	583	0	0	0	0	0	583
2016/17	534	0	534	0	0	0	0	0	534
2017/18	701	0	701	0	0	0	0	0	701
2018/19	545	0	545	0	0	0	0	0	545
2019/20	600	0	600	0	0	0	0	0	600
2020/21	605	0	605	0	0	0	0	0	605
2021/22	663	0	663	0	0	0	0	0	663
Forecast									
2022/23	669	0	669	0	0	0	0	0	669
2023/24	674	0	674	0	0	0	0	0	674
2024/25	679	0	679	0	0	0	0	0	679
2025/26	683	0	683	0	0	0	0	0	683
2026/27	688	0	688	0	0	0	0	0	688
2027/28	695	0	695	0	0	0	0	0	695
2028/29	700	0	700	0	0	0	0	0	700
2029/30	704	0	704	0	0	0	0	0	704
2030/31	709	0	709	0	0	0	0	0	709
2031/32	715	0	715	0	0	0	0	0	715

Table 8-6a Schedule 3.2a: History and Forecast of Winter Peak Demand Low Case (MW)									
(1)	(2)	(3)	(4)	(5)	(6)	(7)	(8)	(9)	(10)
Year	Total	Wholesale	Retail	Interrupt.	Residential		Comm./Ind.		Net Firm Demand
					Load Management	Conservation	Load Management	Conservation	
2012/13	549	0	549	0	0	0	0	0	549
2013/14	577	0	577	0	0	0	0	0	577
2014/15	653	0	653	0	0	0	0	0	653
2015/16	583	0	583	0	0	0	0	0	583
2016/17	534	0	534	0	0	0	0	0	534
2017/18	701	0	701	0	0	0	0	0	701
2018/19	545	0	545	0	0	0	0	0	545
2019/20	600	0	600	0	0	0	0	0	600
2020/21	605	0	605	0	0	0	0	0	605
2021/22	663	0	663	0	0	0	0	0	663
Forecast									
2022/23	665	0	665	0	0	0	0	0	665
2023/24	671	0	671	0	0	0	0	0	671
2024/25	675	0	675	0	0	0	0	0	675
2025/26	679	0	679	0	0	0	0	0	679
2026/27	684	0	684	0	0	0	0	0	684
2027/28	691	0	691	0	0	0	0	0	691
2028/29	696	0	696	0	0	0	0	0	696
2029/30	700	0	700	0	0	0	0	0	700
2030/31	704	0	704	0	0	0	0	0	704
2031/32	711	0	711	0	0	0	0	0	711

Table 8-6b Schedule 3.2b: History and Forecast of Winter Peak Demand High Case (MW)									
(1)	(2)	(3)	(4)	(5)	(6)	(7)	(8)	(9)	(10)
Year	Total	Wholesale	Retail	Interrupt.	Residential		Comm./Ind.		Net Firm Demand
					Load Management	Conservation	Load Management	Conservation	
2012/13	549	0	549	0	0	0	0	0	549
2013/14	577	0	577	0	0	0	0	0	577
2014/15	653	0	653	0	0	0	0	0	653
2015/16	583	0	583	0	0	0	0	0	583
2016/17	534	0	534	0	0	0	0	0	534
2017/18	701	0	701	0	0	0	0	0	701
2018/19	545	0	545	0	0	0	0	0	545
2019/20	600	0	600	0	0	0	0	0	600
2020/21	605	0	605	0	0	0	0	0	605
2021/22	663	0	663	0	0	0	0	0	663
Forecast									
2022/23	672	0	672	0	0	0	0	0	672
2023/24	678	0	678	0	0	0	0	0	678
2024/25	683	0	683	0	0	0	0	0	683
2025/26	687	0	687	0	0	0	0	0	687
2026/27	692	0	692	0	0	0	0	0	692
2027/28	699	0	699	0	0	0	0	0	699
2028/29	704	0	704	0	0	0	0	0	704
2029/30	708	0	708	0	0	0	0	0	708
2030/31	713	0	713	0	0	0	0	0	713
2031/32	719	0	719	0	0	0	0	0	719

Table 8-7 Schedule 3.3: History and Forecast of Annual Net Energy for Load – GWh Base Case								
(1)	(2)	(3)	(4)	(5)	(6)	(7)	(8)	(9)
Year	Total Sales	Residential Conservation	Comm./Ind. Conservation	Retail	Wholesale	Utility Use & Losses	Net Energy for Load	Load Factor %
2012	2,751	0	0	2,751	0	122	2,873	54%
2013	2,831	0	0	2,831	0	88	2,919	55%
2014	2,903	0	0	2,903	0	103	3,006	55%
2015	3,034	0	0	3,034	0	92	3,126	54%
2016	3,030	0	0	3,030	0	79	3,109	55%
2017	3,018	0	0	3,018	0	68	3,086	55%
2018	3,118	0	0	3,118	0	62	3,180	55%
2019	3,117	0	0	3,117	0	73	3,190	55%
2020	3,163	0	0	3,163	0	109	3,273	55%
2021	3,210	0	0	3,210	0	95	3,304	53%
Forecast								
2022	3,155	0	0	3,155	0	84	3,239	56%
2023	3,180	0	0	3,180	0	84	3,264	56%
2024	3,208	0	0	3,208	0	84	3,292	56%
2025	3,236	0	0	3,236	0	85	3,321	56%
2026	3,263	0	0	3,263	0	86	3,349	56%
2027	3,292	0	0	3,292	0	86	3,379	57%
2028	3,324	0	0	3,324	0	87	3,411	57%
2029	3,359	0	0	3,359	0	88	3,448	57%
2030	3,391	0	0	3,391	0	90	3,481	57%
2031	3,425	0	0	3,425	0	91	3,516	57%

Table 8-7a Schedule 3.3a: History and Forecast of Annual Net Energy for Load – GWh Low Case							
(1)	(2)	(3)	(4)	(5)	(6)	(7)	(8)
Year	Total Sales	Residential Conservation	Comm./Ind. Conservation	Retail	Wholesale	Utility Use & Losses	Net Energy for Load
2012	2,751	0	0	2,751	0	122	2,873
2013	2,831	0	0	2,831	0	88	2,919
2014	2,903	0	0	2,903	0	103	3,006
2015	3,034	0	0	3,034	0	92	3,126
2016	3,030	0	0	3,030	0	79	3,109
2017	3,018	0	0	3,018	0	68	3,086
2018	3,118	0	0	3,118	0	62	3,180
2019	3,117	0	0	3,117	0	73	3,190
2020	3,163	0	0	3,163	0	109	3,273
2021	3,210	0	0	3,210	0	95	3,304
Forecast							
2022	3,138	0	0	3,138	0	84	3,222
2023	3,163	0	0	3,163	0	84	3,247
2024	3,190	0	0	3,190	0	84	3,274
2025	3,218	0	0	3,218	0	85	3,302
2026	3,244	0	0	3,244	0	85	3,329
2027	3,273	0	0	3,273	0	86	3,359
2028	3,305	0	0	3,305	0	86	3,392
2029	3,340	0	0	3,340	0	88	3,428
2030	3,371	0	0	3,371	0	89	3,460
2031	3,404	0	0	3,404	0	91	3,495

Table 8-7b Schedule 3.3b: History and Forecast of Annual Net Energy for Load – GWh High Case							
(1)	(2)	(3)	(4)	(5)	(6)	(7)	(8)
Year	Total Sales	Residential Conservation	Comm./Ind. Conservation	Retail	Wholesale	Utility Use & Losses	Net Energy for Load
2012	2,751	0	0	2,751	0	122	2,873
2013	2,831	0	0	2,831	0	88	2,919
2014	2,903	0	0	2,903	0	103	3,006
2015	3,034	0	0	3,034	0	92	3,126
2016	3,030	0	0	3,030	0	79	3,109
2017	3,018	0	0	3,018	0	68	3,086
2018	3,118	0	0	3,118	0	62	3,180
2019	3,117	0	0	3,117	0	73	3,190
2020	3,163	0	0	3,163	0	109	3,273
2021	3,210	0	0	3,210	0	95	3,304
Forecast							
2022	3,172	0	0	3,172	0	85	3,257
2023	3,198	0	0	3,198	0	85	3,282
2024	3,226	0	0	3,226	0	85	3,311
2025	3,254	0	0	3,254	0	86	3,340
2026	3,281	0	0	3,281	0	86	3,368
2027	3,311	0	0	3,311	0	87	3,398
2028	3,343	0	0	3,343	0	87	3,431
2029	3,379	0	0	3,379	0	89	3,468
2030	3,411	0	0	3,411	0	90	3,501
2031	3,445	0	0	3,445	0	92	3,537

Table 8-8

Schedule 4: Previous Year and Two Year Forecast of Retail Peak Demand and Net Energy for Load by Month

(1)	(2)	(3)	(4)	(5)	(6)	(7)
Month	2021 Actual		2022 Forecast		2023 Forecast	
	Peak Demand ¹ MW	NEL GWh	Peak Demand ¹ MW	NEL GWh	Peak Demand ¹ MW	NEL GWh
January	509	237	667	255	669	257
February	605	223	587	207	588	208
March	576	247	440	244	441	246
April	590	252	537	251	539	253
May	645	302	620	307	623	309
June	647	313	645	306	648	308
July	677	329	660	315	662	317
August	692	341	646	330	648	332
September	636	307	635	298	638	300
October	638	290	606	267	610	270
November	472	221	497	212	500	214
December	457	242	457	248	461	251
¹ Includes Conservation						

Table 8-9														
Schedule 5: Fuel Requirements														
(1)	(2)	(3)	(4)	(5)	(6)	(7)	(8)	(9)	(10)	(11)	(12)	(13)	(14)	(15)
				Calendar Year										
	Fuel Requirements	Type	UNITS	2021-Actual	2022	2023	2024	2025	2026	2027	2028	2029	2030	2031
(1)	Nuclear		Trillion Btu	0	0	0	0	0	0	0	0	0	0	0
(2)	Coal ¹		1000 Ton	192	0	0	0	0	0	0	0	0	0	0
(3)	Residual	Steam	1000 BBL	0	0	0	0	0	0	0	0	0	0	0
(4)		CC	1000 BBL	0	0	0	0	0	0	0	0	0	0	0
(5)		CT	1000 BBL	0	0	0	0	0	0	0	0	0	0	0
(6)		Total	1000 BBL	0	0	0	0	0	0	0	0	0	0	0
(7)	Distillate	Steam	1000 BBL	0	0	0	0	0	0	0	0	0	0	0
(8)		CC	1000 BBL	1	0	0	0	0	0	0	0	0	0	0
(9)		CT	1000 BBL	2	7	9	5	5	1	0	0	0	0	0
(10)		Total	1000 BBL	3	7	9	5	5	1	0	0	0	0	0
(11)	Natural Gas	Steam	1000 MCF	526	0	0	0	0	0	0	0	0	0	0
(12)		CC	1000 MCF	15,753	20,702	21,500	17,376	21,155	21,859	21,435	21,011	21,342	21,299	20,674
(13)		CT	1000 MCF	130	503	789	2,106	2,574	2,245	2,409	1,811	2,505	2,375	1,673
(14)		Total	1000 MCF	16,409	21,205	22,289	19,482	23,729	24,104	23,844	22,822	23,847	23,674	22,347
(15)	Other		Trillion Btu	0	0	0	0	0	0	0	0	0	0	0

¹ Fuel required for LAK's share (60%)

Table 8-10
Schedule 6.1: Energy Sources

(1)	(2)	(3)	(4)	(5)	(6)	(7)	(8)	(9)	(10)	(11)	(12)	(13)	(14)	(15)
	Energy Sources	Type	UNITS	Calendar Year										
				2021- Actual	2022	2023	2024	2025	2026	2027	2028	2029	2030	2031
(1)	Inter-Regional Interchange		GWh	0	0	0	0	0	0	0	0	0	0	0
(2)	Nuclear		GWh	0	0	0	0	0	0	0	0	0	0	0
(3)	Coal		GWh	434	0	0	0	0	0	0	0	0	0	0
(4)	Residual	Steam	GWh	0	0	0	0	0	0	0	0	0	0	0
(5)		CC	GWh	0	0	0	0	0	0	0	0	0	0	0
(6)		CT	GWh	0	0	0	0	0	0	0	0	0	0	0
(7)		Total	GWh	0	0	0	0	0	0	0	0	0	0	0
(8)	Distillate	Steam	GWh	0	0	0	0	0	0	0	0	0	0	0
(9)		CC	GWh	0	0	0	0	0	0	0	0	0	0	0
(10)		CT	GWh	0	4	5	3	3	1	0	0	0	0	0
(11)		Total	GWh	0	4	5	3	3	1	0	0	0	0	0
(12)	Natural Gas	Steam	GWh	0	0	0	0	0	0	0	0	0	0	0
(13)		CC	GWh	2,193	2,882	2,993	2,419	2,945	3,043	2,984	2,925	2,971	2,965	2,878
(14)		CT	GWh	15	58	91	243	297	259	278	209	289	274	193
(15)		Total	GWh	2,208	2,940	3,084	2,662	3,242	3,302	3,262	3,134	3,260	3,239	3071
(16)	NUG													
(17)	Solar			26	24	23	63	154	155	154	154	153	153	153
(18)	Other (Purchase/Sales) ¹			636	271	152	564	-78	-109	-37	123	35	89	292
(19)	Net Energy for Load		GWh	3,304	3,239	3,264	3,292	3,321	3,349	3,379	3,411	3,448	3,481	3,516

¹ Intra-Regional Purchase

Table 8-11
Schedule 6.2: Energy Sources

(1)	(2)	(3)	(4)	(5)	(6)	(7)	(8)	(9)	(10)	(11)	(12)	(13)	(14)	(15)
	Energy Source	Type	Units	Calendar Year										
				2021- Actual	2022	2023	2024	2025	2026	2027	2028	2029	2030	2031
(1)	Inter-Regional Interchange		%	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
(2)	Nuclear		%	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
(3)	Coal		%	13.1%	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%
(4)	Residual	Steam	%	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
(5)		CC	%	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
(6)		CT	%	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
(7)		Total	%	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
(8)	Distillate	Steam	%	0.00%	0.00%	0.00%	0.00%	0.00%	0.00%	0.00%	0.00%	0.00%	0.00%	0.00%
(9)		CC	%	0.00%	0.00%	0.00%	0.00%	0.00%	0.00%	0.00%	0.00%	0.00%	0.00%	0.00%
(10)		CT	%	0.00%	0.12%	0.15%	0.09%	0.09%	0.03%	0.00%	0.00%	0.00%	0.00%	0.00%
(11)		Total	%	0.00%	0.12%	0.15%	0.09%	0.09%	0.03%	0.00%	0.00%	0.00%	0.00%	0.00%
(12)	Natural Gas	Steam	%	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
(13)		CC	%	66.4%	89.0%	91.7%	73.5%	88.7%	90.9%	88.3%	85.8%	86.2%	85.2%	81.9%
(14)		CT	%	0.5%	1.8%	2.8%	7.4%	8.9%	7.7%	8.2%	6.1%	8.4%	7.9%	5.5%
(15)		Total	%	66.8%	90.8%	94.5%	80.9%	97.6%	98.6%	96.5%	91.9%	94.5%	93.0%	87.3%
(16)	NUG		%	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
	Solar		%	0.8%	0.7%	0.7%	1.9%	4.6%	4.6%	4.6%	4.5%	4.4%	4.4%	4.4%
	Other (Specify) ¹		%	19.2%	8.4%	4.7%	17.1%	-2.3%	-3.3%	-1.1%	3.6%	1.0%	2.6%	8.3%
(18)	Net Energy for Load		%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%

¹ Other = Purchase

Table 8-12

Schedule 7.1: Forecast of Capacity, Demand, and Scheduled Maintenance at Time of Summer Peak

(1)	(2)	(3)	(4)	(5)	(6)	(7)	(8)	(9)	(10)	(11)	(12)	(13)
Year	Total Installed Capacity	Firm Capacity Import	Firm Capacity Export	Projected Firm Net To Grid from NUG	Firm Contracts	Total Capacity Available	System Firm Peak Demand	Reserve Margin Before Maintenance ¹		Scheduled Maintenance	Reserve Margin After Maintenance ¹	
	MW	MW	MW	MW	MW	MW	MW	MW	%	MW	MW	%
2022	647	0	0	7	125	779	660	119	18	0	119	18
2023	647	0	0	7	125	779	662	117	18	0	117	18
2024	767	0	0	15	0	782	667	115	17	0	115	17
2025	767	0	0	32	0	799	671	128	19	0	128	19
2026	767	0	0	32	0	799	677	122	18	0	122	18
2027	767	0	0	32	0	799	682	117	17	0	117	17
2028	767	0	0	32	0	799	687	112	16	0	112	16
2029	767	0	0	32	0	799	694	105	15	0	105	15
2030	767	0	0	32	15	814	702	112	16	0	112	16
2031	767	0	0	32	15	814	707	107	15	0	107	15

¹ Includes conservation.

Table 8-13 Schedule 7.2: Forecast of Capacity, Demand, and Scheduled Maintenance at the time of Winter Peak												
(1)	(2)	(3)	(4)	(5)	(6)	(7)	(8)	(9)	(10)	(11)	(12)	(13)
Year	Total Installed Capacity	Firm Capacity Import	Firm Capacity Export	Projected Firm Net To Grid from NUG	Firm Contracts	Total Capacity Available	System Firm Peak Demand	Reserve Margin Before Maintenance ¹		Scheduled Maintenance	Reserve Margin After Maintenance ¹	
	MW	MW	MW	MW		MW	MW	MW	%	MW	MW	%
2022/23	715	0	0	0	125	840	669	171	26	0	171	26
2023/24	835	0	0	0	0	835	674	161	24	0	161	24
2024/25	835	0	0	0	0	835	679	156	23	0	156	23
2025/26	835	0	0	0	0	835	683	152	22	0	152	22
2026/27	835	0	0	0	0	835	688	147	21	0	147	21
2027/28	835	0	0	0	0	835	695	140	20	0	140	20
2028/29	835	0	0	0	0	835	700	135	19	0	135	19
2029/30	835	0	0	0	0	835	704	131	19	0	131	19
2030/31	835	0	0	0	0	835	709	126	18	0	126	18
2031/32	835	0	0	0	0	835	715	120	17	0	120	17
¹ Includes Conservation												

Table 8-14 Schedule 8.0: Planned and Prospective Generating Facility Additions and Changes														
(1)	(2)	(3)	(4)	(5)	(6)	(7)	(8)	(9)	(10)	(11)	(12)	(13)	(14)	(15)
Plant Name	Unit No.	Location	Unit Type	Fuel		Fuel Transport		Const Start	Commercial In-Service	Expected Retirement	Gen Max Nameplate	Net Capability		¹ Status
				Pri.	Alt.	Pri.	Alt.	Mo/Yr	Mo/Yr	Mo/Yr	MW	Sum MW	Win MW	
Charles Larsen Power Plant	Gas Turbine #2	Polk County	CT	NG	DFO	PL	TK	-	Nov-62	-	11.2	10	14	OS
Charles Larsen Power Plant	Gas Turbine #3	Polk County	CT	NG	DFO	PL	TK	-	Dec-62	-	11.2	9	13	OS
C.D. McIntosh Power Plant	3	Polk County	ST	BIT	-	RR	-	-	Sep-82	Apr-21	365	205	205	RE
C.D. McIntosh Power Plant	McIntosh Solar	Polk County	PV	SUN	-	-	-	-	Jan-24	-	16	16	16	P
-	-	Polk County	PV	SUN	-	-	-	-	Jan-25	-	34	34	34	P
C.D. McIntosh Power Plant	ME1-ME6	Polk County	IC	NG	-	PL	-	-	Jan-24	-	120	120	120	P
¹ Notes: OS - On long-term scheduled maintenance; RE - Retired ; P - Planned for installation														

Table 8-15		
Schedule 9.1: Status Report and Specifications of Approved Generating Facilities (McIntosh Solar)		
(1)	Plant Name and Unit Number:	McIntosh Solar
(2)	Nameplate Capacity:	16 MW-ac
(3)	Firm Summer MW	8 MW-ac
(4)	Firm Winter MW	0 MW-ac
(5)	Technology Type:	Single Axis Tracking PV
(6)	Anticipated Construction Timing:	
(7)	Field Construction Start-date:	2022
(8)	Commercial In-Service date:	Jan-24
(9)	Fuel	
(10)	Primary	Sun
(11)	Alternate	N/A
(12)	Air Pollution Control Strategy:	N/A
(13)	Cooling Method:	N/A
(14)	Total Site Area (Acre):	123
(15)	Construction Status:	Planned in Summer 2022
(16)	Certification Status: DEP	Resource Permit Application in Summer 2022
(17)	Status with Federal Agencies:	N/A
(18)	Projected Unit Performance Data:	
(19)	Planned Outage Factor (POF):	N/A
(20)	Forced Outage Factor (FOF):	N/A
(21)	Equivalent Availability Factor (EAF):	N/A
(22)	Resulting Capacity Factor (%):	25-30% (expected)
(23)	Average Net Operating Heat Rate (ANOHR):	N/A
(24)	Projected Unit Financial Data:	
(25)	Book Life:	30
(26)	Total Installed Cost* (2024 \$/kW):	N/A
(27)	Direct Construction Cost (\$/kW):	N/A
(28)	AFUDC Amount (2024\$/kW):	N/A
(29)	Escalation (\$/kW):	N/A
(30)	Fixed O&M (\$/kW-yr):	N/A
(31)	Variable O&M (\$/MWh):	N/A

Note: * The project will be under the Power Purchase Agreement with Florida Renewable Partners.

Table 8-16	
Schedule 9.1: Status Report and Specifications of Approved Generating Facilities (McIntosh RICE Engines)	
(1) Plant Name and Unit Number:	McIntosh MANIC Engines, MEI-6
(2) Nameplate Capacity:	120 MW (6 units)
(3) Firm Summer MW	120 MW
(4) Firm Winter MW	120 MW
(5) Technology Type:	Reciprocating Internal Combustion Engine (RICE)
(6) Anticipated Construction Timing:	
(7) Field Construction Start-date:	2022
(8) Commercial In-Service date:	2024
(9) Fuel	
(10) Primary	Natural Gas
(11) Alternate	N/A
(12) Air Pollution Control Strategy:	SCR [#] - anhydrous ammonia for NO _x Control
(13) Cooling Method:	N/A
(14) Total Site Area (Acres):	7.2
(15) Construction Status:	Planned
(16) Certification Status:	Air Construction permit in place from FDEP.
(17) Status with Federal Agencies:	N/A
(18) Projected Unit Performance Data:	
(19) Planned Outage Factor (POF):	2%
(20) Forced Outage Factor (FOF):	2%
(21) Equivalent Availability Factor (EAF):	98%
(22) Resulting Capacity Factor (%):	20-30% (expected)
(23) Average Net Operating Heat Rate (ANOHR):	8300 Btu/KWh
(24) Projected Unit Financial Data:	
(25) Book Life:	30
(26) Total Installed Cost* (2021 \$/kW):	1188
(27) Direct Construction Cost (\$/kW):	1119
(28) AFUDC Amount ¹ (2021\$/kW):	55
(29) Escalation ² (\$/kW):	71
(30) Fixed O&M (\$/kW-yr):	135
Variable O&M (\$/MWh):	4
(31) K-Factor	No Calculation

Note: * overnight cost without finance and escalation. ¹ Allowance for fund during construction. ² Based on escalation or inflation.

[#] Selective Catalytic Reduction

<p>Table 8-16 Schedule 10: Status Report and Specifications of Proposed Directly Associated Transmission Lines</p>		
(1)	Point of Origin and Termination:	None planned.
(2)	Number of Lines:	None planned.
(3)	Right of Way:	None planned.
(4)	Line Length:	None planned.
(5)	Voltage:	None planned.
(6)	Anticipated Construction Time:	None planned.
(7)	Anticipated Capital Investment:	None planned.
(8)	Substations:	None planned.
(9)	Participation with Other Utilities:	None planned.

8.1 Abbreviations and Descriptions

The following abbreviations are used throughout the Ten-Year Site Plan Schedules.

<u>Abbreviation</u>	<u>Description</u>
Unit Type	
CA	Combined Cycle Steam Part
GT	Combustion Gas Turbine
ST	Steam Turbine
CT	Combined Cycle Combustion Turbine
CC	Combined Cycle
IC	Internal Combustion Engine
Fuel Type	
NG	Natural Gas
DFO	Distillate Fuel Oil
RFO	Residual Fuel Oil
BIT	Bituminous Coal
WH	Waste Heat
Fuel Transportation Method	
PL	Pipeline
TK	Truck
RR	Railroad
Unit Status Code	
RE	Retired
RT	To be Retired
SB	Cold Standby (Reserve)
TS	Construction Complete, not yet in commercial operation
U	Under Construction
P	Planned for installation

Table 8-17 Schedule 10: Status Report and Specifications of Proposed Directly Associated Transmission Lines		
(1)	Point of Origin and Termination:	None planned in this current Planning Cycle.
(2)	Number of Lines:	
(3)	Right of Way:	
(4)	Line Length:	
(5)	Voltage:	
(6)	Anticipated Construction Time:	
(7)	Anticipated Capital Investment:	
(8)	Substations:	
(9)	Participation with Other Utilities:	

Table 8-1a													
Schedule 1.0: Existing Generating Facilities as of December 31, 2021													
				Fuel ⁴		Fuel Transport ⁵						Net Capability	
Plant Name	Unit No.	Location	Unit Type ³	Pri	Alt	Pri	Alt	Alt Fuel Days Use ²	Commercial In-Service Month/Year	Expected Retirement Month/Year	Gen. Max. Nameplate kW	Summer MW	Winter MW
Winston Peaking Station	1-20	21/28S/23E	IC	DFO	---	TK	---	---	12/01	Unknown	2,500 each	50	50
Plant Total												50	50
C.D. McIntosh, Jr.	D1	4-5/28S/24E	IC	DFO	---	TK	---	---	01/70	Unknown	2,600	2.5	2.5
	D2		IC	DFO	---	TK	---	---	01/70	Unknown	2,600	2.5	2.5
	GT1		GT	NG	DFO	PL	TK	---	05/73	Unknown	26,640	17	19
	GT2		GT	NG	RFO	PL	TK	---	06/20	Unknown	130,050	117	122
	3 ³		ST	BIT	---	RR	TK	---	09/82	Apr-21	219,000	205	205
	5		CT	NG	---	PL	---	---	05/01	Unknown	292,950	234	280
	5		CA	WH	---	---	---	---	05/02	Unknown	135,000	118	118
Plant Total												491	544
System Total												647	715
³ Lakeland's 60 percent portion of joint ownership with Orlando Utilities Commission.Retired in 2021.													
² Lakeland does not maintain records of the number of days that alternate fuel is used.													
³ Unit Type				⁴ Fuel Type					⁵ Fuel Transportation Method				
CA Combined Cycle Steam Part				DFO Distillate Fuel Oil					PL Pipeline				
CT Combined Cycle Combustion Turbine				RFO Residual Fuel Oil					TK Truck				
GT Combustion Gas Turbine				BIT Bituminous Coal					RR Railroad				
ST Steam Turbine				WH Waste Heat									
				NG Natural Gas									

Table 8-2

Schedule 2.1: History and Forecast of Energy Consumption and Number of Customers by Customer Class

(1)	(2)	(3)	(4)	(5)	(6)	(7)	(8)	(9)
Year	Rural & Residential					Commercial		
	Population	Members per Household	GWh	Average No. of Customers	Average kWh Consumption per Customer	GWh	Average No. of Customers	Average kWh Consumption per Customer
2012	262,288	2.59	1,343	101,252	13,264	727	11,765	61,793
2013	264,023	2.59	1,368	101,968	13,416	742	11,864	62,542
2014	271,379	2.63	1,400	103,099	13,579	752	12,022	62,552
2015	274,861	2.63	1,468	104,581	14,037	789	12,157	64,901
2016	279,331	2.64	1,473	105,932	13,905	795	12,225	65,031
2017	283,626	2.63	1,460	107,703	13,556	803	12,372	64,905
2018	288,157	2.64	1,524	109,043	13,976	813	12,543	64,817
2019	292,465	2.65	1,540	110,403	13,949	806	12,687	63,530
2020	295,899	2.64	1,612	112,175	14,370	789	12,889	61,215
2021	299,557	2.61	1,597	114,683	13,925	832	13,219	62,940
Forecast								
2022	302,985	2.66	1,568	115,191	13,612	817	13,227	61,768
2023	306,431	2.65	1,577	116,617	13,523	828	13,371	61,925
2024	309,771	2.65	1,592	118,056	13,485	836	13,518	61,843
2025	313,112	2.66	1,608	119,539	13,452	845	13,670	61,814
2026	316,542	2.66	1,624	121,024	13,419	852	13,824	61,632
2027	320,106	2.66	1,640	122,484	13,390	861	13,977	61,601
2028	323,774	2.66	1,658	123,927	13,379	870	14,128	61,580
2029	327,489	2.67	1,678	125,361	13,385	880	14,277	61,638
2030	331,200	2.67	1,696	126,764	13,379	889	14,425	61,629
2031	334,867	2.67	1,716	128,100	13,396	898	14,567	61,646

Table 8-3 Schedule 2.2: History and Forecast of Energy Consumption and Number of Customers by Customer Class							
(1)	(2)	(3)	(4)	(5)	(6)	(7)	(8)
Year	Industrial			Railroads and Railways	Street & Highway Lighting GWh	Other Sales to Public Authorities GWh	Total Sales to Ultimate Consumers GWh
	GWh	Average No. of Customers	Average kWh Consumption per Customer				
2012	579	81	7,148,148	0	33	70	2,751
2013	618	79	7,822,785	0	33	70	2,831
2014	649	77	8,428,571	0	33	70	2,903
2015	670	76	8,815,789	0	34	73	3,034
2016	655	74	8,851,351	0	34	73	3,030
2017	648	72	9,000,000	0	35	72	3,018
2018	676	74	9,135,135	0	35	70	3,118
2019	667	76	8,776,316	0	35	69	3,117
2020	660	75	8,800,000	0	35	68	3,163
2021	679	71	9,563,380	0	35	67	3,210
Forecast							
2022	667	77	8,662,338	0	35	67	3,154
2023	673	77	8,740,260	0	35	67	3,180
2024	678	78	8,692,308	0	35	67	3,208
2025	681	79	8,620,253	0	35	67	3,236
2026	685	80	8,562,500	0	35	67	3,263
2027	690	81	8,518,519	0	35	67	3,293
2028	695	82	8,475,610	0	35	67	3,325
2029	700	83	8,433,735	0	35	67	3,360
2030	704	84	8,380,952	0	35	67	3,391
2031	709	85	8,341,176	0	35	67	3,425

Table 8-4					
Schedule 2.3: History and Forecast of Energy Consumption and Number of Customers by Customer Class					
(1)	(2)	(3)	(4)	(5)	(6)
Year	Wholesale Purchases for Resale GWh	Wholesale Sales for Resale GWh	Net Energy for Load GWh	Other Customers (Average No.)	Total No. of Customers
2012	0	0	2,873	8,953	122,050
2013	0	0	2,919	8,892	122,803
2014	0	0	3,006	8,820	124,019
2015	0	0	3,126	8,860	125,674
2016	0	0	3,109	8,921	127,152
2017	0	0	3,086	8,966	129,113
2018	0	0	3,180	8,997	130,658
2019	0	0	3,189	9,051	132,217
2020	0	0	3,273	9,182	134,320
2021	65	0	3,305	9,189	137,162
Forecast					
2022	65	0	3,238	9,196	137,691
2023	65	0	3,264	9,248	139,313
2024	0	0	3,292	9,300	140,952
2025	0	0	3,321	9,353	142,641
2026	0	0	3,349	9,406	144,334
2027	0	0	3,379	9,460	146,002
2028	0	0	3,412	9,514	147,650
2029	0	0	3,448	9,569	149,289
2030	0	0	3,481	9,624	150,896
2031	0	0	3,516	9,679	152,431

Table 8-5 Schedule 3.1: History and Forecast of Summer Peak Demand Base Case (MW)									
(1)	(2)	(3)	(4)	(5)	(6)		(7)		(10)
Year	Total	Wholesale	Retail	Interrupt.	Residential		Commercial/Industrial		Net Firm Demand
					Load Management	Conservation	Load Management	Conservation	
2012	590	0	590	0	0	0	0	0	590
2013	602	0	602	0	0	0	0	0	602
2014	627	0	627	0	0	0	0	0	627
2015	632	0	632	0	0	0	0	0	632
2016	649	0	649	0	0	0	0	0	649
2017	644	0	644	0	0	0	0	0	644
2018	639	0	639	0	0	0	0	0	639
2019	667	0	667	0	0	0	0	0	667
2020	678	0	678	0	0	0	0	0	678
2021	692	0	692	0	0	0	0	0	692
Forecast									
2022	660	0	660	0	0	0	0	0	660
2023	662	0	662	0	0	0	0	0	662
2024	667	0	667	0	0	0	0	0	667
2025	671	0	671	0	0	0	0	0	671
2026	677	0	677	0	0	0	0	0	677
2027	682	0	682	0	0	0	0	0	682
2028	687	0	687	0	0	0	0	0	687
2029	694	0	694	0	0	0	0	0	694
2030	702	0	702	0	0	0	0	0	702
2031	707	0	707	0	0	0	0	0	707

Table 8-5a Schedule 3.1a: History and Forecast of Summer Peak Demand Low Case (MW)									
(1)	(2)	(3)	(4)	(5)	(6)		(7)		(10)
Year	Total	Wholesale	Retail	Interrupt.	Residential		Commercial/Industrial		Net Firm Demand
					Load Management	Conservation	Load Management	Conservation	
2012	590	0	590	0	0	0	0	0	590
2013	602	0	602	0	0	0	0	0	602
2014	627	0	627	0	0	0	0	0	627
2015	632	0	632	0	0	0	0	0	632
2016	649	0	649	0	0	0	0	0	649
2017	644	0	644	0	0	0	0	0	644
2018	639	0	639	0	0	0	0	0	639
2019	667	0	667	0	0	0	0	0	667
2020	678	0	678	0	0	0	0	0	678
2021	692	0	692	0	0	0	0	0	692
Forecast									
2022	656	0	656	0	0	0	0	0	656
2023	659	0	659	0	0	0	0	0	659
2024	663	0	663	0	0	0	0	0	663
2025	667	0	667	0	0	0	0	0	667
2026	673	0	673	0	0	0	0	0	673
2027	678	0	678	0	0	0	0	0	678
2028	683	0	683	0	0	0	0	0	683
2029	690	0	690	0	0	0	0	0	690
2030	697	0	697	0	0	0	0	0	697
2031	703	0	703	0	0	0	0	0	703

Table 8-5b Schedule 3.1b: History and Forecast of Summer Peak Demand High Case (MW)									
(1)	(2)	(3)	(4)	(5)	(6)		(7)		(10)
Year	Total	Wholesale	Retail	Interrupt.	Residential		Commercial/Industrial		Net Firm Demand
					Load Management	Conservation	Load Management	Conservation	
2012	590	0	590	0	0	0	0	0	590
2013	602	0	602	0	0	0	0	0	602
2014	627	0	627	0	0	0	0	0	627
2015	632	0	632	0	0	0	0	0	632
2016	649	0	649	0	0	0	0	0	649
2017	644	0	644	0	0	0	0	0	644
2018	639	0	639	0	0	0	0	0	639
2019	667	0	667	0	0	0	0	0	667
2020	678	0	678	0	0	0	0	0	678
2021	692	0	692	0	0	0	0	0	692
Forecast									
2022	664	0	664	0	0	0	0	0	664
2023	666	0	666	0	0	0	0	0	666
2024	671	0	671	0	0	0	0	0	671
2025	675	0	675	0	0	0	0	0	675
2026	681	0	681	0	0	0	0	0	681
2027	686	0	686	0	0	0	0	0	686
2028	692	0	692	0	0	0	0	0	692
2029	698	0	698	0	0	0	0	0	698
2030	706	0	706	0	0	0	0	0	706
2031	712	0	712	0	0	0	0	0	712

Table 8-6 Schedule 3.2: History and Forecast of Winter Peak Demand Base Case (MW)									
(1)	(2)	(3)	(4)	(5)	(6)	(7)	(8)	(9)	(10)
Year	Total	Wholesale	Retail	Interrupt.	Residential		Comm./Ind.		Net Firm Demand
					Load Management	Conservation	Load Management	Conservation	
2012/13	549	0	549	0	0	0	0	0	549
2013/14	577	0	577	0	0	0	0	0	577
2014/15	653	0	653	0	0	0	0	0	653
2015/16	583	0	583	0	0	0	0	0	583
2016/17	534	0	534	0	0	0	0	0	534
2017/18	701	0	701	0	0	0	0	0	701
2018/19	545	0	545	0	0	0	0	0	545
2019/20	600	0	600	0	0	0	0	0	600
2020/21	605	0	605	0	0	0	0	0	605
2021/22	663	0	663	0	0	0	0	0	663
Forecast									
2022/23	669	0	669	0	0	0	0	0	669
2023/24	674	0	674	0	0	0	0	0	674
2024/25	679	0	679	0	0	0	0	0	679
2025/26	683	0	683	0	0	0	0	0	683
2026/27	688	0	688	0	0	0	0	0	688
2027/28	695	0	695	0	0	0	0	0	695
2028/29	700	0	700	0	0	0	0	0	700
2029/30	704	0	704	0	0	0	0	0	704
2030/31	709	0	709	0	0	0	0	0	709
2031/32	715	0	715	0	0	0	0	0	715

Table 8-6a Schedule 3.2a: History and Forecast of Winter Peak Demand Low Case (MW)									
(1)	(2)	(3)	(4)	(5)	(6)	(7)	(8)	(9)	(10)
Year	Total	Wholesale	Retail	Interrupt.	Residential		Comm./Ind.		Net Firm Demand
					Load Management	Conservation	Load Management	Conservation	
2012/13	549	0	549	0	0	0	0	0	549
2013/14	577	0	577	0	0	0	0	0	577
2014/15	653	0	653	0	0	0	0	0	653
2015/16	583	0	583	0	0	0	0	0	583
2016/17	534	0	534	0	0	0	0	0	534
2017/18	701	0	701	0	0	0	0	0	701
2018/19	545	0	545	0	0	0	0	0	545
2019/20	600	0	600	0	0	0	0	0	600
2020/21	605	0	605	0	0	0	0	0	605
2021/22	663	0	663	0	0	0	0	0	663
Forecast									
2022/23	665	0	665	0	0	0	0	0	665
2023/24	671	0	671	0	0	0	0	0	671
2024/25	675	0	675	0	0	0	0	0	675
2025/26	679	0	679	0	0	0	0	0	679
2026/27	684	0	684	0	0	0	0	0	684
2027/28	691	0	691	0	0	0	0	0	691
2028/29	696	0	696	0	0	0	0	0	696
2029/30	700	0	700	0	0	0	0	0	700
2030/31	704	0	704	0	0	0	0	0	704
2031/32	711	0	711	0	0	0	0	0	711

Table 8-6b Schedule 3.2b: History and Forecast of Winter Peak Demand High Case (MW)									
(1)	(2)	(3)	(4)	(5)	(6)	(7)	(8)	(9)	(10)
Year	Total	Wholesale	Retail	Interrupt.	Residential		Comm./Ind.		Net Firm Demand
					Load Management	Conservation	Load Management	Conservation	
2012/13	549	0	549	0	0	0	0	0	549
2013/14	577	0	577	0	0	0	0	0	577
2014/15	653	0	653	0	0	0	0	0	653
2015/16	583	0	583	0	0	0	0	0	583
2016/17	534	0	534	0	0	0	0	0	534
2017/18	701	0	701	0	0	0	0	0	701
2018/19	545	0	545	0	0	0	0	0	545
2019/20	600	0	600	0	0	0	0	0	600
2020/21	605	0	605	0	0	0	0	0	605
2021/22	663	0	663	0	0	0	0	0	663
Forecast									
2022/23	672	0	672	0	0	0	0	0	672
2023/24	678	0	678	0	0	0	0	0	678
2024/25	683	0	683	0	0	0	0	0	683
2025/26	687	0	687	0	0	0	0	0	687
2026/27	692	0	692	0	0	0	0	0	692
2027/28	699	0	699	0	0	0	0	0	699
2028/29	704	0	704	0	0	0	0	0	704
2029/30	708	0	708	0	0	0	0	0	708
2030/31	713	0	713	0	0	0	0	0	713
2031/32	719	0	719	0	0	0	0	0	719

Table 8-7 Schedule 3.3: History and Forecast of Annual Net Energy for Load – GWh Base Case								
(1)	(2)	(3)	(4)	(5)	(6)	(7)	(8)	(9)
Year	Total Sales	Residential Conservation	Comm./Ind. Conservation	Retail	Wholesale	Utility Use & Losses	Net Energy for Load	Load Factor %
2012	2,751	0	0	2,751	0	122	2,873	54%
2013	2,831	0	0	2,831	0	88	2,919	55%
2014	2,903	0	0	2,903	0	103	3,006	55%
2015	3,034	0	0	3,034	0	92	3,126	54%
2016	3,030	0	0	3,030	0	79	3,109	55%
2017	3,018	0	0	3,018	0	68	3,086	55%
2018	3,118	0	0	3,118	0	62	3,180	55%
2019	3,117	0	0	3,117	0	73	3,190	55%
2020	3,163	0	0	3,163	0	109	3,273	55%
2021	3,210	0	0	3,210	0	95	3,304	53%
Forecast								
2022	3,155	0	0	3,155	0	84	3,239	56%
2023	3,180	0	0	3,180	0	84	3,264	56%
2024	3,208	0	0	3,208	0	84	3,292	56%
2025	3,236	0	0	3,236	0	85	3,321	56%
2026	3,263	0	0	3,263	0	86	3,349	56%
2027	3,292	0	0	3,292	0	86	3,379	57%
2028	3,324	0	0	3,324	0	87	3,411	57%
2029	3,359	0	0	3,359	0	88	3,448	57%
2030	3,391	0	0	3,391	0	90	3,481	57%
2031	3,425	0	0	3,425	0	91	3,516	57%

Table 8-7a Schedule 3.3a: History and Forecast of Annual Net Energy for Load – GWh Low Case							
(1)	(2)	(3)	(4)	(5)	(6)	(7)	(8)
Year	Total Sales	Residential Conservation	Comm./Ind. Conservation	Retail	Wholesale	Utility Use & Losses	Net Energy for Load
2012	2,751	0	0	2,751	0	122	2,873
2013	2,831	0	0	2,831	0	88	2,919
2014	2,903	0	0	2,903	0	103	3,006
2015	3,034	0	0	3,034	0	92	3,126
2016	3,030	0	0	3,030	0	79	3,109
2017	3,018	0	0	3,018	0	68	3,086
2018	3,118	0	0	3,118	0	62	3,180
2019	3,117	0	0	3,117	0	73	3,190
2020	3,163	0	0	3,163	0	109	3,273
2021	3,210	0	0	3,210	0	95	3,304
Forecast							
2022	3,138	0	0	3,138	0	84	3,222
2023	3,163	0	0	3,163	0	84	3,247
2024	3,190	0	0	3,190	0	84	3,274
2025	3,218	0	0	3,218	0	85	3,302
2026	3,244	0	0	3,244	0	85	3,329
2027	3,273	0	0	3,273	0	86	3,359
2028	3,305	0	0	3,305	0	86	3,392
2029	3,340	0	0	3,340	0	88	3,428
2030	3,371	0	0	3,371	0	89	3,460
2031	3,404	0	0	3,404	0	91	3,495

Table 8-7b Schedule 3.3b: History and Forecast of Annual Net Energy for Load – GWh High Case							
(1)	(2)	(3)	(4)	(5)	(6)	(7)	(8)
Year	Total Sales	Residential Conservation	Comm./Ind. Conservation	Retail	Wholesale	Utility Use & Losses	Net Energy for Load
2012	2,751	0	0	2,751	0	122	2,873
2013	2,831	0	0	2,831	0	88	2,919
2014	2,903	0	0	2,903	0	103	3,006
2015	3,034	0	0	3,034	0	92	3,126
2016	3,030	0	0	3,030	0	79	3,109
2017	3,018	0	0	3,018	0	68	3,086
2018	3,118	0	0	3,118	0	62	3,180
2019	3,117	0	0	3,117	0	73	3,190
2020	3,163	0	0	3,163	0	109	3,273
2021	3,210	0	0	3,210	0	95	3,304
Forecast							
2022	3,172	0	0	3,172	0	85	3,257
2023	3,198	0	0	3,198	0	85	3,282
2024	3,226	0	0	3,226	0	85	3,311
2025	3,254	0	0	3,254	0	86	3,340
2026	3,281	0	0	3,281	0	86	3,368
2027	3,311	0	0	3,311	0	87	3,398
2028	3,343	0	0	3,343	0	87	3,431
2029	3,379	0	0	3,379	0	89	3,468
2030	3,411	0	0	3,411	0	90	3,501
2031	3,445	0	0	3,445	0	92	3,537

Table 8-8

Schedule 4: Previous Year and Two Year Forecast of Retail Peak Demand and Net Energy for Load by Month

(1)	(2)	(3)	(4)	(5)	(6)	(7)
Month	2021 Actual		2022 Forecast		2023 Forecast	
	Peak Demand ¹ MW	NEL GWh	Peak Demand ¹ MW	NEL GWh	Peak Demand ¹ MW	NEL GWh
January	509	237	667	255	669	257
February	605	223	587	207	588	208
March	576	247	440	244	441	246
April	590	252	537	251	539	253
May	645	302	620	307	623	309
June	647	313	645	306	648	308
July	677	329	660	315	662	317
August	692	341	646	330	648	332
September	636	307	635	298	638	300
October	638	290	606	267	610	270
November	472	221	497	212	500	214
December	457	242	457	248	461	251

¹Includes Conservation

Table 8-9														
Schedule 5: Fuel Requirements														
(1)	(2)	(3)	(4)	(5)	(6)	(7)	(8)	(9)	(10)	(11)	(12)	(13)	(14)	(15)
				Calendar Year										
	Fuel Requirements	Type	UNITS	2021-Actual	2022	2023	2024	2025	2026	2027	2028	2029	2030	2031
(1)	Nuclear		Trillion Btu	0	0	0	0	0	0	0	0	0	0	0
(2)	Coal ¹		1000 Ton	192	0	0	0	0	0	0	0	0	0	0
(3)	Residual	Steam	1000 BBL	0	0	0	0	0	0	0	0	0	0	0
(4)		CC	1000 BBL	0	0	0	0	0	0	0	0	0	0	0
(5)		CT	1000 BBL	0	0	0	0	0	0	0	0	0	0	0
(6)		Total	1000 BBL	0	0	0	0	0	0	0	0	0	0	0
(7)	Distillate	Steam	1000 BBL	0	0	0	0	0	0	0	0	0	0	0
(8)		CC	1000 BBL	1	0	0	0	0	0	0	0	0	0	0
(9)		CT	1000 BBL	2	7	9	5	5	1	0	0	0	0	0
(10)		Total	1000 BBL	3	7	9	5	5	1	0	0	0	0	0
(11)	Natural Gas	Steam	1000 MCF	526	0	0	0	0	0	0	0	0	0	0
(12)		CC	1000 MCF	15,753	20,702	21,500	17,376	21,155	21,859	21,435	21,011	21,342	21,299	20,674
(13)		CT	1000 MCF	130	503	789	2,106	2,574	2,245	2,409	1,811	2,505	2,375	1,673
(14)		Total	1000 MCF	16,409	21,205	22,289	19,482	23,729	24,104	23,844	22,822	23,847	23,674	22,347
(15)	Other		Trillion Btu	0	0	0	0	0	0	0	0	0	0	0
¹ Fuel required for LAK's share (60%)														

Table 8-10
Schedule 6.1: Energy Sources

(1)	(2)	(3)	(4)	(5)	(6)	(7)	(8)	(9)	(10)	(11)	(12)	(13)	(14)	(15)
	Energy Sources	Type	UNITS	Calendar Year										
				2021- Actual	2022	2023	2024	2025	2026	2027	2028	2029	2030	2031
(1)	Inter-Regional Interchange		GWh	0	0	0	0	0	0	0	0	0	0	0
(2)	Nuclear		GWh	0	0	0	0	0	0	0	0	0	0	0
(3)	Coal		GWh	434	0	0	0	0	0	0	0	0	0	0
(4)	Residual	Steam	GWh	0	0	0	0	0	0	0	0	0	0	0
(5)		CC	GWh	0	0	0	0	0	0	0	0	0	0	0
(6)		CT	GWh	0	0	0	0	0	0	0	0	0	0	0
(7)		Total	GWh	0	0	0	0	0	0	0	0	0	0	0
(8)	Distillate	Steam	GWh	0	0	0	0	0	0	0	0	0	0	0
(9)		CC	GWh	0	0	0	0	0	0	0	0	0	0	0
(10)		CT	GWh	0	4	5	3	3	1	0	0	0	0	0
(11)		Total	GWh	0	4	5	3	3	1	0	0	0	0	0
(12)	Natural Gas	Steam	GWh	0	0	0	0	0	0	0	0	0	0	0
(13)		CC	GWh	2,193	2,882	2,993	2,419	2,945	3,043	2,984	2,925	2,971	2,965	2,878
(14)		CT	GWh	15	58	91	243	297	259	278	209	289	274	193
(15)		Total	GWh	2,208	2,940	3,084	2,662	3,242	3,302	3,262	3,134	3,260	3,239	3,071
(16)	NUG													
(17)	Solar			26	24	23	63	154	155	154	154	153	153	153
(18)	Other (Purchase/Sales) ¹			636	271	152	564	-78	-109	-37	123	35	89	292
(19)	Net Energy for Load		GWh	3,304	3,239	3,264	3,292	3,321	3,349	3,379	3,411	3,448	3,481	3,516

¹ Intra-Regional Purchase

Table 8-11
Schedule 6.2: Energy Sources

(1)	(2)	(3)	(4)	(5)	(6)	(7)	(8)	(9)	(10)	(11)	(12)	(13)	(14)	(15)
	Energy Source	Type	Units	Calendar Year										
				2021- Actual	2022	2023	2024	2025	2026	2027	2028	2029	2030	2031
(1)	Inter-Regional Interchange		%	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
(2)	Nuclear		%	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
(3)	Coal		%	13.1%	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%
(4)	Residual	Steam	%	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
(5)		CC	%	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
(6)		CT	%	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
(7)		Total	%	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
(8)	Distillate	Steam	%	0.00%	0.00%	0.00%	0.00%	0.00%	0.00%	0.00%	0.00%	0.00%	0.00%	0.00%
(9)		CC	%	0.00%	0.00%	0.00%	0.00%	0.00%	0.00%	0.00%	0.00%	0.00%	0.00%	0.00%
(10)		CT	%	0.00%	0.12%	0.15%	0.09%	0.09%	0.03%	0.00%	0.00%	0.00%	0.00%	0.00%
(11)		Total	%	0.00%	0.12%	0.15%	0.09%	0.09%	0.03%	0.00%	0.00%	0.00%	0.00%	0.00%
(12)	Natural Gas	Steam	%	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
(13)		CC	%	66.4%	89.0%	91.7%	73.5%	88.7%	90.9%	88.3%	85.8%	86.2%	85.2%	81.9%
(14)		CT	%	0.5%	1.8%	2.8%	7.4%	8.9%	7.7%	8.2%	6.1%	8.4%	7.9%	5.5%
(15)		Total	%	66.8%	90.8%	94.5%	80.9%	97.6%	98.6%	96.5%	91.9%	94.5%	93.0%	87.3%
(16)	NUG		%	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
	Solar		%	0.8%	0.7%	0.7%	1.9%	4.6%	4.6%	4.6%	4.5%	4.4%	4.4%	4.4%
	Other (Specify) ¹		%	19.2%	8.4%	4.7%	17.1%	-2.3%	-3.3%	-1.1%	3.6%	1.0%	2.6%	8.3%
(18)	Net Energy for Load		%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%
Other = Purchase														

Table 8-12

Schedule 7.1: Forecast of Capacity, Demand, and Scheduled Maintenance at Time of Summer Peak

(1)	(2)	(3)	(4)	(5)	(6)	(7)	(8)	(9)	(10)	(11)	(12)	(13)
Year	Total Installed Capacity	Firm Capacity Import	Firm Capacity Export	Projected Firm Net To Grid from NUG	Firm Contracts	Total Capacity Available	System Firm Peak Demand	Reserve Margin Before Maintenance ¹		Scheduled Maintenance	Reserve Margin After Maintenance ¹	
	MW	MW	MW	MW	MW	MW	MW	MW	%	MW	MW	%
2022	647	0	0	7	125	779	660	119	18	0	119	18
2023	647	0	0	7	125	779	662	117	18	0	117	18
2024	767	0	0	15	0	782	667	115	17	0	115	17
2025	767	0	0	32	0	799	671	128	19	0	128	19
2026	767	0	0	32	0	799	677	122	18	0	122	18
2027	767	0	0	32	0	799	682	117	17	0	117	17
2028	767	0	0	32	0	799	687	112	16	0	112	16
2029	767	0	0	32	0	799	694	105	15	0	105	15
2030	767	0	0	32	15	814	702	112	16	0	112	16
2031	767	0	0	32	15	814	707	107	15	0	107	15

¹ Includes conservation.

Table 8-13
Schedule 7.2: Forecast of Capacity, Demand, and Scheduled Maintenance at the time of Winter Peak

(1)	(2)	(3)	(4)	(5)	(6)	(7)	(8)	(9)	(10)	(11)	(12)	(13)
Year	Total Installed Capacity	Firm Capacity Import	Firm Capacity Export	Projected Firm Net To Grid from NUG	Firm Contracts	Total Capacity Available	System Firm Peak Demand	Reserve Margin Before Maintenance ¹		Scheduled Maintenance	Reserve Margin After Maintenance ¹	
	MW	MW	MW	MW		MW	MW	MW	%	MW	MW	%
2022/23	715	0	0	0	125	840	669	171	26	0	171	26
2023/24	835	0	0	0	0	835	674	161	24	0	161	24
2024/25	835	0	0	0	0	835	679	156	23	0	156	23
2025/26	835	0	0	0	0	835	683	152	22	0	152	22
2026/27	835	0	0	0	0	835	688	147	21	0	147	21
2027/28	835	0	0	0	0	835	695	140	20	0	140	20
2028/29	835	0	0	0	0	835	700	135	19	0	135	19
2029/30	835	0	0	0	0	835	704	131	19	0	131	19
2030/31	835	0	0	0	0	835	709	126	18	0	126	18
2031/32	835	0	0	0	0	835	715	120	17	0	120	17

¹Includes Conservation

Table 8-14
Schedule 8.0: Planned and Prospective Generating Facility Additions and Changes

(1)	(2)	(3)	(4)	(5)	(6)	(7)	(8)	(9)	(10)	(11)	(12)	(13)	(14)	(15)
Plant Name	Unit No.	Location	Unit Type	Fuel		Fuel Transport		Const Start	Commercial In-Service	Expected Retirement	Gen Max Nameplate	Net Capability		¹ Status
				Pri.	Alt.	Pri.	Alt.	Mo/Yr	Mo/Yr	Mo/Yr	MW	Sum MW	Win MW	
Charles Larsen Power Plant	Gas Turbine #2	Polk County	CT	NG	DFO	PL	TK	-	Nov-62	-	11.2	10	14	OS
Charles Larsen Power Plant	Gas Turbine #3	Polk County	CT	NG	DFO	PL	TK	-	Dec-62	-	11.2	9	13	OS
C.D. McIntosh Power Plant	3	Polk County	ST	BIT	-	RR	-	-	Sep-82	Apr-21	365	205	205	RE

Table 8-15		
Schedule 9.1: Status Report and Specifications of Approved Generating Facilities (McIntosh Solar)		
(1)	Plant Name and Unit Number:	McIntosh Solar
(2)	Nameplate Capacity:	16 MW-ac
(3)	Firm Summer MW	8 MW-ac
(4)	Firm Winter MW	0 MW-ac
(5)	Technology Type:	Single Axis Tracking PV
(6)	Anticipated Construction Timing:	
(7)	Field Construction Start-date:	2022
(8)	Commercial In-Service date:	Jan-24
(9)	Fuel	
(10)	Primary	Sun
(11)	Alternate	N/A
(12)	Air Pollution Control Strategy:	N/A
(13)	Cooling Method:	N/A
(14)	Total Site Area (Acre):	123
(15)	Construction Status:	Planned in Summer 2022
(16)	Certification Status: DEP	Resource Permit Application in Summer 2022
(17)	Status with Federal Agencies:	N/A
(18)	Projected Unit Performance Data:	
(19)	Planned Outage Factor (POF):	N/A
(20)	Forced Outage Factor (FOF):	N/A
(21)	Equivalent Availability Factor (EAF):	N/A
(22)	Resulting Capacity Factor (%):	25-30% (expected)
(23)	Average Net Operating Heat Rate (ANOHR):	N/A
(24)	Projected Unit Financial Data:	
(25)	Book Life:	30
(26)	Total Installed Cost* (2024 \$/kW):	N/A
(27)	Direct Construction Cost (\$/kW):	N/A
(28)	AFUDC Amount (2024\$/kW):	N/A
(29)	Escalation (\$/kW):	N/A
(30)	Fixed O&M (\$/kW-yr):	N/A
(31)	Variable O&M (\$/MWh):	N/A

C:\Users\cdem\AppData\Local\Microsoft\Windows\NetCache\Content.Outlook\SKTSEYSP\LAKELAND ELECTRIC 2022 TYSP Schedules

Note: * The project will be under the Power Purchase Agreement with Florida Renewable Partners.

Table 8-16	
Schedule 9.2: Status Report and Specifications of Approved Generating Facilities (McIntosh RICE Engines)	
(1) Plant Name and Unit Number:	McIntosh MAN IC Engines, ME1-6
(2) Nameplate Capacity:	120 MW (6 units)
(3) Firm Summer MW	120 MW
(4) Firm Winter MW	120 MW
(5) Technology Type:	Reciprocating Internal Combustion Engine (RICE)
(6) Anticipated Construction Timing:	
(7) Field Construction Start-date:	2022
(8) Commercial In-Service date:	2024
(9) Fuel	
(10) Primary	Natural Gas
(11) Alternate	N/A
(12) Air Pollution Control Strategy:	SCR [#] - anhydrous ammonia for NOx Control
(13) Cooling Method:	N/A
(14) Total Site Area (Acres):	7.2
(15) Construction Status:	Planned
(16) Certification Status:	Air Construction permit in place from FDEP.
(17) Status with Federal Agencies:	N/A
(18) Projected Unit Performance Data:	
(19) Planned Outage Factor (POF):	2%
(20) Forced Outage Factor (FOF):	2%
(21) Equivalent Availability Factor (EAF):	98%
(22) Resulting Capacity Factor (%):	20-30% (expected)
(23) Average Net Operating Heat Rate (ANOHR):	8300 Btu/KWh
(24) Projected Unit Financial Data:	
(25) Book Life:	30
(26) Total Installed Cost* (2021 \$/kW):	1188
(27) Direct Construction Cost (\$/kW):	1119
(28) AFUDC Amount ¹ (2021\$/kW):	55
(29) Escalation ² (\$/kW):	71
(30) Fixed O&M (\$/kW-yr):	135
Variable O&M (\$/MWh):	4
(31) K-Factor	No Calculation

C:\Users\clem\AppData\Local\Microsoft\Windows\NetCache\Content.Outlook\KITEVSP\AKELAND-ELEC-2022-01-15\Schedules

[#] Selective Catalytic Reduction