

# AUSLEY & McMULLEN

ATTORNEYS AND COUNSELORS AT LAW

123 SOUTH CALHOUN STREET  
P.O. BOX 391 (ZIP 32302)  
TALLAHASSEE, FLORIDA 32301  
(850) 224-9115 FAX (850) 222-7560

April 1, 2022

**VIA EMAIL**

Mr. Donald Phillips  
Engineering Specialist  
Division of Engineering  
Florida Public Service Commission  
2540 Shumard Oak Boulevard  
Tallahassee, FL 32399-0850  
[dphillip@psc.state.fl.us](mailto:dphillip@psc.state.fl.us)


Re: Review of 2022 Ten-Year Site Plans – First Data Request (Nos. 1-95)  
Undocketed 20220000-OT

Dear Mr. Phillips:

Pursuant to your email dated March 7, 2022, attached is Tampa Electric Company's responses to Staff's First Data Request (Nos. 1-2) regarding the company's 2022 Ten-Year Site Plan, as filed with the FPSC today.

Thank you for your assistance in connection with this matter.

Sincerely,

  
Malcolm N. Means

MNM/bmp  
Attachment  
cc: TECO Regulatory Department

# TEN-YEAR SITE PLAN

JANUARY 2022 - DECEMBER 2031

*For Electrical Generating Facilities and Associated Transmission Lines*



Tampa Electric Company

# Ten-Year Site Plan

For Electrical Generating Facilities and Associated Transmission Lines  
January 2022 to December 2031

*April 1, 2022*

THIS PAGE INTENTIONALLY LEFT BLANK

# TABLE OF CONTENTS

---

Executive Summary.....	1
Chapter I: Description of Existing Facilities.....	3
Chapter II: Tampa Electric Company Forecasting Methodology .....	7
RETAIL LOAD .....	7
1. <i>Economic Analysis</i> .....	8
2. <i>Customer Multiregression Model</i> .....	8
3. <i>Energy Multiregression Model</i> .....	9
4. <i>Peak Demand Multiregression Model</i> .....	12
5. <i>Interruptible Demand and Energy Analysis</i> .....	12
6. <i>Roof Top Solar</i> .....	12
7. <i>Electric Vehicle</i> .....	12
8. <i>Conservation, Load Management and Cogeneration Programs</i> .....	13
BASE CASE FORECAST ASSUMPTIONS .....	18
RETAIL LOAD .....	18
1. <i>Population and Households</i> .....	18
2. <i>Commercial, Industrial and Governmental Employment</i> .....	18
3. <i>Commercial, Industrial and Governmental Output</i> .....	18
4. <i>Real Household Income</i> .....	18
5. <i>Price of Electricity</i> .....	18
6. <i>Appliance Efficiency Standards</i> .....	19
7. <i>Weather</i> .....	19
HIGH AND LOW SCENARIO FOCUS ASSUMPTIONS .....	19
HISTORY AND FORECAST OF ENERGY USE.....	19
1. <i>Retail Energy</i> .....	19
2. <i>Wholesale Energy</i> .....	19
HISTORY AND FORECAST OF PEAK LOADS.....	20
Chapter III: Integrated Resource Planning Processes.....	21
FINANCIAL ASSUMPTIONS .....	23
FUEL FORECAST.....	23
TEC RENEWABLE RESOURCES AND STORAGE TECHNOLOGY INITIATIVES .....	24
1. <i>Renewable Energy Initiatives</i> .....	24
2. <i>Storage Technology Initiatives</i> .....	25
3. <i>Electric Vehicle Initiatives</i> .....	25
GENERATING UNIT PERFORMANCE ASSUMPTIONS.....	26

GENERATION RELIABILITY CRITERIA .....	26
1. <i>Reserve Margin</i> .....	26
2. <i>Winter Reliability Assessment</i> .....	27
SUPPLY-SIDE RESOURCES PROCUREMENT PROCESS.....	27
TRANSMISSION PLANNING - CONSTRAINTS AND IMPACTS .....	27
TRANSMISSION PLANNING RELIABILITY CRITERIA.....	27
1. <i>Transmission</i> .....	27
2. <i>Available Transmission Transfer Capability (ATC) Criteria</i> .....	28
TRANSMISSION SYSTEM PLANNING ASSESSMENT PRACTICES .....	28
1. <i>Base Case Operating Conditions</i> .....	28
2. <i>Single Contingency Planning Criteria</i> .....	28
3. <i>Multiple Contingency Planning Criteria</i> .....	29
4. <i>Transmission Construction and Upgrade Plans</i> .....	29
ENERGY EFFICIENCY, CONSERVATION, AND ENERGY SAVINGS DURABILITY .....	29
Chapter IV: Forecast of Electric Power, Demand and Energy Consumption.....	30
Chapter V: Forecast of Facilities Requirements.....	55
COGENERATION .....	55
FIRM INTERCHANGE SALES AND PURCHASES .....	56
FUEL REQUIREMENTS .....	56
ENVIRONMENTAL CONSIDERATIONS .....	56
Chapter VI: Environmental and Land Use Information .....	91

# LIST OF SCHEDULES & TABLES

---

Schedule 1:	Existing Generating Facilities .....	4
Table III-1:	Comparison of Achieved MW and GWh Reductions with Florida Public Service Commission Goals .....	17
Schedule 2.1:	History and Forecast of Energy Consumption and Number of Customers by Customer Class (Base, High & Low) .....	31 to 33
Schedule 2.2:	History and Forecast of Energy Consumption and Number of Customers by Customer Class (Base, High & Low) .....	34 to 36
Schedule 2.3:	History and Forecast of Energy Consumption and Number of Customers by Customer Class (Base, High & Low) .....	37 to 39
Schedule 3.1:	History and Forecast of Summer Peak Demand (Base, High & Low) .....	40 to 42
Schedule 3.2:	History and Forecast of Winter Peak Demand (Base, High & Low) .....	43 to 45
Schedule 3.3:	History and Forecast of Annual Net Energy for Load (Base, High & Low) .....	46 to 48
Schedule 4:	Previous Year and 2-Year Forecast of Peak Demand and Net Energy for Load by Month (Base, High & Low) .....	49 to 51
Schedule 5:	History and Forecast of Fuel Requirements .....	52
Schedule 6.1:	History and Forecast of Net Energy for Load by Fuel Source in GWh .....	53
Schedule 6.2:	History and Forecast of Net Energy for Load by Fuel Source as a percent.....	54
Table IV-I:	2020 Cogeneration Capacity Forecast .....	55
Schedule 7.1:	Forecast of Capacity, Demand, and Scheduled Maintenance at Time of Summer Peak .....	58
Schedule 7.2:	Forecast of Capacity, Demand, and Scheduled Maintenance at Time of Winter Peak.....	59
Schedule 8.1:	Planned and Prospective Generating Facility Additions.....	60 to 61

Schedule 9:	Status Report and Specifications of Proposed Generating Facilities.....	62 to 88
Schedule 10:	Status Report and Specifications of Proposed Directly Associated Transmission Lines.....	89



# LIST OF FIGURES

---

Figure I-I:	Tampa Electric Service Area Map .....	5
Figure VI-I:	Site Location of H.L. Culbreath Bayside Power Station .....	92
Figure VI-II:	Site Location of Polk Power Station .....	93
Figure VI-III:	Site Location of Big Bend Power Station .....	94
Figure VI-IV:	Site Location of Future Solar Power Stations .....	95

THIS PAGE INTENTIONALLY LEFT BLANK

# GLOSSARY OF TERMS

---

## CODE IDENTIFICATION SHEET

<u>Unit Type:</u>	BA	=	Battery Storage
	CC	=	Combined Cycle
	D	=	Diesel
	FS	=	Fossil Steam
	GT	=	Gas Turbine (includes jet engine design)
	HRSG	=	Heat Recovery Steam Generator
	IC	=	Internal Combustion
	IGCC	=	Integrated Gasification Combined Cycle
	PV	=	Photovoltaic
	ST	=	Steam Turbine
 <u>Unit Status:</u>	LTRS	=	Long-Term Reserve Stand-By
	OP	=	Operating (In commercial operation)
	OT	=	Other
	P	=	Planned
	T	=	Regulatory Approval Received
	U	=	Under Construction, less than or equal to 50 percent complete
	V	=	Under Construction, more than 50 percent complete
	RT	=	Planned Retirement
 <u>Fuel Type:</u>	BIT	=	Bituminous Coal
	RFO	=	Residual Fuel Oil (Heavy - #6 Oil)
	DFO	=	Distillate Fuel Oil (Light - #2 Oil)
	NG	=	Natural Gas
	PC	=	Petroleum Coke
	WH	=	Waste Heat
	BIO	=	Biomass
	SOLAR	=	Solar Energy
 <u>Environmental:</u>	FQ	=	Fuel Quality
	LS	=	Low Sulfur
	SCR	=	Selective Catalytic Reduction
 <u>Transportation:</u>	PL	=	Pipeline
	RR	=	Railroad
	TK	=	Truck
	WA	=	Water
 <u>Other:</u>	EV	=	Electric Vehicle(s)
	NA	=	Not Applicable

THIS PAGE INTENTIONALLY LEFT BLANK

# Executive Summary

Tampa Electric Company's (TEC) 2022 Ten-Year Site Plan (TYSP) features plans to enhance electric generating capability as part of our efforts to meet projected incremental resource needs for 2022 through 2031. The 2022 TYSP provides the Florida Public Service Commission (FPSC) with assurance that TEC will be able to supply cost-effective alternatives to ensure the delivery of adequate, safe, environmentally responsible, and reliable power to TEC's customers.

The company plans to meet the power needs of its customers through additional resources and seeks to do so in the most cost-effective way possible while seeking cleaner and greener lower carbon emitting assets. The resource additions are based on TEC's Integrated Resource Planning (IRP) process, which incorporates an on-going evaluation of demand-side and supply-side resources on a comparable and consistent basis to satisfy future demand and energy requirements in a cost-effective, reliable, and environmentally responsible manner.

Investments in renewable generation enables fuel savings for customers, energy diversification, and continues TEC's commitment towards a lower carbon future. The future solar in this expansion plan provides energy diversity by reducing both reliance on natural gas and its associated price volatility risk for customers. The company has announced its plans to deploy more solar projects over the next several years, bringing the total committed solar capacity to 2,071.6 MW or approximately 28.7% of the total installed capacity by the end of the study horizon. As a result, TEC will continue to significantly produce more energy from solar than coal generation.

In addition to enhancements of the aforementioned solar, TEC plans to add approximately 265 MW of battery storage capacity and approximately 74 MW of capacity using reciprocating engines over the study horizon. These distributed resources provide peaking capacity, fuel savings, and the potential for system operational benefits, avoided transmission and distribution investment, and reduced line losses.

TEC is also committed to pursuing cost-effective improvements on the existing generating fleet. Effective December 01, 2021, the Big Bend Modernization Simple Cycle Units 5 and 6 were released for commercial operation. The waste heat from these CTs will then be captured for use in the modernized Big Bend Unit 1 steam turbine as a natural gas combined cycle plant by the end of 2022. In addition, between 2023 and 2024, the Bayside station will undergo advanced hardware upgrades to improve efficiency, generating capacity, and operational flexibility to its seven CTs.

Tampa Electric Company's current and expected resources meet operating reserve requirements under normal peak demand scenarios. The reserve margin provides operating flexibility in the case of unplanned outages and deviations to load from colder than normal (or hotter than normal) weather. However, temperatures that vary significantly from those used to prepare this plan would result in the need to employ operating mitigation under these extreme conditions. These mitigations could include changes to unit dispatch to enhance reliability, switching to alternate fuels, making full use of demand response, pursuing purchase power agreements, and in a worst-case scenario interrupting customers to maintain grid stability. The company is also reviewing and updating its freeze protection plans for each of its generation stations and implementing measures to mitigate equipment failure during these extreme temperatures.

The portfolio of resource additions presented in this TYSP work in concert to provide cost savings, environmental, and reliability benefits for customers while also enhancing the system's operational flexibility, energy diversity, and resiliency.

THIS PAGE INTENTIONALLY LEFT BLANK

# Chapter I



## DESCRIPTION OF EXISTING FACILITIES

TEC has three (3) central generating stations that include steam units, combined cycle units, combustion turbine peaking units, and an integrated coal gasification combined cycle (IGCC) unit. Additionally, TEC has multiple solar facilities.

### **Big Bend Power Station**

Big Bend Station is composed of two simple cycle units 5 and 6, and two steam units 3 and 4. Both steam units are equipped with desulfurization scrubbers, electrostatic precipitators, and Selective Catalytic Reduction (SCR) air pollution control systems. Big Bend unit 4 can be fired with natural gas or coal. Natural gas is the primary fuel on 3, 5, and 6. Big Bend CT 4 is a natural gas aero-derivative combustion turbine.



### **H.L. Culbreath “Bayside” Power Station**

The Bayside station consists of two (2) natural gas-fired combined cycle units and (4) aero derivative combustion turbines. Bayside Unit 1 utilizes three (3) combustion turbines, three (3) heat recovery steam generators (HRSGs) and one (1) steam turbine. Bayside Unit 2 utilizes four (4) combustion turbines, four (4) HRSGs and one (1) steam turbine. Bayside 3, 4, 5, and 6 are four (4) natural gas fired aero-derivative combustion turbines.



### **Polk Power Station**

Polk Unit 1 is a dual fuel IGCC / natural gas unit consisting of one (1) combustion turbine, one (1) HSRG, and one (1) steam turbine. Polk 2 Combined Cycle utilizes four (4) natural gas-fired combustion turbines, four (4) HRSGs and one (1) steam turbine. Two of the combustion turbines can also be fired with distillate oil.



### **Solar**

As of December 31, 2021, TEC owns 729.3 MW<sub>AC</sub> of solar throughout our territory. It consists of 706.5 MW<sub>AC</sub> single axis tracking PV solar arrays at eleven solar sites throughout Hillsborough and Polk counties, a 1.6 MW<sub>AC</sub> fixed tilt solar PV rooftop canopy array located atop the south parking garage at Tampa International Airport, a 1.4 MW<sub>AC</sub> fixed tilt solar PV ground canopy array located at LEGOLAND® Florida, and a 19.8 MW<sub>AC</sub> single axis tracking solar station coupled with a 12.6 MW battery storage unit located at Big Bend Power Station. In 2021, TEC also completed its first integrated renewable energy system, consisting of solar PV carports that charge commercial-sized batteries which re-charge the company's EV fleet.



**Schedule 1**  
**Existing Generating Facilities**  
**As of December 31, 2021**

(1) Plant Name	(2) Unit No.	(3) Location	(4) Unit Type	(5) Fuel		(6) Alt	(7) Fuel Pri	(8) Transport Alt	(9) Fuel Days	(10) Commercial In-Service Mo/Yr	(11) Expected Retirement Mo/Yr	(12) Gen. Max. Nameplate kW	(13) Summer MW	(14) Winter MW
Big Bend <sup>1</sup>	1 <sup>4</sup>	Hillsborough Co.	ST	NG	NG		PL	PL	NA	10/70	**	445,500	0	0
	2 <sup>5</sup>		ST	NG	NA		PL	NA	04/73	12/21	445,500	0	0	
	3		ST	NG	NA	PL	NA	04/23	395	400				
	4		ST	BIT	NG	W/A/RR	PL	NA	01/45	442				
	CT 4		GT	NG	NA	PL	NA	08/09	56	61				
	5 <sup>6</sup>		GT	NG	NA	PL	NA	12/21	330	350				
Big Bend Total	6 <sup>6</sup>	GT	NG	NA	PL	NA	12/21	330	350	1,603				
	1,797,000												1,548	
Bayside	1	Hillsborough Co.	CC	NG	NA		PL	NA	NA	04/03	04/38	809,060	701	792
	2		CC	NG	NA	PL	NA	01/39	929	1,047				
	3		GT	NG	NA	PL	NA	07/09	56	61				
	4		GT	NG	NA	PL	NA	07/09	56	61				
	5		GT	NG	NA	PL	NA	04/09	56	61				
	6		GT	NG	NA	PL	NA	04/09	56	61				
2,293,759												1,854	2,083	
Polk	1	Polk Co.	IGCC	NG	PC/BIT	PL	W/ATK	*	09/96	09/36	326,299	220	220	
Polk Total	2		CC	NG	DFO	PL	TK	*	01/17	1,061	1,200			
	1,542,379												1,281	1,420
TIA LEGOLAND® Big Bend Solar <sup>2</sup> Payne Creek Solar Balm Solar Lithia Solar Grange Hall Solar Bonnie Mine Solar Peace Creek Solar Lake Hancock Solar Little Manatee Solar Wimauma Solar Durrance Solar Magnolia Solar Solar Total <sup>3</sup>	1	Hillsborough Co. Polk Co. Hillsborough Co. Polk Co. Hillsborough Co. Hillsborough Co. Hillsborough Co. Polk Co. Polk Co. Polk Co. Hillsborough Co. Hillsborough Co. Hillsborough Co. Hillsborough Co. Hillsborough Co.	PV	SOLAR	NA	NA	NA	NA	NA	12/15	**	1,600	1.6	1.6
	1		PV	SOLAR	NA	NA	NA	NA	NA	12/16	**	1,400	1.4	1.4
	1		PV	SOLAR	NA	NA	NA	NA	NA	02/17	**	19,800	19.8	19.8
	1		PV	SOLAR	NA	NA	NA	NA	NA	09/18	**	70,300	70.3	70.3
	1		PV	SOLAR	NA	NA	NA	NA	NA	09/18	**	74,400	74.4	74.4
	1		PV	SOLAR	NA	NA	NA	NA	NA	01/19	**	74,500	74.5	74.5
	1		PV	SOLAR	NA	NA	NA	NA	NA	01/19	**	61.1	61.1	61.1
	1		PV	SOLAR	NA	NA	NA	NA	NA	01/19	**	37,500	37.5	37.5
	1		PV	SOLAR	NA	NA	NA	NA	NA	03/19	**	55,400	55.4	55.4
	1		PV	SOLAR	NA	NA	NA	NA	NA	04/19	**	49,500	49.5	49.5
	1		PV	SOLAR	NA	NA	NA	NA	NA	02/20	**	74,500	74.5	74.5
	1		PV	SOLAR	NA	NA	NA	NA	NA	04/20	**	74,800	74.8	74.8
	1		PV	SOLAR	NA	NA	NA	NA	NA	1/21	**	60,000	60.0	60.0
	1		PV	SOLAR	NA	NA	NA	NA	NA	12/21	**	74,500	74.5	74.5
	729,300												729	729
TOTAL												5,412	5,835	

**Notes:**

- \* Limited by environmental permit.
- \*\* Undetermined.
- 1 Plant firm net capability will be limited effective January 2023.
- 2 The 12.6 MW Big Bend Battery was integrated into the solar site at Big Bend in December 2019.
- 3 Approximately 54.1% of Solar generation is considered firm for Summer Reserve Margin and 0% is considered firm for Winter Reserve Margin calculation. Rating for Solar units are nameplate ratings. Utility owned solar/battery less than 1MW not included.
- 4 Big Bend 1 ST will be restricted to 0 MW until placed into combined cycle mode in 2023.
- 5 Big Bend 2 retired on December 2021.
- 6 Big Bend 5 and 6 net capability is restricted to 330 MW summer / 350 MW winter until placed into combined cycle mode in 2023.




Figure I-I: Tampa Electric Service Area Map

# Tampa Electric Service Area

- 1 Balm
- 2 Bayside
- 3 Big Bend
- 4 Bonnie Mine
- 5 Durrance
- 6 Grange Hall
- 7 Lake Hancock
- 8 Legoland Florida
- 9 Lithia
- 10 Little Manatee River
- 11 Magnolia
- 12 Payne Creek
- 13 Peace Creek
- 14 Polk
- 15 Tampa International Airport
- 16 Wimauma

- Solar Generation
- Power Station
- Storage
- Service Area



THIS PAGE INTENTIONALLY LEFT BLANK

# Chapter II



## TAMPA ELECTRIC COMPANY FORECASTING METHODOLOGY

The customer, demand and energy forecasts are the foundation from which the IRP is developed. Recognizing their importance, TEC employs proven methodologies for carrying out this function. The primary objective of this procedure is to blend proven statistical techniques with practical forecasting experience to provide a projection that represents the highest probability of occurrence.

This chapter is devoted to describing TEC's forecasting methodologies and the major assumptions utilized in developing the 2022-2031 forecasts. The data tables in Chapter IV outline the expected customer, demand, and energy values for the 2022-2031 time period.

### **RETAIL LOAD**

MetrixND, an advanced statistics program for analysis and forecasting, was used to develop the 2022-2031 customer, demand and energy forecasts. This software allows a platform for the development of more dynamic and fully integrated models.

In addition, TEC uses MetrixLT, which integrates with MetrixND, to develop multiple-year forecasts of energy usage at the hourly level. This tool allows the annual or monthly forecasts in MetrixND to be combined with hourly load shape data to develop a long-term "bottom-up" forecast that is consistent with short-term statistical forecasts.

TEC's retail customer, demand and energy forecasts are the result of eight separate forecasting analyses:

1. Economic Analysis
2. Customer Multiregression Model
3. Energy Multiregression Model
4. Peak Demand Multiregression Model
5. Interruptible Demand and Energy Analysis
6. Photovoltaic (PV)
7. Electric Vehicle Charging (EV)
8. Conservation, Load Management and Cogeneration Programs



The MetrixND models are the company's most sophisticated and primary load forecasting models. The phosphate demand and energy are forecasted separately and then combined in the final forecast, as well as the effects of photovoltaic (PV) and electric vehicle (EV) related energy and demand. Likewise, the effects of TEC's conservation, load management, and cogeneration programs are incorporated into the process by subtracting the expected reduction in demand and energy from the forecast.

## **1. Economic Analysis**

The economic assumptions used in the forecast models are derived from forecasts from Moody's Analytics and the University of Florida's Bureau of Economic and Business Research (BEBR).

See the "Base Case Forecast Assumptions" section of this chapter for an explanation of the most significant economic inputs to the MetrixND models.

## **2. Customer Multiregression Model**

The customer multiregression forecasting model is a nine-equation model. The primary economic drivers in the customer forecast models are population estimates, new construction, and employment growth. Below is a description of the models used for the five-customer classes.

- **Residential Customer Model (Equation #1):** Customer projections are a function of regional population due to the strong correlation that exists between regional population and historical changes in service area customers.
- **Commercial Customer Model:** Total commercial customers include commercial customers plus construction service customers; therefore, two models are used to forecast total commercial customers:
  - The Commercial Customer Model (Equation #2) is a function of population. An increase in the number of households provides the need for additional services, restaurants, and retail establishments. The amount of residential activity also plays a part in the attractiveness of the Tampa Bay area as a place to relocate or start a new business.
  - Projections of permits in the construction sector are a good indicator of expected increases and decreases in local construction activity. Therefore, the Construction Service Model (Equation #3) projects the number of customers as a function of new construction permits.
- **Industrial Customer Model (Non-Phosphate):** Non-phosphate industrial customers include two rate classes that have been modeled individually: General Service and General Service Demand.
  - The General Service Customer Model (Equation #4) is a function of Hillsborough County commercial employment.
  - The General Service Demand Customer Model (Equation #5) is a function of Hillsborough County employment in the manufacturing sector as well as recent trends.
- **Public Authority Customer Model:** Customer projections are based on the recent growth trends in the governmental sector and are modeled individually for three rate classes: Residential Service, General Service and General Service Demand. Starting in 2017, street and highway lighting data was included as

part of the public authority sector.

- The Residential Service Customer Model (**Equation #6**) is a function of recent trends.
  - The General Service Customer Model (**Equation #7**) is a function of recent trends.
  - The General Service Demand Customer Model (**Equation #8**) is a function of recent trends, as well.
- **Street & Highway Lighting Customer Model (Equation #9):** Customer projections are based on recent growth trends in the sector.

### 3. Energy Multiregression Model

The energy multiregression forecasting model is also a nine-equation model. All these equations represent average usage per customer (kWh/customer), except for the construction services and lighting equations which represent total kWh sales. The average usage models interact with the customer models to arrive at total sales for each class.

The energy models are based on an approach known as Statistically Adjusted Engineering (SAE). SAE entails specifying end-use variables, such as heating, cooling and base use appliance/equipment, and incorporating these variables into regression models. This approach allows the models to capture long-term structural changes that end-use models are known for, while also performing well in the short-term time frame, as do econometric regression models.

- **Residential Energy Model (Equation #1):** The residential forecast model is made up of three major components: (1) end-use equipment index variables, which capture the long-term net effect of equipment saturation and equipment efficiency improvements; (2) changes in the economy such as household income, household size, and the price of electricity; and (3) weather variables, which serve to allocate the seasonal impacts of weather throughout the year. The SAE model framework begins by defining energy use for an average customer in year (y) and month (m) as the sum of energy used by heating equipment (XHeat<sub>y,m</sub>), cooling equipment (XCool<sub>y,m</sub>), and other equipment (XOther<sub>y,m</sub>). The XHeat, XCool, and XOther variables are defined as a product of an annual equipment index and a monthly usage multiplier.

$$\text{Average Usage}_{y,m} = (\text{XHeat}_{y,m} + \text{XCool}_{y,m} + \text{XOther}_{y,m})$$

Where:

$$\begin{array}{llll} \text{XHeat}_{y,m} & = & \text{HeatEquipIndex}_y & \times & \text{HeatUse}_{y,m} \\ \text{XCool}_{y,m} & = & \text{CoolEquipIndex}_y & \times & \text{CoolUse}_{y,m} \\ \text{XOtherUse}_{y,m} & = & \text{OtherEquipIndex}_y & \times & \text{OtherUse}_{y,m} \end{array}$$

The annual equipment variables (HeatEquipIndex, CoolEquipIndex, OtherEquipIndex) are defined as a weighted average across equipment types multiplied by equipment saturation levels normalized by operating efficiency levels. Given a set of fixed weights, the index will change over time with changes in equipment saturations and operating efficiencies. The weights are defined by the estimated energy use per household for each equipment type in the base year.

Where:

$$\text{HeatEquipIndex} = \sum_{Tech.} \text{Weight} \times \left( \frac{\text{Saturation}_y / \text{Efficiency}_y}{\text{Saturation}_{base\ y} / \text{Efficiency}_{base\ y}} \right)$$

$$\text{CoolEquipIndex} = \sum_{Tech.} \text{Weight} \times \left( \frac{\text{Saturation}_y / \text{Efficiency}_y}{\text{Saturation}_{base\ y} / \text{Efficiency}_{base\ y}} \right)$$

$$\text{OtherEquipIndex} = \sum_{Tech.} \text{Weight} \times \left( \frac{\text{Saturation}_y / \text{Efficiency}_y}{\text{Saturation}_{base\ y} / \text{Efficiency}_{base\ y}} \right)$$

Next, the monthly usage multiplier or utilization variables (HeatUse, CoolUse, OtherUse) are defined using economic and weather variables. A customer's monthly usage level is impacted by several factors, including weather, household size, income levels, electricity prices and the number of days in the billing cycle. The degree-day variables serve to allocate the seasonal impacts of weather throughout the year, while the remaining variables serve to capture changes in the economy.

**HeatUse<sub>y,m</sub>** =

$$\left( \frac{\text{Price}_{y,m}}{\text{Price}_{base\ y,m}} \right)^{-10} \times \left( \frac{\text{HH Income}_{y,m}}{\text{HH Income}_{base\ y,m}} \right)^{.17} \times \left( \frac{\text{HH Size}_{y,m}}{\text{HH Size}_{base\ y,m}} \right)^{.15} \times \left( \frac{\text{HDD}_{y,m}}{\text{Normal HDD}} \right)$$

**CoolUse<sub>y,m</sub>** =

$$\left( \frac{\text{Price}_{y,m}}{\text{Price}_{base\ y,m}} \right)^{-10} \times \left( \frac{\text{HH Income}_{y,m}}{\text{HH Income}_{base\ y,m}} \right)^{.17} \times \left( \frac{\text{HH Size}_{y,m}}{\text{HH Size}_{base\ y,m}} \right)^{.15} \times \left( \frac{\text{CDD}_{y,m}}{\text{Normal CDD}} \right)$$

**OtherUse<sub>y,m</sub>** =

$$\left( \frac{\text{Price}_{y,m}}{\text{Price}_{base\ y,m}} \right)^{-10} \times \left( \frac{\text{HH Income}_{y,m}}{\text{HH Income}_{base\ y,m}} \right)^{.17} \times \left( \frac{\text{HH Size}_{y,m}}{\text{HH Size}_{base\ y,m}} \right)^{.15} \times \left( \frac{\text{Billing Days}_{y,m}}{\text{Billing Days}_{base\ y,m}} \right)$$

The SAE approach to modeling provides a powerful framework for developing short-term and long-term energy forecasts. This approach reflects changes in equipment saturation and efficiency levels and gives estimates of weather sensitivities that vary over time as well as estimate trend adjustments.

- **Commercial Energy Model:** total commercial energy sales include commercial sales plus construction service sales; therefore, two equations are used to forecast total commercial energy sales.
  - **Commercial Energy Model (Equation #2):** The model framework for the commercial sector is the same as the residential model. It also has three major components and utilizes the SAE model framework. The differences lie in the type of end-use equipment and in the economic variables used. The end-use equipment variables are based on commercial appliance/equipment saturation and efficiency assumptions. The economic drivers in the commercial model are commercial productivity measured in terms of dollar output and the price of electricity for the commercial sector. The third component, weather variables, is the same as in the residential model.

- Construction Service Energy Model (Equation #3): This model is a subset of the total commercial sector and is a rather small percentage of the total commercial sector. Although small in nature, it is still a component that needs to be included. A simple regression model is used with the primary driver being construction service customer growth along with the number of days billed, cooling and heating degree-days.
- **Industrial Energy Model (Non-Phosphate)**: Non-phosphate industrial energy includes two rate classes that have been modeled individually: General Service and General Service Demand.
  - The General Service Energy Model (Equation #4) utilizes the same SAE model framework as the commercial energy model. The weather component is consistent with the residential and commercial models.
  - The General Service Demand Energy Model (Equation #5) is based on manufacturing output, the price of electricity in the industrial sector, cooling degree-days and number of days billed. Unlike the previous models discussed, heating load does not impact this sector.
- **Public Authority Sector Energy Model**: The governmental sector is modeled individually for three rate classes: Residential Service, General Service and General Service Demand.
  - The Residential Service Energy Model (Equation #6) is based on the residential equipment saturation and efficiency assumptions used in the residential model.
  - The General Service Energy Model (Equation #7) is based on the same commercial equipment saturation and efficiency assumptions used in the commercial model. The economic component is based on government sector productivity and the price of electricity in this sector. Weather variables are consistent with the residential and commercial models.
  - The General Service Demand Energy Model (Equation #8) is a function of cooling and heating degree-days.
- **Street & Highway Lighting Sector Energy Model (Equation #9)**: The street and highway lighting sector is not weather sensitive; therefore, it is a rather simple model and the SAE modeling approach does not apply. The model is a linear regression model where street and highway lighting energy consumption is a function of the number of billing days in the cycle, the number of daylight hours in a day for each month, and recent trends. Starting in 2017, street and highway lighting data was included as part of the public authority sector. The street and highway lighting forecast reflects the impacts of the company's LED lighting program.

The nine energy models described above, plus the incremental effects of rooftop solar [PV], electric vehicles [EV] and conservation related energy, along with an exogenous interruptible and phosphate forecast, are added together to arrive at the total retail energy sales forecast. (See sections 5 – 8 below for details.) A line loss factor is applied to the energy sales forecast to produce the retail net energy for load forecast.

In summary, the SAE approach to modeling provides a powerful framework for developing short-term and long-term energy forecasts. This approach reflects changes in equipment saturation and efficiency levels, gives estimates of weather sensitivity that varies over time, as well as estimates trend adjustments.

#### **4. Peak Demand Multiregression Model**

After the retail net energy for load forecast is complete, it is integrated into the peak demand model as an independent variable along with weather variables. The energy variable represents the long-term economic and appliance trend impacts. To stabilize the peak demand data series and improve model accuracy, the volatility of the phosphate load is removed. To further stabilize the data, the peak demand models project on a per customer basis.

The weather variables provide the monthly seasonality to the peaks. The weather variables used are heating and cooling degree-days for both the temperature at the time of the peak and the 24-hour average on the day of the peak and day prior to the peak. By incorporating both temperatures, the model is accounting for the fact that cold/heat buildup contributes to determining the peak day.

The non-phosphate per customer kW forecast is multiplied by the final customer forecast. This result is then aggregated with a phosphate-coincident peak forecast and adjusted for the incremental effects of PV, EV and conservation related demand to arrive at the final projected peak demand.

#### **5. Interruptible Demand and Energy Analysis**

TEC interruptible customers are relatively few, which has allowed the company's Sales and Marketing Department to obtain detailed knowledge of industry developments including:

- Knowledge of expansion and close-out plans
- Familiarity with historical and projected trends
- Personal contact with industry personnel
- Governmental legislation
- Familiarity with worldwide demand for phosphate products

This department's familiarity with industry dynamics and their close working relationship with phosphate and other company representatives were used to form the basis for a survey of the interruptible customers to determine their future energy and demand requirements. This survey is the foundation upon which the phosphate forecast, and the commercial/industrial interruptible rate class forecasts are based. Further input is provided by individual customer trend analysis and discussions with industry experts.

#### **6. Roof Top Solar**

Roof top solar forecasts are based on the historical number of PV installations and the average size of the PV systems installed in the service area. From this historical data, future penetration levels of PVs are based on assumptions used by the Energy Information Administration's (EIA) for the South Atlantic region. It is assumed Tampa Electric will no longer have to serve this portion of PV customers' load; therefore, the energy sales forecast is adjusted downward to incorporate the loss of this load.

#### **7. Electric Vehicle**

The electric vehicle forecast process begins with an estimate of the number of EVs operating in Tampa Electric's service area. Future penetration levels of EVs are based on assumptions used by the Energy Information Administration's (EIA) for the South Atlantic region. The demand and energy consumption associated with EV



charging is based on a number of assumptions including the average number of miles driven in a year, the weighted average battery size of four common EV models sold within the service area and the number of charges per year.

## **8. Conservation, Load Management and Cogeneration Programs**

Conservation and Load Management demand and energy savings are forecasted for each individual program. The savings are based on a forecast of the annual number of new participants, estimated annual average energy savings per participant and estimated summer and winter average demand savings per participant. The individual forecasts are aggregated and represent the cumulative amount of Demand Side Management (DSM) savings throughout the forecast horizon.

TEC retail demand and energy forecasts are adjusted downward to reflect the incremental demand and energy savings of these DSM programs.

TEC has developed conservation, load management and cogeneration programs to achieve five major objectives:

1. Defer expansion, particularly production plant construction.
2. Reduce marginal fuel cost by managing energy usage during higher fuel cost periods.
3. Provide customers with some ability to control energy usage and decrease energy costs.
4. Pursue the cost-effective accomplishment of the FPSC ten-year demand and energy conservation goals for the residential and commercial/industrial sectors.
5. Achieve the comprehensive energy policy objectives as required by the Florida Energy Efficiency Conservation Act (FEECA).

In 2021, Tampa Electric continued operating within the FPSC approved 2020-2029 DSM Plan which consists of one renewable program, one research and development program, 15 residential and 20 commercial DSM Programs which support the approved FPSC goals which are reasonable, beneficial and cost-effective to all customers as required by the FEECA. The following is a list that briefly describes the company's DSM programs:

1. Energy Audits - a "how to" information and analysis guide for customers. Six types of audits are available to Tampa Electric customers; four types are for residential customers and two types are for commercial/industrial customers.
2. Residential Ceiling Insulation – a rebate program that encourages existing residential customers to install additional ceiling insulation in existing homes.
3. Residential Duct Repair – a rebate program that encourages residential customers to repair leaky duct work of central air conditioning systems in existing homes.
4. Energy Education, Awareness and Agency Outreach - a program that provides opportunities for engaging and educating groups of customers, students on energy-efficiency and conservation in an organized setting and electric vehicles at participating high schools. Participants are provided with an energy savings kit which includes energy saving devices and supporting information appropriate for the audience.

5. Energy Star for New Multi-Family Residences - a rebate program that encourages the construction of new multi-family residences to meet the requirements to achieve the ENERGY STAR certified apartments and condominium label.
6. Energy Star for New Homes - a rebate program that encourages residential customers to construct residential dwellings that qualify for the Energy Star Award by achieving efficiency levels greater than current Florida building code baseline practices.
7. Energy Star Pool Pumps - a rebate program that encourages residential customers to install Energy Star rated pool pumps in existing homes.
8. Energy Star Thermostats - a rebate program that encourages residential customers to install Energy Star rated thermostats in existing homes.
9. Residential Heating and Cooling – a rebate program that encourages residential customers to install high-efficiency residential heating and cooling equipment in existing homes.
10. Neighborhood Weatherization – a program that provides for the installation of energy efficient measures for qualified low-income customers.
11. Prime Time Plus – a program that reduces weather-sensitive loads through direct load control of residential customers HVAC, water heating and pool pumps. This program will use the company’s advanced metering infrastructure (“AMI”) system. Once the company completes the AMI system and it becomes fully available, this program will start.
12. Residential Price Responsive Load Management (Energy Planner) – a program that reduces weather-sensitive loads through an innovative price responsive rate used to encourage residential customers to make behavioral or equipment usages changes by pre-programming HVAC, water heating and pool pumps.
13. Residential Window Replacement – a rebate program that encourages existing residential customers to install window upgrades in existing homes.
14. Commercial Chiller – a rebate program that encourages commercial and industrial customers to install high efficiency chiller equipment.
15. Cogeneration – an incentive program whereby large industrial customers with waste heat or fuel resources may install electric generating equipment, meet their own electrical requirements and/or sell their surplus to the company.
16. Conservation Value - a rebate program that encourages commercial and industrial customers to invest in energy efficiency and conservation measures that are not sanctioned by other commercial programs.
17. Commercial Cooling – a rebate program that encourages commercial and industrial customers to install high efficiency direct expansion commercial air conditioning cooling equipment.
18. Demand Response – a turn-key incentive program for commercial and industrial customers to reduce their demand for electricity in response to market signals.

19. Commercial Facility Energy Management System - a rebate program that encourages commercial and industrial customers to install high efficiency energy management systems.
20. Industrial Load Management – an incentive program whereby large industrial customers allow for the interruption of their facility or portions of their facility electrical load.
21. Street and Outdoor Lighting Conversion – A program that converts Tampa Electric’s metal halide and high-pressure sodium street and outdoor lighting to energy efficient light emitting diode (LED) technology to reduce energy consumption and Tampa Electric’s peak demand. Tampa Electric will recover the remaining unamortized costs in rate base with the eligible Non-LED luminaires.
22. Lighting Conditioned Space – a rebate program that encourages commercial and industrial customers to invest in more efficient lighting technologies in existing conditioned areas of commercial and industrial facilities.
23. Lighting Non-Conditioned Space – a rebate program that encourages commercial and industrial customers to invest in more efficient lighting technologies in existing non-conditioned areas of commercial and industrial facilities.
24. Lighting Occupancy Sensors – a rebate program that encourages commercial and industrial customers to install occupancy sensors to control commercial lighting systems.
25. Commercial Load Management – an incentive program that encourages commercial and industrial customers to allow for the control of weather-sensitive heating, cooling and water heating systems to reduce the associated weather sensitive peak.
26. Commercial Smart Thermostat - a rebate program that encourages commercial and industrial customers to smart thermostats.
27. Standby Generator – an incentive program designed to utilize the emergency generation capacity of commercial/industrial facilities in order to reduce weather sensitive peak demand.
28. Variable Frequency Drive Control for Compressors - a rebate program that encourages commercial and industrial customers to install variable frequency drives on refrigerant or compressed air systems.
29. Commercial Water Heating – a rebate program that encourages commercial and industrial customers to install high efficiency water heating systems.
30. Integrated Renewable Energy System – a five-year pilot program to study and understand the potential opportunities and interactions of a fully integrated renewable energy system that contains a photovoltaic system, batteries, car charging and industrial truck charging.
31. Conservation Research and Development (R&D) – a program that allows for the exploration of DSM measures that have insufficient data on the cost-effectiveness of the measure and the potential impact to Tampa Electric and its ratepayers.

The programs listed above were developed to meet FPSC demand and energy goals established in Docket No. 20190021-EG, Order No. PSC-2019-0509-FOF-EU, Issued November 26, 2019. The 2021 demand and energy savings achieved by conservation and load management programs are listed in Table III-1.

TEC developed a Monitoring and Evaluation (M&E) plan in response to FPSC requirements filed in Docket No. 941173-EG. The M&E plan was designed to effectively accomplish the required objective with prudent application of resources.

The M&E plan has its focus on two distinct areas: process evaluation and impact evaluation. Process evaluation examines how well a program has been implemented including the efficiency of delivery and customer satisfaction regarding the usefulness and quality of the services delivered. Impact evaluation is an evaluation of the change in demand and energy consumption achieved through program participation. The results of these evaluations give TEC insight into the direction that should be taken to refine delivery processes, program standards, and overall program cost-effectiveness.

**TABLE III-1**  
**Comparison of Achieved MW and GWh Reductions With Florida Public Service Commission Goals**  
Savings at the Generator

<b>Residential</b>									
Year	Winter Peak MW Reduction			Summer Peak MW Reduction			GWh Energy Reduction		
	Total Achieved	Commission Approved	%	Total Achieved	Commission Approved	%	Total Achieved	Commission Approved	%
		Goal			Goal			Goal	
2015	12.3	2.6	473.1%	10.8	1.1	981.8%	21.2	1.8	1,177.8%
2016	7.7	4.1	187.8%	5.1	1.6	318.8%	13.2	3.5	377.1%
2017	6.9	5.2	132.7%	4.7	2.2	213.6%	14.9	4.8	310.4%
2018	8.0	6.5	123.0%	5.6	2.7	205.7%	17.1	6.1	280.3%
2019	8.3	7.6	108.8%	5.7	3.1	184.5%	16.8	6.9	243.2%
2020	3.5	7.6	45.5%	2.6	3.3	78.2%	8.9	7.4	120.3%
2021	4.5	8.0	55.8%	6.4	3.3	194.2%	16.4	7.7	213.1%
2022		7.4			3.0			6.9	
2023		6.8			2.9			6.3	
2024		6.1			2.5			5.5	

<b>Commercial/Industrial</b>									
Year	Winter Peak MW Reduction			Summer Peak MW Reduction			GWh Energy Reduction		
	Total Achieved	Commission Approved	%	Total Achieved	Commission Approved	%	Total Achieved	Commission Approved	%
		Goal			Goal			Goal	
2015	8.1	1.2	675.0%	11.7	1.7	688.2%	12.5	3.9	320.5%
2016	2.9	1.3	223.1%	4.4	2.5	176.0%	17.8	6.0	296.7%
2017	9.2	1.6	575.0%	10.4	2.7	385.2%	30.2	8.0	377.5%
2018	13.0	1.7	767.1%	15.0	3.3	453.6%	33.7	9.2	365.9%
2019	22.4	1.6	1401.9%	29.2	3.3	885.9%	74.6	9.9	753.4%
2020	10.4	1.7	612.5%	11.8	3.5	336.0%	26.1	10.3	253.3%
2021	4.7	1.9	246.2%	5.6	3.6	156.8%	20.4	10.4	196.1%
2022		1.9			3.3			10.2	
2023		1.8			3.5			9.9	
2024		1.7			3.2			9.6	

<b>Combined Total</b>									
Year	Winter Peak MW Reduction			Summer Peak MW Reduction			GWh Energy Reduction		
	Total Achieved	Commission Approved	%	Total Achieved	Commission Approved	%	Total Achieved	Commission Approved	%
		Goal			Goal			Goal	
2015	20.4	3.8	536.8%	22.5	2.8	803.6%	33.7	5.7	591.2%
2016	10.6	5.4	196.3%	9.5	4.1	231.7%	31.0	9.5	326.3%
2017	16.1	6.8	236.8%	15.1	4.9	308.2%	45.1	12.8	352.3%
2018	21.0	8.2	256.5%	20.5	6.0	342.1%	50.8	15.3	331.8%
2019	30.7	9.2	333.7%	35.0	6.4	546.2%	91.4	16.8	543.9%
2020	13.9	9.3	149.1%	14.3	6.8	210.9%	35.0	17.7	197.7%
2021	9.1	9.9	92.3%	12.1	6.9	174.7%	36.8	18.1	203.3%
2022		9.3			6.3			17.1	
2023		8.6			6.4			16.2	
2024		7.8			5.7			15.1	

## **BASE CASE FORECAST ASSUMPTIONS**

### **RETAIL LOAD**

Numerous assumptions are inputs to the MetrixND models, of which the more significant ones are listed below.

1. Population and Households
2. Commercial, Industrial and Governmental Employment
3. Commercial, Industrial and Governmental Output
4. Real Household Income
5. Price of Electricity
6. Appliance Efficiency Standards
7. Weather

#### ***1. Population and Households***

Florida and Hillsborough County population forecasts are the starting point for developing the customer and energy projections. Both the University of Florida's Bureau of Economic and Business Research (BEBR) and Moody's Analytics supply population projections for Hillsborough County and Florida comparisons. BEBR's population growth for Hillsborough County was used to project future growth patterns in residential customers for the period of 2022-2031. The average annual population growth rate is expected to be 1.4%.

#### ***2. Commercial, Industrial and Governmental Employment***

Commercial, industrial and governmental employment assumptions are utilized in computing the number of customers in their respective sectors. Over the next ten years (2022-2031), employment is assumed to rise at a 1.4% average annual rate within Hillsborough County. Moody's Analytics supplies employment projections for the non-residential models.

#### ***3. Commercial, Industrial and Governmental Output***

In addition to employment, output in terms of real gross domestic product by employment sector is utilized in computing energy in their respective sectors. Output for the entire employment sector within Hillsborough County is assumed to rise at a 3.3% average annual rate from 2022-2031. Moody's Analytics supplies output projections.

#### ***4. Real Household Income***

Moody's Analytics supplies the assumptions for Hillsborough County's real household income growth. During 2022-2031, real household income for Hillsborough County is expected to increase at a 1.1% average annual rate.

#### ***5. Price of Electricity***

Forecasts for the price of electricity by customer class are supplied by TEC's Regulatory Affairs Department.

## **6. Appliance Efficiency Standards**

Another factor influencing energy consumption is the movement toward more efficient appliances such as heat pumps, refrigerators, lighting and other household appliances. The forces behind this development include market pressures for greater energy-saving devices, legislation, rules, and the appliance efficiency standards enacted by the state and federal governments. Also influencing energy consumption is the customer saturation levels of appliances. The saturation trend for heating appliances is increasing through time; however, overall electricity consumption declines over time as less efficient heating technologies (room heating and furnaces) are replaced with more efficient technologies (heat pumps). Similarly, cooling equipment saturation will continue to increase, but be offset by heat pump and central air conditioning efficiency gains.

Improvements in the efficiency of other non-weather-related appliances also help to lower electricity consumption. Although there is an increasing saturation trend of electronic equipment and appliances in households throughout the forecast period, it does not offset the efficiency gains from lighting and appliances.

## **7. Weather**

The weather assumptions are the most difficult to project. Therefore, historical data is the major determinant in developing temperature profiles. For example, monthly profiles used in calculating energy consumption are based on twenty years of historical data. In addition, the temperature profiles used in projecting the winter and summer system peak are based on an examination of the minimum and maximum temperatures for the past twenty years plus the temperatures on peak days for the past twenty years.

## **HIGH AND LOW SCENARIO FOCUS ASSUMPTIONS**

The base case scenario is tested for sensitivity to varying economic conditions and customer growth rates. The high and low peak demand and energy scenarios represent alternatives to the company's base case outlook. Compared to the base case, the expected economic growth rates are 0.5 percent higher in the high scenario and 0.5 percent lower in the low scenario.

## **HISTORY AND FORECAST OF ENERGY USE**

A history and forecast of energy consumption by customer classification are shown in Schedules 2.1 - 2.3 in Chapter IV.

### **1. Retail Energy**

For 2022-2031, retail energy sales are projected to rise at a 0.6% annual rate. The primary contributor to growth is the residential class increasing at an annual rate of 1.0%.

### **2. Wholesale Energy**

TEC has no scheduled firm wholesale power sales currently.

## **HISTORY AND FORECAST OF PEAK LOADS**

Historical, base, high, and low scenario forecasts of peak loads for the summer and winter seasons are presented in Schedules 3.1 and 3.2, respectively. For the period of 2022-2031, TEC's base retail firm peak demand is expected to increase at an average annual rate of 0.7% in the summer and 0.8% in the winter.



# Chapter III



## INTEGRATED RESOURCE PLANNING PROCESSES

TEC's IRP process was designed to evaluate demand-side and supply-side resources on a comparable and consistent basis to satisfy future demand and energy requirements in a cost-effective and reliable manner, while considering the interests of utility customers and shareholders.

The process incorporates a reliability analysis to determine timing of future needs and an economic analysis to determine what resource alternatives best meet future system demand and energy requirements. Initially, a demand and energy forecast is developed which excludes incremental energy efficiency and conservation programs. This forecast is used to identify the basis for the next potential avoided unit(s), and becomes the baseline used to perform a comprehensive cost effectiveness analysis of these programs based on the following Commission approved tests: the Rate Impact Measure test (RIM), the Total Resource Cost test (TRC), and the Participants Cost test (PCT). Using the FPSC's standard cost-effectiveness methodology, each measure is evaluated based on different marketing and incentive assumptions. Utility plant avoidance assumptions for generation, transmission, and distribution are also used in this analysis. All measures that pass the RIM and PCT tests in the energy efficiency and demand response analysis are considered for utility program adoption.

Each adopted measure is quantified into its coincident summer and winter peak kW reduction contribution and its annual kWh savings and is reflected in the demand and energy forecast. TEC evaluates and reports energy efficiency and demand response measures that comports with Rule 25-17.008, F.A.C., the FPSC's prescribed cost-effectiveness methodology.

Once this comprehensive analysis is complete and the cost-effective energy efficiency and conservation programs are determined, the system demand and energy requirements are revised to include the effects of these programs on reducing system peak and energy requirements. The process is repeated to incorporate the energy efficiency and conservation programs and supply-side resources.

Generating resources to be considered are determined through an alternative technology screening analysis, which is designed to determine the economic viability of a wide range of generating technologies for the TEC service area. The technologies that pass the screening are included in a supply-side analysis that examines various supply-side alternatives for meeting future system requirements.

TEC uses a computer model developed by Hitachi Energy, System Optimizer (SO), to evaluate supply-side resources. SO utilizes a mixed integer linear program (MILP) to develop an estimate of the timing and type of supply-side resources for generation additions that would economically meet the system demand and energy requirements. The objective function of the MILP is to compare all feasible combinations of generating unit additions, satisfy the specified reliability criteria, and determine the schedule and addition with the lowest total system cost.

Detailed cost analyses for each of the top ranked resource plans are performed using the Planning & Risk (PaR) production cost model, also developed by Hitachi. The capital expenditures, including interconnection costs and incremental fuel transportation associated with each capacity addition are obtained based on the type of generating unit, fuel type, capital spending curve, and in-service year. The fixed charges resulting from the capital expenditures are expressed in present worth dollars for comparison. The fuel and the operating and

maintenance costs associated with each scenario are projected based on economic dispatch of all the energy resources in our system. The projected operating expense, expressed in present worth dollars, is combined with the fixed charges to obtain the total cumulative present value of revenue requirements for each alternative plan.

The result of the IRP process provides Tampa Electric's customers with a plan that is cost-effective while maintaining flexibility and adaptability to a dynamic regulatory and competitive environment, while positioning Tampa Electric for a lower carbon future. To meet the expected system demand and energy requirements and cost-effectively maintain system reliability, the company's expansion plan includes the following:

- Modernization of Big Bend unit 1
- Enhancements to and retirement of existing assets
- Completion of solar PV through 2023, in accordance with the 2021 Rate Case Settlement
- Additional future utility-scale solar, battery storage, and reciprocating engines beyond 2023 until the end of the study period

Furthermore, the first phase of the Big Bend modernization project commenced with the retirement of Unit 2 at the end of November 2021 and the deployment of two simple cycle CTs in December 2021. The exhaust from these CTs will then be captured and integrated into a modernized Big Bend Unit 1 steam turbine to create a natural gas combined cycle by December of 2022. In addition, the Bayside station will undergo advanced hardware improvements to its existing seven CTs during 2023 and 2024. Big Bend Unit 3 will retire in April of 2023. All these changes to the expansion plan are shown in Schedule 8.1.

The remainder of the expansion plan presented in this Ten-Year Site Plan will meet growing customer needs with the addition of energy resources distributed throughout our territory. In addition to enhancements to the existing assets and the utility-scale solar, battery storage and reciprocating engines will be added to meet customer demand growth and provide operational flexibility and system resiliency to better serve our customers. The detailed expansion plan is shown in Schedule 8.1.

TEC will continue to assess competitive purchase power agreements and DSM programs that may replace or delay the scheduled units. Such optimizations must achieve the overall objective of providing reliable power in a cost-effective manner.

## **FINANCIAL ASSUMPTIONS**

TEC makes numerous financial assumptions as part of the preparation for its TYSP process. These assumptions are based on the current financial status of the company, the market for securities, and the best available forecast of future conditions. The primary financial assumptions include the FPSC-approved Allowance for Funds Used During Construction (AFUDC) rate, capitalization ratios, financing cost rates, tax rates, and FPSC-approved depreciation rates.

- Per the Florida Administrative Code 25-6, an amount for AFUDC is recorded by the company during the construction phase of each capital project that meets the requirements. This rate is approved by the FPSC and represents the cost of money invested in the applicable project while it is under construction. This cost is capitalized, becomes part of the project investment, and is recovered over the life of the asset. The AFUDC rate assumed in the Ten-Year Site Plan represents the company's currently approved AFUDC rate.
- The capitalization ratios represent the percentages of incremental long-term capital that are expected to be issued to finance the capital projects identified in the TYSP.
- The financing cost rates reflect the incremental cost of capital associated with each of the sources of long-term financing.
- Tax rates include federal income tax, state income tax, and miscellaneous taxes including property tax.
- Depreciation represents the annual cost to amortize the total original investment in a plant over its useful life less net salvage value. This provides for the recovery of plant investment. The assumed book life for each capital project within the TYSP represents the average expected life for that type of asset.

## **FUEL FORECAST**

TEC forecasts base case natural gas, coal, and oil fuel commodity prices by analyzing current market prices and price forecasts obtained from various consultants and agencies. These sources include the New York Mercantile Exchange, S&P Scenario Planning Service Annual Guidebook (originally produced by PIRA Energy Group), U.S. Energy Information Administration, S&P Global Market Intelligence, IHS Markit, Argus Coal Daily, Inside FERC, and Platt's Oilgram. For natural gas, coal and oil prices, the company produces both high and low fuel price projections, which represent alternative forecasts to the company's base case outlook.



## **TEC RENEWABLE RESOURCES AND STORAGE TECHNOLOGY INITIATIVES**

### ***1. Renewable Energy Initiatives***

In September 2017, TEC announced plans to build 600 MW<sub>AC</sub> of new solar PV generating capacity from 2018 through January 2021, which is enough electricity to power more than 100,000 homes. The actual design and completion of these projects resulted in 632 MW<sub>AC</sub> and combined with 23 MW<sub>AC</sub> from three smaller projects built prior to 2018, created a total of 655 MW<sub>AC</sub> of solar capacity. In February 2020, the Company announced plans to build an additional 600 MW<sub>AC</sub> of new cost-effective, utility-scale solar PV generating capacity from 2021 through the end of 2023. By 2023, Tampa Electric will have more than 1,324 MW<sub>AC</sub> of solar power – enough to power more than 200,000 homes – with about 13.6 percent of our energy produced by the sun.

The solar energy significantly reduces Tampa Electric's carbon emissions, reduces the use of potable water, reduces the utility dependency on natural gas and our customers will benefit from zero-fuel cost solar energy for years to come. As part of its strategic transformation to become cleaner and greener, Tampa Electric is launching another significant expansion of solar power.

Beyond 2023 there is an additional 747 MW<sub>AC</sub> of solar PV generating capacity shown in this TYSP that is in the planning and analysis phase and requires further development. In sum, TEC would have 2071.6 MW<sub>AC</sub> of solar capacity by the end of the study horizon, which means approximately 20.4 percent of our energy comes from the sun.

Since 2006, TEC implemented the Renewable Energy Program which offers residential, commercial and industrial customers the opportunity to purchase 200 kWh renewable energy “blocks” for their home or business. In 2009, TEC added a new portion to the program which allows residential, commercial and industrial customers the opportunity to purchase renewable energy in one-time blocks to power a specific event. This enables a family, business or venue to make a statement about their commitment to the environment and to renewable energy. Through December 2021, TEC's Renewable Energy Program has 1,146 customers purchasing over 1,900 blocks of renewable energy each month and there have been over 5,600 one-time blocks purchased since program inception.

The company's renewable generation portfolio is a mix of various technologies and renewable generation sources, including both large utility scale solar PV sites and smaller, company-owned community sited PV arrays that provide ample solar energy for the Renewable Energy Block Program. The smaller, community-sited PV arrays are currently installed at Middleton High school, the Manatee Viewing Center, Zoo Tampa at Lowry Park, the Florida Aquarium, LEGOLAND Florida's Imagination Zone and two arrays at the Museum of Science and Industry (MOSI). The newest array is located at Meachum Urban Farm, an organic farm and store open to the public in downtown Tampa. This system is a solar with battery storage, featuring a charging station for visitor use. The Renewable Energy Program installations are strategically located throughout the community and are designed to educate students and the public on the benefits of renewable energy. Educational signage touts the advantages of solar energy and interactive displays provide hands-on experience to engage visitors' interest in clean, renewable technologies.

The Florida Conservation and Technology Center (FCTC) located south of Big Bend Station is a collaborative partnership with the Florida Aquarium and Florida Fish & Wildlife to develop and educate students and the public on water and energy conservation technologies, marine science development and clean energy demonstrations. The FCTC site includes the TEC Manatee Viewing Center, the Center for Conservation, and the TEC Clean Energy Center (CEC). The CEC has a flexible rooftop adhesive PV array, a dual axis tracking PV Smart

Flower array, and a fixed tilt solar canopy array. The FCTC also includes a vertical axis Be-Wind wind turbine and a vanadium flow battery. A 1 MW<sub>AC</sub> floating solar pilot project at FCTC is scheduled to be commissioned by end of March 2022. It integrates solar panels onto floats and will analyze the benefits of bi-facial solar panels capabilities to increase the output created from reflected light onto the reverse side of the solar panels. The data collected and lessons learned will inform future applications over open water reservoirs and demonstrate that floating solar has the potential to decrease the evaporation of potable water. A 1 MW<sub>AC</sub> agrivoltaics pilot project at FCTC is scheduled to be operational in 2022. The project is designed to combine renewable energy with agriculture by positioning elevated solar panels over an understory of plants or crops. This will provide farmable acreage to balance the community attrition of acreage due to development. Agrivoltaics applications have the potential to lower the operating costs of large utility scale solar sites by sharing viable land with agricultural interests.

By Order No. PSC-2019-0215-TRF-EI, the Commission approved Tampa Electric Company's (TECO or utility) Shared Solar Tariff (SSR-1 tariff). The SSR-1 tariff provides residential and commercial customers with the option to purchase energy produced from a TECO-owned solar generation facility to replace all or a portion of their monthly energy consumption. Participants are charged a Shared Solar Charge of \$0.063 per kilowatt-hour. The SSR-1 tariff became effective on June 25, 2019, after TECO completed programming its billing system to administer the SSR-1 tariff. Tampa Electric Company launched Sun Select on June 26, 2019 to its customers.

## ***2. Storage Technology Initiatives***

Battery storage costs have declined over the last few years and are projected to continue to decline in the future. In December 2019, a 12.6 MW, 25 MWh lithium-ion energy storage system (ESS) was put in service at TEC's Big Bend Solar site. The ESS is integrated with the solar array and will charge via solar energy produced at the site and is discharged to the grid at times when our system is peaking or when solar production is reduced or unavailable. Expected benefits of battery storage projects include firming of the solar output during peak times and contribution to contingency reserves. TEC expects to develop and deploy approximately 265 MW of various types of energy storage systems from 2023 through 2031 to meet system reliability needs, maximize solar energy production by minimize solar clipping during low system peak periods, and potentially avoid transmission and distribution investments.

In 2018, Tampa Electric began interconnecting customer-owned battery storage. As of December 31, 2021, there are 318 customers interconnected with 3.030 kW DC storage capacity.

## ***3. Electric Vehicle Initiatives***

Customer adoption of Electric Vehicles (EV) continues to increase, and this trend is expected to continue into the foreseeable future. In 2021, Florida ranked second in the nation for the number of EVs sold, and TEC saw a nearly 30% increase in the number of EVs within our service area when compared to 2020. With continued improvements in battery technology and cost, increased access to public charging infrastructure, and announcements from major automakers to fully electrify in the coming decade, the upward trend in adoption is expected to accelerate.

Most recently, in 2021, the FPSC approved TEC's Drive Smart<sup>SM</sup> EV charging pilot, which allows for the installation of up to 200 Level 2 (240V) and up to four Direct Current Fast Charging (DCFC) stations across the service territory. The 4-year pilot will help to increase driver confidence by expanding access to EV charging, while also providing valuable data to support proper grid planning. In 2020, TEC received FPSC approval for Waiver of CIAC Rule No. 25-6.064, F.A.C. when primary line extensions are required to serve high-power DCFC locations. Through this waiver, TEC can extend the revenue period used in determining customer CIAC, from 5-years to

10-years. By doing so, the economics for charging station developers should significantly improve. In addition, to help educate the next generation of EV drivers, TEC launched a high school driver education program as an enhancement to the company's existing Energy Education and Awareness conservation program. TEC not only provides funding for the vehicles, but also installed the necessary EV chargers and helped to develop curriculum used in the classrooms.

As EV adoption continues to increase, smart grid enhancements, smart charging infrastructure and innovative customer programs will be necessary to help manage the potential effects of EV charging on our grid, in a way that benefits all TEC customers.

## **GENERATING UNIT PERFORMANCE ASSUMPTIONS**

TEC's generating unit performance assumptions are used to evaluate long-range system operating costs associated with integrated resource plans. Generating units are characterized by several different performance parameters. These parameters include capacity, heat rate, unit derations, planned maintenance days, and unplanned outage rates.

The unit performance projections are based on historical data trends, engineering judgment, time since last planned outage, and recent equipment performance. The first five years of planned outages are based on a forecasted outage schedule, and the planned outages for the balance of the years are based on a repetitive pattern.

The forecasted outage schedule is based on unit-specific maintenance needs, material lead-time, labor availability, and the need to supply our customers with power in the most economical manner. Unplanned outage rates are projected based on an average of three years of historical data, future expectations, and any necessary adjustments to account for current unit conditions.

## **GENERATION RELIABILITY CRITERIA**

### ***1. Reserve Margin***

TEC calculates reserve margin in two ways to measure reliability of the generating system. The company utilizes a minimum 20 percent firm reserve margin with a minimum contribution of 7 percent supply-side resources. TEC's approach to calculating percent reserves are consistent with the agreement that is outlined in the Commission approved Docket No. 981890-EU, Order No. PSC-99-2507-S-EU, issued December 22, 1999. The calculation of the minimum 20 percent firm reserve margin employs an industry accepted method of using total available generating capacity and firm purchased power capacity (capacity less planned maintenance and solar capacity unavailable at the time of peak demand, and contracted unit sales) and subtracting the annual firm peak load, then dividing by the firm peak load, and multiplying by 100. Capacity dedicated to any firm unit or station power sales at the time of system peak is subtracted from TEC's available capacity.

TEC's supply-side reserve margin is calculated by dividing the difference of projected supply-side resources and projected total peak demand by the forecasted firm peak demand. The total peak demand includes the firm peak demand and interruptible and load management loads.

## **2. Winter Reliability Assessment**

Tampa Electric Company's current and expected resources meet operating reserve requirements under normal peak demand scenarios. The reserve margin provides operating flexibility in the case of unplanned outages and deviations to load from colder than normal (or hotter than normal) weather. However, temperatures that vary significantly from those used to prepare this plan would result in the need to employ operating mitigation under these extreme conditions. These mitigations could include changes to unit dispatch to enhance reliability, switching to alternate fuels, making full use of demand response, pursuing purchase power agreements, and in a worst-case scenario interrupting customers to maintain grid stability. The company is also reviewing and updating its freeze protection plans for each of its generation stations and implementing measures to mitigate equipment failure during these extreme temperatures.

### **SUPPLY-SIDE RESOURCES PROCUREMENT PROCESS**

TEC uses wholesale power market opportunities to enhance and optimize its system. Prospective suppliers of supply-side resources are identified in accordance with established policies and procedures. Competitive bid evaluations are used in developing award recommendations to management. Fuel, fuel transportation, transmission availability, transmission cost, environmental requirements, ancillary services, and balancing requirements are considered as part of evaluating future supply-side resources.

This process allows for future supply-side resources to be supplied from self-build, purchased power, or asset purchases. Consistent with company practice, bidders are encouraged to propose incentive arrangements that promote development and implementation of cost savings and process-improvement recommendations.

### **TRANSMISSION PLANNING - CONSTRAINTS AND IMPACTS**

The TEC transmission system supports the reliable delivery of required capacity and energy to TEC's retail and wholesale customers. Transmission Planning studies are performed annually to evaluate the performance of the TEC transmission system with the results of the studies varying due to refinements in load projections, planning criteria, generation plans and operating flexibility. This involves the use of steady-state load flow, short circuit and transient stability programs to model various contingency situations, 3-Phase Fault and Single Line-Ground Fault analysis that may occur to determine if the TEC transmission system meets the reliability criteria. Simulations of normal system conditions, as well as single and select multiple contingency events, are performed during system peak and off-peak load levels, and summer and/or winter conditions.

Based on existing studies (ex: internal expansion, joint utility, operating, Florida Reliability Coordinating Council (FRCC) Long Range Study, FRCC Planning and Extreme Events Stability Analysis, FRCC Summer Assessment, FRCC Winter Assessment and other miscellaneous studies) and TEC's current transmission construction program, TEC anticipates no transmission constraints that violate the criteria as described in the Transmission Planning Reliability Criteria section of this document.

### **TRANSMISSION PLANNING RELIABILITY CRITERIA**

#### **1. Transmission**

TEC developed the transmission planning reliability criteria, as described in the FERC Form 715 filing, to assess and test the strength and limits of the transmission system, while meeting the load responsibility and being able to move bulk power between and among other electric systems. TEC has adopted the transmission planning

criteria outlined in the FRCC's *FRCC Regional Transmission Planning Process*. The FRCC's transmission planning criteria are consistent with the North American Electric Reliability Corporation (NERC) Reliability Standards.

In general, the NERC Reliability Standards state the transmission system will remain stable, within the applicable thermal and voltage rating limits, without cascading outages, under normal, single and select multiple contingency conditions. In addition to the FRCC criteria, TEC utilizes company-specific planning criteria for normal system operation and contingency operation, along with a Facility Rating Methodology and Facility Interconnection Requirements document available at <https://www.oasis.oati.com/TEC/index.html>.

The transmission planning reliability criteria are used as guidelines for proposing transmission system expansion and/or improvement projects, however they are not absolute rules for system expansion. These criteria are used to alert planners of potential transmission system capacity limitations. Engineering analysis is used in all stages of the planning process to weigh the impact of system deficiencies, the likelihood of the triggering contingency, and the viability of any operating options. Only by carefully researching each potential planning criteria violation can a final evaluation of available transmission capacity be made.

## **2. Available Transmission Transfer Capability (ATC) Criteria**

TEC adheres to the ATC calculation methodology described in the Attachment C of the *Tampa Electric Company Open Access Transmission Tariff FERC Electric Tariff, Fourth Revised Volume No. 4* document, accessible at <https://www.oasis.oati.com/woa/docs/TEC/TECdocs/TransmissionTariff.pdf>, as well as the principles contained in the NERC Reliability Standards relating to ATC calculations. Members of the FRCC, including TEC, have formed the Florida Transmission Capability Determination Group in an effort to provide ATC values to the regional electric market that are transparent, coordinated, timely and accurate.

## **TRANSMISSION SYSTEM PLANNING ASSESSMENT PRACTICES**

TEC's transmission system planning assessment practices are developed according to the TEC and NERC Reliability Standards to ensure a reliable system is planned that demonstrates adequacy within TEC's footprint to meet present and future system needs. The Reliability Standards require that the TEC transmission system be planned such that it will remain stable within the applicable facility ratings and voltage rating limits and without cascading outages under normal system conditions, as well as single and select multiple contingency events.

TEC performs transmission studies independently, collaboratively with other utilities, and as part of the FRCC to determine if the system meets the criteria. The studies involve the use of steady-state power flows, transient stability analyses, short circuit assessments and various other assessments to ensure adequate system performance.

### **1. Base Case Operating Conditions**

The TEC transmission system can support peak and off-peak system load levels while meeting the criteria as described in the Transmission Planning Reliability Criteria section of this document.

### **2. Single Contingency Planning Criteria**

The TEC transmission system is designed to support any single event outage of a transmission circuit, autotransformer, generator, or shunt device (including FRCC studies of Category P1 and P2-1 events) at a variety



of load levels while meeting the criteria as described in the Transmission Planning Reliability Criteria section of this document.

### **3. Multiple Contingency Planning Criteria**

Select double contingencies (including FRCC studies of Category P2-2 through P7 events) involving two or more Bulk Electric System (BES) transmission system elements out of service are analyzed at a variety of load levels. The TEC transmission system is designed such that double contingencies meet the criteria as described in the Transmission Planning Reliability Standards Criteria section of this document.

### **4. Transmission Construction and Upgrade Plans**

A specific list of the proposed directly associated transmission construction projects corresponding with the proposed generating facilities can be found in Chapter V, Schedule 10. This list represents the latest BES transmission construction related to the generation expansion on Schedule 8.1 and 9. However, due to the timing of this document in relationship to the company's internal planning schedule, this plan may change in the future. The current transmission construction and upgrade plan for the planning horizon does not require any electric utility system lines to be certified under the Transmission Line Siting Act (403.52-403.536, F.S.).

## **ENERGY EFFICIENCY, CONSERVATION, AND ENERGY SAVINGS DURABILITY**

TEC ensures that DSM programs the company offers are directly monitorable and yield measurable results. The achievements and durability of energy savings from the company's conservation and load management programs is validated by several methods. First, TEC has established a monitoring and evaluation process where historical analysis validates the energy savings. These include:

- Periodic system load reduction analysis for price responsive load management (Energy Planner), Commercial industrial load management and Commercial demand response to confirm and verify the accuracy of TEC's load reduction estimation formulas.
- Billing energy usage and demand analysis of participants in certain energy efficiency and conservation programs as compared to control groups.
- Analysis of DOE2 modeling of various program participants.
- End-use monitoring and evaluation of projects and programs.
- Specific metering of loads under control to determine the actual demand and energy savings in commercial programs such as Standby Generator and Commercial Load Management and Commercial Demand Response.

Second, the programs are designed to promote the use of high-efficiency equipment having permanent installation characteristics. Specifically, those programs that promote the installation of energy-efficient measures or equipment (heat pumps, hard-wired lighting fixtures, ceiling insulation, wall insulation, window replacements, air distribution system repairs, DX commercial cooling units, chiller replacements, water heating replacements, and ECM motor upgrades) have program standards that require the new equipment to be installed in a permanent manner thus ensuring their durability.

# Chapter IV



## **FORECAST OF ELECTRIC POWER, DEMAND AND ENERGY CONSUMPTION**

Tables in Schedules 2 through 4 reflect three different levels of load forecasting: base case, high case, and low case. The expansion plan is developed using the base case load forecast and is reflected on Schedules 5 through 9. This forecast band best represents the current economic conditions and the long-term impacts to TEC's service territory.

Schedule 2.1: History and Forecast of Energy Consumption and Number of Customers by Customer Class (Base, High & Low)

Schedule 2.2: History and Forecast of Energy Consumption and Number of Customers by Customer Class (Base, High & Low)

Schedule 2.3: History and Forecast of Energy Consumption and Number of Customers by Customer Class (Base, High & Low)

Schedule 3.1: History and Forecast of Summer Peak Demand (Base, High & Low)

Schedule 3.2: History and Forecast of Winter Peak Demand (Base, High & Low)

Schedule 3.3: History and Forecast of Annual Net Energy for Load (Base, High & Low)

Schedule 4: Previous Year and 2-Year Forecast of Peak Demand and Net Energy for Load by Month (Base, High & Low)

Schedule 5: History and Forecast of Fuel Requirements

Schedule 6.1: History and Forecast of Net Energy for Load by Fuel Source in GWh

Schedule 6.2: History and Forecast of Net Energy for Load by Fuel Source as a Percent



Schedule 2.1

History and Forecast of Energy Consumption and  
Number of Customers by Customer Class  
Base Case

(1)	(2)	(3)	Rural and Residential			Commercial		
	Hillsborough County Population	Members Per Household	GWH	Customers*	Average KWH Consumption Per Customer	GWH	Customers*	Average KWH Consumption Per Customer
2012	1,256,118	2.6	8,395	603,594	13,909	6,185	71,143	86,937
2013	1,276,410	2.6	8,470	613,206	13,812	6,090	71,966	84,619
2014	1,301,887	2.6	8,656	623,846	13,875	6,142	72,647	84,548
2015	1,325,563	2.6	9,045	635,403	14,235	6,301	73,556	85,658
2016	1,352,797	2.5	9,187	646,221	14,217	6,310	74,313	84,911
2017	1,379,302	2.6	9,029	659,387	13,693	6,362	74,998	84,830
2018	1,408,864	2.6	9,418	670,517	14,046	6,266	74,895	83,664
2019	1,444,870	2.6	9,584	685,122	13,989	6,239	76,038	82,057
2020	1,459,762	2.6	10,122	698,493	14,491	6,058	76,790	78,890
2021	1,490,374	2.6	9,941	713,135	13,940	6,144	78,115	78,653
2022	1,517,882	2.5	9,739	724,906	13,435	6,312	79,374	79,519
2023	1,544,461	2.5	9,853	737,780	13,355	6,359	80,193	79,299
2024	1,570,136	2.5	9,971	750,216	13,291	6,399	80,925	79,073
2025	1,594,771	2.5	10,062	762,148	13,202	6,430	81,493	78,897
2026	1,617,899	2.4	10,149	773,350	13,124	6,453	81,711	78,974
2027	1,640,079	2.4	10,235	784,094	13,054	6,471	81,737	79,163
2028	1,661,385	2.4	10,329	794,413	13,002	6,490	81,857	79,283
2029	1,681,901	2.4	10,431	804,351	12,968	6,509	82,105	79,280
2030	1,701,491	2.4	10,521	813,840	12,928	6,530	82,451	79,196
2031	1,720,003	2.4	10,608	822,806	12,892	6,547	82,762	79,102

Notes:

December 31, 2021 Status

\*Average of end-of-month customers for the calendar year.

Values shown may be affected due to rounding.

Schedule 2.1

History and Forecast of Energy Consumption and  
Number of Customers by Customer Class  
High Case

(1)	(2)	(3)	Rural and Residential			(6)	(7)	Commercial		(9)
			Hillsborough County <u>Population</u>	Members Per <u>Household</u>	<u>GWH</u>	<u>Customers*</u>	<u>Average KWH Consumption Per Customer</u>	<u>GWH</u>	<u>Customers*</u>	<u>Average KWH Consumption Per Customer</u>
2022	1,532,699	2.6			9,804	728,516	13,457	6,325	79,531	79,535
2023	1,567,200	2.6			9,985	745,147	13,400	6,387	80,515	79,333
2024	1,601,090	2.5			10,172	761,483	13,358	6,442	81,418	79,126
2025	1,634,216	2.5			10,334	777,451	13,292	6,488	82,161	78,972
2026	1,666,086	2.5			10,494	792,813	13,237	6,528	82,562	79,068
2027	1,698,578	2.5			10,656	807,839	13,190	6,562	82,774	79,276
2028	1,730,357	2.5			10,827	822,558	13,162	6,598	83,088	79,414
2029	1,761,488	2.5			11,009	837,007	13,153	6,635	83,533	79,432
2030	1,792,048	2.5			11,181	851,113	13,137	6,674	84,080	79,373
2031	1,821,881	2.5			11,351	864,792	13,126	6,709	84,597	79,303

Notes:

\*Average of end-of-month customers for the calendar year.  
Values shown may be affected due to rounding.

Schedule 2.1

History and Forecast of Energy Consumption and  
Number of Customers by Customer Class  
Low Case

(1)	(2)	(3)	Rural and Residential			(6)	(7)	Commercial		(9)
			Hillsborough County Population	Members Per Household	GWH	Customers*	Average KWH Consumption Per Customer	GWH	Customers*	Average KWH Consumption Per Customer
Year										
2022	1,502,929	2.5			9,674	721,297	13,412	6,298	79,216	79,503
2023	1,521,731	2.5			9,723	730,449	13,311	6,331	79,873	79,265
2024	1,539,420	2.4			9,773	739,060	13,224	6,356	80,437	79,019
2025	1,555,876	2.4			9,796	747,070	13,112	6,372	80,834	78,823
2026	1,570,660	2.4			9,813	754,267	13,010	6,380	80,877	78,880
2027	1,584,339	2.3			9,829	760,926	12,917	6,381	80,724	79,051
2028	1,596,999	2.3			9,851	767,088	12,842	6,385	80,663	79,151
2029	1,608,736	2.3			9,880	772,801	12,784	6,388	80,727	79,125
2030	1,619,430	2.3			9,896	778,007	12,720	6,391	80,885	79,018
2031	1,628,952	2.2			9,908	782,642	12,660	6,391	81,007	78,899

Notes:

\*Average of end-of-month customers for the calendar year.  
Values shown may be affected due to rounding.

Schedule 2.2

History and Forecast of Energy Consumption and  
Number of Customers by Customer Class  
Base Case

(1) Year	(2) GWH	(3) Industrial		(4) Average KWH Consumption Per Customer	(5) Railroads and Railways GWH	(6) Street & Highway Lighting GWH **	(7) Other Sales to Public Authorities GWH	(8) Total Sales to Ultimate Consumers GWH
		Customers*						
2012	2,001	1,537		1,302,171	0	75	1,756	18,412
2013	2,027	1,564		1,295,916	0	75	1,756	18,418
2014	1,901	1,572		1,208,831	0	75	1,752	18,526
2015	1,870	1,586		1,179,087	0	77	1,714	19,006
2016	1,928	1,616		1,193,504	0	78	1,730	19,234
2017	2,024	1,608		1,259,094	0	0	1,771	19,186
2018	2,014	1,588		1,268,262	0	0	1,933	19,631
2019	2,021	1,516		1,332,913	0	0	1,939	19,783
2020	1,891	1,408		1,342,642	0	0	1,883	19,954
2021	2,122	1,382		1,535,835	0	0	1,886	20,093
2022	1,862	1,392		1,337,396	0	0	1,899	19,812
2023	1,854	1,393		1,330,858	0	0	1,898	19,965
2024	1,840	1,394		1,319,389	0	0	1,899	20,109
2025	1,841	1,395		1,319,234	0	0	1,901	20,233
2026	1,840	1,396		1,318,016	0	0	1,903	20,345
2027	1,840	1,397		1,317,036	0	0	1,904	20,450
2028	1,839	1,397		1,316,592	0	0	1,906	20,564
2029	1,839	1,397		1,316,084	0	0	1,908	20,687
2030	1,839	1,397		1,316,139	0	0	1,909	20,800
2031	1,840	1,398		1,316,311	0	0	1,911	20,905

Notes:

December 31, 2021 Status

\*Average of end-of-month customers for the calendar year.

\*\*Sales shown for Street and Highway Lighting from 2017 forward are now included with Other Sales to Public Authorities.

Values shown may be affected due to rounding.

Schedule 2.2

History and Forecast of Energy Consumption and  
Number of Customers by Customer Class  
High Case

(1) Year	(2) GWH	(3) Industrial Customers*	(4) Average KWH Consumption Per Customer	(5) Railroads and Railways GWH	(6) Street & Highway Lighting GWH **	(7) Other Sales to Public Authorities GWH	(8) Total Sales to Ultimate Consumers GWH
2022	1,862	1,392	1,337,754	0	0	1,899	19,891
2023	1,855	1,393	1,331,785	0	0	1,898	20,126
2024	1,841	1,394	1,320,812	0	0	1,899	20,355
2025	1,843	1,395	1,321,010	0	0	1,901	20,566
2026	1,843	1,396	1,319,905	0	0	1,903	20,768
2027	1,842	1,397	1,318,859	0	0	1,904	20,965
2028	1,843	1,397	1,319,155	0	0	1,906	21,174
2029	1,843	1,397	1,319,266	0	0	1,908	21,395
2030	1,844	1,397	1,319,877	0	0	1,910	21,609
2031	1,845	1,398	1,319,611	0	0	1,911	21,816

Notes:

\*Average of end-of-month customers for the calendar year.

\*\*Sales for Street and Highway Lighting from 2017 forward are now included with Other Sales to Public Authorities.  
Values shown may be affected due to rounding.

Schedule 2.2

History and Forecast of Energy Consumption and  
Number of Customers by Customer Class  
Low Case

(1) Year	(2) GWH	(3) Industrial		(4) Average KWH Consumption Per Customer	(5) Railroads and Railways GWH	(6) Street & Highway Lighting GWH **	(7) Other Sales to Public Authorities GWH	(8) Total Sales to Ultimate Consumers GWH
		Customers*						
2022	1,861	1,392		1,337,130	0	0	1,899	19,733
2023	1,853	1,393		1,330,495	0	0	1,898	19,805
2024	1,838	1,394		1,318,828	0	0	1,899	19,867
2025	1,839	1,395		1,318,314	0	0	1,901	19,907
2026	1,838	1,396		1,316,488	0	0	1,902	19,933
2027	1,837	1,397		1,314,709	0	0	1,904	19,951
2028	1,836	1,397		1,314,248	0	0	1,906	19,977
2029	1,835	1,397		1,313,575	0	0	1,907	20,009
2030	1,835	1,397		1,313,371	0	0	1,909	20,031
2031	1,835	1,398		1,312,264	0	0	1,910	20,044

Notes:

\*Average of end-of-month customers for the calendar year.

\*\*Sales for Street and Highway Lighting from 2017 forward are now included with Other Sales to Public Authorities.  
Values shown may be affected due to rounding.



### Schedule 2.3

#### History and Forecast of Energy Consumption and Number of Customers by Customer Class Base Case

(1) <u>Year</u>	(2) <u>Sales for * Resale GWH</u>	(3) <u>Utility Use ** &amp; Losses GWH</u>	(4) <u>Net Energy *** for Load GWH</u>	(5) <u>Other **** Customers</u>	(6) <u>Total **** Customers</u>
2012	69	839	19,320	7,962	684,236
2013	0	760	19,177	7,999	694,735
2014	0	789	19,315	8,095	706,161
2015	0	1,098	20,105	8,168	718,713
2016	9	930	20,173	8,353	730,503
2017	2	1,110	20,298	8,698	744,690
2018	0	1,031	20,662	9,254	756,254
2019	0	986	20,770	9,283	771,960
2020	0	1,101	21,055	9,356	786,047
2021	0	940	21,033	9,418	802,050
2022	0	971	20,783	9,506	815,178
2023	0	978	20,943	9,551	828,917
2024	0	985	21,095	9,601	842,136
2025	0	992	21,225	9,652	854,689
2026	0	997	21,342	9,706	866,163
2027	0	1,003	21,452	9,761	876,988
2028	0	1,008	21,572	9,816	887,484
2029	0	1,014	21,701	9,871	897,725
2030	0	1,020	21,820	9,927	907,615
2031	0	1,025	21,930	9,983	916,948

**Notes:**

December 31, 2021 Status

\*Includes sales to St. Cloud (STC), Reedy Creek (RCID) and Florida Power & Light (FPL).

Contract ended with STC on 12/31/2012, and FPL on 12/31/12. RCID contract from 2016 to 2017.

\*\*Utility Use and Losses include accrued sales.

\*\*\*Net Energy for Load includes output to line including energy supplied by purchased cogeneration.

\*\*\*\*Average of end-of-month customers for the calendar year.

Values shown may be affected due to rounding.

**Schedule 2.3**

**History and Forecast of Energy Consumption and  
Number of Customers by Customer Class  
High Case**

(1)	(2)	(3)	(4)	(5)	(6)
<u>Year</u>	<u>Sales for Resale GWH</u>	<u>Utility Use * &amp; Losses GWH</u>	<u>Net Energy ** for Load GWH</u>	<u>Other *** Customers</u>	<u>Total *** Customers</u>
<b>2022</b>	0	974	20,865	9,506	818,945
<b>2023</b>	0	986	21,112	9,551	836,606
<b>2024</b>	0	997	21,352	9,601	853,896
<b>2025</b>	0	1,008	21,574	9,652	870,659
<b>2026</b>	0	1,018	21,786	9,706	886,477
<b>2027</b>	0	1,027	21,992	9,761	901,771
<b>2028</b>	0	1,038	22,212	9,816	916,859
<b>2029</b>	0	1,049	22,444	9,871	931,808
<b>2030</b>	0	1,059	22,668	9,927	946,517
<b>2031</b>	0	1,070	22,886	9,983	960,770

**Notes:**

\*Utility Use and Losses include accrued sales.

\*\*Net Energy for Load includes output to line including energy supplied by purchased cogeneration.

\*\*\*Average of end-of-month customers for the calendar year.

Values shown may be affected due to rounding.

**Schedule 2.3**

**History and Forecast of Energy Consumption and  
Number of Customers by Customer Class  
Low Case**

(1) <u>Year</u>	(2) <u>Sales for Resale GWH</u>	(3) <u>Utility Use * &amp; Losses GWH</u>	(4) <u>Net Energy ** for Load GWH</u>	(5) <u>Other *** Customers</u>	(6) <u>Total *** Customers</u>
<b>2022</b>	0	967	20,700	9,506	811,411
<b>2023</b>	0	971	20,776	9,551	821,266
<b>2024</b>	0	974	20,841	9,601	830,492
<b>2025</b>	0	976	20,883	9,652	838,951
<b>2026</b>	0	978	20,911	9,706	846,246
<b>2027</b>	0	978	20,929	9,761	852,808
<b>2028</b>	0	979	20,956	9,816	858,964
<b>2029</b>	0	982	20,991	9,871	864,796
<b>2030</b>	0	983	21,014	9,927	870,216
<b>2031</b>	0	984	21,028	9,983	875,030

**Notes:**

\*Utility Use and Losses include accrued sales.  
 \*\*Net Energy for Load includes output to line including energy supplied by purchased cogeneration.  
 \*\*\*Average of end-of-month customers for the calendar year.  
 Values shown may be affected due to rounding.

Schedule 3.1

History and Forecast of Summer Peak Demand (MW)  
Base Case

(1) Year	(2) Total *	(3) Wholesale**	(4) Retail *	(5) Interruptible	(6) Residential Load Management	(7) Residential Conservation***	(8) Comm./Ind. Load Management	(9) Comm./Ind. Conservation	(10) Net Firm Demand
2012	4,089	15	4,073	133	45	111	86	71	3,627
2013	4,072	0	4,072	131	39	122	89	77	3,614
2014	4,270	0	4,270	170	36	132	91	83	3,757
2015	4,245	0	4,245	111	21	143	98	87	3,784
2016	4,403	15	4,388	138	0	150	101	92	3,907
2017	4,373	5	4,368	110	0	155	100	98	3,905
2018	4,287	0	4,287	125	0	160	98	106	3,798
2019	4,591	0	4,591	122	0	166	98	126	4,079
2020	4,568	0	4,568	113	0	169	98	135	4,053
2021	4,706	0	4,706	187	0	174	98	139	4,108
2022	4,555	0	4,555	113	1	187	106	147	4,002
2023	4,616	0	4,616	112	4	198	106	153	4,043
2024	4,674	0	4,674	110	8	209	106	159	4,082
2025	4,729	0	4,729	110	13	221	106	165	4,113
2026	4,780	0	4,780	110	20	234	106	171	4,139
2027	4,829	0	4,829	110	27	248	107	177	4,161
2028	4,880	0	4,880	110	35	261	107	183	4,184
2029	4,931	0	4,931	110	43	275	107	189	4,207
2030	4,981	0	4,981	110	52	288	107	195	4,229
2031	5,029	0	5,029	110	60	301	108	201	4,249

Notes:

December 31, 2021 Status

2016, 2018 and 2020 Net Firm Demand is not coincident with system peak.

\*Includes residential and commercial/industrial conservation.

\*\*Includes sales to RCID, STC and FP&L. Contract ended with STC on 12/31/12 and FP&L on 12/31/12.

Contract with RCID from 2016 to 2017.

\*\*\*Includes Energy Planner program.

Values shown may be affected due to rounding.

Schedule 3.1

Forecast of Summer Peak Demand (MW)  
High Case

(1) Year	(2) <u>Total *</u>	(3) <u>Wholesale</u>	(4) <u>Retail *</u>	(5) <u>Interruptible</u>	(6) <u>Residential Load Management</u>	(7) <u>Residential Conservation**</u>	(8) <u>Comm./Ind. Load Management</u>	(9) <u>Comm./Ind. Conservation</u>	(10) <u>Net Firm Demand</u>
2022	4,576	0	4,576	113	1	187	106	147	4,023
2023	4,658	0	4,658	112	4	198	106	153	4,085
2024	4,740	0	4,740	110	8	209	106	159	4,147
2025	4,819	0	4,819	110	13	221	106	165	4,204
2026	4,897	0	4,897	110	20	234	106	171	4,256
2027	4,975	0	4,975	110	27	248	107	177	4,307
2028	5,056	0	5,056	110	35	261	107	183	4,360
2029	5,137	0	5,137	110	43	275	107	189	4,413
2030	5,218	0	5,218	110	52	288	107	195	4,466
2031	5,298	0	5,298	110	60	301	108	201	4,518

**Notes:**

\*Includes residential and commercial/industrial conservation.

\*\*Includes Energy Planner program.

Values shown may be affected due to rounding.

Schedule 3.1

Forecast of Summer Peak Demand (MW)  
Low Case

(1) <u>Year</u>	(2) <u>Total *</u>	(3) <u>Wholesale</u>	(4) <u>Retail *</u>	(5) <u>Interruptible</u>	(6) <u>Residential Load Management</u>	(7) <u>Residential Conservation**</u>	(8) <u>Comm./Ind. Load Management</u>	(9) <u>Comm./Ind. Conservation</u>	(10) <u>Net Firm Demand</u>
2022	4,540	0	4,540	113	1	187	106	147	3,987
2023	4,585	0	4,585	112	4	198	106	153	4,012
2024	4,628	0	4,628	110	8	209	106	159	4,035
2025	4,668	0	4,668	110	13	221	106	165	4,053
2026	4,705	0	4,705	110	20	234	106	171	4,064
2027	4,742	0	4,742	110	27	248	107	177	4,074
2028	4,781	0	4,781	110	35	261	107	183	4,085
2029	4,819	0	4,819	110	43	275	107	189	4,095
2030	4,856	0	4,856	110	52	288	107	195	4,104
2031	4,891	0	4,891	110	60	301	108	201	4,111

**Notes:**

\*Includes residential and commercial/industrial conservation.

\*\*Includes Energy Planner program.

Values shown may be affected due to rounding.

**Schedule 3.2**

**History and Forecast of Winter Peak Demand (MW)  
Base Case**

(1) <u>Year</u>	(2) <u>Total *</u>	(3) <u>Wholesale **</u>	(4) <u>Retail *</u>	(5) <u>Interruptible</u>	(6) <u>Residential Load Management</u>	(7) <u>Residential Conservation***</u>	(8) <u>Comm./Ind. Load Management</u>	(9) <u>Comm./Ind. Conservation</u>	(10) <u>Net Firm Demand</u>
2011/12	4,186	120	4,066	103	68	487	83	58	3,267
2012/13	3,780	15	3,764	130	65	501	90	61	2,918
2013/14	3,876	0	3,876	61	63	512	97	64	3,079
2014/15	4,195	0	4,195	79	44	521	96	65	3,390
2015/16	4,025	0	4,025	145	13	533	96	67	3,171
2016/17	3,749	0	3,749	137	0	541	96	70	2,905
2017/18	4,670	0	4,670	66	0	548	96	77	3,883
2018/19	3,921	0	3,921	104	0	556	98	92	3,071
2019/20	4,237	0	4,237	140	0	564	97	99	3,336
2020/21	4,147	0	4,147	132	0	568	98	103	3,247
2021/22	5,148	0	5,148	112	0	578	103	109	4,246
2022/23	5,211	0	5,211	111	2	588	103	114	4,294
2023/24	5,278	0	5,278	109	6	598	104	119	4,342
2024/25	5,342	0	5,342	109	10	608	104	124	4,387
2025/26	5,400	0	5,400	109	16	618	105	128	4,423
2026/27	5,455	0	5,455	109	22	629	105	133	4,456
2027/28	5,511	0	5,511	109	30	639	106	138	4,488
2028/29	5,566	0	5,566	109	38	650	106	143	4,519
2029/30	5,620	0	5,620	109	47	660	107	148	4,549
2030/31	5,673	0	5,673	109	55	671	107	153	4,578

**Notes:**

December 31, 2021 Status

2011/2012, 2015/2016 and 2020/2021 Net Firm Demand is not coincident with system peak.

\*Includes residential and commercial/industrial conservation.

\*\*Includes sales to RCID, STC and FP&L. Contract ended with STC on 12/31/12 and FP&L on 12/31/12. Contract with RCID from 2016 to 2017.

\*\*\*Includes energy planner program.

Values shown may be affected due to rounding.

Schedule 3.2

Forecast of Winter Peak Demand (MW)  
High Case

(1) Year	(2) Total *	(3) Wholesale	(4) Retail *	(5) Interruptible	(6) Residential Load Management	(7) Residential Conservation**	(8) Comm./Ind. Load Management	(9) Comm./Ind. Conservation	(10) Net Firm Demand
2021/22	5,168	0	5,168	112	0	578	103	109	4,267
2022/23	5,255	0	5,255	111	2	588	103	114	4,337
2023/24	5,346	0	5,346	109	6	598	104	119	4,411
2024/25	5,435	0	5,435	109	10	608	104	124	4,480
2025/26	5,521	0	5,521	109	16	618	105	128	4,544
2026/27	5,606	0	5,606	109	22	629	105	133	4,607
2027/28	5,692	0	5,692	109	30	639	106	138	4,670
2028/29	5,779	0	5,779	109	38	650	106	143	4,732
2029/30	5,866	0	5,866	109	47	660	107	148	4,795
2030/31	5,952	0	5,952	109	55	671	107	153	4,857

**Notes:**

\*Includes residential and commercial/industrial conservation.

\*\*Includes Energy Planner program

Values shown may be affected due to rounding.



Schedule 3.2

Forecast of Winter Peak Demand (MW)  
Low Case

(1) Year	(2) Total *	(3) Wholesale	(4) Retail *	(5) Interruptible	(6) Residential Load Management	(7) Residential Conservation**	(8) Comm./Ind. Load Management	(9) Comm./Ind. Conservation	(10) Net Firm Demand
2021/22	5,129	0	5,129	112	0	578	103	109	4,228
2022/23	5,176	0	5,176	111	2	588	103	114	4,258
2023/24	5,227	0	5,227	109	6	598	104	119	4,292
2024/25	5,274	0	5,274	109	10	608	104	124	4,319
2025/26	5,317	0	5,317	109	16	618	105	128	4,340
2026/27	5,358	0	5,358	109	22	629	105	133	4,359
2027/28	5,399	0	5,399	109	30	639	106	138	4,377
2028/29	5,441	0	5,441	109	38	650	106	143	4,394
2029/30	5,481	0	5,481	109	47	660	107	148	4,410
2030/31	5,519	0	5,519	109	55	671	107	153	4,424

Notes:

\*Includes residential and commercial/industrial conservation.

\*\*Includes Energy Planner program

Values shown may be affected due to rounding.

Schedule 3.3

History and Forecast of Annual Net Energy for Load (GWh)  
Base Case

(1) Year	(2) Total*	(3) Residential Conservation**	(4) Comm./Ind. Conservation	(5) Retail	(6) Wholesale ***	(7) Utility Use & Losses	(8) Net Energy for Load	(9) Load **** Factor %
2012	19,178	493	273	18,412	69	839	19,320	56.3
2013	19,225	513	294	18,418	0	760	19,177	56.5
2014	19,377	546	305	18,526	0	789	19,315	54.4
2015	19,890	568	315	19,006	0	1,098	20,105	57.2
2016	20,153	588	331	19,234	9	930	20,173	55.2
2017	20,141	602	353	19,186	2	1,110	20,298	56.2
2018	20,647	618	399	19,631	0	1,031	20,662	58.3
2019	20,896	635	478	19,783	0	986	20,770	55.2
2020	21,085	644	487	19,954	0	1,101	21,055	56.2
2021	21,256	656	508	20,093	0	940	21,033	54.7
2022	21,041	686	543	19,812	0	971	20,783	53.2
2023	21,249	713	572	19,965	0	978	20,943	53.0
2024	21,450	740	601	20,109	0	985	21,095	52.7
2025	21,631	767	631	20,233	0	992	21,225	52.6
2026	21,802	798	660	20,345	0	997	21,342	52.4
2027	21,968	829	689	20,450	0	1,003	21,452	52.2
2028	22,143	861	719	20,564	0	1,008	21,572	51.9
2029	22,327	892	748	20,687	0	1,014	21,701	51.9
2030	22,501	924	777	20,800	0	1,020	21,820	51.8
2031	22,667	956	806	20,905	0	1,025	21,930	51.6

**Notes:**

December 31, 2021 Status

\*Includes residential and commercial/industrial conservation.

\*\*Includes Energy Planner program.

\*\*\*Includes sales to RCID, STC and FP&L. Contract ended with STC on 12/31/12 and FP&L on 12/31/12.

Contract with RCID from 2016 to 2017.

\*\*\*\*Load Factor is the ratio of total system average load to peak demand.

Values shown may be affected due to rounding.

### Schedule 3.3

#### Forecast of Annual Net Energy for Load (GWh) High Case

(1) Year	(2) Total*	(3) Residential Conservation**	(4) Comm./Ind. Conservation	(5) Retail	(6) Wholesale	(7) Utility Use & Losses	(8) Net Energy for Load	(9) Load *** Factor %
2022	21,120	686	543	19,891	0	974	20,865	53.1
2023	21,410	713	572	20,126	0	986	21,112	52.9
2024	21,696	740	601	20,355	0	997	21,352	52.5
2025	21,964	767	631	20,566	0	1,008	21,574	52.4
2026	22,225	798	660	20,768	0	1,018	21,786	52.1
2027	22,483	829	689	20,965	0	1,027	21,992	51.8
2028	22,753	861	719	21,174	0	1,038	22,212	51.4
2029	23,036	892	748	21,395	0	1,049	22,444	51.4
2030	23,310	924	777	21,609	0	1,059	22,668	51.2
2031	23,578	956	806	21,816	0	1,070	22,886	50.9

**Notes:**

\*Includes residential and commercial/industrial conservation.

\*\*Includes Energy Planner program

\*\*\*Load Factor is the ratio of total system average load to peak demand.  
Values shown may be affected due to rounding.

Schedule 3.3

Forecast of Annual Net Energy for Load (GWh)  
Low Case

(1) Year	(2) <u>Total*</u>	(3) <u>Residential Conservation**</u>	(4) <u>Comm./Ind. Conservation</u>	(5) <u>Retail</u>	(6) <u>Wholesale</u>	(7) <u>Utility Use &amp; Losses</u>	(8) <u>Net Energy for Load</u>	(9) <u>Load *** Factor %</u>
2022	20,962	686	543	19,733	0	967	20,700	53.2
2023	21,090	713	572	19,805	0	971	20,776	53.0
2024	21,208	740	601	19,867	0	974	20,841	52.6
2025	21,305	767	631	19,907	0	976	20,883	52.5
2026	21,391	798	660	19,933	0	978	20,911	52.2
2027	21,469	829	689	19,951	0	978	20,929	52.0
2028	21,556	861	719	19,977	0	979	20,956	51.6
2029	21,650	892	748	20,009	0	982	20,991	51.6
2030	21,732	924	777	20,031	0	983	21,014	51.3
2031	21,806	956	806	20,044	0	984	21,028	51.1

**Notes:**

\*Includes residential and commercial/industrial conservation.

\*\*Includes Energy Planner program

\*\*\*Load Factor is the ratio of total system average load to peak demand.  
Values shown may be affected due to rounding.

**Schedule 4  
Base Case**

**Previous Year and 2-Year Forecast of Peak Demand and Net Energy for Load (NEL) by Month**

(1)	(2)	(3)	(4)	(5)	(6)	(7)
	<b>2021 Actual</b>		<b>2022 Forecast</b>		<b>2023 Forecast</b>	
<u>Month</u>	<u>Peak Demand *</u> <u>MW</u>	<u>NEL **</u> <u>GWH</u>	<u>Peak Demand *</u> <u>MW</u>	<u>NEL **</u> <u>GWH</u>	<u>Peak Demand *</u> <u>MW</u>	<u>NEL **</u> <u>GWH</u>
<b>January</b>	2,905	1,476	4,461	1,506	4,510	1,512
<b>February</b>	3,415	1,389	3,663	1,347	3,700	1,352
<b>March</b>	3,467	1,571	3,522	1,496	3,557	1,504
<b>April</b>	3,636	1,594	3,567	1,589	3,601	1,599
<b>May</b>	4,069	1,929	3,856	1,847	3,893	1,861
<b>June</b>	4,057	1,993	4,149	2,001	4,191	2,019
<b>July</b>	4,211	2,123	4,135	2,081	4,177	2,101
<b>August</b>	4,393	2,169	4,222	2,120	4,265	2,141
<b>September</b>	3,968	1,964	3,915	1,967	3,956	1,987
<b>October</b>	3,961	1,879	3,664	1,830	3,700	1,847
<b>November</b>	2,924	1,391	3,101	1,465	3,134	1,477
<b>December</b>	2,941	1,555	3,768	1,533	3,809	1,543
<b><u>TOTAL</u></b>		<u>21,033</u>		<u>20,783</u>		<u>20,943</u>

**Notes:**

December 31, 2021 Status

\*Peak demand represents total retail and wholesale demand, excluding conservation impacts.

\*\*Values shown may be affected due to rounding.

**Schedule 4  
High Case**

**Previous Year and 2-Year Forecast of Peak Demand and Net Energy for Load (NEL) by Month**

(1) <u>Month</u>	2021 Actual		2022 Forecast		2023 Forecast	
	(2) <u>Peak Demand *</u> <u>MW</u>	(3) <u>NEL **</u> <u>GWH</u>	(4) <u>Peak Demand *</u> <u>MW</u>	(5) <u>NEL **</u> <u>GWH</u>	(6) <u>Peak Demand *</u> <u>MW</u>	(7) <u>NEL **</u> <u>GWH</u>
<b>January</b>	2,905	1,476	4,482	1,512	4,553	1,524
<b>February</b>	3,415	1,389	3,679	1,352	3,732	1,363
<b>March</b>	3,467	1,571	3,537	1,502	3,587	1,515
<b>April</b>	3,636	1,594	3,582	1,595	3,632	1,611
<b>May</b>	4,069	1,929	3,872	1,854	3,927	1,876
<b>June</b>	4,057	1,993	4,167	2,010	4,227	2,036
<b>July</b>	4,211	2,123	4,153	2,090	4,213	2,119
<b>August</b>	4,393	2,169	4,242	2,129	4,307	2,159
<b>September</b>	3,968	1,964	3,932	1,975	3,989	2,003
<b>October</b>	3,961	1,879	3,679	1,837	3,731	1,862
<b>November</b>	2,924	1,391	3,114	1,471	3,160	1,489
<b>December</b>	2,941	1,555	3,783	1,539	3,841	1,555
<b><u>TOTAL</u></b>		<u>21,033</u>		<u>20,865</u>		<u>21,112</u>

**Notes:**

December 31, 2021 Status

\*Peak demand represents total retail and wholesale demand, excluding conservation impacts.

\*\*Values shown may be affected due to rounding.

**Schedule 4  
Low Case**

**Previous Year and 2-Year Forecast of Peak Demand and Net Energy for Load (NEL) by Month**

(1) <u>Month</u>	2021 Actual		2022 Forecast		2023 Forecast	
	(2) <u>Peak Demand *</u> <u>MW</u>	(3) <u>NEL **</u> <u>GWH</u>	(4) <u>Peak Demand *</u> <u>MW</u>	(5) <u>NEL **</u> <u>GWH</u>	(6) <u>Peak Demand *</u> <u>MW</u>	(7) <u>NEL **</u> <u>GWH</u>
January	2,905	1,476	4,443	1,500	4,474	1,500
February	3,415	1,389	3,648	1,342	3,669	1,342
March	3,467	1,571	3,507	1,491	3,526	1,492
April	3,636	1,594	3,552	1,583	3,570	1,587
May	4,069	1,929	3,839	1,839	3,860	1,846
June	4,057	1,993	4,131	1,993	4,155	2,003
July	4,211	2,123	4,117	2,072	4,141	2,083
August	4,393	2,169	4,206	2,111	4,234	2,123
September	3,968	1,964	3,899	1,959	3,922	1,970
October	3,961	1,879	3,649	1,822	3,669	1,832
November	2,924	1,391	3,089	1,459	3,108	1,466
December	2,941	1,555	3,752	1,527	3,777	1,532
<b><u>TOTAL</u></b>		<u>21,033</u>		<u>20,701</u>		<u>20,776</u>

**Notes:**

December 31, 2021 Status

\*Peak demand represents total retail and wholesale demand, excluding conservation impacts.

\*\*Values shown may be affected due to rounding.

**Schedule 5**

**History and Forecast of Fuel Requirements  
Base Case Forecast Basis**

(1)	(2)	(3)	(4)	(5)	(6)	(7)	(8)	(9)	(10)	(11)	(12)	(13)	(14)	(15)
	<u>Fuel Requirements</u>	<u>Unit</u>	<u>Actual</u> <u>2020</u>	<u>Actual</u> <u>2021</u>	<u>2022</u>	<u>2023</u>	<u>2024</u>	<u>2025</u>	<u>2026</u>	<u>2027</u>	<u>2028</u>	<u>2029</u>	<u>2030</u>	<u>2031</u>
(1)	Nuclear	Trillion BTU	0	0	0	0	0	0	0	0	0	0	0	0
(2)	Coal	1000 Ton	434	638	719	357	385	75	104	84	82	82	65	88
(3)	Residual	1000 BBL	0	0	0	0	0	0	0	0	0	0	0	0
(4)	ST	1000 BBL	0	0	0	0	0	0	0	0	0	0	0	0
(5)	CC	1000 BBL	0	0	0	0	0	0	0	0	0	0	0	0
(6)	GT	1000 BBL	0	0	0	0	0	0	0	0	0	0	0	0
(7)	D	1000 BBL	0	0	0	0	0	0	0	0	0	0	0	0
(8)	Distillate	1000 BBL	4	6	0	0	0	0	0	0	0	0	0	0
(9)	ST	1000 BBL	0	0	0	0	0	0	0	0	0	0	0	0
(10)	CC	1000 BBL	0	0	0	0	0	0	0	0	0	0	0	0
(11)	GT	1000 BBL	4	6	0	0	0	0	0	0	0	0	0	0
(12)	D	1000 BBL	0	0	0	0	0	0	0	0	0	0	0	0
(13)	Natural Gas	1000 MCF	127,841	124,017	128,793	121,386	119,075	123,481	120,375	119,419	118,689	118,761	118,206	118,476
(14)	ST	1000 MCF	25,422	20,466	5,833	1,963	547	3,895	5,439	4,389	4,245	4,308	3,418	4,566
(15)	CC	1000 MCF	101,977	99,954	121,293	117,690	115,609	118,683	114,000	114,292	113,977	113,582	113,281	112,602
(16)	GT	1000 MCF	442	3,596	1,667	1,733	2,919	903	936	738	467	871	1,507	1,308
(17)	Other (Specify)													
(18)	PC	1000 Ton	0	0	0	0	0	0	0	0	0	0	0	0

**Notes:**

Values shown may be affected due to rounding.  
 Actual values exclude ignition.  
 Values are based on the economic dispatch of TEC's planned portfolio using the most recent fuel price projections and are subject to change.  
 Dual fuel capabilities will be maintained on applicable units.



**Schedule 6.1**

**History and Forecast of Net Energy for Load by Fuel Source  
Base Case Forecast Basis**

(1)	(2)	(3)	(4)	(5)	(6)	(7)	(8)	(9)	(10)	(11)	(12)	(13)	(14)	(15)
	<u>Energy Sources</u>	<u>Unit</u>	<u>Actual</u> <u>2020</u>	<u>Actual</u> <u>2021</u>	<u>2022</u>	<u>2023</u>	<u>2024</u>	<u>2025</u>	<u>2026</u>	<u>2027</u>	<u>2028</u>	<u>2029</u>	<u>2030</u>	<u>2031</u>
(1)	Annual Firm Interchange	GWh	1,175	77	1	0	0	0	0	0	0	0	0	0
(2)	Nuclear	GWh	0	0	0	0	0	0	0	0	0	0	0	0
(3)	Coal	GWh	909	1,358	1,321	652	702	136	190	152	148	150	119	160
(4)	Residual	GWh	0	0	0	0	0	0	0	0	0	0	0	0
(5)	ST	GWh	0	0	0	0	0	0	0	0	0	0	0	0
(6)	CC	GWh	0	0	0	0	0	0	0	0	0	0	0	0
(7)	GT	GWh	0	0	0	0	0	0	0	0	0	0	0	0
(8)	D	GWh	0	0	0	0	0	0	0	0	0	0	0	0
(9)	Distillate	GWh	2	2	0	0	0	0	0	0	0	0	0	0
(10)	ST	GWh	0	0	0	0	0	0	0	0	0	0	0	0
(11)	CC	GWh	0	0	0	0	0	0	0	0	0	0	0	0
(12)	GT	GWh	2	2	0	0	0	0	0	0	0	0	0	0
(13)	D	GWh	0	0	0	0	0	0	0	0	0	0	0	0
(14)	Natural Gas	GWh	16,514	16,124	17,452	17,877	17,482	18,083	17,501	17,528	17,400	17,379	17,361	17,278
(15)	ST	GWh	2,163	1,743	485	158	37	317	444	356	346	349	278	374
(16)	CC	GWh	14,313	13,992	16,836	17,593	17,204	17,698	16,982	17,116	17,017	16,958	16,952	16,787
(17)	GT	GWh	38	389	131	126	241	68	75	56	37	72	131	117
(18)	Renewable	GWh	1,120	1,252	1,949	2,356	2,874	2,981	3,619	3,755	4,010	4,165	4,323	4,481
(19)	Solar	GWh	1,120	1,252	1,949	2,356	2,874	2,981	3,619	3,755	4,010	4,165	4,323	4,481
(20)	Other (Specify)													
(21)	PC	GWh	0	0	0	0	0	0	0	0	0	0	0	0
(22)	Net Interchange	GWh	1,202	2,157	(9)	(6)	(19)	(29)	(22)	(34)	(36)	(38)	(27)	(29)
(23)	Purchased Energy from													
(24)	Non-Utility Generators	GWh	133	63	69	64	59	59	59	59	59	59	59	59
(24)	Other	GWh	0	0	0	0	(3)	(5)	(5)	(8)	(9)	(14)	(15)	(18)
(25)	Net Energy for Load	GWh	21,055	21,033	20,783	20,943	21,095	21,225	21,342	21,452	21,572	21,701	21,820	21,930

**Notes:**

Line (22) includes energy purchased from Non-Renewable and Renewable resources.  
 Values shown may be affected due to rounding.  
 Values are based on the economic dispatch of TEC's planned portfolio using the most recent fuel price projections and are subject to change.  
 Dual fuel capabilities will be maintained on applicable units.  
 Generation quantities do not reflect periodic testing of distillate fuel oil capability  
 Batteries are represented in row (24)

**History and Forecast of Net Energy for Load by Fuel Source**  
Base Case Forecast Basis

(1)	(2)	(3)	(4)	(5)	(6)	(7)	(8)	(9)	(10)	(11)	(12)	(13)	(14)	(15)
	<u>Energy Sources</u>	<u>Unit</u>	<u>Actual</u> <u>2020</u>	<u>Actual</u> <u>2021</u>	<u>2022</u>	<u>2023</u>	<u>2024</u>	<u>2025</u>	<u>2026</u>	<u>2027</u>	<u>2028</u>	<u>2029</u>	<u>2030</u>	<u>2031</u>
(1)	Annual Firm Interchange	%	5.6	0.4	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
(2)	Nuclear	%	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
(3)	Coal	%	4.3	6.5	6.4	3.1	3.3	0.6	0.9	0.7	0.7	0.7	0.5	0.7
(4)	Residual	%	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
(5)	ST	%	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
(6)	CC	%	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
(7)	GT	%	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
(8)	D	%	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
(9)	Distillate	%	0.0	0.01	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
(10)	ST	%	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
(11)	CC	%	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
(12)	GT	%	0.0	0.01	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
(13)	D	%	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
(14)	Natural Gas	%	78.4	76.7	84.0	85.4	82.9	85.2	82.0	81.7	80.7	80.1	79.6	78.8
(15)	ST	%	10.3	8.3	2.3	0.8	0.2	1.5	2.1	1.7	1.6	1.6	1.3	1.7
(16)	CC	%	68.0	66.5	81.0	84.0	81.6	83.4	79.6	79.8	78.9	78.1	77.7	76.5
(17)	GT	%	0.2	1.8	0.6	0.6	1.1	0.3	0.4	0.3	0.2	0.3	0.6	0.5
(18)	Renewable	%	5.3	6.0	9.4	11.2	13.6	14.0	17.0	17.5	18.6	19.2	19.8	20.4
(19)	Solar	%	5.3	6.0	9.4	11.2	13.6	14.0	17.0	17.5	18.6	19.2	19.8	20.4
(20)	Other (Specify)													
(21)	PC	%	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
(22)	Net Interchange	%	5.7	10.3	(0.0)	(0.0)	(0.1)	(0.1)	(0.1)	(0.2)	(0.2)	(0.2)	(0.1)	(0.1)
(23)	Purchased Energy from													
(24)	Non-Utility Generators	%	0.6	0.3	0.3	0.3	0.3	0.3	0.3	0.3	0.3	0.3	0.3	0.3
(24)	Other	%	0.0	0.0	0.0	0.0	(0.0)	(0.0)	(0.0)	(0.0)	(0.0)	(0.1)	(0.1)	(0.1)
(25)	Net Energy for Load	%	100.0	100.0	100.0	100.0	100.0	100.0	100.0	100.0	100.0	100.0	100.0	100.0

**Notes:**

Line (22) includes energy purchased from Non-Renewable and Renewable resources.

Values shown may be affected due to rounding.

Values are based on the economic dispatch of TEC's planned portfolio using the most recent fuel price projections and are subject to change. Dual fuel capabilities will be maintained on applicable units.

Generation quantities do not reflect periodic testing of distillate fuel oil capability

# Chapter V



## FORECAST OF FACILITIES REQUIREMENTS

The proposed generating facility changes and additions shown in Schedule 8.1 integrate energy efficiency and conservation programs and generating resources to provide economical, reliable service to TEC's customers. Various energy resource plan alternatives, comprised of a mixture of generating technologies, purchased power, and cost-effective energy efficiency and conservation programs, are developed to determine this plan. These alternatives are combined with existing resources and analyzed to determine the resource options which best meets TEC's future system demand and energy requirements. A detailed discussion of TEC's integrated resource planning process is included in Chapter III.

The results of the IRP process provide TEC with a cost-effective plan that maintains system reliability and environmental requirements while considering technology, availability, dispatchability, resiliency, and lead times for construction. To cost-effectively meet the expected system demand and energy requirements over the next ten years, solar PV, base load, intermediate, and distributed energy resources are needed. By the end of 2023, TEC will add an incremental 600 MW<sub>AC</sub> of utility-scale solar PV capacity, and is researching the viability of additional renewable technologies. The modernization of the Big Bend Power Station through the repowering of Unit 1 to a 2x1 combined cycle unit, the retirement of Unit 2 and Unit 3, and the advanced hardware upgrades on the CTs at Bayside provide low-cost, reliable, and grid-friendly options for customers. Additionally, distributed energy resources such as batteries and reciprocating engines provide reliability and resiliency to our system. The operating and cost parameters are shown in Schedule 9.

TEC will continue to compare purchased power options as an alternative and/or enhancement to planned unit additions, conservation, and load management. At a minimum, the purchased power must have firm transmission service and firm fuel transportation to support firm reserve margin criteria for reliability. Assumptions and information that impact the plan are discussed in the following sections and in Chapter III.

### **COGENERATION**

In 2022, TEC plans for 263 MW of cogeneration capacity operating in its service area.

<b>Table IV-I 2022 Cogeneration Capacity Forecast</b>	<b>Capacity (MW)</b>
Self-service <sup>1</sup>	187
Firm to Tampa Electric	0
As-available to Tampa Electric	22
Export to other systems	54
Total	263

<sup>1</sup> Capacity and energy that cogenerators produce to serve their own internal load requirements.

## **FIRM INTERCHANGE SALES AND PURCHASES**

Currently, TEC has no long-term firm purchase power agreements. The company does have two (2) short-term agreements that provide firm capacity during the winter of 2022. The purchases are (i) 50 MW from the Florida Municipal Power Agency (FMPA), and (ii) 250 MW from Duke Energy Florida (DEF). Both purchases cover the period January through February 2022.

## **FUEL REQUIREMENTS**

A forecast of fuel requirements and energy sources is shown in Schedule 5, Schedule 6.1 and Schedule 6.2. TEC currently uses a generation portfolio consisting mainly of solid fuels and natural gas for its energy requirements. TEC has firm transportation contracts with the Florida Gas Transmission Company, Gulfstream Natural Gas System LLC, and Sabal Trail for delivery of natural gas to Big Bend, Bayside, and Polk. As shown in Schedule 6.2, in 2022, coal will fuel 6.4 % of the net energy for load, natural gas is expected to fuel 84.0 %, and solar is expected to provide 9.4 %. The remaining net energy for load is served by firm, non-firm, and non-utility generator purchases. Some of the company's generating units have dual-fuel (i.e., natural gas or oil) capability, which enhances system reliability, resiliency, and provides fuel cost reduction opportunities.

## **ENVIRONMENTAL CONSIDERATIONS**

### **Air Quality**

TEC continually strives to reduce emissions from its generating facilities, and since 2000, has reduced sulfur dioxide, nitrogen oxide, particulate matter and mercury emissions by 96 % or more. Carbon emissions have also been reduced by more than 50 %, and TEC has committed to a 60 % reduction of carbon emissions by 2025, 80-% by 2040, and has a vision to achieve net zero carbon emissions by 2050.

The installation of 1,324 megawatts of solar power by 2023 will enable the company to continue to reduce its dependence on carbon-based fuels. Once complete, 13.6 percent of TEC's energy will be fueled by the sun, and TEC will continue to be a leader in solar capacity per customer than any other utility in Florida.

In addition to solar, TEC's emission reduction activities include:

1. Phasing in a modernization of Big Bend through the repowering of Unit 1 by the end of 2022 into a highly efficient combined cycle unit and retiring Unit 2.
2. The retirement of Big Bend Unit 3 in April of 2023.
3. The Polk Power Station combined-cycle project improved system reliability and efficiency, and reduced emissions system-wide.
4. The upgrade of gas path components on Bayside Power Station's Unit 1 and Unit 2 combustion turbines will increase output, efficiency and reliability while reducing fuel consumption.
5. Advanced battery storage that will capture solar energy and discharge when its needed most.

## Water Conservation

TEC's Big Bend and Polk Power Station use reclaimed water from local municipalities to minimize the use of potable water and groundwater for plant processes. Most of the properties purchased by TEC for solar generation are former agricultural lands with existing water use permits. When land is sold to new owners, Southwest Florida Water Management District (SWFWMD) rules require that these water permits are transferred as well. Since solar generation requires no water, TEC conserves this groundwater, which otherwise would have pumped and used for agricultural needs. To date, TEC's acquisition of land for the development of solar power has saved more than 3.7 billion gallons of water, which significantly helps an area of the state that has critical concerns over water use.

## Water Quality

The final 316(b) rule became effective in October 2014 and seeks to reduce impingement and entrainment at cooling water intakes. This rule affects both Big Bend and Bayside Power Stations, since both withdraw cooling water from waters of the U.S. The full impact of the new regulations will be determined by the results of the study elements performed to comply with the rule as well as the actual requirements of the state regulatory agencies.

FDEP's numeric nutrient regulations are effective and may potentially impact the discharge from the Polk Power Station cooling water reservoir in the future. The established nitrogen allocations by Tampa Bay Nitrogen Management Consortium for both Bayside and Big Bend Power Stations are expected to meet the numeric nutrient criteria in Tampa Bay.

The final Effluent Limitations Guidelines (ELG) were published on November 3, 2015. The ELGs establish limits for wastewater discharges from flue gas desulfurization (FGD) processes, fly ash and bottom ash transport water, leachate from ponds and landfills containing coal combustion residuals, gasification processes, and flue gas mercury controls. New limits will require new technology at Big Bend Station.

## Solid Waste

The Coal Combustion Residuals Rule (CCR) became effective on October 19, 2015. The former Big Bend Unit #4 Economizer Ash & Pyrites Pond System (EAPPS), converted Units 1-3 West Slag Disposal Pond (WSDP) and North Gypsum Stackout Area (NGSA) were covered by this rule. Three ECRC projects were proposed and approved by the Commission for these operating units to comply with the CCR Rule requirements, as follows. The WSDP was remediated and lined in 2020 to allow for continued storm water storage and the EAPPS Closure Project was completed in 2021 by removing and disposing of the CCRs offsite and restoring the site. Phase II of the NGSA Drainage Enhancements Project will be initiated in 2022 and completed not later than 2023. The South Gypsum Storage Area Closure Project was completed as a component of the Big Bend Modernization in January 2020. There are no other regulated CCR units at the Big Bend, Polk or Bayside Power Stations.



# Schedule 7.1

## Forecast of Capacity, Demand, and Scheduled Maintenance at Time of Summer Peak

(1) Year	(2) Total Installed Capacity MW	(3) Firm Capacity Import MW	(4) Firm Capacity Export MW	(5) QF MW	(6) Total Capacity Available MW	(7) System Firm Summer Peak Demand MW	(8) Reserve Margin Before Maintenance MW	(9) Reserve Margin After Maintenance % of Peak	(10) Scheduled * Maintenance MW	(11) Reserve Margin After Maintenance MW	(12) Reserve Margin % of Peak
2022	5,566	0	0	0	5,566	4,002	1,563	39%	387	1,177	29%
2023	5,811	0	0	0	5,811	4,043	1,768	44%	474	1,294	32%
2024	6,222	0	0	0	6,222	4,082	2,140	52%	576	1,565	38%
2025	6,255	0	0	0	6,255	4,113	2,141	52%	573	1,568	38%
2026	6,550	0	0	0	6,550	4,139	2,411	58%	704	1,708	41%
2027	6,669	0	0	0	6,669	4,161	2,508	60%	734	1,774	43%
2028	6,776	0	0	0	6,776	4,184	2,592	62%	765	1,827	44%
2029	6,895	0	0	0	6,895	4,207	2,688	64%	795	1,893	45%
2030	6,964	0	0	0	6,964	4,229	2,735	65%	825	1,910	45%
2031	7,083	0	0	0	7,083	4,249	2,833	67%	856	1,978	47%

\* Indicates capacity unavailable at time of peak.  
Values shown may be affected due to rounding.

## Schedule 7.2

### Forecast of Capacity, Demand, and Scheduled Maintenance at Time of Winter Peak

(1) Year	(2) Total Installed Capacity MW	(3) Firm Capacity Import MW	(4) Firm Capacity Export MW	(5) QF MW	(6) Total Capacity Available MW	(7) System Firm Winter Peak Demand MW	(8) Reserve Margin Before Maintenance MW	(9) Reserve Margin % of Peak	(10) Scheduled * Maintenance MW	(11) Reserve Margin After Maintenance MW	(12) Reserve Margin % of Peak
2021-22	5,998	300	0	0	6,298	4,246	2,052	48%	870	1,182	28%
2022-23	6,350	0	0	0	6,350	4,294	2,056	48%	1067	989	23%
2023-24	6,606	0	0	0	6,606	4,342	2,264	52%	1298	966	22%
2024-25	6,702	0	0	0	6,702	4,387	2,315	53%	1293	1,022	23%
2025-26	7,034	0	0	0	7,034	4,423	2,611	59%	1588	1,023	23%
2026-27	7,153	0	0	0	7,153	4,456	2,697	61%	1657	1,040	23%
2027-28	7,260	0	0	0	7,260	4,488	2,772	62%	1726	1,046	23%
2028-29	7,379	0	0	0	7,379	4,519	2,860	63%	1795	1,064	24%
2029-30	7,448	0	0	0	7,448	4,549	2,898	64%	1864	1,034	23%
2030-31	7,566	0	0	0	7,566	4,578	2,988	65%	1933	1,056	23%

\* Indicates capacity unavailable at time of peak.  
Values shown may be affected due to rounding.

## Schedule 8.1 Planned and Prospective Generating Facility Additions and Changes

(1)	(2)	(3)	(4)	(5)	(6)	(7)	(8)	(9)	(10)	(11)	(12)	(13)	(14)	(15)	
Plant Name	Unit No.	Location	Unit Type	Fuel		Fuel Trans.		Const. Start Mo/Yr	Commercial In-Service Mo/Yr	Expected Retirement Mo/Yr	Gen. Max. Nameplate kW	Firm Net Capacity		Status	
				Primary	Alternate	Primary	Alternate					Summer MW	Winter MW		
2022															
Big Bend II Solar <sup>1</sup> Mountain View Solar <sup>1</sup> Jamison Solar <sup>1</sup> Laurel Oaks Solar <sup>1</sup> Riverside Solar <sup>1</sup> Big Bend II Solar <sup>1,5</sup> Juniper Solar <sup>1</sup> Big Bend CT 5 <sup>2</sup> Big Bend CT 6 <sup>2</sup> Big Bend ST1 Modernization Solar Degradation <sup>3</sup>	1	Hillsborough	PV	SOLAR	NA	NA	NA	-	1/22	*	31,500	17.6	-	P	
	1	Pasco	PV	SOLAR	NA	NA	NA	-	3/22	*	54,600	30.5	-	P	
	1	Polk	PV	SOLAR	NA	NA	NA	-	4/22	*	74,500	41.6	-	P	
	1	Hillsborough	PV	SOLAR	NA	NA	NA	-	12/22	*	61,200	34.2	-	P	
	1	Hillsborough	PV	SOLAR	NA	NA	NA	-	12/22	*	55,200	30.9	-	P	
	1	Hillsborough	PV	SOLAR	NA	NA	NA	-	12/22	*	14,300	8.0	-	P	
	1	Pasco	PV	SOLAR	NA	NA	NA	-	12/22	*	70,000	39.1	-	P	
	5M	Big Bend	GT	NG	NA	PL	NA	08/19	12/22	*	397,800	30.0	42.0	P	
	6M	Big Bend	GT	NG	NA	PL	NA	08/19	12/22	*	397,800	30.0	42.0	P	
	1M	Big Bend	ST	NG	NA	PL	NA	04/20	12/22	*	445,500	335.0	335.0	P	
	N/A											(1.0)	-		
	2022 Changes and Additions:												595.9	419.0	
	2023														
	Bayside 1 Enhancement Big Bend 3 Retirement Alafia Solar <sup>1</sup> Lake Mabel Solar <sup>1</sup> Dover Solar + Storage <sup>1</sup> Future Solar 1 <sup>1</sup> Solar Degradation <sup>3</sup>	1	Bayside	CC	NG	NA	PL	NA	-	1/23	*	65,000	48.0	65.0	P
		3	Big Bend	ST	BIT	NG	WA/RR	PL	-	05/76	4/23	445,500	(395.0)	(400.0)	RT
1		Polk	PV	SOLAR	NA	NA	NA	-	12/23	*	60,000	33.5	-	P	
1		Polk	PV	SOLAR	NA	NA	NA	-	12/23	*	74,500	41.6	-	P	
1		Hillsborough	PV	SOLAR	NA	NA	NA	-	12/23	*	25,000	25.0	15.0	P	
1		Unknown	PV	SOLAR	NA	NA	NA	-	12/23	*	74,500	41.6	-	P	
N/A												(1.9)	-		
2023 Changes and Additions:												(207.1)	(320.0)		
2024															
Bayside 2 Enhancement Battery Storage 1 Solar Degradation <sup>3</sup>	2	Bayside	CC	NG	NA	PL	NA	-	1/24	*	80,000	70.0	80.0	P	
	1	Unknown	BA	N/A	N/A	N/A	N/A	-	7/24	*	100,000	100.0	100.0	P	
	N/A											(2.3)	-		
2024 Changes and Additions:												167.7	180.0		

**Notes:**

- \* Undetermined
- \*\* This is the incremental update to the original Big Bend Solar II capacity
- <sup>1</sup> Solar MW values reflect capacity at time of peak.
- <sup>2</sup> This is the incremental update to the original CT 5 and 6 capacity.
- <sup>3</sup> Solar capacity degrades at approximately 0.4% every year.
- Tampa Electric Company continually analyzes renewable energy and distributed generation alternatives with the objective to integrate them into its resource portfolio.
- <sup>4</sup> Multiple Sites, each not to exceed 74.5MW



## Schedule 8.1 Cont'd Planned and Prospective Generating Facility Additions and Changes

(1)	(2)	(3)	(4)	(5)	(6)	(7)	(8)	(9)	(10)	(11)	(12)	(13)	(14)	(15)
Plant Name	Unit No.	Location	Unit Type	Fuel		Fuel Trans.		Const. Start Mo/Yr	Commercial In-Service Mo/Yr	Expected Retirement Mo/Yr	Gen. Max. Nameplate kW	Firm Net Capacity Summer MW	Firm Net Capacity Winter MW	Status
				Primary	Alternate	Primary	Alternate							
<b>2025</b>														
Future Solar 2 <sup>1,4</sup>	1	Unknown	PV	SOLAR	NA	NA	NA	-	12/25	*	300,000	167.7	-	P
Reciprocating Engine 1	1	Unknown	IC	NG	NA	PL	NA	-	4/25	*	37,000	37.0	37.0	P
Solar Degradation <sup>3</sup>	N/A											(2.6)	-	
											2025 Changes and Additions:	202.1	37.0	
<b>2026</b>														
Future Solar 3 <sup>1</sup>	1	Unknown	PV	SOLAR	NA	NA	NA	-	12/26	*	74,500	41.6	-	P
Solar Degradation <sup>3</sup>	N/A											(2.6)	-	
											2026 Changes and Additions:	(2.6)	-	
<b>2027</b>														
Battery Storage 2	1	Unknown	BA	N/A	N/A	N/A	N/A	-	1/27	*	50,000	50.0	50.0	P
Future Solar 4 <sup>1</sup>	1	Unknown	PV	SOLAR	NA	NA	NA	-	12/27	*	74,500	41.6	-	P
Solar Degradation <sup>3</sup>	N/A											(2.9)	-	
											2027 Changes and Additions:	88.7	50.0	
<b>2028</b>														
Reciprocating Engine 2	1	Unknown	IC	NG	NA	PL	NA	-	1/28	*	37,000	37.0	37.0	P
Future Solar 5 <sup>1</sup>	1	Unknown	BA	N/A	N/A	N/A	N/A	-	12/28	*	74,500	41.6	-	P
Solar Degradation <sup>3</sup>	N/A											(3.0)	-	
											2028 Changes and Additions:	75.7	37.0	
<b>2029</b>														
Battery Storage 3	1	Unknown	BA	N/A	N/A	N/A	N/A	-	1/29	*	50,000	50.0	50.0	P
Future Solar 6 <sup>1</sup>	1	Unknown	PV	SOLAR	NA	NA	NA	-	12/29	*	74,500	41.6	-	P
Solar Degradation <sup>3</sup>	N/A											(3.1)	-	
											2029 Changes and Additions:	88.6	50.0	
<b>2030</b>														
Future Solar 7 <sup>1</sup>	4	Unknown	BA	N/A	N/A	N/A	N/A	-	12/30	*	74,500	41.6	-	P
Solar Degradation <sup>3</sup>	N/A											(3.1)	-	
											2030 Changes and Additions:	38.5	-	
<b>2031</b>														
Battery Storage 4	1	Unknown	BA	N/A	N/A	N/A	N/A	-	1/31	*	50,000	50.0	50.0	P
Future Solar 8 <sup>1</sup>	1	Unknown	PV	SOLAR	NA	NA	NA	-	12/31	*	74,500	41.6	-	P
Solar Degradation <sup>3</sup>	N/A											(3.2)	-	
											2031 Changes and Additions:	88.4	50.0	

**Notes:**

- \* Undetermined
- <sup>1</sup> Solar MW values reflect capacity at time of peak.
- <sup>2</sup> This is the incremental update to the original CT 5 and 6 capacity.
- <sup>3</sup> Solar capacity degrades at approximately 0.4% every year.
- <sup>4</sup> Tampa Electric Company continually analyzes renewable energy and distributed generation alternatives with the objective to integrate them into its resource portfolio.
- <sup>5</sup> Multiple Sites, each not to exceed 74.5MW
- This is the incremental update to the original Big Bend Solar II capacity

**Schedule 9**  
**(Page 1 of 27)**  
**Status Report and Specifications of Proposed Generating Facilities**

(1)	Plant Name and Unit Number	Big Bend II Solar (Phase 1)
(2)	Net Capability	
	A. Summer	31.5 MW-ac
	B. Winter	31.5 MW-ac
(3)	Technology Type	Single Axis Tracking PV Solar
(4)	Anticipated Construction Timing	
	A. Field Construction Start Date <sup>4</sup>	April 2021
	B. Commercial In-Service Date	January 2022
(5)	Fuel.	
	A. Primary Fuel	Solar
	B. Alternate Fuel	N/A
(6)	Air Pollution Control Strategy	N/A
(7)	Cooling Method	N/A
(8)	Total Site Area	+191 Acres
(9)	Construction Status	In Service
(10)	Certification Status	N/A
(11)	Status with Federal Agencies	N/A
(12)	Projected Unit Performance Data	
	Planned Outage Factor (POF)	N/A
	Forced Outage Factor (FOF)	N/A
	Equivalent Availability Factor (EAF)	N/A
	Resulting Capacity Factor (2021)	26 %
	Average Net Operating Heat Rate (In-Service Year ANOHR)	N/A
(13)	Projected Unit Financial Data	
	Book Life (Years)	35
	Total Installed Cost <sup>3</sup> (In-Service Year \$/kW)	1,496.76
	Direct Construction Cost (\$/kW)	1,376.00
	AFUDC <sup>2</sup> Amount (\$/kW)	120.76
	Escalation (\$/kW)	-
	Fixed O&M (In-Service Year \$/kW – Yr)	11.15
	Variable O&M (In-Service Year \$/MWh)	-
	K-Factor <sup>1</sup>	1.20

<sup>1</sup> w/o Land

<sup>2</sup> Based on the current AFUDC rate of 6.46 %

<sup>3</sup> Total installed cost includes transmission interconnection

<sup>4</sup> Construction schedule includes engineering design and permitting

**Schedule 9**  
**(Page 2 of 27)**  
**Status Report and Specifications of Proposed Generating Facilities**

(1)	Plant Name and Unit Number	Mountain View Solar
(2)	Net Capability	
	A. Summer	54.6 MW-ac
	B. Winter	54.6 MW-ac
(3)	Technology Type	Single Axis Tracking PV Solar
(4)	Anticipated Construction Timing	
	A. Field Construction Start Date <sup>4</sup>	April 2021
	B. Commercial In-Service Date	March 2022
(5)	Fuel	
	A. Primary Fuel	Solar
	B. Alternate Fuel	N/A
(6)	Air Pollution Control Strategy	N/A
(7)	Cooling Method	N/A
(8)	Total Site Area	+359 Acres
(9)	Construction Status	In Service
(10)	Certification Status	N/A
(11)	Status with Federal Agencies	N/A
(12)	Projected Unit Performance Data	
	Planned Outage Factor (POF)	N/A
	Forced Outage Factor (FOF)	N/A
	Equivalent Availability Factor (EAF)	N/A
	Resulting Capacity Factor (2022)	26 %
	Average Net Operating Heat Rate (In-Service Year ANOHR)	N/A
(13)	Projected Unit Financial Data	
	Book Life (Years)	35
	Total Installed Cost <sup>3</sup> (In-Service Year \$/kW)	1,527.70
	Direct Construction Cost (\$/kW)	1,484.00
	AFUDC <sup>2</sup> Amount (\$/kW)	43.70
	Escalation (\$/kW)	-
	Fixed O&M (In-Service Year \$/kW – Yr)	11.15
	Variable O&M (In-Service Year \$/MWh)	-
	K-Factor <sup>1</sup>	1.17

<sup>1</sup> w/o Land

<sup>2</sup> Based on the current AFUDC rate of 6.46 %

<sup>3</sup> Total installed cost includes transmission interconnection

<sup>4</sup> Construction schedule includes engineering design and permitting

**Schedule 9**  
**(Page 3 of 27)**  
**Status Report and Specifications of Proposed Generating Facilities**

1)	Plant Name and Unit Number	Jamison Solar
2)	Net Capability	
	A. Summer	74.5 MW-ac
	B. Winter	74.5 MW-ac
3)	Technology Type	Single Axis Tracking PV Solar
4)	Anticipated Construction Timing	
	A. Field Construction Start Date <sup>4</sup>	April 2021
	B. Commercial In-Service Date	April 2022
5)	Fuel	
	A. Primary Fuel	Solar
	B. Alternate Fuel	N/A
6)	Air Pollution Control Strategy	N/A
7)	Cooling Method	N/A
8)	Total Site Area	+695 Acres
9)	Construction Status	Under Construction
10)	Certification Status	N/A
11)	Status with Federal Agencies	N/A
12)	Projected Unit Performance Data	
	Planned Outage Factor (POF)	N/A
	Forced Outage Factor (FOF)	N/A
	Equivalent Availability Factor (EAF)	N/A
	Resulting Capacity Factor (2022)	26 %
	Average Net Operating Heat Rate (In-Service Year ANOHR)	N/A
13)	Projected Unit Financial Data	
	Book Life (Years)	35
	Total Installed Cost <sup>3</sup> (In-Service Year \$/kW)	1,576.17
	Direct Construction Cost (\$/kW)	1,449.00
	AFUDC <sup>2</sup> Amount (\$/kW)	127.17
	Escalation (\$/kW)	-
	Fixed O&M (In-Service Year \$/kW – Yr)	11.15
	Variable O&M (In-Service Year \$/MWh)	-
	K-Factor <sup>1</sup>	1.16

<sup>2</sup> Based on the current AFUDC rate of 6.46 %

<sup>3</sup> Total installed cost includes transmission interconnection

<sup>4</sup> Construction schedule includes engineering design and permitting

**Schedule 9**  
**(Page 4 of 27)**  
**Status Report and Specifications of Proposed Generating Facilities**

(1)	Plant Name and Unit Number	Laurel Oaks Solar
(2)	Net Capability	
	A. Summer	61.2 MW-ac
	B. Winter	61.2 MW-ac
(3)	Technology Type	Single Axis Tracking PV Solar
(4)	Anticipated Construction Timing	
	A. Field Construction Start Date <sup>4</sup>	January 2022
	B. Commercial In-Service Date	December 2022
(5)	Fuel	
	A. Primary Fuel	Solar
	B. Alternate Fuel	N/A
(6)	Air Pollution Control Strategy	N/A
(7)	Cooling Method	N/A
(8)	Total Site Area	+515 Acres
(9)	Construction Status	Planned
(10)	Certification Status	N/A
(11)	Status with Federal Agencies	N/A
(12)	Projected Unit Performance Data	
	Planned Outage Factor (POF)	N/A
	Forced Outage Factor (FOF)	N/A
	Equivalent Availability Factor (EAF)	N/A
	Resulting Capacity Factor (2023)	26 %
	Average Net Operating Heat Rate (In-Service Year ANOHR)	N/A
(13)	Projected Unit Financial Data	
	Book Life (Years)	35
	Total Installed Cost <sup>3</sup> (In-Service Year \$/kW)	1,371.03
	Direct Construction Cost (\$/kW)	1,367.09
	AFUDC <sup>2</sup> Amount (\$/kW)	3.95
	Escalation (\$/kW)	-
	Fixed O&M (In-Service Year \$/kW – Yr)	11.15
	Variable O&M (In-Service Year \$/MWh)	-
	K-Factor <sup>1</sup>	1.14

<sup>1</sup> w/o Land

<sup>2</sup> Based on the current AFUDC rate of 6.46 %

<sup>3</sup> Total installed cost includes transmission interconnection

<sup>4</sup> Construction schedule includes engineering design and permitting

**Schedule 9**  
**(Page 5 of 27)**  
**Status Report and Specifications of Proposed Generating Facilities**

(1)	Plant Name and Unit Number	Riverside Solar
(2)	Net Capability	
	A. Summer	55.2 MW-ac
	B. Winter	55.2 MW-ac
(3)	Technology Type	Single Axis Tracking PV Solar
(4)	Anticipated Construction Timing	
	A. Field Construction Start Date <sup>4</sup>	January 2022
	B. Commercial In-Service Date	December 2022
(5)	Fuel	
	A. Primary Fuel	Solar
	B. Alternate Fuel	N/A
(6)	Air Pollution Control Strategy	N/A
(7)	Cooling Method	N/A
(8)	Total Site Area	+546 Acres
(9)	Construction Status	Planned
(10)	Certification Status	N/A
(11)	Status with Federal Agencies	N/A
(12)	Projected Unit Performance Data	
	Planned Outage Factor (POF)	N/A
	Forced Outage Factor (FOF)	N/A
	Equivalent Availability Factor (EAF)	N/A
	Resulting Capacity Factor (2023)	26 %
	Average Net Operating Heat Rate (In-Service Year ANOHR)	N/A
(13)	Projected Unit Financial Data	
	Book Life (Years)	35
	Total Installed Cost <sup>3</sup> (In-Service Year \$/kW)	1,624.70
	Direct Construction Cost (\$/kW)	1,616.06
	AFUDC <sup>2</sup> Amount (\$/kW)	8.64
	Escalation (\$/kW)	-
	Fixed O&M (In-Service Year \$/kW – Yr)	11.15
	Variable O&M (In-Service Year \$/MWh)	-
	K-Factor <sup>1</sup>	1.12

<sup>1</sup> w/o Land

<sup>2</sup> Based on the current AFUDC rate of 6.46 %

<sup>3</sup> Total installed cost includes transmission interconnection

<sup>4</sup> Construction schedule includes engineering design and permitting

**Schedule 9**  
**(Page 6 of 27)**  
**Status Report and Specifications of Proposed Generating Facilities**

(1)	Plant Name and Unit Number	Big Bend II Solar (Phase II)
(2)	Net Capability	
	A. Summer	14.3 MW-ac
	B. Winter	14.3 MW-ac
(3)	Technology Type	Single Axis Tracking PV Solar
(4)	Anticipated Construction Timing	
	A. Field Construction Start Date <sup>4</sup>	January 2022
	B. Commercial In-Service Date	December 2022
(5)	Fuel	
	A. Primary Fuel	Solar
	B. Alternate Fuel	N/A
(6)	Air Pollution Control Strategy	N/A
(7)	Cooling Method	N/A
(8)	Total Site Area	+191 Acres
(9)	Construction Status	Under Construction
(10)	Certification Status	N/A
(11)	Status with Federal Agencies	N/A
(12)	Projected Unit Performance Data	
	Planned Outage Factor (POF)	N/A
	Forced Outage Factor (FOF)	N/A
	Equivalent Availability Factor (EAF)	N/A
	Resulting Capacity Factor (2022)	26 %
	Average Net Operating Heat Rate (In-Service Year ANOHR)	N/A
(13)	Projected Unit Financial Data	
	Book Life (Years)	35
	Total Installed Cost <sup>3</sup> (In-Service Year \$/kW)	1,376.00
	Direct Construction Cost (\$/kW)	1,376.00
	AFUDC2 Amount (\$/kW)	-
	Escalation (\$/kW)	-
	Fixed O&M (In-Service Year \$/kW – Yr)	11.15
	Variable O&M (In-Service Year \$/MWh)	-
	K-Factor <sup>1</sup>	1.13

<sup>1</sup> w/o Land

<sup>2</sup> Based on the current AFUDC rate of 6.46 %; the rate changes to 5.89 % in April 2022.

<sup>3</sup> Total installed cost includes transmission interconnection

<sup>4</sup> Construction schedule includes engineering design and permitting

**Schedule 9**  
**(Page 7 of 27)**  
**Status Report and Specifications of Proposed Generating Facilities**

(1)	Plant Name and Unit Number	Juniper Solar
(2)	Net Capability	
	A. Summer	70.0 MW-ac
	B. Winter	70.0 MW-ac
(3)	Technology Type	Single Axis Tracking PV Solar
(4)	Anticipated Construction Timing	
	A. Field Construction Start Date <sup>4</sup>	January 2022
	B. Commercial In-Service Date	December 2022
(5)	Fuel	
	A. Primary Fuel	Solar
	B. Alternate Fuel	N/A
(6)	Air Pollution Control Strategy	N/A
(7)	Cooling Method	N/A
(8)	Total Site Area	+695 Acres
(9)	Construction Status	Planned
(10)	Certification Status	N/A
(11)	Status with Federal Agencies	N/A
(12)	Projected Unit Performance Data	
	Planned Outage Factor (POF)	N/A
	Forced Outage Factor (FOF)	N/A
	Equivalent Availability Factor (EAF)	N/A
	Resulting Capacity Factor (2022)	26%
	Average Net Operating Heat Rate (In-Service Year ANOHR)	N/A
(13)	Projected Unit Financial Data	
	Book Life (Years)	35
	Total Installed Cost <sup>3</sup> (In-Service Year \$/kW)	1,426.23
	Direct Construction Cost (\$/kW)	1,419.00
	AFUDC <sup>2</sup> Amount (\$/kW)	7.23
	Escalation (\$/kW)	-
	Fixed O&M (In-Service Year \$/kW – Yr)	11.15
	Variable O&M (In-Service Year \$/MWh)	-
	K-Factor <sup>1</sup>	1.14

<sup>1</sup> w/o Land

<sup>2</sup> Based on the current AFUDC rate of 6.46 %; the rate changes to 5.89 % in April 2022.

<sup>3</sup> Total installed cost includes transmission interconnection

<sup>4</sup> Construction schedule includes engineering design and permitting



**Schedule 9**  
**(Page 8 of 27)**  
**Status Report and Specifications of Proposed Generating Facilities**

(1)	Plant Name and Unit Number	Big Bend ST 1
(2)	Net Capability	
	A. Summer	335 MW
	B. Winter	335 MW
(3)	Technology Type	Combined Cycle <sup>3</sup>
(4)	Anticipated Construction Timing	
	A. Field Construction Start Date	June 2020
	B. Commercial In-Service Date	December 2022
(5)	Fuel	
	A. Primary Fuel	Waste Heat Recovery
	B. Alternate Fuel	N/A
(6)	Air Pollution Control Strategy	SCR, DLN Burners
(7)	Cooling Method	Once Through Cooling
(8)	Total Site Area	Undetermined?
(9)	Construction Status	Planned
(10)	Certification Status	In Progress
(11)	Status with Federal Agencies	N/A
(12)	Projected Unit Performance Data	
	Planned Outage Factor (POF)	5%
	Forced Outage Factor (FOF)	2%
	Equivalent Availability Factor (EAF)	93%
	Resulting Capacity Factor (2023)	89%
	Average Net Operating Heat Rate (In-Service Year ANOHR)	6,263 Btu/kWh
(13)	Projected Unit Financial Data	
	Book Life (Years)	30
	Total Installed Cost <sup>2</sup> (In-Service Year \$/kW)	1,266.28
	Direct Construction Cost (\$/kW)	1,037.75
	AFUDC <sup>1</sup> Amount (\$/kW)	143.43
	Escalation (\$/kW)	85.11
	Fixed O&M (In-Service Year \$/kW – Yr)	6.44
	Variable O&M (In-Service Year \$/MWh)	2.81
	K-Factor	1.46

<sup>1</sup> Based on the current AFUDC rate of 6.46%; the rate changes to 5.89% in April 2022.

<sup>2</sup> Total installed cost includes transmission interconnection

<sup>3</sup> Converts Big Bend CT 5 & 6 and HRSG's to 2x1 Combined Cycle

**Schedule 9**  
**(Page 9 of 27)**  
**Status Report and Specifications of Proposed Generating Facilities**

(1)	Plant Name and Unit Number	Bayside 1 Enhancement
(2)	Net Capability	
	A. Summer	48 MW
	B. Winter	65 MW
(3)	Technology Type	Combustion Turbine
(4)	Anticipated Construction Timing	
	A. Field Construction Start Date	2022
	B. Commercial In-Service Date	November 2022
(5)	Fuel	
	A. Primary Fuel	Natural Gas
	B. Alternate Fuel	N/A
(6)	Air Pollution Control Strategy	Dry-Low NO <sub>x</sub>
(7)	Cooling Method	N/A
(8)	Total Site Area	Undetermined
(9)	Construction Status	Planned
(10)	Certification Status	Undetermined
(11)	Status with Federal Agencies	N/A
(12)	Projected Unit Performance Data	
	Planned Outage Factor (POF)	N/A
	Forced Outage Factor (FOF)	N/A
	Equivalent Availability Factor (EAF)	N/A
	Resulting Capacity Factor (2023)	N/A
	Average Net Operating Heat Rate (In-Service Year ANOHR)	N/A
(13)	Projected Unit Financial Data	
	Book Life (Years)	15
	Total Installed Cost <sup>2</sup> (In-Service Year \$/kW)	375.46
	Direct Construction Cost (\$/kW)	367.37
	AFUDC <sup>1</sup> Amount (\$/kW)	-
	Escalation (\$/kW)	8.10
	Fixed O&M (In-Service Year \$/kW – Yr)	-
	Variable O&M (In-Service Year \$/MWh)	-
	K-Factor	1.43

<sup>1</sup> Based on the current AFUDC rate of 6.46%; the rate changes to 5.89% in April 2022.

<sup>2</sup> Total installed cost includes transmission interconnection

**Schedule 9**  
**(Page 10 of 27)**  
**Status Report and Specifications of Proposed Generating Facilities**

(1)	Plant Name and Unit Number	Alafia Solar
(2)	Net Capability	
	A. Summer	60 MW-ac
	B. Winter	60 MW-ac
(3)	Technology Type	Single Axis Tracking PV Solar
(4)	Anticipated Construction Timing	
	A. Field Construction Start Date <sup>4</sup>	January 2023
	B. Commercial In-Service Date	December 2023
(5)	Fuel	
	A. Primary Fuel	Solar
	B. Alternate Fuel	N/A
(6)	Air Pollution Control Strategy	N/A
(7)	Cooling Method	N/A
(8)	Total Site Area	+408 Acres
(9)	Construction Status	Planned
(10)	Certification Status	N/A
(11)	Status with Federal Agencies	N/A
(12)	Projected Unit Performance Data	
	Planned Outage Factor (POF)	N/A
	Forced Outage Factor (FOF)	N/A
	Equivalent Availability Factor (EAF)	N/A
	Resulting Capacity Factor (2023)	26%
	Average Net Operating Heat Rate (In-Service Year ANOHR)	N/A
(13)	Projected Unit Financial Data	
	Book Life (Years)	35
	Total Installed Cost <sup>3</sup> (In-Service Year \$/kW)	1,537.76
	Direct Construction Cost (\$/kW)	1,458.28
	AFUDC <sup>2</sup> Amount (\$/kW)	79.48
	Escalation (\$/kW)	-
	Fixed O&M (In-Service Year \$/kW – Yr)	11.39
	Variable O&M (In-Service Year \$/MWh)	-
	K-Factor <sup>1</sup>	1.14

<sup>1</sup> w/o Land

<sup>2</sup> Based on the current AFUDC rate of 6.46 %; the rate changes to 5.89 % in April 2022.

<sup>3</sup> Total installed cost includes transmission interconnection

<sup>4</sup> Construction schedule includes engineering design and permitting

**Schedule 9**  
**(Page 11 of 27)**  
**Status Report and Specifications of Proposed Generating Facilities**

(1)	Plant Name and Unit Number	Lake Mabel Solar
(2)	Net Capability	
	A. Summer	74.5 MW-ac
	B. Winter	74.5 MW-ac
(3)	Technology Type	Single Axis Tracking PV Solar
(4)	Anticipated Construction Timing	
	A. Field Construction Start Date <sup>4</sup>	January 2022
	B. Commercial In-Service Date	December 2023
(5)	Fuel	
	A. Primary Fuel	Solar
	B. Alternate Fuel	N/A
(6)	Air Pollution Control Strategy	N/A
(7)	Cooling Method	N/A
(8)	Total Site Area	+575 Acres
(9)	Construction Status	Planned
(10)	Certification Status	N/A
(11)	Status with Federal Agencies	N/A
(12)	Projected Unit Performance Data	
	Planned Outage Factor (POF)	N/A
	Forced Outage Factor (FOF)	N/A
	Equivalent Availability Factor (EAF)	N/A
	Resulting Capacity Factor (2022)	26 %
	Average Net Operating Heat Rate (In-Service Year ANOHR)	N/A
(13)	Projected Unit Financial Data	
	Book Life (Years)	35
	Total Installed Cost <sup>3</sup> (In-Service Year \$/kW)	1,396.76
	Direct Construction Cost (\$/kW)	1,332.19
	AFUDC <sup>2</sup> Amount (\$/kW)	64.57
	Escalation (\$/kW)	-
	Fixed O&M (In-Service Year \$/kW – Yr)	11.39
	Variable O&M (In-Service Year \$/MWh)	-
	K-Factor <sup>1</sup>	1.16

<sup>1</sup> w/o Land

<sup>2</sup> Based on the current AFUDC rate of 6.46 %; the rate changes to 5.89 % in April 2022.

<sup>4</sup> Construction schedule includes engineering design and permitting

**Schedule 9**  
**(Page 12 of 27)**  
**Status Report and Specifications of Proposed Generating Facilities**

(1)	Plant Name and Unit Number	Dover Solar + Storage
(2)	Net Capability	
	A. Summer	25 MW-ac
	B. Winter	25 MW-ac
(3)	Technology Type	Single Axis Tracking PV Solar
(4)	Anticipated Construction Timing	
	A. Field Construction Start Date <sup>4</sup>	January 2023
	B. Commercial In-Service Date	December 2023
(5)	Fuel	
	A. Primary Fuel	Solar
	B. Alternate Fuel	N/A
(6)	Air Pollution Control Strategy	N/A
(7)	Cooling Method	N/A
(8)	Total Site Area	Undetermined
(9)	Construction Status	Planned
(10)	Certification Status	N/A
(11)	Status with Federal Agencies	N/A
(12)	Projected Unit Performance Data	
	Planned Outage Factor (POF)	N/A
	Forced Outage Factor (FOF)	N/A
	Equivalent Availability Factor (EAF)	N/A
	Resulting Capacity Factor (2023)	26 %
	Average Net Operating Heat Rate (In-Service Year ANOHR)	N/A
(13)	Projected Unit Financial Data	
	Book Life (Years)	35
	Total Installed Cost <sup>3</sup> (In-Service Year \$/kW)	2,442.54
	Direct Construction Cost (\$/kW)	2,322.62
	AFUDC <sup>2</sup> Amount (\$/kW)	119.92
	Escalation (\$/kW)	-
	Fixed O&M (In-Service Year \$/kW – Yr)	22.40
	Variable O&M (In-Service Year \$/MWh)	-
	K-Factor <sup>1</sup>	1.22

<sup>1</sup> w/o Land

<sup>2</sup> Based on the current AFUDC rate of 6.46%; the rate changes to 5.89% in April 2022.

<sup>3</sup> Total installed cost includes transmission interconnection

<sup>4</sup> Construction schedule includes engineering design and permitting

**Schedule 9**  
**(Page 13 of 27)**  
**Status Report and Specifications of Proposed Generating Facilities**

(1)	Plant Name and Unit Number	Future Solar 1
(2)	Net Capability	
	A. Summer	74.5 MW-ac
	B. Winter	74.5 MW-ac
(3)	Technology Type	Single Axis Tracking PV Solar
(4)	Anticipated Construction Timing	
	A. Field Construction Start Date <sup>4</sup>	2023
	B. Commercial In-Service Date	December 2023
(5)	Fuel	
	A. Primary Fuel	Solar
	B. Alternate Fuel	N/A
(6)	Air Pollution Control Strategy	N/A
(7)	Cooling Method	N/A
(8)	Total Site Area	Undetermined
(9)	Construction Status	Proposed
(10)	Certification Status	N/A
(11)	Status with Federal Agencies	N/A
(12)	Projected Unit Performance Data	
	Planned Outage Factor (POF)	N/A
	Forced Outage Factor (FOF)	N/A
	Equivalent Availability Factor (EAF)	N/A
	Resulting Capacity Factor (2024)	26 %
	Average Net Operating Heat Rate (In-Service Year ANOHR)	N/A
(13)	Projected Unit Financial Data	
	Book Life (Years)	35
	Total Installed Cost <sup>3</sup> (In-Service Year \$/kW)	1,332.84
	Direct Construction Cost (\$/kW)	1,277.37
	AFUDC <sup>2</sup> Amount (\$/kW)	55.48
	Escalation (\$/kW)	-
	Fixed O&M (In-Service Year \$/kW – Yr)	11.39
	Variable O&M (In-Service Year \$/MWh)	-
	K-Factor <sup>1</sup>	1.17

<sup>1</sup> w/o Land

<sup>2</sup> Based on the current AFUDC rate of 6.46 %; the rate changes to 5.89 % in April 2022.

<sup>3</sup> Total installed cost includes transmission interconnection

<sup>4</sup> Construction schedule includes engineering design and permitting

**Schedule 9**  
**(Page 14 of 27)**  
**Status Report and Specifications of Proposed Generating Facilities**

(1)	Plant Name and Unit Number	Bayside 2 Enhancement
(2)	Net Capability	
	A. Summer	70 MW
	B. Winter	80 MW
(3)	Technology Type	Combustion Turbine
(4)	Anticipated Construction Timing	
	A. Field Construction Start Date	2023
	B. Commercial In-Service Date	November 2023
(5)	Fuel	
	A. Primary Fuel	Natural Gas
	B. Alternate Fuel	N/A
(6)	Air Pollution Control Strategy	Dry-Low NO <sub>x</sub>
(7)	Cooling Method	N/A
(8)	Total Site Area	Undetermined
(9)	Construction Status	Planned
(10)	Certification Status	Undetermined
(11)	Status with Federal Agencies	N/A
(12)	Projected Unit Performance Data	
	Planned Outage Factor (POF)	N/A
	Forced Outage Factor (FOF)	N/A
	Equivalent Availability Factor (EAF)	N/A
	Resulting Capacity Factor (2024)	N/A
	Average Net Operating Heat Rate (In-Service Year ANOHR)	N/A
(13)	Projected Unit Financial Data	
	Book Life (Years)	15
	Total Installed Cost <sup>2</sup> (In-Service Year \$/kW)	406.75
	Direct Construction Cost (\$/kW)	397.98
	AFUDC <sup>1</sup> Amount (\$/kW)	-
	Escalation (\$/kW)	8.77
	Fixed O&M (In-Service Year \$/kW – Yr)	-
	Variable O&M (In-Service Year \$/MWh)	-
	K-Factor	1.46

<sup>1</sup> Based on the current AFUDC rate of 6.46 %; the rate changes to 5.89 % in April 2022.

<sup>2</sup> Total installed cost includes transmission interconnection

**Schedule 9**  
**(Page 15 of 27)**  
**Status Report and Specifications of Proposed Generating Facilities**

(1)	Plant Name and Unit Number	Battery Storage 1
(2)	Net Capability	
	A. Summer	100 MW
	B. Winter	100 MW
(3)	Technology Type	Battery
(4)	Anticipated Construction Timing	
	A. Field Construction Start Date <sup>3</sup>	2024
	B. Commercial In-Service Date	July 2024
(5)	Fuel	
	A. Primary Fuel	N/A
	B. Alternate Fuel	N/A
(6)	Air Pollution Control Strategy	N/A
(7)	Cooling Method	N/A
(8)	Total Site Area	Undetermined
(9)	Construction Status	Proposed
(10)	Certification Status	Undetermined
(11)	Status with Federal Agencies	N/A
(12)	Projected Unit Performance Data	
	Planned Outage Factor (POF)	N/A
	Forced Outage Factor (FOF)	N/A
	Equivalent Availability Factor (EAF)	N/A
	Resulting Capacity Factor (2024)	N/A
	Average Net Operating Heat Rate (In-Service Year ANOHR)	N/A
(13)	Projected Unit Financial Data	
	Book Life (Years)	10
	Total Installed Cost <sup>2</sup> (In-Service Year \$/kW)	1075.12
	Direct Construction Cost (\$/kW)	1075.12
	AFUDC <sup>1</sup> Amount (\$/kW)	-
	Escalation (\$/kW)	-
	Fixed O&M (In-Service Year \$/kW – Yr)	19.08
	Variable O&M (In-Service Year \$/MWh)	-
	K-Factor	1.35

<sup>1</sup> Based on the AFUDC rate of 5.89 % as of April 2022.

<sup>2</sup> Total installed cost includes transmission interconnection

<sup>3</sup> Construction schedule includes engineering design and permitting



**Schedule 9**  
**(Page 16 of 27)**  
**Status Report and Specifications of Proposed Generating Facilities**

(1)	Plant Name and Unit Number	Future Solar 2 (Multiple Sites, each not to exceed 74.5MW)
(2)	Net Capability	
	A. Summer	300 MW-ac
	B. Winter	300 MW-ac
(3)	Technology Type	Single Axis Tracking PV Solar
(4)	Anticipated Construction Timing	
	A. Field Construction Start Date <sup>4</sup>	2024
	B. Commercial In-Service Date	December 2025
(5)	Fuel	
	A. Primary Fuel	Solar
	B. Alternate Fuel	N/A
(6)	Air Pollution Control Strategy	N/A
(7)	Cooling Method	N/A
(8)	Total Site Area	Undetermined
(9)	Construction Status	Proposed
(10)	Certification Status	N/A
(11)	Status with Federal Agencies	N/A
(12)	Projected Unit Performance Data	
	Planned Outage Factor (POF)	N/A
	Forced Outage Factor (FOF)	N/A
	Equivalent Availability Factor (EAF)	N/A
	Resulting Capacity Factor (2025)	26 %
	Average Net Operating Heat Rate (In-Service Year ANOHR)	N/A
(13)	Projected Unit Financial Data	
	Book Life (Years)	35
	Total Installed Cost <sup>3</sup> (In-Service Year \$/kW)	1,362.80
	Direct Construction Cost (\$/kW)	1,305.52
	AFUDC <sup>2</sup> Amount (\$/kW)	57.27
	Escalation (\$/kW)	-
	Fixed O&M (In-Service Year \$/kW – Yr)	11.90
	Variable O&M (In-Service Year \$/MWh)	-
	K-Factor <sup>1</sup>	1.19

<sup>1</sup> w/o Land

<sup>2</sup> Based on the AFUDC rate of 5.89 % as of April 2022.

<sup>3</sup> Total installed cost includes transmission interconnection

<sup>4</sup> Construction schedule includes engineering design and permitting

**Schedule 9**  
**(Page 17 of 27)**  
**Status Report and Specifications of Proposed Generating Facilities**

(1)	Plant Name and Unit Number	Reciprocating Engine 1
(2)	Net Capability	
	A. Summer	37 MW (Consisting of 2 Units)
	B. Winter	37 MW (Consisting of 2 Units)
(3)	Technology Type	Combustion Turbine
(4)	Anticipated Construction Timing	
	A. Field Construction Start Date <sup>3</sup>	December 2022
	B. Commercial In-Service Date	April 2025
(5)	Fuel	
	A. Primary Fuel	Natural Gas
	B. Alternate Fuel	N/A
(6)	Air Pollution Control Strategy	Dry-Low NO <sub>x</sub>
(7)	Cooling Method	N/A
(8)	Total Site Area	Undetermined
(9)	Construction Status	Proposed
(10)	Certification Status	Undetermined
(11)	Status with Federal Agencies	N/A
(12)	Projected Unit Performance Data	
	Planned Outage Factor (POF)	2%
	Forced Outage Factor (FOF)	2%
	Equivalent Availability Factor (EAF)	98%
	Resulting Capacity Factor (2026)	0.64%
	Average Net Operating Heat Rate (In-Service Year ANOHR)	8,117 Btu/kWh
(13)	Projected Unit Financial Data	
	Book Life (Years)	30
	Total Installed Cost <sup>2</sup> (In-Service Year \$/kW)	1,304.42
	Direct Construction Cost (\$/kW)	1,176.00
	AFUDC <sup>1</sup> Amount (\$/kW)	66.72
	Escalation (\$/kW)	61.70
	Fixed O&M (In-Service Year \$/kW – Yr)	23.28
	Variable O&M (In-Service Year \$/MWh)	2.52
	K-Factor	1.62

<sup>1</sup> Based on the AFUDC rate of 5.89% as of April 2022.

<sup>2</sup> Total installed cost includes transmission interconnection

<sup>3</sup> Construction schedule includes engineering design and permitting

**Schedule 9**  
**(Page 18 of 27)**  
**Status Report and Specifications of Proposed Generating Facilities**

(1)	Plant Name and Unit Number	Future Solar 3
(2)	Net Capability	
	A. Summer	74.5 MW-ac
	B. Winter	74.5 MW-ac
(3)	Technology Type	Single Axis Tracking PV Solar
(4)	Anticipated Construction Timing	
	A. Field Construction Start Date <sup>4</sup>	2025
	B. Commercial In-Service Date	December 2026
(5)	Fuel	
	A. Primary Fuel	Solar
	B. Alternate Fuel	N/A
(6)	Air Pollution Control Strategy	N/A
(7)	Cooling Method	N/A
(8)	Total Site Area	Undetermined
(9)	Construction Status	Proposed
(10)	Certification Status	Undetermined
(11)	Status with Federal Agencies	N/A
(12)	Projected Unit Performance Data	
	Planned Outage Factor (POF)	N/A
	Forced Outage Factor (FOF)	N/A
	Equivalent Availability Factor (EAF)	N/A
	Resulting Capacity Factor (2026)	26%
	Average Net Operating Heat Rate (In-Service Year ANOHR)	N/A
(13)	Projected Unit Financial Data	
	Book Life (Years)	35
	Total Installed Cost <sup>3</sup> (In-Service Year \$/kW)	1,379.80
	Direct Construction Cost (\$/kW)	1,321.97
	AFUDC <sup>2</sup> Amount (\$/kW)	57.82
	Escalation (\$/kW)	-
	Fixed O&M (In-Service Year \$/kW – Yr)	12.16
	Variable O&M (In-Service Year \$/MWh)	-
	K-Factor <sup>1</sup>	1.24

<sup>1</sup> w/o Land

<sup>1</sup> Based on the AFUDC rate of 5.89 % as of April 2022.

<sup>3</sup> Total installed cost includes transmission interconnection

<sup>4</sup> Construction schedule includes engineering design and permitting

**Schedule 9**  
**(Page 19 of 27)**  
**Status Report and Specifications of Proposed Generating Facilities**

(1)	Plant Name and Unit Number	Battery Storage 2
(2)	Net Capability	
	A. Summer	50 MW
	B. Winter	50 MW
(3)	Technology Type	Battery
(4)	Anticipated Construction Timing	
	A. Field Construction Start Date <sup>3</sup>	2026
	B. Commercial In-Service Date	January 2027
(5)	Fuel	
	A. Primary Fuel	N/A
	B. Alternate Fuel	N/A
(6)	Air Pollution Control Strategy	N/A
(7)	Cooling Method	N/A
(8)	Total Site Area	Undetermined
(9)	Construction Status	Proposed
(10)	Certification Status	Undetermined
(11)	Status with Federal Agencies	N/A
(12)	Projected Unit Performance Data	
	Planned Outage Factor (POF)	N/A
	Forced Outage Factor (FOF)	N/A
	Equivalent Availability Factor (EAF)	N/A
	Resulting Capacity Factor (2027)	N/A
	Average Net Operating Heat Rate (In-Service Year ANOHR)	N/A
(13)	Projected Unit Financial Data	
	Book Life (Years)	10
	Total Installed Cost <sup>2</sup> (In-Service Year \$/kW)	1,190.35
	Direct Construction Cost (\$/kW)	1,190.35
	AFUDC <sup>1</sup> Amount (\$/kW)	-
	Escalation (\$/kW)	-
	Fixed O&M (In-Service Year \$/kW – Yr)	23.89
	Variable O&M (In-Service Year \$/MWh)	-
	K-Factor	1.25

<sup>1</sup> Based on the AFUDC rate of 5.89 % as of April 2022.

<sup>2</sup> Total installed cost includes transmission interconnection

<sup>3</sup> Construction schedule includes engineering design and permitting

**Schedule 9**  
**(Page 20 of 27)**  
**Status Report and Specifications of Proposed Generating Facilities**

(1)	Plant Name and Unit Number	Future Solar 4
(2)	Net Capability	
	A. Summer	74.5 MW-ac
	B. Winter	74.5 MW-ac
(3)	Technology Type	Single Axis Tracking PV Solar
(4)	Anticipated Construction Timing	
	A. Field Construction Start Date <sup>4</sup>	2026
	B. Commercial In-Service Date	December 2027
(5)	Fuel	
	A. Primary Fuel	Solar
	B. Alternate Fuel	N/A
(6)	Air Pollution Control Strategy	N/A
(7)	Cooling Method	N/A
(8)	Total Site Area	Undetermined
(9)	Construction Status	Proposed
(10)	Certification Status	Undetermined
(11)	Status with Federal Agencies	N/A
(12)	Projected Unit Performance Data	
	Planned Outage Factor (POF)	N/A
	Forced Outage Factor (FOF)	N/A
	Equivalent Availability Factor (EAF)	N/A
	Resulting Capacity Factor (2028)	26% (1st Full Yr Operation)
	Average Net Operating Heat Rate (In-Service Year ANOHR)	N/A
(13)	Projected Unit Financial Data	
	Book Life (Years)	35
	Total Installed Cost <sup>3</sup> (In-Service Year \$/kW)	1,362.35
	Direct Construction Cost (\$/kW)	1,305.18
	AFUDC <sup>2</sup> Amount (\$/kW)	57.17
	Escalation (\$/kW)	-
	Fixed O&M (In-Service Year \$/kW – Yr)	12.43
	Variable O&M (In-Service Year \$/MWh)	-
	K-Factor <sup>1</sup>	1.25

<sup>1</sup> w/o Land

<sup>2</sup> Based on the AFUDC rate of 5.89 % as of April 2022.

<sup>3</sup> Total installed cost includes transmission interconnection

<sup>4</sup> Construction schedule includes engineering design and permitting

**Schedule 9**  
**(Page 21 of 27)**  
**Status Report and Specifications of Proposed Generating Facilities**

(1)	Plant Name and Unit Number	Reciprocating Engine 2
(2)	Net Capability	
	A. Summer	37 MW (Consisting of 2 Units)
	B. Winter	37 MW (Consisting of 2 Units)
(3)	Technology Type	Combustion Turbine
(4)	Anticipated Construction Timing	
	A. Field Construction Start Date <sup>3</sup>	January 2025
	B. Commercial In-Service Date	January 2028
(5)	Fuel	
	A. Primary Fuel	Natural Gas
	B. Alternate Fuel	N/A
(6)	Air Pollution Control Strategy	Dry-Low NO <sub>x</sub>
(7)	Cooling Method	N/A
(8)	Total Site Area	Undetermined
(9)	Construction Status	Proposed
(10)	Certification Status	Undetermined
(11)	Status with Federal Agencies	N/A
(12)	Projected Unit Performance Data	
	Planned Outage Factor (POF)	2%
	Forced Outage Factor (FOF)	2%
	Equivalent Availability Factor (EAF)	98%
	Resulting Capacity Factor (2028)	0.64%
	Average Net Operating Heat Rate (In-Service Year ANOHR)	8,117 Btu/kWh
(13)	Projected Unit Financial Data	
	Book Life (Years)	30
	Total Installed Cost <sup>2</sup> (In-Service Year \$/kW)	1,411.95
	Direct Construction Cost (\$/kW)	1,151.29
	AFUDC <sup>1</sup> Amount (\$/kW)	72.22
	Escalation (\$/kW)	188.44
	Fixed O&M (In-Service Year \$/kW – Yr)	24.85
	Variable O&M (In-Service Year \$/MWh)	2.69
	K-Factor	1.62

<sup>1</sup> Based on the AFUDC rate of 5.89 % as of April 2022.

<sup>2</sup> Total installed cost includes transmission interconnection

<sup>3</sup> Construction schedule includes engineering design and permitting

**Schedule 9**  
**(Page 22 of 27)**  
**Status Report and Specifications of Proposed Generating Facilities**

(1)	Plant Name and Unit Number	Future Solar 5
(2)	Net Capability	
	A. Summer	74.5 MW-ac
	B. Winter	74.5 MW-ac
(3)	Technology Type	Single Axis Tracking PV Solar
(4)	Anticipated Construction Timing	
	A. Field Construction Start Date <sup>4</sup>	2027
	B. Commercial In-Service Date	December 2028
(5)	Fuel	
	A. Primary Fuel	Solar
	B. Alternate Fuel	N/A
(6)	Air Pollution Control Strategy	N/A
(7)	Cooling Method	N/A
(8)	Total Site Area	Undetermined
(9)	Construction Status	Proposed
(10)	Certification Status	Undetermined
(11)	Status with Federal Agencies	N/A
(12)	Projected Unit Performance Data	
	Planned Outage Factor (POF)	N/A
	Forced Outage Factor (FOF)	N/A
	Equivalent Availability Factor (EAF)	N/A
	Resulting Capacity Factor (2029)	26%
	Average Net Operating Heat Rate (In-Service Year ANOHR)	N/A
(13)	Projected Unit Financial Data	
	Book Life (Years)	35
	Total Installed Cost <sup>3</sup> (In-Service Year \$/kW)	1,374.6
	Direct Construction Cost (\$/kW)	1,317.11
	AFUDC <sup>2</sup> Amount (\$/kW)	57.50
	Escalation (\$/kW)	-
	Fixed O&M (In-Service Year \$/kW – Yr)	12.70
	Variable O&M (In-Service Year \$/MWh)	-
	K-Factor <sup>1</sup>	1.26

<sup>1</sup> w/o Land

<sup>2</sup> Based on the AFUDC rate of 5.89 % as of April 2022.

<sup>3</sup> Total installed cost includes transmission interconnection

<sup>4</sup> Construction schedule includes engineering design and permitting

**Schedule 9**  
**(Page 23 of 27)**  
**Status Report and Specifications of Proposed Generating Facilities**

(1)	Plant Name and Unit Number	Battery Storage 3
(2)	Net Capability	
	A. Summer	50 MW
	B. Winter	50 MW
(3)	Technology Type	Battery
(4)	Anticipated Construction Timing	
	A. Field Construction Start Date <sup>3</sup>	2028
	B. Commercial In-Service Date	January 2029
(5)	Fuel	
	A. Primary Fuel	N/A
	B. Alternate Fuel	N/A
(6)	Air Pollution Control Strategy	N/A
(7)	Cooling Method	N/A
(8)	Total Site Area	Undetermined
(9)	Construction Status	Proposed
(10)	Certification Status	Undetermined
(11)	Status with Federal Agencies	N/A
(12)	Projected Unit Performance Data	
	Planned Outage Factor (POF)	N/A
	Forced Outage Factor (FOF)	N/A
	Equivalent Availability Factor (EAF)	N/A
	Resulting Capacity Factor (2029)	N/A
	Average Net Operating Heat Rate (In-Service Year ANOHR)	N/A
(13)	Projected Unit Financial Data	
	Book Life (Years)	10
	Total Installed Cost <sup>2</sup> (In-Service Year \$/kW)	1,163.46
	Direct Construction Cost (\$/kW)	1,163.46
	AFUDC <sup>1</sup> Amount (\$/kW)	-
	Escalation (\$/kW)	-
	Fixed O&M (In-Service Year \$/kW – Yr)	24.04
	Variable O&M (In-Service Year \$/MWh)	-
	K-Factor	1.47

<sup>1</sup> Based on the AFUDC rate of 5.89 % as of April 2022.

<sup>2</sup> Total installed cost includes transmission interconnection

<sup>3</sup> Construction schedule includes engineering design and permitting



**Schedule 9**  
**(Page 24 of 27)**  
**Status Report and Specifications of Proposed Generating Facilities**

(1)	Plant Name and Unit Number	Future Solar 6
(2)	Net Capability	
	A. Summer	74.5 MW-ac
	B. Winter	74.5 MW-ac
(3)	Technology Type	Single Axis Tracking PV Solar
(4)	Anticipated Construction Timing	
	A. Field Construction Start Date <sup>4</sup>	2028
	B. Commercial In-Service Date	December 2029
(5)	Fuel	
	A. Primary Fuel	Solar
	B. Alternate Fuel	N/A
(6)	Air Pollution Control Strategy	N/A
(7)	Cooling Method	N/A
(8)	Total Site Area	Undetermined
(9)	Construction Status	Proposed
(10)	Certification Status	Undetermined
(11)	Status with Federal Agencies	N/A
(12)	Projected Unit Performance Data	
	Planned Outage Factor (POF)	N/A
	Forced Outage Factor (FOF)	N/A
	Equivalent Availability Factor (EAF)	N/A
	Resulting Capacity Factor (2030)	26% (1st Full Yr Operation)
	Average Net Operating Heat Rate (In-Service Year ANOHR)	N/A
(13)	Projected Unit Financial Data	
	Book Life (Years)	35
	Total Installed Cost <sup>3</sup> (In-Service Year \$/kW)	1,357.16
	Direct Construction Cost (\$/kW)	1,300.31
	AFUDC <sup>2</sup> Amount (\$/kW)	56.85
	Escalation (\$/kW)	-
	Fixed O&M (In-Service Year \$/kW – Yr)	12.98
	Variable O&M (In-Service Year \$/MWh)	-
	K-Factor <sup>1</sup>	1.27

<sup>1</sup> w/o Land

<sup>2</sup> Based on the AFUDC rate of 5.89 % as of April 2022.

<sup>3</sup> Total installed cost includes transmission interconnection

<sup>4</sup> Construction schedule includes engineering design and permitting

**Schedule 9**  
**(Page 25 of 27)**  
**Status Report and Specifications of Proposed Generating Facilities**

(1)	Plant Name and Unit Number	Future Solar 7
(2)	Net Capability	
	A. Summer	74.5 MW-ac
	B. Winter	74.5 MW-ac
(3)	Technology Type	Single Axis Tracking PV Solar
(4)	Anticipated Construction Timing	
	A. Field Construction Start Date <sup>4</sup>	2029
	B. Commercial In-Service Date	December 2030
(5)	Fuel	
	A. Primary Fuel	Solar
	B. Alternate Fuel	N/A
(6)	Air Pollution Control Strategy	N/A
(7)	Cooling Method	N/A
(8)	Total Site Area	Undetermined
(9)	Construction Status	Proposed
(10)	Certification Status	Undetermined
(11)	Status with Federal Agencies	N/A
(12)	Projected Unit Performance Data	
	Planned Outage Factor (POF)	N/A
	Forced Outage Factor (FOF)	N/A
	Equivalent Availability Factor (EAF)	N/A
	Resulting Capacity Factor (2031)	26% (1st Full Yr Operation)
	Average Net Operating Heat Rate (In-Service Year ANOHR)	N/A
(13)	Projected Unit Financial Data	
	Book Life (Years)	35
	Total Installed Cost <sup>3</sup> (In-Service Year \$/kW)	1,369.45
	Direct Construction Cost (\$/kW)	1,312.28
	AFUDC <sup>2</sup> Amount (\$/kW)	57.18
	Escalation (\$/kW)	-
	Fixed O&M (In-Service Year \$/kW – Yr)	13.26
	Variable O&M (In-Service Year \$/MWh)	-
	K-Factor <sup>1</sup>	1.28

<sup>1</sup> w/o Land

<sup>2</sup> Based on the AFUDC rate of 5.89 % as of April 2022.

<sup>3</sup> Total installed cost includes transmission interconnection

<sup>4</sup> Construction schedule includes engineering design and permitting

**Schedule 9**  
**(Page 26 of 27)**  
**Status Report and Specifications of Proposed Generating Facilities**

(1)	Plant Name and Unit Number	Battery Storage 4
(2)	Net Capability	
	A. Summer	50 MW
	B. Winter	50 MW
(3)	Technology Type	Battery
(4)	Anticipated Construction Timing	
	A. Field Construction Start Date <sup>3</sup>	2030
	B. Commercial In-Service Date	January 2031
(5)	Fuel	
	A. Primary Fuel	N/A
	B. Alternate Fuel	N/A
(6)	Air Pollution Control Strategy	N/A
(7)	Cooling Method	N/A
(8)	Total Site Area	Undetermined
(9)	Construction Status	Proposed
(10)	Certification Status	Undetermined
(11)	Status with Federal Agencies	N/A
(12)	Projected Unit Performance Data	
	Planned Outage Factor (POF)	N/A
	Forced Outage Factor (FOF)	N/A
	Equivalent Availability Factor (EAF)	N/A
	Resulting Capacity Factor (2031)	N/A
	Average Net Operating Heat Rate (In-Service Year ANOHR)	N/A
(13)	Projected Unit Financial Data	
	Book Life (Years)	10
	Total Installed Cost <sup>2</sup> (In-Service Year \$/kW)	1,164.14
	Direct Construction Cost (\$/kW)	1,164.14
	AFUDC <sup>1</sup> Amount (\$/kW)	-
	Escalation (\$/kW)	-
	Fixed O&M (In-Service Year \$/kW – Yr)	24.85
	Variable O&M (In-Service Year \$/MWh)	-
	K-Factor	1.48

<sup>1</sup> Based on the AFUDC rate of 5.89 % as of April 2022.

<sup>2</sup> Total installed cost includes transmission interconnection

<sup>3</sup> Construction schedule includes engineering design and permitting

**Schedule 9**  
**(Page 27 of 27)**  
**Status Report and Specifications of Proposed Generating Facilities**

(1)	Plant Name and Unit Number	Future Solar 8
(2)	Net Capability	
	A. Summer	74.5 MW-ac
	B. Winter	74.5 MW-ac
(3)	Technology Type	Single Axis Tracking PV Solar
(4)	Anticipated Construction Timing	
	A. Field Construction Start Date <sup>4</sup>	2030
	B. Commercial In-Service Date	December 2031
(5)	Fuel	
	A. Primary Fuel	Solar
	B. Alternate Fuel	N/A
(6)	Air Pollution Control Strategy	N/A
(7)	Cooling Method	N/A
(8)	Total Site Area	Undetermined
(9)	Construction Status	Proposed
(10)	Certification Status	Undetermined
(11)	Status with Federal Agencies	N/A
(12)	Projected Unit Performance Data	
	Planned Outage Factor (POF)	N/A
	Forced Outage Factor (FOF)	N/A
	Equivalent Availability Factor (EAF)	N/A
	Resulting Capacity Factor (2028)	26%
	Average Net Operating Heat Rate (In-Service Year ANOHR)	N/A
(13)	Projected Unit Financial Data	
	Book Life (Years)	35
	Total Installed Cost <sup>3</sup> (In-Service Year \$/kW)	1,352.00
	Direct Construction Cost (\$/kW)	1,295.48
	AFUDC <sup>2</sup> Amount (\$/kW)	56.53
	Escalation (\$/kW)	-
	Fixed O&M (In-Service Year \$/kW – Yr)	13.56
	Variable O&M (In-Service Year \$/MWh)	-
	K-Factor <sup>1</sup>	1.29

<sup>1</sup> w/o Land

<sup>2</sup> Based on the AFUDC rate of 5.89 % as of April 2022.

<sup>3</sup> Total installed cost includes transmission interconnection

<sup>4</sup> Construction schedule includes engineering design and permitting

Schedule 10

Status Report and Specifications of Proposed Directly Associated Transmission Lines  
As of December 31, 2021

<u>Units</u>	<u>Point of Origin and Termination</u>	<u>Number of Circuits</u>	<u>Right-of-Way (ROW)</u>	<u>Circuit Length **</u>	<u>Voltage</u>	<u>Anticipated In-Service Date</u>	<u>Anticipated Capital Investment ***</u>	<u>Substations</u>	<u>Participation with Other Utilities</u>
Jamison Solar	Polk - Jamison - Pebbledale	1	No ROW required	1	230 kV	April 2022	Included in total installed cost on Schedule 9	Jamison Solar Station; Polk & Pebbledale Substations	None
Big Bend ST 1	Big Bend ST 1 does not require any new transmission lines ****	-	-	-	230 kV	December 2022	-	Big Bend	None
Bayside CC 1	Bayside CC 1 does not require any new transmission lines ****	-	-	-	230 kV	January 2023	-	Gannon	None
Alafia Solar	Polk - Alafia	1	New ROW required	2	230 kV	December 2023	Included in total installed cost on Schedule 9	Alafia Solar Station; Polk Substation	None
Bayside CC 2	Bayside CC 2 does not require any new transmission lines ****	-	-	-	230 kV	January 2024	-	Gannon	None

**Note:**

- \* Specific information related to "Unsitd" units unknown at this time.
- \*\* Approximate mileage listed is based on construction activity, not overall circuit length.
- \*\*\* Cumulative capital investment at the in-service date. Cost included in total installed cost on Schedule 9.
- \*\*\*\* Interconnection request studies pertaining to a Large Generating Facility have been completed and the unit does not require any new transmission lines.

THIS PAGE INTENTIONALLY LEFT BLANK

# Chapter VI



## ENVIRONMENTAL AND LAND USE INFORMATION

The H.L. Culbreath Bayside Power Station site is located in Hillsborough County on Port Sutton Road (See Figure VI-I), Polk Power Station site is located in southwest Polk County close to the Hillsborough and Hardee County lines (See Figure VI-II) and Big Bend Power Station is located in Hillsborough County on Big Bend Road (See Figure VI-III). The solar sites identified in Schedule 1 are spread across Hillsborough, Polk, and Pasco counties (See Figure VI-IV). Additional land use requirements and/or alternative site locations are currently under consideration to accommodate the addition of future solar PV generation facilities and distributed energy resources.





Figure VI-I: Site Location of H.L. Culbreth Bayside Power Station





Figure VI-II: Site Location of Polk Power Station






Figure VI-III: Site Location of Big Bend Power Station





Figure VI-IV: Site Location of Solar Power Stations

